



Summary

Guidance on Risk Analysis and Safety Implications of a Large Liquefied Natural Gas (LNG) Spill Over Water

Sandia National Laboratories

February 2005



Sandia is a multiprogram laboratory operated by Sandia Corporation, a Lockheed Martin Company, for the United States Department of Energy under contract DE-AC04-94AL85000.







Motivation and Scope of Sandia Study on LNG Spills Over Water

- 1. Detailed literature search.**
- 2. Review of four recent spill modeling studies.**
- 3. Evaluate accidental and intentional breaching of LNG cargo tanks.**
- 4. Assess extent of hazards from an LNG spill.**
- 5. Develop guidance on a risk-based approach**
 - to analyze and manage possible threats, hazards, and consequences
 - to reduce the overall risks of an LNG spill to levels that are protective of public safety and property.


Key Features Impacting Possible LNG Carrier Spills



Extent of Thermal Hazards Predicted in Four Recent LNG Carrier Spill Studies



Suggested Risk-based Assessment Approach for LNG Carrier Spills








Safety and Consequence Analyses

- **Evaluated several breaching events**
 - Collisions, groundings, impacts
 - Sabotage and possible attacks
- **Evaluated consequences from LNG spills**
 - Fire, vapor dispersion, explosions
- **Evaluated possibility of cascading damage**
 - Cryogenic damage from a spill
 - Thermal damage to structures and LNG vessel from a fire
- **Identified high, medium, and low consequence zones for range of possible spills**



Analysis of Accidental Breaching of Double Hull Tanker

- LNG tankers designs are robust
- Breaching conditions vary by site
- An LNG container breach can have various results
 - Spill onto water, spill between double hulls, etc.
- Analysis was based on large, 3- D, finite element model results





Analysis of Intentional Breaching of LNG Cargo Tanks

- **Assessed “credible threats”**
 - Plausible with knowledge and resources
 - Historically observed
- **Coordinated analysis with government agencies**
- **Analysis conducted using modern modeling tools**





Summary of Accidental and Intentional LNG Cargo Tank Breach Analyses

- **Accidental breach hole sizes of 0.5 – 1.5 m² possible**
 - No breach for collisions with small boats
 - Conditions for accidental breach unlikely at many sites
 - Current accident safety measures appropriate and effective
- **Intentional breach hole sizes of 2- 12 m² possible**
 - Nominal breach size ~5 m², smaller than used in many studies
 - Cryogenic damage to ship possible for large spills
- **Most events are expected to have an ignition source**



Nominal Conditions Used for Spill, Thermal, and Dispersion Analyses

- **Spill of 12,500 m³ per cargo tank**
- **Liquid height of 15 m above the breach**
- **Used nominal spill conditions**
 - Nominal wind and wind speed
 - General discharge and orifice flow parameters
 - Common data for burn rates, surface emissive power, etc.
- **Nominal sensitivity analysis of experimental data variation on hazard results**
- **Cascading damage hazards considered**



Thermal Damage and Consequence Considerations

- **Two thermal hazard evaluation criteria were considered**
 - 35 kW/m² (major structural damage in 10 minutes)
 - 5 kW/m² (2nd degree burns in 30 seconds, NFPA Standard for land-based LNG)
- **LNG Foam insulation degradation**
 - Some LNG insulation materials (foams) degrade and decompose around 600-800°F
 - Without safety systems operating, top-side insulation decomposition on the order of 5 minutes during a fire
- **Fires longer than 5 minutes assessed and sequential, cascading cargo tank failures evaluated**



Thermal Hazard Analysis Results for Accidental LNG Breaches and Spills

HOLE SIZE (m ²)	NUMBER OF HOLES	DISCHARGE COEFFICIENT	BURN RATE (m/s)	SURFACE EMISSIVE POWER (kW/m ²)	POOL DIAMETER (m)	BURN TIME (min)	DISTANCE TO 37.5 kW/m ² (m)	DISTANCE TO 5 kW/m ² (m)
1	1	.6	3X10 ⁻⁴	220	148	40	177	554
2	1	.6	3X10 ⁻⁴	220	209	20	250	784
2	3	.6	3X10 ⁻⁴	220	362	20	398	1358

Uses nominal input parameters from existing data
Simultaneous, multiple tank damage highly unlikely



Estimated Impacts to Public Health and Safety from Accidental Spills

EVENT	POTENTIAL SHIP DAMAGE AND SPILL	POTENTIAL HAZARD	POTENTIAL IMPACT ON PUBLIC SAFETY ^a		
			~250 m	~250 – 750 m	>750 m
Collisions: Low speed	Minor ship damage, no breach	Minor ship damage	Low	Very Low	Very Low
Collisions: High Speed	LNG cargo tank breach from 0.5 to 1.5 m ² spill area	<ul style="list-style-type: none"> ▪ Small fire ▪ Damage to ship ▪ Vapor Cloud 	High Med High	Med Low High - Med	Low Very Low Med - Low
Grounding: <3 m high object	Minor ship damage, no breach	Minor ship damage	Low	Very Low	Very Low

Very low – little or no property damage or injuries
Low – minor property damage and minor injuries
Medium – potential for injuries and property damage
High – major injuries and significant damage to property



Thermal Hazard Analysis Results for Intentional LNG Breaches and Spills

HOLE SIZE (m ²)	NUMBER OF HOLES	DISCHARGE COEFFICIENT	BURN RATE (m/s)	SURFACE EMISSIVE POWER (kW/m ²)	POOL DIAMETER (m)	BURN TIME (min)	DISTANCE TO 37.5 kW/m ² (m)	DISTANCE TO 5 kW/m ² (m)
2	3	.6	3 x 10 ⁻⁴	220	209	20	250	784
5	3	.6	3 x 10 ⁻⁴	220	572	8.1	630	2118
5*	1	.6	3 x 10 ⁻⁴	220	330	8.1	391	1305
5	1	.9	3 x 10 ⁻⁴	220	405	5.4	478	1579
5	1	.6	2 x 10 ⁻⁴	220	395	8.1	454	1538
5	1	.6	3 x 10 ⁻⁴	350	330	8.1	529	1652
12	1	.6	3 x 10 ⁻⁴	220	512	3.4	602	1920

*Nominal case: Expected outcomes of a potential breach and thermal hazards based on credible threats and best available experimental data
 Limited sensitivity analysis




Estimated Impacts to Public Health and Safety from Intentional Spills

EVENT	POTENTIAL SHIP DAMAGE AND SPILL	POTENTIAL HAZARD	POTENTIAL IMPACT ON PUBLIC SAFETY ^a		
			~500 m	~500 – 1600 m	>1600 m
Insider Threat or Hijacking	Intentional, 2-7 m ² breach and medium to large spill	<ul style="list-style-type: none"> ▪ Large fire ▪ Damage to ship ▪ Fireball 	High	Med	Low
	Intentional, large release of LNG	<ul style="list-style-type: none"> ▪ Large fire ▪ Damage to ship ▪ Vapor cloud fire 	High	Med	Low
Attack on Ship	Intentional, 2-12 m ² breach and medium to large spill	<ul style="list-style-type: none"> ▪ Large fire ▪ Damage to ship ▪ Fireball 	High	Med	Low
			High	Med	Low
			Med	Low	Very Low

Very low – little or no property damage or injuries
Low – minor property damage and minor injuries
Medium – potential for injuries and property damage
High – major injuries and significant damage to property

Suggested Risk-based Assessment Approach for LNG Carrier Spills





LNG Spill Risk Management Analysis

Risks can be responsibly managed through a combination of approaches:

- **Improve risk prevention measures**
 - **Earlier ship interdiction, boardings, and searches; positive vessel control during transit; port traffic control measures; safety and security zones and surveillance; or operational changes**
- **Locate LNG terminals where risks to public safety, infrastructures, and energy security are minimized**
- **Improve LNG safety and security systems**
- **Improve emergency response, evacuation, and mitigation strategies**



LNG Spill Safety and Risk Analysis Conclusions

- **While limitations exist in data and modeling capabilities for LNG spills over water, current tools, when as identified in the guidance, can be used to identify and mitigate hazards and safely protect the public. As better models and additional data become available they can be incorporated into the guidance.**
- **Consequences from accidental spills using current safety and security practices are generally low.**
- **Consequences an intentional breach can be more severe than from accidents. The most significant impacts to the public exist within about 500 m of a spill, with much lower effects at distances beyond 1600 m, even for very large spills.**
- **Risk-based approaches should be used in cooperation with stakeholders to help reduce hazards and risks to public safety and property to levels compatible with site-specific protection goals.**



LNG Spill Analysis and Risk Management Guidance

Zone 1 (High hazard areas)

- Use appropriate and validated analytical models as necessary, especially where interaction with critical infrastructures, terrain, etc. is possible
- Risk prevention and mitigation and emergency response strategies are very important and should be closely coordinated

Zone 2 (Intermediate hazard areas)

- Similar to Zone 1 but less rigorous modeling and risk management operations and strategies required

Zone 3 (Low hazard areas)

- Use of simpler models generally appropriate and nominal risk management operations needed



Report Guidance to Help Evaluate Site-specific LNG Import Issues

Report provides guidance on safely siting LNG terminals by identifying and discussing various elements:

- **Consideration of site-specific elements**
 - location, closeness to critical infrastructures or residential or commercial areas, and available resources
- **Assessing potential threats and concerns**
- **Cooperating with stakeholders, public safety, and public officials to identify site “protection goals”**
- **Modeling and analysis approaches most appropriate for a given site, location, or operations**
- **Assessing system safeguards and protective measures**
- **Responsibly managing risks by cooperative prevention and mitigation approaches to ensure a safe and reliable energy supply while being protective of public safety and property**