

**Environmental Protection Agency**

**§ 425.64**

with 40 CFR part 403, and achieve the following pretreatment standards:

| Pollutant or pollutant property | PSES                        |                             |
|---------------------------------|-----------------------------|-----------------------------|
|                                 | Maximum for any 1 day       | Maximum for monthly average |
|                                 | Milligrams per liter (mg/l) |                             |
| Total chromium .....            | 19                          | 12                          |
| pH .....                        | ( <sup>1</sup> )            | ( <sup>1</sup> )            |

<sup>1</sup> Within the range 6.0 to 10.0.

**§ 425.56 Pretreatment standards for new sources (PSNS).**

Except as provided in 40 CFR 403.7, any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403, and achieve the pretreatment standards contained in § 425.55.

**Subpart F—Through-the-Blue Subcategory**

**§ 425.60 Applicability; description of the through-the-blue subcategory.**

The provisions of this subpart are applicable to process wastewater discharges resulting from any tannery which processes raw or cured cattle or cattle-like hides through the blue tanned state by hair pulp unhairing and chrome tanning; no retan-wet finishing is performed.

**§ 425.61 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

| Pollutant or pollutant property | BPT limitations                                    |                             |
|---------------------------------|--|-----------------------------|
|                                 | Maximum for any 1 day                              | Maximum for monthly average |
|                                 | kg/kg (or pounds per 1,000 pounds) of raw material |                             |
| BOD <sub>5</sub> .....          | 3.2  | 1.5                         |
| TSS .....                       | 4.7  | 2.1                         |
| Oil & Grease .....              | 1.4  | 0.61                        |
| Total Chromium .....            | 0.08   | 0.03                        |
| pH .....                        | ( <sup>1</sup> )                                   | ( <sup>1</sup> )            |

<sup>1</sup> Within the range of 6.0 to 9.0.

[47 FR 52870, Nov. 23, 1982, as amended at 53 FR 9183, Mar. 21, 1988]

**§ 425.62 Effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The effluent limitations are those for BOD<sub>5</sub>, TSS, Oil and Grease, and pH contained in § 425.61.

**§ 425.63 Effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT): The effluent limitations are those for Total Chromium contained in § 425.61.

**§ 425.64 New source performance standards (NSPS).**

Any new source subject to this subpart must achieve the following new source performance standards (NSPS):