

TABLE 6-1a (METRIC). COSTS OF ESP REPLACEMENT TO CONTROL PM TO 0.10 G/DSCM FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate-- ESP exit, m <sup>3</sup> /sec @8% O <sub>2</sub>	ESP plate area, m <sup>2</sup>	New SCA, m <sup>2</sup> /(m <sup>3</sup> /sec)	Downtime, d	TCI, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1a/4a	BI	NDCE	700,000	380	93.4	9,806	105	30	\$4,120,000	\$19,400	\$165,000	\$482,000	\$666,000
RF-2a/5a	BI	NDCE	1,200,000	680	168	17,638	105	30	\$7,430,000	\$35,000	\$297,000	\$869,000	\$1,200,000
RF-3a/6a	BI	NDCE	1,800,000	1,000	243	25,512	105	30	\$10,700,000	\$50,500	\$428,000	\$1,250,000	\$1,730,000
RF-7a	BI	DCE	400,000	230	56.2	4,794	85	30	\$2,010,000	\$11,700	\$80,400	\$286,000	\$378,000
RF-8a	BI	DCE	700,000	380	93.4	7,967	85	30	\$3,350,000	\$19,400	\$134,000	\$477,000	\$630,000
RF-9a	BI	DCE	1,200,000	680	168	14,331	85	30	\$6,030,000	\$35,000	\$241,000	\$859,000	\$1,140,000
RF-1a/4a	Unbl	NDCE	700,000	450	93.4	9,806	105	30	\$4,120,000	\$19,400	\$165,000	\$482,000	\$666,000
RF-2a/5a	Unbl	NDCE	1,200,000	820	168	17,638	105	30	\$7,430,000	\$35,000	\$297,000	\$869,000	\$1,200,000
RF-3a/6a	Unbl	NDCE	1,800,000	1,200	243	25,512	105	30	\$10,700,000	\$50,500	\$428,000	\$1,250,000	\$1,730,000
RF-7a	Unbl	DCE	400,000	270	56.2	4,794	85	30	\$2,010,000	\$11,700	\$80,400	\$286,000	\$378,000
RF-8a	Unbl	DCE	700,000	450	93.4	7,967	85	30	\$3,350,000	\$19,400	\$134,000	\$477,000	\$630,000
RF-9a	Unbl	DCE	1,200,000	820	168	14,331	85	30	\$6,030,000	\$35,000	\$241,000	\$859,000	\$1,140,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-1b. Refer to Table 6-1b for footnotes, which include calculations.

TABLE 6-1b (ENGLISH). COSTS OF ESP REPLACEMENT TO CONTROL PM TO 0.044 GR/DSCF FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP exit, acfm @8% O <sub>2</sub>	ESP plate area, ft <sup>2</sup> (b)	New SCA, ft <sup>2</sup> /1,000 acfm	Downtime, d	TCI, \$ (c)	Electricity, \$/yr (d)	A, I & T, \$/yr (e)	Capital recovery, \$/yr (f)	ITAC, \$/yr (g)
RF-1a/4a	Bl	NDCE	1,500,000	420	198,000	105,600	533	30	\$4,120,000	\$19,400	\$165,000	\$482,000	\$666,000
RF-2a/5a	Bl	NDCE	2,700,000	750	357,000	190,400	533	30	\$7,430,000	\$35,000	\$297,000	\$869,000	\$1,200,000
RF-3a/6a	Bl	NDCE	3,900,000	1,100	515,000	274,667	533	30	\$10,700,000	\$50,500	\$428,000	\$1,250,000	\$1,730,000
RF-7a	Bl	DCE	900,000	250	119,000	51,567	433	30	\$2,010,000	\$11,700	\$80,400	\$286,000	\$378,000
RF-8a	Bl	DCE	1,500,000	420	198,000	85,800	433	30	\$3,350,000	\$19,400	\$134,000	\$477,000	\$630,000
RF-9a	Bl	DCE	2,700,000	750	357,000	154,700	433	30	\$6,030,000	\$35,000	\$241,000	\$859,000	\$1,140,000
RF-1a/4a	Unbl	NDCE	1,500,000	500	198,000	105,600	533	30	\$4,120,000	\$19,400	\$165,000	\$482,000	\$666,000
RF-2a/5a	Unbl	NDCE	2,700,000	900	357,000	190,400	533	30	\$7,430,000	\$35,000	\$297,000	\$869,000	\$1,200,000
RF-3a/6a	Unbl	NDCE	3,900,000	1,300	515,000	274,667	533	30	\$10,700,000	\$50,500	\$428,000	\$1,250,000	\$1,730,000
RF-7a	Unbl	DCE	900,000	300	119,000	51,567	433	30	\$2,010,000	\$11,700	\$80,400	\$286,000	\$378,000
RF-8a	Unbl	DCE	1,500,000	500	198,000	85,800	433	30	\$3,350,000	\$19,400	\$134,000	\$477,000	\$630,000
RF-9a	Unbl	DCE	2,700,000	900	357,000	154,700	433	30	\$6,030,000	\$35,000	\$241,000	\$859,000	\$1,140,000

(a) All costs in \$1991

(b) ESP plate area = model gas flowrate x new SCA

(c) TCI = ESP plate area x (\$39/ft<sup>2</sup> plate area)

(d) For NDCE furnaces, electricity = 0.00194 x model gas flowrate x (533 - 433 ft<sup>2</sup>/1,000 acfm x 8,424 hr/yr x \$0.06/kWh

For DCE furnaces, electricity = 0.00194 x model gas flowrate x (433 - 333 ft<sup>2</sup>/1,000 acfm x 8,424 hr/yr x \$0.06/kWh

(e) Administrative, insurance, and taxes (A, I & T) = 0.04 x TCI

(f) For NDCE furnaces, capital recovery = 0.1169 CRF x TCI (based on 13.5-yr ESP life and 7% interest)

For DCE furnaces, capital recovery = 0.1424 CRF x TCI (based on 10-yr ESP life and 7% interest)

(g) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-2a (METRIC). COSTS OF ESP REPLACEMENT TO CONTROL PM TO 0.10 G/DSCM FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate--ESP exit, m3/sec @8% O2	ESP plate area, m2	New SCA, m2/(m3/sec)	Downtime, d	TCI, \$	Pulp production losses, \$	TCI+ production losses, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1a/4a	Bl	NDCE	700,000	380	93.4	9,806	105	30	\$4,120,000	\$1,190,000	\$5,310,000	\$19,400	\$165,000	\$621,000	\$905,000
RF-2a/5a	Bl	NDCE	1,200,000	680	168	17,638	105	30	\$7,430,000	\$2,130,000	\$9,560,000	\$35,000	\$297,000	\$1,120,000	\$1,450,000
RF-3a/6a	Bl	NDCE	1,800,000	1,000	243	25,512	105	30	\$10,700,000	\$3,120,000	\$13,800,000	\$50,500	\$428,000	\$1,610,000	\$2,090,000
RF-7a	Bl	DCE	400,000	230	56.2	4,794	85	30	\$2,010,000	\$844,000	\$4,960,000	\$19,400	\$165,000	\$580,000	\$764,000
RF-8a	Bl	DCE	700,000	380	93.4	7,967	85	30	\$3,350,000	\$1,520,000	\$8,950,000	\$35,000	\$297,000	\$1,050,000	\$1,380,000
RF-9a	Bl	DCE	1,200,000	680	168	14,331	85	30	\$6,030,000	\$2,190,000	\$12,900,000	\$50,500	\$428,000	\$1,510,000	\$1,990,000
RF-1a/4a	Unbl	NDCE	700,000	450	93.4	9,806	105	30	\$4,120,000	\$844,000	\$4,960,000	\$19,400	\$165,000	\$580,000	\$764,000
RF-2a/5a	Unbl	NDCE	1,200,000	820	168	17,638	105	30	\$7,430,000	\$1,520,000	\$8,950,000	\$35,000	\$297,000	\$1,050,000	\$1,380,000
RF-3a/6a	Unbl	NDCE	1,800,000	1,200	243	25,512	105	30	\$10,700,000	\$2,190,000	\$12,900,000	\$50,500	\$428,000	\$1,510,000	\$1,990,000
RF-7a	Unbl	DCE	400,000	270	56.2	4,794	85	30	\$2,010,000	\$506,000	\$2,520,000	\$11,700	\$80,400	\$359,000	\$451,000
RF-8a	Unbl	DCE	700,000	450	93.4	7,967	85	30	\$3,350,000	\$844,000	\$4,190,000	\$19,400	\$134,000	\$597,000	\$750,000
RF-9a	Unbl	DCE	1,200,000	820	168	14,331	85	30	\$6,030,000	\$1,520,000	\$7,550,000	\$35,000	\$241,000	\$1,080,000	\$1,360,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-2b. Refer to Table 6-2b for footnotes, which include calculations.

TABLE 6-2b (ENGLISH). COSTS OF ESP REPLACEMENT TO CONTROL PM TO 0.044 GR/DSCF FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP ext, acfm @8% O <sub>2</sub>	ESP plate area, ft <sup>2</sup> (b)	New SCA, ft <sup>2</sup> /1,000 acfm	Downtime, d	TCI, \$ (c)	Pulp production losses, \$ (d)	TCI + production losses, \$	Electricity, \$/yr (e)	A, I & T, \$/yr (f)	Capital recovery, \$/yr (g)	ITAC, \$/yr (h)
RF-1a/4a	BI	NDCE	1,500,000	420	198,000	105,600	533	30	\$4,120,000	\$1,190,000	\$5,310,000	\$19,400	\$165,000	\$621,000	\$805,000
RF-2a/5a	BI	NDCE	2,700,000	750	357,000	190,400	533	30	\$7,430,000	\$2,130,000	\$9,560,000	\$35,000	\$297,000	\$1,120,000	\$1,450,000
RF-3a/6a	BI	NDCE	3,900,000	1,100	515,000	274,667	533	30	\$10,700,000	\$3,120,000	\$13,800,000	\$50,500	\$428,000	\$1,610,000	\$2,090,000
RF-7a	BI	DCE	900,000	250	119,000	51,567	433	30	\$2,010,000	\$710,000	\$2,720,000	\$11,700	\$80,400	\$387,000	\$479,000
RF-8a	BI	DCE	1,500,000	420	198,000	85,800	433	30	\$3,350,000	\$1,190,000	\$4,540,000	\$19,400	\$134,000	\$646,000	\$799,000
RF-9a	BI	DCE	2,700,000	750	357,000	154,700	433	30	\$6,030,000	\$2,130,000	\$8,160,000	\$35,000	\$241,000	\$1,160,000	\$1,440,000
RF-1a/4a	Unbl	NDCE	1,500,000	500	198,000	105,600	533	30	\$4,120,000	\$844,000	\$4,960,000	\$19,400	\$165,000	\$580,000	\$784,000
RF-2a/5a	Unbl	NDCE	2,700,000	900	357,000	190,400	533	30	\$7,430,000	\$1,520,000	\$8,950,000	\$35,000	\$297,000	\$1,050,000	\$1,380,000
RF-3a/6a	Unbl	NDCE	3,900,000	1,300	515,000	274,667	533	30	\$10,700,000	\$2,190,000	\$12,900,000	\$50,500	\$428,000	\$1,510,000	\$1,990,000
RF-7a	Unbl	DCE	900,000	300	119,000	51,567	433	30	\$2,010,000	\$505,000	\$2,520,000	\$11,700	\$80,400	\$359,000	\$451,000
RF-8a	Unbl	DCE	1,500,000	500	198,000	85,800	433	30	\$3,350,000	\$844,000	\$4,190,000	\$19,400	\$134,000	\$597,000	\$750,000
RF-9a	Unbl	DCE	2,700,000	900	357,000	154,700	433	30	\$6,030,000	\$1,520,000	\$7,550,000	\$35,000	\$241,000	\$1,080,000	\$1,360,000

(a) All costs in \$1991

(b) ESP plate area = model gas flowrate x new SCA

(c) TCI = ESP plate area x (\$39/ft<sup>2</sup> plate area)

(d) Pulp production losses = (25% gross profit margin) x (\$646/ton bleached pulp or \$384/ton unbleached pulp) x (136.2 \$1991/124 \$1989) x (30 d downtime-14 d scheduled downtime) x ADTP/d

(e) For NDCE furnaces, electricity = 0.00194 x model gas flowrate x (533 - 433 ft<sup>2</sup>)/1,000 acfm x 8,424 hr/yr x \$0.06/kWh

(f) For DCE furnaces, electricity = 0.00194 x model gas flowrate x (433 - 333 ft<sup>2</sup>)/1,000 acfm x 8,424 hr/yr x \$0.06/kWh

(g) Administrative, insurance, and taxes (A, I, & T) = 0.04 x TCI

(h) For NDCE furnaces, capital recovery = 0.1169 CRF x (TCI + production losses) (based on 13.5-yr ESP life and 7% interest)

For DCE furnaces, capital recovery = 0.1424 CRF x (TCI + production losses) (based on 10-yr ESP life and 7% interest)

(i) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-3. SUMMARY OF ASSUMPTIONS USED IN ESP UPGRADE COSTS<sup>9</sup>

NDCE Recovery Furnace ESP Characteristics:	
<p>Existing ESP:</p> <ul style="list-style-type: none"> <li>● The existing ESP is assumed to contain 46 lanes on 10-inch centers (weighted wire design).</li> <li>● The existing ESP is 3 fields long, with each field 10 feet long and 30 feet tall.</li> <li>● The existing ESP has a parallel drag scraper arrangement (dry-bottom).</li> </ul>	<p>New ESP:</p> <ul style="list-style-type: none"> <li>● The ESP is rebuilt with 42 lanes on 11-inch centers (rigid electrode design).</li> <li>● The size will be adequate for 99.4 percent PM removal, yielding an outlet PM residual of 0.044 gr/dscf at 8 percent oxygen.</li> <li>● The ESP will be 3 fields long, with each field 10 feet long and 30 feet high.</li> </ul>
DCE Recovery Furnace ESP Characteristics:	
<p>Existing ESP:</p> <ul style="list-style-type: none"> <li>● The existing ESP is assumed to contain 50 lanes on 10-inch centers (weighted wire design).</li> <li>● The existing ESP is 3 fields long, with each field 10 feet long and 30 feet tall.</li> <li>● The existing ESP has a steel shell design (wet-bottom).</li> </ul>	<p>New ESP:</p> <ul style="list-style-type: none"> <li>● The ESP is rebuilt with 46 lanes on 11-inch centers (rigid electrode design).</li> <li>● The size will be adequate for 98.8 percent PM removal, yielding an outlet PM residual of 0.044 gr/dscf at 8 percent oxygen.</li> <li>● The ESP will be 3 fields long, with each field 10 feet long and 32 feet high.</li> </ul>
<p><u>Modifications:</u></p> <ul style="list-style-type: none"> <li>● There is single-chamber operation while the other chamber is washed down, the roof removed, and the internals gutted.</li> <li>● The recovery furnace is taken off line; work continues on rebuild; one chamber is finished.</li> <li>● The recovery furnace is at partial load through rebuilt chamber; the other chamber is finished.</li> </ul> <p><u>Other Assumptions:</u></p> <ul style="list-style-type: none"> <li>● The existing casing is in acceptable condition; only minor replating is needed.</li> <li>● Wet- and dry-bottoms are reused "as is," except for minor repairs. Transformers, controls, and inlet and outlet ductwork are also reused.</li> <li>● The roof insulation is replaced, but all other insulation is acceptable.</li> <li>● The site location is in the southeast United States. As such, all field labor is based on merit shop, 1993 wage rates and work rules.</li> <li>● No removal of asbestos or polychlorinated biphenyls (PCB's) is required.</li> <li>● The scrap is taken to a site within the plant gates.</li> <li>● There are no perforated plates.</li> <li>● The ductwork and stack do not obstruct crane mobility.</li> <li>● The ESP is at grade.</li> <li>● There is no low voltage.</li> </ul>	

TABLE 6-4a (METRIC). COSTS OF SCHEDULE 1 ESP UPGRADE TO CONTROL PM TO 0.10 G/DSCM FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate-- ESP exit, m3/sec @ 8% O2	Downtime, d	TCI, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1a/4a	Bl	NDCE	700,000	380	93.4	17	\$1,200,000	\$19,400	\$48,000	\$140,000	\$207,000
RF-2a/5a	Bl	NDCE	1,200,000	680	168	17	\$1,700,000	\$35,000	\$68,000	\$199,000	\$302,000
RF-3a/6a	Bl	NDCE	1,800,000	1,000	243	17	\$2,120,000	\$50,500	\$84,800	\$248,000	\$383,000
RF-7a	Bl	DCE	400,000	230	56.2	17	\$811,000	\$11,700	\$32,400	\$115,000	\$159,000
RF-8a	Bl	DCE	700,000	380	93.4	17	\$1,100,000	\$19,400	\$44,000	\$157,000	\$220,000
RF-9a	Bl	DCE	1,200,000	680	168	17	\$1,570,000	\$35,000	\$62,800	\$224,000	\$322,000
RF-1a/4a	Unbl	NDCE	700,000	450	93.4	17	\$1,200,000	\$19,400	\$48,000	\$140,000	\$207,000
RF-2a/5a	Unbl	NDCE	1,200,000	820	168	17	\$1,700,000	\$35,000	\$68,000	\$199,000	\$302,000
RF-3a/6a	Unbl	NDCE	1,800,000	1,200	243	17	\$2,120,000	\$50,500	\$84,800	\$248,000	\$383,000
RF-7a	Unbl	DCE	400,000	270	56.2	17	\$811,000	\$11,700	\$32,400	\$115,000	\$159,000
RF-8a	Unbl	DCE	700,000	450	93.4	17	\$1,100,000	\$19,400	\$44,000	\$157,000	\$220,000
RF-9a	Unbl	DCE	1,200,000	820	168	17	\$1,570,000	\$35,000	\$62,800	\$224,000	\$322,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-4b. Refer to Table 6-4b for footnotes, which include calculations.

TABLE 6-4b (ENGLISH). COSTS OF SCHEDULE 1 ESP UPGRADE TO CONTROL PM TO 0.044 GR/DSCF FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES) a

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP exit, acfm @ 8% O2	Downtime, d	TCI, \$ (b)	Electricity, \$/yr (c)	A, I & T, \$/yr (d)	Capital recovery, \$/yr (e)	ITAC, \$/yr (f)
RF-1a/4a	BI	NDCE	1,500,000	420	198,000	17	\$1,200,000	\$19,400	\$48,000	\$140,000	\$207,000
RF-2a/5a	BI	NDCE	2,700,000	750	357,000	17	\$1,700,000	\$35,000	\$68,000	\$199,000	\$302,000
RF-3a/6a	BI	NDCE	3,900,000	1,100	515,000	17	\$2,120,000	\$50,500	\$84,800	\$248,000	\$383,000
RF-7a	BI	DCE	900,000	250	119,000	17	\$811,000	\$11,700	\$32,400	\$115,000	\$159,000
RF-8a	BI	DCE	1,500,000	420	198,000	17	\$1,100,000	\$19,400	\$44,000	\$157,000	\$220,000
RF-9a	BI	DCE	2,700,000	750	357,000	17	\$1,570,000	\$35,000	\$62,800	\$224,000	\$322,000
RF-1a/4a	Unbl	NDCE	1,500,000	500	198,000	17	\$1,200,000	\$19,400	\$48,000	\$140,000	\$207,000
RF-2a/5a	Unbl	NDCE	2,700,000	900	357,000	17	\$1,700,000	\$35,000	\$68,000	\$199,000	\$302,000
RF-3a/6a	Unbl	NDCE	3,900,000	1,300	515,000	17	\$2,120,000	\$50,500	\$84,800	\$248,000	\$383,000
RF-7a	Unbl	DCE	900,000	300	119,000	17	\$811,000	\$11,700	\$32,400	\$115,000	\$159,000
RF-8a	Unbl	DCE	1,500,000	500	198,000	17	\$1,100,000	\$19,400	\$44,000	\$157,000	\$220,000
RF-9a	Unbl	DCE	2,700,000	900	357,000	17	\$1,570,000	\$35,000	\$62,800	\$224,000	\$322,000

(a) All costs in \$1991

(b) For NDCE furnaces, TCI =  $(\$1,292,000)/[(230,000 \text{ acfm}/\text{model gas flowrate})^{0.6}] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$   
 For DCE furnaces, TCI =  $(\$1,504,750)/[(340,000 \text{ acfm}/\text{model gas flowrate})^{0.6}] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

(c) Electricity costs for ESP upgrade assumed to equal electricity costs for ESP replacement.  
 For NDCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (533 - 433 \text{ ft}^2)/1,000 \text{ acfm} \times 8.424 \text{ hr/yr} \times \$0.06/\text{kWh}$   
 For DCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (433 - 333 \text{ ft}^2)/1,000 \text{ acfm} \times 8.424 \text{ hr/yr} \times \$0.06/\text{kWh}$

(d) Administrative, insurance, and taxes (A, I & T) =  $0.04 \times \text{TCI}$

(e) For NDCE furnaces, capital recovery =  $0.1169 \text{ CRF} \times \text{TCI}$  (based on 13.5-yr ESP life and 7% interest)  
 For DCE furnaces, capital recovery =  $0.1424 \text{ CRF} \times \text{TCI}$  (based on 10-yr ESP life and 7% interest)

(f) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-5a (METRIC). COSTS OF SCHEDULE 2 ESP UPGRADE TO CONTROL PM TO 0.10 G/DSCM FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate-- ESP exit, m3/sec @ 8% O2	Downtime, d	TCI, \$ (b)	Electricity, \$/yr (c)	A, I & T, \$/yr (d)	Capital recovery, \$/yr (e)	ITAC, \$/yr (f)
RF-1a/4a	BI	NDCE	700,000	380	93.4	30	\$1,160,000	\$19,400	\$46,400	\$136,000	\$202,000
RF-2a/5a	BI	NDCE	1,200,000	680	168	30	\$1,660,000	\$35,000	\$66,400	\$194,000	\$295,000
RF-3a/6a	BI	NDCE	1,800,000	1,000	243	30	\$2,070,000	\$50,500	\$82,800	\$242,000	\$375,000
RF-7a	BI	DCE	400,000	230	56.2	30	\$791,000	\$11,700	\$31,600	\$113,000	\$156,000
RF-8a	BI	DCE	700,000	380	93.4	30	\$1,070,000	\$19,400	\$42,800	\$152,000	\$214,000
RF-9a	BI	DCE	1,200,000	680	168	30	\$1,530,000	\$35,000	\$61,200	\$218,000	\$314,000
RF-1a/4a	Unbl	ESP	700,000	450	93.4	30	\$1,160,000	\$19,400	\$46,400	\$136,000	\$202,000
RF-2a/5a	Unbl	ESP	1,200,000	820	168	30	\$1,660,000	\$35,000	\$66,400	\$194,000	\$295,000
RF-3a/6a	Unbl	ESP	1,800,000	1,200	243	30	\$2,070,000	\$50,500	\$82,800	\$242,000	\$375,000
RF-7a	Unbl	DCE	400,000	270	56.2	30	\$791,000	\$11,700	\$31,600	\$113,000	\$156,000
RF-8a	Unbl	DCE	700,000	450	93.4	30	\$1,070,000	\$19,400	\$42,800	\$152,000	\$214,000
RF-9a	Unbl	DCE	1,200,000	820	168	30	\$1,530,000	\$35,000	\$61,200	\$218,000	\$314,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-5b. Refer to Table 6-5b for footnotes, which include calculations.



TABLE 6-5b (ENGLISH). COSTS OF SCHEDULE 2 ESP UPGRADE TO CONTROL PM TO 0.044 GR/DSCF FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES) a

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP exit, acfm @ 8% O2	Downtime, d	TCI, \$ (b)	Electricity, \$/yr (c)	A, I & T, \$/yr (d)	Capital recovery, \$/yr (e)	ITAC, \$/yr (f)
RF-1a/4a	Bl	NDCE	1,500,000	420	198,000	30	\$1,160,000	\$19,400	\$46,400	\$136,000	\$202,000
RF-2a/5a	Bl	NDCE	2,700,000	750	357,000	30	\$1,660,000	\$35,000	\$66,400	\$194,000	\$295,000
RF-3a/6a	Bl	NDCE	3,900,000	1,100	515,000	30	\$2,070,000	\$50,500	\$82,800	\$242,000	\$375,000
RF-7a	Bl	DCE	900,000	250	119,000	30	\$791,000	\$11,700	\$31,600	\$113,000	\$156,000
RF-8a	Bl	DCE	1,500,000	420	198,000	30	\$1,070,000	\$19,400	\$42,800	\$152,000	\$214,000
RF-9a	Bl	DCE	2,700,000	750	357,000	30	\$1,530,000	\$35,000	\$61,200	\$218,000	\$314,000
RF-1a/4a	Unbl	NDCE	1,500,000	500	198,000	30	\$1,160,000	\$19,400	\$46,400	\$136,000	\$202,000
RF-2a/5a	Unbl	NDCE	2,700,000	900	357,000	30	\$1,660,000	\$35,000	\$66,400	\$194,000	\$295,000
RF-3a/6a	Unbl	NDCE	3,900,000	1,300	515,000	30	\$2,070,000	\$50,500	\$82,800	\$242,000	\$375,000
RF-7a	Unbl	DCE	900,000	300	119,000	30	\$791,000	\$11,700	\$31,600	\$113,000	\$156,000
RF-8a	Unbl	DCE	1,500,000	500	198,000	30	\$1,070,000	\$19,400	\$42,800	\$152,000	\$214,000
RF-9a	Unbl	DCE	2,700,000	900	357,000	30	\$1,530,000	\$35,000	\$61,200	\$218,000	\$314,000

(a) All costs in \$1991

(b) For NDCE furnaces, TCI =  $(\$1,259,000)/[(230,000 \text{ acfm}/\text{model gas flowrate}) \wedge 0.6] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

For DCE furnaces, TCI =  $(\$1,466,500)/[(340,000 \text{ acfm}/\text{model gas flowrate}) \wedge 0.6] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

(c) Electricity costs for ESP upgrade assumed to equal electricity costs for ESP replacement.

For NDCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (533 - 433 \text{ ft}^2)/1,000 \text{ acfm} \times 8,424 \text{ hr/yr} \times \$0.06/\text{kWh}$

For DCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (433 - 333 \text{ ft}^2)/1,000 \text{ acfm} \times 8,424 \text{ hr/yr} \times \$0.06/\text{kWh}$

(d) Administrative, insurance, and taxes (A, I & T) =  $0.04 \times \text{TCI}$

(e) For NDCE furnaces, capital recovery =  $0.1169 \text{ CRF} \times \text{TCI}$  (based on 13.5-yr ESP life and 7% interest)

For DCE furnaces, capital recovery =  $0.1424 \text{ CRF} \times \text{TCI}$  (based on 10-yr ESP life and 7% interest)

(f) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-6a (METRIC). COSTS OF SCHEDULE 1 ESP UPGRADE TO CONTROL PM TO 0.10 G/DSCM FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate-- ESP exit, m3/sec @8% O2	Downtime, d	TCI, \$	Pulp production losses, \$	TCI+ production losses, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1a/4a	BI	NDCE	700,000	380	93.4	17	\$1,200,000	\$224,000	\$1,420,000	\$19,400	\$48,000	\$166,000	\$233,000
RF-2a/5a	BI	NDCE	1,200,000	680	168	17	\$1,700,000	\$399,000	\$2,100,000	\$35,000	\$68,000	\$245,000	\$348,000
RF-3a/6a	BI	NDCE	1,800,000	1,000	243	17	\$2,120,000	\$585,000	\$2,710,000	\$50,500	\$84,800	\$317,000	\$452,000
RF-7a	BI	DCE	400,000	230	56.2	17	\$811,000	\$133,000	\$944,000	\$11,700	\$32,400	\$134,000	\$178,000
RF-8a	BI	DCE	700,000	380	93.4	17	\$1,100,000	\$224,000	\$1,320,000	\$19,400	\$44,000	\$188,000	\$251,000
RF-9a	BI	DCE	1,200,000	680	168	17	\$1,570,000	\$399,000	\$1,970,000	\$35,000	\$62,800	\$281,000	\$379,000
RF-1a/4a	Unbl	NDCE	700,000	450	93.4	17	\$1,200,000	\$158,000	\$1,360,000	\$19,400	\$48,000	\$159,000	\$226,000
RF-2a/5a	Unbl	NDCE	1,200,000	820	168	17	\$1,700,000	\$285,000	\$1,990,000	\$35,000	\$68,000	\$233,000	\$336,000
RF-3a/6a	Unbl	NDCE	1,800,000	1,200	243	17	\$2,120,000	\$411,000	\$2,530,000	\$50,500	\$84,800	\$296,000	\$431,000
RF-7a	Unbl	DCE	400,000	270	56.2	17	\$811,000	\$94,900	\$906,000	\$11,700	\$32,400	\$129,000	\$173,000
RF-8a	Unbl	DCE	700,000	450	93.4	17	\$1,100,000	\$158,000	\$1,260,000	\$19,400	\$44,000	\$179,000	\$242,000
RF-9a	Unbl	DCE	1,200,000	820	168	17	\$1,570,000	\$285,000	\$1,860,000	\$35,000	\$62,800	\$265,000	\$363,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-6b. Refer to Table 6-6b for footnotes, which include calculations.

TABLE 6-6b (ENGLISH). COSTS OF SCHEDULE 1 ESP UPGRADE TO CONTROL PM TO 0.044 GR/DSCF FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES) <sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP exit, acfm @8% O <sub>2</sub>	Downtime, d	TCI, \$ (b)	Pulp production losses, \$ (c)	TCI+ production losses, \$	Electricity, \$/yr (d)	A, I & T, \$/yr (e)	Capital recovery, \$/yr (f)	ITAC, \$/yr (g)
RF-1a/4a	BI	NDCE	1,500,000	420	198,000	17	\$1,200,000	\$224,000	\$1,420,000	\$19,400	\$48,000	\$166,000	\$233,000
RF-2a/5a	BI	NDCE	2,700,000	750	357,000	17	\$1,700,000	\$399,000	\$2,100,000	\$35,000	\$68,000	\$245,000	\$348,000
RF-3a/6a	BI	NDCE	3,900,000	1,100	515,000	17	\$2,120,000	\$585,000	\$2,710,000	\$50,500	\$94,800	\$317,000	\$452,000
RF-7a	BI	DCE	900,000	250	119,000	17	\$811,000	\$133,000	\$944,000	\$11,700	\$32,400	\$134,000	\$178,000
RF-8a	BI	DCE	1,500,000	420	198,000	17	\$1,100,000	\$224,000	\$1,320,000	\$19,400	\$44,000	\$188,000	\$251,000
RF-9a	BI	DCE	2,700,000	750	357,000	17	\$1,570,000	\$399,000	\$1,970,000	\$35,000	\$62,800	\$281,000	\$379,000
RF-1a/4a	Unbl	NDCE	1,500,000	500	198,000	17	\$1,200,000	\$158,000	\$1,360,000	\$19,400	\$48,000	\$159,000	\$226,000
RF-2a/5a	Unbl	NDCE	2,700,000	900	357,000	17	\$1,700,000	\$285,000	\$1,990,000	\$35,000	\$68,000	\$233,000	\$336,000
RF-3a/6a	Unbl	NDCE	3,900,000	1,300	515,000	17	\$2,120,000	\$411,000	\$2,530,000	\$50,500	\$94,800	\$296,000	\$431,000
RF-7a	Unbl	DCE	900,000	300	119,000	17	\$811,000	\$94,900	\$906,000	\$11,700	\$32,400	\$129,000	\$173,000
RF-8a	Unbl	DCE	1,500,000	500	198,000	17	\$1,100,000	\$158,000	\$1,260,000	\$19,400	\$44,000	\$179,000	\$242,000
RF-9a	Unbl	DCE	2,700,000	900	357,000	17	\$1,570,000	\$285,000	\$1,860,000	\$35,000	\$62,800	\$265,000	\$363,000

(a) All costs in \$1991

(b) For NDCE furnaces, TCI =  $(\$1,292,000)/[(230,000 \text{ acfm}/\text{model gas flowrate}) \wedge 0.6] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

For DCE furnaces, TCI =  $(\$1,504,750)/[(340,000 \text{ acfm}/\text{model gas flowrate}) \wedge 0.6] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

(c) Pulp production losses =  $(25\% \text{ gross profit margin}) \times (\$646/\text{ton bleached pulp or } \$384/\text{ton unbleached pulp}) \times (136.2 \text{ } \$1991/124 \text{ } \$1989) \times (17 \text{ d downtime} - 14 \text{ d scheduled downtime}) \times \text{ADTP/d}$

(d) Electricity costs for ESP upgrade assumed to equal electricity costs for ESP replacement.

For NDCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (533 - 433 \text{ ft}^2)/1,000 \text{ acfm} \times 8,424 \text{ hr/yr} \times \$0.06/\text{kWh}$

For DCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (433 - 333 \text{ ft}^2)/1,000 \text{ acfm} \times 8,424 \text{ hr/yr} \times \$0.06/\text{kWh}$

(e) Administrative, insurance, and taxes (A, I & T) =  $0.04 \times \text{TCI}$

(f) For NDCE furnaces, capital recovery =  $0.1169 \text{ CRF} \times (\text{TCI} + \text{production losses})$  (based on 13.5-yr ESP life and 7% interest)

For DCE furnaces, capital recovery =  $0.1424 \text{ CRF} \times (\text{TCI} + \text{production losses})$  (based on 10-yr ESP life and 7% interest)

(g) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-7a (METRIC). COSTS OF SCHEDULE 2 ESP UPGRADE TO CONTROL PM TO 0.10 G/DSCM FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate--ESP exit, m3/sec @8% O2	Downtime, d	TCI, \$	Pulp production losses, \$	TCH+ production losses, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1a/4a	BI	NDCE	700,000	380	93.4	30	\$1,160,000	\$1,190,000	\$2,350,000	\$19,400	\$46,400	\$275,000	\$341,000
RF-2a/5a	BI	NDCE	1,200,000	680	168	30	\$1,660,000	\$2,130,000	\$3,790,000	\$35,000	\$66,400	\$443,000	\$544,000
RF-3a/6a	BI	NDCE	1,800,000	1,000	243	30	\$2,070,000	\$3,120,000	\$5,190,000	\$50,500	\$82,800	\$607,000	\$740,000
RF-7a	BI	DCE	400,000	230	56.2	30	\$791,000	\$710,000	\$1,500,000	\$11,700	\$31,600	\$214,000	\$257,000
RF-8a	BI	DCE	700,000	380	93.4	30	\$1,070,000	\$1,190,000	\$2,260,000	\$19,400	\$42,800	\$322,000	\$384,000
RF-9a	BI	DCE	1,200,000	680	168	30	\$1,530,000	\$2,130,000	\$3,660,000	\$35,000	\$61,200	\$521,000	\$617,000
RF-1a/4a	Unbl	NDCE	700,000	450	93.4	30	\$1,160,000	\$844,000	\$2,000,000	\$19,400	\$46,400	\$234,000	\$300,000
RF-2a/5a	Unbl	NDCE	1,200,000	820	168	30	\$1,660,000	\$1,520,000	\$3,180,000	\$35,000	\$66,400	\$372,000	\$473,000
RF-3a/6a	Unbl	NDCE	1,800,000	1,200	243	30	\$2,070,000	\$2,190,000	\$4,260,000	\$50,500	\$82,800	\$498,000	\$631,000
RF-7a	Unbl	DCE	400,000	270	56.2	30	\$791,000	\$506,000	\$1,300,000	\$11,700	\$31,600	\$185,000	\$228,000
RF-8a	Unbl	DCE	700,000	450	93.4	30	\$1,070,000	\$844,000	\$1,910,000	\$19,400	\$42,800	\$272,000	\$334,000
RF-9a	Unbl	DCE	1,200,000	820	168	30	\$1,530,000	\$1,520,000	\$3,050,000	\$35,000	\$61,200	\$434,000	\$530,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-7b. Refer to Table 6-7b for footnotes, which include calculations.

TABLE 6-7b (ENGLISH) . COSTS OF SCHEDULE 2 ESP UPGRADE TO CONTROL PM TO 0.044 GR/DSCF FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES) a

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP exit, acfm @8% O2	Downtime, d	TCI, \$ (b)	Pulp production losses, \$ (c)	TCI+ production losses, \$	Electricity, \$/yr (d)	A, I & T, \$/yr (e)	Capital recovery, \$/yr (f)	ITAC, \$/yr (g)
RF-1a/4a	BI	NDCE	1,500,000	420	198,000	30	\$1,160,000	\$1,190,000	\$2,350,000	\$19,400	\$46,400	\$275,000	\$341,000
RF-2a/5a	BI	NDCE	2,700,000	750	357,000	30	\$1,660,000	\$2,130,000	\$3,790,000	\$35,000	\$66,400	\$443,000	\$544,000
RF-3a/6a	BI	NDCE	3,900,000	1,100	515,000	30	\$2,070,000	\$3,120,000	\$5,190,000	\$50,500	\$82,800	\$607,000	\$740,000
RF-7a	BI	DCE	900,000	250	119,000	30	\$791,000	\$710,000	\$1,500,000	\$11,700	\$31,600	\$214,000	\$257,000
RF-8a	BI	DCE	1,500,000	420	198,000	30	\$1,070,000	\$1,190,000	\$2,260,000	\$19,400	\$42,800	\$322,000	\$384,000
RF-9a	BI	DCE	2,700,000	750	357,000	30	\$1,530,000	\$2,130,000	\$3,660,000	\$35,000	\$61,200	\$521,000	\$617,000
RF-1a/4a	Unbl	NDCE	1,500,000	500	198,000	30	\$1,160,000	\$844,000	\$2,000,000	\$19,400	\$46,400	\$234,000	\$300,000
RF-2a/5a	Unbl	NDCE	2,700,000	900	357,000	30	\$1,660,000	\$1,520,000	\$3,180,000	\$35,000	\$66,400	\$372,000	\$473,000
RF-3a/6a	Unbl	NDCE	3,900,000	1,300	515,000	30	\$2,070,000	\$2,190,000	\$4,260,000	\$50,500	\$82,800	\$498,000	\$631,000
RF-7a	Unbl	DCE	900,000	300	119,000	30	\$791,000	\$506,000	\$1,300,000	\$11,700	\$31,600	\$185,000	\$228,000
RF-8a	Unbl	DCE	1,500,000	500	198,000	30	\$1,070,000	\$844,000	\$1,910,000	\$19,400	\$42,800	\$272,000	\$334,000
RF-9a	Unbl	DCE	2,700,000	900	357,000	30	\$1,530,000	\$1,520,000	\$3,050,000	\$35,000	\$61,200	\$434,000	\$530,000

(a) All costs in \$1991

(b) For NDCE furnaces, TCI =  $(\$1,259,000)/[(230,000 \text{ acfm}/\text{model gas flowrate}) \wedge 0.6] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

For DCE furnaces, TCI =  $(\$1,466,500)/[(340,000 \text{ acfm}/\text{model gas flowrate}) \wedge 0.6] \times (361.3 \text{ } \$1991/357 \text{ } \$\text{May } 1993)$

(c) Pulp production losses =  $(25\% \text{ gross profit margin}) \times (\$646/\text{ton bleached pulp or } \$384/\text{ton unbleached pulp}) \times (136.2 \text{ } \$1991/124 \text{ } \$1989) \times (30 \text{ d downtime}-14 \text{ d scheduled downtime}) \times \text{ADTP}/\text{d}$

(d) Electricity costs for ESP upgrade assumed to equal electricity costs for ESP replacement.

For NDCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (533 - 433 \text{ ft}^2)/1,000 \text{ acfm} \times 8,424 \text{ hr/yr} \times \$0.06/\text{kWh}$

For DCE furnaces, electricity =  $0.00194 \times \text{model gas flowrate} \times (433 - 333 \text{ ft}^2)/1,000 \text{ acfm} \times 8,424 \text{ hr/yr} \times \$0.06/\text{kWh}$

(e) Administrative, insurance, and taxes (A, I & T) =  $0.04 \times \text{TCI}$

(f) For NDCE furnaces, capital recovery =  $0.1169 \text{ CRF} \times (\text{TCI} + \text{production losses})$  (based on 13.5-yr ESP life and 7% interest)

For DCE furnaces, capital recovery =  $0.1424 \text{ CRF} \times (\text{TCI} + \text{production losses})$  (based on 10-yr ESP life and 7% interest)

(g) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-8a (METRIC). COSTS OF ESP UPGRADE TO CONTROL PM FROM 0.10 G/DSCM TO 0.034 G/DSCM FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate-- ESP exit, m <sup>3</sup> /sec @8% O <sub>2</sub>	Increase in ESP plate area, m <sup>2</sup>	Increase in SCA, m <sup>2</sup> /(m <sup>3</sup> /sec)	Downtime, d	TCI, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1b/4b	BI	NDCE	700,000	380	93.4	1,532	16	17	\$644,000	\$16,200	\$25,800	\$75,300	\$117,000
RF-2b/5b	BI	NDCE	1,200,000	680	168	2,756	16	17	\$1,160,000	\$29,200	\$46,400	\$136,000	\$212,000
RF-3b/6b	BI	NDCE	1,800,000	1,000	243	3,986	16	17	\$1,670,000	\$42,100	\$66,800	\$195,000	\$304,000
RF-7b	BI	DCE	400,000	230	56.2	922	16	17	\$387,000	\$9,720	\$15,500	\$55,100	\$80,300
RF-8b	BI	DCE	700,000	380	93.4	1,532	16	17	\$644,000	\$16,200	\$25,800	\$91,700	\$134,000
RF-9b	BI	DCE	1,200,000	700	168	2,756	16	17	\$1,160,000	\$29,200	\$46,400	\$165,000	\$241,000
RF-1b/4b	Unbl	NDCE	700,000	450	93.4	1,532	16	17	\$644,000	\$16,200	\$25,800	\$75,300	\$117,000
RF-2b/5b	Unbl	NDCE	1,200,000	820	168	2,756	16	17	\$1,160,000	\$29,200	\$46,400	\$136,000	\$212,000
RF-3b/6b	Unbl	NDCE	1,800,000	1,200	243	3,986	16	17	\$1,670,000	\$42,100	\$66,800	\$195,000	\$304,000
RF-7b	Unbl	DCE	400,000	270	56.2	922	16	17	\$387,000	\$9,720	\$15,500	\$55,100	\$80,300
RF-8b	Unbl	DCE	700,000	450	93.4	1,532	16	17	\$644,000	\$16,200	\$25,800	\$91,700	\$134,000
RF-9b	Unbl	DCE	1,200,000	820	168	2,756	16	17	\$1,160,000	\$29,200	\$46,400	\$165,000	\$241,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-8b. Refer to Table 6-8b for footnotes, which include calculations.

TABLE 6-8b (ENGLISH). COSTS OF ESP UPGRADE TO CONTROL PM FROM 0.044 GR/DSCF TO 0.015 GR/DSCF FOR MODEL RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES) <sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADIP/d	Gas flowrate-- ESP exit, acfm @8% O2	Increase in ESP plate area, ft2 (b)	Increase in SCA, ft2/1,000 acfm	Downtime, d	TCI, \$ (c)	Electricity, \$/yr (d)	A, I & T, \$/yr (e)	Capital recovery, \$/yr (f)	ITAC, \$/yr (g)
RF-1b/4b	BI	NDCE	1,500,000	420	198,000	16,500	83	17	\$644,000	\$16,200	\$25,800	\$75,300	\$117,000
RF-2b/5b	BI	NDCE	2,700,000	750	357,000	29,750	83	17	\$1,160,000	\$29,200	\$46,400	\$136,000	\$212,000
RF-3b/6b	BI	NDCE	3,900,000	1,100	515,000	42,917	83	17	\$1,670,000	\$42,100	\$66,800	\$195,000	\$304,000
RF-7b	BI	DCE	900,000	250	119,000	9,917	83	17	\$387,000	\$9,720	\$15,500	\$55,100	\$80,300
RF-8b	BI	DCE	1,500,000	420	198,000	16,500	83	17	\$644,000	\$16,200	\$25,800	\$91,700	\$134,000
RF-9b	BI	DCE	2,700,000	750	357,000	29,750	83	17	\$1,160,000	\$29,200	\$46,400	\$165,000	\$241,000
RF-1b/4b	Unbl	NDCE	1,500,000	500	198,000	16,500	83	17	\$644,000	\$16,200	\$25,800	\$75,300	\$117,000
RF-2b/5b	Unbl	NDCE	2,700,000	900	357,000	29,750	83	17	\$1,160,000	\$29,200	\$46,400	\$136,000	\$212,000
RF-3b/6b	Unbl	NDCE	3,900,000	1,300	515,000	42,917	83	17	\$1,670,000	\$42,100	\$66,800	\$195,000	\$304,000
RF-7b	Unbl	DCE	900,000	300	119,000	9,917	83	17	\$387,000	\$9,720	\$15,500	\$55,100	\$80,300
RF-8b	Unbl	DCE	1,500,000	500	198,000	16,500	83	17	\$644,000	\$16,200	\$25,800	\$91,700	\$134,000
RF-9b	Unbl	DCE	2,700,000	900	357,000	29,750	83	17	\$1,160,000	\$29,200	\$46,400	\$165,000	\$241,000

(a) All costs in \$1991

(b) Increase in ESP plate area = model gas flowrate x increase in SCA

(c) TCI = Increase in ESP plate area x (\$39/ft2 plate area)

(d) For NDCE furnaces, electricity = 0.00194 x model gas flowrate x (617 - 533 ft2)/1,000 acfm x 8,424 hr/yr x \$0.06/kWh

For DCE furnaces, electricity = 0.00194 x model gas flowrate x (517 - 433 ft2)/1,000 acfm x 8,424 hr/yr x \$0.06/kWh

(e) Administrative, insurance, and taxes (A, I & T) = 0.04 x TCI

(f) For NDCE furnaces, capital recovery = 0.1169 CRF x TCI (based on 13.5-yr ESP life and 7% interest)

For DCE furnaces, capital recovery = 0.1424 CRF x TCI (based on 10-yr ESP life and 7% interest)

(g) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-9a (METRIC). COSTS OF ESP UPGRADE TO CONTROL PM FROM 0.10 G/DSCM TO 0.034 G/DSCM FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate--ESP exit, m <sup>3</sup> /sec @8% O <sub>2</sub>	Increase in ESP plate area, m <sup>2</sup>	Increase in SCA, m <sup>2</sup> /(m <sup>3</sup> /sec)	Downtime, d	TCI, \$	Pulp production losses, \$	TCI+ production losses, \$	Electricity, \$/yr	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-1b/4b	BI	NDCE	700,000	380	93.4	1,532	16	17	\$644,000	\$224,000	\$868,000	\$16,200	\$25,800	\$101,000	\$143,000
RF-2b/5b	BI	NDCE	1,200,000	680	168	2,756	16	17	\$1,160,000	\$399,000	\$1,560,000	\$29,200	\$46,400	\$182,000	\$259,000
RF-3b/6b	BI	NDCE	1,800,000	1,000	243	3,986	16	17	\$1,670,000	\$585,000	\$2,260,000	\$42,100	\$66,800	\$264,000	\$373,000
RF-7b	BI	DCE	400,000	230	56.2	922	16	17	\$387,000	\$133,000	\$520,000	\$9,700	\$15,500	\$74,000	\$99,000
RF-8b	BI	DCE	700,000	380	93.4	1,532	16	17	\$644,000	\$224,000	\$868,000	\$16,200	\$25,800	\$124,000	\$166,000
RF-9b	BI	DCE	1,200,000	680	168	2,756	16	17	\$1,160,000	\$399,000	\$1,560,000	\$29,200	\$46,400	\$222,000	\$298,000
RF-1b/4b	Unbl	NDCE	700,000	230	93.4	1,532	16	17	\$644,000	\$156,000	\$802,000	\$16,200	\$25,800	\$93,800	\$136,000
RF-2b/5b	Unbl	NDCE	1,200,000	820	168	2,756	16	17	\$1,160,000	\$285,000	\$1,450,000	\$29,200	\$46,400	\$170,000	\$246,000
RF-3b/6b	Unbl	NDCE	1,800,000	1,200	243	3,986	16	17	\$1,670,000	\$411,000	\$2,080,000	\$42,100	\$66,800	\$243,000	\$352,000
RF-7b	Unbl	DCE	400,000	270	56.2	922	16	17	\$387,000	\$94,900	\$482,000	\$9,700	\$15,500	\$68,600	\$94,000
RF-8b	Unbl	DCE	700,000	450	93.4	1,532	16	17	\$644,000	\$158,000	\$802,000	\$16,200	\$25,800	\$114,000	\$156,000
RF-9b	Unbl	DCE	1,200,000	820	168	2,756	16	17	\$1,160,000	\$285,000	\$1,450,000	\$29,200	\$46,400	\$206,000	\$282,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-9b. Refer to Table 6-9b for footnotes, which include calculations.



TABLE 6-9b (ENGLISH). COSTS OF ESP UPGRADE TO CONTROL PM FROM 0.044 GR/DSCF TO 0.015 GR/DSCF FOR MODEL RECOVERY FURNACES (INCLUDING PULP PRODUCTION LOSSES) <sup>a</sup>

Model recovery furnaces	Pulp type	Furnace type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Gas flowrate-- ESP exit, acfm @9% O <sub>2</sub>	Increase in ESP plate area, ft <sup>2</sup> (b)	Increase in SCA, ft <sup>2</sup> /1,000 acfm	Downtime, d	TCI, \$ (c)	Pulp production losses, \$ (d)	TCI + production losses, \$	Electricity, \$/yr (e)	A, I & T, \$/yr (f)	Capital recovery, \$/yr (g)	ITAC, \$/yr (h)
RF-1b/4b	BI	NDCE	1,500,000	420	198,000	16,500	83	17	\$644,000	\$224,000	\$868,000	\$16,200	\$25,800	\$101,000	\$143,000
RF-2b/5b	BI	NDCE	2,700,000	750	357,000	29,750	83	17	\$1,160,000	\$399,000	\$1,560,000	\$29,200	\$46,400	\$182,000	\$258,000
RF-3b/6b	BI	NDCE	3,900,000	1,100	515,000	42,917	83	17	\$1,670,000	\$585,000	\$2,260,000	\$42,100	\$66,800	\$264,000	\$373,000
RF-7b	BI	DCE	900,000	250	119,000	9,917	83	17	\$387,000	\$133,000	\$520,000	\$9,700	\$15,500	\$74,000	\$98,000
RF-8b	BI	DCE	1,500,000	420	198,000	16,500	83	17	\$644,000	\$224,000	\$868,000	\$16,200	\$25,800	\$124,000	\$166,000
RF-9b	BI	DCE	2,700,000	750	357,000	29,750	83	17	\$1,160,000	\$399,000	\$1,560,000	\$29,200	\$46,400	\$222,000	\$298,000
RF-1b/4b	Unbl	NDCE	1,500,000	500	198,000	16,500	83	17	\$644,000	\$158,000	\$802,000	\$16,200	\$25,800	\$93,800	\$136,000
RF-2b/5b	Unbl	NDCE	2,700,000	900	357,000	29,750	83	17	\$1,160,000	\$285,000	\$1,450,000	\$29,200	\$46,400	\$170,000	\$246,000
RF-3b/6b	Unbl	NDCE	3,900,000	1,300	515,000	42,917	83	17	\$1,670,000	\$411,000	\$2,080,000	\$42,100	\$66,800	\$243,000	\$352,000
RF-7b	Unbl	DCE	900,000	300	119,000	9,917	83	17	\$387,000	\$94,900	\$482,000	\$9,700	\$15,500	\$68,600	\$94,000
RF-8b	Unbl	DCE	1,500,000	500	198,000	16,500	83	17	\$644,000	\$158,000	\$802,000	\$16,200	\$25,800	\$114,000	\$156,000
RF-9b	Unbl	DCE	2,700,000	900	357,000	29,750	83	17	\$1,160,000	\$285,000	\$1,450,000	\$29,200	\$46,400	\$206,000	\$282,000

(a) All costs in \$1991

(b) Increase in ESP plate area = model gas flowrate x increase in SCA

(c) TCI = Increase in ESP plate area x (\$39/ft<sup>2</sup> plate area)

(d) Pulp production losses = (25% gross profit margin) x (\$646/ton bleached pulp or \$384/ton unbleached pulp) x (136.2 \$1991/124 \$1989) x (17 d downtime-14 d scheduled downtime) x ADTP/d

(e) For NDCE furnaces, electricity = 0.00194 x model gas flowrate x (617 - 533 ft<sup>2</sup>/1,000 acfm x 8,424 hr/yr x \$0.06/kWh)

(f) For DCE furnaces, electricity = 0.00194 x model gas flowrate x (517 - 433 ft<sup>2</sup>/1,000 acfm x 8,424 hr/yr x \$0.06/kWh)

(g) For NDCE furnaces, capital recovery = 0.1169 CRF x (TCI + production losses) (based on 13.5-yr ESP life and 7% interest)

(h) For DCE furnaces, capital recovery = 0.1424 CRF x (TCI + production losses) (based on 10-yr ESP life and 7% interest)

(i) Incremental total annual cost (ITAC) = Electricity + A, I & T + capital recovery

TABLE 6-10a (METRIC). WET- TO DRY-BOTTOM ESP CONVERSION COSTS FOR MODEL NDCE RECOVERY FURNACES<sup>a</sup>

Model recovery furnaces	Pulp type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Baseline ESP type	Control option ESP type	Gas flowrate-- ESP exit, m3/sec @8% O2	TCI, \$	A, I & T, \$/yr	Capital recovery, \$/yr	ITAC, \$/yr
RF-4a/4b	BI	700,000	380	wet-bottom	dry-bottom	93.4	\$596,000	\$23,800	\$69,700	\$93,500
RF-5a/5b	BI	1,200,000	680	wet-bottom	dry-bottom	168	\$849,000	\$34,000	\$99,200	\$133,000
RF-6a/6b	BI	1,800,000	1,000	wet-bottom	dry-bottom	243	\$1,060,000	\$42,400	\$124,000	\$166,000
RF-4a/4b	Unbl	700,000	450	wet-bottom	dry-bottom	93.4	\$596,000	\$23,800	\$69,700	\$93,500
RF-5a/5b	Unbl	1,200,000	820	wet-bottom	dry-bottom	168	\$849,000	\$34,000	\$99,200	\$133,000
RF-6a/6b	Unbl	1,800,000	1,200	wet-bottom	dry-bottom	243	\$1,060,000	\$42,400	\$124,000	\$166,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-10b. Refer to Table 6-10 for footnotes, which include calculations.

TABLE 6-10b (ENGLISH). WET- TO DRY-BOTTOM ESP CONVERSION COSTS FOR MODEL NDCE RECOVERY FURNACES<sup>a</sup>

Model recovery furnaces	Pulp type	Black liquor firing rate, lb BLS/d	Equivalent ADTP/d	Baseline ESP type	Control option ESP type	Gas flowrate-- ESP exit, acfm @8% O2	TCI, \$ (b)	A, I & T, \$/yr (c)	Capital recovery, \$/yr (d)	ITAC, \$/yr (e)
RF-4a/4b	Bl	1,500,000	420	wet-bottom	dry-bottom	198,000	\$596,000	\$23,800	\$69,700	\$93,500
RF-5a/5b	Bl	2,700,000	750	wet-bottom	dry-bottom	357,000	\$849,000	\$34,000	\$99,200	\$133,000
RF-6a/6b	Bl	3,900,000	1,100	wet-bottom	dry-bottom	515,000	\$1,060,000	\$42,400	\$124,000	\$166,000
RF-4a/4b	Unbl	1,500,000	500	wet-bottom	dry-bottom	198,000	\$596,000	\$23,800	\$69,700	\$93,500
RF-5a/5b	Unbl	2,700,000	900	wet-bottom	dry-bottom	357,000	\$849,000	\$34,000	\$99,200	\$133,000
RF-6a/6b	Unbl	3,900,000	1,300	wet-bottom	dry-bottom	515,000	\$1,060,000	\$42,400	\$124,000	\$166,000

(a) All costs in \$1991

(b) TCI = \$845,000/(357,000 acfm/model gas flowrate) ^ 0.6 x (361.3 \$1991/359.4 \$July 1993)

(c) Administrative, insurance, and taxes (A, I & T) = 0.04 x TCI

(d) Capital recovery = 0.1169 CRF x TCI (based on 13.5-yr ESP life and 7% interest)

(e) Incremental total annual cost (ITAC) = A, I & T + capital recovery

TABLE 6-11a (METRIC). CAPITAL COSTS OF LOW-ODOR CONVERSION (INCLUDING ESP UPGRADE TO CONTROL PM TO 0.10 G/DSCM) FOR MODEL DCE RECOVERY FURNACES (EXCLUDING PULP PRODUCTION LOSSES)<sup>a</sup>

Model recovery furnaces	Pulp type	Black liquor firing rate, kg BLS/d	Equivalent ADMP/d	Gas flowrate-- ESP exit, m <sup>3</sup> /sec @ 8% O <sub>2</sub>	Downtime, d	Economizer expansion, demolition, \$	Concentrator, \$	Low-odor conversion, \$	ESP upgrade, \$	Wet to dry-bottom ESP conversion, \$	TCI, \$
RF-7a/7b	Bl	400,000	230	56.2	25	\$4,780,000	\$3,310,000	\$8,090,000	\$881,000	\$439,000	\$9,410,000
RF-8a/8b	Bl	700,000	380	93.4	25	\$6,500,000	\$4,500,000	\$11,000,000	\$1,200,000	\$596,000	\$12,800,000
RF-9a/9b	Bl	1,200,000	680	168	25	\$9,250,000	\$6,400,000	\$15,700,000	\$1,700,000	\$849,000	\$18,200,000
RF-7a/7b	Unbl	400,000	270	56.2	25	\$4,780,000	\$3,310,000	\$8,090,000	\$881,000	\$439,000	\$9,410,000
RF-8a/8b	Unbl	700,000	450	93.4	25	\$6,500,000	\$4,500,000	\$11,000,000	\$1,200,000	\$596,000	\$12,800,000
RF-9a/9b	Unbl	1,200,000	820	168	25	\$9,250,000	\$6,400,000	\$15,700,000	\$1,700,000	\$849,000	\$18,200,000

(a) Metric equivalents in this table were converted from the calculated English unit values given in Table 6-11b. Refer to Table 6-11b for footnotes, which include calculations.