


Fort Worth Central City Preliminary Design



Civil/Structural Preliminary Design



Draft Environmental Impact Statement

Appendix C

May 2005



Volume V - Stability Analysis Storm Water Pump Station



Images courtesy of CDM, Gibson Toal, and Bing Thom Architects



STABILITY ANALYSES FOR STORM WATER PUMP STATION

Contents: Stability Analyses for Storm Water Pump Station

Volume V

- Section 1** **Index of Excel Spreadsheets**

- Section 2** **Center of Gravity (CG) Spreadsheet for Various Components**

- Section 3** **Counterfort**

- Section 4** **Storm Water Pump Station Stability Analyses**
 - Load Case 1 - During Construction
 - Load Case 2 - During Construction Maintenance
 - Load Case 3 - Normal
 - Load Case 4 - Normal

- Section 5** **Bearing Pressure**

- Section 6** **Cell Formulas for Excel Spreadsheets**
 - Counterfort
 - Stability
 - Bearing Pressure Analysis

- Section 7** **Design of Steel H - Piles (Manual Calculations)**

- Section 8** **Seismic Load Case Check**

Section 1
Index of Excel Spreadsheets

STABILITY ANALYSES STORM WATER PUMP STATION

Index of Excel Spreadsheets:

Center of Gravity of various structure components:

File name: CG of building side walls

File name: CG of conc Upper side wall

File name: CG of conc Lower side wall

File name: CG of conc Upper counterfort

File name: CG of conc Lower counterfort

Counterfort:

File name: Counterfort.xls

Stability:

File name: PS Stability.xls

Tab name: Load Case 1

(Construction Case - Unusual)

Tab name: Load Case 2

(Maintenance or Construction Case - Unusual)

Tab name: Load Case 3

(Normal (drained soil) - Usual)

Tab name: Load Case 4

(Normal (undrained soil) - Usual)

Bearing Pressure:

File name: PS Bearing Pressure.xls

Section 2
Center of Gravity (CG)
Spreadsheets for Various Components

Storm Water Pump Station

Center of Gravity (CG) spreadsheets for various components:

1. Building Side Walls (File: CG of building side walls.xls)
2. Upper Concrete Side Wall (File: CG of conc Upper side wall.xls)
3. Lower Concrete Side Wall (File: CG of conc Lower side wall.xls)
4. Upper Counterfort for Lateral Force (File: CG of conc Upper counterfort.xls)
5. Lower Counterfort for Lateral Force (File: CG of conc Lower counterfort.xls)

CDM 8140 Walnut Hill Lane Dallas, TX 75231 tel. (214) 346-2800	Project: TRWD-FWCC Storm Water P.S.	Engineer: EJB	Project #
	Subject: Building side walls	Date: 18-Jan	42275
		Checker:	Page:
		Date:	



PROPERTIES OF SECTION DESCRIBED BY NODES COORDINATES

Units: **ft**

Nodes Coordinates		
	X	Y
1	0.000	0.000
2	0.000	20.000
3	20.000	20.000
4	20.000	8.500
5	0.000	0.000
6	0.000	0.000
7	0.000	0.000
8	0.000	0.000
9	0.000	0.000
10	0.000	0.000
11	0.000	0.000
12	0.000	0.000
13	0.000	0.000
14	0.000	0.000
15	0.000	0.000
16	0.000	0.000
17	0.000	0.000
18	0.000	0.000
19	0.000	0.000
20	0.000	0.000
21	0.000	0.000
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		

Section Properties About Centroidal Axis Parallel to Original Axis		
$\phi =$	28.643 deg	X-dim = 20 ft
A =	315.00 ft ²	Y-dim = 20 ft
Xcg =	9.101 ft	Sx(top) = 923.4 ft ³
Ycg =	11.934 ft	Sx(bot) = 624.1 ft ³
l _{xo} =	7448.4 ft ⁴	Sy(left) = 1125.8 ft ³
l _{yo} =	10245.1 ft ⁴	Sy(right) = 940.0 ft ³
l _{xyo} =	2177.1 ft ⁴	

Section Properties About Principal Axis		
$\phi =$	28.643 deg	S _{xp} (top) = 547.1 ft ³
l _{xp} =	6259.3 ft ⁴	S _{xp} (bot) = 759.8 ft ³
l _{yp} =	11434.3 ft ⁴	S _{yp} (left) = 834.2 ft ³
l _{xyp} =	0.0 ft ⁴	S _{yp} (right) = 851.3 ft ³
J =	17693.6 ft ⁴	



CDM 8140 Walnut Hill Lane Dallas, TX 75231 tel. (214) 346-2800	Project: TRWD-FWCC Storm Water P.S.	Engineer: EJB	Project #
	Subject: Upper Conc Side Wall	Date: 18-Jan	42275
		Checker:	Page:
		Date:	


PROPERTIES OF SECTION DESCRIBED BY NODES COORDINATES

Units: **ft**

Nodes Coordinates		
	X	Y
1	0.000	0.000
2	0.000	26.000
3	30.000	33.500
4	30.000	0.000
5	0.000	0.000
6	0.000	0.000
7	0.000	0.000
8	0.000	0.000
9	0.000	0.000
10	0.000	0.000
11	0.000	0.000
12	0.000	0.000
13	0.000	0.000
14	0.000	0.000
15	0.000	0.000
16	0.000	0.000
17	0.000	0.000
18	0.000	0.000
19	0.000	0.000
20	0.000	0.000
21	0.000	0.000
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		

Section Properties About Centroidal Axis Parallel to Original Axis		
$\phi =$	-42.716 deg	X-dim = 30 ft
A =	892.50 ft ²	Y-dim = 33.5 ft
Xcg =	15.630 ft	Sx(top) = 3661.8 ft ³
Ycg =	14.954 ft	Sx(bot) = 4541.5 ft ³
lxo =	67912.8 ft ⁴	Sy(left) = 4259.9 ft ³
lyo =	66583.0 ft ⁴	Sy(right) = 4633.6 ft ³
lxyo =	8322.9 ft ⁴	

Section Properties About Principal Axis		
$\phi =$	-42.716 deg	Sxp(top) = 3234.2 ft ³
lxp =	75597.3 ft ⁴	Sxp(bot) = 3501.5 ft ³
lyp =	58898.5 ft ⁴	Syp(left) = 3103.6 ft ³
lxyp =	0.0 ft ⁴	Syp(right) = 2845.1 ft ³
J =	134495.8 ft ⁴	



15.63' moment arm
Toe

CDM 8140 Walnut Hill Lane Dallas, TX 75231 tel. (214) 346-2800	Project: TRWD-FWCC Storm Water P.S.	Engineer: EJB	Project #
	Subject: Lower Conc Side Wall	Date: 18-Jan	42275
		Checker:	Page:
		Date:	


PROPERTIES OF SECTION DESCRIBED BY NODES COORDINATES

Units: **ft**

Nodes Coordinates		
	X	Y
1	0.000	0.000
2	0.000	32.500
3	30.000	41.000
4	30.000	0.000
5	0.000	0.000
6	0.000	0.000
7	0.000	0.000
8	0.000	0.000
9	0.000	0.000
10	0.000	0.000
11	0.000	0.000
12	0.000	0.000
13	0.000	0.000
14	0.000	0.000
15	0.000	0.000
16	0.000	0.000
17	0.000	0.000
18	0.000	0.000
19	0.000	0.000
20	0.000	0.000
21	0.000	0.000
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		

Section Properties About Centroidal Axis Parallel to Original Axis		
$\phi =$	-13.679 deg	X-dim = 30 ft
A =	1102.50 ft ²	Y-dim = 41 ft
Xcg =	15.578 ft	Sx(top) = 5651.2 ft ³
Ycg =	18.457 ft	Sx(bot) = 6902.3 ft ³
Ixo =	127394.5 ft ⁴	Sy(left) = 5284.2 ft ³
Iyo =	82318.9 ft ⁴	Sy(right) = 5708.0 ft ³
Ixyo =	11661.8 ft ⁴	

Section Properties About Principal Axis		
$\phi =$	-13.679 deg	Sxp(top) = 5144.7 ft ³
Ixp =	130232.9 ft ⁴	Sxp(bot) = 6024.4 ft ³
Iyp =	79480.5 ft ⁴	Syp(left) = 4306.2 ft ³
Ixyp =	0.0 ft ⁴	Syp(right) = 4324.9 ft ³
J =	209713.4 ft ⁴	



15.58' moment arm
Toe

CDM 8140 Walnut Hill Lane Dallas, TX 75231 tel. (214) 346-2800	Project: TRWD-FWCC Storm Water P.S.	Engineer: EJB	Project #
	Subject: Upper Counterfort for lateral force	Date: 18-Jan	42275
		Checker:	Page:
		Date:	


PROPERTIES OF SECTION DESCRIBED BY NODES COORDINATES

Units: **ft**

Nodes Coordinates		
	X	Y
1	0.000	0.000
2	0.000	19.000
3	10.000	3.000
4	10.000	0.000
5	0.000	0.000
6	0.000	0.000
7	0.000	0.000
8	0.000	0.000
9	0.000	0.000
10	0.000	0.000
11	0.000	0.000
12	0.000	0.000
13	0.000	0.000
14	0.000	0.000
15	0.000	0.000
16	0.000	0.000
17	0.000	0.000
18	0.000	0.000
19	0.000	0.000
20	0.000	0.000
21	0.000	0.000
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		

Section Properties About Centroidal Axis Parallel to Original Axis		
$\phi =$	20.155 deg	X-dim = 10 ft
A =	110.00 ft ²	Y-dim = 19 ft
Xcg =	3.788 ft	Sx(top) = 173.9 ft ³
Ycg =	6.470 ft	Sx(bot) = 336.8 ft ³
Ixo =	2179.1 ft ⁴	Sy(left) = 199.3 ft ³
Iyo =	755.1 ft ⁴	Sy(right) = 121.5 ft ³
Ixyo =	-604.0 ft ⁴	

Section Properties About Principal Axis		
$\phi =$	20.155 deg	Sxp(top) = 183.7 ft ³
Ixp =	2400.8 ft ⁴	Sxp(bot) = 292.3 ft ³
Iyp =	533.3 ft ⁴	Syp(left) = 92.2 ft ³
Ixyp =	0.0 ft ⁴	Syp(right) = 115.0 ft ³
J =	2934.1 ft ⁴	



Use Area (110 ft²) for lateral force

CDM 8140 Walnut Hill Lane Dallas, TX 75231 tel. (214) 346-2800	Project: TRWD-FWCC Storm Water P.S.	Engineer: EJB	Project #
	Subject: Lower Counterfort for lateral force	Date: 18-Jan	42275
		Checker:	Page:
		Date:	


PROPERTIES OF SECTION DESCRIBED BY NODES COORDINATES

Units: **ft**

Nodes Coordinates		
	X	Y
1	0.000	0.000
2	-9.500	0.000
3	-9.500	3.000
4	0.000	29.000
5	0.000	0.000
6	0.000	0.000
7	0.000	0.000
8	0.000	0.000
9	0.000	0.000
10	0.000	0.000
11	0.000	0.000
12	0.000	0.000
13	0.000	0.000
14	0.000	0.000
15	0.000	0.000
16	0.000	0.000
17	0.000	0.000
18	0.000	0.000
19	0.000	0.000
20	0.000	0.000
21	0.000	0.000
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		

Section Properties About Centroidal Axis Parallel to Original Axis		
$\phi =$	-10.803 deg	X-dim = 9.5 ft
A =	152.00 ft ²	Y-dim = 29 ft
Xcg =	-3.464 ft	Sx(top) = 366.6 ft ³
Ycg =	9.760 ft	Sx(bot) = 722.6 ft ³
Ixo =	7052.9 ft ⁴	Sy(left) = 147.7 ft ³
Iyo =	891.6 ft ⁴	Sy(right) = 257.4 ft ³
Ixyo =	1220.1 ft ⁴	

Section Properties About Principal Axis		
$\phi =$	-10.803 deg	Sxp(top) = 372.7 ft ³
Ixp =	7285.8 ft ⁴	Sxp(bot) = 679.7 ft ³
Iyp =	658.8 ft ⁴	Syp(left) = 141.3 ft ³
Ixyp =	0.0 ft ⁴	Syp(right) = 125.9 ft ³
J =	7944.6 ft ⁴	



Use Area (152 ft²) for lateral force

Section 3 Counterfort

**Storm Water Pump Station
Counterfort**

(File: Counterfort.xls)

PROJECT:	TRWD - STORM WATER PUMP STATION						
PROJECT NO:	2521-42275-PRSTR.PS						
DESIGNED BY:	E. BJORKLUND				DATE:	1/17/2005	
CHECKED BY:					DATE:		
UPPER COUNTERFORT							
E.F.P.=	70	psf / ft of depth					
Depth =	38	ft from grade to upper counterfort base					
Centroid =	6.47	ft from centroid to upper counterfort base - SEE CG SPREADSHEET					
Section	ground to centroid	pressure at centroid	Section Area	Total Force on Area	Centroid Location	Moment Arm about upper slab	Moment
Trapezoid	31.53	2207	110	242781	6.47	6.47	1570793
LOWER COUNTERFORT							
E.F.P.=	70	psf / ft of depth					
Depth =	45.5	ft from grade to base					
Centroid =	9.76	ft from centroid to base - SEE CG SPREADSHEET					
Section	ground to centroid	pressure at centroid	Section Area	Total Force on Area	Centroid Location	Moment Arm about lower slab	Moment
Trapezoid	35.74	2502	152	380273.6	9.76	9.76	3711470
UPPER COUNTERFORT							
E.F.P.=	105	psf / ft of depth					
Depth =	38	ft from grade to upper counterfort base					
Centroid =	6.47	ft from centroid to upper counterfort base - SEE CG SPREADSHEET					
Section	ground to centroid	pressure at centroid	Section Area	Total Force on Area	Centroid Location	Moment Arm about upper slab	Moment
Trapezoid	31.53	3311	110	364171.5	6.47	6.47	2356190
LOWER COUNTERFORT							
E.F.P.=	105	psf / ft of depth					
Depth =	45.5	ft from grade to base					
Centroid =	9.76	ft from centroid to base - SEE CG SPREADSHEET					
Section	ground to centroid	pressure at centroid	Section Area	Total Force on Area	Centroid Location	Moment Arm about lower slab	Moment
Trapezoid	35.74	3753	152	570410.4	9.76	9.76	5567206

Section 4

Storm Water Pump Station Stability Analysis

Storm Water Pump Station Stability

(File: PS Stability.xls with Tabs for Load Cases)

Load Case 1 - During Construction

1. Dead loads + equipment.
2. No live loads, no soil, no water.

PROJECT:	TRWD - STORM WATER PUMP STATION												
PROJECT NO:	2521-42275-PRSTR.PS												
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005								
CHECKED BY:				DATE:									
STABILITY													
Load Condition 1 - During Construction													
(dead loads + equipment loads, no live loads no soil, no water)													
		Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)		
VERTICAL													
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/ lighting/etc. minus roof openings		50 psf	23	53		4 x 36sf = 144	53,750	20	1,075,000			
Building Walls	12" CMU at 20' height minus vent openings		80 psf	53		20	16 x 16 sf = 256	64,320	9.25	594,960			
	12" CMU at 16.5' avg height minus vent openings		80 psf	2	20	16.5	5 x 16 sf = 80	40,000	19.1	764,000			
	12" CMU at 11.5' height minus vent openings		80 psf		53	11.5	8 x 16 sf = 128	38,520	30.75	1,184,490			
Top Floor Slab	18" thick		225 psf	21.5	50			241,875	19.25	4,656,094			
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)		563 pLF	2	50			56,300	16	900,800			
C.I.P. Walls	Upper exterior end wall - 24" avg thickness EI 548.0 to 513.0 =35' height		300 psf		39.25	35			412,125	31.17	12,845,936		
	Upper exterior side wall - 24" avg thickness EI (546.5-538.0) to 513.0 =29.25' avg height		300 psf		30	29.25			263,250	15.63	4,114,598		
	Lower (deep) exterior end wall - 27" avg thickness EI 548.0 to 505.5 =42.5' height		338 psf		15.08	42.5			216,624	31.17	6,752,176		
	Lower (deep) exterior side wall - 27" avg thickness EI (546.5-538.0) to 505.5 =36.75' avg height		338 psf		30	36.75			372,645	15.58	5,805,809		
	channel divider wall 18" thick EI 538.0 to 513.0 =25' height		225 psf	3	30	25			506,250	15	7,593,750		
	Lower channel divider (side) wall 18" thick		225 psf		30	7.5			50,625	15	759,375		
	Upper counterfort (SOUTH) 24" thick		300 psf	1	5	16			24,000	1	24,000		
	Upper counterfort (MID) 24" thick		300 psf	1	5	16			24,000	16	384,000		
	Upper counterfort (NORTH) 24" thick		300 psf	1	5	16			24,000	31	744,000		
	Lower counterfort (SOUTH) 24" thick		300 psf	1	4.75	23			32,775	1	32,775		
Lower counterfort (MID) 24" thick		300 psf	1	4.75	23			32,775	16	524,400			
Lower counterfort (NORTH) 24" thick		300 psf	1	4.75	23			32,775	31	1,016,025			
Base Slab	36" thick		450 psf	75	51			1,721,250	25.5	43,891,875			
Pumps	Upper vertical pumps		30500 lbs	3				91,500	25.5	2,333,250			
	Lower vertical pump		34500 lbs	1				34,500	25.5	879,750			
Trash Racks	at Upper channels w/ 11.33' width each using 55 ~ 5/8"x6" steel bars x 25' long @ 2.5"c/c		319 lbs	165				52,635	4.25	223,699			
	at Lower channel w/ 11.33' width using 55 ~ 5/8"x8" steel bars x 32' long @ 2.5"c/c		545 lbs	55				29,975	4.25	127,394			
								4,416,469	22.01	97,228,155			

Storm Water Pump Station

Stability

(File: PS Stability.xls with Tabs for Load Cases)

Load Case 2 - During Construction or Maintenance

1. Dead loads.
2. No equipment, no live loads, low water (empty inlet).
3. Undrained (saturated) backfill.
4. Uplift

PROJECT:	TRWD - STORM WATER PUMP STATION											
PROJECT NO:	2521-42275-PRSTR.PS											
DESIGNED BY:	E. BJORKLUND		DATE:	1/18/2005								
CHECKED BY:			DATE:									
STABILITY												
Load Condition 2 - During Construction/Maintenance												
(dead loads, no equipment, no live loads saturated backfill + low water/empty + uplift)												
	Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight/force (lbs)	Lateral Force (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)	
VERTICAL												
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/lighting/etc. minus roof openings	50 psf	23	53		4 x 36sf = 144	53,750		20	1,075,000		
Building Walls	12" CMU at 20' height minus vent openings	80 psf	53			16 x 16 sf = 256	64,320		9.25	594,960		
	12" CMU at 16.5' avg height minus vent openings	80 psf	2	20	16.5	5 x 16 sf = 80	40,000		19.1	764,000		
	12" CMU at 11.5' height minus vent openings	80 psf	53		11.5	8 x 16 sf = 128	38,520		30.75	1,184,490		
Top Floor Slab	18" thick	225 psf	21.5	50			241,875		19.25	4,656,094		
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563 pLF	2	50			56,300		16	900,800		
C.I.P. Walls	Upper exterior end wall - 24" avg thickness EI 548.0 to 513.0 =35' height	300 psf		39.25			412,125		31.17	12,845,936		
	Upper exterior side wall - 24" avg thickness EI (546.5-538.0) to 513.0 =29.25' avg height	300 psf		30	29.25		263,250		15.63	4,114,598		
	Lower (deep) exterior end wall - 27" avg thickness EI 548.0 to 505.5 =42.5' height	338 psf		15.08	42.5		216,624		31.17	6,752,176		
	Lower (deep) exterior side wall - 27" avg thickness EI (546.5-538.0) to 505.5 =36.75' avg height	338 psf		30	36.75		372,645		15.58	5,805,809		
	channel divider wall 18" thick EI 538.0 to 513.0 =25' height	225 psf	3	30	25		506,250		15	7,593,750		
	Lower channel divider (side) wall 18" thick	225 psf		30	7.5		50,625		15	759,375		
	Upper counterfort (SOUTH) 24" thick	300 psf	1	5	16		24,000		1	24,000		
	Upper counterfort (MID) 24" thick	300 psf	1	5	16		24,000		16	384,000		
	Upper counterfort (NORTH) 24" thick	300 psf	1	5	16		24,000		31	744,000		
	Lower counterfort (SOUTH) 24" thick	300 psf	1	4.75	23		32,775		1	32,775		
	Lower counterfort (MID) 24" thick	300 psf	1	4.75	23		32,775		16	524,400		
	Lower counterfort (NORTH) 24" thick	300 psf	1	4.75	23		32,775		31	1,016,025		
Base Slab	36" thick	450 psf		75	51		1,721,250		25.5	43,891,875		
Soil weight	on Upper Heel Footing (vertical volume, no cone action)	130 pcf		51.17	18.5	35	4,307,235		41.75	179,827,051		
	on Lower Heel Footing (vertical volume, no cone action)	130 pcf		23.83	18	42.5	2,369,894		42	99,535,527		
	on Upper Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	10	29.25	1,140,750		15	17,111,250		
	on Lower Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	9.5	36.75	1,361,588		15	20,423,813		
							13,387,325		30.67	410,561,703		
LATERAL												
Saturated soil forces	on Upper end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 pcf		51.17	38			3,879,198	12.65		49,087,368	Assumes moment-arm rotation about bottom of UPPER foundation
(see COUNTERFORT spreadsheet)	on Upper end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3311 pcf			10	11		364,210	6.47		2,356,439	Assumes moment-arm rotation about bottom of UPPER foundation
	on Lower end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 pcf		23.83	45.5			2,590,038	15.15		39,242,961	Assumes moment-arm rotation about bottom of LOWER foundation
(see COUNTERFORT spreadsheet)	on Lower end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3753 pcf			9.5	16		570,456	9.76		5,567,651	Assumes moment-arm rotation about bottom of LOWER foundation
							7,403,902		13.00		96,254,418	
UPLIFT												
Uplift	at Upper channel at inlet/bar screen (UPPER TOE): High Groundwater/Saturated soil up to Elev. 513.0, bottom of base at 510.0 = 3.0 ft head (uniform load)	62.4 pcf		49.5	51	3	-472,586		25.5		12,050,953	
	at Upper channel at end wall (UPPER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 513.0 = 35.0 ft head (triangular load)	62.4 pcf		49.5	51	35	-2,756,754		34.02		93,784,771	
	at Lower channel at inlet/bar screen (LOWER TOE): High Groundwater/Saturated soil up to Elev. 505.5, bottom of base at 502.5 = 3.0 ft head (uniform load)	62.4 pcf		25.33	51	3	-241,831		25.5		6,166,680	
	at Lower channel at end wall (LOWER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 505.5 = 42.5 ft head (triangular load)	62.4 pcf		25.33	51	42.5	-1,712,967		34.02		58,275,123	
							-5,184,138		32.85		170,277,527	
							8,203,187	7,403,902		410,561,703	266,531,945	

**Storm Water Pump Station
Stability**

(File: PS Stability.xls with Tabs for Load Cases)

Load Case 3 - Normal

1. Dead loads + equipment + live loads.
2. Maximum design water surface (full inlet) at Elevation 527.3.
3. Drained (dry) backfill.
4. No uplift.

PROJECT:	TRWD - STORM WATER PUMP STATION												
PROJECT NO:	2521-42275-PRSTR.PS												
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005								
CHECKED BY:				DATE:									
STABILITY													
Load Condition 3 - Normal													
(dead loads + equipment + live loads, unsaturated backfill + max. water surface, no uplift)													
		Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight/force (lbs)	Lateral Force (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)	
VERTICAL													
Roof L.L.		55 psf		23	53			67,045		20	1,340,900		
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/ lighting/etc. minus roof openings	50 psf		23	53		4 x 36sf = 144	53,750		20	1,075,000		
Building Walls	12" CMU at 20' height minus vent openings	80 psf		53		20	16 x 16 sf = 256	64,320		9.25	594,960		
	12" CMU at 16.5' avg height minus vent openings	80 psf	2	20		16.5	5 x 16 sf = 80	40,000		19.1	764,000		
	12" CMU at 11.5' height minus vent openings	80 psf		53		11.5	8 x 16 sf = 128	38,520		30.75	1,184,490		
Top Floor Slab L.L.		200 psf		20	50			200,000		20	4,000,000		
Top Floor Slab	18" thick	225 psf		21.5	50			241,875		19.25	4,656,094		
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563 pLF	2	50				56,300		16	900,800		
C.I.P. Walls	Upper exterior end wall - 24" avg thickness El 548.0 to 513.0 = 35' height	300 psf		39.25		35		412,125		31.17	12,845,936		
	Upper exterior side wall - 24" avg thickness El (546.5-538.0) to 513.0 = 29.25' avg height	300 psf		30		29.25		263,250		15.63	4,114,598		
	Lower (deep) exterior end wall - 27" avg thickness El 548.0 to 505.5 = 42.5' height	338 psf		15.08		42.5		216,624		31.17	6,752,176		
	Lower (deep) exterior side wall - 27" avg thickness El (546.5-538.0) to 505.5 = 36.75' avg height	338 psf		30		36.75		372,645		15.58	5,805,809		
	channel divider wall 18" thick El 538.0 to 513.0 = 25' height	225 psf	3	30		25		506,250		15	7,593,750		
	Lower channel divider (side) wall 18" thick	225 psf		30		7.5		50,625		15	759,375		
	Upper counterfort (SOUTH) 24" thick	300 psf	1	5		16		24,000		1	24,000		
	Upper counterfort (MID) 24" thick	300 psf	1	5		16		24,000		16	384,000		
	Upper counterfort (NORTH) 24" thick	300 psf	1	5		16		24,000		31	744,000		
	Lower counterfort (SOUTH) 24" thick	300 psf	1	4.75		23		32,775		1	32,775		
	Lower counterfort (MID) 24" thick	300 psf	1	4.75		23		32,775		16	524,400		
	Lower counterfort (NORTH) 24" thick	300 psf	1	4.75		23		32,775		31	1,016,025		
Base Slab	36" thick	450 psf		75	51			1,721,250		25.5	43,891,875		
Pumps	Upper vertical pumps	30500 lbs	3					91,500		25.5	2,333,250		
	Lower vertical pump	34500 lbs	1					34,500		25.5	879,750		
Trash Racks	at Upper channels w/ 11.33' width each using 55 - 5/8"x6" steel bars x 25' long @ 2.5"c/c	319 lbs	165					52,635		4.25	223,699		
	at Lower channel w/ 11.33' width using 55 - 5/8"x8" steel bars x 32' long @ 2.5"c/c	545 lbs	55					29,975		4.25	127,394		
Soil weight	on Upper Heel Footing (vertical volume, no cone action)	100 pcf		51.17	18.5	35		3,313,258		41.75	138,328,501		
	on Lower Heel Footing (vertical volume, no cone action)	100 pcf		23.83	18	42.5		1,822,995		42	76,565,790		
	on Upper Counterfort Footing (vertical volume, no cone action)	100 pcf	1	30	10	29.25		877,500		15	13,162,500		
	on Lower Counterfort Footing (vertical volume, no cone action)	100 pcf	1	30	9.5	36.75		1,047,375		15	15,710,625		
Water weight	Upper channels w/ Max Design Flow WS Elev. Elev. 527.3 to 513.0 base = 14.3' water height	62.4 pcf	3	30	11.33	14.3		909,899		15	13,648,481		
	Lower channels w/ Max Design Flow WS Elev. Elev. 527.3 to 505.5 base = 21.8' water height	62.4 pcf	1	30	11.33	21.8		462,373		15	6,935,592		
								12,996,118		28.23	366,920,543		
LATERAL													
Unsaturated soil forces	on Upper end wall area. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge	70 pcf		51.17		38			2,586,132	12.65		32,724,912	Assumes moment-arm rotation about bottom of UPPER foundation
(see COUNTERFORT spreadsheet)	on Upper end wall counterfort area only. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	2207 pcf			10	11			242,770	6.47		1,570,722	Assumes moment-arm rotation about bottom of UPPER foundation
	on Lower end wall area. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge	70 pcf		23.83		45.5			1,726,692	15.15		26,161,974	Assumes moment-arm rotation about bottom of LOWER foundation
(see COUNTERFORT spreadsheet)	on Lower end wall counterfort area only. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	2502 pcf			9.5	16			380,304	9.76		3,711,767	Assumes moment-arm rotation about bottom of LOWER foundation
								4,935,898		13.00		64,169,375	
								12,996,118	4,935,898		366,920,543	64,169,375	

Storm Water Pump Station

Stability

(File: PS Stability.xls with Tabs for Load Cases)

Load Case 4 - Normal

1. Dead loads + equipment.
2. No live loads, low water (empty inlet).
3. Undrained (saturated) backfill.
4. Uplift

PROJECT:	TRWD - STORM WATER PUMP STATION												
PROJECT NO:	2521-42275-PRSTR.PS												
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005								
CHECKED BY:				DATE:									
STABILITY													
Load Condition 4 - Normal													
(dead loads + equipment loads, no live loads saturated backfill + low water/empty + uplift)													
	Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight/force (lbs)	Lateral Force (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)		
VERTICAL													
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/lighting/etc. minus roof openings	50 psf	23	53		4 x 36sf = 144	53,750		20	1,075,000			
Building Walls	12" CMU at 20' height minus vent openings	80 psf			20	16 x 16 sf = 256	64,320		9.25	594,960			
	12" CMU at 16.5' avg height minus vent openings	80 psf	2	20	16.5	5 x 16 sf = 80	40,000		19.1	764,000			
	12" CMU at 11.5' height minus vent openings	80 psf		53	11.5	8 x 16 sf = 128	38,520		30.75	1,184,490			
Top Floor Slab	18" thick	225 psf		50			241,875		19.25	4,656,094			
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563 pLF	2	50			56,300		16	900,800			
C.I.P. Walls	Upper exterior end wall - 24" avg thickness El 548.0 to 513.0 =35' height	300 psf		39.25			412,125		31.17	12,845,936			
	Upper exterior side wall - 24" avg thickness El (546.5-538.0) to 513.0 =29.25' avg height	300 psf		30		29.25	263,250		15.63	4,114,598			
	Lower (deep) exterior end wall - 27" avg thickness El 548.0 to 505.5 =42.5' height	338 psf		15.08		42.5		216,624		31.17	6,752,176		
	Lower (deep) exterior side wall - 27" avg thickness El (546.5-538.0) to 505.5 =36.75' avg height	338 psf		30		36.75		372,645		15.58	5,805,809		
	channel divider wall 18" thick El 538.0 to 513.0 =25' height	225 psf	3	30		25		506,250		15	7,593,750		
	Lower channel divider (side) wall 18" thick	225 psf		30		7.5		50,625		15	759,375		
	Upper counterfort (SOUTH) 24" thick	300 psf	1	5		16		24,000		1	24,000		
	Upper counterfort (MID) 24" thick	300 psf	1	5		16		24,000		16	384,000		
	Upper counterfort (NORTH) 24" thick	300 psf	1	5		16		24,000		31	744,000		
	Lower counterfort (SOUTH) 24" thick	300 psf	1	4.75		23		32,775		1	32,775		
	Lower counterfort (MID) 24" thick	300 psf	1	4.75		23		32,775		16	524,400		
	Lower counterfort (NORTH) 24" thick	300 psf	1	4.75		23		32,775		31	1,016,025		
	Base Slab	36" thick	450 psf		75	51		1,721,250		25.5	43,891,875		
	Pumps	upper vertical pumps	30500 lbs	3				91,500		25.5	2,333,250		
lower vertical pump		34500 lbs	1				34,500		25.5	879,750			
Trash Racks	at Upper channels w/ 11.33' width each using 55 ~ 5/8"x6" steel bars x 25' long @ 2.5"c/c	319 lbs	165				52,635		4.25	223,699			
	at Lower channel w/ 11.33' width using 55 ~ 5/8"x8" steel bars x 32' long @ 2.5"c/c	545 lbs	55				29,975		4.25	127,394			
Soil weight	on Upper Heel Footing (vertical volume, no cone action)	130 pcf		51.17	18.5	35	4,307,235		41.75	179,827,051			
	on Lower Heel Footing (vertical volume, no cone action)	130 pcf		23.83	18	42.5	2,369,894		42	99,535,527			
	on Upper Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	10	29.25	1,140,750		15	17,111,250			
	on Lower Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	9.5	36.75	1,361,588		15	20,423,813			
							13,595,935		30.46	414,125,796			
LATERAL													
Saturated soil forces	on Upper end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 psf		51.17		38		3,879,198	12.65		49,087,368	Assumes moment-arm rotation about bottom of UPPER foundation	
(see COUNTERFORT spreadsheet)	on Upper end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3311 psf			10	11		364,210	6.47		2,356,439	Assumes moment-arm rotation about bottom of UPPER foundation	
	on Lower end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 psf		23.83		45.5		2,590,038	15.15		39,242,961	Assumes moment-arm rotation about bottom of LOWER foundation	
(see COUNTERFORT spreadsheet)	on Lower end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3753 psf			9.5	16		570,456	9.76		5,567,651	Assumes moment-arm rotation about bottom of LOWER foundation	
								7,403,902	13.00		96,254,418		
UPLIFT													
Uplift	at Upper channel at inlet/bar screen (UPPER TOE): High Groundwater/Saturated soil up to Elev. 513.0, bottom of base at 510.0 = 3.0 ft head (uniform load)	62.4 pcf		49.5	51	3	-472,586		25.5		12,050,953		
	at Upper channel at end wall (UPPER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 513.0 = 35.0 ft head (triangular load)	62.4 pcf		49.5	51	35	-2,756,754		34.02		93,784,771		
	at Lower channel at inlet/bar screen (LOWER TOE): High Groundwater/Saturated soil up to Elev. 505.5, bottom of base at 502.5 = 3.0 ft head (uniform load)	62.4 pcf		25.33	51	3	-241,831		25.5		6,166,680		
	at Lower channel at end wall (LOWER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 505.5 = 42.5 ft head (triangular load)	62.4 pcf		25.33	51	42.5	-1,712,967		34.02		58,275,123		
							-5,184,138		32.85		170,277,527		
							8,411,797	7,403,902		414,125,796	266,531,945		

Section 5

Bearing Pressure

Storm Water Pump Station

Bearing Pressure

(File: PS Bearing Pressure.xls)

PROJECT:	TRWD - STORM WATER PUMP STATION									
PROJECT NO:	2521-42275-PRSTR.PS									
DESIGNED BY:	E. BJORKLUND									
CHECKED BY:										
				DATE:	1/18/2005					
				DATE:						
Values from STABILITY spreadsheet										
	Fdn Length	Fdn Width	Weight	Lateral force	Mom. Resist	Mom. Overturn				
	ft	ft	lbs	lbs	lb-ft	lb-ft				
Case 1	51	75	4,416,469	0	97,228,155	0				
Case 2	51	75	8,203,187	7,403,902	410,561,703	266,531,945				
Case 3	51	75	12,996,118	4,935,898	366,920,543	64,169,375				
Case 4	51	75	8,411,797	7,403,902	414,125,796	266,531,945				
friction coefficient =	0.4									
sliding ratio =	(weight x friction coeff) / lateral force =									
overturning ratio =	moment resist / moment overturn =									
eccentricity (from CL) (ft) =	1/2 Fdn length - (moment resist - moment overturn) / weight =									
bearing pressure (psf) =	((weight / Fdn length) x (1 +/- (6 x (eccen / Fdn length)))) / Fdn width =									
max bearing pressure (psf) =	((weight / Fdn length) x (1 + (6 x (eccen / Fdn length)))) / Fdn width =									
min bearing pressure (psf) =	((weight / Fdn length) x (1 - (6 x (eccen / Fdn length)))) / Fdn width =									
							Case 1	Case 2	Case 3	Case 4
							n/a	0.44	1.05	0.45
							n/a	1.54	5.72	1.55
							3.49	7.94	2.20	7.95
							1628	4149	4279	4257
							681	141	2516	141

Section 6

Cell Formulas for Excel Spreadsheets

CELL FORMULAS FOR EXCEL SPREADSHEETS

(Exception is the Center of Gravity (CG) spreadsheets, which were produced using a freeware spreadsheet with the sheet protected by the author)

PROJECT:	TRWD - STORM WATER PUMP STATION							
PROJECT NO:	2521-42275-PRSTR.PS							
DESIGNED BY:	E. BJORKLUND				DATE:	1/17/2005		
CHECKED BY:					DATE:			
UPPER COUNTERFORT								
E.F.P.=	70	psf / ft of depth						
Depth =	38	ft from grade to upper counterfort base						
Centroid =	6.47	ft from centroid to upper counterfort base - SEE CG SPREADSHEET						
Section Trapezoid	ground to centroid =B9-B10	pressure at centroid		Section Area	Total Force on Area =C13*D13	Centroid Location =B10	Moment Arm about upper slab =F13	Moment =E13*G13
LOWER COUNTERFORT								
E.F.P.=	70	psf / ft of depth						
Depth =	45.5	ft from grade to base						
Centroid =	9.76	ft from centroid to base - SEE CG SPREADSHEET						
Section Trapezoid	ground to centroid =B18-B19	pressure at centroid		Section Area	Total Force on Area =C22*D22	Centroid Location =B19	Moment Arm about lower slab =F22	Moment =E22*G22
UPPER COUNTERFORT								
E.F.P.=	105	psf / ft of depth						
Depth =	38	ft from grade to upper counterfort base						
Centroid =	6.47	ft from centroid to upper counterfort base - SEE CG SPREADSHEET						
Section Trapezoid	ground to centroid =B30-B31	pressure at centroid		Section Area	Total Force on Area =C34*D34	Centroid Location =B31	Moment Arm about upper slab =F34	Moment =E34*G34
LOWER COUNTERFORT								
E.F.P.=	105	psf / ft of depth						
Depth =	45.5	ft from grade to base						
Centroid =	9.76	ft from centroid to base - SEE CG SPREADSHEET						
Section Trapezoid	ground to centroid =B39-B40	pressure at centroid		Section Area	Total Force on Area =C43*D43	Centroid Location =B40	Moment Arm about lower slab =F43	Moment =E43*G43

**Storm Water Pump Station
Stability
Excel Spreadsheet with Cell Formulas Displayed**

PROJECT:	TRWD - STORM WATER PUMP STATION										
PROJECT NO:	2521-42275-PRSTR.PS										
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005						
CHECKED BY:				DATE:							
STABILITY											
Load Condition 1 - During Construction											
(dead loads + equipment loads, no live loads no soil, no water)											
		Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)
VERTICAL											
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/ lighting/etc. minus roof openings	50	psf	23	53		4 x 36sf = 144	=C11*((F11*G11)-J11)	20	=K11*L11	
Building Walls	12" CMU at 20' height minus vent openings	80	psf	53		20	16 x 16 sf = 256	=C12*((F12*H12)-J12)	9.25	=K12*L12	
	12" CMU at 16.5' avg height minus vent openings	80	psf	2	20	16.5	5 x 16 sf = 80	=C13*E13*((F13*H13)-J13)	19.1	=K13*L13	
	12" CMU at 11.5' height minus vent openings	80	psf	53		11.5	8 x 16 sf = 128	=C14*((F14*H14)-J14)	30.75	=K14*L14	
Top Floor Slab	18" thick	225	psf	21.5	50			=C15*F15*G15	19.25	=K15*L15	
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563	pLF	2	50			=C16*E16*F16	16	=K16*L16	
C.I.P. Walls	Upper exterior end wall - 24" avg thickness EI 548.0 to 513.0 =35' height	300	psf	39.25		35		=C17*F17*H17	31.17	=K17*L17	
	Upper exterior side wall - 24" avg thickness EI (546.5-538.0) to 513.0 =29.25' avg height	300	psf	30		29.25		=C18*F18*H18	15.63	=K18*L18	
	Lower (deep) exterior end wall - 27" avg thickness EI 548.0 to 505.5 =42.5' height	338	psf	15.08		42.5		=C19*F19*H19	31.17	=K19*L19	
	Lower (deep) exterior side wall - 27" avg thickness EI (546.5-538.0) to 505.5 =36.75' avg height	338	psf	30		36.75		=C20*F20*H20	15.58	=K20*L20	
	channel divider wall 18" thick EI 538.0 to 513.0 =25' height	225	psf	3	30	25		=C21*E21*F21*H21	15	=K21*L21	
	Lower channel divider (side) wall 18" thick	225	psf	30		7.5		=C22*F22*H22	15	=K22*L22	
	Upper counterfort (SOUTH) 24" thick	300	psf	1	5	16		=C23*F23*H23	1	=K23*L23	
	Upper counterfort (MID) 24" thick	300	psf	1	5	16		=C24*F24*H24	16	=K24*L24	
	Upper counterfort (NORTH) 24" thick	300	psf	1	5	16		=C25*F25*H25	31	=K25*L25	
	Lower counterfort (SOUTH) 24" thick	300	psf	1	4.75	23		=C26*F26*H26	1	=K26*L26	
	Lower counterfort (MID) 24" thick	300	psf	1	4.75	23		=C27*F27*H27	16	=K27*L27	
	Lower counterfort (NORTH) 24" thick	300	psf	1	4.75	23		=C28*F28*H28	31	=K28*L28	
Base Slab	36" thick	450	psf	75	51			=C29*F29*G29	25.5	=K29*L29	
Pumps	Upper vertical pumps	30500	lbs	3				=C30*E30	25.5	=K30*L30	
	Lower vertical pump	34500	lbs	1				=C31*E31	25.5	=K31*L31	
Trash Racks	at Upper channels w/ 11.33' width each using 55 ~ 5/8"x6" steel bars x 25' long @ 2.5"c/c	319	lbs	165				=C32*E32	4.25	=K32*L32	
	at Lower channel w/ 11.33' width using 55 ~ 5/8"x8" steel bars x 32' long @ 2.5"c/c	545	lbs	55				=C33*E33	4.25	=K33*L33	
								=SUM(K11:K33)	=M34/K34	=SUM(M11:M33)	

PROJECT:	TRWD - STORM WATER PUMP STATION												
PROJECT NO:	2521-42275-PRSTR.PS												
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005								
CHECKED BY:				DATE:									
STABILITY													
Load Condition 2 - During Construction/Maintenance													
(dead loads, no equipment, no live loads saturated backfill + low water/empty + uplift)													
		Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight/force (lbs)	Lateral Force (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)	
VERTICAL													
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/lighting/etc. minus roof openings	50 psf		23	53		4 x 36sf = 144	=C11*(F11*G11)-J11		20	=K11*M11		
Building Walls	12" CMU at 20' height minus vent openings	80 psf		53		20	16 x 16 sf = 256	=C12*(F12*H12)-J12		9.25	=K12*M12		
	12" CMU at 16.5' avg height minus vent openings	80 psf	2	20		16.5	5 x 16 sf = 80	=C13*E13*(F13*H13)-J13		19.1	=K13*M13		
	12" CMU at 11.5' height minus vent openings	80 psf		53		11.5	8 x 16 sf = 128	=C14*(F14*H14)-J14		30.75	=K14*M14		
Top Floor Slab	18" thick	225 psf		21.5	50			=C15*F15*G15		19.25	=K15*M15		
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563 pLF	2	50				=C16*E16*F16		16	=K16*M16		
C.I.P. Walls	Upper exterior end wall - 24" avg thickness EI 548.0 to 513.0 =35' height	300 psf		39.25		35		=C17*F17*H17		31.17	=K17*M17		
	Upper exterior side wall - 24" avg thickness EI (546.5-538.0) to 513.0 =29.25' avg height	300 psf		30		29.25		=C18*F18*H18		15.63	=K18*M18		
	Lower (deep) exterior end wall - 27" avg thickness EI 548.0 to 505.5 =42.5' height	338 psf		15.08		42.5		=C19*F19*H19		31.17	=K19*M19		
	Lower (deep) exterior side wall - 27" avg thickness EI (546.5-538.0) to 505.5 =36.75' avg height	338 psf		30		36.75		=C20*F20*H20		15.58	=K20*M20		
	channel divider wall 18" thick EI 538.0 to 513.0 =25' height	225 psf	3	30		25		=C21*E21*F21*H21		15	=K21*M21		
	Lower channel divider (side) wall 18" thick	225 psf		30		7.5		=C22*F22*H22		15	=K22*M22		
	Upper counterfort (SOUTH) 24" thick	300 psf	1	5		16		=C23*F23*H23		1	=K23*M23		
	Upper counterfort (MID) 24" thick	300 psf	1	5		16		=C24*F24*H24		16	=K24*M24		
	Upper counterfort (NORTH) 24" thick	300 psf	1	5		16		=C25*F25*H25		31	=K25*M25		
	Lower counterfort (SOUTH) 24" thick	300 psf	1	4.75		23		=C26*F26*H26		1	=K26*M26		
	Lower counterfort (MID) 24" thick	300 psf	1	4.75		23		=C27*F27*H27		16	=K27*M27		
	Lower counterfort (NORTH) 24" thick	300 psf	1	4.75		23		=C28*F28*H28		31	=K28*M28		
Base Slab	36" thick	450 psf		75	51			=C29*F29*G29		25.5	=K29*M29		
Soil weight	on Upper Heel Footing (vertical volume, no cone action)	130 pcf		51.17	18.5	35		=C30*F30*G30*H30		41.75	=K30*M30		
	on Lower Heel Footing (vertical volume, no cone action)	130 pcf		23.83	18	42.5		=C31*F31*G31*H31		42	=K31*M31		
	on Upper Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	10	29.25		=C32*E32*F32*G32*H32		15	=K32*M32		
	on Lower Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	9.5	36.75		=C33*E33*F33*G33*H33		15	=K33*M33		
								=SUM(K11:K33)		=N34/K34	=SUM(N11:N33)		
LATERAL													
Saturated soil forces	on Upper end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 pcf		51.17		38			=C36*H36^2/2*F36	=H36*0.333		=L36*M36	Assumes moment-arm rotation about bottom of UPPER foundation
(see COUNTERFORT spreadsheet)	on Upper end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3311 pcf			10	11			=C37*G37*H37	6.47		=L37*M37	Assumes moment-arm rotation about bottom of UPPER foundation
	on Lower end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 pcf		23.83		45.5			=C38*H38^2/2*F38	=H38*0.333		=L38*M38	Assumes moment-arm rotation about bottom of LOWER foundation
(see COUNTERFORT spreadsheet)	on Lower end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3753 pcf			9.5	16			=C39*G39*H39	9.76		=L39*M39	Assumes moment-arm rotation about bottom of LOWER foundation
									=SUM(L36:L39)	=O40/L40		=SUM(O36:O39)	
UPLIFT													
Uplift	at Upper channel at inlet/bar screen (UPPER TOE): High Groundwater/Saturated soil up to Elev. 513.0, bottom of base at 510.0 = 3.0 ft head (uniform load)	62.4 pcf		49.5	51	3			=C42*F42*G42*H42	25.5		=-K42*M42	
	at Upper channel at end wall (UPPER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 513.0 = 35.0 ft head (triangular load)	62.4 pcf		49.5	51	35			=-0.5*(C43*F43*G43*H43)	34.02		=-K43*M43	
	at Lower channel at inlet/bar screen (LOWER TOE): High Groundwater/Saturated soil up to Elev. 505.5, bottom of base at 502.5 = 3.0 ft head (uniform load)	62.4 pcf		25.33	51	3			=-C44*F44*G44*H44	25.5		=-K44*M44	
	at Lower channel at end wall (LOWER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 505.5 = 42.5 ft head (triangular load)	62.4 pcf		25.33	51	42.5			=-0.5*(C45*F45*G45*H45)	34.02		=-K45*M45	
									=SUM(K42:K45)	=O46/-K46		=SUM(O42:O45)	
									=K34+K46	=L40		=N34	=O40+O46

PROJECT:	TRWD - STORM WATER PUMP STATION												
PROJECT NO:	2521-42275-PRSTR.PS												
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005								
CHECKED BY:				DATE:									
STABILITY													
Load Condition 3 - Normal													
(dead loads + equipment + live loads, unsaturated backfill + low water/empty, no uplift)													
	Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight/force (lbs)	Lateral Force (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturing Moment (lbs-ft)		
VERTICAL													
Roof L.L.			23	53			=C11*F11*G11		20	=K11*M11			
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/lighting/etc. minus roof openings	50	23	53		4 x 36sf = 144	=C12*((F12*G12)-J12)		20	=K12*M12			
Building Walls	12" CMU at 20' height minus vent openings	80	53		20	16 x 16 sf = 256	=C13*((F13*H13)-J13)		9.25	=K13*M13			
	12" CMU at 16.5' avg height minus vent openings	80	20		16.5	5 x 16 sf = 80	=C14*E14*((F14*H14)-J14)		19.1	=K14*M14			
	12" CMU at 11.5' height minus vent openings	80	53		11.5	8 x 16 sf = 128	=C15*((F15*H15)-J15)		30.75	=K15*M15			
Top Floor Slab L.L.		200	20	50			=C16*F16*G16		20	=K16*M16			
Top Floor Slab	18" thick	225	21.5	50			=C17*F17*G17		19.25	=K17*M17			
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563	50				=C18*E18*F18		16	=K18*M18			
C.I.P. Walls	Upper exterior end wall - 24" avg thickness EI 548.0 to 513.0 =35' height	300	39.25		35		=C19*F19*H19		31.17	=K19*M19			
	Upper exterior side wall - 24" avg thickness EI (546.5-538.0) to 513.0 =29.25' avg height	300	30		29.25		=C20*F20*H20		15.63	=K20*M20			
	Lower (deep) exterior end wall - 27" avg thickness EI 548.0 to 505.5 =42.5' height	338	15.08		42.5		=C21*F21*H21		31.17	=K21*M21			
	Lower (deep) exterior side wall - 27" avg thickness EI (546.5-538.0) to 505.5 =36.75' avg height	338	30		36.75		=C22*F22*H22		15.58	=K22*M22			
	channel divider wall 18" thick EI 538.0 to 513.0 =25' height	225	30		25		=C23*E23*F23*H23		15	=K23*M23			
	Lower channel divider (side) wall 18" thick	225	30		7.5		=C24*F24*H24		15	=K24*M24			
	Upper counterfort (SOUTH) 24" thick	300	5		16		=C25*F25*H25		1	=K25*M25			
	Upper counterfort (MID) 24" thick	300	5		16		=C26*F26*H26		16	=K26*M26			
	Upper counterfort (NORTH) 24" thick	300	5		16		=C27*F27*H27		31	=K27*M27			
	Lower counterfort (SOUTH) 24" thick	300	4.75		23		=C28*F28*H28		1	=K28*M28			
	Lower counterfort (MID) 24" thick	300	4.75		23		=C29*F29*H29		16	=K29*M29			
	Lower counterfort (NORTH) 24" thick	300	4.75		23		=C30*F30*H30		31	=K30*M30			
Base Slab	36" thick	450	75	51			=C31*F31*G31		25.5	=K31*M31			
Pumps	Upper vertical pumps	30500	3				=C32*E32		25.5	=K32*M32			
	Lower vertical pump	34500	1				=C33*E33		25.5	=K33*M33			
Trash Racks	at Upper channels w/ 11.33' width each using 55 ~ 5/8"x6" steel bars x 25' long @ 2.5'c/c	319	165				=C34*E34		4.25	=K34*M34			
	at Lower channel w/ 11.33' width using 55 ~ 5/8"x8" steel bars x 32' long @ 2.5'c/c	545	55				=C35*E35		4.25	=K35*M35			
Soil weight	on Upper Heel Footing (vertical volume, no cone action)	100	51.17	18.5	35		=C36*F36*G36*H36		41.75	=K36*M36			
	on Lower Heel Footing (vertical volume, no cone action)	100	23.83	18	42.5		=C37*F37*G37*H37		42	=K37*M37			
	on Upper Counterfort Footing (vertical volume, no cone action)	100	30	10	29.25		=C38*E38*F38*G38*H38		15	=K38*M38			
	on Lower Counterfort Footing (vertical volume, no cone action)	100	30	9.5	36.75		=C39*E39*F39*G39*H39		15	=K39*M39			
Water weight	Upper channels w/ Max Design Flow WS Elev. Elev. 527.3 to 513.0 base = 14.3' water height	62.4	30	11.33	14.3		=C40*E40*F40*G40*H40		15	=K40*M40			
	Lower channels w/ Max Design Flow WS Elev. Elev. 527.3 to 505.5 base = 21.8' water height	62.4	30	11.33	21.8		=C41*E41*F41*G41*H41		15	=K41*M41			
							=SUM(K13:K41)		=N42/K42	=SUM(N11:N41)			
LATERAL													
Unsaturated soil forces	on Upper end wall area. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge	70	51.17		38			=C44*H44^2/2*F44	=H44*0.333		=L44*M44		Assumes moment-arm rotation about bottom of UPPER foundation
(see COUNTERFORT spreadsheet)	on Upper end wall counterfort area only. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	2207			10	11		=C45*G45*H45	6.47		=L45*M45		Assumes moment-arm rotation about bottom of UPPER foundation
	on Lower end wall area. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge	70	23.83		45.5			=C46*H46^2/2*F46	=H46*0.333		=L46*M46		Assumes moment-arm rotation about bottom of LOWER foundation
(see COUNTERFORT spreadsheet)	on Lower end wall counterfort area only. Pressure of 70 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	2502			9.5	16		=C47*G47*H47	9.76		=L47*M47		Assumes moment-arm rotation about bottom of LOWER foundation
							=SUM(L44:L47)	=O48/L48			=SUM(O44:O47)		
							=K42	=L48		=N42	=O48		

PROJECT:	TRWD - STORM WATER PUMP STATION												
PROJECT NO:	2521-42275-PRSTR.PS												
DESIGNED BY:	E. BJORKLUND			DATE:	1/18/2005								
CHECKED BY:				DATE:									
STABILITY													
Load Condition 4 - Normal													
(dead loads + equipment loads, no live loads saturated backfill + low water/empty + uplift)													
		Unit force	Quantity	Total or Avg Length (ft)	Total or Avg Width (ft)	Total or Avg Height (ft)	Removed portions	Weight/force (lbs)	Lateral Force (lbs)	Moment Arm to Toe (ft)	Resisting Moment (lbs-ft)	Overturning Moment (lbs-ft)	
VERTICAL													
Roof D.L.	lt wt conc on metal deck/bar joists at 6' spacing/ lighting/etc. minus roof openings	50 psf		23	53		4 x 36sf = 144	=C11*((F11*G11)-J11)		20	=K11*M11		
Building Walls	12" CMU at 20' height minus vent openings	80 psf		53		20	16 x 16 sf = 256	=C12*((F12*H12)-J12)		9.25	=K12*M12		
	12" CMU at 16.5' avg height minus vent openings	80 psf	2	20		16.5	5 x 16 sf = 80	=C13*E13*((F13*H13)-J13)		19.1	=K13*M13		
	12" CMU at 11.5' height minus vent openings	80 psf		53		11.5	8 x 16 sf = 128	=C14*((F14*H14)-J14)		30.75	=K14*M14		
Top Floor Slab	18" thick	225 psf		21.5	50			=C15*F15*G15		19.25	=K15*M15		
Top Floor Beams	2 beams at 2.5' x 1.5' each (beneath slab)	563 pLF	2	50				=C16*E16*F16		16	=K16*M16		
C.I.P. Walls	Upper exterior end wall - 24" avg thickness EI 548.0 to 513.0 =35' height	300 psf		39.25		35		=C17*F17*H17		31.17	=K17*M17		
	Upper exterior side wall - 24" avg thickness EI (546.5-538.0) to 513.0 =29.25' avg height	300 psf		30		29.25		=C18*F18*H18		15.63	=K18*M18		
	Lower (deep) exterior end wall - 27" avg thickness EI 548.0 to 505.5 =42.5' height	338 psf		15.08		42.5		=C19*F19*H19		31.17	=K19*M19		
	Lower (deep) exterior side wall - 27" avg thickness EI (546.5-538.0) to 505.5 =36.75' avg height	338 psf		30		36.75		=C20*F20*H20		15.58	=K20*M20		
	channel divider wall 18" thick EI 538.0 to 513.0 =25' height	225 psf	3	30		25		=C21*E21*F21*H21		15	=K21*M21		
	Lower channel divider (side) wall 18" thick	225 psf		30		7.5		=C22*F22*H22		15	=K22*M22		
	Upper counterfort (SOUTH) 24" thick	300 psf	1	5		16		=C23*F23*H23		1	=K23*M23		
	Upper counterfort (MID) 24" thick	300 psf	1	5		16		=C24*F24*H24		16	=K24*M24		
	Upper counterfort (NORTH) 24" thick	300 psf	1	5		16		=C25*F25*H25		31	=K25*M25		
	Lower counterfort (SOUTH) 24" thick	300 psf	1	4.75		23		=C26*F26*H26		1	=K26*M26		
	Lower counterfort (MID) 24" thick	300 psf	1	4.75		23		=C27*F27*H27		16	=K27*M27		
	Lower counterfort (NORTH) 24" thick	300 psf	1	4.75		23		=C28*F28*H28		31	=K28*M28		
Base Slab	36" thick	450 psf		75		51		=C29*F29*G29		25.5	=K29*M29		
Pumps	upper vertical pumps	30500 lbs	3					=C30*E30		25.5	=K30*M30		
	lower vertical pump	34500 lbs	1					=C31*E31		25.5	=K31*M31		
Trash Racks	at Upper channels w/ 11.33' width each using 55 - 5/8"x6" steel bars x 25' long @ 2.5"c/c	319 lbs	165					=C32*E32		4.25	=K32*M32		
	at Lower channel w/ 11.33' width using 55 - 5/8"x8" steel bars x 32' long @ 2.5"c/c	545 lbs	55					=C33*E33		4.25	=K33*M33		
Soil weight	on Upper Heel Footing (vertical volume, no cone action)	130 pcf		51.17	18.5	35		=C34*F34*G34*H34		41.75	=K34*M34		
	on Lower Heel Footing (vertical volume, no cone action)	130 pcf		23.83	18	42.5		=C35*F35*G35*H35		42	=K35*M35		
	on Upper Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	10	29.25		=C36*E36*F36*G36*H36		15	=K36*M36		
	on Lower Counterfort Footing (vertical volume, no cone action)	130 pcf	1	30	9.5	36.75		=C37*E37*F37*G37*H37		15	=K37*M37		
								=SUM(K11:K37)		=N38/K38	=SUM(N11:N37)		
LATERAL													
Saturated soil forces	on Upper end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 psf		51.17		38			=C40*H40^2/2*F40	=H40*0.333		=L40*M40	Assumes moment-arm rotation about bottom of UPPER foundation
(see COUNTERFORT spreadsheet)	on Upper end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3311 psf			10	11			=C41*G41*H41	6.47		=L41*M41	Assumes moment-arm rotation about bottom of UPPER foundation
	on Lower end wall area. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge	105 psf		23.83		45.5			=C42*H42^2/2*F42	=H42*0.333		=L42*M42	Assumes moment-arm rotation about bottom of LOWER foundation
(see COUNTERFORT spreadsheet)	on Lower end wall counterfort area only. Pressure of 105 psf is per CTWALL results, includes effects from 260 psf surface surcharge. Unit force shown is at centroid of counterfort area.	3753 psf			9.5	16			=C43*G43*H43	9.76		=L43*M43	Assumes moment-arm rotation about bottom of LOWER foundation
								=SUM(L40:L43)		=O44/L44		=SUM(O40:O43)	
UPLIFT													
Uplift	at Upper channel at inlet/bar screen (UPPER TOE): High Groundwater/Saturated soil up to Elev. 513.0, bottom of base at 510.0 = 3.0 ft head (uniform load)	62.4 pcf		49.5	51	3		=-C46*F46*G46*H46		25.5		=-K46*M46	
	at Upper channel at end wall (UPPER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 513.0 = 35.0 ft head (triangular load)	62.4 pcf		49.5	51	35		=-0.5*(C47*F47*G47*H47)		34.02		=-K47*M47	
	at Lower channel at inlet/bar screen (LOWER TOE): High Groundwater/Saturated soil up to Elev. 505.5, bottom of base at 502.5 = 3.0 ft head (uniform load)	62.4 pcf		25.33	51	3		=-C48*F48*G48*H48		25.5		=-K48*M48	
	at Lower channel at end wall (LOWER HEEL): High Groundwater/Saturated soil up to Elev. 548.0, bottom of base at 505.5 = 42.5 ft head (triangular load)	62.4 pcf		25.33	51	42.5		=-0.5*(C49*F49*G49*H49)		34.02		=-K49*M49	
								=SUM(K46:K49)		=O50/-K50		=SUM(O46:O49)	
								=K38+K50	=L44		=N38	=O44+O50	

**Storm Water Pump Station
Bearing Pressure Analysis
Excel Spreadsheet with Cell Formulas Displayed**

PROJECT:	TRWD - STORM WATER PUMP STATION							
PROJECT NO:	2521-42275-PRSTR.PS							
DESIGNED BY:	E. BJORKLUND				DATE:	1/18/2005		
CHECKED BY:					DATE:			
Values from STABILITY spreadsheet								
	Fdn Length ft	Fdn Width ft	Weight lbs	Lateral force lbs	Mom. Resist lb-ft	Mom. Overturn lb-ft		
Case 1	51	75	4416469	0	97228155	0		
Case 2	51	75	8203187	7403902	410561703	266531945		
Case 3	51	75	12996118	4935898	366920543	64169375		
Case 4	51	75	8411797	7403902	414125796	266531945		
friction coefficient = 0.4								
sliding ratio =	(weight x friction coeff) / lateral force =				Case 1	Case 2	Case 3	Case 4
overturning ratio =	moment resist / moment overturn =				n/a	=(D10*B16)/E10	=(D11*B16)/E11	=(D12*B16)/E12
eccentricity (from CL) (ft) =	1/2 Fdn length - (moment resist - moment overturn) / weight =				n/a	=F10/G10	=F11/G11	=F12/G12
bearing pressure (psf) =	((weight / Fdn length) x (1 + (6 x (eccen / Fdn length)))) / Fdn width =				=(0.5*B9)-((F9-G9)/D9)	=(0.5*B10)-((F10-G10)/D10)	=(0.5*B11)-((F11-G11)/D11)	=(0.5*B12)-((F12-G12)/D12)
max bearing pressure (psf) =	((weight / Fdn length) x (1 + (6 x (eccen / Fdn length)))) / Fdn width =				=(D9/B9)*(1+(6*(G20/B9)))/C9	=(D10/B10)*(1+(6*(H20/B10)))/C10	=(D11/B11)*(1+(6*(I20/B11)))/C11	=(D12/B12)*(1+(6*(J20/B12)))/C12
min bearing pressure (psf) =	((weight / Fdn length) x (1 - (6 x (eccen / Fdn length)))) / Fdn width =				=(D9/B9)*(1-(6*(G20/B9)))/C9	=(D10/B10)*(1-(6*(H20/B10)))/C10	=(D11/B11)*(1-(6*(I20/B11)))/C11	=(D12/B12)*(1-(6*(J20/B12)))/C12

Section 7
Design of H-Piles
(Manual Calculations)

**Design of Steel H-Piles
(Manual Calculations)**



CLIENT TRWD-FWCC
PROJECT Storm Water P.S.
DETAIL Foundation Design

JOB NO. 2521-42275
DATE CHECKED _____
CHECKED BY _____

COMPUTER BY E. Bjorklund
DATE _____
PAGE NO. _____

From results of stability spreadsheets:

CASE 1 Vertical Summary = 4146^k
 Horiz. (Lateral) Summary = N/A

CASE 2 Vertical Summary = 5714^k
 Horiz. (Lateral) Summary = 7404^k

CASE 3 Vertical Summary = 12996^k ← controls
 Horiz. (Lateral) Summary = 4936^k


CASE 4 Vertical Summary = 5923^k
 Horiz. (Lateral) Summary = 7404^k ← controls

Need to determine number of piles required.

Number of H-piles

Assume: HP 14 x 102 piles for analysis

- : Max stress = 10 ksi
- : Area = 30 in²
- ∴ P_{max} = 300 k each



$$\text{Number of piles} = \frac{12996^k \text{ vert}}{268^k \text{ per pile vert.}} = 48.5, \text{ say } 50 \text{ piles}$$

$$\frac{7404^k \text{ lateral}}{134^k \text{ per pile lat.}} = 55.3, \text{ say } 60 \text{ piles} \leftarrow \text{controls}$$

Piles per Row

$$\frac{75' \text{ foundation width}}{5' \text{ pile spacing}} = 15 \text{ piles}$$

Number of Rows

$$\frac{60 \text{ piles needed}}{15 \text{ piles/row}} = 4 \text{ rows to resist controlling lateral load}$$

Suggest adding some number of piles symmetrically to provide for balanced distribution

Section 8

Seismic Load Case Check

**Stability Analysis
Seismic Load Case Check
(Manual Calculations)**



CLIENT: FWCC
 PROJECT: PUMP STATION SEISMIC
 DETAIL: PUMP STATION SEISMIC

JOB NO. _____
 DATE CHECKED _____
 CHECKED BY _____

COMPUTED BY _____
 DATE: 1-19-05
 PAGE NO. _____

SEISMIC ANALYSIS AT PUMP STATION:

HORIZ. GROUND ACCELERATION = 0.05g

NEGLECT K_v

$\psi = \tan^{-1}(K_h) = 2.86$

$\phi_d = 24.85^\circ$

$K_{AE} = 0.442$

STATIC $K_A = 0.408$

$\Delta K_{AE} = K_{AE} - K_A = 0.034$

REFER TO
 SEISMIC
 ANALYSIS
 AT FLOODWALLS

INERTIA OF MASS (CONC, EQUIP, & SOIL) = 0.05(13,595,935) = 679,797. lbs
 FROM LOAD CONDITION 4

SOIL PRESSURES w/ F.S. = 1.10:

$P_{AE} = P_A + P_{ws} + \Delta P_{AE}$

$= \frac{1}{2} K_A \gamma_b h^2 + \frac{1}{2} \gamma_w h^2 + \frac{1}{2} \Delta K_{AE} \gamma h^2$

$= \frac{1}{2} (0.408) \left(\frac{130-62.5}{1000} \right) (38)^2 + \frac{1}{2} (0.0625) (38)^2 + \frac{1}{2} (0.034) (0.130) (38)^2$

$= 19.9 + 4511 + 3.2 = 68.2 \text{ k/ft} \quad \times 75' \text{ WIDTH} = 5115 \text{ k}$

NOTE: CONSIDER ^{SOIL} PRESSURES ABOVE EL. 510.0 AND FOR 75' WIDTH ONLY FOR PRELIMINARY STUDY.

TOTAL ^{SEISMIC} LATERAL FORCE = 680 + 5115 = 5795 k

EQUIVALENT STATIC LATERAL FORCE USED IN LOAD CONDITION 4

$= \frac{1}{2} (0.105) (38)^2 = 75.8 \text{ k/ft} \quad \times 75' = 5686 \text{ k}$

$\frac{5795}{5686} = 1.02 \rightarrow 2\% \text{ ADDL SEISMIC LOADS OKAY}$

IF ALLOW STRESS INCREASE IN PILES

NOTE: ABOVE ANALYSIS IS APPROXIMATE - IT IGNORES SOIL FORCES AT COUNTERWALLS & AT DEEPER PORTION OF THE PUMP STATION BUT INCLUDES THE FULL INERTIA FORCE. RATIO OF SEISMIC TO STATIC FORCE IS CONSIDERED TO BE CONSERVATIVE.

CONCLUSION: SEISMIC LOAD CASE IS NOT CRITICAL.