



# Estimating Avoided Emissions from Renewable Resources

Jim Platts – ISO New England

WRI – USEPA – CEC Workshop  
Washington DC – November 4, 2004




# Objectives

1. Describe NEPOOL's Marginal Emission Rate Analysis (MEA)
2. Describe how the MEA could be used to estimate avoided emissions from a 1000 MW and 100 MW wind farm
3. Describe how to estimate the avoided emissions from a 5 MW landfill gas project

# New England's Electric Power System



- Serves 6.5 million customers; 14 million people
- 350+ generating units
- 8,000+ miles of transmission lines
- 12 interconnections to neighboring systems
- 31,000 MW of total supply
- Peak demand: 25,348 MW on 8/14/02
- \$7.0 billion annual energy market
- Headquarters in Holyoke, MA






# ISO New England, Inc.


- Is a private, not-for-profit corporation created in 1997 to administer New England's deregulated wholesale electric power system.
- **Is Responsible for:**
  - Power system reliability
  - Deregulated market administration
  - Regional transmission planning
- Is in transition to becoming a Regional Transmission Organization (RTO)

# New England's Energy Sources: 1993 and 2003

1993



2003



Sources: ISO NE 1993 Annual Report and  
ISO NE Regional Transmission Expansion Plan 2004



# 2003 NEPOOL Marginal Emission Rate Analysis

- The NEPOOL Marginal Emission Rate Analysis (MEA) Report is developed by ISO-NE for New England Power Pool's (NEPOOL) Environmental Planning Committee (EPC).
- **Rationale for Analysis:**
  - Originally done to support applications for obtaining Massachusetts NO<sub>x</sub> Emission Reduction Credits (ERCs) resulting from impacts from Demand Side Management (DSM) programs.
  - Such applications were filed under the Mass. ERC banking & trading program effective January 1, 1994, for inventoried sources of NO<sub>x</sub>, VOCs and CO<sub>2</sub>
  - NEPOOL MEA Report has been performed annually since 1993 (public domain).




# 2003 NEPOOL Marginal Emission Rate Analysis

## What are Marginal Emission Rates & how are they calculated?


- Use a production simulation model to replicate annual historical system operations for a “Reference Case”
- Develop a “*Marginal Case*” which ‘*increases*’ all hourly loads by the amount of the DSM contribution to calculate the amount of additional (marginal) emissions that would have been emitted if DSM programs were not in place
- Conversely, the “*Avoided Emissions*” resulting from a renewable resource could be calculated by a ‘*decrease*’ in the hourly loads representing generation from that resource.
- Calculate the difference in total emissions between the two cases and convert to a rate in Lbs/MWh. The resultant values of “*Marginal (or Avoided) Emission Rates*” can then be quantified for SO<sub>2</sub>, CO<sub>2</sub> & NO<sub>x</sub> or any other modeled pollutant.

## New England Peak Load Day -- August 22, 2003





# MEA Data and Model Overview





# 2003 NEPOOL Marginal Emission Rate Analysis

## Description of Methodology

### **Geographic Scale = Power Pool = NEPOOL**

- 6 New England states = 1 Control Area operated by ISO-NE
- Overall impacts on aggregate generating unit emissions (entire fleet)

### **Type of Emissions = Seasonal & annual marginal emissions rates**

- Emission rates of all incremental generation required to serve the incremental load is quantified in Lbs/MWh & Lbs/MBtu
- Calculation of NEPOOL Marginal Heat Rate

### **Temporal Scale = Chronological hourly emissions aggregated**

- On-peak and off-peak ozone & non-ozone season and annual average
- Incremental generation and emissions by State and Market Load Zone



# 2003 NEPOOL Marginal Emission Rate Analysis

## **Modeling:**

- Used IRREM model for chronological simulation of New England's energy market
- IRREM models short-run marginal cost methodology (no bids)
- One bus modeling – Effect of real-time transmission constraints are captured in the historical generation patterns
- Replicate system operation of units in 2003 within 25% of actual unit monthly energies



# 2003 NEPOOL Marginal Emission Rate Analysis

## Assumptions:

- DSM programs modeled at 500 MW in all hours
  - Although approx. 1,500 MW of DSM reported by load serving entities
  - No modeling of load response programs/initiatives
- Discrete generator seasonal capacity ratings
- Discrete generator maintenance & forced outages
- Actual historical hourly loads for NEPOOL system (1 Control Area)
  - Pumped storage pumping loads included in hourly loads
  - Subtract actual hourly net interchange with neighboring systems (New York, Hydro-Quebec, New Brunswick)
  - Equates to modeling only native generation impacts



# 2003 NEPOOL Marginal Emission Rate Analysis

## Assumptions (cont):

- Some generation modeled as limited energy units:
  - All hydro facilities: dispatchable, run-of-river & pump storage
- All dispatchable units operated in accordance to system economics (merit order)
- 2003 New England historical fuel prices used (Source: EIA):
- Unit specific 2003 generating unit emission rates:
  - As reported to US EPA Acid Rain Division (Scorecard captures about 75% of emissions)
- Other units:
  - US EPA's E-Grid 2002 Ver 2.0 or typical default rates



# 2003 NEPOOL Marginal Emission Rate Analysis

## **Incremental generation and emissions by state and season:**

- Tons of emissions of SO<sub>2</sub> & NO<sub>x</sub> and Ktons of emissions of CO<sub>2</sub>
- By Power Pool and sub-divided by state: CT, RI, MA, ME, NH & VT
- By ozone & non-ozone season & annual


## **Track new generation additions in NEPOOL by:**

- Unit type, capacity rating and location, fuel type
- Log historical commercialization information


## **Compare “Reference Case” aggregate NEPOOL emissions against the US EPA reported emissions**

- Calculate delta and that should approximate non-US EPA reported emissions

# 2003 NEPOOL CO<sub>2</sub> Marginal Emission Rates




# 2003 NEPOOL NO<sub>x</sub> Marginal Emission Rates





# 2003 NEPOOL SO<sub>2</sub> Marginal Emission Rates





# 2003 NEPOOL Marginal Emission Rate Analysis

## Marginal Heat Rate:

- The marginal heat rate is a useful metric and a global conversion factor

(Marginal Case Fuel Consumption – Reference Case Fuel Consumption)

$$\frac{\text{-----}}{\text{(Marginal Case Generation – Reference Case Generation)}} = \text{MBtu/MWH}$$

- NEPOOL Marginal Heat Rates: MBtu/MWH (decreasing trend)
  - 1999 = 10.013
  - 2000 = 9.279
  - 2001 = 9.610
  - 2002 = 8.660
  - 2003 = 8.250



# 2002 NEPOOL Marginal Emission Rate Analysis

## 2002 NEPOOL MEA Report – Evaluation of Parameters

### **Accuracy:**

- Receives peer review by the NEPOOL EPC

### **Practicality/Feasibility:**

- Manpower: 1 FTE-month: Data collection, input, debugging, benchmarking and results review
- Ease of Development: Follows initial methodology with refinements over time to enhance overall accuracy & quality
- Public Replication:
  - Can use similar production simulation model
  - Generation capacity and loads on ISO website
  - Generation heat input, MWH and emissions available at EIA and EPA websites.



# 2003 NEPOOL Marginal Emission Rate Analysis

## **Evaluation of Parameters:**

### **Transparency:**

- Inputs, methodology, outputs & results are fully disclosed/documentated (i.e. MEA Report is public)

### **Conservativeness:**

- Questionable or unknown inputs are set to reasonable default values

### **Congruency:**

- Generic methodology with New England specific granularity



# Estimating Avoided Emissions from the Cape Wind Project

- Cape Wind is a proposed 420 MW project of 130 wind turbines to be located offshore between Cape Cod and Nantucket Is.
- Estimated annual capacity factor is 38%
- Daily summer winds correlate with the summer peak load
- Winter winds provide highest energy
- More info at [www.capewind.org](http://www.capewind.org)



## Cape Wind's Projected Energy and Avoided Emissions


	MWH
April 03	150,390
May 03	108,910
June 03	49,267
July 03	109,517
August 03	112,954
September 03	89,717
October 03	148,365
November 03	145,959
December 03	219,112
January 04	212,333
February 04	146,670
March 04	198,067
Total	1,691,261

$$\begin{aligned} &\text{Avoided CO}_2 \text{ equals} \\ &1,179 \text{ lbs/MWH} \times \\ &1,691,261 \text{ MWH} / 2,000 \\ &= 996,998 \text{ tons} \end{aligned}$$

Source: DOE and Cape Wind Associates



# Average hourly output forecast for 101 wind sites and New York Control Area average load for July




## Landfill Gas Project: Avoided Emissions

- A 42 acre landfill in Groton, CT was flaring low BTU landfill gas (LFG).  
Composition:  $\text{CH}_4$  – 57%,  $\text{CO}_2$  – 41%
- In 1996 the Town of Groton, EPA, Northeast Utilities and International Fuel Cells installed a 200 kW fuel cell at the landfill with a gas cleanup system to generate electricity from the  $\text{CH}_4$  the LFG. This was a demonstration project.
- The calculation of avoided GHG emissions is based on
  - The  $\text{CO}_2$  emissions from the fuel cell being the same as those emitted by flaring  $\text{CH}_4$
  - The fuel cell generation avoids  $\text{CO}_2$  emissions from an equivalent amount of marginal energy from the grid.
  - The  $\text{CO}_2$  in the LFG is ignored since it is from normal decay of the landfill waste.
- The results can be scaled to 5 MW.



# Landfill Gas Project: Avoided Emissions



## Landfill Gas

- ✎ Methane and NMOC mitigation
- ✎ Low-Btu fuel
- ✎ Heavily contaminated

## Contaminant Removal

- ✎ Remove sulfur and halides

## Energy Conversion

- ✎ Energy sold offsite
  - operating revenue
  - energy offset
  - environmental benefit
- ✎ Very low emissions at site

## Landfill Gas Project: Avoided Emissions

- Base Case – Flaring Methane
  - $\text{CH}_4 + 2\text{O}_2 \rightarrow \text{CO}_2 + 2\text{H}_2\text{O}$
  - A 1 ton reduction of  $\text{CH}_4$  has the same global warming effect as 21 tons of  $\text{CO}_2$  (Difference in GWP)
  - Flaring a ton of  $\text{CH}_4$  releases 2.75 tons of  $\text{CO}_2$  to the atmosphere (molecular weight difference)
  - The net reduction of  $\text{CO}_2$  equivalent from flaring is 18.25 tons

## Landfill Gas Project: Avoided Emissions

- Fuel Cell Case (Used ~20% of LFG)
    - Converts 20% of CH<sub>4</sub> to CO<sub>2</sub> through fuel cell's reformer
      - CH<sub>4</sub> + 2H<sub>2</sub>O → 4H<sub>2</sub> + CO<sub>2</sub>
      - Same reduction as flaring
    - But the fuel cell's generation avoids marginal generation from the grid and its corresponding emissions of CO<sub>2</sub>
    - Scaling to 5 MW:
      - 1179 lb/MWH\* x 5 MW x 8760 hr x 0.7 / 2000 = 18,074 tons/yr of avoided CO<sub>2</sub>.
- \*ISO NE 2003 marginal CO<sub>2</sub> rate

# Observations by ISO New England

- The calculation of marginal system emissions is a useful method to determine emissions reductions from DSM. Similarly, it can be used for determining avoided emissions from clean renewable projects.
- Simulating the actual hourly loads from a large renewable project, especially for wind, and netting them from the system hourly load, could provide a more accurate estimate of the avoided emissions from the project than annual marginal rates.
- Small projects like landfill gas may need to account for the GWP of landfill gas in addition to using the annual avoided system emissions method.



# Jim Platts

(413) 540-4516 –*jplatts@iso-ne.com*

System Planning  
ISO New England Inc.  
One Sullivan Road  
Holyoke, Massachusetts  
01040-2841  
*www.iso-ne.com*