

Estimated No. of Respondents/Recordkeepers: 5,732.
Estimated Burden Hours Per Response: 46.15 hours.
Frequency of Response: Recordkeeping, Reporting, On Occasion, Quarterly.
Estimated Total Annual Burden Hours: 264,529 hours.
Estimated Total Annual Cost: None.

By the National Credit Union Administration Board September 20, 2007.
Mary Rupp,
Secretary of the Board.
 [FR Doc. E7-18999 Filed 9-25-07; 8:45 am]
BILLING CODE 7535-01-P

NATIONAL CREDIT UNION ADMINISTRATION

Agency Information Collection Activities: Submission to OMB for Extension of a Currently Approved Collection; Comment Request

AGENCY: National Credit Union Administration (NCUA).

ACTION: Request for comment.

SUMMARY: The NCUA intends to submit the following information collection to the Office of Management and Budget (OMB) for review and clearance under the Paperwork Reduction Act of 1995 (Pub. L. 104-13, 44 U.S.C. Chapter 35). This information collection is published to obtain comments from the public.

DATES: Comments will be accepted until October 29, 2007.

ADDRESSES: Interested parties are invited to submit written comments to the NCUA Clearance Officer:

Clearance Officer: Mr. Neil McNamara, National Credit Union Administration, 1775 Duke Street, Alexandria, Virginia 22314-3428, Fax No. 703-837-2861. E-mail: ociomail@ncua.gov.

FOR FURTHER INFORMATION CONTACT: Requests for additional information or a copy of the information collection request should be directed to Tracy Sumpter at the National Credit Union Administration, 1775 Duke Street, Alexandria, VA 22314-3428, or at (703) 518-6444.

SUPPLEMENTARY INFORMATION: Proposal for the following collection of information:

Title: Written Reimbursement Policy.
OMB Number: 3133-0130.
Form Number: None.

Type of Review: Extension of a currently approved collection.

Description: Each Federal Credit Union (FCU) must draft a written reimbursement policy to ensure that the

FCU makes payments to its director within the guidelines that the FCU has established in advance and to enable examiners to easily verify compliance by comparing the policy to the actual reimbursements.

Respondents: All federal credit unions.

Estimated No. of Respondents/Recordkeepers: 5,732.

Estimated Burden Hours per Response: .50 hours.

Frequency of Response: Other. Once and update.

Estimated Total Annual Burden Hours: 2879.50.

Estimated Total Annual Cost: None.

By the National Credit Union Administration Board on September 20, 2007.

Mary Rupp,

Secretary of the Board.

[FR Doc. E7-19001 Filed 9-25-07; 8:45 am]
BILLING CODE 7535-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-328]

Tennessee Valley Authority; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. 50-328, issued to the Tennessee Valley Authority (TVA, the licensee), for operation of the Sequoyah Nuclear Plant, Unit No. 2, located in Hamilton County, Tennessee.

The proposed amendment would incorporate a one-time change to technical specification Limiting Condition for Operation 3.6.1.9 to allow an increase to the annual limit for operation of the containment ventilation system with purge isolation valves open from 1000 hours to 1400 hours during calendar year 2007.

The licensee has been experiencing an accumulation of gaseous formaldehyde in the containment atmosphere, which has necessitated more than normal purging in order to provide protection for personnel entering the containment to perform maintenance or surveillance activities during operation. This increase in gaseous formaldehyde began during 2007. The licensee has installed High-Efficiency Particulate Air and charcoal filters in the upper containment, which has been effective

in reducing the overall concentration of formaldehyde, but additional purging is still necessary to allow required containment entries. The licensee has identified three potential sources of the formaldehyde, but positive identification and corrective action cannot be completed with the plant in operation. The limit on purge hours has been in effect since 1982 and typically has not been exceeded. However, based on the current need for purging, the licensee projects that the 1000-hour limit will be exceeded around October 15, 2007. Approval of the increase in containment purge hours will avoid an unnecessary unit shutdown and allow the licensee to perform detailed leak identification and corrective action in the spring 2008 refueling outage. Based on the preceding discussion, the Commission concludes that exigent circumstances exist.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

Pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 50.91(a)(6) for amendments to be granted under exigent circumstances, the NRC staff must determine that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. The proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

TVA's proposed change is not considered to be a significant departure from the current requirements. The containment purge and ventilation system is qualified and designed to isolate in the event of a design basis accident. The probability of occurrence of an accident is not increased as the increase in purge/ventilation system operation does not affect the system's capability for purge valve closure or containment isolation. The increase in system operation for the remainder of calendar year 2007 would continue to be governed by the limits of 10 CFR 20. In addition, purge system isolation capability remains unchanged. Consequently,