

§ 3280.205

24 CFR Ch. XX (4-1-04 Edition)

aluminum, or .020 copper) with not less than a 3-inch eyebrow projecting horizontally from the front cabinet face. The 5/16-inch thick gypsum board or equivalent material which is above the top of the hood may be supported by the hood. A 3/8-inch enclosed air space shall be provided between the bottom surface of the cabinet and the gypsum board or equivalent material. The hood shall be at least as wide as the cooking range.

(b) The 3-inch metal eyebrow required by paragraph (a) of this section will project from the front and rear cabinet faces when there is no adjacent surface behind the range, or the 5/16-inch thick gypsum board or equivalent material shall be extended to cover all exposed rear surfaces of the cabinet.

(c) The metal hood required by paragraphs (a) and (b) of this section can be omitted when an oven of equivalent metal protection is installed between the cabinet and the range and all exposed cabinet surfaces are protected as described in paragraph (a) of this section.

(d) When a manufactured home is designed for the future installation of a cooking range, the metal hood and cabinet protection required by paragraph (a) of this section and the wall-surfacing cabinet surfaces behind the range required by § 3280.203 shall be installed in the factory.

(e) Vertical clearance above cooking top. Ranges shall have a vertical clearance above the cooking top of not less than 24 inches to the bottom of combustible cabinets.

§ 3280.205 Carpeting.

Carpeting shall not be used in a space or compartment designed to contain only a furnace and/or water heater. Carpeting may be used in other areas where a furnace or water heater is installed, provided that it is not located under the furnace or water heater.

§ 3280.206 Firestopping.

(a) Firestopping of at least 1-inch nominal lumber, 5/16-inch thick gypsum board, or the equivalent, shall be provided to cut off concealed draft openings between walls and partitions, including furred spaces, and the roof or floors, so as to retard vertical move-

ment of fire. In particular, such concealed spaces must be constructed so that floor-to-ceiling concealed spaces on one floor do not communicate with any concealed space on another floor, any concealed spaces in the floor, or any concealed space in the roof cavity. A barrier must be installed to prevent communication between adjacent concealed spaces.

(1) Where the barrier is vertical, it must be made of exterior or interior covering(s) equivalent to that used on the nearest exposed wall surface; and

(2) In all other cases, the barrier must be made of 1-inch nominal lumber, 5/16-inch thick gypsum board, or the equivalent.

(b) A space does not lose its character as a concealed draft opening if it is filled with insulation or other material or if it is blocked by a barrier other than as required by paragraph (a) of this section.

(c) All openings for pipes and vents and other penetrations in walls, floors, and ceilings of furnace and water heater spaces shall be tight-fitted or firestopped. Pipes, vents, and other penetrations are tight-fitted when they cannot be moved freely in the opening.

§ 3280.207 Requirements for foam plastic thermal insulating materials.

(a) *General.* Foam plastic thermal insulating materials shall not be used within the cavity of walls (not including doors) or ceilings or be exposed to the interior of the home unless:

(1) The foam plastic insulating material is protected by an interior finish of 5/16-inch thick gypsum board or equivalent material for all cavities where the material is to be installed; or

(2) The foam plastic is used as a sheathing or siding backerboard, and it:

(i) Has a flame spread rating of 75 or less and a smoke-developed rating of 450 or less (not including outer covering of sheathing);

(ii) Does not exceed 3/8-inch in thickness; and

(iii) Is separated from the interior of the manufactured home by a minimum of 2 inches of mineral fiber insulation or an equivalent thermal barrier; or

(3) The foam plastic insulating material has been previously accepted by