

§ 141.1

40 CFR Ch. I (7–1–07 Edition)

SOURCE WATER MONITORING REQUIREMENTS

- 141.701 Source water monitoring.
- 141.702 Sampling schedules.
- 141.703 Sampling locations.
- 141.704 Analytical methods.
- 141.705 Approved laboratories.
- 141.706 Reporting source water monitoring results.
- 141.707 Grandfathering previously collected data.

DISINFECTION PROFILING AND BENCHMARKING REQUIREMENTS

- 141.708 Requirements when making a significant change in disinfection practice.
- 141.709 Developing the disinfection profile and benchmark.

TREATMENT TECHNIQUE REQUIREMENTS

- 141.710 Bin classification for filtered systems.
- 141.711 Filtered system additional *Cryptosporidium* treatment requirements.
- 141.712 Unfiltered system *Cryptosporidium* treatment requirements.
- 141.713 Schedule for compliance with *Cryptosporidium* treatment requirements.
- 141.714 Requirements for uncovered finished water storage facilities.

REQUIREMENTS FOR MICROBIAL TOOLBOX COMPONENTS

- 141.715 Microbial toolbox options for meeting *Cryptosporidium* treatment requirements.
- 141.716 Source toolbox components.
- 141.717 Pre-filtration treatment toolbox components.
- 141.718 Treatment performance toolbox components.
- 141.719 Additional filtration toolbox components.
- 141.720 Inactivation toolbox components.

REPORTING AND RECORDKEEPING REQUIREMENTS

- 141.721 Reporting requirements.
- 141.722 Recordkeeping requirements.

REQUIREMENTS FOR SANITARY SURVEYS PERFORMED BY EPA

- 141.723 Requirements to respond to significant deficiencies identified in sanitary surveys performed by EPA.

AUTHORITY: 42 U.S.C. 300f, 300g–1, 300g–2, 300g–3, 300g–4, 300g–5, 300g–6, 300j–4, 300j–9, and 300j–11.

SOURCE: 40 FR 59570, Dec. 24, 1975, unless otherwise noted.

EDITORIAL NOTE: Nomenclature changes to part 141 appear at 69 FR 18803, Apr. 9, 2004.

NOTE: For community water systems serving 75,000 or more persons, monitoring must

begin 1 year following promulgation and the effective date of the MCL is 2 years following promulgation. For community water systems serving 10,000 to 75,000 persons, monitoring must begin within 3 years from the date of promulgation and the effective date of the MCL is 4 years from the date of promulgation. Effective immediately, systems that plan to make significant modifications to their treatment processes for the purpose of complying with the TTHM MCL are required to seek and obtain State approval of their treatment modification plans. This note affects §§141.2, 141.6, 141.12, 141.24 and 141.30. For additional information see 44 FR 68641, Nov. 29, 1979.

Subpart A—General

§ 141.1 Applicability.

This part establishes primary drinking water regulations pursuant to section 1412 of the Public Health Service Act, as amended by the Safe Drinking Water Act (Pub. L. 93–523); and related regulations applicable to public water systems.

§ 141.2 Definitions.

As used in this part, the term:

Act means the Public Health Service Act, as amended by the Safe Drinking Water Act, Public Law 93–523.

Action level, is the concentration of lead or copper in water specified in §141.80(c) which determines, in some cases, the treatment requirements contained in subpart I of this part that a water system is required to complete.

Bag filters are pressure-driven separation devices that remove particulate matter larger than 1 micrometer using an engineered porous filtration media. They are typically constructed of a non-rigid, fabric filtration media housed in a pressure vessel in which the direction of flow is from the inside of the bag to outside.

Bank filtration is a water treatment process that uses a well to recover surface water that has naturally infiltrated into ground water through a river bed or bank(s). Infiltration is typically enhanced by the hydraulic gradient imposed by a nearby pumping water supply or other well(s).

Best available technology or *BAT* means the best technology, treatment techniques, or other means which the Administrator finds, after examination for efficacy under field conditions and