

§ 141.520

ADDITIONAL WATERSHED CONTROL REQUIREMENTS FOR UNFILTERED SYSTEMS

§ 141.520 Is my system subject to the updated watershed control requirements?

If you are a subpart H system serving fewer than 10,000 persons which does not provide filtration, you must continue to comply with all of the filtration avoidance criteria in §141.71, as well as the additional watershed control requirements in §141.521.

§ 141.521 What updated watershed control requirements must my unfiltered system implement to continue to avoid filtration?

Your system must take any additional steps necessary to minimize the potential for contamination by *Cryptosporidium* oocysts in the source water. Your system's watershed control program must, for *Cryptosporidium*:

- (a) Identify watershed characteristics and activities which may have an adverse effect on source water quality; and
- (b) Monitor the occurrence of activities which may have an adverse effect on source water quality.

§ 141.522 How does the State determine whether my system's watershed control requirements are adequate?

During an onsite inspection conducted under the provisions of §141.71(b)(3), the State must determine whether your watershed control program is adequate to limit potential contamination by *Cryptosporidium* oocysts. The adequacy of the program must be based on the comprehensiveness of the watershed review; the effectiveness of your program to monitor and control detrimental activities occurring in the watershed; and the extent to which your system has maximized land ownership and/or controlled land use within the watershed.

DISINFECTION PROFILE

§ 141.530 What is a disinfection profile and who must develop one?

A disinfection profile is a graphical representation of your system's level of *Giardia lamblia* or virus inactivation

40 CFR Ch. I (7-1-07 Edition)

measured during the course of a year. If you are a subpart H community or non-transient non-community water system which serves fewer than 10,000 persons, your system must develop a disinfection profile unless your State determines that your system's profile is unnecessary. Your State may approve the use of a more representative data set for disinfection profiling than the data set required under §§141.532-141.536.

[67 FR 1839, Jan. 14, 2002, as amended at 69 FR 38856, June 29, 2004]

§ 141.531 What criteria must a State use to determine that a profile is unnecessary?

States may only determine that a system's profile is unnecessary if a system's TTHM and HAA5 levels are below 0.064 mg/L and 0.048 mg/L, respectively. To determine these levels, TTHM and HAA5 samples must be collected after January 1, 1998, during the month with the warmest water temperature, and at the point of maximum residence time in your distribution system. Your State may approve a more representative TTHM and HAA5 data set to determine these levels.

[67 FR 1839, Jan. 14, 2002, as amended at 69 FR 38856, June 29, 2004]

§ 141.532 How does my system develop a disinfection profile and when must it begin?

A disinfection profile consists of three steps:

- (a) First, your system must collect data for several parameters from the plant as discussed in §141.533 over the course of 12 months. If your system serves between 500 and 9,999 persons you must begin to collect data no later than July 1, 2003. If your system serves fewer than 500 persons you must begin to collect data no later than January 1, 2004.
- (b) Second, your system must use this data to calculate weekly log inactivation as discussed in §§141.534 and 141.535; and
- (c) Third, your system must use these weekly log inactivations to develop a disinfection profile as specified in §141.536.