

§ 108.175 Contiguous locations.

An enclosed space that has direct access to a Division 1 or Division 2 location is the same division as that location, except—

(a) An enclosed space that has direct access to a Division 1 location is not a hazardous location if—

(1) The access has self-closing gas-tight doors that form an air lock;

(2) The ventilation causes greater pressure in the space than in the Division 1 location; and

(3) Loss of ventilation overpressure activates an alarm at a manned station;

(b) An enclosed space that has direct access to a Division 1 location can be considered as a Division 2 location if—

(1) The access has a self-closing, gas-tight door that opens into the space and that has no hold-back device;

(2) Ventilation causes the air to flow with the door open from the space into the Division 1 location; and

(3) Loss of ventilation activates an alarm at a manned control station; and

(c) An enclosed space that has direct access to a Division 2 location is not a hazardous location if—

(1) The access has a self-closing, gas-tight door that opens into the space and that has no hold-back device;

(2) Ventilation causes the air to flow with the door open from the space into the Division 2 location; and

(3) Loss of ventilation activates an alarm at a manned control station.

§ 108.177 Electrical equipment in classified locations.

Electrical equipment and devices installed in spaces made non-hazardous by the methods indicated in § 108.175 must only be essential equipment.

VENTILATION

§ 108.181 Ventilation for enclosed spaces.

(a) Each enclosed space must be vented or ventilated.

(b) There must be a means to close each vent or ventilating system.

(c) Each fan in a ventilating system must have remote controls installed in accordance with part 111, subpart 111.103, of this chapter.

(d) There must be a means to close each doorway, ventilator, and annular space around each funnel or other opening to machinery, stowage, or working spaces. The means must be located outside the space.

(e) Each intake in a ventilating system must be located so as to prevent, as far as practicable, the intake of noxious fumes.

[CGD 73-251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 94-108, 61 FR 28270, June 4, 1996]

§ 108.185 Ventilation for enclosed classified locations.

(a) The ventilation system for each enclosed classified location must be designed to maintain a pressure differential between the enclosed classified location and each non-classified location adjacent to the enclosed classified location, so as to prevent the discharge of ignitable gases into the non-classified adjacent locations.

(b) Each air intake must be outside of enclosed classified locations.

(c) Each unit must have alarms that are powered independently of the ventilation motor power and control circuitry and sound at a continuously manned station when—

(1) Gas is present in an enclosed classified location; or

(2) The ventilation system for the space is not working.

(d) Each ventilation system for enclosed classified locations must provide a complete change of air every five minutes.

[CGD 73-251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 94-108, 61 FR 28270, June 4, 1996]

§ 108.187 Ventilation for brush type electric motors in classified spaces.

Ventilation for brush type electric motors in classified locations must meet N.F.P.A. 496-1974 "Standard for Purged and Pressurized Enclosures for Electrical Equipment in Hazardous Locations", except audible and visual alarms may be used if shutting down the motors may cause unsafe conditions.