

installation of rails of such height will be unreasonable and impracticable, having regard to the business of the vessel, rails of a lesser height or in some cases grab rails may be accepted and inboard rails may be eliminated if the deck is not generally accessible.

(b) Where it can be shown to the satisfaction of the Commandant that a vessel is engaged exclusively in voyages of a sheltered nature, the provisions of paragraph (a) of this section may be relaxed.

[CGFR 69-72, 34 FR 17484, Oct. 29, 1969, as amended by CGD 80-120, 47 FR 5723, Feb. 8, 1982]

§ 92.25-10 Storm rails.

(a) On vessels in ocean and coastwise service, suitable storm rails shall be installed in all passageways and at the deckhouse sides where persons on board might have normal access. Storm rails shall be installed on both sides of passageways which are 6 feet or more in width.

§ 92.25-15 Guards in dangerous places.

(a) Suitable hand covers, guards, or rails shall be installed in way of all exposed and dangerous places such as gears, machinery, etc.

§ 92.25-90 Vessels contracted for prior to July 1, 1969.

(a) Vessels contracted for prior to July 1, 1969, assigned a deeper load line under part 42 of subchapter E (Load Lines) of this chapter shall have efficient guard rails or bulwarks as required by § 92.25-5. Otherwise, existing structure, arrangements, materials, and facilities previously approved will be considered satisfactory so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original construction. However, in no case will greater departure from the standards of §§ 92.25-5 through 92.25-15 be permitted than presently exists.

[CGFR 69-72, 34 FR 17484, Oct. 29, 1969, as amended by CGD 80-120, 47 FR 5723, Feb. 8, 1982]

PART 93—STABILITY

AUTHORITY: 46 U.S.C. 3306, 5115; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; 49 CFR 1.46.

Subpart 93.01—Application

§ 93.01-1 General.

Each vessel must meet the applicable requirements in subchapter S of this chapter.

[CGD 79-023, 48 FR 51008, Nov. 4, 1983]

PART 95—FIRE PROTECTION EQUIPMENT

Subpart 95.01—Application

Sec.

- 95.01-1 General.
- 95.01-2 Incorporation by reference.
- 95.01-5 Equipment installed but not required.

Subpart 95.05—Fire Detecting and Extinguishing Equipment, Where Required

- 95.05-1 Fire detecting, manual alarm, and supervised patrol systems.
- 95.05-5 Fire main system.
- 95.05-10 Fixed fire extinguishing systems.
- 95.05-15 Hand portable fire extinguishers and semiportable fire extinguishing systems.

Subpart 95.10—Fire Main System, Details

- 95.10-1 Application.
- 95.10-5 Fire pumps.
- 95.10-10 Fire hydrants and hose.
- 95.10-15 Piping.
- 95.10-90 Installations contracted for prior to May 26, 1965.

Subpart 95.13—Steam Smothering Systems

- 95.13-1 Application.

Subpart 95.15—Carbon Dioxide Extinguishing Systems, Details

- 95.15-1 Application.
- 95.15-5 Quantity, pipe sizes, and discharge rates.
- 95.15-10 Controls.
- 95.15-15 Piping.
- 95.15-20 Carbon dioxide storage.
- 95.15-25 Discharge outlets.
- 95.15-30 Alarms.
- 95.15-35 Enclosure openings.
- 95.15-40 Pressure relief.
- 95.15-90 Installations contracted for prior to November 19, 1952.