

## § 111.12-13

(j) *Circuit breaker reclosing.* Generator circuit breakers must not automatically close after tripping.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 81-030, 53 FR 17847, May 18, 1988; CGD 94-108, 61 FR 28277, June 4, 1996; 62 FR 23908, May 1, 1997]

### § 111.12-13 Propulsion generator protection.

For general requirements, see § 111.35-1 of this chapter.

## Subpart 111.15—Storage Batteries and Battery Chargers: Construction and Installation

### § 111.15-1 General.

Each battery must meet the requirements of this subpart.

[CGD 94-108, 61 FR 28277, June 4, 1996]

### § 111.15-2 Battery construction.

(a) A battery cell, when inclined at 40 degrees from the vertical, must not spill electrolyte.

(b) Each fully charged lead-acid battery must have a specific gravity that meets section 16 of IEEE Std 45.

(c) Batteries must not evolve hydrogen at a rate exceeding that of a similar size lead-acid battery under similar charging condition.

(d) Batteries must be constructed to take into account the environmental conditions of a marine installation, including temperature, vibration, and shock.

[CGD 94-108, 61 FR 28277, June 4, 1996]

### § 111.15-3 Battery categories.

(a) A battery installation is classified as one of three types, based upon power output of the battery charger, as follows:

(1) *Large.* A large battery installation is one connected to a battery charger that has an output of more than 2 kw computed from the highest possible charging current and the rated voltage of the battery installation.

(2) *Moderate.* A moderate battery installation is one connected to a battery charger that has an output of between 0.2 kw and 2 kw computed from the highest possible charging current and

## 46 CFR Ch. I (10-1-06 Edition)

the rated voltage of the battery installation.

(3) *Small.* A small battery installation is one connected to a battery charger that has an output of less than 0.2 kw computed from the highest possible charging current and the rated voltage of the battery installation.

(b) Batteries that generate less hydrogen under normal charging and discharging conditions than an equivalent category of lead-acid batteries (e.g., sealed batteries) may have their battery category reduced to an equivalent category of lead-acid batteries.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28278, June 4, 1996]

### § 111.15-5 Battery installation.

(a) *Large batteries.* Each large battery installation must be in a room that is only for batteries or a box on deck. Installed electrical equipment must meet the hazardous location requirements in subpart 111.105 of this part.

(b) *Moderate batteries.* Each moderate battery installation must be in a battery room, in a box on deck, or in a box or locker in another space such as an engineroom, storeroom, or similar space, except if a moderate battery installation is in a ventilated compartment such as the engineroom and is protected from falling objects, a box or locker is not required. A moderate battery installation must not be in a sleeping space. An engine cranking battery for one or more engines must be as close as possible to the engine or engines.

(c) *Small batteries.* Small size battery installations must not be located in poorly-ventilated spaces, such as closets, or in living spaces, such as staterooms.

(d) *Battery trays.* Each battery tray must be chocked with wood strips or their equivalent to prevent movement, and each tray must have non-absorbent insulating supports on the bottom and similar spacer blocks at the sides, or equivalent provisions for air circulation space all around each tray. Each battery tray must provide adequate accessibility for installation, maintenance, and removal of the batteries.