

§ 111.60-7 Demand loads.

Generator, feeder, and bus-tie cables must be selected on the basis of a computed load of not less than the demand load given in Table 111.60-7.

TABLE 111.60-7—DEMAND LOADS

Type of circuit	Demand load
Generator cables .....	115 percent of continuous generator rating.
Switchboard bus-tie, except ship's service to emergency switchboard bus-tie.	75 percent of generating capacity of the larger switchboard.
Emergency switchboard bus-tie .....	115 percent of continuous rating of emergency generator.
Motor feeders .....	Article 430, National Electrical Code.
Galley equipment feeder .....	100 percent of either the first 50 KW or one-half the connected load, whichever is the larger, plus 65 percent of the remaining connected load, plus 50 percent of the rating of the spare switches or circuit breakers on the distribution panel.
Lighting feeder .....	100 percent of the connected load plus the average active circuit load for the spare switches or circuit breakers on the distribution panels.
Grounded neutral of a dual voltage feeder .....	100 percent of the capacity of the ungrounded conductors when grounded neutral is not protected by a circuit breaker overcurrent trip, or not less than 50 percent of the capacity of the ungrounded conductors when the grounded neutral is protected by a circuit breaker overcurrent trip or overcurrent alarm.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by USCG-2004-18884, 69 FR 58348, Sept. 30, 2004]

§ 111.60-9 Segregation of vital circuits.

(a) *General.* A branch circuit that supplies equipment vital to the propulsion, control, or safety of the vessel must not supply any other equipment.

(b) *Passenger vessels.* (1) Each passenger vessel with firescreen bulkheads that form main fire zones must have distribution systems arranged so that fire in a main fire zone does not interfere with essential services in another main fire zone.

(2) Main and emergency feeders passing through a main fire zone must be separated vertically and horizontally as much as practicable.

§ 111.60-11 Wire.

- (a) Wire must be in an enclosure.
- (b) Wire must be component insulated.
- (c) Wire, other than in switchboards, must meet the requirements in sections 19.6.4 and 19.8 of IEEE Std 45; MIL-W-76D; MIL-W-16878F; UL 44; UL 83; or equivalent standard.
- (d) Switchboard wire must meet subpart 111.30 of this part.
- (e) Wire must be of the copper stranded type.

[CGD 94-108, 61 FR 28281, June 4, 1996, as amended at 62 FR 23908, May 1, 1997; 62 FR 27659, May 20, 1997]

§ 111.60-13 Flexible electric cord and cables.

(a) *Construction and testing.* Each flexible cord and cable must meet the requirements in section 19.6.1 of IEEE Std 45, article 400 of the NEC, NEMA WC 3, NEMA WC 8, or UL 62.

(b) *Application.* A flexible cord must be used:

- (1) Only as allowed under Sections 400-7 and 400-8 of the National Electrical Code; and
- (2) In accordance with Table 400-4 of the National Electrical Code.

(c) *Allowable current-carrying capacity.* A flexible cord must not carry more current than allowed under Table 400-5 of the National Electrical Code, NEMA WC 3 or NEMA WC 8.

(d) *Conductor size.* Each flexible cord must be No. 18 AWG (0.82 mm<sup>2</sup>) or larger.

(e) *Splices.* Each flexible cord and cable must be without splices or taps except for a cord or cable No. 12 AWG (3.3 mm<sup>2</sup>) or larger spliced for repairs in accordance with §111.60-19.

(f) *Pull at joints and terminals.* Each flexible cord and cable must be connected to a device or fitting by a knot, tape, or special fitting so that tension is not transmitted to joints or terminal screws.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28281, June 4, 1996]