TABLE H-19—SAFE WORKING LOADS FOR SHACKLES

[In tons of 2,000 pounds]

| Material size (inches | Pin diame- ter (inches) | Safe work- ing load |
|-----------------------|----------------------------|------------------------|
| 1/2 | 5/8 | 1.4 |
| 5/8 | 3/4 | 2.2 |
| 3/4 | 7/8 | 3.2 |
| 7/8 | 1 | 4.3 |
| 1 | 11/8 | 5.6 |
| 11/8 | 11/4 | 6.7 |
| 11/4 | 13/8 | 8.2 |
| 13/8 | 11/2 | 10.0 |
| 1½ | 15/8 | 11.9 |
| 13/4 | 2 | 16.2 |
| 2 | 21/4 | 21.2 |

TABLE H–20—NUMBER AND SPACING OF U-BOLT WIRE ROPE CLIPS

| Impressed plans at all years | Number of clips | | Minimum |
|---|-----------------|-------------------|---------------------|
| Improved plow steel, rope diameter (inches) | Drop forged | Other material | spacing (inches) |
| 1/2 | 3 | 4 | 3 |
| 5/8 | 3 | 4 | 33/4 |
| 3/4 | 4 | 5 | 41/2 |
| 7/8 | 4 | 5 | 51/4 |
| 1 | 5 | 6 | 6 |
| 11/8 | 6 | 6 | 63/4 |
| 11/4 | 6 | 7 | 71/2 |
| 13/8 | 7 | 7 | 81/4 |
| 1½ | 7 | 8 | 9 |

[44 FR 8577, Feb. 9, 1979; 44 FR 20940, Apr. 6, 1979, as amended at 58 FR 35173, June 30, 1993]

§ 1926.252 Disposal of waste materials.

(a) Whenever materials are dropped more than 20 feet to any point lying outside the exterior walls of the building, an enclosed chute of wood, or equivalent material, shall be used. For the purpose of this paragraph, an enclosed chute is a slide, closed in on all sides, through which material is moved from a high place to a lower one.

(b) When debris is dropped through holes in the floor without the use of chutes, the area onto which the material is dropped shall be completely enclosed with barricades not less than 42 inches high and not less than 6 feet back from the projected edge of the opening above. Signs warning of the hazard of falling materials shall be posted at each level. Removal shall not be permitted in this lower area until debris handling ceases above.

(c) All scrap lumber, waste material, and rubbish shall be removed from the immediate work area as the work progresses.

- (d) Disposal of waste material or debris by burning shall comply with local fire regulations.
- (e) All solvent waste, oily rags, and flammable liquids shall be kept in fire resistant covered containers until removed from worksite.

Subpart I—Tools—Hand and Power

AUTHORITY: Sections 4, 6, and 8 of the Occupational Safety and Health Act of 1970 (29 U.S.C. 653, 655, 657); Secretary of Labor's Order No. 12–71 (36 FR 8754), 8–76 (41 FR 25059), 9–83 (48 FR 35736), 1–90 (55 FR 9033), or 5–2002 (67 FR 65008), as applicable; and 29 CFR part 1911. Section 1926.307 also issued under 5 U.S.C. 553.

§1926.300 General requirements.

- (a) Condition of tools. All hand and power tools and similar equipment, whether furnished by the employer or the employee, shall be maintained in a safe condition.
- (b) Guarding. (1) When power operated tools are designed to accommodate guards, they shall be equipped with such guards when in use.
- (2) Belts, gears, shafts, pulleys, sprockets, spindles, drums, fly wheels, chains, or other reciprocating, rotating or moving parts of equipment shall be guarded if such parts are exposed to contact by employees or otherwise create a hazard. Guarding shall meet the requirements as set forth in American National Standards Institute, B15.1–1953 (R1958), Safety Code for Mechanical Power-Transmission Apparatus.
- (3) Types of guarding. One or more methods of machine guarding shall be provided to protect the operator and other employees in the machine area from hazards such as those created by point of operation, ingoing nip points, rotating parts, flying chips and sparks. Examples of guarding methods are—barrier guards, two-hand tripping devices, electronic safety devices, etc.
- (4) Point of operation guarding. (i) Point of operation is the area on a machine where work is actually performed upon the material being processed.
- (ii) The point of operation of machines whose operation exposes an employee to injury, shall be guarded. The guarding device shall be in conformity