

R-95-09



LAKE HAVASU CITY WATER TREATMENT RESEARCH STUDY

Water Treatment Technology Program Report No. 8



September 1995

U.S. DEPARTMENT OF THE INTERIOR
Bureau of Reclamation
Technical Service Center
Environmental Resources Team
Water Treatment Engineering and Research Group

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suit 1204, Arlington VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Report (0704-0188), Washington DC 20503.

1. AGENCY USE ONLY (Leave Blank)		2. REPORT DATE September 1995	3. REPORT TYPE AND DATES COVERED Final	
4. TITLE AND SUBTITLE Lake Havasu City Water Treatment Research Study— Water Treatment Technology Program Report No. 8			5. FUNDING NUMBERS PR	
6. AUTHOR(S) Wilbur J. Boegli, Robert Jurenka, and Michelle Chapman-Wilbert				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Bureau of Reclamation Technical Service Center Denver CO 80225			8. PERFORMING ORGANIZATION REPORT NUMBER R-95-09	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Bureau of Reclamation Denver Federal Center PO Box 25007 Denver CO 80225-0007			10. SPONSORING/MONITORING AGENCY REPORT NUMBER DIBR	
11. SUPPLEMENTARY NOTES Microfiche and hard copy available at the Technical Service Center, Denver, Colorado				
12a. DISTRIBUTION/AVAILABILITY STATEMENT Available from the National Technical Information Service, Operations Division, 5285 Port Royal Road, Springfield, Virginia 22161			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) The Bureau of Reclamation and Lake Havasu City conducted a jointly funded research study to evaluate selected ground-water treatment options to assist the city in planning for water treatment expansion. The study included pilot testing at well S6, one of 14 city-owned wells. The ground water from this well, and others in the vicinity, is in full compliance with all EPA (Environmental Protection Agency) primary drinking water standards. However, the concentrations of other constituents, such as hardness, sulfate, TDS (total dissolved solids), and manganese, are in excess of secondary MCLs (maximum contaminant levels). High manganese levels are of particular concern to the community because precipitates, formed in the water from chlorination, accumulate in the distribution system and cause discoloration of tap water. Two processes were pilot tested: KMnO ₄ (potassium permanganate) oxidation followed by greensand filtration to remove Mn ⁺² (manganese); and nanofiltration to reduce the concentrations of not only manganese, but also sulfate, hardness, and TDS as well. Process recommendations, cost estimates, and design considerations for scale-up are provided in the report based on the results of this testing.				
14. SUBJECT TERMS -- water treatment/ desalting/ nanofiltration/ reverse osmosis/ permanganate oxidation/ ground water/ Lake Havasu/ Water Treatment Technology Program			15. NUMBER OF PAGES 86	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT UL	18. SECURITY CLASSIFICATION OF THIS PAGE UL	19. SECURITY CLASSIFICATION OF ABSTRACT UL	20. LIMITATION OF ABSTRACT UL	

R-95-09

LAKE HAVASU CITY WATER TREATMENT RESEARCH STUDY

Water Treatment Technology Program Report No. 8

by

Wilbur J. Boegli
Robert Jurenka
Michelle Chapman-Wilbert

Water Treatment Engineering and Research Group
Environmental Resources Team
Technical Service Center
Denver, Colorado

September 1995

ACKNOWLEDGMENTS

We would like to thank all of the people at the Lake Havasu Water District who made this field study a success. Special thanks go to Gene Cheramy and Bobby Trujillo for their expert assistance in monitoring and keeping the equipment running properly. We also want to thank Brad Colby for hauling samples to Phoenix on several occasions, and Jennifer MacSweeney at Westech Laboratories, Inc., for her prompt attention.

U.S. Department of the Interior Mission Statement

As the Nation's principal conservation agency, the Department of the Interior has responsibility for most of our nationally-owned public lands and natural resources. This includes fostering sound use of our land and water resources; protecting our fish, wildlife, and biological diversity; preserving the environmental and cultural values of our national parks and historical places; and providing for the enjoyment of life through outdoor recreation. The Department assesses our energy and mineral resources and works to ensure that their development is in the best interests of all our people by encouraging stewardship and citizen participation in their care. The Department also has a major responsibility for American Indian reservation communities and for people who live in island territories under U.S. administration.

The information contained in this report regarding commercial products or firms may not be used for advertising or promotional purposes and is not to be construed as an endorsement of any product or firm by the Bureau of Reclamation.

CONTENTS

	Page
1. Executive summary	1
2. Introduction	2
2.1 Purpose and scope	2
2.2 Background	3
3. Contaminants of concern	3
4. Pilot test objectives	3
4.1 KMnO_4 (potassium permanganate) oxidation	3
4.2 Nanofiltration	5
5. Pilot test description	5
5.1 Site selection	5
5.2 Process selection	5
5.2.1 KMnO_4 oxidation	5
5.2.2 Nanofiltration	6
5.3 Pilot plant equipment and site layout	7
5.4 Test procedures	11
5.4.1 KMnO_4 oxidation	11
5.4.2 Nanofiltration	14
6. Pilot test results and conclusions	15
6.1 Results	15
6.1.1 KMnO_4 oxidation	15
6.1.1.1 Optimization of KMnO_4 dosage	15
6.1.1.2 Permanganate reaction kinetics	15
6.1.1.3 Filtration efficiency	19
6.1.1.4 Alum clarification	21
6.1.2 Nanofiltration	21
6.1.2.1 Operational data	21
6.1.2.2 Performance degradation	31
6.1.2.3 Membrane autopsy and SEM analysis	35
6.2 Conclusions	37
6.2.1 KMnO_4 oxidation	37
6.2.2 Nanofiltration	38
7. Full scale treatment	39
7.1 General	39
7.2 Manganese removal (KMnO_4 oxidation)	40
7.3 Full compliance	42
7.3.1 General	42
7.3.2 Nanofiltration	42
7.3.2.1 Brine production	45
7.3.2.2 Brine disposal	45
7.3.3 Lime softening	46
7.3.3.1 Sludge production	48
7.3.3.2 Sludge disposal	48
7.4 Potential alternatives not pilot-tested	48

CONTENTS — CONTINUED

	Page
8. Treatment costs	48
8.1 General	48
8.2 KMnO ₄ oxidation	49
8.2.1 Construction cost	49
8.2.2 Operations and maintenance costs	50
8.3 Full compliance using nanofiltration	50
8.3.1 Construction cost	50
8.3.2 Operations and maintenance costs	52
8.4 Lime softening	52
8.4.1 Construction cost	52
8.4.2 Operations and maintenance costs	53
8.5 Cost analysis	53
8.6 Surface water treatment costs	53
9. Conclusions	53
10. Recommendations	55
11. References	55

TABLES

Table

1 Available ground-water analysis for well S6	6
2 Lake Havasu City water treatment study analytical requirements	13
3 Percent salt rejection data	31
4 Metals found on autopsied membrane surface	37
5 City average day water demands	39
6 Nanofiltration ion concentrations	44
7 Construction and annual operations and maintenance costs, 12 Mgal/d potassium permanganate oxidation	50
8 Construction and annual operations and maintenance costs, 12 Mgal/d nanofiltration	51
9 Construction and annual operations and maintenance costs, 12 Mgal/d lime softening	52
10 Cost summary of ground-water treatment options (12 Mgal/d)	53
11 Life cycle costs for ground-water treatment options	54

FIGURES

Figure

1 Lake Havasu City well fields	4
2 Ground-water treatment processes selected for pilot testing	8
3 Equipment setup for ground-water treatment process No. 1 (KMnO ₄ oxidation and manganese greensand filtration)	9
4 Equipment setup for ground-water treatment process No. 2 (Anti-scalant, UV disinfection, and nanofiltration)	10

CONTENTS — CONTINUED

FIGURES — CONTINUED

Figure	Page
5 Pilot plant equipment layout at the well S6 site	12
6 Optimization of KMnO_4 dosage	17
7 Timed reaction test	17
8 Turbidity data	19
9 System flow rates (nanofiltration)	23
10 Feed temperature	23
11 System conductivities	25
12 Permeate conductivities	25
13 System pressures	29
14 Stage pressure drops	29
15 Average net driving pressure	33
16 Normalized permeate flow	33
17 SEM showing characteristic rod-shaped bacterial cell forms	36
18 Water treatment with potassium permanganate oxidation	41
19 Water treatment with nanofiltration	43
20 Water treatment with lime softening	47

APPENDIXES

Appendix

A KMnO_4 oxidation and greensand test data	57
B Nanofiltration test data	61
C Generalized NF process diagram for checking data reduction	71
D Analytical data for nanofiltration testing	75
E Nanofiltration element serial numbers as loaded in pressure vessels	79
F Lime softening process calculations	83

ACRONYMS AND ABBREVIATIONS

ADEQ	Arizona Department of Environmental Quality
BPV	back pressure valve
cfu	colony forming units
ENR	<i>Engineering News Record</i>
EPA	Environmental Protection Agency
FCV	flow control valve
HDPE	high density polyethylene
HPC	heterotrophic plate count
ICP	inductively-coupled plasma
LHC	Lake Havasu City
MCL	maximum contaminant level
Mgal	million gallons
NF	nanofiltration
NPF	normalized permeate flow
NDP	net driving pressure
ntu	nephelometric turbidity unit
O&M	operations and maintenance
PID	proportional integral derivative
PLC	programmable logic controller
RO	reverse osmosis
SDI	silt density index
SEM	scanning electron microscopy
SR	salt rejection
TCF	temperature correction factor
TDS	total dissolved solids
TFC	thin film composite
THM	trihalomethane
THMFP	trihalomethane formation potential
TOC	total organic carbon
UV	ultraviolet

CHEMICAL FORMULAS

Al^{+3}	aluminum ion
$\text{Al}_2(\text{SO}_4)_3 \cdot 14.3\text{H}_2\text{O}$	aluminum sulfate (alum)
Ba^{+2}	barium ion
Ca^{+2}	calcium ion
CaCO_3	calcium carbonate
$\text{Ca}(\text{OH})_2$	calcium hydroxide (lime)
Cl^-	chloride ion
Cl_2	chlorine
ClO_2	chlorine dioxide
Cr	chromium
Fe^{+2}	ferrous iron
Fe^{+3}	ferric iron
H^+	hydrogen ion
HCO_3^-	bicarbonate ion
H_2O	water

CHEMICAL FORMULAS — CONTINUED

H ₂ SO ₄	sulfuric acid
K ⁺	potassium ion
KMnO ₄	potassium permanganate
Mg ⁺²	magnesium ion
Mn ⁺²	manganese ion
MnO	manganous oxide
MnO ₂	manganic dioxide
MnO ₄ ⁻	permanganate ion
Na ⁺	sodium ion
Na ₂ CO ₃	sodium carbonate (soda ash)
Ni	nickel
NO ₃ ⁻	nitrate ion
O ₃	ozone
SiO ₂	silica
SO ₄ ⁻²	sulfate ion

SI METRIC CONVERSIONS

From	To	Multiply by
ft	m	3.048 000 E-01
in	m	2.540 000 E-02
ft ²	m ²	9.290 304 E-02
kgal	m ³	3.785 412
Mgal	m ³	3.785 412 E+3
acre-ft	m ³	1.233 489 E+3
lb/in ²	kPa	6.894 757
°F	°C	$t_C = (t_F - 32)/1.8$

1. EXECUTIVE SUMMARY

The Bureau of Reclamation (Reclamation) and LHC (Lake Havasu City) conducted a jointly-funded research study to evaluate selected ground-water treatment options to assist the city in planning for water treatment expansion. The study included pilot testing at well S6, one of 14 city-owned wells. In this report, Reclamation is providing process recommendations, cost estimates, and design considerations for scale-up based on the results of this testing.

Based on available data, the city water supply is in full compliance with primary drinking water standards. However, concentrations of other constituents such as hardness, sulfate, TDS (total dissolved solids) and manganese exceed secondary MCLs (maximum contaminant levels). High manganese levels in several wells are of concern to the community because precipitates formed in the water from chlorination accumulate in the distribution system. Poor quality ground water is commonly made acceptable by blending with better quality wells. However, with established wells declining in quality, this approach is becoming impractical or unavailable.

Two processes were selected for pilot testing: KMnO_4 (potassium permanganate) oxidation followed by greensand filtration to remove Mn^{+2} (manganese); and NF (nanofiltration) to reduce the concentrations of not only manganese, but sulfate, hardness, and TDS as well. Nanofiltration is capable of producing product water that meets *all* secondary MCLs.

KMnO_4 oxidation and greensand filtration were effective in reducing the concentration of Mn^{+2} in well S6 ground water to 0.05 mg/L, the secondary MCL. The optimum KMnO_4 dose was about 1.1 mg/L. Considering the average reduction of Mn^{+2} (0.62 mg/L [influent] - 0.05 mg/L [effluent]), this dose is equivalent to 1.93 mg/L KMnO_4 per mg/L Mn^{+2} , which is essentially the same as the stoichiometric requirement. The reaction is fast. About 90 percent of the Mn^{+2} is oxidized within the first 1-1/2 minutes. The initial reaction rate was determined to be second order dependent on both $[\text{MnO}_4^-]$ and $[\text{Mn}^{+2}]$ with a rate constant of -0.198/mol-sec.

Greensand effluent turbidity measurements were at or below 0.09 ntu (nephelometric turbidity units), indicating efficient filtration. The greensand filter media was also effective in controlling the over- and under-dosing of KMnO_4 . Interestingly, water samples collected just prior to filtration contained less Mn^{+2} (0.02-0.03 mg/L) than the filter effluent when operating near the optimum KMnO_4 dose of 1.1 mg/L (this observation is based on Hach analyses in the field). This result suggests that KMnO_4 could be removed more efficiently with conventional dual- or multi-media filtration, assuming an effective control could be employed for chemical dosing.

Jar test results showed that alum concentrations of 20 to 40 mg/L could be used to coagulate and settle MnO_2 (manganic dioxide [oxidized Mn^{+2} particles]); however, the required settling time of 90 minutes was excessive and the floc produced was very fragile. Thus, this report concludes that alum is not effective for this application, and apparently is not necessary to produce acceptable filter effluent turbidities as described above.

The nanofiltration test system employed 18 FilmTec NF90-2540 elements in a 12:6 (2-stage) array. The feed flow rate and product recovery were maintained at 18.2 L/min (4.8 gal/min) and 80 percent, respectively. The initial feed pressure was 570 kPa (83 lb/in²). Hypersperse AF 200™ and sulfuric acid were added for scale control. The system was operated for about 1000 hours to allow time for any potential membrane degradation from fouling or scaling to develop. UV (ultraviolet) disinfection was used for the control of microbial contamination.

Nanofiltration effectively reduced the concentrations of all contaminants of concern to below MCLs. The average TDS rejection for the 984-hour test was 90.9 percent. The percent rejection for specific ions of interest was: Ca^{+2} (calcium) - 98.1; Mg^{+2} (magnesium) - 98.5; SO_4^{-2} (sulfate) - 97.4; and Mn^{+2} - ≥ 90.3 . The average TDS for the feed and permeate (product) was 826 and 75 mg/L, respectively. This low permeate concentration allows blending to obtain higher overall net product recoveries.

The test data show that biofouling probably occurred during the 6 weeks of operation. NPF (normalized permeate flow) dropped about 16 percent during this period, and feed pressure increased from 75 to 89 lb/in². A membrane autopsy was performed to determine the cause of the performance degradation. SEM (scanning electron microscopy) imaging was also used in an attempt to visually identify fouling or scaling components. The results of these procedures, along with high heterotrophic plate counts measured throughout the test system, all pointed to biofouling as the most likely cause. Because of high microbial populations present in the feed water (7900 cfu/mL measured at the wellhead sample tap), a more aggressive disinfection will be needed, e.g., the use of chloramines or chlorination followed by dechlorination. However, any Mn^{+2} oxidized by these chemicals would have to be removed by media filtration prior to membrane desalting.

Lake Havasu City may choose a treatment plant for manganese removal alone, such as a potassium permanganate oxidation plant, or may elect treatment that would reduce the concentrations of all EPA-regulated primary and secondary drinking water parameters to below MCLs. This report concludes that several options are available to the city to provide the latter defined, full compliance, water quality. These options include nanofiltration alone or nanofiltration blended with water from either Lake Havasu or treated ground water. Lime-softened ground water can also be blended with treated water from either Lake Havasu or ground water that has received nanofiltration treatment.

If Lake Havasu City selects a nanofiltration treatment plant, the reject brine produced will have to be disposed of in a manner that is consistent with Arizona Department of Environmental Quality rules. Methods available to the city for reject brine disposal include evaporation ponds, reuse using irrigation of brine-tolerant plants or landscaped areas when the salt concentrations are appropriately adjusted (diluted), and creation of a wetlands environment.

2. INTRODUCTION

2.1 Purpose and Scope

In light of a rapid population increase over the last 15 years, Lake Havasu City is facing several challenges concerning their water supply and distribution system. One of these challenges is the need to provide a reasonable level of water treatment to ensure the delivery of safe and palatable drinking water to the residents of the city. To address this need, and to assist the city in planning for water treatment expansion, Reclamation and Lake Havasu City conducted a jointly-funded research study to evaluate selected ground-water treatment options.

The study included the pilot testing of selected water treatment processes to confirm their performance and efficiency. Based on the results of this testing, process recommendations and cost estimates are provided, along with design considerations for scale-up. The cost estimates include both capital and O&M (operation and maintenance) costs for a full-scale treatment plant with a capacity of 12 Mgal/day. Capital cost estimates are based on a combination of direct

quotes from manufacturers, plus allowances for installation, and cost curves prepared by the EPA (Environmental Protection Agency) using current indices of the ENR (*Engineering News Record*). O&M cost estimates include current prices for electricity, chemicals, and supplies, when available. Most estimates for materials, equipment, and labor are based on updated ENR values. Consequently, the estimates found herein are valuable for a comparison of the alternatives presented, and are not final construction estimates.

The final treatment process recommendations made in this report should be integrated with other design factors that address the city's comprehensive needs. It is recommended that consideration be given to such issues as capacity, water sources, desired level of treatment, and location, in an engineering analysis to arrive at a final determination of an appropriate treatment scheme.

2.2 Background

Lake Havasu City receives all of its potable water supply from fourteen city-owned and operated wells located along the shoreline of Lake Havasu (fig. 1). The wells are grouped into three separate well fields: north, central and south. The total combined pumping capacity of the wells is about 24 Mgal/day (HDR Engineering, 1992).

Poor quality ground water in the study area is commonly made acceptable by blending with better quality wells. In the past, the city drilled wells to avoid poorer water quality areas. However, with established wells declining in quality, new wells must be located where only poor quality ground water is available and where blending is impractical or unavailable.

3. CONTAMINANTS OF CONCERN

Based on available data, the city's water supply is in full compliance with all primary drinking water standards. However, the concentrations of other constituents such as hardness, sulfate, TDS (total dissolved solids), and manganese are in excess of secondary MCLs (maximum contaminant levels). High manganese (Mn^{+2}) levels are of particular concern to the community because precipitates, formed in the water from chlorination, accumulate in the distribution system and cause discoloration of tap water. Elevated manganese concentrations are generally confined to the central and south well fields (wells C2, C9, S4 and S6).

4. PILOT TEST OBJECTIVES

4.1 $KMnO_4$ (Potassium Permanganate) Oxidation

The principal objectives of the $KMnO_4$ (potassium permanganate) oxidation testing were to:

- Determine the concentration of $KMnO_4$ needed to reduce the Mn^{+2} (manganese) level in well S6 ground water to below 0.05 mg/L (EPA secondary drinking water standard).
- Determine the required reaction time and attempt to develop an initial rate constant.
- Assess the ability of manganese-greensand filtration to compensate for over- and under-dosing of $KMnO_4$.




Figure 1. - Lake Havasu City well fields (HDR Engineering, 1992).

- Evaluate the efficiency of the greensand filter in removing MnO_2 (manganic dioxide [oxidized manganese particles]).
- Evaluate the effectiveness of alum (aluminum sulfate) for coagulating and settling MnO_2 precipitates.

4.2 Nanofiltration

The principal objectives of the nanofiltration testing were to:

- Evaluate the performance of FilmTec NF-90 nanofiltration membrane elements for reducing TDS, hardness, sulfate, and manganese levels in the well S6 water.
- Assess blending opportunities (NF permeate with filtered well water) to achieve high overall net recoveries.
- Determine potential long-term adverse effects on the membranes from fouling or scaling.

5. PILOT TEST DESCRIPTION

5.1 Site Selection

Site selection for ground-water testing focused on the city-owned wells that contained manganese in 1993: C2, C9, S4, and S6 (fig. 1). Of these four wells, the 1992-93 average concentration for manganese and TDS indicated C2 and S6 as the leading candidates. The 2-year data base showed well C2 had an average of 0.28 mg/L manganese and 1227 mg/L TDS, and well S6 had an average of 0.50 mg/L manganese and 764 mg/L TDS. Because manganese is the primary contaminant of concern for Lake Havasu City, it was decided that testing at well S6 would yield the most useful data.

Table 1 shows the most recent chemical analysis (existing prior to this test program) for well S6. Corresponding primary and secondary federal drinking water standards are also included in the table for comparison. The constituents that exceed secondary MCLs are highlighted with an asterisk. Well S6, with a drilled depth of 160 feet, is rated at 900 gal/min and has a usable capacity of 550 gal/min.

5.2 Process Selection


Two approaches to treatment were considered for evaluation in the field: the first, an oxidation and filtration process for the removal of manganese; and the second, a softening process (lime or membrane) to reduce the concentrations of not only manganese, but also sulfate, hardness, and TDS.

5.2.1 $KMnO_4$ oxidation. - The most effective oxidants available for the treatment of Mn^{+2} (manganese) are O_3 (ozone), ClO_2 (chlorine dioxide) and $KMnO_4$. Of the three, $KMnO_4$ is the more commonly used in the United States, and is generally favored for waters with high manganese content (Glase, 1990). Both O_3 and ClO_2 require on-site generation, which involves a greater equipment and capital investment. Cl_2 (chlorine) will also oxidize manganese, but care must be exercised when the THMFP (trihalomethane formation potential) of the water is high.

Table 1. - Available ground-water analysis for well S6.

Cations	Concentration	Federal MCL	
		(Primary)	(Secondary)
Calcium	Ca mg/L	100	
Magnesium	Mg mg/L	35	
Sodium	Na mg/L	110	
Potassium	K mg/L	1.8	
Strontium	Sr mg/L	1.3	
Barium	Ba mg/L	0.05	1
Iron	Fe mg/L	0.05	0.3
Manganese*	Mn mg/L	0.55	0.05
Anions			
Bicarbonate	HCO ₃ mg/L	232	
Carbonate	CO ₃ mg/L	0	
Sulfate*	SO ₄ mg/L	300	250
Chloride	Cl mg/L	95	250
Nitrate	NO ₃ (as N) mg/L	1	10
Fluoride	F mg/L	0.64	4.0
Ammonia (N)	NH ₃ (N) mg/L	0.2	
Silica (soluble)	SiO ₂ mg/L	15	
Silica (total)	SiO ₂ mg/L	17	
Alkalinity	as CaCO ₃ mg/L	190	
Hardness	as CaCO ₃ mg/L	390	
TDS (reported)*	mg/L	790	500
TDS (summation)*	mg/L	880	500
pH		7.62	6.5-8.5

A combination of KMnO₄ oxidation and manganese-greensand filtration was selected for testing. Manganese-greensand provides effective filtration and also controls under- and over-dosing of KMnO₄ (prevents the development of pink water breakthrough). Manganese (II) removal depends on the precipitation of MnO₂(s) (manganese [IV] [manganic dioxide]), as follows:



Manganic dioxide is essentially insoluble over the entire pH range of interest in drinking water treatment. Also, the oxidation of both Mn⁺² and Fe⁺² (ferrous iron) using KMnO₄ is reported to be quite rapid at pH 7 and higher (Glase, 1990).

The stoichiometry for manganese and iron oxidized with permanganate is:

1.92 mg/L KMnO₄ per mg/L of Mn⁺² removed
 0.94 mg/L KMnO₄ per mg/L of Fe⁺² removed

5.2.2 Nanofiltration. - Lime softening and membrane softening (nanofiltration) can be used to reduce hardness and TDS. Lime softening can remove carbonate hardness (calcium and magnesium bicarbonates) to the level of CaCO₃ (calcium carbonate) solubility by stoichiometric additions of Ca(OH)₂ (lime). Further reduction of noncarbonate hardness (calcium and

magnesium sulfates or chlorides) requires addition of Na_2CO_3 (soda ash). Lime softening also causes effective chemical precipitation of manganese as MnO (manganous oxide) when the pH of the water is in the range of 9.5 to 10.0. No reduction in sulfate is achieved with this process.

RO (reverse osmosis) and NF are processes used for desalting water by the application of hydrostatic pressure to drive feed water through a semi-permeable membrane. Most of the water's impurity (dissolved salts) remain behind and is discharged as waste brine; relatively pure product water (permeate) emerges at near atmospheric pressure. A typical operating pressure range for RO is 200 to 400 lb/in^2 for brackish water and 800 to 1000 lb/in^2 for seawater desalination. Ion rejections achieved with RO usually are in the mid-to-high 90-percent range.

NF membranes are generally used to treat low TDS waters where the reduction of hardness ions is desirable. The rejection of divalent ions (Ca^{+2} , Mg^{+2} , SO_4^{-2}) and organics having a molecular weight above 200 is very high, typically above 95 percent; thus the name "softening membranes." Monovalent ions (Na^+ , Cl^- , HCO_3^-) are rejected at around 60 to 70 percent. Typical applications for NF include the removal of TDS, hardness, color, THM (trihalomethane) precursors, TOC (total organic carbon), and radium. Operating pressures are in the range of 75 to 150 lb/in^2 , depending on temperature, feed-water constituents, salinity, and recovery (FilmTec Corporation, undated).

Both softening processes have disposal requirements: CaCO_3 sludge with lime precipitation; and reject brine with NF.

NF was selected for field testing because of its ability to meet *all* secondary MCLs, and because of blending opportunities to achieve high overall net recoveries (reducing brine disposal requirements).

5.3 Pilot Plant Equipment and Site Layout


Reclamation's Mobile Water Treatment Pilot Plant was used at Lake Havasu City for the field testing described herein. This pilot plant incorporates skid-mounted equipment to test many unit treatment processes, including chemical precipitation, oxidation (ozone, permanganate), ion exchange, activated carbon, and membrane separation. Most of the process equipment is controlled using an Allen-Bradley SLC 500 programmable controller, and provisions are included for automatic data acquisition; however, data acquisition for this test program was performed manually. A 35-kW generator is available for remote-site operations where commercial power is not available.

Figure 2 presents schematic diagrams of the treatment processes that were pilot tested at Lake Havasu City:


- KMnO_4 (potassium permanganate) oxidation followed by manganese-greensand filtration
- Nanofiltration preceded by anti-scalant addition and UV (ultraviolet) disinfection

Post-chlorination was not included in the testing, but would be incorporated as part of the prototype treatment plant(s).

Figures 3 and 4 show the equipment setups and interconnections (plumbing and level sensor) for the two processes.



Potassium permanganant (KMnO4) oxidation; greensand filtration



Anti-scalant addition; UV disinfection; nanofiltration

Figure 2. - Ground-water treatment processes selected for pilot testing.




Figure 3. - Equipment setup for ground-water treatment process No. 1 (KMnO₄ oxidation and manganese-greensand filtration).




Figure 4. - Equipment setup for ground-water treatment process No. 2 (anti-scalant, UV disinfection, and nanofiltration).

Figure 5 shows the actual layout of the trailer, tanks, and exterior skids at well S6. The intake pump skid (not shown) was used to transfer feed water from the well to the intake pump connection on the trailer located just behind the stairway. All process effluent and drain flows were directed to the gravel drain shown next to the fence line behind the trailer.

5.4 Test Procedures


5.4.1 KMnO_4 oxidation. - From the stoichiometry described earlier, the concentration of KMnO_4 required to completely oxidize 0.55 mg/L Mn^{+2} and 0.05 mg/L Fe^{+2} would be 1.10 mg/L. Based on this requirement, the range of KMnO_4 concentrations selected for evaluation in this test phase was 0.60 to 1.80 mg/L (this range represents 55 to 165 percent of the stoichiometric value).

Initially, each test was run at 22.7 L/min (6 gal/min), which provided about 55 minutes of reaction time before greensand filtration. Later, four additional tests were run at a reduced reaction time of 12 minutes. For each test, the KMnO_4 feed concentration was set in the morning and allowed to stabilize for about 10 hours. During this time, physical parameters (flow, pH, turbidity, and filter ΔP) were monitored and manually recorded on the operator's data sheet. Four recordings were made each day. At the end of each day's testing, two separate samples were collected of the raw feed and the greensand filter influent and effluent. One set was sent to a contract lab for manganese and iron analyses (refer to table 2), and a second set was analyzed in the field using Hach reagents. The two sets of data were later compared as a quality-control measure. Immediately after collection, the greensand filter *influent* samples were vacuum-filtered into a flask containing sodium bisulfite (1.5 times stoichiometric). This procedure was done to remove accumulated oxidation particles and to stop the reaction by neutralizing any residual KMnO_4 .

An LMI (Liquid Metronics, Inc.) pump was used to feed a 0.5-percent KMnO_4 solution directly to the rapid mix tank. The chemical feed rates for a process flow of 22.7 L/min were as follows:

KMnO_4 dosage (mg/L)	mL/min of 0.5% KMnO_4
0.6	2.72
0.8	3.63
1.0	4.54
1.2	5.45
1.4	6.36
1.6	7.26
1.8	8.17

Permanganate dosages were checked daily by observing and recording the level change in the chemical feed tank. Also, periodic spot checks of the feed rate were made using a 10-mL graduated cylinder and stopwatch.



WELL S6





Figure 5. - Pilot plant equipment layout at the well S6 site.

Table 2. - Lake Havasu City water treatment study analytical requirements.

Parameter	Units	Number of Samples/Readings GW#1	Number of Samples/Readings GW#2	Responsibility for Testing/Recording	Preservation	Container Type	Minimum Volume (mL)	Maximum Holding Time
Flow	L/min	Many	Many	Operator	-	-	-	-
Temperature	deg C	Many	Many	Operator	-	-	-	-
pH	-	Many	Many	Operator	-	-	-	-
Turbidity	NTU	Many	Many	Operator	-	-	-	-
Conductivity	uS/cm	Many	Many	Operator	-	-	-	-
Silt Density Index (SDI)	-	40	40	Operator, SDI Test kit	-	-	-	-
Calcium, Ca	mg/L	2	16	LHC	Store at 4 deg C	Plastic	200	28 days
Magnesium, Mg	mg/L	2	16	LHC	Store at 4 deg C	Plastic	200	28 days
Sodium, Na	mg/L	2	16	LHC	Store at 4 deg C	Plastic	200	28 days
Potassium, K	mg/L	2	16	LHC	Store at 4 deg C	Plastic	200	28 days
Strontium, Sr (total)	mg/L	2	16	LHC	Store at 4 deg C	Plastic	200	28 days
Barium, Ba (total)	mg/L	2	16	LHC	Nitric, < pH 2	Plastic	250	6 months
Aluminum, Al (total) **	mg/L	2	16	LHC	Nitric, < pH 2	Plastic	250	6 months
Iron, Fe (total)	mg/L	42	16	LHC	Nitric, < pH 2	Plastic	250	6 months
Manganese, Mn (total)	mg/L	42	16	LHC/Operator, Hach	Nitric, < pH 2	Plastic	250	6 months
Bicarbonate, HCO3	mg/L	2	16	LHC/Operator, Hach	Nitric, < pH 2	Plastic	250	6 months
Chloride, Cl	mg/L	2	16	LHC	Store at 4 deg C	Plastic, glass	50	28 days
Fluoride, F	mg/L	2	16	LHC	None required	Plastic	300	28 days
Sulfate, SO4	mg/L	2	16	LHC	Store at 4 deg C	Plastic, glass	50	28 days
Nitrate, NO3	mg/L	2	16	LHC	Store at 4 deg C	Plastic, glass	100	48 hours
Phosphate, PO4	mg/L	2	16	LHC	Store at 4 deg C	Amber plastic, glass	100	48 hours
Hardness (as CaCO3)	mg/L	2	16	LHC	Nitric, < pH 2	Plastic, glass	100	6 months
Alkalinity (as CaCO3)	mg/L	2	16	LHC	Store at 4 deg C	Plastic, glass	100	14 days
Silica, SiO2	mg/L	16	16	LHC	Store at 4 deg C	Plastic	-	28 days
Total Organic Carbon (TOC)	mg/L	4	4	LHC	4 deg C; HCl, < pH 2 & 4 drops 10% S.T.	Amber glass; TFE cap	100	7 days
Standard Plate Count (SPC)	CFUs/mL	4	4	LHC	Store at 4 deg C	Sterilized glass, plastic	100	8 hours
Headloss	psig	Many	Many	Operator	-	-	-	-
Backwash (B/W) Frequency	hours	Many	Many	Operator	-	-	-	-

GW#1 - Groundwater treatment process no. 1 (KMnO4 oxidation; filtration)
 GW#2 - Groundwater treatment process no. 2 (Nanofiltration)

** Only if alum is being used in the process

The manganese-greensand filter was charged initially using a 3-percent KMnO_4 solution injected at a rate of 0.2 to 0.3 gal/min, until a total of 8 gallons had been pumped through the media (manufacturer's recommendation). During operation, the filter was backwashed when the ΔP had increased by about 10 lb/in² over its original startup value.

Finally, a series of jar tests were performed to evaluate alum [$\text{Al}_2(\text{SO}_4)_3 \cdot 14.3\text{H}_2\text{O}$] as a coagulant for the removal of suspended particles (oxidized Mn^{+2}). Required settling time, supernatant turbidity and floc stability were used as the determining factors for judging the effectiveness of the coagulant.

5.4.2 Nanofiltration. - The NF test system design parameters were as follows:

- Array 12:6 (2-stage) (refer to appendix C for diagram)
- Element FilmTec NF90-2540
- Recovery 80 percent
- Initial feed pressure 570 kPa (83 lb/in²) @ 25 °C
- Feed flow 18.2 L/min (4.8 gal/min)
- Projected permeate TDS 271 mg/L

The following chemical additions were added for scale control:

- Hypersperse AF 200TM @ 3.0 p/m
- Sulfuric acid to pH 7.00

The NF system was operated for nearly 1000 hours to allow time for any potential membrane degradation from fouling or scaling to develop. System startup was at operating pressures required to achieve 80-percent recovery at a feed flow of 18.2 L/min (4.8 gal/min). Thereafter, these same flows were maintained and system pressures were allowed to vary.

Process instrument data were manually recorded four times per day, with about 4 hours between observations. Just before data collection, the operator adjusted the system flows to the following:

- Feed 18.2 L/min (4.80 gal/min)
- Concentrate 3.6 L/min (0.96 gal/min)

These flows were achieved by adjusting the BPV (back pressure valve) on the high pressure pump recycle line and the FCV (flow control valve) on the concentrate line.

An SDI (silt density index) measurement of the cartridge filter effluent stream was made once a day. SDI is a measure of fouling potential of the feed from colloidal-size materials.

Samples of the feed, interstage, permeate, and concentrate (reject) streams were collected after 5, 362, 693 and 984 hours of operation. These samples were sent to a contract laboratory for the following analyses: major anions and cations, selected metals, hardness, alkalinity, and SiO_2 (silica). In addition, feed samples were analyzed for TOC and standard (heterotrophic) plate count (refer to table 2 for the specific constituents).

The 5u cartridge filter elements on the NF skid were changed about every 3 to 4 days.

A PID-controlled LMI chemical feed pump was used to regulate the addition of a 10-percent H_2SO_4 (sulfuric acid) solution for pH adjustment (fig. 4). Hypersperse AF 200 (anti-scalant) was added using a manually-controlled LMI pump. A fresh 5-percent solution was prepared about every 4 days.

6. PILOT TEST RESULTS AND CONCLUSIONS

6.1 Results

This section presents the test results for both the potassium permanganate oxidation and nanofiltration processes. Tabulations of the raw data and calculated parameters are presented in appendices A and B, respectively.

6.1.1 KMnO_4 oxidation. - The testing described below was designed to determine the following:

- (1) The concentration of KMnO_4 needed to reduce the Mn^{+2} level in well S6 ground water to below 0.05 mg/L (EPA secondary drinking water standard)
- (2) The required reaction time and an initial rate constant
- (3) The ability of manganese-greensand filtration to compensate for over- and under-dosing of KMnO_4
- (4) The efficiency of the greensand filter in removing oxidized manganese particles (MnO_2)
- (5) The effectiveness of alum for coagulating and settling MnO_2 precipitates

6.1.1.1 Optimization of KMnO_4 dosage. - Figure 6 shows the variation in manganese ion concentration in the raw feed water, and in the greensand influent and effluent, with increasing KMnO_4 dosage. The greensand influent curve appears to verify the optimum dose of 1.10 mg/L KMnO_4 (based on stoichiometry). Permanganate additions above and below this level result in significantly higher residual Mn^{+2} levels. Also, the greensand filter media seems to be effective in controlling the over- and under-dosing of KMnO_4 . It is interesting to note, however, that the water apparently picked up Mn^{+2} from the greensand in the region of optimum KMnO_4 dosage. From figure 6, the overall process appears to have an effectiveness limitation of about 0.05 mg/L.

6.1.1.2 Permanganate reaction kinetics. - Reaction kinetic experiments were conducted to optimize detention time prior to greensand filtration. Because of the pilot plant configuration, detention time was fixed (for a given process flow rate) by the combined capacities of the rapid mix tank, flocculation basin, and clearwell. At a process flow rate of 22.7 L/min (6 gal/min), this detention time was 55 minutes. The tests described below were designed to find out if a shorter detention time could be used.

Test water was taken from the detention tank. The optimum KMnO_4 dose of 1.1 mg/L was added to water in a jar test apparatus. After a brief rapid mixing period, stirring was slowed to mimic the stirring in the flocculation basin. At a predetermined reaction time the contents of the jar were vacuum filtered, through a Whatman #40 filter paper, into a flask containing NaHSO_3 to stop the oxidation. The Mn^{+2} concentration was then measured using the Hach DR/2000. This procedure was repeated for the following reaction times: 1, 1.25, 2, 5, 11, 21, 31, 41, 51, and 60 minutes. Results of this testing are shown on figure 7.




Figure 6. - Optimization of KMnO₄ dosage.




Figure 7. - Timed reaction test.

About 90 percent of the Mn^{+2} had been oxidized by the end of the first 1-1/2 minutes, and the reaction was complete within 20 minutes. By 40 minutes, distinct particles were forming. Shorter reaction times were attempted, but because the filtering process required about 2 minutes, obtaining a precise reaction stop time was difficult. Obviously, the permanganate reaction is not going to require significant detention time. The initial reaction rate was found to be second order dependent on both $[MnO_4^-]$ and $[Mn^{+2}]$ with a rate constant of $-0.198/mol\cdot sec$.

6.1.1.3 Filtration efficiency. - Figure 8 shows turbidity data for the 22.7 L/min (55-minute detention) tests. The greensand *effluent* turbidities were all at or below 0.06 ntu, indicating very efficient filtration. The greensand *influent* turbidities ranged from 5 to nearly 20 ntu, generally increasing with $KMnO_4$, suggesting a greater number of suspended MnO_2 particles.




Figure 8. - Turbidity data.

Although Mn^{+2} is oxidized rapidly, it may still require time to form filterable particles. To check this possibility, additional pilot tests were run with a 12-minute detention time and the same optimum $KMnO_4$ dosage of 1.1 mg/L. This procedure was accomplished by bypassing the flocculation basin, i.e., flowing directly from the rapid mix tank to the clearwell. As expected, greensand filter effluent Mn^{+2} concentrations were not significantly different from the earlier 55-minute detention tests (refer to data in appendix A). Interestingly, the filter effluent turbidities were also not that much different than before, ranging from 0.06 to 0.09 ntu.

6.1.1.4 Alum clarification. - Filter alum was evaluated for coagulating and settling MnO_2 precipitates. Jar tests were performed to determine optimum dosage, settling time, and supernatant clarity (in terms of turbidity). The best floc formation was achieved within the range of 20 and 40 mg alum/L. However, the required settling time of 90 minutes was excessive and the floc produced was very fragile. Slight agitation of the samples would tend to break up floc particles.

6.1.2 Nanofiltration. - The testing described below was designed to determine the following:

- (1) The performance of the FilmTec NF-90 membrane element in reducing TDS, hardness, sulfate, and manganese levels in well S6 ground water
- (2) The potential long-term adverse effects on the membranes from fouling or scaling
- (3) The blending ratio (NF permeate with filtered well water) to achieve high overall net recoveries

6.1.2.1 Operational data. - A total of 984 hours of operation accrued on the NF elements during this test phase. The raw data collected by the plant operators and other calculated values are tabulated in appendix B. Flow, temperature, conductivity, and pressure data are also graphically depicted on figures 9 through 14.

Referring to figure 9, feed and reject flows were held constant at 18.2 L/min (4.8 gal/min) and 3.6 L/min (0.95 gal/min), respectively, yielding an 80-percent recovery of desalted water (permeate). The total amount of permeate recovered is the summation of the following three flows:

- Stage 1, vessel 1 permeate (orange symbols)
- Stage 1, vessel 2 permeate (yellow symbols)
- Stage 2 permeate (blue symbols)

Figure 10 shows diurnal and long-term variation in feed temperature. This measurement was taken at the feed end of the first stage. Temperature has a significant effect on membrane performance and is used in calculations of net permeate flow, which is normalized to 25 °C.

Figure 11 displays system conductivities as $\mu S/cm$ (microSiemens per centimeter). Also, for better resolution, figure 12 shows an expanded view of the permeate conductivities. Note that the permeate conductivities show a gradual decrease throughout the test period, particularly in the second stage. This decrease may be the result of a "dynamic layer" developing on the membrane surface, either from biofouling or the deposition of colloidal-size particles (clays, silts). The greater effect in the second stage could be caused by the lower average brine velocity (about 16 percent less than the first stage). With reduced scouring action, microorganisms and colloidal particles settle out and attach to the membrane surface with greater ease. These contaminants are also present in greater numbers in the second stage.




Figure 9. - System flow rates (nanofiltration).




Figure 10. - Feed temperature.




Figure 11. - System conductivities.




Figure 12. - Permeate conductivities.

Figure 13 shows the feed, interstage, and reject operating pressures in lb/in². All three pressures are increasing with time, indicating again the possibility of membrane fouling or scaling (less likely). Also, referring to figure 14, the pressure drop across the first stage appears to increase at a slightly faster rate than across the second stage. The downward blip in the three data plots at about 30 hours elapsed time may have resulted from an initial instrument calibration problem (pressure or flow sensors). No other explanation is apparent from a review of the operator data sheets.

Chemical analyses were performed at 5, 362, 693, and 984 hours into the test program on four separate process streams (NF feed, interstage, permeate [combined], and reject), for the following constituents:

- Cations (Ca, Mg, Na, K)
- Anions (HCO₃, Cl, SO₄, NO₃, F)
- Metals (Al, Ba, Sr, Fe, Mn, P)
- Silica

Results of these analyses are shown in appendix D.


Table 3 summarizes %SR (percent salt rejections) for selected ions and for TDS that were calculated from the concentration data in appendix D. The values shown as ">" result from the permeate concentration falling below the detection limit. The %SR for other constituents (Al, Ba, Fe and NO₃), where both the feed and permeate concentrations were below the detection limit, could not be calculated. As shown, the average reduction in TDS, sulfate, and manganese all exceeded 90 percent. Also, based on the Ca⁺² and Mg⁺² data in table 3, the average reduction in hardness exceeded 98 percent.

In addition to the analyses indicated above, TOC and standard (heterotrophic) plate counts were run on detention tank effluent. The plate counts taken at the 5- and 362-hour sampling times were high—5700 and 4000 cfu/mL (colony forming units per milliliter), respectively. Based on these values, it was decided that plate counts should be run at several locations within the process to better define what might be a potential problem. Samples collected on November 1, 1994, resulted in the following data:

• Wellhead (sample tap)	7900 cfu/mL
• Detention tank effluent	7200 cfu/mL
• NF feed water (after cartridge filter)	1100 cfu/mL
• Interstage	1200 cfu/mL
• Permeate (second stage)	790 cfu/mL
• Reject	1900 cfu/mL

Because well S6 is fairly shallow (160 feet) and close to Lake Havasu (within a few hundred meters), the high bacterial populations could result from lake recharge. Deep inland wells generally have much lower plate counts. The city's practice of continually adding food-grade oil (Unocal White Oil) to the well as a lubricant may also be exacerbating the problem. This oil is *biodegradable* and was found at the surface and along the walls of the detention tank.

At least one SDI measurement was performed on the NF feed water (downstream from the 5µ cartridge filter) each day of testing. SDI measures fouling potential of the feed from colloidal-size materials. The recommended maximum SDI specified by the manufacturer for the NF-90






Figure 13. - System pressures.




Figure 14. - Stage pressure drops.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Table 3. - Percent salt rejection data.

Constituent	5-Hour	362-Hour	693-Hour	984-Hour	Average
Calcium	97.8	98.2	98.4	99.0	98.4
Magnesium	97.7	98.8	98.5	98.9	98.5
Sodium	80.0	84.5	81.8	85.8	83.0
Potassium	74.4	68.6	≥ 68.6	≥ 63.0	-
Manganese	≥ 90.0	≥ 90.0	≥ 90.7	≥ 90.6	≥ 90.3
Bicarbonate	83.5	91.8	89.4	91.2	89.0
Chloride	70.2	83.1	80.8	78.9	78.3
Sulfate	96.6	97.5	97.6	97.9	97.4
Fluoride	87.5	84.8	84.9	83.1	85.1
Silica	70.0	82.2	80.2	82.6	78.8
TDS	88.0	92.1	91.1	92.5	90.9

membrane is 5.0. During the 6-week test period, a total of 64 SDIs were performed with values ranging from 1.68 to 4.28. The average SDI was 2.98 with a standard deviation of 0.53.

6.1.2.2 Performance degradation. - Figures 15 and 16 present the average *NDP* (net driving pressure) and *NPF* (normalized permeate flow) for this test phase. Average *NDP* is the pressure available to force water through the membrane, and is calculated as follows:

$$NDP = P_f - P_p - P_o$$

where:

P_f = average feed pressure (average of feed and reject pressures)

P_p = pressure in the permeate line (gauge pressure)

P_o = average osmotic back pressure of the feed water (estimated by averaging the feed and reject concentrations and dividing by 100)

NPF is the total permeate flow adjusted to standard temperature (25°C) and to normalized *NDP* at startup, and is calculated as follows:

$$NPF = NDP_{startup} / NDP_{today} \times TCF \times F_p$$




Figure 15. - Average net driving pressure.




Figure 16. - Normalized permeate flow.



where:

TCF = temperature correction factor

F_p = permeate flow

The NPF graph (fig. 16) can be used to estimate the degree to which membranes are being fouled or if damage is occurring, and is commonly used to determine the time at which membranes should be chemically cleaned. Some drop in NPF with time is expected. For the TFC (thin-film composite) membranes used in this study, a 15- to 20-percent decline over a 3- to 5-year period would not be unusual. The roughly 16-percent drop in NPF experienced in this test program over a 1000-hour (6-week) test period is excessive by comparison.

One of two possible causes were considered for this decline in system performance: (1) the deposition of MnO_2 (oxidized manganese precipitates) on the membrane surface; and (2) biofouling.

6.1.2.3 Membrane autopsy and SEM analysis. - On November 11, 1994, autopsies were performed on 2 of the 18 NF elements, one of the lead elements in stage 1 (serial # A2282494; refer to appendix E) and the trailing element in stage 2 (serial # A2282495). Initial observations of the lead element membrane surface revealed no obvious fouling or scaling, perhaps only a slight and fairly uniform discoloration (darkening). Also, the vexar (plastic feed water-brine spacer located between membrane envelopes) showed no signs of any buildup. After measuring the dimensions of the active membrane area of the two leaves, one of the membrane surfaces was irrigated with deionized water and thoroughly squeegeed to collect any adhering deposits. Surprisingly, this operation yielded a significant amount of light brownish-colored material (the total quantity of material collected was later determined to have a dry mass of 0.32 grams; this material was collected from a membrane active surface area of 0.52 m²). The uniformity of deposition, color, consistency, and strength of adherence was determined to be consistent with biofouling. Similar material was found in the trailing element of the second stage, but to a lesser degree (dry mass of 0.09 grams).

Two-inch-square membrane samples were cut from the second leaf of each element for SEM (scanning electron microscopy) imaging to determine if biological cell structure and morphology could be identified. Some of the samples were gold-coated to enhance the imaging resolution and detail. Several showed characteristic rod-shaped bacterial cell forms (refer to fig. 17 as a typical example). No attempt was made to classify specific bacterial types or strains.

The sample collected from the lead element squeegeeing operation (liquid with suspended material) was digested and analyzed for trace metals using ICP (inductively-coupled plasma) spectroscopy. Because the concentration of Mn^{+2} was high in the feed water, the presence of MnO_2 (manganic dioxide) was suspected. A total of 25 metals were identified. Table 4 lists the metals found with a total mass ≥ 0.030 mg. Remember, these metals were collected from a membrane surface area of about 0.50 m².

From these analyses, it appears unlikely that a problem exists with manganese. However, the presence of such a high level of iron is surprising. The concentration of iron (total) in the NF feed water was ≤ 0.05 mg/L, significantly less than the general RO/NF process limitation for Fe^{+2} of 0.3 mg/L. Two possible explanations were considered:



Figure 17. - SEM showing characteristic rod-shaped bacterial cell forms.

Table 4. - Metals found on autopsied membrane surface.

Metal	Mass (mg)
Iron, Fe	8.1
Sodium, Na	2.5
Calcium, Ca	0.89
Chromium, Cr	0.56
Silicon, Si	0.55
Arsenic, As	0.30
Aluminum, Al	0.19
Zinc, Zn	0.15
Magnesium, Mg	0.14
Barium, Ba	0.037
Manganese, Mn	0.030
Lead, Pb	0.030

- Iron-fixing bacteria may have oxidized the available Fe^{+2} to Fe^{+3} (ferric iron) which deposited on the membrane, or may have concentrated iron within the biomass of the fouling layer (Bess, 1994).
- Some corrosion of system components may have occurred (both Cr [chromium] and Ni [nickel] were found on the membrane surface, which are major components of 304 and 316 stainless steel); all wetted components of the NF system were specified to contain only 316 stainless.

A final test was performed on the membrane surfaces (both lead and trailing elements) to determine if any physical degradation had occurred during operation. Congo red dye was applied to a small area of the membrane's surface and then wiped away after a few moments. By doing this, surface penetrations (pin holes, cracks, etc.) can be readily identified by a residual dye stain. No physical degradation was observed.

6.2 Conclusions

6.2.1 $KMnO_4$ oxidation. - The following conclusions were reached based on this test phase:

- The combination of $KMnO_4$ oxidation and manganese-greensand filtration effectively reduced Mn^{+2} in the well S6 ground water to an average concentration of 0.05 mg/L (fig. 6), which is the secondary MCL.

- The optimum KMnO_4 dose was found to be about 1.1 mg/L (fig. 6). Considering the amount of Mn^{+2} removed (0.62 mg/L [average influent concentration] - 0.05 mg/L [average effluent concentration]), this dose is equivalent to 1.93 mg/L KMnO_4 per mg/L Mn^{+2} , which is essentially the same as the stoichiometric requirement (section 5.2.1).
- Greensand filtration was effective in controlling the over- and under-dosing of KMnO_4 (fig. 6).
- KMnO_4 oxidation could be used with conventional dual- or multi-media filtration, i.e., without greensand, if an effective control could be employed for chemical dosing. From figure 6, lower Mn^{+2} concentrations appear to be achievable without greensand (near the optimum KMnO_4 dose of 1.1 mg/L).
- The reaction is extremely fast (fig. 7). About 90 percent of the Mn^{+2} is oxidized within the first 1-1/2 minutes. The initial reaction rate was found to be second order dependent on both $[\text{MnO}_4^-]$ and $[\text{Mn}^{+2}]$ with a rate constant of -0.198/mol-sec.
- The greensand effluent turbidities were all ≤ 0.06 ntu for the 55-minute data and ≤ 0.09 ntu for the 12-minute data (appendix A), indicating efficient filtration.
- In jar testing for coagulating and settling MnO_2 precipitates, 20 to 40 mg/L alum was found to produce the best floc formation. However, the required settling time of 90 minutes was excessive and the floc produced was very fragile. It is therefore concluded that alum is not effective for this application.

6.2.2 Nanofiltration. - The following conclusions were reached based on this test phase:

- NF effectively reduced the concentrations of all contaminants of concern (see section 3.0) to below MCLs. The average TDS rejection for the 984-hour test was 90.9 percent. Specific ions of interest were removed as follows:

Constituent	% Rejection	Average Conc. Permeate (mg/L)
Ca^{+2} (hardness)	98.1	1.6
Mg^{+2} (hardness)	98.5	0.5
SO_4^{-2}	97.4	7.7
Mn^{+2}	≥ 90.3	< 0.05

- The average TDS (summation of ions [appendix D]) for the feed and permeate were 826 and 75 mg/L, respectively. By blending the NF permeate and filtered well water at an approximate ratio of 1:1.25, a net overall recovery of 90 percent (at 496 mg/L TDS) could be achieved. However, Mn^{+2} would have to be removed from the well water, prior to blending, to meet its secondary MCL of 0.05 mg/L.
- NPF dropped by about 16 percent during the 6 weeks of testing (fig. 15). During this same period, system feed pressure increased from about 75 to 89 lb/in² (fig. 13). The membrane autopsy, SEM analysis, and high heterotrophic plate counts (measured throughout the NF system) all point to biofouling as the cause.

- UV (ultraviolet) disinfection was not effective in controlling microbial contamination (biofouling) of the NF system. Chloramines or chlorination-dechlorination would provide more effective control; however, Mn^{+2} oxidized by these chemicals would have to be removed by media filtration prior to desalting. Also, because of the high microbial populations in the feed water, residual cell components of microorganisms killed during disinfection may have to be removed as well. These dead organisms can provide a food source for other live bacteria, and some evidence suggests that they may also deposit on and adhere to the membrane contributing directly to a biofouling layer (Ridgeway, 1984).
- The use of a food-grade oil (Unocal White Oil) as a well pump lubricant may have contributed to the biofouling. A plate count taken at the wellhead sample tap indicated 7900 cfu/mL (section 6.1.2.1). In addition, residues of the oil were found at the surface and along the walls of the detention tank.
- Very little manganese was found on the membrane surface of the autopsied first stage lead element (refer to section 6.1.2.3). However, a considerable quantity of iron was present. Because the feed-water concentration of iron was low (0.05 mg/L), it is suspected that iron-fixing bacteria may have oxidized or concentrated Fe^{+2} within the biomass of the fouling layer.

7. FULL SCALE TREATMENT

7.1 General

Lake Havasu City has several choices and decisions to make regarding the construction of a full-scale water treatment plant. Among these are plant location, level of treatment, and the amount of surface water versus ground water used to meet water demands. Full-scale treatment for Lake Havasu City is estimated to be accomplished over a phased expansion. The city and their consultant, HDR Engineering Inc., have concluded that water demands for the city are projected according to table 5 below.

Table 5. - City average day water demands.

Year	Water Demand (acre-ft\yr)	Water Demand (Mgal/d)
1994-95	14,562	12.99
2004-05	19,180	17.12
2015	24,454	21.8

City officials have stated a size preference for a full-scale treatment plant, initially at 12 Mgal/d (million gallons per day), with a projected expansion of 12 Mgal/d, for a total plant capacity of 24 Mgal/d. This report addresses several treatment plant options available to the city at 12 Mgal/d capacity and, in section 8, presents construction cost estimates that the city can consider in final design.

It is important to note that the current and recent past water quality levels of LHC drinking water meet all EPA primary drinking water standards, which are designed to protect the public health (if the current action level for lead of 0.015 mg/L had been in place in 1991, then southern wells S4, S6, and S17 would have exceeded the standard).

Secondary drinking water standards are in effect to protect the public welfare by providing guidelines regarding the taste, odor, color, and other aesthetic aspects of the water. A review of the city's ground-water quality from wells in the north, central, and southern well fields indicates that several secondary standards have been exceeded in recent years and currently still exceed the manganese, TDS, and sulfate MCLs. HDR Engineering, Inc., addressed these secondary water quality levels in their Comprehensive Water Master Plan (HDR Engineering, 1992) with a discussion of treatment options for each constituent. Based on this information, Reclamation was asked to perform field pilot testing at well S6, which has historically contained high levels of manganese, TDS, and sulfates.

Full-scale treatment alternatives presented in this report fall into two levels of treatment. A significant cost increase occurs from one level to the next. These levels can be described as:

- Manganese removal using the piloted process of permanganate oxidation followed by filtration. This alternative will remove manganese but will not affect total dissolved solids.
- A higher level of treatment which would provide, or nearly provide, full compliance with all secondary standards of the Safe Drinking Water Act. These processes of NF and lime softening are included for complete and partial compliance, respectively.

7.2 Manganese Removal (KMnO₄ Oxidation)

The results of pilot testing on ground water indicate that manganese removal can be accomplished by a water treatment plant employing potassium permanganate (KMnO₄) oxidation followed by filtration. Full-scale ground-water treatment would consist of the following unit processes, as shown in the process flow diagram on figure 18: raw water pumping, permanganate feed system, 2-stage mixing, filtration, controls for monitoring and compensating for over- or under-dosing of KMnO₄, clearwell, post-disinfection, and booster pumping.

Formation of the precipitate MnO₂ (manganic dioxide), from the oxidation of Mn⁺² (manganese), requires a rapid mix step followed by a slow mix, or flocculation step. The rapid mix step can be accomplished by an agitator-mixer designed to impart adequate energy for the size and shape of the rapid mix tank. A detention time of 1 minute is recommended for rapid mixing. From the piloting work, a detention time for flocculation of about 20 minutes is recommended.

The optimum amount of KMnO₄ required for the oxidation process was determined to be stoichiometric, based on the concentrations of soluble manganese and iron present (refer to section 6.1.1.1). Two control options could be considered for KMnO₄ addition: the use of greensand filtration for the compensation of over- and under-dosing; and the use of an effluent monitor and feedback loop to control the chemical feed pump. Test results indicated that although greensand filtration effectively controlled over- and under-dosing, the use of greensand apparently caused a slight increase in the soluble manganese level of the filter effluent at KMnO₄ doses that were determined to be near optimum (refer to section 6.1.1.1 and fig. 6).




Figure 18. - Water treatment with potassium permanganate oxidation—Lake Havasu City water treatment study.

Because of this increase, and the higher cost of greensand filtration compared to conventional filtration, a multi-media (sand and anthracite) filter is recommended instead of greensand. This recommendation assumes that an effective KMnO_4 feed control system is commercially available for incorporation in the process design.

Following filtration, a post-disinfection step, consisting of chlorine addition, is recommended. The design includes a 30-minute chlorine contact basin, which also serves as a wetwell for the finished water booster pumping to the city's distribution system. Chlorine was selected because the final trihalomethane formation potential is low. Should this THMFP increase or more stringent limits be imposed for THMs, the city may have to use an alternate disinfectant, such as chloramine or ozone.

7.3 Full Compliance

7.3.1 General. - To achieve full compliance with secondary drinking water standards, contaminants which have repeatedly exceeded established MCLs in the city's ground water (manganese, sulfate, and TDS), must be reduced in concentration. Only a limited number of treatment methods can accomplish this reduction and, as shown in this report, the cost of treatment increases proportionately with levels of removal.

The nanofiltration option includes blending with partially treated ground water so that the volume of water treated by NF, and thus overall treatment costs, are reduced. The lime softening option does not remove all secondary drinking water contaminants to below the MCL, and therefore does not produce a product water that is in full compliance with all secondary MCLs. However, the lime softening option does have the potential to be blended with other higher quality waters, such as NF-treated ground water or surface water, to achieve full compliance.

7.3.2 Nanofiltration. - As discussed earlier in section 5.2.2, NF is a separation process that desalts water by the application of hydrostatic pressure to drive feed water through a semi-permeable membrane. A major portion of the water's impurity (dissolved salts) remains behind and is discharged as waste brine; relatively pure water emerges at near atmospheric pressure. Operating pressures for NF are in the range of 75 to 150 lb/in^2 . Typical ion rejections are 90 to 95 percent for divalent ions (Ca^{+2} , Mg^{+2} , SO_4^{-2}), and 60 to 70 percent for monovalent ions (Na^+ , K^+ , Cl^- , HCO_3^-).

A proposed flow scheme for LHC using NF is presented on figure 19. As shown, the raw feed water is split, after pumping, with half of the flow directed to NF treatment, and the remaining half to KMnO_4 oxidation treatment for the removal of manganese. Because the NF product is of such high quality (far exceeds drinking water standards), the two product streams can be blended and still meet secondary MCLs. Also, by doing this blending, the overall treatment cost is lower than if the entire flow stream were to receive NF treatment.

Pretreatment is critical to protect membranes from scale deposits and colloidal and biological fouling. For LHC ground water, the following NF pretreatment is recommended: disinfection to destroy microorganisms; polymer addition and filtration to remove suspended colloidal materials; and the addition of an anti-scalant and acid to prevent scaling of the membranes.

Table 6 presents a summary of the anticipated ion concentrations in the proposed NF plant for the following flow streams: feed, reject brine, permeate (product), and blended (or final) product.




Figure 19. - Water treatment with nanofiltration—Lake Havasu City water treatment study.

Table 6. - Nanofiltration ion concentrations.

Constituent	Feed (mg/L)	NF Brine (mg/L)	NF Permeate (mg/L)	Blended Permeate (mg/L)
Calcium	84.4	400	1.39	48.1
Magnesium	29.5	120	0.46	16.7
Sodium	113	500	19	71.6
Potassium	3.33	11	≤1.0	≤2.3
Barium	<0.05	0.16	<0.05	
Strontium	1.35	7.4	<1.0	
Iron	<0.05	<0.05	<0.05	
Manganese	<0.05	2.3	<0.05	
Bicarbonate	173	780	19	105
Chloride	108	430	23.3	70.7
Sulfate	293	1600	7.7	167
Nitrate	<0.80	0.7	<0.50	
Fluoride	0.93	3	0.13	0.58
Silica (total)	18.3	77	3.88	12
Alkalinity	173	780	19	105
Hardness	333	1500	5.33	189
Total dissolved solids (TDS)	826	3932	75	496

7.3.2.1 Brine production. - Reject brine, or concentrate, is the waste stream resulting from the NF desalting process. It contains most of the impurities (dissolved salts) originally present in the feed water. The estimated ionic makeup of this reject stream for the proposed LHC plant is shown in the second column of table 6 (NF Brine). As shown on figure 19, about 1.34 Mgal/d of reject brine will be produced from the nanofiltration process.

7.3.2.2 Brine disposal. - Generally, brine disposal options include the following: surface water discharge, deep well injection, evaporation, spray irrigation, and constructed wetlands. However, for LHC, as with most other municipalities, brine disposal choices are restricted by State and Federal regulatory requirements.

By far, the least costly brine disposal option is discharge to a nearby surface water. Surface water discharges are regulated by the Clean Water Act and, as such, would be subject to permit restrictions. Arizona's permit program under the National Pollutant Discharge Elimination System program would probably not allow a high saline discharge to the Colorado River. Such cost-prohibitive treatment requirements make this option infeasible for the city.

Deep-well injection is possible in Arizona; however, an Aquifer Protection Permit is required with discharge limits which also are likely to make this option cost prohibitive. It would have to be shown that injection of the brine would not adversely impact sub-surface aquifers. This demonstration can be done with geohydraulic modeling of the aquifer, once the aquifer characteristics are known and understood.

The three remaining options for brine disposal are evaporation, spray irrigation, and the creation of a constructed wetlands. The final selection of the type of disposal depends on many factors. Combinations of these options are also possible and may satisfy several goals of the city.

1. *Evaporation:* An evaporative pond system of about 250 surface acres would evaporate the 1.34 Mgal/d of brine, based on an estimated net evaporation rate of 6 ft/yr. This land area can be separated into several ponds to suit the desired goals and objectives of the disposal option. The liner for the ponds would be PVC, HDPE, or compacted clay if locally available. A force main system from the plant to the pond is assumed, which includes a storage tank, sized at 5 days production (6.7 Mgal), and a pump station operating at 4653 gal/min for 24 hours every 5th day. This disposal option was assumed for preparation of the cost estimate (section 8), primarily because of its popularity.
2. *Irrigation:* In a desert environment, a high priority must be placed on both water conservation and the reuse of waste waters to lessen water demands where possible. The city's "Comprehensive Master Water Plan" devotes an entire chapter to the scenario of developing areas around the city which can use reclaimed water for the irrigation of landscaped areas, thereby lowering water demands. Specifically identified in this Master Water Plan are nine potential reclaimed water sites that could use an average monthly rate of 1.3 Mgal/d and a peak monthly rate of 2.9 Mgal/d of reclaimed water for irrigating landscaped areas. The report concludes that because the city's three reclaimed water plants produce only 1.4 Mgal/d, any additional reclaimed water would lower the city's potable water demand. Therefore, disposal of NF brine by landscape irrigation is an attractive option serving a dual purpose, reducing water demands while increasing the city's landscaping. The ADEQ (Arizona Department of Environmental Quality) must approve such a plan.



Using appropriate salt-tolerant grasses and foliage, irrigation of landscaped areas can be applied at a rate of about 0.3 in/d and require 160 irrigable acres. Such areas can include open space, green belts, golf courses, highway medians, and resort complexes. An irrigation system would require a storage tank or lined holding pond sized for at least 2 days of storage (6.7 Mgal), a pump station that would operate at 1860 gal/min for 12 h/d, and a force main-distribution network.

3. **Wetlands:** The creation of a wetlands in a desert environment is aesthetically pleasing in that it creates an environment where selected brine-tolerant plants can proliferate. At a pilot saline wetlands in Hemet, California, alkali bulrush, cattails, arrow grass and spikerush plants have survived and flourished in the reject brine from a reverse osmosis demonstration plant (Boegli and Thullen, 1994). In addition, the wetlands will attract waterfowl and animals, i.e., ducks, geese, frogs, and insects. The ADEQ must approve such a brine disposal plan, and there would likely be a permitted discharge from a wetlands system to surface water or to the ground-water aquifer. Alternately, the discharge brine would be further concentrated in an evaporation pond.

For the 12 Mgal/d water treatment facility being considered in this report, a wetlands area of 8.2 acres is required to dispose of 1.34 Mgal/d of brine produced. This area is based on an application rate of 6 in/d, which is the application rate in use at Hemet, California, a site similar in climate to LHC. The other main features of a wetland brine disposal system include a storage tank or lined holding pond sized at about 5 days of flow (6.7 Mgal), a pump station that can operate at 4653 gal/min for 24 hours every 5th day, and a force main.

7.3.3 Lime softening. - Lime softening is a widely used process for clarification, reduction of hardness and salinity, and heavy metals removal in natural waters. The process requires the presence of a significant concentration of HCO_3^- (bicarbonate ion) in the raw water.

$\text{Ca}(\text{OH})_2$ (lime) is added to the water at ambient temperature. The following reactions occur:



In water containing a reasonable amount of bicarbonate, a voluminous precipitate, consisting primarily of calcium bicarbonate, is formed. This precipitate entraps suspended particles of silica and other materials which cause turbidity in the raw water. To enhance flocculation, a small amount of coagulant, say 10 p/m of ferric chloride, is added.

In waters containing heavy metals like iron and manganese, these metals are precipitated as hydroxides or oxides, which are caught up in the precipitate. Reaction zone pH and residence time can be adjusted to ensure satisfactory removal of manganese.

A lime softening ground-water treatment plant for LHC would consist of rapid mixing, flocculation, settling, and filtration. Figure 20 illustrates these unit operations along with the raw and finished water pumping, a clearwell, and post-disinfection using chlorine.

Rapid mixing, flocculation, and settling occur in one unit, the solids contact reactor. These steps may be separated for greater system flexibility, but at a higher construction cost. A slurry of




Figure 20. - Water treatment with lime softening—Lake Havasu City water treatment study.

lime in water is added to raw feed water in a high intensity mixing vessel or zone in which reactions (1) and (2) are carried out. Flocculation occurs under gentle agitation, and settling occurs in a zone with very low flow rates. The objective is to create large agglomerates of precipitate which will settle rapidly. Most of the solids are removed as a slurry from the bottom of the reactor. The clarified water is filtered, usually with a rapid sand and anthracite filter, to remove the balance of the solids and produce a clear, treated effluent. The filter is periodically backwashed with treated water to remove the solids. Backwash water is typically returned to the reactor.

The chemistry of this process is well understood. Sludge quantity and composition have been estimated, based on a process feed flow similar to well S6, and are included in appendix F.

7.3.3.1 Sludge production. - Sludge from lime softening results from the initial raw water solids, plus the precipitate formed from the introduction of lime. At 12 Mgal/d, this volume is estimated to be 66,000 gal/d of a slurry that contains about 6 percent solids by weight. If this sludge was dried, it would weigh about 33,000 lb/d. These solids collect in the bottom of the solids contact reactor and are periodically pumped to a sludge holding tank and filter press for thickening.

7.3.3.2 Sludge disposal. - It is recommended that the drying of thickened sludge at LHC be accomplished in a lined sludge drying bed. The final quantity of solids that would be hauled to a local landfill would be about 30,300 yd³/yr, at a solids content of 50 percent. For cost estimation purposes, the hauling distance is estimated to be 5 miles.

7.4 Potential Alternatives Not Pilot-tested

Each summer, LHC experiences nationwide high temperatures and it struggles to provide enough water to its residents. To compound this problem, existing wells are declining in productivity as overall water levels in the vicinity recede. The quality of water found in Lake Havasu exceeds the quality of water in the wells. Both manganese and TDS in Lake Havasu are at levels that would not warrant the expense of their removal. Thus, a lower capital cost for treatment of surface water would be required than for ground water. To solve the city's imminent water shortage problem, a surface water treatment plant, sized to satisfy the city's critical summertime shortage, is recommended. The finished water quality data generated from such a plant would benefit the city in design of a larger ground-water treatment plant, both in terms of a lower capacity and for blending with ground water. By using the higher quality and less costly surface water, residents would pay less for their water because the volume of treated ground water would be lower.

Other ground-water treatment processes could not be tested during this pilot test, but they represent additional alternatives to the city to meet future water demands.

8. TREATMENT COSTS

8.1 General

Construction, annual O&M (operations and maintenance), and life cycle cost estimates for a 12-Mgal/d plant capacity are provided for the following three levels of ground-water treatment:

- Manganese removal using potassium permanganate oxidation.
- Full compliance with both primary and secondary drinking water standards using nanofiltration.
- Complete removal of manganese and partial removal of sulfates and TDS using lime softening.

Capital cost estimates are based on a combination of direct quotes from manufacturers, plus allowances for installation, and a newly-developed Reclamation software program that uses cost curves prepared by the EPA (Environmental Protection Agency). This program uses the raw water quality from the site and current indices of the ENR (*Engineering News Record*), along with the Producer Price Index, to calculate both construction and O&M cost estimates.

Capital construction costs are for individual treatment units, including all equipment, but do not include costs for land ownership, rights of way, special site-work, easements, or yard and offsite piping. Also not included are costs for an intake structure, grit removal equipment, or buildings (chemical feed, storage, administration, or laboratory). Legal, administrative and engineering costs for permitting, water quality monitoring, testing, and modeling are not included, nor are general contractor overhead and profit, fees for engineering, legal and fiscal services, and interest during construction. For these reasons, the cost estimates found herein are valuable for a comparison of the alternatives presented, and are not final construction estimates.

The basis for the cost estimates is the EPA's Research and Development manual numbered EPA-600/2-79-162a, titled "Estimating Water Treatment Costs." Each unit process is defined in terms of the following eight subcategories: excavation and site work, concrete, steel, labor, pipe and valves, electrical equipment and instrumentation, and housing. These subcategories are linked to various cost indices and, for this report, have been updated to December 1994 or the *Engineering News Record* construction cost index for January 1995. Each unit's estimate also includes the cost of a standby or spare unit plus a 15-percent allowance for miscellaneous and contingency items. For O&M costs, the EPA curves are also used with updates for electrical energy costs, maintenance materials, chemicals, and labor. Citizens Electric provided a value of nearly \$0.06/kWh for plants under 1,000 kW. Chemical costs are estimated from recent contacts with chemical supply companies or from a chemical periodical. Labor has been estimated at \$20.00/h.

8.2 KMnO₄ Oxidation

A plant that uses potassium permanganate to oxidize manganese in the well S6 feed water is described in section 7.1, and is shown schematically on figure 18. Because little water is lost in this treatment scheme, the flow rate of 12 Mgal/d is used for all unit processes. This treatment plant will effectively remove manganese down to its MCL of 0.05 mg/L. However, other secondary drinking water parameters such as sulfates and TDS will remain above their maximum contaminant levels.

8.2.1 Construction cost. - The total estimated construction cost for a plant which removes manganese using potassium permanganate oxidation is \$3,018,700, as shown in table 7. This cost is equivalent to about \$0.25 per daily gallon.

8.2.2 Operations and maintenance costs. - The total estimated annual O&M cost for a plant which removes manganese using potassium permanganate oxidation is \$301,500, as shown in table 7. This cost is equivalent to about \$0.07 per thousand gallons treated.

Table 7. - Construction and annual operations and maintenance costs (12 Mgal/d).

Option 1: Potassium permanganate oxidation

	Construction Cost (\$)	Annual O & M (\$)
Raw Water Pumping ¹	145,200	44,600
Potassium Permanganate Addition ²	74,200	62,500
Rapid Mix ³	72,200	30,000
Flocculation ⁴	247,000	8,000
Dual Media Filter ⁵	1,422,100	83,100
Filter Backwash Pumping ⁶	455,000	10,800
Chlorination ⁷	74,000	33,400
Clearwell ⁸	393,000	8,000
Booster Pumping ⁹	136,000	21,100
Total	3,018,700	301,500

¹ Six pumps with intake screens, each rated at 2083 gal/min at 50 feet of TDH

² Concentration of 1.2 p/m potassium permanganate

³ 1-minute detention time, $G = 900/\text{second}$

⁴ 20-minute detention time

⁵ 1700 ft² filter area, includes dual media and housing

⁶ Four pumps, each rated at 6375 gal/min at 75 feet of TDH

⁷ Residual concentration of 3 p/m chlorine

⁸ 0.25-Mgal capacity

⁹ Four pumps, each rated at 2083 gal/min at 231 feet of TDH

8.3 Full Compliance using Nanofiltration

If the residents of LHC decide they want drinking water that meets all primary and secondary drinking water standards, then an NF plant is recommended. NF produces water of such high quality that blending with available raw water sources will still produce a combined product meeting all secondary MCLs. Data gathered during pilot testing suggest that a full scale treatment plant producing 12 Mgal/d of full-compliance water could treat 6 Mgal/d for manganese alone, and 6 Mgal/d with NF.

8.3.1 Construction cost. - The water treatment plant discussed above, described in section 7.3.2 and shown schematically on figure 19, will cost about \$16,910,100, as shown in table 8. This cost is equivalent to \$1.41 per daily gallon. This cost estimate includes brine disposal using total evaporative drying beds for half of the brine and spray irrigation of greenbelts for the other 50 percent of the brine flow.

Table 8. - Construction and annual operations and maintenance costs (12 Mgal/d).

Option 2: Nanofiltration

	Construction Cost (\$)	Annual O & M (\$)
Raw Water Pumping ¹	217,100	66,700
Chlorination ^{2,3}	35,200	16,600
Polymer ^{2,4}	46,200	87,600
Dual Media Filter ^{2,5}	949,200	47,900
Filter Backwash Pumping ^{2,14}	269,300	8,300
Dechlorination ^{2,6}	46,200	87,600
Acid Addition ^{2,7}	778,100	11,200
Anti-Scalant ^{2,8}	87,900	285,900
Nanofiltration ²	3,581,400	622,400
Brine Disposal ²	8,735,000	436,800
Potassium Permanganate Addition ^{9,10}	46,200	61,400
Rapid Mix ^{9,11}	40,000	12,200
Flocculation ^{9,12}	186,000	5,600
Dual Media Filter ^{9,13}	949,200	47,900
Filter Backwash Pumping ^{9,14}	269,300	8,300
Chlorination ³	78,500	35,700
Clearwell ¹⁵	393,000	8,000
Booster Pumping ¹⁶	202,300	31,500
Total	16,910,100	1,881,600

- ¹ 13.4 Mgal/d, 6 pumps with intake screens, each rated at 1542 gal/min at 50 feet of TDH
- ² Flow stream for nanofiltration process, 6.7 Mgal/d
- ³ Concentration of 1 p/m chlorine
- ⁴ Concentration of 2 p/m polymer
- ⁵ 930 ft² filter area
- ⁶ Concentration of 2 p/m sodium bisulfite
- ⁷ Concentration of 25 p/m of 93% sulfuric acid
- ⁸ Concentration of 7 p/m anti-scalant
- ⁹ Flow stream for potassium permanganate oxidation process, 6.7 Mgal/d
- ¹⁰ Concentration of 1.2 p/m potassium permanganate
- ¹¹ 1-minute detention time
- ¹² 20-minute detention time
- ¹³ 930 ft² filter area
- ¹⁴ Four pumps, each rated at 3475 gal/min at 75 feet of TDH
- ¹⁵ 0.25-Mgal capacity
- ¹⁶ Four pumps, each rated at 2083 gal/min at 231 feet of TDH
- ¹⁷ Assumes half of brine is spray irrigated and half is evaporated

8.3.2 Operations and maintenance costs. - The total estimated annual O&M cost for a 12-Mgal/d ground-water treatment plant using NF is \$1,881,600, as shown in table 8. This cost includes a membrane cleaning apparatus, and the cost of membrane replacement every 3 years. This cost is equivalent to \$0.43 per thousand gallons treated.

8.4 Lime Softening

As described in section 7.3.3, lime softening of ground water will remove the manganese to levels below the MCL (as long as influent values do not differ much from well S6). Lime softening will not reduce TDS or sulfates to secondary drinking water standards. However, these standards could be achieved by blending with water of higher quality, such as surface or ground water that has been treated with NF.

8.4.1 Construction cost. - The 12-Mgal/d lime softening ground-water treatment plant, which is shown schematically on figure 20, will cost about \$7,818,400, as shown in table 9. This cost is equivalent to about \$0.65 per daily gallon.

Table 9. - Construction and annual operations and maintenance costs (12 Mgal/d).

Option 3: Lime Softening

	Construction Cost (\$)	Annual O & M (\$)
Raw Water Pumping ¹	145,200	44,600
Ferric Sulfate Addition ²	488,900	723,100
Lime Feed Addition ³	266,500	290,000
Solids Contact Reactor ⁴	1,549,700	66,200
Dual Media Filter ⁵	1,422,100	83,100
Acid Addition ⁶	28,000	5,900
Filter Backwash Pumping ⁷	455,000	10,800
Chlorination	74,000	33,400
Clearwell ⁸	393,000	8,000
Sludge Disposal ⁹	2,860,000	462,500
Booster Pumping ¹⁰	136,000	21,100
Total	7,818,400	1,748,600

- 1 Six pumps with intake screens, each rated at 1542 gal/min at 50 feet of TDH
- 2 Concentration of 10 p/m ferric sulfate
- 3 Concentration of 185 p/m of hydrated lime
- 4 Four pumps, each rated at 2083 gal/min at 231 feet of TDH
- 5 1700 ft² filter area, includes dual media and housing
- 6 Concentration of 2.5 p/m of 93% sulfuric acid
- 7 Ten pumps, each rated at 2505 gal/min at 75 feet of TDH
- 8 0.25-Mgal capacity
- 9 Includes sludge pumping, storage, filter press thickening, drying beds, and off-site hauling up to 5 miles
- 10 Four pumps, each rated at 2083 gal/min at 231 feet of TDH

8.4.2 Operations and maintenance costs. - The total estimated O&M cost for a 12-Mgal/d lime softening plant is \$1,748,600, as shown in table 9. This cost is equivalent to about \$0.40 per thousand gallons treated.

8.5 Cost Analysis

Table 10 summarizes the ground-water treatment options presented in this study. It is important to note that these options are not equivalent in terms of the level of treatment each provides and that both construction and O&M costs increase with the increasing levels of treatment. These costs also do not represent final capital costs as explained in section 8.1. It is also important to note that final costs depend on the type of residual disposal option selected. For NF, the combined use of single-lined evaporation ponds and spray irrigation is assumed.

Table 10. - Cost summary of ground-water treatment options (12 Mgal/d).

	Option 1	Option 2	Option 3
Construction Cost (\$)	3,018,700	16,910,100	7,818,400
Annual O&M (\$)	301,500	1,881,600	1,748,600
Construction Cost (\$)/Daily Gallon	0.25	1.41	0.65
O&M Cost (\$)/1000 Gallons	0.07	0.43	0.40

A 20-year life cycle cost analysis is presented in table 11. The analysis is presented in terms of total present worth and total annual cost. A final cost/1000 gal of treated water is also shown.

8.6 Surface Water Treatment Costs

Assuming that lime or alum chemical treatment will remove suspended solids and the city can obtain all necessary water rights, a 12-Mgal/d water treatment plant for surface water would cost about \$9,300,000 or \$0.78/daily gallon to construct (HDR Master Plan, table 9-2, and figure 9-6). It would also cost about \$4,190,000 to operate per year or \$0.96/1000 gallons (interpolated from HDR Master Plan table A3-4).

9. CONCLUSIONS

This report concludes the following:

1. Water treatment costs to remove contaminants of concern to the residents of LHC vary proportionately with the level of treatment provided. For a 12-Mgal/d (product) treatment plant, these costs range from \$0.25 to \$1.41 per daily gallon for construction, and from \$0.07 to \$0.43 per 1000 gallons treated for annual O&M, as detailed below:
 - a. For a 12-Mgal/d water treatment plant employing potassium permanganate oxidation and the unit operations displayed on figure 18, the construction cost estimate is \$3,018,700 and the annual O&M costs are \$301,500.
 - b. For a 12-Mgal/d water treatment plant employing nanofiltration and the unit operations displayed on figure 19, the construction cost estimate is \$16,910,100 and the annual O&M costs are \$1,881,600.

Table 11. - Life cycle costs for ground-water treatment options.

Basic Assumptions			
Study Period	20 years		
Annual Interest Rate	6.5%		
Capital Recovery Factor	0.0908		
Present Worth Factor	11.019		
	Potassium Permanganate	Nanofiltration	Lime Softening
Capital Cost	\$3,018,700	\$16,910,100	\$7,818,600
Present Worth of Annual Operating Cost ¹	\$3,322,200	\$20,733,400	\$19,267,800
Total Present Worth	\$6,340,900	\$37,643,500	\$27,086,400
Annualized Capital Cost ²	\$274,100	\$1,535,400	\$709,900
Annual Operating Cost	\$301,500	\$1,881,600	\$1,748,600
Total Annual Cost	\$575,600	\$3,417,000	\$2,458,500
Cost/1000 Gal of Product ³	\$0.13	\$0.78	\$0.56

¹ Present worth of annual operating cost is annual O & M cost times the present worth factor

² Annualized capital cost is capital cost times capital recovery factor

³ Total annual cost/(365x12,000)

c. For a 12-Mgal/d water treatment plant employing lime softening and the unit operations displayed on figure 20, the construction cost estimate is \$7,818,400, and the annual O&M costs are \$1,748,600.

2. Based on the assumptions made in this report and the life cycle cost analysis assuming 20 years at an interest rate of 6.5 percent, the total annual cost of a 12-Mgal/d plant for the three alternatives studied are:

- 1) Potassium permanganate oxidation - \$575,600 or \$0.13/1000 gal
- 2) Nanofiltration - \$3,417,000 or \$0.78/1000 gal
- 3) Lime softening - \$2,458,500 or \$0.56/1000 gal.

Refer to section 8.1 for an explanation as to what these life cycle costs include.

3. For a 12-Mgal/d treatment plant employing nanofiltration and the unit operations displayed on figure 19, potential benefits might be realized by using about 1.34 Mgal/d of reject brine in either a reclaimed water capacity that could lower irrigation demands on the city's water system, or to create a wetland environment.


10. RECOMMENDATIONS

Based on the conclusions noted above, the following recommendations are made:

1. LHC is experiencing a severe problem with manganese in their drinking water. Although manganese is only a secondary drinking water standard, and the quality of the water served to the residents of the city meets all Federal and State primary drinking water standards, manganese-related problems such as discolored water, stained clothing, and clogged waterlines are a continuing concern. It is recommended that the city use the economic and treatment process conclusions contained in this report in their planning for future water treatment expansion, and that consideration be given to achieving full compliance with secondary drinking water standards.
2. If LHC considers nanofiltration an affordable water treatment option, it is recommended that meetings be arranged with the State of Arizona to determine specific requirements for the brine disposal options presented in this report.
3. From a water shortage standpoint, the city is urged to proceed with the construction of a temporary surface water treatment plant sized to provide enough water to meet the critical summertime demands.

11. REFERENCES

- Bess, Vicki, microbiologist, BBC Laboratory, Environmental Microbiological Services, Tempe, AZ, teleconference on December 12, 1994.
- Boegli, W. J. and J. S. Thullen, "Eastern Municipal Water District RO Treatment/Saline Vegetated Wetlands Pilot Study," *Currents*, Bureau of Reclamation, Denver, CO, pp. 6-10, Spring/Summer 1994.
- FilmTec Corporation, "Quick Reference Guide for the NF70 Nanofiltration Membranes," undated.
- Glase, William H., "Chemical Oxidation," chapter 12, *Water Quality and Treatment - A Handbook of Community Water Supplies*, 4th ed., American Water Works Association, McGraw-Hill, Inc., New York, NY, 1990.
- HDR Engineering, Inc., "Lake Havasu City Water Master Plan," January, 1992.
- Ridgeway, H. F., et al., "Biofilm Fouling of RO Membranes - Its Nature and Effect on Treatment of Water for Reuse," *Journal, American Water Works Association*, pp. 94-102, June 1984.



APPENDIX A

KMnO₄ oxidation and greensand test data

KMnO4 Oxidation/Greensand Test Data

Date	Feed (L/min)	KMnO4 (mg/L)	Res. Time (min)	Sample	Mn (mg/L)		Sample	Mn (mg/L)		Sample	Mn (mg/L)		Avg Temp. (deg C)	Raw Feed		Turbidity (ntu)	
					Hach	Westech		Hach	Westech		Hach	Westech		GS Influent	GS Effluent		
9/11/94	22.7	0.54	55	GS1-1	0.613	0.57	GS1-2	0.252	0.21	GS1-3	0.033	<0.05	24.3	0.09	5.09	0.06	
9/12/94	22.7	0.76	55	GS2-1	0.621	0.58	GS2-2	0.119	0.10	GS2-3	0.046	<0.05	23.8	0.15	7.84	0.05	
9/13/94	22.7	0.99	55	GS3-1	0.621	0.57	GS3-2	0.021	<0.05	GS3-3	0.060	<0.05	23.5	0.10	11.70	0.06	
9/14/94	22.7	1.16	55	GS4-1	0.633	0.52	GS4-2	0.017	<0.05	GS4-3	0.040	<0.05	23.7	0.09	16.40	0.06	
9/15/94	22.7	1.30	55	GS5-1	0.630	0.53	GS5-2	0.064	<0.05	GS5-3	0.054	<0.05	23.7	0.09	18.70	0.06	
9/16/94	22.7	1.57	55	GS6-1	0.647	0.57	GS6-2	0.125	0.10	GS6-3	0.062	<0.05	24.0	0.10	17.80	0.05	
9/17/94	22.7	1.72	55	GS7-1	0.597	0.55	GS7-2	0.177	0.15	GS7-3	0.052	<0.05	24.0	0.12	19.20	0.06	
9/19/94	15.1	0.81	12	GS8-1	0.621	0.56	GS8-2	0.011	<0.05	GS8-3	0.079	0.06	25.5	0.16	12.90	0.09	
9/20/94	15.1	0.95	12	GS9-1	0.614	0.59	GS9-2	0.017	<0.05	GS9-3	0.088	0.06	24.5	0.12	12.00	0.07	
9/21/94	15.1	0.95	12	GS10-1	0.618	0.59	GS10-2	0.017	<0.05	GS10-3	0.096	0.07	24.3	0.11	12.80	0.06	
9/22/94	15.1	0.95	12	GS11-1	0.626	0.58	GS11-2	0.012	<0.05	GS11-3	0.100	0.08	24.4	0.10	13.30	0.07	

APPENDIX B

Nanofiltration test data

Nanofiltration Test Data

Elapsed Time (hours)	Flowrates			Conductivity			Pressure		Temperature		Turbidity Feed - after cart. filter (ntu)	
	Feed (L/min)	Permeate Stage 1/1 (L/min)	Reject (L/min)	Permeate Stage 1/2 (L/min)	Permeate Stage 1/1 (uS/cm)	Reject (uS/cm)	Feed (lb/in ²)	Interstage (lb/in ²)	Reject (lb/in ²)	Feed (deg F)		Feed (deg C)
1.0	18.2	5.9	3.6	6.0	87	5380	79	57	49	78.6	25.9	0.112
4.8	18.2	5.8	3.6	5.9	84	5040	77	56	47	78.4	25.8	0.077
7.6	18.3	5.8	3.6	5.9	88	4940	75	55	46	80.3	26.8	0.064
11.2	18.1	5.8	3.6	5.8	81	5070	75	55	47	76.9	24.9	0.063
23.0	18.0	5.6	3.6	5.7	87	4870	76	55	46	74.7	23.7	0.064
26.9	18.1	5.6	3.6	5.6	87	4950	72	53	44	76.8	24.9	0.064
30.9	18.2	5.6	3.6	5.6	87	4890	72	52	43	79.0	26.1	0.066
35.3	18.1	5.6	3.6	5.6	87	5020	72	53	44	76.4	24.7	0.066
46.6	18.2	5.6	3.6	5.7	84	5160	76	56	47	75.3	24.1	0.067
50.6	18.2	5.6	3.6	5.6	82	5260	75	55	47	75.0	23.9	0.067
54.6	18.3	5.7	3.6	5.7	83	5220	74	55	46	77.9	25.5	0.069
59.4	18.2	5.6	3.6	5.7	83	5240	75	55	46	76.7	24.8	0.069
71.0	18.2	5.6	3.6	5.8	73	5190	79	58	49	74.7	23.7	0.073
71.9	18.2	5.6	3.6	5.7	74	5140	78	58	49	74.6	23.7	0.077
74.6	18.2	5.7	3.6	5.7	78	5350	77	58	49	76.3	24.6	0.082
78.6	18.2	5.6	3.6	5.7	82	4990	75	56	46	79.0	26.1	0.084
82.5	18.2	5.6	3.6	5.6	79	5150	76	56	47	76.8	24.9	0.081
94.7	18.2	5.7	3.6	5.5	79	5160	80	59	49	73.9	23.3	0.073
98.6	18.2	5.5	3.6	5.6	80	5100	78	57	48	75.3	24.1	0.074
102.6	18.2	5.8	3.6	5.9	83	5050	77	56	47	78.0	25.6	0.070
108.7	18.1	5.6	3.6	5.7	83	5010	76	56	46	77.6	25.3	0.064
118.8	18.2	5.6	3.6	5.4	75	5170	79	58	49	74.1	23.4	0.053
122.8	18.2	5.6	3.6	5.7	76	5090	78	57	48	77.1	25.1	0.050
126.8	18.2	5.7	3.6	5.7	80	4980	76	55	46	81.1	27.3	0.049
130.6	18.2	5.6	3.6	5.6	82	5000	75	55	46	79.6	26.4	0.046
142.5	18.2	5.6	3.6	5.6	84	5200	75	55	46	74.5	23.6	0.041
146.1	18.2	5.6	3.6	5.6	77	5270	80	58	49	77.0	25.0	0.040
150.9	18.2	5.7	3.6	5.7	76	5000	76	55	46	81.2	27.3	0.043
154.6	18.2	5.6	3.6	5.6	81	4940	76	55	45	80.8	27.1	0.044
166.9	18.2	5.5	3.6	5.6	72	5230	81	59	49	74.3	23.5	0.045
171.0	18.2	5.6	3.6	5.6	81	5160	79	57	48	77.3	25.2	0.051
175.1	18.2	5.6	3.6	5.7	82	5030	76	55	46	81.1	27.3	0.052
178.7	18.2	5.6	3.6	5.7	79	5110	78	57	47	79.9	26.6	0.051
190.6	18.2	5.6	3.6	5.6	71	5190	80	58	49	76.7	24.8	0.057
194.6	18.2	5.8	3.6	5.7	75	5270	81	60	50	74.4	23.6	0.053
202.6	18.2	5.6	3.6	5.7	78	5110	78	56	47	81.1	27.3	0.059
214.6	18.2	5.6	3.6	5.7	74	5240	81	59	49	80.1	26.7	0.056
218.6	18.2	5.6	3.6	5.7	75	5210	80	58	48	77.1	25.1	0.063
222.6	18.2	5.6	3.6	5.7	76	5060	78	56	47	81.5	27.5	0.067
226.6	18.2	5.6	3.6	5.6	79	5090	78	56	47	80.3	26.8	0.065
238.6	18.2	5.6	3.6	5.6	73	5220	81	59	50	74.6	23.7	0.074
242.6	18.2	5.7	3.6	5.7	72	5190	80	58	49	77.1	25.1	0.045
246.6	18.2	5.7	3.6	5.7	75	5050	78	56	47	80.9	27.2	0.047
250.6	18.2	5.7	3.6	5.6	81	5220	78	56	46	77.4	25.2	0.046
262.6	18.2	5.6	3.6	5.7	72	5080	81	58	48	76.8	24.9	0.045
266.6	18.2	5.6	3.6	5.7	73	5130	80	58	48	76.7	24.8	0.048
270.6	18.2	5.6	3.6	5.7	79	5250	79	57	48	77.1	25.1	0.045
274.6	18.2	5.6	3.6	5.6	80	5230	79	57	47	77.4	25.2	0.043
287.0	18.2	5.7	3.6	5.7	69	5140	82	59	49	76.0	24.4	0.045
290.7	18.2	5.6	3.6	5.7	70	5060	81	58	49	77.4	25.2	0.047
294.7	18.2	5.6	3.6	5.7	79	5210	80	57	47	77.0	25.0	0.052

Nanofiltration Test Data - Continued

Elapsed Time (hours)	Flowrates			Conductivity			Pressure			Temperature		Turbidity Feed - after cart. filter (ntu)
	Feed (L/min)	Permeate Stage 1/1 (L/min)	Permeate Stage 2 (L/min)	Feed (uS/cm)	Permeate Stage 1/1 (uS/cm)	Permeate Stage 2 (uS/cm)	Feed (lb/in ²)	Interstage (lb/in ²)	Reject (lb/in ²)	Feed (deg F)	Feed (deg C)	
296.7	18.2	3.6	5.8	1200	5280	79	80	57	48	76.5	24.7	0.053
310.6	18.2	3.6	5.6	1190	5110	67	82	59	49	75.8	24.3	0.054
318.6	18.2	3.6	5.6	1190	5130	67	83	60	50	74.3	23.5	0.060
322.6	18.2	3.6	5.6	1190	5160	71	83	60	50	75.8	24.3	0.065
334.6	18.2	3.6	5.6	1190	5210	70	83	60	50	75.4	24.1	0.064
338.6	18.2	3.6	5.6	1190	5200	68	85	61	51	72.7	22.7	0.076
342.6	18.2	3.6	5.6	1190	5200	69	84	61	51	74.8	23.8	0.074
346.6	18.2	3.6	5.6	1190	5130	67	83	60	50	77.5	25.3	0.077
358.6	18.2	3.6	5.6	1200	5300	71	85	62	52	76.8	24.9	0.045
362.6	18.2	3.6	5.6	1190	5210	70	84	60	50	72.9	22.7	0.045
366.6	18.2	3.6	5.6	1200	5270	70	84	60	50	75.9	24.4	0.044
370.6	18.2	3.6	5.6	1200	5270	69	82	59	49	77.0	25.0	0.043
382.7	18.2	3.6	5.6	1190	5310	67	85	62	52	76.3	22.8	0.042
386.7	18.2	3.6	5.6	1190	5200	68	84	61	51	76.2	24.6	0.043
390.6	18.2	3.6	5.6	1200	5270	68	82	59	49	77.1	25.1	0.043
394.5	18.2	3.6	5.6	1200	5340	72	83	59	49	76.2	24.6	0.044
406.6	18.2	3.6	5.6	1190	5260	66	86	62	51	73.1	22.8	0.065
410.6	18.2	3.6	5.6	1190	5300	70	84	60	50	75.0	23.9	0.049
414.5	18.2	3.6	5.8	1200	5290	75	82	59	49	77.1	25.1	0.049
418.7	18.2	3.6	5.6	1200	5270	75	83	59	49	76.8	24.9	0.052
430.2	18.2	3.6	5.6	1190	5290	66	86	62	52	73.1	22.8	0.060
434.5	18.2	3.6	5.6	1190	5260	68	85	61	51	75.4	24.1	0.081
438.6	18.2	3.6	5.7	1200	5200	74	82	58	49	78.2	25.7	0.060
442.9	18.2	3.6	5.6	1200	5290	75	83	60	49	76.9	24.9	0.056
454.6	18.2	3.6	5.6	1190	5360	71	86	60	49	72.6	22.6	0.076
458.6	18.2	3.6	5.6	1190	4830	64	84	59	47	75.1	23.9	0.047
462.8	18.2	3.6	5.7	1200	5220	71	83	59	49	79.0	26.1	0.056
466.6	18.2	3.6	5.6	1200	5260	73	82	58	49	78.6	25.9	0.056
479.2	18.2	3.6	5.6	1190	5130	63	85	61	51	75.1	23.9	0.052
482.6	18.2	3.6	5.6	1190	5030	66	85	60	49	76.7	24.8	0.052
486.7	18.2	3.6	5.6	1200	5230	70	82	58	48	77.5	25.3	0.052
490.6	18.2	3.6	5.6	1200	5270	73	83	59	49	76.4	24.7	0.049
502.7	18.2	3.6	5.5	1190	5240	69	85	61	51	74.5	23.6	0.056
507.7	18.2	3.6	5.6	1190	5280	72	83	60	50	75.4	24.1	0.060
510.7	18.2	3.6	5.6	1190	5230	73	83	59	49	77.1	25.1	0.070
514.7	18.2	3.6	5.6	1190	5260	73	83	60	49	75.0	23.9	0.073
526.6	18.2	3.6	5.6	1190	5170	66	85	61	50	74.9	23.8	0.067
530.6	18.2	3.6	5.6	1190	5070	67	84	60	49	77.5	25.3	0.064
534.6	18.2	3.6	5.6	1190	5030	69	84	59	48	77.2	25.3	0.059
538.6	18.2	3.6	5.7	1190	5350	70	84	60	50	81.0	27.2	0.054
526.6	18.2	3.6	5.6	1190	5170	66	85	61	50	78.8	26.0	0.054
530.6	18.2	3.6	5.6	1190	5070	67	84	60	49	74.9	23.8	0.067
534.6	18.2	3.6	5.6	1190	5030	69	83	59	48	77.5	25.3	0.064
538.6	18.2	3.6	5.7	1190	5350	70	84	60	50	81.0	27.2	0.059
550.6	18.2	3.6	5.6	1190	5540	67	86	62	53	74.0	23.3	0.050
554.3	18.2	3.6	5.6	1190	5230	70	83	59	50	77.7	25.4	0.053
558.6	18.2	3.6	5.6	1190	5330	72	81	58	49	80.8	27.1	0.051
562.6	18.2	3.6	5.6	1190	5510	78	81	58	49	78.1	25.6	0.054
574.6	18.2	3.6	5.6	1190	4980	67	84	60	49	76.3	24.6	0.057
578.6	18.2	3.6	5.6	1190	4860	65	84	59	49	79.1	26.2	0.064
582.6	18.2	3.6	5.6	1190	5040	71	81	57	47	79.4	26.3	0.074

Nanofiltration Test Data - Continued

Elapsed Time (hours)	Flowrates			Conductivity			Pressure			Temperature		Turbidity Feed - after cart. filter (ntu)
	Feed (L/min)	Reject (L/min)	Permeate Stage 1/1 (L/min)	Permeate Stage 1/1 (uS/cm)	Permeate Stage 1/2 (uS/cm)	Permeate Stage 2 (uS/cm)	Feed (lb/in ²)	Interstage (lb/in ²)	Reject (lb/in ²)	Feed (deg F)	Feed (deg C)	
586.8	18.2	3.6	5.6	77	77	256	82	57	46	77.6	25.3	0.063
598.6	18.2	3.6	5.6	54	70	241	86	61	50	74.8	23.8	0.055
602.6	18.2	3.6	5.6	67	72	252	85	60	49	78.8	26.0	0.055
606.6	18.2	3.6	5.6	73	77	269	83	59	48	80.2	26.8	0.054
610.6	18.2	3.6	5.6	77	77	258	83	59	48	78.6	25.9	0.055
623.0	18.2	3.6	5.6	66	71	238	86	61	50	76.2	24.6	0.053
626.6	18.2	3.6	5.6	71	74	248	85	60	49	76.7	24.8	0.056
630.6	18.2	3.6	5.5	77	80	272	82	57	47	80.2	26.8	0.062
646.6	18.2	3.6	5.6	77	79	267	83	58	47	78.4	25.8	0.066
650.8	18.2	3.6	5.6	71	73	246	88	61	50	75.7	24.3	0.067
654.8	18.2	3.6	5.6	62	75	254	86	61	50	77.2	25.1	0.057
658.8	18.2	3.6	5.6	71	76	274	84	59	49	82.0	27.8	0.056
670.8	18.2	3.6	5.6	74	78	271	85	60	50	79.3	26.3	0.055
674.8	18.2	3.6	5.6	66	71	240	86	61	50	76.1	24.5	0.052
678.6	18.2	3.6	5.6	69	74	254	84	59	49	79.1	26.2	0.052
682.1	18.2	3.6	5.6	70	74	213	82	58	47	82.3	27.9	0.052
686.3	18.2	3.6	5.6	74	77	265	83	59	48	80.6	27.0	0.057
690.1	18.2	3.6	5.6	70	73	244	86	62	51	74.9	23.8	0.058
694.2	18.2	3.6	5.6	71	74	251	85	61	50	77.3	25.2	0.057
698.1	18.2	3.6	5.6	81	81	269	81	58	46	78.6	25.9	0.052
710.1	18.2	3.6	5.6	79	80	267	80	57	46	77.2	25.1	0.053
714.1	18.2	3.6	5.6	71	73	240	86	62	51	74.6	23.7	0.073
718.1	18.2	3.6	5.6	74	76	255	85	61	50	77.5	25.3	0.078
722.0	18.2	3.6	5.6	79	81	271	82	58	47	79.0	26.1	0.096
734.2	18.2	3.6	5.6	81	80	265	83	59	48	77.4	25.2	0.081
738.2	18.2	3.6	5.6	71	73	243	86	61	50	74.8	23.8	0.079
742.2	18.2	3.6	5.5	77	78	254	85	60	49	76.3	24.6	0.072
746.2	18.2	3.6	5.5	74	77	254	84	60	49	77.1	25.1	0.090
757.9	18.2	3.6	5.5	76	76	252	85	60	50	76.0	24.4	0.083
762.5	18.2	3.6	5.6	71	73	240	87	62	51	72.9	22.7	0.081
766.4	18.2	3.6	5.4	69	74	245	87	62	51	76.7	24.8	0.088
770.2	18.2	3.6	5.6	74	76	248	86	62	50	74.8	23.8	0.090
782.1	18.2	3.6	5.6	75	76	242	87	62	51	73.2	22.9	0.101
786.1	18.2	3.6	5.6	72	73	231	90	64	52	72.4	22.4	0.122
790.1	18.2	3.6	5.6	57	74	240	89	63	52	74.8	23.8	0.077
794.1	18.2	3.6	5.6	73	73	250	87	61	50	78.4	25.8	0.076
806.1	18.2	3.6	5.6	59	75	238	86	62	51	77.1	25.1	0.077
810.1	18.2	3.6	5.6	72	75	245	90	64	52	72.7	22.6	0.072
814.1	18.2	3.6	5.6	75	75	255	87	61	50	75.7	24.3	0.070
818.1	18.2	3.6	5.6	69	73	251	86	61	50	80.4	26.9	0.069
830.1	18.2	3.6	5.6	72	73	231	89	64	52	79.4	26.3	0.070
834.1	18.2	3.6	5.6	62	64	231	90	64	52	73.6	23.1	0.072
838.1	18.2	3.6	5.6	72	74	205	89	63	51	76.6	24.8	0.077
842.1	18.2	3.6	5.6	71	74	218	89	63	51	81.1	27.3	0.080
854.1	18.2	3.6	5.6	67	72	206	87	61	50	80.0	26.7	0.087
858.1	18.2	3.6	5.6	72	74	227	90	63	52	73.8	23.2	0.092
861.8	18.2	3.6	5.6	72	74	241	85	59	48	77.2	25.1	0.077
				69	73	235	85	59	48	80.6	27.0	0.093

Nanofiltration Test Data - Continued

Elapsed Time (hours)	Flowrates		Permeate		Reject		Conductivity		Pressure		Temperature		Turbidity Feed - after cart. filter (ntu)			
	Feed (L/min)	Reject (L/min)	Permeate Stage 1/1 (L/min)	Permeate Stage 1/2 (L/min)	Permeate Stage 2 (L/min)	Feed (uS/cm)	Reject (uS/cm)	Permeate Stage 1/1 (uS/cm)	Permeate Stage 1/2 (uS/cm)	Permeate Stage 2 (uS/cm)	Feed (lb/in ²)	Interstage (lb/in ²)		Reject (lb/in ²)	Feed (deg F)	Feed (deg C)
865.6	18.2	3.6	5.6	5.6	3.4	1190	4730	67	71	227	86	60	48	79.2	26.2	0.079
877.6	18.2	3.6	5.6	5.6	3.4	1190	5040	68	71	225	89	63	51	75.1	23.9	0.156
881.6	18.2	3.6	5.6	5.6	3.4	1190	5100	69	72	239	88	63	51	77.1	25.1	0.103
885.2	18.2	3.6	5.6	5.6	3.4	1190	5040	66	68	238	88	63	52	80.4	26.9	0.135
889.2	18.2	3.6	5.6	5.6	3.4	1190	5060	64	67	232	88	63	52	79.0	26.1	0.090
893.9	18.2	3.6	5.6	5.6	3.4	1190	5500	60	70	229	93	68	56	72.2	22.3	0.084
897.9	18.2	3.6	5.6	5.6	3.4	1190	5090	66	68	227	90	64	53	76.5	24.7	0.078
901.9	18.2	3.6	5.6	5.6	3.4	1190	5110	70	72	239	88	61	51	78.8	26.0	0.065
905.9	18.2	3.6	5.6	5.6	3.4	1190	5150	76	76	242	87	61	50	76.6	24.8	0.064
912.3	18.2	3.6	5.6	5.6	3.4	1180	5300	73	68	189	92	66	54	70.6	21.4	0.071
916.3	18.2	3.6	5.6	5.6	3.4	1190	5120	70	72	236	88	63	52	77.1	25.1	0.063
920.3	18.2	3.6	5.6	5.6	3.4	1180	4990	67	70	233	87	62	51	78.9	26.1	0.057
924.3	18.2	3.6	5.6	5.6	3.4	1180	4960	66	69	230	87	62	51	78.4	25.8	0.058
936.3	18.2	3.6	5.6	5.6	3.4	1180	5090	67	70	227	87	62	51	76.2	24.6	0.073
940.2	18.2	3.6	5.7	5.7	3.5	1190	5230	69	72	240	87	63	52	76.7	24.8	0.065
944.2	18.2	3.6	5.7	5.7	3.5	1190	5190	69	72	246	86	62	52	78.8	26.0	0.092
948.2	18.2	3.6	5.6	5.6	3.4	1180	5240	73	74	239	87	62	51	75.2	24.0	0.104
960.1	18.2	3.6	5.6	5.6	3.5	1190	5400	73	73	234	90	65	54	72.9	22.7	0.127
964.5	18.2	3.6	5.6	5.6	3.5	1180	5230	72	73	240	89	64	53	76.5	24.7	0.069
968.5	18.2	3.6	5.6	5.6	3.5	1190	5110	68	71	241	87	62	52	79.5	26.4	0.068
972.5	18.2	3.6	5.6	5.6	3.5	1180	5250	71	73	240	88	63	52	76.9	24.9	0.068
984.2	18.2	3.6	5.6	5.6	3.4	1180	5390	74	75	237	90	65	54	73.2	22.9	0.063

Nanofiltration Calculated Values

Elapsed Time (hours)	Delta P		Temperature Correction Factor (TCF)	Inverse Temp. Correction Factor (1/TCF)	Average Feed Pressure (lb/in ²)	Feed Cf (mg/L)	Concentration Reject Cr (mg/L)	Average (Cf+Cr)/2 (mg/L)	Average Osmosis Pressure (lb/in ²)	Average Net Driving Pressure (lb/in ²)	Normalized Permeate Flow (L/min)
	Stage 1 (lb/in ²)	Stage 2 (lb/in ²)									
1.0	22	8	1.027	0.974	64.0	787	3649	2216	22.2	41.8	14.6
4.8	21	9	1.023	0.977	62.0	787	3418	2103	21.0	41.0	14.9
7.6	20	9	1.056	0.947	60.5	787	3351	2069	20.7	39.8	14.8
11.2	20	8	1.059	1.001	61.0	787	3439	2113	21.1	39.9	15.7
23.0	21	9	0.967	1.034	61.0	787	3303	2045	20.5	40.5	15.7
26.9	19	9	0.997	1.003	58.0	787	3357	2072	20.7	37.3	16.3
30.9	19	9	1.033	0.968	57.0	787	3317	2052	20.5	36.5	18.1
35.3	19	9	0.991	1.009	58.0	787	3405	2096	21.0	37.0	18.5
46.6	20	9	0.975	1.025	61.5	787	3500	2143	21.4	40.1	15.6
50.6	19	9	0.971	1.030	61.0	787	3588	2177	21.8	39.2	15.9
54.6	19	9	1.015	0.985	60.0	787	3541	2164	21.6	38.4	15.8
59.4	19	9	0.998	1.004	61.0	787	3554	2171	21.7	39.3	15.8
71.0	21	9	0.967	1.034	64.0	801	3520	2154	21.5	42.5	14.9
71.9	20	9	0.965	1.036	63.5	801	3486	2143	21.4	42.1	14.9
74.6	19	9	0.990	1.010	63.0	801	3629	2215	22.1	40.9	15.2
78.6	19	10	1.033	0.968	60.5	801	3385	2093	20.9	39.6	14.9
82.5	20	9	0.997	1.003	61.5	801	3493	2147	21.5	40.0	15.2
94.7	21	10	0.955	1.047	64.5	801	3500	2150	21.5	43.0	14.9
98.6	21	9	0.975	1.025	63.0	801	3459	2130	21.3	41.7	14.8
102.6	21	9	1.017	0.984	62.0	801	3425	2113	21.1	40.9	15.2
106.7	20	10	1.010	0.990	61.0	801	3398	2099	21.0	40.0	15.1
118.8	21	9	0.958	1.044	64.0	801	3507	2154	21.5	42.5	14.7
122.8	21	9	1.002	0.998	63.0	801	3452	2126	21.3	41.7	14.6
128.8	21	9	1.070	0.935	61.0	807	3378	2093	20.9	40.1	14.2
130.6	20	9	1.044	0.958	60.5	807	3391	2099	21.0	39.5	14.6
142.5	22	9	0.964	1.037	64.5	801	3527	2164	21.6	42.9	14.6
146.1	22	9	1.000	1.000	64.5	801	3574	2187	21.9	42.6	14.3
150.9	21	9	1.071	0.933	61.0	807	3391	2099	21.0	40.0	14.2
154.6	21	10	1.064	0.940	60.5	807	3351	2079	20.8	39.7	14.3
166.9	22	10	0.961	1.041	65.0	801	3547	2174	21.7	43.3	14.5
171.0	22	9	1.005	0.995	63.5	801	3500	2150	21.5	42.0	14.4
175.1	21	9	1.070	0.935	61.0	807	3412	2109	21.1	39.9	14.2
178.7	21	10	1.049	0.963	62.5	807	3466	2137	21.4	41.1	14.2
180.6	21	10	0.962	1.039	65.5	801	3520	2160	21.6	43.9	14.4
194.6	22	10	0.996	1.004	65.0	801	3574	2187	21.9	43.1	14.2
198.6	22	9	1.070	0.935	62.5	807	3466	2137	21.4	41.1	13.9
202.6	21	10	1.052	0.960	62.5	801	3459	2130	21.3	41.2	14.1
214.6	22	9	0.964	1.037	65.5	801	3554	2177	21.8	43.7	14.5
218.6	22	9	1.002	0.998	64.5	801	3534	2167	21.7	42.8	14.2
222.6	22	9	1.076	0.929	62.5	807	3432	2120	21.2	41.3	13.7
226.6	22	9	1.056	0.947	62.5	801	3452	2126	21.3	41.2	14.0
238.6	22	9	0.965	1.036	65.5	801	3541	2171	21.7	43.8	14.3
242.6	22	9	1.002	0.998	64.5	807	3520	2164	21.6	42.9	14.3
246.6	22	9	1.066	0.938	62.5	807	3425	2116	21.2	41.3	14.0
250.6	22	10	1.007	0.993	62.0	807	3541	2174	21.7	40.3	15.1
262.6	23	10	0.997	1.003	64.5	801	3446	2123	21.2	43.3	14.2
266.6	22	10	0.996	1.004	64.0	807	3479	2143	21.4	42.6	14.4
270.6	22	9	1.002	0.998	63.5	807	3561	2184	21.8	41.7	14.6
274.6	22	10	1.007	0.993	63.0	807	3547	2177	21.8	41.2	14.6
287.0	23	10	0.986	1.015	65.5	801	3486	2143	21.4	44.1	14.2
290.7	23	9	1.007	0.993	65.0	801	3432	2116	21.2	43.8	13.8
294.7	23	10	1.000	1.000	63.5	807	3534	2171	21.7	41.8	14.6

Nanofiltration Calculated Values - Continued

Elapsed Time (hours)	Stage 1 (lb/in ²)	Delta P (lb/in ²)	Stage 2 (lb/in ²)	Temperature Correction Factor (TCF)	Inverse Temp. Correction Factor (1/TCF)	Average Feed Pressure (lb/in ²)	Feed Cf (mg/L)	Concentration Reject Cr (mg/L)	Average (Cl+Cr)/2 (mg/L)	Average Osmosis Pressure (lb/in ²)	Average Net Driving Pressure (lb/in ²)	Normalized Permeate Flow (L/min)
298.7	23	9	10	0.993	1.007	64.0	807	3581	2194	21.9	42.1	14.6
310.6	23	10	10	0.983	1.018	65.5	801	3466	2133	21.3	44.2	14.1
314.6	23	10	10	0.961	1.041	66.5	801	3479	2140	21.4	45.1	14.1
318.6	23	10	10	0.983	1.018	68.5	801	3500	2150	21.5	45.0	13.8
322.6	23	10	10	0.977	1.024	68.5	801	3534	2167	21.7	44.8	13.9
334.6	24	10	10	0.939	1.065	68.0	801	3602	2201	22.0	46.0	14.1
338.6	23	10	10	0.968	1.033	67.5	801	3527	2164	21.6	45.9	13.7
342.6	23	10	10	1.008	0.992	66.5	801	3479	2140	21.4	45.1	13.4
348.6	23	10	10	0.997	1.003	65.5	807	3459	2133	21.3	44.2	13.9
358.5	23	10	10	0.941	1.063	68.5	801	3615	2208	22.1	48.4	14.1
362.6	24	10	10	0.984	1.016	67.0	801	3534	2167	21.7	45.3	13.8
368.6	23	10	10	1.000	1.000	65.5	807	3574	2191	21.9	43.6	14.0
370.6	23	10	10	0.990	1.010	65.5	807	3574	2191	21.9	43.6	14.1
382.7	23	10	10	0.942	1.061	68.5	801	3602	2201	22.0	46.5	14.0
386.7	23	10	10	0.988	1.012	67.5	801	3527	2184	21.6	45.9	13.6
390.6	23	10	10	1.002	0.998	65.5	807	3574	2191	21.9	43.6	14.0
394.5	24	10	10	0.988	1.012	66.0	807	3622	2215	22.1	43.9	14.2
408.6	24	11	10	0.944	1.060	68.5	801	3568	2184	21.8	46.7	13.9
410.6	24	10	10	0.971	1.030	67.0	801	3595	2198	22.0	45.0	14.0
414.5	23	10	10	1.002	0.998	65.5	807	3588	2198	22.0	43.5	14.4
418.7	24	10	10	0.997	1.003	66.0	807	3574	2191	21.9	44.1	13.9
430.2	24	10	10	0.944	1.060	69.0	801	3588	2194	21.9	47.1	13.8
434.5	24	10	10	0.977	1.024	68.0	801	3568	2184	21.8	46.2	13.6
436.6	24	9	10	1.020	0.980	65.5	807	3527	2167	21.7	43.8	13.8
442.9	23	11	10	0.989	1.001	66.0	807	3588	2198	22.0	44.0	14.0
454.6	23	11	10	0.936	1.068	69.0	801	3635	2218	22.2	46.8	13.9
458.6	25	12	10	0.973	1.028	65.5	801	3276	2038	20.4	45.1	13.8
462.6	24	10	10	1.033	0.968	66.0	807	3541	2174	21.7	44.3	13.4
466.6	24	9	10	1.027	0.974	65.5	807	3568	2187	21.9	43.6	13.6
479.2	24	10	10	0.973	1.028	68.0	801	3479	2140	21.4	46.6	13.5
482.6	23	11	10	0.996	1.004	66.0	801	3412	2106	21.1	44.9	13.6
486.7	24	10	10	1.008	0.992	65.0	807	3547	2177	21.8	43.2	14.0
490.6	24	10	10	0.991	1.009	66.0	807	3574	2191	21.9	44.1	14.0
507.7	24	10	10	0.964	1.037	66.0	801	3554	2177	21.8	46.2	13.6
510.7	24	10	10	0.977	1.024	66.5	801	3581	2191	21.9	44.6	14.0
514.7	23	11	10	1.002	0.998	66.0	801	3547	2174	21.7	44.3	13.8
526.6	24	11	10	0.970	1.031	66.0	801	3568	2184	21.8	44.2	14.2
530.6	24	11	10	1.008	0.992	67.5	801	3507	2154	21.5	46.0	13.7
534.6	24	11	10	1.068	0.937	66.5	801	3439	2120	21.2	45.3	13.3
538.6	24	11	10	1.068	0.937	65.5	801	3412	2106	21.1	44.4	13.0
526.6	24	11	10	1.030	0.971	67.5	801	3629	2215	22.1	44.9	13.2
530.6	24	11	10	1.008	0.992	66.5	801	3507	2154	21.5	46.0	13.7
534.6	24	11	10	1.088	0.937	65.5	801	3439	2120	21.2	45.3	13.3
538.6	24	10	10	1.030	0.971	67.0	801	3629	2215	22.1	44.4	13.0
550.6	24	9	10	1.045	0.971	67.0	801	3629	2215	22.1	44.9	13.2
554.3	24	9	10	1.012	0.989	69.5	801	3758	2279	22.8	46.7	13.7
558.6	23	9	10	1.064	0.940	66.5	801	3547	2174	21.7	44.8	13.4
562.6	23	8	10	1.018	0.982	65.5	801	3615	2208	22.1	42.9	13.4
574.6	24	11	10	0.990	1.010	66.5	801	3737	2269	22.7	42.8	14.0
576.6	25	10	10	1.036	0.966	66.5	801	3296	2048	20.5	45.6	13.5
582.6	24	10	10	1.040	0.961	64.0	801	3418	2109	21.1	42.9	13.7

Nanofiltration Calculated Values - Continued

Elapsed Time (hours)	Delta P		Temperature Correction Factor (TCF)	Inverse Temp. Correction Factor (1/TCF)	Average Feed Pressure (lb/in ²)	Concentration		Average Osmosis Pressure (lb/in ²)	Average Normalized Flow (L/minh)		
	Stage 1 (lb/in ²)	Stage 2 (lb/in ²)				Feed Cf (mg/L)	Reject Cr (mg/L)				
586.6	25	11	1.010	0.990	64.0	801	3418	2109	21.1	42.9	14.1
598.6	25	11	0.968	1.033	68.0	801	3581	2181	21.8	46.2	13.7
602.6	25	11	1.030	0.971	67.0	801	3412	2106	21.1	45.9	12.9
608.6	24	11	1.054	0.949	65.5	801	3527	2164	21.6	43.9	13.2
610.6	24	11	1.027	0.974	65.5	801	3581	2191	21.9	43.6	13.6
623.0	25	11	0.988	1.012	68.0	801	3439	2120	21.2	46.8	13.2
626.6	25	11	0.998	1.004	67.0	801	3466	2133	21.3	45.7	13.4
630.6	25	10	1.054	0.949	64.5	801	3439	2120	21.2	43.3	13.3
634.6	25	11	1.023	0.977	65.0	801	3446	2123	21.2	43.8	13.5
646.6	25	11	0.981	1.019	68.0	801	3500	2150	21.5	46.5	13.4
650.6	25	11	1.003	0.997	68.0	801	3541	2171	21.7	46.3	13.1
654.6	25	10	1.085	0.921	66.5	801	3459	2130	21.3	45.2	12.4
658.6	25	10	1.039	0.963	67.5	801	3724	2262	22.6	44.9	13.1
670.6	25	11	0.987	1.013	68.0	801	3446	2123	21.2	46.8	13.2
674.6	25	10	1.035	0.966	66.5	801	3364	2082	20.8	45.7	12.9
678.6	24	11	1.091	0.917	64.5	801	3298	2048	20.5	44.0	12.7
682.1	24	11	1.061	0.943	65.5	801	3391	2096	21.0	44.5	12.9
688.3	24	11	1.031	0.970	68.5	801	3479	2140	21.4	47.1	13.5
690.1	24	11	1.005	0.995	67.5	801	3378	2089	20.9	46.6	13.2
694.2	23	11	1.027	0.974	64.5	801	3425	2113	21.1	41.9	14.2
698.1	23	10	1.003	0.997	64.5	801	3400	2104	21.0	43.5	13.8
710.1	24	11	0.965	1.036	68.5	801	3493	2147	21.5	47.0	13.4
714.1	24	11	1.008	0.992	67.5	801	3479	2140	21.4	46.1	13.2
718.1	24	11	1.033	0.968	64.5	801	3507	2154	21.5	43.0	13.8
722.0	24	11	1.007	0.993	65.5	801	3534	2171	21.7	43.8	13.8
734.2	25	11	0.968	1.033	68.0	801	3581	2181	21.8	46.2	13.7
738.2	25	11	0.990	1.010	67.0	801	3554	2177	21.8	45.2	13.5
742.2	24	11	1.002	0.998	66.5	801	3541	2174	21.7	44.8	13.5
746.2	25	10	0.988	1.015	67.5	801	3584	2177	21.8	45.7	13.5
757.9	25	11	0.941	1.063	69.0	801	3622	2211	22.1	46.9	13.7
762.5	25	11	0.996	1.004	69.0	801	3473	2137	21.4	47.6	12.4
766.4	24	12	0.968	1.033	68.0	801	3513	2157	21.6	46.4	13.6
770.2	25	11	0.945	1.058	69.0	801	3581	2191	21.9	47.1	13.6
782.1	26	12	0.934	1.071	71.0	801	3568	2184	21.8	49.2	13.3
786.1	26	11	0.968	1.033	70.5	801	3493	2147	21.5	49.0	12.9
790.1	26	11	1.023	0.977	68.5	801	3425	2113	21.1	47.4	12.6
794.1	24	11	1.002	0.998	68.5	801	3452	2126	21.3	47.2	12.9
806.1	26	12	0.938	1.066	71.0	801	3568	2184	21.8	49.2	13.2
810.1	27	12	0.981	1.019	70.5	801	3513	2157	21.6	48.9	12.7
814.1	26	11	1.057	0.946	68.5	801	3418	2109	21.1	47.4	12.2
818.1	25	12	1.040	0.961	67.5	801	3357	2079	20.8	46.7	12.6
830.1	26	12	0.951	1.052	71.0	801	3547	2174	21.7	49.3	13.0
834.1	26	12	0.994	1.006	70.0	801	3486	2143	21.4	48.6	12.6
838.1	27	11	1.070	0.935	68.0	801	3486	2143	21.4	47.0	12.2
842.1	26	11	1.051	0.952	68.5	801	3398	2103	21.0	47.0	12.2
830.1	26	11	0.981	1.021	71.0	801	3357	2079	20.8	47.7	12.2
834.1	26	12	0.994	1.006	70.0	801	3486	2143	21.4	48.6	12.6
842.1	26	11	1.070	0.935	68.0	801	3398	2103	21.0	47.0	12.2
842.1	26	11	1.051	0.952	68.5	801	3357	2079	20.8	47.7	12.2
854.1	27	12	1.054	0.948	71.0	801	3527	2164	21.6	49.4	13.0
858.1	27	12	1.003	0.997	70.5	801	3466	2133	21.3	49.2	12.4
861.6	26	11	1.061	0.943	66.5	801	3195	1998	20.0	46.5	12.4


Nanofiltration Calculated Values - Continued

Elapsed Time (hours)	Delta P		Temperature Correction Factor (TCF)	Inverse Temp. Correction Factor (1/TCF)	Average Feed Pressure (lb/in ²)	Feed Cf (mg/L)	Concentration		Average (Cl+Cr)/2 (mg/L)	Average Osmosis Pressure (lb/in ²)	Average Net Driving Pressure (lb/in ²)	Normalized Permeate Flow (L/min)
	Stage 1 (lb/in ²)	Stage 2 (lb/in ²)					Reject Cr (mg/L)	Feed Cf (mg/L)				
865.6	26	12	1.037	0.964	67.0	801	3208	2004	20.0	47.0	12.5	
877.6	26	12	0.973	1.028	70.0	801	3418	2109	21.1	48.9	12.8	
881.6	25	12	1.002	0.998	69.5	801	3459	2130	21.3	48.2	12.6	
885.2	25	11	1.057	0.946	70.0	801	3418	2109	21.1	48.9	11.8	
889.2	25	11	1.033	0.968	70.0	801	3432	2116	21.2	48.8	12.1	
893.9	25	12	0.931	1.074	74.5	801	3730	2265	22.7	51.8	12.7	
897.9	26	11	0.983	1.007	71.5	801	3452	2126	21.3	50.2	12.2	
901.9	25	10	1.030	0.971	68.5	801	3486	2133	21.3	47.2	12.6	
905.9	26	11	0.994	1.006	68.5	801	3493	2147	21.5	47.0	13.1	
912.3	26	12	0.908	1.102	73.0	794	3595	2194	21.9	51.1	13.2	
916.3	25	11	1.002	0.998	70.0	801	3473	2137	21.4	48.6	12.5	
920.3	25	11	1.032	0.969	69.0	794	3365	2089	20.9	48.1	12.3	
924.3	25	11	1.023	0.977	69.0	794	3364	2079	20.8	48.2	12.4	
936.3	25	11	0.988	1.012	69.0	794	3452	2123	21.2	47.8	12.9	
940.2	24	11	0.996	1.004	69.5	801	3547	2174	21.7	47.8	13.1	
944.2	24	10	1.030	0.971	69.0	801	3520	2160	21.6	47.4	12.8	
948.2	25	11	0.974	1.027	69.0	794	3554	2174	21.7	47.3	13.3	
960.1	25	11	1.063	0.941	72.0	801	3663	2232	22.3	49.7	13.2	
964.5	25	11	0.993	1.007	71.0	794	3547	2171	21.7	49.3	12.6	
968.5	25	10	1.042	0.960	69.5	801	3486	2133	21.3	48.2	12.2	
972.5	25	11	0.999	1.001	70.0	794	3561	2177	21.8	48.2	12.8	
984.2	25	11	0.945	1.058	72.0	794	3656	2225	22.2	49.8	13.0	


APPENDIX C

Generalized NF process diagram for checking data reduction

Generalized NF Process Diagram for Checking Data Reduction




- Ff - Flow, feed
- Fr - Flow, reject
- Fp - Flow, permeate
- Cf - Conductivity, feed
- Cr - Conductivity, reject
- Cp - Conductivity, permeate
- Pf - Pressure, feed
- Pr - Pressure, reject
- Pi - Pressure, interstage
- Tf - Temperature, feed



APPENDIX D

Analytical data for nanofiltration testing



Analytical Data for Nanofiltration Testing

5-Hour Data

362-Hour Data

CATIONS		5-Hour Data			362-Hour Data				
		Feed	Interstage	Permeate	Reject	Feed	Interstage	Permeate	Reject
Calcium	mg/L	88	220	1.9	420	84	220	1.5	390
Magnesium	mg/L	30	72	0.69	130	29	65	0.34	120
Sodium	mg/L	110	260	22	510	110	250	17	480
Potassium	mg/L	3.9	8	1	16	3.5	7.2	1.1	13
Aluminum	mg/L	<0.05	<0.05	<0.05	0.08	<0.20	<0.20	<0.20	<0.20
Barium	mg/L	<0.05	0.09	<0.05	0.17	<0.05	0.07	<0.05	0.15
Strontium	mg/L	1.2	2.8	<1.0	5.1	1.3	3	<1.0	6.3
Iron	mg/L	<0.02	0.02	<0.02	0.03	<0.05	<0.05	<0.05	0.07
Manganese	mg/L	0.50	1.3	<0.05	2.5	0.50	1.2	<0.05	2.4
Phosphorus	mg/L	0.11	1.3	<0.10	0.58	<0.10	0.26	<0.10	<0.10

ANIONS

Bicarbonate	HCO3	mg/L	170	400	28	770	170	410	14	790
Chloride	Cl	mg/L	94	250	28	280	130	250	22	390
Sulfate	SO4	mg/L	290	720	10	1112	290	730	7.2	1500
Nitrate (N)	NO3 (N)	mg/L	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
Fluoride	F	mg/L	1.6	1.4	0.2	3	0.66	1.6	0.1	3
Silica (total)	SiO2	mg/L	18	42	5.4	74	18	39	3.2	69
Total Organic Carbon	TOC	mg/L	1.7	-	-	-	1.8	-	-	-
Standard Plate Count	SPC	cfu	5700	-	-	-	4000	-	-	-
Alkalinity	as CaCO3	mg/L	170	400	28	770	170	410	14	790
Hardness	as CaCO3	mg/L	340	850	7.6	1600	330	770	5.1	1500
Conductivity (lab)		uS/cm	1200	2600	160	4900	1200	2600	110	4700
Conductivity (ops)		uS/cm	1170	-	138	4900	1170	-	-	-
Total Dissolved Solids	TDS (sum)	mg/L	807	1979	97	3323	837	1977	66	3764
Anions (Ca,Mg,Na,K)		meq/L	11.74	28.42	1.13	54.25	11.45	27.39	0.87	50.55
Cations (HCO3,Cl,SO4)		meq/L	11.48	28.60	1.46	43.67	12.49	28.97	1.00	55.18
Ratio Anions:Cations		-	1.02	0.99	0.78	1.24	0.92	0.95	0.87	0.92

Analytical Data for Nanofiltration Testing - Continued

693-Hour Data

984-Hour Data


		Feed	Interstage	Permeate	Reject	Feed	Interstage	Permeate	Reject
CATIONS									
Ca	mg/L	81	200	1.3	380	86	200	0.87	400
Mg	mg/L	30	69	0.46	130	29	63	0.33	120
Na	mg/L	110	260	20	490	120	250	17	500
Potassium	mg/L	3.2	6.9	<1.0	13	2.7	5.6	<1.0	11
Aluminum	mg/L	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Barium	mg/L	<0.05	0.08	<0.05	0.17	<0.05	0.08	<0.05	0.16
Strontium	mg/L	1.3	3.4	<1.0	7.1	1.6	3.7	<1.0	7.4
Iron	mg/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05
Manganese	mg/L	0.54	1.3	<0.05	2.6	0.53	1.2	<0.05	2.3
Phosphorus	mg/L	0.12	0.27	<0.10	<0.10	0.12	0.28	<0.10	<0.10

ANIONS

Bicarbonate	mg/L	180	400	19	820	170	390	15	780
Chloride	mg/L	120	220	23	380	95	230	20	430
Sulfate	mg/L	290	730	7	1500	300	720	6.4	1600
Nitrate (N)	mg/L	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	0.7
Fluoride	mg/L	0.73	1.7	0.11	3	0.71	1.6	0.12	3
Silica (total)	mg/L	18	40	3.6	69	19	42	3.3	77
Total Organic Carbon	mg/L	1.7	-	-	-	3	-	-	-
Standard Plate Count	SPC	1100	1200	790	1900	-	-	-	-
Alkalinity	mg/L	180	400	19	820	170	390	15	780
Hardness	as CaCO3	330	780	5.1	1500	330	760	3.5	1500
Conductivity (lab)	uS/cm	1000	2200	98	4000	1100	2300	91	4300
Conductivity (ops)	uS/cm	835	1933	74	3795	825	1907	63	3932
Total Dissolved Solids	TDS (sum)	835	1933	74	3795	825	1907	63	3932
Anions (Ca,Mg,Na,K)	meq/L	11.38	27.14	0.97	51.31	11.97	26.18	0.81	51.87
Cations (HCO3,Cl,SO4)	meq/L	12.37	27.96	1.11	55.39	11.71	27.87	0.94	58.22
Ratio Anions:Cations	-	0.92	0.97	0.88	0.93	1.02	0.94	0.86	0.89

APPENDIX E

Nanofiltration element serial numbers as loaded in pressure vessels



NF Element Serial Numbers as Loaded in Pressure Vessels

Manufacturer Filmtec ; Model NF70-2540 ; Date 9/30/94

Stage 2, Vessel 1B, Elements 4-6 (top front)

A2282539	A2282531	A2282495
----------	----------	----------

Stage 2, Vessel 1A, Elements 1-3 (top rear)

A2282470	A2282546	A2282536
----------	----------	----------

Stage 1, Vessel 2B, Elements 4-6 (2nd from top)

A2282542	A2282481	A2282515
----------	----------	----------

Stage 1, Vessel 1B, Elements 4-6 (2nd from bottom)


A2282514	A2282524	A2282522
----------	----------	----------

Stage 1, Vessel 2A, Elements 1-3 (bottom rear)

A2282534	A2282489	A2282501
----------	----------	----------


Stage 1, Vessel 1A, Elements 1-3 (bottom front)

A2282535	A2282466	A2282494
----------	----------	----------



APPENDIX F

Lime softening process calculations



COLD LIME PROCESS - Lake Havasu City - Well S6

FEED WATER COMPOSITION

Na+	110.00	mg/L	=	4.78	meq/L	=	239.45	mg/L (as CaCO3)
K+	1.80	mg/L	=	0.05	meq/L	=	2.30	mg/L (as CaCO3)
Ca++	100.00	mg/L	=	4.99	meq/L	=	249.72	mg/L (as CaCO3)
Mg++	35.00	mg/L	=	2.88	meq/L	=	144.09	mg/L (as CaCO3)
S cations				12.70	meq/L	=	635.56	mg/L (as CaCO3)
Cl-	95.00	mg/L	=	2.68	meq/L	=	134.10	mg/L (as CaCO3)
HCO3-	232.00	mg/L	=	3.80	meq/L	=	190.29	mg/L (as CaCO3)
SO4=	300.00	mg/L	=	6.25	meq/L	=	312.57	mg/L (as CaCO3)
NO3-	4.42	mg/L	=	0.07	meq/L	=	3.57	mg/L (as CaCO3)
CO3=	0.00	mg/L	=	0.00	meq/L	=	0.00	mg/L (as CaCO3)
OH-	0.00	mg/L	=	0.00	meq/L	=	0.00	mg/L (as CaCO3)
S anions				12.80	meq/L	=	640.53	mg/L (as CaCO3)
Cation/Anion Ratio			=	0.99	Balance is excellent.			
TDS =	878.22							
pH =	7.62			R =	20.89			
CO2	9.11	mg/L (as CO2)						
Total Hardness (TH) =							393.81	mg/L (as CaCO3)
Alkalinity (Alk) =							190.29	mg/L (as CaCO3)

COAGULENT-CORRECTED COMPOSITION

Coagulent: Aluminum Sulfate (20 ppm)
 Ferrous Sulfate (20 ppm)
 4 Ferric Sulfate (10 ppm)
 Sodium Aluminate (10 ppm)

Total Hardness (TH) =				393.81	mg/L (as CaCO3)
Alkalinity (Alk)				184.29	mg/L (as CaCO3)
Calcium Alkalinity (Ca Alk) =				184.29	mg/L (as CaCO3)
Magnesium Alkalinity (Mg Alk) =				0.00	mg/L (as CaCO3)
Sodium Alkalinity (Na Alk) =				0.00	mg/L (as CaCO3)
Calcium Noncarbonate Hardness (NCH) =				65.43	mg/L (as CaCO3)
Magnesium Noncarbonate Hardness (MgNCH) =				144.09	mg/L (as CaCO3)
Total Noncarbonate Hardness (NCH) =				209.53	mg/L (as CaCO3)
Sulfate =				318.57	mg/L (as CaCO3)
Free Carbon Dioxide =				15.11	mg/L (as CO2)

DOSAGE OF LIME REQUIRED

Hyd. Lime - 93% Ca(OH)2 =	185	ppm =	1.55	lbs/1000 gallons
Chemical Lime - 90% CaO =	145	ppm =	1.21	lbs/1000 gallons
Theor. Lime - 100% CaO =	131	ppm =	1.09	lbs/1000 gallons

COLD LIME PROCESS - Lake Havasu City - Well S6 (continued)

EFFLUENT COMPOSITION

Calcium Hardness =			114.84	mg/L (as CaCO3)
Magnesium Hardness =			129.68	mg/L (as CaCO3)
Total Hardness =			244.53	mg/L (as CaCO3)
Alkalinity =			35.00	mg/L (as CaCO3)
pH =	10.0 (estimated)	R =	5011.87	

CO2 0.01 mg/L (as CO2)

DOSAGE OF ACID REQUIRED FOR pH ADJUSTMENT

4 93% H2SO4 =	2.46	ppm =	0.02	lbs/1000 gallons
35% HCl =	4.86	ppm =	0.04	lbs/1000 gallons
pH = 7.5 (target)	R	=	15.85	

TREATED WATER COMPOSITION

Na+	110.00	mg/L =	4.78	meq/L =	239.45	mg/L (as CaCO3)
K+	1.80	mg/L =	0.05	meq/L =	2.30	mg/L (as CaCO3)
Ca++	45.99	mg/L =	2.29	meq/L =	114.84	mg/L (as CaCO3)
Mg++	31.50	mg/L =	2.59	meq/L =	129.68	mg/L (as CaCO3)
S cations			9.72	meq/L =	189.29	mg/L (as CaCO3)
Cl-	95.00	mg/L =	2.68	meq/L =	134.10	mg/L (as CaCO3)
HCO3-	39.82	mg/L =	0.65	meq/L =	32.66	mg/L (as CaCO3)
SO4=	308.00	mg/L =	6.41	meq/L =	320.91	mg/L (as CaCO3)
NO3-	4.42	mg/L =	0.14	meq/L =	3.57	mg/L (as CaCO3)
CO3=	0.00	mg/L =	0.00	meq/L =	0.00	mg/L (as CaCO3)
OH-	0.00	mg/L =	0.00	meq/L =	0.00	mg/L (as CaCO3)
S anions			9.89	meq/L =	447.25	mg/L (as CaCO3)
Cation/Anion Ratio		=	0.98		Balance is good.	
TDS =	636.53					
CO2	2.06	mg/L (as CO2)				

Mission

The mission of the Bureau of Reclamation is to manage, develop, and protect water and related resources in an environmentally and economically sound manner in the interest of the American Public.

