

Low Cost Options for Moderate Levels of Mercury Control 2007 Update on TOXECON II™



DOE/NETL Mercury Control Technology Conference

December 11, 2007

Tom Campbell, ADA-ES, Inc.

DOE/NETL Project Manager: Andrew O’Palko
DOE Cooperative Agreement DE-FC26-05NT42307

Test Participants

- DOE/ NETL – Andrew O’Palko
- EPRI – Ramsay Chang
- Entergy – Independence Station
- ADA-ES
- DOE Phase II Participants
- Modeling
 - REI
 - NELS
 - ADA-ES

TOXECON II™ Evaluation Co-funders

Alliant

Atco Power

DTE

Entergy*

Oglethorpe Power

Southern Company

Xcel Energy

ADA-ES

Arch Coal

EPCOR

EPRI

NORIT Americas

Calgon Carbon

** Host Sites*




TOXECON II™ Full-Scale Evaluation

- Entergy's Independence Steam Electric Station
 - 880 MW
 - PRB Coal from North Antelope
 - Test on 1/8 of Unit 2
- Cold Side ESP
 - 540 SCA
- Project goal
 - 50-70% Hg removal




- Ash sold for concrete
 - PAC/ash routed to separate silo during tests

General TOXECON II Layout



ISES ESP General Arrangement




SCA 542 ft²/kACFM

ESP Layout




NELS Model
1/2 of 4 ESP boxes on Unit 2
(3rd field not installed)



TOXECON II™ Design Challenge: Grid Size

ESP Inlet Grid Area (60 ft/sec)



TOXECON II™ Grid Area (4 ft/sec)

Silo and Booster Blower



Injection Grid



2006 Test Results – Summary



- Achieved project goal of 50 to 70% Hg removal
- TOXECON II™ Hg removal limited to < 80% at full load with up to 8 lb/MMacf DARCO® Hg-LH
- TOXECON II™ Hg removal varied significantly with load (lower removal at high load)
- Hg removal > 80% with pre-ESP injection of DARCO® Hg-LH at 1 to 2 lb/MMacf

Suspected that poor distribution contributed to conflicting results from injection upstream of ESP versus TOXECON II™ grid

2007 Testing

- Goals for Testing
 - Improve mercury removal efficiency
 - Inject continuously to evaluate grid operability
 - Minimize sorbent use
 - Manage costs
 - Minimize potential of increased particulate emissions
 - Assess impact of injection on particulate emissions (through EPRI funding)
- Baseline/Parametric/30 day test with Lance Design 2
January – February 2007
- Five-Day Continuous Injection Test with Lance Design 3
May 2007


Original Lance Design – High Load




Phase II - New Distribution Design

- Installed new penetrations to allow on-line lance insertion and maintenance
- Redesigned lances for better top to bottom carbon distribution
- Redesigned nozzles for better plume development and to better direct carbon into gas flow
- Redesigned carrier air distribution for better penetration into gas passages


Design 2 – High Load




ISES TOXECON II™ Results Summary



Hopper, E Field, and Spring 2007 Lance Locations



Hopper Ash Comparison



Ash Analyses

LOI (%)
Hg (ng/g)


| | | | |
|--------------------|--------------------|--------------------|----------------------|
| 2-4 0.44 192 | 2-3 | 2-2 0.21 173 | 2-1 0.22 198 |
| 3-4 | 3-3 0.94 460 | 3-2 1.00 609 | 3-1 18.75 4425 |
| 4-4 | 4-3 | 4-2 2.44 893 | 4-1 15.15 6940 |

* = Carbon migrating towards control side


Test Results – Balance of Plant

- Opacity
 - Some opacity spikes measured during last field rapping while operating at reduced ESP power
 - Testing with full ESP power and varying the rapping sequence limited the particulate and opacity spikes for all sorbents tested
- Minimal other plant impacts
 - Potential fouling with ash handling valves

PAC Injection and ESP Power




Results of February 2007 PM Tests



Fall 2007 Testing

- EPRI/Entergy Supported
- Test 1/2 of B ESP or 1/8 of Unit
 - Install 24 more lances
 - Modify manifold arrangement and carrier line sizes
- Conduct PM measurements on Control and Test sides
- Goals
 - Obtain 90% mercury removal at high load and low load conditions
 - Assess impact of PAC injection on PM emissions

Fall 2007 Testing



Testing 1/8 of unit - 1/2 of B ESP

Preliminary Economics for Independence

| | |
|---|----------------------------|
| Mercury Removal Rate | 85%* |
| Brominated PAC Injection rate for above removal | 5 lb/MMacf (960 lbs/hr) |
| Native Mercury Removal | 10 – 15% |
| Stack Flow | 3.2M acfm |
| Average Coal Mercury Concentration | 5.5 lb/ TBtu |
| Mercury Removed | 643 lb/ yr |
| 20 Year Levelized Cost | \$ 7.8M ** |
| 20 Year Levelized \$/lb Mercury Removed | \$ 12.0K ** |

* Includes baseline removal.

** Includes loss of ash sales and disposal fees.

Capital Cost Estimate:\$5.15/kW

O&M Cost Estimate: 1.03 mills/KW-hr

Contacts

- **Tom Campbell**, ADA-ES Manager of DOE Demonstrations
Project Engineer responsible for site activities at
Independence 2005-2007
Tomc@adaes.com
- **Sharon Sjostrom**, ADA-ES VP Technology
Current DOE Project Manager
Sharons@adaes.com
- **Cam Martin**, ADA-ES Director of Engineering
Responsible for Commercial Applications
Camm@adaes.com

(303) 734-1727