

nh – Arrester Units⁽¹⁾

<u>nh-a Gas Tubes</u>			
<u>Manufacturer</u>	<u>MDF Module</u>	<u>Station Module</u>	<u>Well Mount</u>
Bourns		125-EW-R ⁽²⁾⁽⁵⁾	
		2374-01 ⁽²⁾⁽⁵⁾	
		2375-01 ⁽²⁾⁽⁵⁾	
		2377-01 ⁽³⁾⁽⁵⁾	
		2377-45-HS/-BC ⁽³⁾⁽⁶⁾	
		2378-35-HS/-BC ⁽³⁾⁽⁵⁾	
Corning Cable Systems	7A ⁽²⁾⁽⁵⁾	7X ⁽²⁾⁽⁵⁾	
		PTD ⁽³⁾⁽⁵⁾	
		PTD ⁽³⁾⁽⁶⁾	
Emerson Network Power Energy Systems	6A20 ⁽²⁾⁽⁵⁾	6U2VS ⁽²⁾⁽⁵⁾	1304VSR ⁽²⁾⁽⁵⁾
	3G ⁽³⁾⁽⁴⁾	3GUVS ⁽³⁾⁽⁴⁾	
		G1200-0-350 ⁽²⁾⁽⁵⁾	
Porta Systems		65BCN ⁽²⁾⁽⁵⁾	
Surge Technologies	ST3B1E ⁽³⁾⁽⁵⁾	ST356-350V ⁽³⁾⁽⁵⁾	
TII (Non-Domestic Technical Acceptance expires on <u>October 26, 2008.</u>)		126M ⁽²⁾⁽⁵⁾	
		355M ⁽³⁾⁽⁶⁾	
		356M1 ⁽³⁾⁽⁵⁾	
		AD-02W-FS ⁽³⁾⁽⁵⁾	
Tyco		GSSP ⁽³⁾⁽⁵⁾	

See page 4.4.1 for notes

4.4.1
12-27-2007
nh

nh – Arrester Units⁽¹⁾

<u>nh-b Solid-State</u>		
<u>Manufacturer</u>	<u>MDF Module</u>	<u>Station Module</u>
Bourns		2380-27-01 ⁽⁷⁾
Circa Telecom	CT3B1FS ⁽⁷⁾⁽¹¹⁾	
	CT3B1S ⁽⁷⁾⁽¹¹⁾	
Corning Cable Systems	11A ⁽⁷⁾⁽⁹⁾	PTD ⁽⁷⁾⁽¹⁰⁾
Surge Technologies	ST3B1E-BAL ⁽⁸⁾	

Notes:

⁽¹⁾Arresters listed under this category are not complete protected building entrance terminals (BET) mainframe protectors, or network interface devices (NID). They are intended for use as components, as accepted and listed, in the protected BETs, mainframe protectors, and network interface device “ni”, “nm”, and “nid” sections of the List of Materials. Arrester units here shall not be used in a BET, mainframe protector or network interface device listed in the “ni”, “nm”, or “nid” sections unless the same arrester unit is listed for use in the particular BET, mainframe protector, or network interface device on the “ni”, “nm”, or “nid” pages.

⁽²⁾2-electrode.

⁽³⁾3-electrode.

⁽⁴⁾Medium duty.

⁽⁵⁾Heavy duty.

⁽⁶⁾Maximum duty.

⁽⁷⁾PEG-7, Class I Category.

⁽⁸⁾PEG-7, Class II Category.

⁽⁹⁾For use with Corning's C-388.

⁽¹⁰⁾For use with Corning's NI-2000 Series NID unit.

⁽¹¹⁾For use with Circa Telecom's 2500QC2-100.