



September 18, 2002

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
FINAL REPORT PURSUANT TO 10 CFR PART 21
(SSH 2002-001)

Reference: STEPHEN A. BYRNE (SCE&G) TO DOCUMENT CONTROL DESK
LETTER, APRIL 16, 2002. (RC-02-0067)

South Carolina Electric & Gas Company (SCE&G) submits this letter in accordance with the requirements of 10 CFR 21.21(a)(2) as a final report of an identified defect potentially associated with a substantial safety hazard.

An Interim report was submitted on April 16, 2002 in the referenced letter.

On August 26, 2002, ABB submitted a 10CFR Part 21 Report to the NRC with the subject "Power Shield Transformer Saturation at 12X Instantaneous 10CFR Part 21 Report" discussing the current transformer problem discovered at the Virgil C. Summer Nuclear Station.

Based upon testing and engineering review of potentially affected components at VCSNS, a substantial safety hazard does not exist at VCSNS. Corrective actions have also been taken to reconfigure the potentially affected Power Shield units out of the limiting conditions noted in the ABB report.

Should you have any questions, please call Mr. Jeffrey Pease at (803) 345-4124.

Very truly yours,

Stephen A. Byrne

IE19.

Document Control Desk
SSH 2002-001
RC-02-0167
Page 2 of 2

SAB/jwp

c. N. O. Lorick
N. S. Carns
T. G. Eppink
R. J. White
L. A. Reyes
G. E. Edison
K. R. Cotton
K. W. Sutton
NRC Resident Inspector

J. M. Wagner
INPO Records Center
NSRC
QC
W. R. Higgins
RTS (0-L-02-0045)
File (818.18)
DMS (RC-02-0167)