



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
SAM NUNN ATLANTA FEDERAL CENTER
61 FORSYTH STREET SW SUITE 23T85
ATLANTA, GEORGIA 30303-8931**

March 31, 2000

Carolina Power and Light Company
ATTN: Mr. J. S. Keenan
Vice President
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461

SUBJECT: PLANT PERFORMANCE REVIEW - BRUNSWICK NUCLEAR PLANT

Dear Mr. Keenan:

The purpose of this letter is to communicate our assessment of your performance and to inform you of our planned inspections at your facility. On February 24, 2000, we completed a plant performance review (PPR) of Brunswick Nuclear Plant. We conduct these reviews to develop an integrated overview of the safety performance of each operating nuclear power plant. We use the results of the PPR in planning and allocating inspection resources and as inputs to our senior management meeting (SMM) process. This PPR evaluated inspection results and safety performance information for the period from February 1, 1999, through January 31, 2000, but emphasized the last six months to ensure that our assessment reflected your current performance. Our most recent summary of plant performance at Brunswick was provided to you in a letter dated March 23, 1999, and was discussed with you in a public meeting on July 20, 1999.

The NRC has been developing a revised reactor oversight process that will replace our existing inspection and assessment processes, including the PPR, the SMM, and the Systematic Assessment of Licensee Performance (SALP). We recently completed a pilot program for the revised reactor oversight process at nine participating sites and are making necessary adjustments based on feedback and lessons learned. We plan to begin initial implementation of the revised reactor oversight process industry-wide, including your facility, on April 2, 2000.

This PPR reflects continued process improvements as we make the transition into the revised reactor oversight process. Instead of characterizing our assessment results by SALP functional area, we are organizing the results into the strategic performance areas embodied in the revised reactor oversight process. In addition, we have considered the historical performance indicator data that you submitted in January 2000 in conjunction with the inspection results in assessing your performance. The results of this PPR were used to establish the inspection

plan in accordance with the new risk-informed inspection program (consisting of baseline and supplemental inspections). Although this letter incorporates some terms and concepts associated with the new oversight process, it does not reflect the much broader changes in inspection and assessment that will be evident after we have fully implemented our revised reactor oversight process.

During the last six months, Unit 1 operated at or near 100 percent power up to the scheduled refueling outage on February 25, 2000, with the exception of an unscheduled shutdown of both units due to hurricane Floyd, and a manual scram on November 5, 1999. The scram was caused by the inadvertent loss of a reactor feedwater pump during routine testing. During the last six months, Unit 2 has operated at or near 100 percent power with the exception of a manual scram on September 20 due to a procedural error during startup.

We have not identified any significant performance issues during this assessment period and note that Brunswick continues to operate in a safe manner. Therefore, we plan to conduct only baseline inspections at your facility as noted in the enclosed inspection plan.

Enclosure 1 contains an historical listing of plant issues, referred to as the Plant Issues Matrix (PIM), that were used during this PPR process to arrive at our integrated view of your performance trends. The PIM for this assessment is grouped by the prior SALP functional areas of operations, maintenance, engineering and plant support. Future PIMs will be organized along the cornerstones of safety as described in the revised reactor oversight process. The enclosed PIM includes items summarized from inspection reports or other docketed correspondence regarding Brunswick. We did not document all aspects of licensee programs and performance that may be functioning appropriately. Rather, we only documented issues that we believe warrant management attention or represent noteworthy aspects of performance. In addition, the PPR may also have considered some predecisional and draft material that does not appear in the enclosed PIM, including observations from events and inspections that had occurred since our last inspection report was issued, but had not yet received full review and consideration. We will make this material publically available as part of the normal issuance of our inspection reports and other correspondence.

Enclosure 2 lists our planned inspections for the period April 2000 through March 2001 at Brunswick to allow you to resolve scheduling conflicts and personnel availability in advance of our inspectors' arrival onsite. The inspection schedule for the latter half of the period is more tentative and may be adjusted in the future due to emerging performance issues at Brunswick or other Region II facilities. Routine resident inspections are not listed due to their ongoing and continuous nature.

CP&L

3

We will inform you of any changes to the inspection plan. If you have any questions, please contact me at (404) 562-4560.

Sincerely,

/RA/

Brian R. Bonser, Chief
Reactor Projects Branch 4
Division of Reactor Projects

Docket Nos. 50-325, 50-324
License Nos. DPR-71, DPR-62

Enclosures: 1. Plant Issues Matrix
2. Inspection Plan

cc w/encls: (See page 4)

CP&L

4

cc w/encls:

J. J. Lyash, Director
Site Operations
Brunswick Steam Electric Plant
Carolina Power & Light
Electronic Mail Distribution

Terry C. Morton, Manager
Performance Evaluation and
Regulatory Affairs CPB 7
Carolina Power & Light Company
Electronic Mail Distribution

K. R. Jury, Manager
Regulatory Affairs
Carolina Power & Light Company
Brunswick Steam Electric Plant
Electronic Mail Distribution

William D. Johnson
Vice President & Corporate Secretary
Carolina Power and Light Company
Electronic Mail Distribution

John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, NW
Washington, DC 20037-1128

Mel Fry, Director
Division of Radiation Protection
N. C. Department of Environment
and Natural Resources
Electronic Mail Distribution

Peggy Force
Assistant Attorney General
State of North Carolina
Electronic Mail Distribution

Robert P. Gruber
Executive Director

Public Staff NCUC
P. O. Box 29520
Raleigh, NC 27626-0520

Public Service Commission
State of South Carolina
P. O. Box 11649
Columbia, SC 29211

Jo Ann Simmons, Chairman
Brunswick County Board of
Commissioners
P. O. Box 249
Bolivia, NC 28422

Dan E. Summers
Emergency Management Coordinator
New Hanover County Department of
Emergency Management
P. O. Box 1525
Wilmington, NC 28402

Distribution w/encls: (See page 5)

CP&L

5

Distribution w/encls:
A. Hansen, NRR
PUBLIC

OFFICE	RII:DRP	RII:DRS	RII:DRS	RII:DRS	RII:DRS		
SIGNATURE							
NAME	GMacDonald:vg	KBarr	ABelisle	GHopper	EGirard		
DATE	8/ /2000	8/ /2000	8/ /2000	8/ /2000	8/ /2000	8/ /2000	8/ /2000
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\pprltr 2000.wpd