

## SYNOPSIS

### General

This year is the 52<sup>nd</sup> consecutive year that an Annual Operating Plans (AOP) has been prepared for the Federally-owned dams and reservoirs in the Niobrara, Lower Platte, and Kansas River Basins. The plan has been developed by the Water Operations Group in McCook, Nebraska for the 16 dams and reservoirs that are located in Colorado, Nebraska, and Kansas. These reservoirs, together with 9 diversion dams, 9 pumping plants, and 20 canal systems, serve approximately 265,411 acres of project lands in Nebraska and Kansas. In addition to irrigation and municipal water, these features serve flood control, recreation, and fish and wildlife purposes. A map at the end of this report shows the location of these features.

The reservoirs in the Niobrara and Lower Platte River Basins are operated by either irrigation or reclamation districts. The reservoirs in the Kansas River Basin are operated by either the Bureau of Reclamation (Reclamation), or the Corps of Engineers. Kirwin Irrigation District provides operational and maintenance assistance for Kirwin Dam. The diversion dams, pumping plants, and canal systems are operated by either irrigation or reclamation districts.

A Supervisory Control and Data Acquisition System (SCADA) located at McCook is used to assist in operational management of all 11 dams under Reclamation's jurisdiction that are located in the Kansas River Basin. A Hydromet system collects and stores near real-time data at selected stations in the Nebraska-Kansas Projects. The data includes water levels in streams, canals, and reservoirs and also gate openings. This data is transmitted to a satellite and downloaded to a Reclamation receiver in Boise, Idaho. The data can then be accessed by anyone interested in monitoring water levels or water usage in an irrigation system. The Nebraska-Kansas Projects currently has 109 Hydromet stations that can be accessed. The McCook Field Office has installed and maintains 55 Hydromet stations with plans to install more as time permits. When fully implemented, the projects will have a Hydromet station installed to provide real-time data on all reservoirs, most diversion dams, and most of the measuring structures in the irrigation systems. These stations can be found on the Internet by accessing Reclamation's home page at <http://www.usbr.gov/gp>. From the home page, select "Hydromet Data Center" under the Water Operations heading.

The Headlines 2004 that follows this synopsis is indicative of the awareness that the local people have of the natural resource development and conservation in the Niobrara, Lower Platte, and Kansas River Basins.

### 2004 Summary

#### Climatic Conditions

Precipitation at the project dams during 2004 ranged from 87 percent of normal at Davis Creek Dam to 142 percent of normal at Trenton Dam. Precipitation during the first four months of the year varied throughout the projects area. Precipitation totals were above normal at 9 of the 16 project dams, varying from 77 to 137 percent. Temperatures were generally well above normal during January and March and below normal in February. April brought weather that was generally drier than normal with temperatures averaging near to slightly above normal.

Precipitation during May and June was generally below normal throughout the basin. Only two project dams recorded above normal precipitation during May while six project dams were above normal in June. Precipitation totals for the first six months of the year were below normal at 14 of the 16 project dams, varying from 63 percent at Norton Dam to 125 percent at Lovewell Dam. Temperatures were above normal in May and averaged well below normal in June. July brought some much needed precipitation to the project reservoirs with only two dams having below normal precipitation for the month. Trenton and Enders Dams in southwest Nebraska recorded the highest July precipitation on record at the respective sites. Red Willow Dam recorded the second highest July precipitation total at the site. A few isolated thunderstorms in July did produce some localized short term runoff. The improvement turned out to be short lived as August precipitation was well below normal at all project dams with the exception of Merritt Dam. Precipitation during August was only 45 percent of normal over the projects. Temperatures in July were generally near to below normal throughout the projects area and near normal in August. Temperatures during September varied considerably while precipitation was generally above average throughout the projects.


Total precipitation during October and November was generally above normal throughout the projects. Only six dams recorded below normal precipitation during October and only five during the month of November. Precipitation during December was well below normal at all project dams averaging only 17 percent of average. Temperatures averaged well above normal during October, November, and December.

### Storage Reservoirs

1. Conservation Operations. The 2004 inflow was below the dry-year forecast at Box Butte, Bonny, Enders, Kirwin and Webster Reservoirs, and Swanson, Hugh Butler, Harry Strunk, Harlan County and Waconda Lakes. Merritt, Calamus, Davis Creek, Lovewell and Cedar Bluff Reservoirs along with Keith Sebelius Lake had inflows between the dry- and normal-year forecasts. None of the project reservoirs had inflows above the normal-year forecast.

Project reservoirs had below average carryover storage from the 2003 water year with the exception of Cedar Bluff Reservoir. Of the 12 project reservoirs in the Kansas River Basin, only Hugh Butler Lake and Lovewell Reservoir did not record below average inflows during all 12 months of 2004. Hugh Butler Lake recorded below average inflows during 11 months of 2004. Reservoir releases were made from Merritt and Virginia Smith Dams to maintain reservoir levels prior to the 2004 irrigation season. Just prior to the irrigation season, Enders, Kirwin, Webster and Box Butte Reservoirs, along with Keith Sebelius, Swanson, Hugh Butler, Harry Strunk and Harlan County Lakes, did not have sufficient storage to provide water users with a full water supply. Only Lovewell Reservoir had some flood storage occupied prior to the irrigation season. The high irrigation demand months of July and August significantly reduced storage in those project reservoirs that had storage available for irrigation. Precipitation during late July and August was of little help in reducing the demands on project reservoirs. Storage in the Kansas River Basin project reservoirs was below normal at the end of the irrigation season with the exception of Cedar Bluff Reservoir.

The following summarized graph shows a comparison of 2003 and 2004 carry-over storage conditions as compared to the top of conservation storage for all reservoirs in the Niobrara, Lower Platte, and Kansas River Basins as of September 30th.



2. Flood Control Operations. Lovewell Reservoir utilized flood pool storage in 2004. A flood release was made from Lovewell Reservoir from July 8<sup>th</sup> through July 19<sup>th</sup> to reduce pool levels. The fiscal year 2004 flood control benefits accrued by the operation of Reclamation's Nebraska-Kansas Projects facilities was \$307,000 as determined by the Corps of Engineers. An additional benefit of \$5,000 was credited to Harlan County Lake. The accumulative total of flood control benefits for the years 1951 through 2004 by facilities in this report total \$1,872,447,000 (See Table 5). To date no benefits have been accrued by the operation of Box Butte, Merritt, Calamus, or Davis Creek Reservoirs.

A summary of precipitation, reservoir storage and inflows at Nebraska-Kansas Projects facilities can be found in Table 7.

Water Service

There was 277,458 acre-feet (AF) of water diverted to irrigate approximately 160,554 acres of project lands in the 12 irrigation districts (see Tables 3 and 6). The project water supply was either inadequate or limited for 169,024 acres of the total project lands. This includes lands in Mirage Flats, Frenchman Valley, H&RW, Frenchman-Cambridge, Almena, Bostwick in Nebraska, Kansas Bostwick, Kirwin and Webster Irrigation Districts. The project water supplies for the other units mentioned in this report were more than adequate in 2004.

The water requirements of three municipalities, one rural water district, and two fish hatchery facilities were furnished from storage releases or natural flows.

Irrigation Production

The 2004 crop yields on lands receiving project water in the Nebraska-Kansas Projects were higher than 2003 for five of the seven reporting districts. The average corn yield, the principal crop of all reporting districts, was 177 bushels per acre. This was approximately ten bushels per

acre more than in 2003. The average unit price of corn when harvested was lower than the previous year at approximately \$2.10/bu. The start of irrigation releases from project reservoirs varied considerably depending on storage water available. Much of the growing season was cooler and drier than normal. Most districts experienced some relief from the dry conditions during the first part of July. Crop maturity progressed near normal during the growing season. Several irrigation districts had finished making irrigation releases by the first half of September. Nine canals did not divert water in 2004 as a result of extremely short water supplies. Nearly all irrigation districts had finished delivering water by the end of September with corn harvest commencing by mid October.

### Fish and Wildlife and Recreation Benefits

The National Recreational Fisheries Policy declares that the Government's vested stewardship responsibilities must work in concert with the state managing agency's recreational fisheries constituency and the general public to conserve, restore, and enhance recreational fisheries and their habitats. As a result of this policy, Reclamation has developed fishery management guidelines for reservoirs within the Nebraska-Kansas Projects. These guidelines outline a program which considers public use, fisheries, fish habitat, and improved communication and coordination. The Nebraska-Kansas Area Office is available for meetings if requested with Nebraska, Colorado, and Kansas state management agencies to discuss the Annual Operating Plans (AOP). Information is solicited that will allow Reclamation the flexibility to enhance fisheries resources while still meeting contractual obligations with the various irrigation districts.

During the early part of the 2004 season, normal reservoir operations were favorable for recreation and fish and wildlife uses at most project reservoirs. Late in the season, irrigation operations substantially lowered the water levels of most reservoirs in the Kansas River Basin, limiting the recreation benefits. Normal summer drawdown due to irrigation releases did allow for late summer shoreline revegetation.

Re-authorization of the North Loup Project by the Act of October 18, 1986 [Public Law 99-591, Section 101(e)] authorized the construction of a fish hatchery below Virginia Smith Dam and Calamus Reservoir. The hatchery was constructed under Public Law 89-72 and a cost-sharing agreement with the Nebraska Game and Parks Commission (Commission) with 75 percent federal and 25 percent state funds. Administration of construction was accomplished by the Commission; construction began in July 1989, and was completed in September 1991. The hatchery consists of an office/visitor center, laboratory, 2 residences, a shop and feed storage building, 51 rearing ponds lined with VLDPE and covering 45.5 acres, 24 concrete raceways, 2 lined effluent ponds, 8 groundwater wells, a 36-inch diameter buried pipeline from Virginia Smith Dam, a groundwater degassing tank, and a computerized monitoring and alarm system. The hatchery is operated and maintained by the Commission and in full operation should produce about 53 million fish per year. The water supply is provided by natural flows passed through Virginia Smith Dam and from Calamus Reservoir storage through an agreement dated July 28, 1988, between the Commission and the Twin Loups Reclamation District.

## 2005 Outlook

Three detailed studies have been developed for each of the reservoirs in the Niobrara, Lower Platte, and Kansas River Basins conforming with established operating criteria under various reservoir inflow conditions. These operation studies are included in table 4, sheets 1 through 16. The municipal and rural water district water supply requirements will be met under all three inflow forecast conditions for all units.

Under reasonable minimum inflow forecast conditions, irrigation districts receiving storage water from the following lakes and reservoirs are expected to receive less than a full supply: Box Butte, Enders, Swanson, Hugh Butler, Harry Strunk, Keith Sebelius, Harlan County, Lovewell, Kirwin and Webster. The irrigation districts affected are Mirage Flats; Frenchman Valley and H&RW; Frenchman-Cambridge; Alma; Bostwick in Nebraska and Kansas Bostwick; Kirwin; and Webster; respectively. If 2005 is a dry year, 169,024 of the total 265,411 acres with service available to be irrigated (64 percent) will have an inadequate water supply.

Under most probable inflow conditions, it is also expected that Frenchman Valley, H&RW, Alma, Bostwick in Nebraska, Kansas Bostwick, Kirwin, Webster and Mirage Flats Irrigation Districts would experience some shortages to irrigation demands from Enders Reservoir, Keith Sebelius Lake, Harlan County Lake, Lovewell Reservoir, Kirwin Reservoir, Webster Reservoir and Box Butte Reservoir. Most irrigators in these districts plan to use water from private wells to supplement the project water supply.

Even under reasonable maximum inflow conditions, Mirage Flats, Frenchman Valley, H&RW and Alma Irrigation Districts are expected to experience irrigation demand shortages from Box Butte and Enders Reservoirs, and Keith Sebelius Lake.

During 2005, under all inflow forecast conditions, storage water will be in excess of project needs at Bonny Reservoir and Waconda Lake. The state of Colorado will make Bonny storage water available to downstream water right appropriators.

Under reasonable minimum inflow conditions, the conservation pools at Merritt, Calamus and Davis Creek Reservoirs are expected to fill during 2005.

Even with low reservoir levels and inadequate water supplies for some project lands, the recommendations of various state agencies will be considered. As in the past, irrigation and reclamation districts will advise state agencies regarding aquatic weed control and canal operations. Reclamation will continue to operate the reservoirs and other facilities under its jurisdiction in the best interests of all project functions and for the optimum public benefit.

# HEADLINES 2004

*Farmers anxious about impact of Republican River settlement*

  
McCook Daily Gazette  
Bureau of Reclamation to  
build new office in McCook

**Lower Republican NRD  
irrigators uneasy with  
Compact compliance**

Impact of scaled-back irrigation  
may not be as grim as expected

**Toxic algae blamed on drought**

Irrigation district members  
to vote on state water lease

**NRD meetings  
seek input on  
Compact plans**

New water  
law faces  
challenges

**Governor, local NRD  
committee talk about  
compliance issues**

**Heavy snow helps; won't end drought**

Republican  
State issues warnings  
on Enders, other lakes

Nebraska looks at conserving water  
by paying farmers not to pump

Republican River Compact compliance

**State faces 2007 deadline**

Farm leaders seek drought aid

Water levels at Harlan County  
Lake reason for concern

**Irrigators study strategies**

**NRD adopts water regulations**

Water shortage still is a  
major concern for 2004

**Model links ground, surface water**

**Area lakes showing slow improvement**

BY GLORIA MASONER

**Salt cedar sucks up precious water**

New water-shortage strategies are foreseen

## CHAPTER I – INTRODUCTION

### Purpose of This Report

This AOP advises water users, cooperating agencies, and other interested groups or persons of the actual operations during 2004 and serves as a guideline for the 2005 operations. This report also describes the responsibilities of Reclamation, Corps of Engineers, and the irrigation and reclamation districts in the Niobrara, Lower Platte, and Kansas River Basins.

### Operational Responsibilities

Reclamation is responsible for irrigation operations at all federal reservoirs in the Nebraska-Kansas Projects. Reclamation is also responsible for the operation and maintenance (O&M), safety of the structure, and reservoir operations not specifically associated with regulation of the flood control storage at the reservoirs constructed by Reclamation. Regulation of the flood control storage is the responsibility of the Corps of Engineers. In addition to irrigation and flood control, these reservoirs provide recreation, fish and wildlife, and municipal benefits.

By contractual arrangements with Reclamation, the irrigation or reclamation districts in the Niobrara, Lower Platte, and Kansas River Basins are responsible for the O&M of the canals and irrigation distribution facilities constructed or rehabilitated by Reclamation. In addition, the appropriate irrigation or reclamation districts are responsible for operating and maintaining Box Butte, Merritt, Virginia Smith and Davis Creek Dams. The Corps of Engineers operates and maintains Harlan County Dam and Lake. The state of Colorado provides operational guidelines for Bonny Reservoir. Operational guidelines for Cedar Bluff Reservoir will be provided by the State of Kansas. Reclamation operates and maintains 11 dams and reservoirs in the Republican, Solomon, and Smoky Hill River Basins. Under a contract with Reclamation, Kirwin Irrigation District performs certain operational and maintenance functions at Kirwin Dam.

An updated Field Working Agreement was executed on July 17, 2001 between the Corps of Engineers and Reclamation regarding operation of Harlan County Dam and Lake. The agreement provides for a sharing of the decreasing water supply into Harlan County Lake. Storage capacity allocations were redefined based on the latest sediment survey (2000) and a procedure was established for sharing the reduced inflow and summer evaporation among the various lake uses.

The states of Nebraska, Colorado, and Kansas are responsible for the administration and enforcement of their state laws pertaining to the water rights and priorities of all parties concerned with the use of water. The states are also responsible for administering the water surface activities and the federal lands around the reservoir. The U.S. Fish and Wildlife Service administers the water surface activities and most of the federal lands at Kirwin Reservoir.

Reclamation cooperates with all state agencies and compact commissions to ensure that all operations are in compliance with state laws and compact requirements.

### Tables and Exhibits

Records for the facilities reported in the AOP are included as tables and exhibits and are located following page 35.

## Water Supply

For forecasting purposes, values of annual inflows that will be statistically equaled or exceeded 10, 50, and 90 percent of the time were selected from the probability data to be reasonable maximum (wet year), most probable (normal year), and reasonable minimum (dry year) inflow conditions, respectively.

Inflow records from 1985 through 2004 were used for the analysis of reservoirs in the Niobrara, Lower Platte and Kansas River Basins, with the exception of Calamus and Davis Creek Reservoirs. The more recent available record of 1986 through 2004 was used for Calamus Reservoir. Davis Creek Reservoir is an off-stream storage facility with only 6.3 square miles of drainage area. Inflow to Davis Creek Reservoir is supplied by diversions from Calamus Reservoir and the North Loup River.

## Reservoir Operations

All operations are scheduled for optimum benefits of the authorized project functions. Monthly, or as often as runoff and weather conditions dictate, Reclamation evaluates the carry-over storage and estimated inflow at each reservoir to determine whether excess water is anticipated. If excess inflow is apparent, controlled releases will be made to maximize the downstream benefits, including flood control.

## Major Features

The Mirage Flats Project was constructed under the Water Conservation and Utilization Act and includes an irrigation storage reservoir, diversion dam, and canal system. The other features discussed in this report are all a part of the Pick-Sloan Missouri Basin Program and include single and multipurpose reservoirs, diversion dams, pump stations, and canal systems. The 16 storage facilities now in operation are listed below.

### Constructed by Reclamation

1. Operated by irrigation or reclamation districts--Box Butte and Merritt Dams in the Niobrara River Basin and Virginia Smith and Davis Creek Dams in the Lower Platte River Basin.
2. Operated by Reclamation--Bonny, Trenton, Enders, Red Willow, Medicine Creek, Norton, Lovewell, Kirwin, Webster, Glen Elder, and Cedar Bluff Dams in the Kansas River Basin. A contract provides for Kirwin Irrigation District to perform certain operational and maintenance functions at Kirwin Dam.

### Constructed and Operated by the Corps of Engineers

1. Harlan County Dam in the Kansas River Basin.



## Irrigation and Reclamation Districts

Twelve irrigation districts and one reclamation district in the Niobrara, Lower Platte, and Kansas River Basins have contracted with Reclamation for water supply and irrigation facilities. The Twin Loups Irrigation District has contracted their O&M responsibilities to the Twin Loups Reclamation District. Bostwick Irrigation District in Nebraska has contracted their O&M responsibilities for Courtland Canal between the headgates and the Nebraska-Kansas state line to Kansas Bostwick Irrigation District.

The contracted irrigation season for the Mirage Flats Irrigation District is April through September. The contracted irrigation season for Frenchman Valley, H&RW and Frenchman-Cambridge Irrigation Districts is from May 1<sup>st</sup> through October 15<sup>th</sup> or such additional period from April 1<sup>st</sup> through May 1<sup>st</sup> of each year as determined between the District and Reclamation. The contracted irrigation season for Almena, Bostwick in Nebraska, Kansas-Bostwick and Twin Loups Reclamation District is May 1<sup>st</sup> through September 30<sup>th</sup> or such additional period from April 1<sup>st</sup> through November 15<sup>th</sup> of each year as determined between the District and Reclamation. For all other districts, the contracted irrigation season is from May 1<sup>st</sup> through September 30<sup>th</sup>.

## Long Term Water Service Contract Renewal

The renewal of the long term water service contracts with Frenchman-Cambridge, Kansas Bostwick, Nebraska Bostwick, and Almena Irrigation Districts was completed in 2000. The districts negotiated the conversion of their water service contracts to repayment contracts with a 40 year repayment period. These contracts were signed July 25, 2000 and confirmed in District Court. These contracts became effective January 1, 2001. These contracts include provisions that provide for water supply and distribution works reserve funds, water conservation commitments to improve efficiencies, environmental commitments, and provisions for irrigation policies/deliveries to help preserve lake levels.

The renewal of the long term water service contract with Frenchman Valley Irrigation District was completed in 2000. The district negotiated the renewal of their water service contract that includes a 40 year term. The contract was signed July 25, 2000 and was confirmed in District Court. The contract became effective January 1, 2001. This contract includes provisions that provide for a water supply reserve fund, water conservation commitments to improve efficiencies, environmental commitments, and provisions for irrigation policies/deliveries to help preserve lake levels.

The new contracts require that Reclamation meet with the districts listed above prior to March 1<sup>st</sup> of each year for an annual water operations meeting. Discussions include the previous year's water operations season, the upcoming year's water supplies, historic water supplies and delivery efficiencies and potential water conservation measures.

The renewal of the long term water service contracts with Kirwin Irrigation District No. 1 and Webster Irrigation District No. 4 was completed in 2002. The districts negotiated the conversion of their water service contracts to repayment contracts with a 40 year repayment period. The repayment contracts were signed on June 20, 2002 and became effective January 1, 2003.

The long-term water service contract with the Ainsworth Irrigation District (AID) will expire December 31, 2006. The AID notified Reclamation that on February 16, 2005, the Board approved a motion to request renewal of the AID contract with Reclamation. The process for renewing the long term water service contract with AID will begin in the spring of 2005. The AID is currently working to secure a four year extension to their existing water service contract to ensure an uninterrupted water supply to the District during the renewal process.

### Municipal Water

Three municipalities and one rural water district have executed water service contracts for full or supplemental water supplies.

### Fish and Wildlife

The State of Kansas is presently using the fish hatchery facility below Cedar Bluff Reservoir for waterfowl habitat. The Calamus Fish Hatchery located below Calamus Reservoir is operated by the State of Nebraska for fish production.

### State of Colorado Division of Wildlife

The Colorado Division of Wildlife provides operational guidelines for Bonny Reservoir. The entire conservation pool storage was purchased by the State of Colorado on June 24, 1982.

### State of Kansas Department of Wildlife and Parks

The State of Kansas acquired the use and control of portions of the conservation capacity at Cedar Bluff Reservoir following the reformulation of the Cedar Bluff Unit in October of 1992. The City of Russell's existing water storage right and contract with the United States remained unchanged.

### Power Interference Considerations

A Power Interference Agreement exists between Reclamation, the Twin Loups Reclamation District, and the Loup River Public Power District. Provisions of this agreement will be incorporated into the 2005 operations.

### Environmental Considerations

A "Statement of Operational Objectives" for Harlan County Lake sets forth the general operational objectives and the specific reservoir uses that are desirable. The operational objectives indicate that fish and wildlife interests are best served by high reservoir levels with minimum fluctuations, and regulation of the outflow in excess of the minimum desired flows. Although the statement recognizes flood control and irrigation as primary purposes, it indicates that comprehensive operational plans should be developed for maximum integration of the secondary uses.

These objectives are also considered in the operation of all Reclamation reservoirs in the Kansas River Basin, Niobrara River Basin, and the Lower Platte River Basin. The regulated outflow will also benefit farmers, ranchers, cities, and other interests below the reservoirs.

## Republican River Compact – Kansas v. Nebraska

On May 26, 1998, Kansas filed a petition with the U. S. Supreme Court complaining that Nebraska had violated the Republican River Compact by using more than its share of the Republican River water supply. On November 15, 1999, the Supreme Court appointed Vincent L. McKusick as the Special Master for the case. The three original parties to the Compact; Kansas, Nebraska and Colorado, became parties to the case. Because all of the major water development structures in the Republican River Basin were constructed by the Bureau of Reclamation and the Corps of Engineers, the United States was allowed to participate as an *amicus curiae*. After negotiations were completed the Final Settlement Stipulation was signed by each respective governor and attorney general and was filed with the Special Master on December 16, 2002.

On May 19, 2003, the United States Supreme Court approved the settlement and dismissed the case. On June 30, 2003, the three States reached agreement on the Republican River Compact Administration groundwater model. The model will be used to quantify groundwater consumptive use as part of the compact's accounting process. The settlement provides for a moratorium on new groundwater wells, special rules for administration of water during water-short years, protection of storage releases, minimized flood flow effects on the accounting, recognition by Nebraska of a 1948 priority date for the Kansas-Bostwick Irrigation District, inclusion of the impacts of groundwater pumping from tableland wells in the accounting, and accounting for all reservoirs 15 acre-feet and larger within the river basin.

With the support of Kansas and Nebraska, Reclamation completed an Appraisal Study which analyzed system improvement alternatives in the lower portion of the basin that would provide for more efficient use of the water supply. This study was completed in 2004 and distributed to interested parties in February of 2005. The study met requirements of the Final Settlement Stipulation by investigating system improvements in the Basin, including measures to improve the ability to utilize the water supply below Hardy, Nebraska. This study also met the responsibilities of the Republican River Compact by investigating the most efficient use of the water of the Republican River Basin for multiple purposes. The Stipulation also required that the States, in cooperation with the United States, form a Conservation Committee and by April 30, 2004, develop a proposed study plan to determine the quantitative effects of non-federal reservoirs and land terracing practices on water supplies in the Republican River Basin above Hardy, Nebraska. The Study Plan supported by the three states, the Natural Resources Conservation Service, and Reclamation was completed and signed on April 28, 2004. Cooperative agreements for completing the five year study were developed between Reclamation, the University of Nebraska-Lincoln (UNL), and Kansas State University. Installation of data loggers on 35 reservoirs throughout the basin was completed in 2004. More detailed monitoring equipment for terraces and additional reservoirs will be installed by UNL in the spring of 2005.

Water-Short Year Administration will be in effect in those years in which the projected or actual irrigation supply is less than 119,000 acre feet of storage available for use from Harlan County Lake as determined by Reclamation. It was determined in 2004 that a "Water-Short Year Administration" was in effect.

## Emergency Management

The Nebraska-Kansas Area Office (NKAO) continued to coordinate with local jurisdictions that could potentially be impacted by flooding from large operational releases and/or dam failure. Five tabletop exercises were conducted during calendar year 2004 and orientation

meetings were held for all of the NKAO dams. Tabletop exercises were held for the Bonny Dam Emergency Action Plan (EAP), Enders Dam EAP, Lovewell Dam EAP, Kirwin Dam EAP, and the Webster Dam EAP. Emergency radios have been installed at all dams. These radios will be used as a backup means of communication when notifying the local emergency management officials in the event of an emergency at the dam. Both the Nebraska-Kansas Area Office and the McCook Field Office have a satellite phone that can be used in an emergency. Management and the dam operators have been trained on the use of these phones.

There was one internal alert declared at NKAO projects in 2004. At Enders Dam, an Internal Alert was declared after a small depression was found near the outlet works stilling basin. The cause of the depression is still being investigated. An internal alert at Virginia Smith Dam is still in effect until the repairs of the spillway drainage system are complete. The repair contract is scheduled for the fall of 2005.

Two functional exercises and three table top exercises are planned in 2005. EAP orientation meetings will be held at all NKAO dams. A program of annual meetings with local law enforcement and the facility managers has been established. Risk assessments were conducted for Trenton, Lovewell and Glen Elder Dams in 2004. The risk assessment process for the remaining 11 dams will begin in 2005. Site security plans for each dam are scheduled to be written in 2005.

### Public Safety Reviews

NKAO continues the ongoing safety reviews of project facilities to identify potential safety hazards to the public and operating personnel. During 2004, NKAO combined the Safety Reviews of the major facilities with the Dam Safety Facility Reviews. This format provided for input from both the Area Safety Manager, and teams of Dam Safety Specialists. Some recommendations included enhanced confined space signage, expand the public knowledge of safety issues around our facilities, and provide training to employees regarding some of the new OSHA requirements for record keeping.

NKAO was again involved with emergency personnel at several sites, specifically to brief them on special and unique considerations at our facilities. Many of these visits were required as part of a contracting process when a major construction job was to be conducted at that facility.

In order to ensure facility accessibility, reliability and safety, additional focus was placed on compliance with accessibility standards. Specialists from the Denver Technical Center performed four accessibility evaluations at public access sites at four different reservoirs. These evaluations were comprehensive, and set out specific suggestions as to improvements at public facilities. These evaluations will continue throughout 2005.

During the planning stages of the NKAO Annual Safety Training, an informational letter, and invite was sent to all of the water users within the NKAO jurisdiction. This letter included some safety tips, an invitation to the Annual Safety Training, and promoted the utilization of Reclamation when developing or maintaining safety programs for the water districts.

Particular attention was directed at awareness of issues concerning West Nile Virus. Employees were given information related to protection, and identification of this virus.

The NKAO continues to monitor compliance of the Life Safety Code at all applicable facilities. A new simplified code assessment tool was developed during FY 2004 in conjunction with the Regional Office and will be very helpful, during FY 2005, to reevaluate the facilities with the NKAO jurisdiction.

#### Facility Reviews, Maintenance and Construction

Comprehensive Facility Reviews were conducted at Enders, Trenton, Lovewell, Box Butte and Glen Elder Dams during 2004. Annual Site Inspections were conducted at the other ten NKAO dams in 2004.

Associated Facility Reviews were conducted in 2004 for the following canal systems: Almena, Culbertson, Culbertson Extension, Meeker-Driftwood, Red Willow, Bartley, Cambridge, Kirwin and Osborne.

Technical surveys were completed at Kirwin, Lovewell, and Glen Elder Dams in 2004.

Construction of a new Reclamation office building in McCook, Nebraska began in June of 2004. The new building will replace the existing structure built more than 70 years ago. Construction is expected to be completed in May 2005.

Security enhancements continue at NKAO dams.

Video inspections of the toe drain systems at Trenton and Glen Elder Dams were attempted with varying degrees of success during 2004. A program to examine all of our toe drain systems was initiated in 2001.

## CHAPTER II - NIOBRARA AND LOWER PLATTE RIVER BASINS

### Mirage Flats Project in Nebraska

#### General

Flows in the Niobrara River along with Box Butte Reservoir storage provide a water supply for the 11,662 acre Mirage Flats Project. From 1995 to 2004, the project water supply averaged 12,500 AF, which is about 1.07 acre-foot per irrigable acre. Many irrigators supplement their water supply with private wells.

The Mirage Flats Irrigation District cooperates with the Nebraska Game and Parks Commission (Commission) by operating the Box Butte Dam outlet works gate and the Dunlap Diversion Dam gates in a manner to avoid sudden large changes in the flows of the Niobrara River. A 30-year agreement was made in 1990 between the district and the Commission whereby the district would not draw the reservoir water level below elevation 3978.00 feet (2,819 AF). In return the district received an up-front payment which was used to improve the efficiency of the project's delivery system. On March 17, 2000, the district agreed to increasing the minimum reservoir level by one additional foot to elevation 3979.00 feet (3,244 AF). In return the district received an additional payment from the Commission for the 20 years left on the original agreement.

A data collection platform (DCP) was installed in May of 1992 to monitor the reservoir elevation and outflow at Box Butte Dam. A telephone (primary communication system) and a radio (backup communication system) have been installed at the outlet works for contacting the Region 23 Emergency Management Agency.

#### 2004 Summary

The flows of the Niobrara River plus the carry-over storage in Box Butte Reservoir were not adequate to provide a full water supply for the project lands. Precipitation at the Mirage Flats Irrigation District Office totaled 16.15 inches, which is 94 percent of normal. The 2004 total inflow of 12,527 AF was below the dry-year forecast and the second lowest ever recorded at Box Butte Reservoir.

From mid July through early September, diversions of 8,553 AF to the Mirage Flats Canal provided irrigation water for approximately 11,092 acres, 95 percent of the service available acreage. The farm deliveries from the project water supply totaled 3,490 AF (0.31 acre-foot per irrigable acre), which is a delivery efficiency of 41 percent. Total reservoir storage was only 3,479 AF at the end of the irrigation season. Privately owned irrigation wells supplemented the project water supply.

The Standing Operating Procedures (SOP) for Box Butte Dam was updated and republished in May 2004.

An orientation meeting to review the Box Butte Dam EAP took place in May 2004 and a Comprehensive Facility Review of Box Butte Dam was conducted in August.

The Mirage Flats Irrigation District continued to implement water conservation measures as outlined in their Water Management Plan and their Long Range Plan. The district continued to

assist irrigators with delivery improvements that provide on-farm efficiency improvements, such as relocation of turnouts, burying pipe for better access, and on-farm efficiency incentives. The district continues to modify and update their computer software to improve system operations, scheduling, and accounting and continued development of their web page that allows irrigators to place water orders, review water accounts, and keep updated on district operations. The district continues to develop and expand on the canal automation and remote monitoring system.

### 2005 Outlook

The project water supply is expected to be inadequate in 2005 as it has been since the early 1960's. In the spring, the district will inform their water users of the amount of water that will be available from storage in Box Butte Reservoir. The District plans for the irrigators to continue the use of water from privately-owned irrigation wells as a supplemental supply.

A tabletop exercise of the Box Butte Dam EAP is scheduled for August 2005. On-site dam operator training is also scheduled to take place in 2005.

In 2005, the District will be installing additional canal lining on the upper end of the Mirage Flats Canal. This will extend the 1.0 mile canal lining section an additional 0.5 miles. The District's future water conservation plans include the automation of Dunlap Diversion Dam and the outlet works gate at Box Butte Dam. The District is also investigating the installation of an Automated Weather Data Network station that will assist district irrigators with irrigation scheduling. This station would provide real time weather data, soil moisture data and crop ET data.

### Ainsworth Unit, Sandhills Division in Nebraska

#### General

Within the Ainsworth Irrigation District, there are 34,539 acres with service available. The project water supply is provided by storage of Snake River flows in Merritt Reservoir. The reservoir is filled each fall after the irrigation season to elevation 2944.0 feet. This level is approximately two feet below the top of conservation capacity and within the repaired area of soil cement on the upstream face of the dam. The reservoir is regulated to maintain this level until the ice clears each spring. Maintaining the reservoir at this elevation during the winter will help avoid ice damage to the older existing soil cement at lower elevations. Upon ice-out the outlet pipe is drained, inspected, and repaired as necessary. The reservoir will then be rapidly filled to elevation 2946.0 feet to reduce shoreline erosion around the reservoir and minimize sand accumulations on the face of the dam. This filling process generally takes place in April. The reservoir level is maintained until irrigation releases begin to draw on the pool around mid May. A minimum release of 75 cubic feet per second (cfs) should be made to the river during spring filling operations if at all possible. This operation enhances the spring fish spawn. Seepage, pickup and toe drain flow normally result in flows of up to 15 cfs below Merritt Dam. Whenever possible, daily changes in releases to the river should be made in no more than 50 cfs increments. This will minimize adverse impacts on the Snake River trout fishery downstream of the dam.

The district has a basic water supply. If available, additional water can be purchased by the district as a supplemental supply.

## 2004 Summary

Precipitation, as recorded near Merritt Dam, totaled 24.21 inches, which was 120 percent of normal. February precipitation was the highest on record for the month. The inflow for the year totaled 180,572 AF. This inflow was between the dry- and normal-year forecasts. The water supply was more than adequate to meet the project's irrigation requirement. There were 84,275 AF diverted from Merritt Reservoir into Ainsworth Canal, with 54,164 AF delivered to the farm headgates (delivery efficiency of 64 percent). There were 34,031 acres of land irrigated in 2004.

The district executed several temporary water service contracts which provided a total of 552 AF of irrigation water from holding ponds located within the district's service area.

An orientation meeting to review the Merritt Dam EAP and on-site dam operator training took place in May 2004.

## 2005 Outlook

During the winter months, the reservoir will be regulated to maintain elevation 2944.0 feet (2.0 feet below the top of conservation capacity). In order to alleviate erosive action to the lands around the reservoir and to maximize all benefits associated with the reservoir, releases from Merritt Reservoir will be regulated to fill the conservation capacity during the early spring. This filling generally takes place during April. The reservoir level will be maintained from the end of April until irrigation releases begin. If weather conditions or irrigation demands dictate, it may be necessary to begin filling the reservoir prior to this time. The water supply is expected to be adequate in 2005 for the irrigation of 34,539 acres.

The process of renewing the long term water service contract with Ainsworth Irrigation District will begin in the spring of 2005. The district is currently working to secure a four year extension to their existing water service contract. The existing contract will expire December 31, 2006.

New Area-Capacity Tables for Merritt Reservoir will become effective on January 1, 2005. These revised tables resulted from a sedimentation survey conducted in June, 2003.

A functional exercise of the Merritt Dam EAP is scheduled for 2005.

The Standing Operating Procedures for Merritt Dam is scheduled to be republished in 2005.

The Ainsworth Irrigation District, along with reclamation, the University of Nebraska Extension Service, and the local Natural Resource Districts, are planning on beginning an irrigation scheduling/nitrogen management demonstration that would educate and improve irrigation management in the area. Initially the plan would include one sprinkler demonstration site and one furrow irrigated site.

## North Loup Division in Nebraska

### General

The North Loup Division is located in the Loup River drainage basin. Water is diverted from both the Calamus and North Loup Rivers for the irrigation of approximately 55,000 acres of



project lands. Operation of the division will also provide a sustained groundwater supply for an additional 17,000 acres. Principal features of the division include Virginia Smith Dam and Calamus Reservoir, Calamus Fish Hatchery, Kent Diversion Dam, Davis Creek Dam and Reservoir, five principal canals, one major and one small pumping plant and numerous open ditch and buried pipe laterals.

Calamus Reservoir is normally regulated at three to four feet below the top of conservation capacity during the winter months. Maintaining the reservoir at this elevation during the winter will help avoid ice damage to the soil cement on the upstream face of the dam. After the ice clears in the spring, the reservoir will be filled to conservation capacity. The North Loup Division project operation is restricted to no water diversions from the Calamus and North Loup Rivers during the months of July and August, and also during the month of September whenever sufficient water is available in storage reservoirs to deliver canal design capacity. During this time, inflows to Calamus Reservoir are required to be bypassed under the Power Interference Agreement between Reclamation, the Twin Loups Reclamation District, and the Loup River Public Power District and as required in the authorizing legislation.

Davis Creek Reservoir will be regulated near elevation 2048.0 feet following the irrigation season and throughout the winter months. This carry-over elevation provides a minimal recreational pool while reducing increases in groundwater storage due to reservoir seepage. The reservoir is filled via Mirdan Canal, starting in April and reaching full content by the end of June. A 160-acre recreation area adjoining the reservoir was constructed and is managed by the Lower Loup Natural Resources District. The area includes a boat ramp, a handicapped fishing pier, a day-use area, a primitive camping area, shelter and a hiking path. Kent Diversion Dam is also open to day-use fishing with handicapped accessibility provided.

#### 2004 Summary

Precipitation at Virginia Smith Dam was 20.86 inches which is 88 percent of normal. The inflow totaled 249,768 AF which was between the dry- and normal-year forecasts. There were 84,616 AF of water released into Mirdan Canal and 26,842 AF diverted through Kent Canal from the North Loup River. A total of 51,880 AF was diverted for district use above Davis Creek Reservoir. The farm headgate delivery was 28,343 AF which is a delivery efficiency of 55 percent. Land irrigated in 2004 totaled 33,932 acres above Davis Creek Reservoir. Reservoir inflows were bypassed during July, August, and September as required. The reservoir elevation at the end of the year was at 2238.37 feet. The Calamus Fish Hatchery used bypassed natural flows and storage from Calamus Reservoir totaling 7,091 AF during 2004.

The precipitation of 20.58 inches near Davis Creek Dam was 87 percent of normal. Inflow to Davis Creek Reservoir totaled 51,783 AF during 2004. Beginning in mid April, Davis Creek Reservoir was filled from an elevation of approximately 2048.5 feet to a peak elevation of 2075.97 feet on June 28<sup>th</sup> using diversions from the North Loup River and Calamus Reservoir. A release of 43,729 AF was made from Davis Creek Dam into Fullerton Canal, with 26,658 AF delivered to the farm headgates (61 percent delivery efficiency). There were 20,847 acres irrigated below Davis Creek Reservoir. The reservoir elevation at the end of 2004 was near the normal wintering level at 2048.63 feet.

On-site dam operator training was conducted in May at Virginia Smith Dam.

An orientation meeting to review the Virginia Smith Dam and Davis Creek Dam EAPs took place in December 2004.

Data collection platforms (DCPs) were installed in the spring of 2004 along the Mirдан Canal system to allow for remote monitoring at key delivery system sites to improve operations, scheduling, and accounting. The newly installed stations include Kent Canal, Mirдан Canal below Virginia Smith Dam, Mirдан Canal above Davis Creek Dam, and Fullerton Canal below Davis Creek Dam. Real-time data from these stations can be found on the Internet by accessing Reclamation's home page.

In December of 2002, the irrigation district reported a small depression along the right side of the river outlet works stilling basin wall at Virginia Smith Dam. Safety of Dams personnel in both Denver and Billings were notified and discussions were conducted with the Technical Service Center. Investigations determined that a problem existed with the under-drain system in the outlet works stilling basin. Gravel material beneath the outlet works chute structure and stilling basin was being transported creating a void. Reclamation personnel drilled holes into the floor of the structure and filled the voids and under-drain system with grout. Grouting was completed in March of 2003. Investigations then began on the under-drain system at the spillway stilling basin because of the similarity to the outlet works system. A risk analysis of the spillway chute and stilling basin under-drain system was completed in September 2003. The risk analysis recommends that the drain system under the spillway basin be grouted. Grouting was originally scheduled to start in October of 2004 but was delayed due to a contract default for construction of bulkheads needed to dewater the basin. Grouting of the drains is expected to begin in September 2005.

### 2005 Outlook

Filling of Calamus Reservoir will continue through late winter and early spring. The reservoir will be allowed to fill to an elevation of 2244.0 feet (top of conservation capacity) by late March or April. This reservoir level will be maintained in order to minimize shoreline erosion until demands begin to draw on the reservoir. Bypasses of inflows will be made during July, August and September. In the fall the reservoir will be filled to an elevation of approximately 2240.0 feet, if possible.

Water will be available for all irrigable acres with service from the Mirдан, Geranium and Scotia Canals and Lateral Systems. It is estimated that approximately 34,000 acres will be irrigated from these canals. Water supplies will be sufficient to meet the full dry-year requirements.

Filling of Davis Creek Reservoir will take place this spring with flows diverted from the North Loup River at Kent Division Dam and transported through Kent and Mirдан Canals. Storage water can also be transferred from Calamus Reservoir into Davis Creek Reservoir during the summer months via Mirдан Canal. Water will be sufficient to irrigate an estimated 20,900 acres from Elba and Fullerton Canals under all inflow forecast conditions. The reservoir level will be regulated to normal winter levels at the end of this season.

The fish hatchery demand for 2005 is expected to be similar to that of the last few years with approximately 7,000 AF passing through the hatchery.

A functional exercise of the EAPs for both Virginia Smith and Davis Creek Dams is scheduled for 2005. The Standing Operating Procedures for both Virginia Smith and Davis Creek Dams are scheduled to be updated and republished this year.

In 2005 the District is planning on expanding the remote monitoring system by installing equipment at various wasteways and key canal measurement sites throughout their delivery system.

## CHAPTER III - REPUBLICAN RIVER BASIN

### Armel Unit, Upper Republican Division in Colorado

#### General

Normal reservoir operations for Bonny Reservoir are primarily for recreation and fish and wildlife support, although water will be available for water right administration and irrigation purposes.

Bonny Reservoir inflows from the South Fork of the Republican River and Landsman Creek are released into Hale Ditch as requested by the Colorado State Engineer. The state will make Bonny storage water available to Hale Ditch and other natural flow appropriators under short-term water service contracts. Most of the 700 acres served by Hale Ditch are now owned and operated by the Division of Wildlife, Colorado Department of Natural Resources.

The normal operation pattern of Bonny Reservoir, with a slowly rising or stable pool, enhances fish spawning in the spring and provides excellent fishing opportunities during the summer and hunting conditions each fall.

Toe drains were added at Bonny Dam in 1988 and 1994 to address Safety of Dams concerns. These drains were constructed to minimize the potential for dam failure due to piping when the reservoir elevation exceeds 3691.0 feet.

#### 2004 Summary

The annual precipitation total of 15.60 inches at Bonny Dam was 90 percent of normal. The annual computed inflow of 5,390 AF to Bonny Reservoir was below the dry-year forecast and the lowest ever recorded at this site. Below normal inflows were recorded during every month of the year. January, February, March, April, and June inflows were the lowest on record for the respective months since first filling. The reservoir level was 15.1 feet below the top of conservation at the first of the year. Due to dry conditions during the first four months of the year, the reservoir level only increased 0.5 foot to a maximum reservoir level of 3657.39 feet on May 6<sup>th</sup>. Bonny Dam recorded a maximum one day precipitation total of 1.34 inches overnight on July 1<sup>st</sup>. The reservoir level gradually decreased throughout the remainder of the year. A new historical low reservoir elevation of 3654.39 feet was recorded on December 23<sup>rd</sup>. The reservoir elevation at the end of the year was 17.6 feet below the top of conservation at 3654.42. The Corps of Engineers determined that \$4,000 in flood prevention benefits were realized from the operation of Bonny Reservoir during 2004.

The Colorado Water Commissioner did not direct reservoir inflows from the South Fork of the Republican River and Landsman Creek to be passed through Bonny Reservoir into Hale Ditch. Likewise, the Colorado Department of Natural Resources did not request storage releases for irrigation purposes into Hale Ditch.

A tabletop exercise of the Bonny Dam EAP took place in April 2004 and the Annual Site Inspection of Bonny Dam was conducted in June.

## 2005 Outlook

Water stored in Bonny Reservoir will be available for sale to Hale Ditch and other private irrigators under short-term water service contracts executed with the state.

Inflows will be stored during the winter until filling of the conservation pool is certain. Releases can be made during this period to maintain a constant reservoir elevation when filling of the reservoir is imminent or if icing were to become a problem.

A Periodic Facility Review of Bonny Dam is scheduled for 2005.

## Frenchman Unit, Frenchman-Cambridge Division in Nebraska

### General

The Culbertson Canal and the Culbertson Extension Canal systems serve 9,295 acres in the Frenchman Valley Irrigation District and 11,695 acres in the H&RW Irrigation District. The water supply for these lands is furnished by flows from Frenchman and Stinking Water Creeks and off-season storage in Enders Reservoir located on Frenchman Creek, a tributary of the Republican River in southwest Nebraska. Irrigation releases are conveyed via Frenchman Creek from Enders Reservoir to Culbertson Diversion Dam. Reclamation maintains/clears this section of Frenchman Creek prior to the irrigation season each spring.

The normal operation of Enders Reservoir, with the gradual rise in water surface during the spring months, provides desirable fish spawning conditions. Irrigation releases will normally deplete the conservation storage by late summer, thereby limiting the fishing and recreational usage.

Construction of a filtered drainage collection pipe and monitoring system in the existing open drain below Enders Dam was completed in the spring of 2002. This Safety of Dams modification was deemed necessary to control seepage and improve the level of safety, ensuring the continuation of project benefits and public safety downstream from the dam. The installation of additional piezometer wells was completed in 1999 and data collection was initiated. Several years of data collection will likely be necessary to better evaluate the need for additional modifications. The need for additional corrective measures was evaluated in conjunction with the 2004 Comprehensive Facility Review, and it was determined that no further risk reduction measures were justified at this time.

## 2004 Summary

The annual precipitation total of 22.77 inches at Enders Dam was above normal (120 percent). The 2004 inflow into Enders Reservoir of 4,876 AF was below the dry-year forecast. This inflow was the lowest ever recorded at the site. Seven of the twelve months recorded record low inflows during 2004. Due to extensive groundwater pumping above the reservoir, the inflow was only eight percent of the average historical preconstruction runoff at the Enders Dam site (60,700 AF from 1929-1947). This year was the 37<sup>th</sup> consecutive year with below-normal inflows in which the conservation pool did not fill. The reservoir level was 26.5 feet below the top of conservation at the first of the year. The reservoir pool gradually increased with late winter and spring inflows peaking at 3087.07 feet (25.2 feet below the top of conservation) on May 1<sup>st</sup>. This was the lowest annual peak since initial filling of the reservoir. Due to the extremely low water

supply available, no water was released from Enders Reservoir. The greatest 24-hour precipitation total recorded during the year at Enders Dam was 1.66 inches overnight on July 22<sup>nd</sup>. July precipitation (7.44 inches) was the greatest precipitation total ever for the month. The end of the year reservoir level was 26.0 feet below the top of conservation. The Corps of Engineers determined that \$5,000 in flood prevention benefits were realized from the operation of Enders Reservoir during 2004.

The Frenchman Valley Irrigation District reports that approximately 2,048 acres received water in 2004 from natural flow diversions from Frenchman Creek. Farm delivery averaged about 0.26 foot per irrigable acre in the Irrigation District. Some farmers were able to supplement their project water supply from private irrigation wells. Farm delivery efficiency was 28 percent for the district. The H&RW Irrigation District did not divert water into Culbertson Extension Canal in 2004 due to the extremely low water supply. This was the third consecutive year that the district did not deliver water. H&RW Irrigation District storage water in Enders Reservoir was carried over into 2005.

In August, a small depression was discovered near the outlet works stilling basin at Enders Dam. An Internal Alert remains in effect until investigations to the cause of the depression are completed. Reclamation has installed instrumentation in the area to collect additional data. Investigations and additional analysis are scheduled in 2005.

A Comprehensive Facility Review of Enders Dam was conducted in 2004 and repairs and resurfacing of the spillway bridge deck was completed.

An orientation meeting to review the Enders Dam EAP took place in July and a tabletop exercise of the EAP was conducted in October.

The spillway stilling basin was lowered to facilitate the investigation of the small depression found near the outlet works. A total of 76 AF was conserved by pumping back seepage into the reservoir that was collected in the spillway stilling basin.

In 2004, the district (along with Reclamation) again provided support for a Limited Irrigation Demonstration Project with the University of Nebraska Extension Service. The demonstration site was located just east of Culbertson and demonstrated various irrigation strategies with a short water supply.

### 2005 Outlook

The fall and early winter inflows into Enders Reservoir were below the dry-year forecast. If reasonable minimum inflow conditions prevail, the project water supply is expected to experience a shortage of about 78,300 AF. Most probable inflow conditions are expected to be inadequate by 49,500 AF and reasonable maximum inflow conditions by 17,500 AF, to irrigate the 9,295 acres in the Frenchman Valley Irrigation District and 11,695 acres in the H&RW Irrigation District. Approximately 2,000 AF can be conserved by pumping seepage water back into Enders Reservoir.

On-site dam operator training will be conducted at Enders Dam in 2005.

The District will continue to support the Limited Irrigation Demonstration project in 2005. The District has also expressed an interest in replacement of additional open ditch laterals with buried pipe that will be investigated in 2004. Future piping projects are somewhat limited due to the water supply shortage. The District will also participate in a study initiated by the Nebraska Department of Natural Resources to investigate preferred alternatives as to the most efficient use of the declining water supply in the basin.

## Meeker-Driftwood, Red Willow, and Cambridge Units, Frenchman-Cambridge Division in Nebraska

### General

During the spring months, Swanson, Hugh Butler, and Harry Strunk Lakes normally have a rising or stable pool which enhances the spawning of northern pike and walleye. These lakes provide excellent opportunities for fishing, water sports, and recreation.

Service is provided for Frenchman-Cambridge Irrigation District by Meeker-Driftwood Canal to 16,562 acres; Red Willow Canal to 4,877 acres; Bartley Canal to 6,435 acres; and Cambridge Canal to 17,297 acres. The water supply for these lands is provided by storage in Swanson, Hugh Butler, and Harry Strunk Lakes, and inflows of the Republican River and Red Willow and Medicine Creeks. The Frenchman-Cambridge Irrigation District has replaced all of the open laterals which were physically or economically feasible with pipe laterals which has significantly increased both system and on-farm efficiencies.

### 2004 Summary

The annual precipitation total of 28.43 inches at Trenton Dam was 142 percent of normal, the third greatest annual precipitation total ever recorded. The inflow of 12,714 AF to Swanson Lake was well below the dry-year forecast. This was the lowest annual computed inflow ever recorded at the lake exceeding the previous low by nearly 1,700 AF. The inflow was below normal for all twelve months. Precipitation during July (10.94 inches) was the greatest ever recorded at the dam for the month. The reservoir level began the year approximately 24.2 feet below the top of conservation pool. The reservoir level gradually increased during the spring and summer and peaked at 2730.20 feet on July 26<sup>th</sup> (approximately 21.8 feet below full). This was the lowest annual peak since first filling of the reservoir. Due to the extremely low water supply available, no water was released from Swanson Lake. Irrigation diversions were not made into Meeker-Driftwood or Bartley Canals. This was the second consecutive year that the district did not deliver water from the two canals. At the end of the year the reservoir level was 22.5 feet below the top of conservation at 2729.49 feet. The Corps of Engineers determined that \$3,000 of flood damages were prevented by the operation of Swanson Lake.

The annual precipitation total of 21.70 inches at Red Willow Dam was 110 percent of normal. The greatest precipitation event recorded at Red Willow Dam in 2004 was 1.36 inches overnight on July 4<sup>th</sup>. Precipitation during July totaled 6.58 inches, the second highest ever recorded for the month. The annual inflow of 9,632 AF into Hugh Butler Lake was below the dry-year forecast and the second lowest ever recorded at the site. The computed inflow for eleven of the twelve months was below normal. February, March, May, and June computed inflows were the lowest ever recorded for the respective month. The reservoir level at the first of the year was 15.9 feet below the top of conservation. Inflows gradually increased the level of the reservoir to a peak of 2568.80 feet (13.0 feet below full) on August 2<sup>nd</sup>. Releases were not made from Hugh Butler Lake

in 2004 due to the extremely low water supply available. Irrigation diversions were not made into Red Willow Canal for the second consecutive year. The level of Hugh Butler Lake at the end of the year was 13.2 feet below the top of conservation, the fifth lowest end of year storage ever recorded. The Corps of Engineers determined that \$3,000 of flood damages were prevented by the operation of Hugh Butler Lake.

The annual precipitation total of 24.66 inches at Medicine Creek Dam was 120 percent of normal. The inflow of 28,707 AF was below the dry-year forecast and the lowest annual total ever recorded. The computed inflow was below normal during all twelve months with record lows recorded during February, March, October and November. The reservoir level at the beginning of 2004 was 9.5 feet below the top of conservation. The reservoir pool gradually increased into late June peaking at 2363.91 feet on June 29<sup>th</sup> (2.2 foot below full). Medicine Creek Dam recorded over 6 inches of precipitation in July. Irrigation releases began on June 20<sup>th</sup> and were shut off on September 3<sup>rd</sup> with nearly 23,700 AF of water released from the reservoir for irrigation. The Nebraska Department of Natural Resources directed that some reservoir inflow be bypassed into Medicine Creek for livestock watering in 2004. Releases were made from June 1<sup>st</sup> through June 14<sup>th</sup> and again on September 17<sup>th</sup>. The greatest 24-hour precipitation event recorded at Medicine Creek Dam was 1.89 inches overnight on September 28<sup>th</sup>. Harry Strunk Lake was 9.8 feet below the top of conservation at the end of the year. The Corps of Engineers determined that the reservoir prevented \$16,000 in flood damages.

The water supply was limited with 21,964 AF of water diverted to irrigate 15,192 acres of land served by the Cambridge Canal (farm delivery efficiency was 52 percent).

An EAP orientation meeting took place in August of 2004 for Red Willow, Medicine Creek and Trenton Dams. A Comprehensive Facility Review was conducted in October at Trenton and Annual Site Inspections were conducted at Red Willow and Medicine Creek Dams in 2004.

The Standing Operating Procedures for Red Willow and Medicine Creek Dams were republished in 2004.

In 2004, the district (along with Reclamation) continued to provide support for a Limited Irrigation Demonstration Project with the University of Nebraska Extension Service. The demonstration site was located just north of Holbrook and demonstrated various irrigation strategies with a short water supply. The project received water from the Cambridge Canal and a field day was well attended. The district continued working with Reclamation on a remote monitoring program. The program allows the district to remotely monitor wasteways and other key system measurement sites helping improve system operations and accounting.

### 2005 Outlook

Forecasts show that carry-over storage, streamflow gains, plus reasonable minimum inflows for the three lakes supplying the Frenchman-Cambridge Irrigation District will be inadequate to meet the full dry-year irrigation requirement by 43,000 AF. Shortages are not expected under most probable inflow conditions.

The Standing Operating Procedures for Trenton Dam are being updated and are expected to be republished in 2005. On-site dam operator training is also scheduled to take place at Trenton Dam in 2005.



A combined tabletop exercise of the Trenton, Red Willow, and the Medicine Creek Dams' EAPs is scheduled for 2005.

The district plans to support the limited irrigation demonstration again in 2005. The district is also investigating the possibility of replacing the last four miles of Red Willow Canal with buried pipe to eliminate the high loss, high maintenance section of open ditch. The district is also investigating the installation of additional check structures on Cambridge Canal to improve operations.

### Almena Unit, Kanaska Division in Kansas

#### General

Service is available to 5,764 acres in the Almena Irrigation District. The project water supply is provided by Prairie Dog Creek flows and Keith Sebelius Lake storage.

The water service contract for the City of Norton, Kansas, provides for a maximum annual use of 1,600 AF from Keith Sebelius Lake.

#### 2004 Summary

The annual precipitation at Norton Dam totaled 23.11 inches, which is 93 percent of normal. The total inflow of 3,704 AF was between the dry- and normal-year forecasts. The reservoir level was 16.9 feet below the top of conservation on December 31, 2003. Late winter and spring inflows gradually increased the reservoir level to a peak elevation of 2287.99 feet on April 15<sup>th</sup> (16.3 feet below full pool). The greatest 24-hour precipitation event occurred overnight on July 30<sup>th</sup> with 1.71 inches recorded. Approximately 6.9 inches of rain was recorded at the dam during July. Irrigation releases were not made from the reservoir in 2004. Keith Sebelius Lake was 17.9 feet below the top of conservation (2286.38 feet) at the end of the year. The Corps of Engineers determined that the reservoir prevented \$4,000 in flood damages.

The city of Norton used 539 AF of municipal water during 2004.

An Annual Site Inspection was conducted at Norton Dam in May and an orientation meeting to review the Norton Dam EAP took place in September 2004.

A Safety of Dams recommendation was made in 2000 concerning the seepage through the left abutment and around the outlet works house at Norton Dam. Technical Service Center personnel inspected the seepage areas in June 2001 and recommended consideration of monitoring improvement and additional instrumentation. A final issue evaluation report of findings (Technical Memorandum ND-8312-2) in 2003 concluded that the assessed risks for seepage and piping through the foundation in the left abutment falls in the range of "justification to take action to reduce risk." Topographic surveys and additional instrumentation were installed near the outlet works in 2004. Plans and specifications are scheduled to be completed in 2005.

#### 2005 Outlook

In May of 2004, the Kansas Department of Wildlife and Parks and the Almena Irrigation District entered into a Memorandum of Agreement (MOA) to maintain a minimum pool elevation

in the reservoir for two years. The MOA was approved by the irrigators within the district which provides that no water will be released for irrigation below elevation 2288.0 feet.

If 2005 is a dry year without significant runoff producing storms above Keith Sebelius Lake, it is anticipated that the water supply may be inadequate by as much as 24,100 AF. If normal inflow into the lake and normal rainfall over the irrigated area occur in 2005, a shortage of 19,200 AF may be experienced, and if 2005 is a wet year the water supply may be inadequate by as much as 3,600 AF. Requirements for the city of Norton will be met in full in 2005.

A Periodic Facility Review of Norton Dam is scheduled for 2005.

The district will continue to solicit projects to replace open ditch laterals with buried pipe that will reduce seepage losses, lessen maintenance requirements, and provide improvements in on-farm efficiencies will continue. Current potential piping projects the District is investigating include lateral S-2.5 and portions of lateral 7.1.

### Franklin, Superior-Courtland, and Courtland Units, Bostwick Division in Nebraska and Kansas

#### General

Harlan County Lake storage and Republican River flows provide a project water supply for 22,935 acres in the Bostwick Irrigation District in Nebraska, and 13,378 acres in the Kansas-Bostwick Irrigation District No. 2 above Lovewell Reservoir. These flows, together with White Rock Creek flows and Lovewell Reservoir storage, furnish a water supply for 29,122 acres below Lovewell Reservoir in the Kansas-Bostwick Irrigation District.

The lands in the Franklin and Superior-Courtland Units are in the Bostwick Irrigation District in Nebraska. The lands in the Courtland Unit downstream of the Kansas state line are in the Kansas-Bostwick Irrigation District.

In accordance with the off-season flow alternative outlined in Reclamation's final environmental assessment dated December 16, 1983, and amended on November 21, 2002, Harlan County Lake releases will be 10 cfs during the months of December, January, and February, except when the reservoir is at low levels. During water-short years releases for these three months will be either zero or 5 cfs depending on reservoir levels. At the request of the State of Nebraska, releases of 30 cfs for a maximum 5-day period may be made to relieve icing conditions in the river.

Natural gain in streamflow, plus irrigation return flows, and operational bypass at Superior-Courtland Diversion Dam will provide some flow downstream.

The Kansas Department of Wildlife and Parks has requested that the Kansas-Bostwick Irrigation District and Reclamation maintain, when possible, a flow of 20 cfs into Lovewell Reservoir when the Courtland Canal is in operation and the conservation pool is below capacity. This recommended inflow provides excellent fishing around the canal inlet to the reservoir. The seepage below Lovewell Dam into White Rock Creek maintains a small livestream throughout the year.

### 2004 Summary - Bostwick Division - Harlan County Lake Operations

The annual precipitation at Harlan County Dam totaled 22.83 inches of rainfall, which is 100 percent of normal. The 2004 inflow of 25,099 AF was below the dry-year forecast and the lowest ever recorded. The inflow was below normal for all twelve months with record lows recorded during February, March, April, May, June, and October. A release was not required during January, February or December in accordance to the environmental assessment and the annual operating plan.

Harlan County Lake began 2004 approximately 19.4 feet below the top of conservation pool, at 1926.34 feet. Inflows during the first five months of the year slowly increased the reservoir pool to a peak of 1926.96 feet on May 23<sup>rd</sup> (top of conservation pool is elevation 1945.73 feet). Harlan County Dam recorded 1.31 inches of rain overnight on September 22<sup>nd</sup> (the greatest one day total in 2004). Due to the extremely low water supply available, no water was released from Harlan County Lake. This was the first time since deliveries began in the early 50's that irrigation deliveries were not made from the lake. The reservoir level continued to decline throughout the remainder of the year. A new historical low reservoir elevation of 1925.44 was recorded on December 26<sup>th</sup>. The level of Harlan County Lake at the end of 2004 was 1925.44 feet (20.3 feet below the top of conservation). Harlan County Lake prevented \$5,000 of downstream flood damages during 2004 according to the Corps of Engineers.

A total of 14,130 AF (approximately 46 percent of total inflow) was delivered to Lovewell Reservoir through the Courtland Canal.

### 2004 Summary - Bostwick Division - Nebraska

The Bostwick Irrigation District in Nebraska diverted 5,800 AF of natural flows for the irrigation of 3,127 acres on Superior Canal. Farm delivery efficiency averaged 25 percent in the district. Irrigation diversions were not made into Franklin, Naponee, Franklin Pump, or Courtland Canal in Nebraska in 2004.

The district continued to replace open ditch laterals with buried pipe to reduce losses and improve system operations. In 2004 the district again applied a canal sealant on the Superior Canal to reduce seepage losses.

### 2004 Summary - Bostwick Division - Kansas

The 2004 precipitation at Lovewell Dam totaled 30.73 inches, which was 113 percent of normal. Lovewell Reservoir began 2004 with a water surface elevation only 2.6 feet below the top of conservation. Inflows from White Rock Creek and diversion of Republican River flows via Courtland Canal slowly increased the reservoir level to within .9 foot of full pool by mid February. Diversion of Republican River flows into Lovewell Reservoir were discontinued on February 19<sup>th</sup> and resumed March 22<sup>nd</sup>. The diversions combined with inflows from White Rock Creek to fill the reservoir conservation pool on March 29<sup>th</sup> (elevation 1582.6 feet), and in filling the reservoir to an elevation of 1584.20 feet on May 17<sup>th</sup>. Releases were made into the lower Courtland Canal beginning on May 13<sup>th</sup> to season the canal and maintain the reservoir level. A strong storm system stalled out over Lovewell Reservoir on the evening of July 1<sup>st</sup> dropping 2.35 inches of precipitation overnight. The reservoir pool increased 0.4 foot as a result of the storm, peaking at elevation 1584.10 feet (1.5 feet into the flood pool). Lovewell Dam recorded another 2.79 inches of rainfall from July 7<sup>th</sup> through July 9<sup>th</sup>. Runoff from these storms increased the reservoir level to

1584.7 feet with a peak average daily inflow of 650 cfs. A flood release of 200 cfs began on July 5 from Lovewell Dam and was gradually staged down and discontinued on July 19<sup>th</sup>, reducing the pool to elevation 1583.0 feet. Irrigation demands reduced the pool elevation to 1573.02 feet on August 29<sup>th</sup>. The pool elevation was maintained below the spillway crest (elevation 1573.0 feet) until mid December while a construction contract to rehabilitate the spillway and outlet works gates was completed. The reservoir was credited with preventing \$113,000 in flood damages as determined by the Corps of Engineers. Diversions of Republican River natural flows into Lovewell Reservoir continued after the completion of the contract and were maintained throughout the remainder of December. The water surface elevation gradually increased to 1574.30 feet on December 31, 2004 (8.3 feet below the top of active conservation).

The Kansas-Bostwick Irrigation District diverted a total of 33,402 AF to serve 1,107 acres above Lovewell Dam and 23,034 acres below Lovewell Dam. Farm delivery efficiency averaged 47 percent in the district.

A major construction contract was completed at Lovewell Dam in December 2004. It involved the painting of all metal work in the spillway and outlet structure and rehabilitation of the spillway and outlet works gates.

A Comprehensive Facility Review of Lovewell Dam was conducted in September and a tabletop exercise of the Lovewell Dam EAP took place in October.

In 2004 the district continued to replace open ditch laterals with buried pipe. The district and Reclamation also provided assistance to Kansas State University (KSU) for a sprinkler irrigation demonstration located northeast of Courtland, Kansas. Courtland Canal supplies water for this demonstration and a field day was held at the site in the fall. The district is also providing support to KSU for the installation of a sub-surface drip irrigation project. In the fall of 2004, the District began to replace open ditch lateral 41.4 with buried pipe. This project should be completed in the spring of 2005. This project eliminates lateral seepage losses, eliminates a wasteway, and provides on-farm benefits by allowing land owners the opportunity to convert to sprinkler irrigation. The District is also planning on replacing open ditch lateral 48.9 with buried pipe in the spring/fall of 2005.

### 2005 Outlook - Bostwick Division

The storage in Harlan County Lake and Lovewell Reservoir and flows of the Republican River and White Rock Creek may be inadequate by as much as 146,200 AF in meeting the full dry-year irrigation requirement for the Bostwick lands. Under most probable inflow conditions the water supply may be inadequate by up to 30,800 AF.

Diversions from the Republican River via Courtland Canal will continue through the winter and again in early spring to insure that Lovewell Reservoir is filled prior to the irrigation season. Reclamation has submitted a deviation request to the Corps of Engineers that would allow Lovewell Reservoir to be filled to elevation 1584.6 feet (2.0 feet into flood pool) prior to the irrigation season. The additional storage is to be used for irrigation purposes due to persistent drought conditions. The Corps of Engineers allowed the reservoir to be filled to elevation 1584.2 feet prior to the irrigation season in 2004.

In 2005, the Bostwick Irrigation District in Nebraska has adopted incentive based water pricing which will provide incentives to irrigators that use less water.

Both Districts will continue to investigate remote monitoring site installation that will provide system operations improvements and pursue projects that will eliminate sections of open ditch laterals. The Bostwick Irrigation District in Nebraska applied for a Water 2025 challenge grant that would expand the District buried pipe program in 2005-06. Both of the Bostwick Districts also supported a Water 2025 proposal that would automate the gates on Courtland Canal at the Superior-Courtland Diversion Dam.

On-site dam operator training at Lovewell Dam is scheduled for 2005. The Standing Operating Procedures for Lovewell Dam are scheduled to be updated and republished in 2005.

## CHAPTER IV - SMOKY HILL RIVER BASIN

### Kirwin Unit, Solomon Division in Kansas

#### General

The water supply for the 11,465 acres of land in the Kirwin Irrigation District is furnished by Kirwin Reservoir storage and inflows from the North Fork Solomon River and Bow Creek.

The operation of Kirwin Dam and Reservoir affords many opportunities for recreation, fishing, hunting, water sports, fish spawning, and preservation of waterfowl species.

#### 2004 Summary

The annual precipitation total of 21.51 inches at Kirwin Dam was 92 percent of normal. The inflow of 4,009 AF was below the dry-year forecast and the second lowest ever recorded at the site. Kirwin Reservoir was 20.8 feet below the top of conservation pool at the first of the year. The reservoir level gradually increased to a peak elevation of 1708.81 feet (20.4 feet below full) on March 9<sup>th</sup>. Irrigation releases began on June 20<sup>th</sup> and continued through August 20<sup>th</sup> reducing the pool level 6.2 feet. August precipitation (.13 inch) was the lowest ever recorded for the month. During 2004, 7,937 AF was released into Kirwin Canal. The reservoir level continued to gradually decrease following the irrigation season and by the end of the year was at 1702.05 feet (27.2 feet below the top of conservation). The greatest 24-hour precipitation event occurred overnight on July 28<sup>th</sup> with 1.80 inches recorded. The reservoir was credited with preventing \$9,000 in flood damages as determined by the Corps of Engineers.

The water supply was inadequate to meet diversion requirements for Kirwin Canal. A total of 6,464 acres received project water during 2004 with 3,154 AF delivered to farms. Farm delivery efficiency was 40 percent.

Major concrete repairs were performed by Reclamation personnel at the Kirwin Dam spillway. The effort was concentrated on the downstream row of dentates. Additional repairs still need to be completed on the upstream row of spillway blocks. This work will be scheduled in future years.

An Annual Site Inspection of Kirwin Dam was conducted and exercise of the Kirwin Dam EAP took place in March 2004. On-site dam operator training was conducted in January.

The district continued to replace problem sections of open ditch laterals with buried pipe in 2004. The district also replaced a number of smaller laterals by relocating field delivery points which provided on-farm improvements, eliminated the need for lateral maintenance in the areas and improved water accounting with the use of flowmeters. Kirwin Lateral S-8.0 buried pipe project was completed in the spring of 2004. This project improved delivery service and allowed one landowner to convert from furrow to sprinkler irrigation. In the fall of 2004, the District also replaced the remaining open ditch section of lateral 13.1 with buried pipe.

## 2005 Outlook

Carry-over storage and the forecasted inflows in the North Fork of the Solomon River are expected to be inadequate to irrigate district lands. Under dry-year forecasted inflows a shortage of about 27,900 AF may be experienced. A shortage of 9,100 AF may be expected under normal-year inflows.

A Periodic Facility Review of Kirwin Dam is scheduled for 2005. The Standing Operating Procedures (SOP) is scheduled to be updated and republished this year.

The District is currently not planning on installing any large lateral projects in 2005 but will continue to solicit interest from project irrigators. Future conservation projects include the possibility of installing remote monitoring equipment at the wasteways and at the Kirwin North/South Canal split. The District is also working with the Nebraska Bostwick Irrigation District for applying spray-on canal sealant in a problem area of Kirwin Canal. Many of the future conservation projects may be delayed due to the declining water supply.

## Webster Unit, Solomon Division in Kansas

### General

The Webster Irrigation District has service available to 8,537 acres. The project water supply is provided by Webster Reservoir storage and flows of the South Fork Solomon River.

### 2004 Summary

In 2004, the precipitation at Webster Dam was 91 percent of normal (21.47 inches). The inflow of 4,033 AF was below the dry-year forecast and the lowest ever recorded at the site. Webster Reservoir began 2004, 21.3 feet (elevation 1871.12 feet) below the top of conservation pool. The reservoir pool gradually increased to a peak elevation of 1871.29 feet (21.2 feet below full) on March 5<sup>th</sup>. Irrigation releases began on July 20<sup>th</sup> and continued through August 19<sup>th</sup> reducing the pool level to 1865.92 feet. August precipitation (.98 inch) was the fourth lowest ever recorded for the month. Approximately 6,932 AF was released for irrigation. Webster Dam received 1.20 inches of rainfall overnight on September 22<sup>nd</sup>, the greatest 24-hour precipitation event during the year. The Corps of Engineers determined that the reservoir prevented \$5,000 in flood damages. The reservoir level continued to decline during the final four months of the year and was 27.2 feet below the top of conservation on December 31, 2004.

The district diverted 4,253 AF for irrigation of 3,145 acres. Farm deliveries totaled 1,569 AF for an efficiency of 37 percent. Project water demands were not met in full.

An Annual Site Inspection of Webster Dam was conducted in May and a tabletop exercise of the Webster Dam EAP took place in July. The Standing Operating Procedures for Webster Dam were updated and republished in 2004.

A special inspection was done on the spillway counterweights at Webster Dam in 2004. Prior facility examinations had documented cracks in the metal supporting the concrete counterweights. The cracking has reached a point where repairs are needed to correct the problem.

The district continued to explore opportunities to cost share with Reclamation and district irrigators for the replacement of open ditch laterals with buried pipe

### 2005 Outlook

The carry-over storage and the flows in the South Fork Solomon River are expected to be inadequate under the dry- and normal-year forecast to irrigate the district lands in 2005. Under dry-year inflows a shortage of 33,700 AF may be experienced. A shortage of 13,000 AF may be expected under normal-year inflows.

A Periodic Facility Review of Webster Dam is scheduled for 2005. Repairs to the Webster Dam spillway counterweights are scheduled for 2005.

The District is currently not planning on installing any large lateral projects in 2005 but will continue to solicit interest from project irrigators. The District is investigating improvements to the water measurement structure between the 2<sup>nd</sup> and 3<sup>rd</sup> sections of Osborne Canal. Future conservation projects include the possibility of installing remote monitoring equipment at the wasteways and at the beginning of the second and third sections of Osborne Canal.

### Glen Elder Unit, Solomon Division in Kansas

#### General

Releases from Waconda Lake will be regulated as outlined in two memorandums of understanding between the State of Kansas and Reclamation. Releases are made for the city of Beloit, the Mitchell County Rural Water District, the long-term water service contract with Glen Elder Irrigation District, and for water right administration.

The water service contract with Beloit, Kansas, provides for the annual use of up to 2,000 AF of Waconda Lake storage. Water is measured at the Glen Elder Dam river outlet works. In any year that the city's water supply is insufficient and there is surplus water in Waconda Lake, such additional water may be released for the city at a rate of \$15.00 per acre-foot.

The water service contract with the Mitchell County Rural Water District No. 2 provides for 1,009 AF of storage water as available from Waconda Lake. Based on the current State of Kansas Certificate of Appropriation, water usage is not to exceed 737 AF per calendar year.

The water service contract with the Glen Elder Irrigation District provides for the use of up to 18,000 AF of storage water each year. Based on the current State of Kansas Certificate of Appropriation, water usage is not to exceed 15,170 AF per calendar year. Water is released and measured through the river outlet works.

The available facilities along the shores of Waconda Lake and the large water surface area afford opportunities to thousands of people for picnics, sightseeing, recreation, water sports, hunting, and fishing.

When compatible with flood control operations, the operating criteria for Waconda Lake provide for a stable or rising pool level during the fish spawning period each spring.



When possible, Waconda Lake will be allowed to fill during the late summer and early fall to flood exposed shoreline vegetation. This flooded aquatic vegetation is very beneficial to waterfowl management.

Waconda Lake will normally be regulated at one to two feet below the top of conservation capacity during the winter months. Maintaining the lake at this level will reduce shoreline erosion, provide a buffer for spring runoff and lessen ice damage to the upstream face of Glen Elder Dam. Releases from Waconda Lake will be regulated each year to maintain a constant water surface level while the lake is ice-covered.

### 2004 Summary

The annual precipitation total of 24.41 inches at Glen Elder Dam was 95 percent of normal. The inflow of 49,217 AF was below the dry-year forecast. Waconda Lake began the year only 4.4 feet below the top of conservation. Dry conditions and minimal inflows prevailed throughout most of the year. The lake level peaked at elevation 1452.19 feet on July 31<sup>st</sup> (3.4 feet below the top of conservation). This was the lowest annual peak since first filling of the reservoir. Irrigation releases began on May 6<sup>th</sup> and continued through September 20<sup>th</sup> reducing the lake level to 1450.75 feet. Glen Elder Dam recorded 3.61 inches of precipitation from July 5<sup>th</sup> through July 9<sup>th</sup>. Runoff from these storms increased the storage in Waconda Lake by over 11,000 AF, with a peak average daily inflow of approximately 2,100 cfs. The Corps of Engineers determined Waconda Lake prevented \$142,000 in flood damages. On December 31, 2004 the lake level was 1450.32 feet (5.3 feet below full). The end of December storage was the lowest ever recorded for the month since initial filling.

A total of 20,853 AF of water was released from Glen Elder Dam in 2004. Storage releases of 6,991 AF combined with natural flow releases of 5,646 AF for the irrigation of 6,535 acres in the Glen Elder Irrigation District. Four individual temporary water service contracts received storage water totaling 289 AF for the irrigation of approximately 274 acres. Storage releases totaling 1,027 AF were made for the City of Beloit, with an additional 6,179 AF bypassed for quality control as directed by the State Water Commissioner. Releases to the Mitchell County Rural Water District No. 2 totaled 721 AF.

An orientation meeting to review the Glen Elder Dam EAP took place in July 2004 and a Comprehensive Facility Review of Glen Elder Dam was conducted in September.

A construction contract was completed for spillway concrete repairs in the Glen Elder Dam spillway. Repairs were completed on the concrete downstream of the spillway drain outlets.

A new perimeter drain system was installed by contract at the Cawker City sewer lagoon in 2004.

### 2005 Outlook

The municipal requirement of Beloit and the requirements of the Mitchell County Rural Water District No. 2 will be met in full with releases as required from Waconda Lake. It is expected that the Kansas Water Commissioner will request that inflows be passed through the lake for water right administration. The Glen Elder Irrigation District estimates that approximately 7,000 acres will be irrigated in 2005. The storage in Waconda Lake and flows in the North and South Forks of the Solomon River will furnish an adequate water supply to the district.

Uncontracted storage water from Waconda Lake will be available to private irrigators in the Solomon Valley below Glen Elder Dam during the 2005 irrigation season. With sufficient inflows the active conservation pool will be allowed to fill prior to the irrigation season. The reservoir will be regulated to maintain a constant level during the winter months when the reservoir is ice-covered to minimize ice damage. Under normal-year conditions, the lake is expected to be maintained at about two feet below the top of the conservation pool during the winter.

The Standing Operating Procedures (SOP) for Glen Elder Dam is scheduled to be updated and republished and on-site dam operator training will be conducted at Glen Elder Dam in 2005.

The Glen Elder Irrigation District continues to try to adjust water ordering policies by adjusting the advance water ordering times in order to improve water releases, making more efficient use of the District's water supply. Some District pumping sites present problems due to river conditions at the sites. In order to minimize required reservoir releases, the District is investigating potential improvements to water pumping sites. The District has also been participating in the Solomon Basin Working Group meetings as part of the State of Kansas' Subbasin Water Resources Management Program. This group is designed to take a proactive approach in developing water management strategies that address declines in stream flows and groundwater levels.

#### Cedar Bluff Unit, Smoky Hill Division in Kansas

##### General

Cedar Bluff Reservoir storage furnishes a maximum of 2,000 AF each year for the City of Russell, Kansas when required. Prior to 1993, Cedar Bluff Reservoir storage and Smoky Hill River flows had provided a water supply for 6,800 acres in the Cedar Bluff Irrigation District. No water had been available for delivery to the district since 1978. Reformulation of the Cedar Bluff Unit in October of 1992 allowed the Cedar Bluff Irrigation District to begin the proceedings to disband, and the Kansas Water Office and Kansas Department of Wildlife and Parks to acquire the use and control of portions of the reservoir conservation capacity. The district completed all activities necessary to accomplish disbandment in 1994. A "designated operating pool" has been established for Cedar Bluff Reservoir and includes the following sub allocation pools: The City of Russell's existing water storage right which remained unchanged (2,700 AF); an artificial recharge pool under control of the Kansas Water Office (5,110 AF); and a fish, wildlife and recreation pool under control of the Kansas Department of Wildlife and Parks (21,061 AF). A "joint-use pool" has been established between the operating pool and the flood control pool for water supply, flood control, environmental and fish, wildlife and recreation purposes. Water rights for the "joint-use pool" are held jointly between the Kansas Department of Wildlife and Parks and the Kansas Water Office. A Contract Administration Memorandum between the United States of America, represented by Reclamation, the State of Kansas and the City of Russell was signed in November/December of 2003, establishing a continuous accounting procedure for water storage in Cedar Bluff Reservoir.

## 2004 Summary

The annual precipitation total at Cedar Bluff Dam was 19.51 inches which is 92 percent of normal. The inflow (10,496 AF) was between the dry- and normal-year forecasts. At the beginning of the year, the level of Cedar Bluff Reservoir was 2137.31 feet (top of active conservation is 2144.00 feet). Dry conditions and minimal inflows prevailed during the late winter and spring months. The peak reservoir level recorded during the year was 2137.32 feet on March 1<sup>st</sup>. Above normal precipitation was recorded during June and July with the greatest 24-hour precipitation event occurring overnight on June 17<sup>th</sup> with 2.99 inches of rainfall. The reservoir gradually decreased throughout the remainder of the year and by December 31, 2004, the reservoir level had decreased to 2134.93 feet (9.1 feet below the top of active conservation). Cedar Bluff Reservoir was estimated to have prevented \$3,000 in flood damages by the Corps of Engineers.

The State of Kansas used the fish hatchery facility located below Cedar Bluff Dam for waterfowl habitat with 227 AF released to the facility. Water was not released from Cedar Bluff Reservoir during 2004 for the City of Russell.

An Annual Site Inspection of Cedar Bluff Dam was conducted in May and an orientation meeting to review the Cedar Bluff Dam EAP took place in October 2004.

## 2005 Outlook

Storage in Cedar Bluff Reservoir on December 31, 2004 was within the joint use pool. The Kansas Department of Wildlife and Parks is expected to use up to 400 AF of water in the operations of the fish hatchery facility. The Kansas Water Office may request a minimal release to the river for recharge in 2005.

A Periodic Facility Review of Cedar Bluff Dam is scheduled in 2005.

TABLE 1  
RESERVOIR DATA - NIOBRARA, LOWER PLATTE AND KANSAS RIVER BASINS  
CAPACITY ALLOCATIONS 1/

		LIVE CONSERVATION			FLOOD CONTROL
RESERVOIR		DEAD	Inactive	Active	
Box Butte	- Elevation Ft.	3969.0	3976.5	4007.0	---
	Total Acre-feet	640	2,275	31,060	---
	Net Acre-feet	640	1,635	28,785	---
Merritt 4/	- Elevation Ft.	2875.0	2896.0	2946.0	---
	Total Acre-feet	774	4,662	66,726	---
	Net Acre-feet	774	3,888	62,064	---
Calamus	- Elevation Ft.	2185.0	2213.3	2244.0	---
	Total Acre-feet	817	24,646	127,400	---
	Net Acre-feet	817	23,829	102,754	---
Davis Creek	- Elevation Ft.	1998.5	2003.0	2076.0	---
	Total Acre-feet	76	172	31,158	---
	Net Acre-feet	76	96	30,986	---
Bonny	- Elevation Ft.	3635.5	3638.0	3672.0	3710.0
	Total Acre-feet	1,418	2,134	41,340	170,160
	Net Acre-feet	1,418	716	39,206	128,820
Enders	- Elevation Ft.	3080.0	3082.4	3112.3	3127.0
	Total Acre-feet	7,516	8,948	42,910	72,958
	Net Acre-feet	7,516	1,432	33,962	30,048
Swanson Lake	- Elevation Ft.	2710.0	2720.0	2752.0	2773.0
	Total Acre-feet	2,118	12,430	112,214	246,291
	Net Acre-feet	2,118	10,312	99,784	134,077
Hugh Butler Lake	- Elevation Ft.	2552.0	2558.0	2581.8	2604.9
	Total Acre-feet	5,185	8,921	36,224	85,070
	Net Acre-feet	5,185	3,736	27,303	48,846
Harry Strunk Lake	- Elevation Ft.	2335.0	2343.0	2366.1	2386.2
	Total Acre-feet	4,160	8,859	35,705	88,420
	Net Acre-feet	4,160	4,699	26,846	52,715
Keith Sebelius Lake	- Elevation Ft.	2275.0	2280.4	2304.3	2331.4
	Total Acre-feet	1,636	3,993	34,510	133,740
	Net Acre-feet	1,636	2,357	30,517	99,230
Harlan County Lake 3/	- Elevation Ft.	1885.0	1927.0	1945.73	1973.5
	Total Acre-feet	0	118,099	314,111	814,111
	Net Acre-feet	0	118,099	196,012	500,000
Lovewell	- Elevation Ft.	1562.07	1571.7	1582.6	1595.3
	Total Acre-feet	1,674	11,644	35,666	86,131
	Net Acre-feet	1,674	9,970	24,022	50,465
Kirwin	- Elevation Ft.	1693.0	1697.0	1729.25	1757.3
	Total Acre-feet	4,969	8,515	98,154	313,290
	Net Acre-feet	4,969	3,546	89,639	215,136
Webster	- Elevation Ft.	1855.5	1860.0	1892.45	1923.7
	Total Acre-feet	1,256	4,231	76,157	259,510
	Net Acre-feet	1,256	2,975	71,926	183,353
Waconda Lake	- Elevation Ft.	1407.8	1428.0	1455.6	1488.3
	Total Acre-feet	248	26,237	219,420	942,408
	Net Acre-feet	248	25,989	193,183	722,988
Cedar Bluff	- Elevation Ft.	2090.0	2107.8	2144.0	2166.0
	Total Acre-feet	4,402	28,574	172,452	364,342
	Net Acre-feet	4,402	24,172	143,878	191,890
Total Storage (A.F.)		36,889	274,340	1,475,207	3,909,611 2/
Total Net Acre-feet		36,889	237,451	1,200,867	2,357,568

1/ Includes space for sediment storage.

2/ Includes total active storage for Box Butte, Merritt, Calamus, and Davis Creek Reservoirs.

3/ Bottom of irrigation pool for Harlan County Lake is 1932.5 feet, 164,111 AF.

4/ New Area-Capacity Tables in effect 1-1-05. Sedimentation survey conducted in June 2003.

TABLE 2  
SUMMARY OF 2004 OPERATIONS  
MIRAGE FLATS PROJECT

BOX BUTTE RESERVOIR					MIRAGE FLATS CANAL		
Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Month Content (AF)	Diversions To Canal (AF)	Delivered To Farms (AF)
Jan.	908	61	61	0.29	7,681	0	0
Feb.	1,234	58	83	0.19	8,774	0	0
Mar.	1,396	61	159	0.57	9,950	0	0
Apr.	1,382	71	276	1.44	10,985	0	0
May	1,179	79	343	1.43	11,742	0	0
June	409	71	450	2.43	11,630	0	0
July	202	4,336	380	2.95	7,116	4,375	1,449
Aug.	708	4,149	252	0.62	3,423	3,989	1,964
Sep.	1,436	121	172	3.95	4,566	189	77
Oct.	1,334	61	145	1.81	5,694	0	0
Nov.	1,165	60	88	0.42	6,711	0	0
Dec.	1,174	61	56	0.05	7,768	0	0
<b>TOTAL</b>	<b>12,527</b>	<b>9,189</b>	<b>2,465</b>	<b>16.15</b>	<b>-</b>	<b>8,553</b>	<b>3,490</b>

NOTE -- Acres irrigated 2004: Mirage Flats Canal - 11,092 acres.

SANDHILLS DIVISION AINSWORTH UNIT MERRITT RESERVOIR					AINSWORTH CANAL		
Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Month Content (AF)	Release To Canal (AF)	Delivered To Farms (AF)
Jan.	14,101	14,132	240	0.20	68,560	0	0
Feb.	14,274	13,140	305	1.33	69,389	0	0
Mar.	16,505	11,833	435	1.83	73,626	0	0
Apr.	13,581	12,841	740	1.67	73,626	0	0
May	14,812	12,978	1,261	3.72	74,199	4,300	330
June	13,416	12,375	1,327	3.91	73,913	6,046	1,044
July	14,798	32,420	1,449	3.38	54,842	29,423	20,106
Aug.	15,007	33,219	916	2.42	35,714	30,530	22,124
Sep.	16,996	16,937	688	3.45	35,085	13,976	10,560
Oct.	17,421	2,690	535	1.31	49,281	0	0
Nov.	16,275	893	395	0.96	64,268	0	0
Dec.	13,386	8,231	313	0.03	69,110	0	0
<b>TOTAL</b>	<b>180,572</b>	<b>171,689</b>	<b>8,604</b>	<b>24.21</b>	<b>-</b>	<b>84,275</b>	<b>54,164</b>

NOTE - Acres irrigated 2004: Ainsworth Canal - 34,031 acres.

NORTH LOUP DIVISION CALAMUS RESERVOIR					ABOVE DAVIS CREEK MIRDAN CANAL				
Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Month Content (AF)	Release to Calamus Fish Hatch. (AF)	Release to Canal (AF)	Canal Use (AF)	Delivered To Farms (AF)
Jan.	20,521	5,839	410	0.00	101,926	343	0	0	0
Feb.	19,233	3,663	562	0.85	116,934	330	0	0	0
Mar.	22,194	19,200	1,046	2.43	118,882	434	0	0	0
Apr.	20,426	10,060	1,745	1.26	127,503	591	0	0	0
May	22,427	20,616	1,862	3.43	127,452	500	5,375	1,116	39
June	21,117	22,143	2,278	3.36	124,148	688	11,831	3,503	1,176
July	22,075	39,943	2,485	1.44	103,795	1,039	23,974	16,051	9,360
Aug.	21,719	41,240	1,911	1.63	82,363	916	25,658	21,948	12,436
Sep.	20,643	32,955	1,168	4.63	68,883	1,009	17,778	9,262	5,332
Oct.	20,048	9,531	1,020	0.22	78,380	569	0	0	0
Nov.	20,242	8,150	601	1.57	89,871	258	0	0	0
Dec.	19,123	7,968	377	0.04	100,649	414	0	0	0
<b>TOTAL</b>	<b>249,768</b>	<b>221,308</b>	<b>15,465</b>	<b>20.86</b>	<b>--</b>	<b>7,091</b>	<b>84,616</b>	<b>51,880</b>	<b>28,343</b>

NOTE -- Acres irrigated 2004: Mirdan Canal - 33,932 acres.

NORTH LOUP DIVISION (Continued) DAVIS CREEK RESERVOIR					BELOW DAVIS CREEK FULLERTON CANAL		
Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Mo. Content (AF)	Release To Canal (AF)	Delivered To Farms (AF)
Jan.	0	216	51	0.00	9,844	0	0
Feb.	49	147	62	1.17	9,684	0	0
Mar.	32	161	109	0.74	9,446	0	0
Apr.	5,160	1,008	198	1.95	13,400	0	0
May	14,586	3,648	300	3.29	24,038	2,279	0
June	13,876	6,460	444	1.88	31,010	4,927	1,555
July	6,826	12,307	445	3.45	25,084	11,163	7,138
Aug.	3,266	18,155	351	1.45	9,844	18,097	13,644
Sep.	7,766	7,535	215	4.47	9,860	7,263	4,321
Oct.	174	95	147	0.62	9,792	0	0
Nov.	45	155	79	1.50	9,603	0	0
Dec.	3	216	45	0.06	9,345	0	0
<b>TOTAL</b>	<b>51,783</b>	<b>50,103</b>	<b>2,446</b>	<b>20.58</b>	<b>-</b>	<b>43,729</b>	<b>26,658</b>

NOTE - Acres irrigated 2004: Fullerton Canal - 20,847 acres.

TABLE 2  
SUMMARY OF 2004 OPERATIONS

UPPER REPUBLICAN DIVISION  
ARMEL UNIT  
BONNY RESERVOIR

Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Month Content (AF)	Outflow To Hale Ditch (AF)
Jan.	352	307	119	0.14	16,652	0
Feb.	636	288	134	0.51	16,866	0
Mar.	646	307	203	0.56	17,002	0
Apr.	1,004	298	438	2.52	17,270	0
May	571	307	656	1.08	16,878	0
June	236	298	645	1.57	16,171	0
July	542	307	674	3.69	15,732	0
Aug.	137	307	598	0.41	14,964	0
Sep.	412	298	682	2.39	14,396	0
Oct.	121	307	250	0.61	13,960	0
Nov.	421	298	211	1.81	13,872	0
Dec.	312	307	123	0.31	13,754	0
TOTAL	5,390	3,629	4,733	15.60	—	0

TABLE 2  
SUMMARY OF 2004 OPERATIONS

FRENCHMAN-CAMBRIDGE DIVISION  
FRENCHMAN UNIT

ENDERS RESERVOIR

Month	End of CULBERTSON CANAL				CULBERTSON EXT. CANAL	
	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	Month Content (AF)	Delivered To Farms (AF)
Jan.	506	184	53	0.43	11,536	0
Feb.	507	173	61	0.39	11,809	0
Mar.	442	184	109	0.59	11,958	741
Apr.	603	179	229	2.32	12,153	1,748
May	404	184	303	1.33	12,070	1,733
June	326	179	349	3.07	11,868	1,309
July	578	184	349	7.44	11,913	1,413
Aug.	44	184	310	0.84	11,463	1,487
Sep.	194	151	282	2.38	11,224	243
Oct.	380	177	138	2.40	11,289	0
Nov.	465	179	119	1.39	11,456	0
Dec.	427	184	67	0.19	11,632	0
<b>TOTAL</b>	<b>4,876</b>	<b>2,142</b>	<b>2,369</b>	<b>22.77</b>	<b>-</b>	<b>8,674</b>

NOTE: Acres irrigated 2004: Culbertson Canal - 2,048 acres; Culbertson Extension Canal - 0 acres.

FRENCHMAN-CAMBRIDGE DIVISION (Continued)  
MEEKER-DRIFTWOOD UNIT

SWANSON LAKE

Month	End of MEEKER-DRIFTWOOD				BARTLEY CANAL	
	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	Month Content (AF)	Delivered To Farms (AF)
Jan.	196	61	157	0.23	26,577	0
Feb.	1,147	58	184	0.42	27,482	0
Mar.	2,082	61	330	1.26	29,173	0
Apr.	1,994	60	758	2.04	30,349	0
May	772	61	1,059	0.80	30,001	0
June	1,081	60	1,114	5.30	29,908	0
July	3,376	61	1,151	10.94	32,072	0
Aug.	0	61	1,218	1.19	30,793	0
Sep.	231	60	1,056	2.55	29,908	0
Oct.	100	61	476	2.02	29,471	0
Nov.	537	60	385	1.63	29,563	0
Dec.	1,198	61	211	0.05	30,489	0
<b>TOTAL</b>	<b>12,714</b>	<b>725</b>	<b>8,099</b>	<b>28.43</b>	<b>--</b>	<b>0</b>

NOTE: Acres irrigated 2004: Meeker-Driftwood Canal - 0 acres; Bartley Canal - 0 acres.

FRENCHMAN-CAMBRIDGE DIVISION (Continued)  
RED WILLOW UNIT

HUGH BUTLER LAKE

Month	End of RED WILLOW CANAL			
	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)
Jan.	791	246	64	0.44
Feb.	814	230	74	0.42
Mar.	980	246	141	1.75
Apr.	1,024	238	390	1.98
May	688	246	547	0.94
June	529	238	562	2.34
July	2,149	246	589	6.58
Aug.	390	246	563	1.82
Sep.	405	238	539	2.82
Oct.	460	246	193	1.31
Nov.	728	238	171	1.26
Dec.	674	246	95	0.04
<b>TOTAL</b>	<b>9,632</b>	<b>2,904</b>	<b>3,928</b>	<b>21.70</b>

NOTE -- Acres irrigated 2004: Red Willow Canal - 0 acres.

FRENCHMAN-CAMBRIDGE DIVISION (Continued)  
CAMBRIDGE UNIT

HARRY STRUNK LAKE

Month	End of CAMBRIDGE CANAL			
	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)
Jan.	2,250	61	82	0.50
Feb.	2,263	58	92	0.37
Mar.	2,742	61	193	2.01
Apr.	2,605	60	582	1.66
May	2,025	61	764	1.30
June	2,037	3,477	872	4.46
July	3,640	8,543	742	6.18
Aug.	2,342	10,612	509	0.51
Sep.	2,078	1,182	468	4.50
Oct.	2,116	61	205	1.24
Nov.	2,331	60	169	1.88
Dec.	2,278	61	95	0.05
<b>TOTAL</b>	<b>28,707</b>	<b>24,297</b>	<b>4,773</b>	<b>24.66</b>

NOTE - Acres irrigated 2004: Cambridge Canal - 15.192 acres.

TABLE 2  
SUMMARY OF 2004 OPERATIONS

KANASKA DIVISION  
ALMENA UNIT  
KEITH SEBELIUS LAKE

Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Month Content (AF)	Release To City Of Norton (AF)	ALMENA CANAL	
							Diversions To Canal (AF)	Delivered To Farms (AF)
Jan.	246	61	60	0.40	9,297	30	0	0
Feb.	270	56	70	0.52	9,441	27	0	0
Mar.	353	63	128	1.26	9,603	33	0	0
Apr.	460	83	377	1.86	9,603	53	0	0
May	392	92	553	1.72	9,350	61	0	0
June	237	91	543	2.15	8,953	61	0	0
July	580	86	529	6.91	8,918	55	0	0
Aug.	161	95	511	1.11	8,473	65	0	0
Sep.	384	88	530	3.89	8,239	58	0	0
Oct.	204	69	218	1.68	8,156	38	0	0
Nov.	270	60	135	1.61	8,231	30	0	0
Dec.	147	59	72	0.00	8,247	28	0	0
<b>TOTAL</b>	<b>3,704</b>	<b>903</b>	<b>3,726</b>	<b>23.11</b>	<b>-</b>	<b>539</b>	<b>0</b>	<b>0</b>

NOTE: Acres irrigated 2004: Almena Canal - 0 acres.

BOSTWICK DIVISION  
FRANKLIN UNIT

HARLAN COUNTY LAKE

Month	Data from Corps of Engineers				End of Month Content (AF)	FRANKLIN CANAL		NAPONEE CANAL	
	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)		Release To Canal (AF)	Delivered To Farms (AF)	Release To Canal (AF)	Delivered To Farms (AF)
Jan.	833	0	468	0.80	113,706	0	0	0	0
Feb.	819	0	460	0.68	114,066	0	0	0	0
Mar.	2,489	0	755	1.99	115,795	0	0	0	0
Apr.	2,638	0	1,989	2.02	116,443	0	0	0	0
May	2,638	0	2,563	2.86	116,731	0	0	0	0
June	1,650	0	4,243	2.30	114,139	0	0	0	0
July	4,354	0	2,780	4.09	114,715	0	0	0	0
Aug.	2,009	0	5,177	1.41	111,546	0	0	0	0
Sep.	3,917	0	6,558	2.63	108,905	0	0	0	0
Oct.	1,993	0	2,818	2.30	108,081	0	0	0	0
Nov.	1,567	0	1,773	1.75	107,874	0	0	0	0
Dec.	192	0	1,017	0.00	107,050	0	0	0	0
<b>TOTAL</b>	<b>25,099</b>	<b>0</b>	<b>30,601</b>	<b>22.83</b>	<b>--</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

NOTE: Acres irrigated 2004: Franklin Canal - 0 acres; Naponee Canal - 0 acres.

BOSTWICK DIVISION (Continued)  
SUPERIOR-COURTLAND UNIT

COURTLAND CANAL - ABOVE LOVEWELL

Month	FRANKLIN PUMP CANAL		SUPERIOR CANAL		Total Diversion (AF)	NEBRASKA USE		KANSAS USE	
	Diverted To Canal (AF)	Delivered To Farms (AF)	Diverted To Canal (AF)	Delivered To Farms (AF)		Total (AF)	Delivered To Farms (AF)	Diversion To Canal (AF)	Delivered To Farms (AF)
Jan.	0	0	0	0	4,530	0	0	0	0
Feb.	0	0	0	0	2,350	0	0	0	0
Mar.	0	0	0	0	1,950	0	0	0	0
Apr.	0	0	0	0	5,439	0	0	0	0
May	0	0	554	0	3,910	0	0	0	0
June	0	0	1,961	241	1,302	0	0	0	0
July	0	0	2,077	711	1,779	0	0	280	43
Aug.	0	0	1,015	456	186	0	0	186	11
Sep.	0	0	193	49	525	0	0	0	0
Oct.	0	0	0	0	2,557	0	0	2,536	0
Nov.	0	0	0	0	3,204	0	0	266	90
Dec.	0	0	0	0	3,769	0	0	0	0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>5,800</b>	<b>1,457</b>	<b>31,501</b>	<b>0</b>	<b>0</b>	<b>3,268</b>	<b>144</b>

NOTE: Acres irrigated 2004: Franklin Pump Canal - 0 acres; Superior Canal - 3,127 acres.  
Courtland Canal-Nebraska use - 0 acres.  
Courtland Canal-Kansas use - 1,107 acres.

BOSTWICK DIVISION (Continued)  
COURTLAND UNIT

LOVEWELL RESERVOIR

Month	Est. Flow from White Rock Creek (AF)	Inflow from Courtland 34.8 (AF)	Total Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of Month Content (AF)	COURTLAND (Below)	
								Release To Canal (AF)	Delivered To Farms (AF)
Jan.	364	2,685	3,049	12	150	0.94	31,245	0	0
Feb.	912	1,398	2,310	12	190	0.76	33,353	0	0
Mar.	1,904	1,128	3,032	12	378	3.79	35,995	0	0
Apr.	1,281	3,776	5,057	18	974	1.47	40,060	0	0
May	955	2,150	3,105	1,014	1,285	4.58	40,866	982	0
June	883	104	987	1,349	1,366	5.00	39,138	1,417	0
July	6,848	230	7,078	13,730	1,351	7.44	31,135	9,713	4,043
Aug.	2,320	0	2,320	19,042	884	2.09	13,529	18,022	11,413
Sep.	251	0	251	18	747	2.62	13,015	0	0
Oct.	39	0	39	12	343	1.20	12,699	0	0
Nov.	188	831	1,019	12	242	0.80	13,464	0	0
Dec.	746	1,828	2,574	12	122	0.04	15,904	0	0
<b>TOTAL</b>	<b>16,691</b>	<b>14,130</b>	<b>30,821</b>	<b>35,243</b>	<b>8,032</b>	<b>30.73</b>	<b>--</b>	<b>30,134</b>	<b>15,456</b>

NOTE: Acres irrigated 2004: Courtland Canal below Lovewell - 23,034 acres.



TABLE 2  
SUMMARY OF 2004 OPERATIONS

SOLOMON DIVISION  
KIRWIN UNIT

KIRWIN RESERVOIR

Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of	KIRWIN CANAL	
					Month Content (AF)	Release To Canal (AF)	Delivered To Farms (AF)
Jan.	142	0	122	0.76	24,595	0	0
Feb.	331	0	155	0.45	24,771	0	0
Mar.	709	0	276	2.63	25,204	0	0
Apr.	579	0	717	1.66	25,066	0	0
May	337	0	1,002	1.21	24,401	0	0
June	378	0	1,004	3.06	23,775	0	0
July	680	2,344	864	5.85	21,247	2,548	594
Aug.	214	5,595	808	0.13	15,058	5,389	2,560
Sep.	365	0	716	2.76	14,707	0	0
Oct.	124	0	245	1.35	14,586	0	0
Nov.	119	0	212	1.57	14,493	0	0
Dec.	31	0	110	0.08	14,414	0	0
<b>TOTAL</b>	<b>4,009</b>	<b>7,939</b>	<b>6,231</b>	<b>21.51</b>	<b>-</b>	<b>7,937</b>	<b>3,154</b>

NOTE: Acres irrigated 2004: Kirwin Canal - 6,464 acres.

SOLOMON DIVISION (Continued)  
WEBSTER UNIT

WEBSTER RESERVOIR

Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of	OSBORNE CANAL	
					Month Content (AF)	Diversions To Canal (AF)	Delivered To Farms (AF)
Jan.	83	0	118	0.45	19,108	0	0
Feb.	223	0	136	1.40	19,195	0	0
Mar.	235	0	253	0.77	19,177	0	0
Apr.	187	0	599	1.11	18,765	0	0
May	364	0	940	1.55	18,189	0	0
June	707	0	959	5.17	17,937	0	0
July	1,350	3,344	817	5.17	15,126	1,621	405
Aug.	81	3,588	789	0.98	10,830	2,632	1,164
Sep.	254	0	797	2.46	10,287	0	0
Oct.	267	0	347	1.72	10,207	0	0
Nov.	205	0	219	0.65	10,193	0	0
Dec.	77	0	117	0.04	10,153	0	0
<b>TOTAL</b>	<b>4,033</b>	<b>6,932</b>	<b>6,091</b>	<b>21.47</b>	<b>--</b>	<b>4,253</b>	<b>1,569</b>

NOTE: Acres irrigated 2004: Osborne Canal - 3,145 acres.

SOLOMON DIVISION (Continued)  
GLEN ELDER UNIT

WACONDA LAKE

OUTFLOW TO RIVER

Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of	City of Beloit			Other Controlled Releases (AF)	Release To Mitchell Co. RWD No. 2 (AF)
					Month Content (AF)	Storage Release (AF)	Quality Bypass (AF)	Irrig. District Storage Release (AF)		
Jan.	1,616	1,189	635	0.43	168,417	0	1,134	0	0	55
Feb.	3,531	916	741	1.47	170,291	0	862	0	0	54
Mar.	6,131	983	1,458	2.48	173,981	0	923	0	0	60
Apr.	3,225	886	3,717	1.41	172,603	0	825	0	0	61
May	3,036	1,475	5,539	1.21	168,625	0	187	111	1,107	70
June	4,155	3,311	5,660	3.53	163,809	0	0	1,644	1,599	68
July	22,053	2,076	4,530	7.56	179,256	29	213	242	1,537	55
Aug.	1,493	4,848	4,982	1.46	170,919	0	0	3,382	1,408	58
Sep.	1,125	2,258	5,572	2.50	164,214	254	42	1,612	284	66
Oct.	962	984	1,996	1.32	162,196	744	178	0	0	62
Nov.	1,123	949	1,575	0.94	160,795	0	893	0	0	56
Dec.	767	978	783	0.10	159,801	0	922	0	0	56
<b>TOTAL</b>	<b>49,217</b>	<b>20,853</b>	<b>37,188</b>	<b>24.41</b>	<b>--</b>	<b>1,027</b>	<b>6,179</b>	<b>6,991</b>	<b>5,935</b>	<b>721</b>

NOTE: Acres irrigated 2004: Glen Elder District - 6,535 acres.

SMOKY HILL DIVISION  
ELLIS UNIT

CEDAR BLUFF RESERVOIR

Month	Inflow (AF)	Outflow (AF)	Gross Evap. (AF)	Precip. (Inches)	End of	Release To Fish Hatchery (AF)
					Month Content (AF)	
Jan.	0	0	740	0.14	129,485	0
Feb.	477	0	477	0.83	129,485	0
Mar.	502	0	899	1.46	129,088	0
Apr.	814	0	2,167	1.18	127,735	0
May	940	0	3,280	0.83	125,395	0
June	3,405	14	3,059	5.14	125,727	14
July	3,044	78	2,911	3.84	125,782	78
Aug.	0	89	3,203	1.28	122,490	89
Sep.	1,038	46	3,362	2.49	120,120	46
Oct.	1	0	1,277	1.44	118,844	0
Nov.	275	0	909	0.85	118,210	0
Dec.	0	0	999	0.03	117,211	0
<b>TOTAL</b>	<b>10,496</b>	<b>227</b>	<b>23,283</b>	<b>19.51</b>	<b>-</b>	<b>227</b>

TABLE 3

## ACRES IRRIGATED IN 2004 AND ESTIMATES FOR 2005

Irrigation District and Canal	Acres With Service Available	Acres Irrigated in 2004	Estimated Acres to be Irrigated in 2005
Mirage Flats Irrigation District			
Mirage Flats Canal	11,662	11,092	11,100
Ainsworth Irrigation District			
Ainsworth Canal	34,539	34,031	34,000
Twin Loups Irrigation District			
Above Davis Creek	33,932	33,932	34,000
Below Davis Creek	20,916	20,847	20,900
Total Twin Loups Irrigation District	54,848	54,779	54,900
Frenchman Valley Irrigation District			
Culbertson Canal	9,295	2,048	2,000
H & RW Irrigation District			
Culbertson Extension Canal	11,695	0	0
Frenchman-Cambridge Irrigation District			
Meeker-Driftwood Canal	16,562	0	0
Red Willow Canal	4,877	0	0
Bartley Canal	6,435	0	0
Cambridge Canal	17,297	15,192	15,000
Total Frenchman-Cambridge Irrigation District	45,171	15,192	15,000
Almena Irrigation District			
Almena Canal	5,764	0	0
Bostwick Irrigation District in Nebraska			
Franklin Canal	11,262	0	0
Naponee Canal	1,628	0	0
Franklin Pump Canal	2,106	0	0
Superior Canal	5,972	3,127	3,100
Courtland Canal (Nebraska)	1,967	0	0
Total Bostwick Irrigation Dist. in Nebraska	22,935	3,127	3,100
Kansas-Bostwick Irrigation District			
Courtland Canal above Lovewell	13,378	1,107	1,100
Courtland Canal below Lovewell	29,122	23,034	23,000
Total Kansas-Bostwick Irrigation District	42,500	24,141	24,100
Kirwin Irrigation District			
Kirwin Canal	11,465	6,464	0
Webster Irrigation District			
Osborne Canal	8,537	3,145	0
Glen Elder Irrigation District	7,000	6,535	6,600
TOTAL PROJECT USES	265,411	160,554	150,800
Non-Project Uses			
Hale Ditch	700	0	700
TOTAL PROJECT AND NON-PROJECT	266,111	160,554	151,500

## BOX BUTTE RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW		EVAPORATION		RELEASE REQUIREMENT		RESERVOIR SPILL	REQUIREMENT SHORTAGE	END OF MONTH ELEV	CONT	RESERVOIR CHANGE
	MEAN CFS	1000 AF	INCHES	1000 AF	MEAN CFS	1000 AF	1000 AF	1000 AF	FT	1000 AF	1000 AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	18	1.1	1.2	0.1	2	0.1	0.0	0.0	3988.1	8.7	0.9
FEB	23	1.3	1.5	0.1	2	0.1	0.0	0.0	3989.4	9.8	1.1
MAR	29	1.8	2.5	0.2	2	0.1	0.0	0.0	3991.1	11.3	1.5
APR	25	1.5	4.1	0.3	2	0.1	0.0	0.0	3992.3	12.4	1.1
MAY	20	1.2	4.9	0.4	5	0.3	0.0	0.0	3992.8	12.9	0.5
JUN	12	0.7	6.1	0.4	119	7.1	0.0	0.0	3984.3	6.1	-6.8
JUL	8	0.5	7.0	0.3	226	13.9	0.0	10.8	3978.9	3.2	-2.9
AUG	13	0.8	6.3	0.2	226	13.9	0.0	13.3	3978.9	3.2	0.0
SEP	15	0.9	4.6	0.2	40	2.4	0.0	1.7	3978.9	3.2	0.0
OCT	18	1.1	3.4	0.1	2	0.1	0.0	0.0	3980.8	4.1	0.9
NOV	22	1.3	1.8	0.1	2	0.1	0.0	0.0	3982.8	5.2	1.1
DEC	18	1.1	1.1	0.1	2	0.1	0.0	0.0	3984.3	6.1	0.9
TOTAL		13.3	44.4	2.5		38.3	0.0	25.8			-1.7
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	21	1.3	1.1	0.1	2	0.1	0.0	0.0	3988.3	8.9	1.1
FEB	29	1.6	1.3	0.1	2	0.1	0.0	0.0	3990.0	10.3	1.4
MAR	37	2.3	2.3	0.2	2	0.1	0.0	0.0	3992.2	12.3	2.0
APR	32	1.9	3.8	0.3	2	0.1	0.0	0.0	3993.7	13.8	1.5
MAY	24	1.5	4.5	0.4	3	0.2	0.0	0.0	3994.6	14.7	0.9
JUN	15	0.9	5.6	0.5	71	4.2	0.0	0.0	3990.7	10.9	-3.8
JUL	11	0.7	6.4	0.4	210	12.9	0.0	4.9	3978.9	3.2	-7.7
AUG	18	1.1	5.7	0.2	164	10.1	0.0	9.2	3978.9	3.2	0.0
SEP	18	1.1	4.2	0.1	29	1.7	0.0	0.7	3978.9	3.2	0.0
OCT	21	1.3	3.1	0.1	2	0.1	0.0	0.0	3981.2	4.3	1.1
NOV	27	1.6	1.7	0.1	2	0.1	0.0	0.0	3983.7	5.7	1.4
DEC	23	1.4	1.0	0.1	2	0.1	0.0	0.0	3985.6	6.9	1.2
TOTAL		16.7	40.6	2.6		29.8	0.0	14.8			-0.9
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	28	1.7	1.0	0.1	2	0.1	0.0	0.0	3988.9	9.3	1.5
FEB	38	2.1	1.2	0.1	2	0.1	0.0	0.0	3991.0	11.2	1.9
MAR	47	2.9	2.1	0.2	2	0.1	0.0	0.0	3993.7	13.8	2.6
APR	42	2.5	3.4	0.3	2	0.1	0.0	0.0	3995.7	15.9	2.1
MAY	33	2.0	4.1	0.4	3	0.2	0.0	0.0	3997.0	17.3	1.4
JUN	18	1.1	5.1	0.5	47	2.8	0.0	0.0	3995.0	15.1	-2.2
JUL	13	0.8	5.8	0.4	135	8.3	0.0	0.0	3986.0	7.2	-7.9
AUG	21	1.3	5.2	0.2	104	6.4	0.0	1.3	3978.9	3.2	-4.0
SEP	24	1.4	3.8	0.1	18	1.1	0.0	0.0	3979.3	3.4	0.2
OCT	28	1.7	2.8	0.1	2	0.1	0.0	0.0	3982.3	4.9	1.5
NOV	35	2.1	1.5	0.1	2	0.1	0.0	0.0	3985.5	6.8	1.9
DEC	29	1.8	0.9	0.1	2	0.1	0.0	0.0	3987.7	8.4	1.6
TOTAL		21.4	36.9	2.6		19.5	0.0	1.3			0.6

MERRITT RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW		EVAPORATION		RELEASE REQUIREMENT			RESERVOIR REQUIREMENT		END OF MONTH RESERVOIR			
	MEAN	1000		1000	CANAL	RIVER	TOTAL	SPILL	SHORTAGE	ELEV	CONT	CHANGE	
	CFS	AF	INCHES	AF	1000	1000	MEAN 1000	1000	1000	FT	1000	1000	
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>													
JAN	224	13.8	1.2	0.3	0.0	1.0	16	1.0	12.8	0.0	2944.0	61.1	-0.3
FEB	247	13.7	1.5	0.3	0.0	1.0	18	1.0	12.4	0.0	2944.0	61.1	0.0
MAR	254	15.6	2.1	0.5	0.0	4.6	75	4.6	7.7	0.0	2945.0	63.9	2.8
APR	259	15.4	3.4	0.8	0.0	4.5	76	4.5	7.3	0.0	2946.0	66.7	2.8
MAY	250	15.4	4.7	1.1	3.3	4.6	128	7.9	6.4	0.0	2946.0	66.7	0.0
JUN	239	14.2	5.9	1.4	7.5	3.0	176	10.5	2.3	0.0	2946.0	66.7	0.0
JUL	239	14.7	6.7	1.3	32.9	3.0	584	35.9	0.0	0.0	2936.5	44.2	-22.5
AUG	246	15.1	5.9	0.8	30.6	3.0	546	33.6	0.0	0.0	2923.9	24.9	-19.3
SEP	242	14.4	4.7	0.5	8.4	3.0	192	11.4	0.0	0.0	2925.9	27.4	2.5
OCT	246	15.1	3.9	0.5	0.0	1.0	16	1.0	0.0	0.0	2934.7	41.0	13.6
NOV	239	14.2	2.2	0.4	0.0	1.0	17	1.0	0.0	0.0	2941.0	53.8	12.8
DEC	223	13.7	1.5	0.3	0.0	1.0	16	1.0	5.1	0.0	2944.0	61.1	7.3
TOTAL		175.3	43.5	8.2	82.7	30.7		113.4	54.0	0.0			-0.3
<b>MOST PROBABLE INFLOW CONDITIONS</b>													
JAN	242	14.9	1.1	0.2	0.0	1.0	16	1.0	14.0	0.0	2944.0	61.1	-0.3
FEB	265	14.7	1.3	0.3	0.0	1.0	18	1.0	13.4	0.0	2944.0	61.1	0.0
MAR	273	16.8	1.9	0.4	0.0	4.6	75	4.6	9.0	0.0	2945.0	63.9	2.8
APR	279	16.6	3.1	0.7	0.0	4.5	76	4.5	8.6	0.0	2946.0	66.7	2.8
MAY	270	16.6	4.2	1.0	2.9	4.6	122	7.5	8.1	0.0	2946.0	66.7	0.0
JUN	257	15.3	5.3	1.3	6.4	3.0	158	9.4	4.6	0.0	2946.0	66.7	0.0
JUL	259	15.9	6.1	1.3	28.1	3.0	506	31.1	0.0	0.0	2939.4	50.2	-16.5
AUG	263	16.2	5.3	0.8	26.3	3.0	477	29.3	0.0	0.0	2932.0	36.3	-13.9
SEP	260	15.5	4.2	0.6	7.2	3.0	171	10.2	0.0	0.0	2934.7	41.0	4.7
OCT	263	16.2	3.5	0.6	0.0	1.0	16	1.0	0.0	0.0	2941.8	55.6	14.6
NOV	257	15.3	2.0	0.4	0.0	1.0	17	1.0	8.4	0.0	2944.0	61.1	5.5
DEC	239	14.7	1.4	0.3	0.0	1.0	16	1.0	13.4	0.0	2944.0	61.1	0.0
TOTAL		188.7	39.3	7.9	70.9	30.7		101.6	79.5	0.0			-0.3
<b>REASONABLE MAXIMUM INFLOW CONDITIONS '</b>													
JAN	257	15.8	1.0	0.2	0.0	1.0	16	1.0	14.9	0.0	2944.0	61.1	-0.3
FEB	283	15.7	1.2	0.3	0.0	1.0	18	1.0	14.4	0.0	2944.0	61.1	0.0
MAR	289	17.8	1.7	0.4	0.0	4.6	75	4.6	10.0	0.0	2945.0	63.9	2.8
APR	296	17.6	2.8	0.7	0.0	4.5	76	4.5	9.6	0.0	2946.0	66.7	2.8
MAY	286	17.6	3.8	0.9	2.3	4.6	112	6.9	9.8	0.0	2946.0	66.7	0.0
JUN	272	16.2	4.8	1.2	5.2	3.0	138	8.2	6.8	0.0	2946.0	66.7	0.0
JUL	273	16.8	5.4	1.2	23.0	3.0	423	26.0	0.0	0.0	2942.1	56.3	-10.4
AUG	280	17.2	4.8	0.9	21.6	3.0	400	24.6	0.0	0.0	2938.4	48.0	-8.3
SEP	276	16.4	3.8	0.7	5.8	3.0	148	8.8	0.0	0.0	2941.5	54.9	6.9
OCT	280	17.2	3.1	0.7	0.0	1.0	16	1.0	9.3	0.0	2944.0	61.1	6.2
NOV	272	16.2	1.8	0.4	0.0	1.0	17	1.0	14.8	0.0	2944.0	61.1	0.0
DEC	255	15.7	1.2	0.3	0.0	1.0	16	1.0	14.4	0.0	2944.0	61.1	0.0
TOTAL		200.2	35.2	7.9	57.9	30.7		88.6	104.0	0.0			-0.3

TABLE 4

## CALANR1S RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW		EVAPORATION		RELEASE REQUIREMENT				RESERVOIR REQUIREMENT		END OF MONTH		RESERVOIR
	MEAN	1000		1000	CANAL	RIVER	TOTAL		SPILL	SHORTAGE	ELEV	CONT	CHANGE
	CFS	AF	INCHES	AF	1000	1000	MEAN	1000	1000	1000	FT	1000	1000
					AF	AF	CFS	AF	AF	AF		AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>													
JAN	285	17.5	1.3	0.5	0.5	3.1	59	3.6	0.0	0.0	2241.3	114.0	13.4
FEB	303	16.8	1.6	0.6	0.5	2.8	59	3.3	9.5	0.0	2242.0	117.4	3.4
MAR	337	20.7	2.9	1.2	0.5	3.1	59	3.6	15.9	0.0	2242.0	117.4	0.0
APR	348	20.7	4.7	2.0	0.5	3.0	59	3.5	5.2	0.0	2244.0	127.4	10.0
MAY	385	23.7	4.9	2.1	2.7	3.1	94	5.8	15.8	0.0	2244.0	127.4	0.0
JUN	351	20.9	6.0	2.5	5.6	3.0	145	8.6	9.8	0.0	2244.0	127.4	0.0
JUL	329	20.2	6.8	2.6	35.7	20.2	909	55.9	0.0	0.0	2235.6	89.1	-38.3
AUG	311	19.1	7.0	2.1	28.9	19.1	781	48.0	0.0	0.0	2226.9	58.1	-31.0
SEP	294	17.5	5.3	1.3	6.6	17.5	405	24.1	0.0	0.0	2224.2	50.2	-7.9
OCT	291	17.9	3.9	1.0	0.5	3.1	59	3.6	0.0	0.0	2228.6	63.5	13.3
NOV	316	18.8	2.1	0.6	0.5	3.0	59	3.5	0.0	0.0	2232.8	78.2	14.7
DEC	307	18.9	1.2	0.4	0.5	3.1	59	3.6	0.0	0.0	2236.6	93.1	14.9
TOTAL		232.7	47.7	16.9	83.0	84.1		167.1	56.2	0.0			-7.5
<b>MOST PROBABLE INFLOW CONDITIONS</b>													
JAN	322	19.8	1.2	0.5	0.5	3.1	59	3.6	0.0	0.0	2241.8	116.3	15.7
FEB	346	19.2	1.4	0.6	0.5	2.8	59	3.3	14.2	0.0	2242.0	117.4	1.1
MAR	382	23.5	2.6	1.0	0.5	3.1	59	3.6	18.9	0.0	2242.0	117.4	0.0
APR	395	23.5	4.2	1.7	0.5	3.0	59	3.5	8.3	0.0	2244.0	127.4	10.0
MAY	439	27.0	4.3	1.8	2.3	3.1	88	5.4	19.8	0.0	2244.0	127.4	0.0
JUN	400	23.8	5.3	2.2	4.6	3.0	128	7.6	14.0	0.0	2244.0	127.4	0.0
JUL	374	23.0	6.0	2.4	27.5	23.0	821	50.5	0.0	0.0	2237.6	97.5	-29.9
AUG	353	21.7	6.2	2.0	19.4	21.7	668	41.1	0.0	0.0	2232.2	76.1	-21.4
SEP	333	19.8	4.7	1.4	5.7	19.8	429	25.5	0.0	0.0	2230.3	69.0	-7.1
OCT	332	20.4	3.4	1.0	0.5	3.1	59	3.6	0.0	0.0	2234.5	84.8	15.8
NOV	360	21.4	1.9	0.6	0.5	3.0	59	3.5	0.0	0.0	2238.7	102.1	17.3
DEC	348	21.4	1.1	0.4	0.5	3.1	59	3.6	11.5	0.0	2240.0	108.0	5.9
TOTAL		264.5	42.1	15.6	63.0	91.8		154.8	86.7	0.0			7.4
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>													
JAN	369	22.7	1.0	0.4	0.5	3.1	59	3.6	1.9	0.0	2242.0	117.4	16.8
FEB	393	21.8	1.3	0.5	0.5	2.8	59	3.3	18.0	0.0	2242.0	117.4	0.0
MAR	439	27.0	2.3	0.9	0.5	3.1	59	3.6	22.5	0.0	2242.0	117.4	0.0
APR	454	27.0	3.7	1.5	0.5	3.0	59	3.5	12.0	0.0	2244.0	127.4	10.0
MAY	501	30.8	3.8	1.6	1.9	3.1	81	5.0	24.2	0.0	2244.0	127.4	0.0
JUN	459	27.3	4.6	2.0	3.8	3.0	114	6.8	18.5	0.0	2244.0	127.4	0.0
JUL	429	26.4	5.3	2.2	16.2	26.4	693	42.6	0.0	0.0	2240.2	109.0	-18.4
AUG	405	24.9	5.4	2.0	14.2	24.9	636	39.1	0.0	0.0	2236.5	92.8	-16.2
SEP	381	22.7	4.1	1.4	4.8	22.7	462	27.5	0.0	0.0	2235.0	86.6	-6.2
OCT	379	23.3	3.0	1.1	0.5	3.1	59	3.6	0.0	0.0	2239.4	105.2	18.6
NOV	413	24.6	1.6	0.6	0.5	3.0	59	3.5	17.7	0.0	2240.0	108.0	2.8
DEC	400	24.6	0.9	0.4	0.5	3.1	59	3.6	20.6	0.0	2240.0	108.0	0.0
TOTAL		303.1	37.0	14.6	44.4	101.3		145.7	135.4	0.0			7.4

## DAVIS CREEK RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR SPILL 1000	RESERVOIR REQUIREMENT SHORTAGE 1000	END OF MONTH ELEV	CONT 1000	RESERVOIR CHANGE 1000
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	0	0.0	1.2	0.1	5	0.3	0.0	0.0	2047.7	8.9	-0.4
FEB	0	0.0	1.5	0.1	5	0.3	0.0	0.0	2046.8	8.5	-0.4
MAR	0	0.0	2.8	0.1	10	0.6	0.0	0.0	2045.2	7.8	-0.7
APR	166	9.9	4.5	0.2	25	1.5	0.0	0.0	2059.6	16.0	8.2
MAY	239	14.7	4.8	0.3	78	4.8	0.0	0.0	2070.8	25.6	9.6
JUN	240	14.3	5.9	0.5	138	8.2	0.0	0.0	2076.0	31.2	5.6
JUL	207	12.7	6.4	0.6	288	17.7	0.0	0.0	2070.8	25.6	-5.6
AUG	140	8.6	4.9	0.4	268	16.5	0.0	0.0	2061.3	17.3	-8.3
SEP	10	0.6	4.2	0.2	129	7.7	0.0	0.0	2049.8	10.0	-7.3
OCT	0	0.0	3.7	0.2	5	0.3	0.0	0.0	2048.8	9.5	-0.5
NOV	0	0.0	2.0	0.1	5	0.3	0.0	0.0	2048.1	9.1	-0.4
DEC	0	0.0	1.2	0.0	5	0.3	0.0	0.0	2047.5	8.8	-0.3
<b>TOTAL</b>		60.8	42.9	2.8		58.5	0.0	0.0			-0.5
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	0	0	1.2	0	5	0.3	0.0	0.0	2047.9	9.0	-0.3
FEB	0	0	1.4	0.1	5	0.3	0.0	0.0	2047.0	8.6	-0.4
MAR	0	0	2.6	0.1	10	0.6	0.0	0.0	2045.5	7.9	-0.7
APR	129	7.7	4.1	0.2	25	1.5	0.0	0.0	2056.5	13.9	6
MAY	239	14.7	4.4	0.3	67	4.1	0.0	0.0	2069.4	24.2	10.3
JUN	240	14.3	5.5	0.5	114	6.8	0.0	0.0	2076.0	31.2	7
JUL	140	8.6	6.0	0.5	223	13.7	0.0	0.0	2070.8	25.6	-5.6
AUG	49	3	4.5	0.3	207	12.7	0.0	0.0	2059.0	15.6	-10
SEP	10	0.6	3.9	0.2	101	6	0.0	0.0	2049.8	10.0	-5.6
OCT	0	0	3.4	0.1	5	0.3	0.0	0.0	2049.0	9.6	-0.4
NOV	0	0	1.8	0.1	5	0.3	0.0	0.0	2048.3	9.2	-0.4
DEC	0	0	1.1	0	5	0.3	0.0	0.0	2047.7	8.9	-0.3
<b>TOTAL</b>		48.9	39.9	2.4		46.9	0.0	0.0			-0.4
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	0	0.0	1.1	0.0	5	0.3	0.0	0.0	2047.9	9.0	-0.3
FEB	0	0.0	1.4	0.1	5	0.3	0.0	0.0	2047.0	8.6	-0.4
MAR	0	0.0	2.4	0.1	10	0.6	0.0	0.0	2045.5	7.9	-0.7
APR	94	5.6	3.9	0.2	25	1.5	0.0	0.0	2053.0	11.8	3.9
MAY	239	14.7	4.2	0.3	57	3.5	0.0	0.0	2067.7	22.7	10.9
JUN	240	14.3	5.2	0.4	91	5.4	0.0	0.0	2076.0	31.2	8.5
JUL	29	1.8	5.6	0.5	163	10.0	0.0	0.0	2067.5	22.5	-8.7
AUG	20	1.2	4.3	0.3	153	9.4	0.0	0.0	2056.6	14.0	-8.5
SEP	10	0.6	3.7	0.2	74	4.4	0.0	0.0	2049.8	10.0	-4.0
OCT	0	0.0	3.2	0.1	5	0.3	0.0	0.0	2049.0	9.6	-0.4
NOV	0	0.0	1.7	0.1	5	0.3	0.0	0.0	2048.3	9.2	-0.4
DEC	0	0.0	1.0	0.0	5	0.3	0.0	0.0	2047.7	8.9	-0.3
<b>TOTAL</b>		38.2	37.6	2.3		36.3	0.0	0.0			-0.4

**BONNY RESERVOIR OPERATION ESTIMATES - 2005**

MONTH	INFLOW		EVAPORATION		RELEASE REQUIREMENT				RESERVOIR REQUIREMENT		END OF MONTH		RESERVOIR
	MEAN	1000		1000	CANAL	RIVER	TOTAL	SPILL	SHORTAGE	ELEV	CONT	CHANGE	
	CFS	AF	INCHES	AF	1000	1000	MEAN 1000	1000	1000	FT	1000	1000	
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>													
JAN	13	0.8	1.3	0.1	0.0	0.4	7	0.4	0.0	0.0	3654.7	14.1	0.3
FEB	13	0.7	1.4	0.1	0.0	0.4	7	0.4	0.0	0.0	3654.9	14.3	0.2
MAR	13	0.8	2.2	0.2	0.0	0.4	7	0.4	0.0	0.0	3655.0	14.5	0.2
APR	17	1.0	4.6	0.4	0.0	0.4	7	0.4	0.0	0.0	3655.2	14.7	0.2
MAY	16	1.0	5.9	0.6	0.4	0.4	13	0.8	0.0	0.0	3654.9	14.3	-0.4
JUN	17	1.0	7.5	0.7	0.3	0.4	12	0.7	0.0	0.0	3654.5	13.9	-0.4
JUL	8	0.5	8.5	0.8	1.0	0.4	23	1.4	0.0	0.0	3653.0	12.2	-1.7
AUG	5	0.3	7.3	0.6	0.6	0.4	16	1.0	0.0	0.0	3651.7	10.9	-1.3
SEP	3	0.2	6.1	0.5	0.3	0.4	12	0.7	0.0	0.0	3650.6	9.9	-1.0
OCT	7	0.4	3.8	0.3	0.2	0.4	10	0.6	0.0	0.0	3650.1	9.4	-0.5
NOV	10	0.6	2.5	0.2	0.0	0.4	7	0.4	0.0	0.0	3650.1	9.4	0.0
DEC	11	0.7	1.5	0.1	0.0	0.4	7	0.4	0.0	0.0	3650.3	9.6	0.2
TOTAL		8.0	52.6	4.6	2.8	4.8		7.6	0.0	0.0			-4.2
<b>MOST PROBABLE INFLOW CONDITIONS</b>													
JAN	21	1.3	1.1	0.1	0.0	0.4	7	0.4	0.0	0.0	3655.1	14.6	0.8
FEB	22	1.2	1.3	0.1	0.0	0.4	7	0.4	0.0	0.0	3655.7	15.3	0.7
MAR	23	1.4	1.9	0.2	0.0	0.4	7	0.4	0.0	0.0	3656.4	16.1	0.8
APR	27	1.6	4.2	0.4	0.0	0.4	7	0.4	0.0	0.0	3657.0	16.9	0.8
MAY	31	1.9	5.3	0.6	0.1	0.4	8	0.5	0.0	0.0	3657.7	17.7	0.8
JUN	27	1.6	6.7	0.7	0.3	0.4	12	0.7	0.0	0.0	3657.8	17.9	0.2
JUL	15	0.9	7.6	0.8	0.7	0.4	18	1.1	0.0	0.0	3657.0	16.9	-1.0
AUG	10	0.6	6.6	0.7	0.6	0.4	16	1.0	0.0	0.0	3656.2	15.8	-1.1
SEP	7	0.4	5.5	0.5	0.3	0.4	12	0.7	0.0	0.0	3655.5	15.0	-0.8
OCT	11	0.7	3.4	0.3	0.1	0.4	8	0.5	0.0	0.0	3655.4	14.9	-0.1
NOV	18	1.1	2.2	0.2	0.0	0.4	7	0.4	0.0	0.0	3655.8	15.4	0.5
DEC	18	1.1	1.3	0.1	0.0	0.4	7	0.4	0.0	0.0	3656.3	16.0	0.6
TOTAL		13.8	47.2	4.7	2.1	4.8		6.9	0.0	0.0			2.2
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>													
JAN	31	1.9	1.0	0.1	0.0	0.4	7	0.4	0.0	0.0	3655.7	15.2	1.4
FEB	32	1.8	1.1	0.1	0.0	0.4	7	0.4	0.0	0.0	3656.7	16.5	1.3
MAR	33	2.0	1.7	0.2	0.0	0.4	7	0.4	0.0	0.0	3657.8	17.9	1.4
APR	40	2.4	3.7	0.4	0.0	0.4	7	0.4	0.0	0.0	3659.0	19.5	1.6
MAY	41	2.5	4.8	0.5	0.2	0.4	10	0.6	0.0	0.0	3660.1	20.9	1.4
JUN	40	2.4	6.0	0.7	0.2	0.4	10	0.6	0.0	0.0	3660.8	22.0	1.1
JUL	21	1.3	6.8	0.8	0.4	0.4	13	0.8	0.0	0.0	3660.6	21.7	-0.3
AUG	13	0.8	5.9	0.7	0.4	0.4	13	0.8	0.0	0.0	3660.1	21.0	-0.7
SEP	8	0.5	4.9	0.6	0.2	0.4	10	0.6	0.0	0.0	3659.6	20.3	-0.7
OCT	16	1.0	3.1	0.4	0.2	0.4	10	0.6	0.0	0.0	3659.6	20.3	0.0
NOV	27	1.6	2.0	0.2	0.0	0.4	7	0.4	0.0	0.0	3660.3	21.3	1.0
DEC	28	1.7	1.2	0.1	0.0	0.4	7	0.4	0.0	0.0	3661.2	22.5	1.2
TOTAL		19.9	42.2	4.8	1.6	4.8		6.4	0.0	0.0			8.7

## ENDERS RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR SPILL 1000	RESERVOIR REQUIREMENT SHORTAGE 1000	END OF MONTH ELEV	CONT	RESERVOIR CHANGE 1000
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	11	0.7	1.0	0.1	3	0.2	0.0	0.0	3086.8	12.0	0.4
FEB	13	0.7	1.1	0.1	4	0.2	0.0	0.0	3087.4	12.4	0.4
MAR	11	0.7	1.9	0.1	3	0.2	0.0	0.0	3087.9	12.8	0.4
APR	12	0.7	4.1	0.3	3	0.2	0.0	0.0	3088.1	13.0	0.2
MAY	11	0.7	5.3	0.3	3	0.2	0.0	0.0	3088.4	13.2	0.2
JUN	12	0.7	6.7	0.4	234	13.9	0.0	9.3	3082.3	8.9	-4.3
JUL	13	0.8	7.3	0.4	533	32.8	0.0	32.4	3082.3	8.9	0.0
AUG	11	0.7	6.1	0.3	540	33.2	0.0	32.8	3082.3	8.9	0.0
SEP	12	0.7	4.5	0.2	72	4.3	0.0	3.8	3082.3	8.9	0.0
OCT	11	0.7	2.9	0.2	3	0.2	0.0	0.0	3082.8	9.2	0.3
NOV	12	0.7	2.1	0.1	3	0.2	0.0	0.0	3083.4	9.6	0.4
DEC	11	0.7	1.2	0.1	3	0.2	0.0	0.0	3084.0	10.0	0.4
TOTAL		8.5	44.0	2.6		85.8	0.0	78.3			-1.6
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	24	1.5	0.9	0.1	3	0.2	0.0	0.0	3087.9	12.8	1.2
FEB	23	1.3	1.0	0.1	4	0.2	0.0	0.0	3089.1	13.8	1.0
MAR	24	1.5	1.7	0.1	3	0.2	0.0	0.0	3090.6	15.0	1.2
APR	25	1.5	3.9	0.3	3	0.2	0.0	0.0	3091.7	16.0	1.0
MAY	24	1.5	4.9	0.4	3	0.2	0.0	0.0	3092.6	16.9	0.9
JUN	25	1.5	6.2	0.4	116	6.9	0.0	0.0	3085.6	11.1	-5.8
JUL	28	1.7	6.8	0.4	483	29.7	0.0	26.2	3082.3	8.9	-2.2
AUG	26	1.6	5.7	0.3	384	23.6	0.0	22.3	3082.3	8.9	0.0
SEP	24	1.4	4.2	0.2	37	2.2	0.0	1.0	3082.3	8.9	0.0
OCT	23	1.4	2.7	0.1	3	0.2	0.0	0.0	3084.0	10.0	1.1
NOV	24	1.4	2.0	0.1	3	0.2	0.0	0.0	3085.6	11.1	1.1
DEC	23	1.4	1.1	0.1	3	0.2	0.0	0.0	3087.1	12.2	1.1
TOTAL		17.7	41.0	2.6		64.0	0.0	49.5			0.6
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	36	2.2	0.8	0.1	3	0.2	0.0	0.0	3088.8	13.5	1.9
FEB	34	1.9	0.9	0.1	4	0.2	0.0	0.0	3090.7	15.1	1.6
MAR	34	2.1	1.6	0.1	3	0.2	0.0	0.0	3092.6	16.9	1.8
APR	35	2.1	3.5	0.3	3	0.2	0.0	0.0	3094.3	18.5	1.6
MAY	36	2.2	4.4	0.4	3	0.2	0.0	0.0	3095.8	20.1	1.6
JUN	35	2.1	5.6	0.5	37	2.2	0.0	0.0	3095.2	19.5	-0.6
JUL	41	2.5	6.1	0.4	296	18.2	0.0	5.5	3082.3	8.9	-10.6
AUG	36	2.2	5.1	0.3	226	13.9	0.0	12.0	3082.3	8.9	0.0
SEP	34	2.0	3.8	0.2	3	0.2	0.0	0.0	3084.7	10.5	1.6
OCT	34	2.1	2.4	0.1	3	0.2	0.0	0.0	3087.2	12.3	1.8
NOV	35	2.1	1.8	0.1	3	0.2	0.0	0.0	3089.5	14.1	1.8
DEC	33	2.0	1.0	0.1	3	0.2	0.0	0.0	3091.5	15.8	1.7
TOTAL		25.5	36.9	2.7		36.1	0.0	17.5			4.2



## SWANSON LAKE OPERATION ESTIMATES- 2005

MONTH	INFLOW		EVAPORATION		RELEASE REQUIREMENT				RESERVOIR REQUIREMENT		END OF MONTH		RESERVOIR
	MEAN 1000		1000		CANAL	RIVER	TOTAL		SPILL	SHORTAGE	ELEV	CONT	CHANGE
	CFS	AF	INCHES	AF	1000 AF	1000 AF	MEAN CFS	1000 AF	1000 AF	1000 AF	FT	1000 AF	1000 AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>													
JAN	29	1.8	1.0	0.2	0.0	0.1	2	0.1	0.0	0.0	2730.1	32.0	1.5
FEB	45	2.5	1.1	0.2	0.0	0.1	2	0.1	0.0	0.0	2731.0	34.2	2.2
MAR	50	3.1	1.9	0.4	0.0	0.1	2	0.1	0.0	0.0	2732.0	36.8	2.6
APR	55	3.3	4.3	1.0	0.0	0.1	2	0.1	0.0	0.0	2732.8	39.0	2.2
MAY	49	3.0	5.1	1.2	0.1	0.1	3	0.2	0.0	0.0	2733.4	40.6	1.6
JUN	39	2.3	6.6	1.5	4.3	1.0	89	5.3	0.0	0.0	2731.8	36.1	-4.5
JUL	21	1.3	7.6	1.4	16.0	3.4	316	19.4	0.0	4.3	2725.0	20.9	-15.2
AUG	11	0.7	6.6	1.1	13.4	6.3	320	19.7	0.0	19.6	2724.8	20.4	-0.5
SEP	5	0.3	5.1	0.8	2.0	2.1	69	4.1	0.0	4.0	2724.5	19.8	-0.6
OCT	8	0.5	3.1	0.5	0.0	0.1	2	0.1	0.0	0.0	2724.4	19.7	-0.1
NOV	20	1.2	2.2	0.4	0.0	0.1	2	0.1	0.0	0.0	2724.8	20.4	0.7
DEC	23	1.4	1.2	0.2	0.0	0.1	2	0.1	0.0	0.0	2725.3	21.5	1.1
TOTAL		21.4	45.8	8.9	35.8	13.6		49.4	0.0	27.9			-9.0
<b>MOST PROBABLE INFLOW CONDITIONS</b>													
JAN	63	3.9	0.9	0.2	0.0	0.1	2	0.1	0.0	0.0	2731.0	34.1	3.6
FEB	99	5.5	1.0	0.2	0.0	0.1	2	0.1	0.0	0.0	2732.9	39.3	5.2
MAR	111	6.8	1.7	0.4	0.0	0.1	2	0.1	0.0	0.0	2735.1	45.6	6.3
APR	123	7.3	4.0	1.0	0.0	0.1	2	0.1	0.0	0.0	2737.1	51.8	6.2
MAY	111	6.8	4.7	1.3	0.1	0.1	3	0.2	0.0	0.0	2738.7	57.1	5.3
JUN	87	5.2	6.1	1.7	3.8	0.1	66	3.9	0.0	0.0	2738.6	56.7	-0.4
JUL	47	2.9	7.0	1.8	13.9	4.2	294	18.1	0.0	0.0	2733.1	39.7	-17.0
AUG	26	1.6	6.1	1.2	11.5	4.1	254	15.6	0.0	0.0	2726.8	24.5	-15.2
SEP	13	0.8	4.7	0.8	1.7	0.1	30	1.8	0.0	0.0	2725.9	22.7	-1.8
OCT	18	1.1	2.8	0.5	0.0	0.1	2	0.1	0.0	0.0	2726.2	23.2	0.5
NOV	47	2.8	2.0	0.4	0.0	0.1	2	0.1	0.0	0.0	2727.2	25.5	2.3
DEC	52	3.2	1.1	0.2	0.0	0.1	2	0.1	0.0	0.0	2728.6	28.4	2.9
TOTAL		47.9	42.1	9.7	31.0	9.3		40.3	0.0	0.0			-2.1
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>													
JAN	99	6.1	0.8	0.2	0.0	0.1	2	0.1	0.0	0.0	2731.8	36.3	5.8
FEB	155	8.6	0.9	0.2	0.0	0.1	2	0.1	0.0	0.0	2734.8	44.6	8.3
MAR	174	10.7	1.6	0.4	0.0	0.1	2	0.1	0.0	0.0	2738.0	54.8	10.2
APR	192	11.4	3.7	1.1	0.0	0.1	2	0.1	0.0	0.0	2740.9	65.0	10.2
MAY	171	10.5	4.3	1.4	0.1	0.1	3	0.2	0.0	0.0	2743.3	73.9	8.9
JUN	138	8.2	5.6	1.9	3.0	0.1	52	3.1	0.0	0.0	2744.1	77.1	3.2
JUL	75	4.6	6.5	2.1	11.4	1.2	205	12.6	0.0	0.0	2741.5	67.0	-10.1
AUG	41	2.5	5.6	1.6	9.4	1.8	182	11.2	0.0	0.0	2738.6	56.7	-10.3
SEP	20	1.2	4.3	1.2	1.4	0.1	25	1.5	0.0	0.0	2738.1	55.2	-1.5
OCT	29	1.8	2.6	0.7	0.0	0.1	2	0.1	0.0	0.0	2738.4	56.2	1.0
NOV	72	4.3	1.9	0.5	0.0	0.1	2	0.1	0.0	0.0	2739.5	59.9	3.7
DEC	80	4.9	1.0	0.3	0.0	0.1	2	0.1	0.0	0.0	2740.8	64.4	4.5
TOTAL		74.8	38.7	11.6	25.3	4.0		29.3	0.0	0.0			33.9

## HUGH BUTLER LAKE OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR REQUIREMENT SPILL 1000		END OF MONTH ELEV		RESERVOIR CHANGE
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	1000 AF	1000 AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	13	0.8	0.9	0.1	5	0.3	0.0	0.0	2569.0	18.8	0.4
FEB	16	0.9	1.0	0.1	5	0.3	0.0	0.0	2569.5	19.3	0.5
MAR	20	1.2	1.8	0.2	5	0.3	0.0	0.0	2570.1	20.0	0.7
APR	18	1.1	4.9	0.5	5	0.3	0.0	0.0	2570.3	20.3	0.3
MAY	20	1.2	5.8	0.6	5	0.3	0.0	0.0	2570.6	20.6	0.3
JUN	20	1.2	7.2	0.7	32	1.9	0.0	0.0	2569.4	19.2	-1.4
JUL	16	1.0	8.0	0.6	148	9.1	0.0	0.7	2561.0	11.2	-8.0
AUG	16	1.0	7.1	0.5	67	4.1	0.0	3.6	2561.0	11.2	0.0
SEP	10	0.6	5.4	0.4	17	1.0	0.0	0.8	2561.0	11.2	0.0
OCT	11	0.7	3.5	0.2	5	0.3	0.0	0.0	2561.2	11.4	0.2
NOV	13	0.8	2.1	0.1	5	0.3	0.0	0.0	2561.7	11.8	0.4
DEC	13	0.8	1.1	0.1	5	0.3	0.0	0.0	2562.2	12.2	0.4
TOTAL		11.3	48.7	4.1		18.5	0.0	5.1			-6.2
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	18	1.1	0.8	0.1	5	0.3	0.0	0.0	2569.3	19.1	0.7
FEB	23	1.3	0.9	0.1	5	0.3	0.0	0.0	2570.1	20.0	0.9
MAR	26	1.6	1.6	0.2	5	0.3	0.0	0.0	2571.0	21.1	1.1
APR	27	1.6	4.4	0.4	5	0.3	0.0	0.0	2571.8	22.0	0.9
MAY	26	1.6	5.3	0.5	5	0.3	0.0	0.0	2572.4	22.8	0.8
JUN	27	1.6	6.5	0.7	25	1.5	0.0	0.0	2572.0	22.2	-0.6
JUL	23	1.4	7.2	0.7	67	4.1	0.0	0.0	2569.0	18.8	-3.4
AUG	23	1.4	6.4	0.6	55	3.4	0.0	0.0	2566.5	16.2	-2.6
SEP	15	0.9	4.9	0.4	15	0.9	0.0	0.0	2566.1	15.8	-0.4
OCT	16	1.0	3.1	0.3	5	0.3	0.0	0.0	2566.5	16.2	0.4
NOV	18	1.1	1.9	0.2	5	0.3	0.0	0.0	2567.1	16.8	0.6
DEC	18	1.1	1.0	0.1	5	0.3	0.0	0.0	2567.8	17.5	0.7
TOTAL		15.7	44.1	4.3		12.3	0.0	0.0			-0.9
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	23	1.4	0.7	0.1	5	0.3	0.0	0.0	2569.5	19.4	1.0
FEB	29	1.6	0.8	0.1	5	0.3	0.0	0.0	2570.6	20.6	1.2
MAR	34	2.1	1.5	0.1	5	0.3	0.0	0.0	2572.0	22.3	1.7
APR	34	2.0	4.0	0.4	5	0.3	0.0	0.0	2573.1	23.6	1.3
MAY	36	2.2	4.8	0.5	5	0.3	0.0	0.0	2574.2	25.0	1.4
JUN	37	2.2	5.9	0.6	20	1.2	0.0	0.0	2574.5	25.4	0.4
JUL	28	1.7	6.6	0.7	50	3.1	0.0	0.0	2572.8	23.3	-2.1
AUG	29	1.8	5.8	0.6	41	2.5	0.0	0.0	2571.8	22.0	-1.3
SEP	18	1.1	4.5	0.4	10	0.6	0.0	0.0	2571.9	22.1	0.1
OCT	20	1.2	2.8	0.3	5	0.3	0.0	0.0	2572.4	22.7	0.6
NOV	24	1.4	1.8	0.2	5	0.3	0.0	0.0	2573.1	23.6	0.9
DEC	23	1.4	0.9	0.1	5	0.3	0.0	0.0	2573.9	24.6	1.0
TOTAL		20.1	40.1	4.1		9.8	0.0	0.0			6.2

## HARRY STRUNK LAKE OPERATON ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR REQUIREMENT SPILL 1000		END OF MONTH ELEV CONT 1000		RESERVOIR CHANGE 1000
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	37	2.3	0.9	0.1	2	0.1	0.0	0.0	2358.0	23.3	2.1
FEB	47	2.6	1.0	0.1	2	0.1	0.0	0.0	2359.8	25.7	2.4
MAR	50	3.1	1.8	0.2	2	0.1	0.0	0.0	2361.8	28.5	2.8
APR	49	2.9	4.9	0.6	2	0.1	0.0	0.0	2363.2	30.7	2.2
MAY	54	3.3	5.7	0.8	2	0.1	0.0	0.0	2364.6	33.1	2.4
JUN	54	3.2	7.2	1.0	87	5.2	0.0	0.0	2362.8	30.1	-3.0
JUL	50	3.1	8.1	0.8	311	19.1	0.0	0.0	2348.6	13.3	-16.8
AUG	41	2.5	7.0	0.5	262	16.1	0.0	9.7	2343.0	8.9	-4.4
SEP	27	1.6	5.4	0.3	27	1.6	0.0	0.3	2343.0	8.9	0.0
OCT	33	2.0	3.5	0.2	2	0.1	0.0	0.0	2345.4	10.6	1.7
NOV	37	2.2	2.1	0.1	2	0.1	0.0	0.0	2347.8	12.6	2.0
DEC	34	2.1	1.1	0.1	2	0.1	0.0	0.0	2350.0	14.5	1.9
TOTAL		30.9	48.6	4.8		42.8	0.0	10.0			-6.7
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	42	2.6	0.8	0.1	2	0.1	0.0	0.0	2358.2	23.6	2.4
FEB	54	3.0	0.9	0.1	2	0.1	0.0	0.0	2360.3	26.4	2.8
MAR	57	3.5	1.6	0.2	2	0.1	0.0	0.0	2362.5	29.6	3.2
APR	57	3.4	4.4	0.6	2	0.1	0.0	0.0	2364.2	32.3	2.7
MAY	62	3.8	5.2	0.8	2	0.1	0.0	0.0	2365.8	35.2	2.9
JUN	62	3.7	6.6	1.0	72	4.3	0.0	0.0	2364.9	33.6	-1.6
JUL	59	3.6	7.4	0.9	259	15.9	0.0	0.0	2355.7	20.4	-13.2
AUG	46	2.8	6.4	0.5	220	13.5	0.0	0.0	2343.4	9.2	-11.2
SEP	30	1.8	4.9	0.3	20	1.2	0.0	0.0	2343.9	9.5	0.3
OCT	37	2.3	3.2	0.2	2	0.1	0.0	0.0	2346.5	11.5	2.0
NOV	42	2.5	1.9	0.1	2	0.1	0.0	0.0	2349.2	13.8	2.3
DEC	39	2.4	1.0	0.1	2	0.1	0.0	0.0	2351.6	16.0	2.2
TOTAL		35.4	44.4	4.9		35.7	0.0	0.0			-5.2
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	59	3.6	0.7	0.1	2	0.1	0.0	0.0	2359.0	24.6	3.4
FEB	76	4.2	0.8	0.1	2	0.1	0.0	0.0	2361.8	28.6	4.0
MAR	80	4.9	1.4	0.2	2	0.1	0.0	0.0	2364.7	33.2	4.6
APR	79	4.7	4.0	0.6	2	0.1	1.5	0.0	2366.1	35.7	2.5
MAY	85	5.2	4.7	0.7	2	0.1	4.4	0.0	2366.1	35.7	0.0
JUN	86	5.1	5.9	0.9	45	2.7	1.5	0.0	2366.1	35.7	0.0
JUL	80	4.9	6.7	0.9	177	10.9	0.0	0.0	2362.0	28.8	-6.9
AUG	63	3.9	5.8	0.7	150	9.2	0.0	0.0	2357.6	22.8	-6.0
SEP	42	2.5	4.4	0.5	2	0.1	0.0	0.0	2359.1	24.7	1.9
OCT	52	3.2	2.9	0.3	2	0.1	0.0	0.0	2361.1	27.5	2.8
NOV	57	3.4	1.7	0.2	2	0.1	0.0	0.0	2363.1	30.6	3.1
DEC	55	3.4	0.9	0.1	2	0.1	0.0	0.0	2365.1	33.8	3.2
TOTAL		49.0	40.0	5.3		23.7	7.4	0.0			12.6

## KEITH SEBELIUS LAKE OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR SPILL 1000	RESERVOIR REQUIREMENT SHORTAGE 1000	END OF MONTH ELEV	CONT 1000	RESERVOIR CHANGE 1000
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	2	0.1	0.9	0.1	2	0.1	0.0	0.0	2286.2	8.1	-0.1
FEB	4	0.2	1.1	0.1	2	0.1	0.0	0.0	2286.2	8.1	0.0
MAR	5	0.3	1.9	0.1	2	0.1	0.0	0.0	2286.3	8.2	0.1
APR	7	0.4	5.3	0.4	2	0.1	0.0	0.0	2286.2	8.1	-0.1
MAY	8	0.5	6.0	0.4	7	0.4	0.0	0.3	2286.2	8.1	0.0
JUN	12	0.7	7.5	0.4	77	4.6	0.0	4.5	2286.4	8.3	0.2
JUL	8	0.5	8.6	0.4	146	9.0	0.0	8.9	2286.4	8.3	0.0
AUG	7	0.4	7.6	0.4	146	9.0	0.0	8.9	2286.3	8.2	-0.1
SEP	3	0.2	5.9	0.3	27	1.6	0.0	1.5	2286.0	8.0	-0.2
OCT	2	0.1	4.0	0.2	2	0.1	0.0	0.0	2285.8	7.8	-0.2
NOV	2	0.1	2.2	0.1	2	0.1	0.0	0.0	2285.7	7.7	-0.1
DEC	2	0.1	1.1	0.1	2	0.1	0.0	0.0	2285.6	7.6	-0.1
TOTAL		3.6	52.1	3.0		25.3	0.0	24.1			-0.6
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	5	0.3	0.8	0.1	2	0.1	0.0	0.0	2286.4	8.3	0.1
FEB	7	0.4	1.0	0.1	2	0.1	0.0	0.0	2286.7	8.5	0.2
MAR	11	0.7	1.7	0.1	2	0.1	0.0	0.0	2287.2	9.0	0.5
APR	12	0.7	4.7	0.3	2	0.1	0.0	0.0	2287.6	9.3	0.3
MAY	18	1.1	5.4	0.4	3	0.2	0.0	0.1	2288.3	9.9	0.6
JUN	22	1.3	6.7	0.5	47	2.8	0.0	2.7	2289.0	10.6	0.7
JUL	16	1.0	7.7	0.5	138	8.5	0.0	8.4	2289.4	11.0	0.4
AUG	15	0.9	6.7	0.3	112	6.9	0.0	6.8	2289.9	11.5	0.5
SEP	7	0.4	5.3	0.3	22	1.3	0.0	1.2	2289.9	11.5	0.0
OCT	3	0.2	3.5	0.2	2	0.1	0.0	0.0	2289.8	11.4	-0.1
NOV	5	0.3	2.0	0.1	2	0.1	0.0	0.0	2289.9	11.5	0.1
DEC	3	0.2	1.0	0.0	2	0.1	0.0	0.0	2290.0	11.6	0.1
TOTAL		7.5	46.5	2.9		20.4	0.0	19.2			3.4
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	10	0.6	0.8	0.1	2	0.1	0.0	0.0	2286.8	8.6	0.4
FEB	14	0.8	0.9	0.1	2	0.1	0.0	0.0	2287.5	9.2	0.6
MAR	23	1.4	1.5	0.1	2	0.1	0.0	0.0	2288.7	10.4	1.2
APR	25	1.5	4.2	0.4	2	0.1	0.0	0.0	2289.8	11.4	1.0
MAY	39	2.4	4.8	0.4	3	0.2	0.0	0.0	2291.4	13.2	1.8
JUN	50	3.0	6.1	0.6	34	2.0	0.0	0.0	2291.7	13.6	0.4
JUL	36	2.2	6.9	0.6	94	5.8	0.0	0.3	2288.0	9.7	-3.9
AUG	33	2.0	6.1	0.4	75	4.6	0.0	3.0	2288.0	9.7	0.0
SEP	15	0.9	4.8	0.3	15	0.9	0.0	0.3	2288.0	9.7	0.0
OCT	8	0.5	3.2	0.2	2	0.1	0.0	0.0	2288.3	9.9	0.2
NOV	10	0.6	1.8	0.1	2	0.1	0.0	0.0	2288.7	10.3	0.4
DEC	8	0.5	0.9	0.1	2	0.1	0.0	0.0	2289.0	10.6	0.3
TOTAL		16.4	41.8	3.4		14.2	0.0	3.6			2.4

HARLAN COUNTY LAKE OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR REQUIREMENT SPILL 1000 AF	RESERVOIR REQUIREMENT SHORTAGE 1000 AF	END OF MONTH	RESERVOIR	
	CFS	AF	INCHES	AF	CFS	AF			ELEV	CONT	CHANGE
									FT	1000 AF	1000 AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	49	3.0	0.9	0.5	0	0.0	0.0	0.0	1925.8	109.6	2.5
FEB	77	4.3	0.9	0.5	0	0.0	0.0	0.0	1926.3	113.4	3.8
MAR	104	6.4	1.7	1.0	0	0.0	0.0	0.0	1927.1	118.8	5.4
APR	89	5.3	4.3	2.7	0	0.0	0.0	0.0	1927.4	121.4	2.6
MAY	114	7.0	5.3	3.3	0	0.0	0.0	0.0	1927.9	125.1	3.7
JUN	94	5.6	6.5	4.1	250	14.9	0.0	8.0	1927.2	119.7	-5.4
JUL	96	5.9	7.3	4.5	758	46.6	0.0	45.2	1927.2	119.7	0.0
AUG	76	4.7	6.3	3.9	610	37.5	0.0	36.7	1927.2	119.7	0.0
SEP	39	2.3	5.0	3.1	61	3.6	0.0	3.6	1927.1	118.9	-0.8
OCT	36	2.2	3.3	2.0	0	0.0	0.0	0.0	1927.1	119.1	0.2
NOV	47	2.8	2.0	1.2	0	0.0	0.0	0.0	1927.3	120.7	1.6
DEC	47	2.9	1.3	0.8	0	0.0	0.0	0.0	1927.6	122.8	2.1
TOTAL		52.4	44.7	27.6		102.6	0.0	93.5			15.7
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	130	8.0	0.8	0.5	0	0.0	0.0	0.0	1926.5	114.6	7.5
FEB	203	11.3	0.8	0.5	0	0.0	0.0	0.0	1928.0	125.4	10.8
MAR	273	16.8	1.5	1.0	0	0.0	0.0	0.0	1929.9	141.2	15.8
APR	235	14.0	3.9	2.8	0	0.0	0.0	0.0	1931.2	152.4	11.2
MAY	294	18.1	4.8	3.6	0	0.0	0.0	0.0	1932.8	166.9	14.5
JUN	247	14.7	5.8	4.6	101	6.0	0.0	0.0	1933.2	171.0	4.1
JUL	250	15.4	6.6	5.0	686	42.2	0.0	5.5	1930.3	144.7	-26.3
AUG	202	12.4	5.7	4.0	433	26.6	0.0	18.2	1930.3	144.7	0.0
SEP	99	5.9	4.6	3.3	37	2.2	0.0	0.0	1930.4	145.1	0.4
OCT	94	5.8	3.0	2.1	0	0.0	0.0	0.0	1930.8	148.8	3.7
NOV	124	7.4	1.8	1.3	0	0.0	0.0	0.0	1931.5	154.9	6.1
DEC	124	7.6	1.1	0.9	0	0.0	0.0	0.0	1932.2	161.6	6.7
TOTAL		137.4	40.2	29.6		77.0	0.0	23.7			54.5
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	259	15.9	0.7	0.5	0	0.0	0.0	0.0	1927.6	122.5	15.4
FEB	405	22.5	0.7	0.5	0	0.0	0.0	0.0	1930.3	144.5	22.0
MAR	543	33.4	1.3	1.0	0	0.0	0.0	0.0	1933.8	176.9	32.4
APR	471	28.0	3.5	2.9	0	0.0	0.0	0.0	1936.3	202.0	25.1
MAY	594	36.5	4.2	3.8	0	0.0	0.0	0.0	1939.3	234.7	32.7
JUN	492	29.3	5.2	5.1	39	2.3	0.0	0.0	1941.2	256.6	21.9
JUL	499	30.7	5.8	5.9	161	9.9	0.0	0.0	1942.4	271.5	14.9
AUG	402	24.7	5.0	5.2	161	9.9	0.0	0.0	1943.2	281.1	9.6
SEP	198	11.8	4.0	4.2	20	1.2	0.0	0.0	1943.7	287.5	6.4
OCT	187	11.5	2.6	2.8	0	0.0	0.0	0.0	1944.4	296.2	8.7
NOV	249	14.8	1.6	1.7	0	0.0	0.0	0.0	1945.4	309.3	13.1
DEC	246	15.1	1.0	1.1	0	0.0	5.6	0.0	1946.0	317.7	8.4
TOTAL		274.2	35.6	34.7		23.3	5.6	0.0			210.6

## LOVEWELL RESERVOIR OPERATION ESTIMATES - 2005

MONTH	WHITE ROCK	COURTLAND	TOTAL		EVAPORATION		RELEASE		RES	REQ	END OF MONTH		RESERVOIR
	CREEK	CANAL	INFLOW	INFLOW	MEAN	1000	MEAN	1000	SPILL	SHORT	ELEV	CONT	CHANGE
	1000	1000	MEAN	1000	1000	1000	MEAN	1000	1000	1000	FT	1000	1000
	AF	AF	CFS	AF	INCHES	AF	CFS	AF	AF	AF		AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>													
JAN	0.5	2.2	44	2.7	0.8	0.1	0	0.0	0.0	0.0	1575.7	18.5	2.6
FEB	0.7	2.5	58	3.2	1.0	0.2	0	0.0	0.0	0.0	1577.1	21.5	3.0
MAR	1.5	3.3	78	4.8	1.8	0.4	0	0.0	0.0	0.0	1579.0	25.9	4.4
APR	1.4	2.3	62	3.7	3.7	0.8	0	0.0	0.0	0.0	1580.1	28.8	2.9
MAY	1.8	2.5	70	4.3	4.7	1.1	16	1.0	0.0	0.0	1581.0	31.0	2.2
JUN	1.9	0.0	32	1.9	6.0	1.2	188	11.2	0.0	0.0	1576.6	20.5	-10.5
JUL	1.3	0.0	21	1.3	6.7	1.0	566	34.8	0.0	25.6	1571.7	11.6	-8.9
AUG	0.1	0.0	2	0.1	5.4	0.7	389	23.9	0.0	23.9	1571.3	11.0	-0.6
SEP	1.0	0.0	17	1.0	4.1	0.5	52	3.1	0.0	3.2	1571.7	11.6	0.6
OCT	0.7	1.9	42	2.6	2.8	0.4	0	0.0	0.0	0.0	1573.1	13.8	2.2
NOV	0.6	2.5	52	3.1	2.1	0.3	0	0.0	0.0	0.0	1574.7	16.6	2.8
DEC	0.4	2.6	49	3.0	1.0	0.2	0	0.0	0.0	0.0	1576.1	19.4	2.8
TOTAL	11.9	19.8		31.7	40.2	6.9		74.0	0.0	52.7			3.5
<b>MOST PROBABLE INFLOW CONDITIONS</b>													
JAN	1.1	3.8	80	4.9	0.7	0.1	0	0.0	0.0	0.0	1576.7	20.7	4.8
FEB	1.6	4.9	117	6.5	0.8	0.2	0	0.0	0.0	0.0	1579.4	27.0	6.3
MAR	3.7	5.4	148	9.1	1.5	0.3	0	0.0	0.0	0.0	1582.6	35.8	8.8
APR	3.4	0.0	57	3.4	3.1	0.8	0	0.0	0.0	0.0	1583.5	38.4	2.6
MAY	4.2	0.0	68	4.2	4.0	1.1	15	0.9	0.0	0.0	1584.2	40.6	2.2
JUN	4.6	5.9	176	10.5	5.0	1.3	155	9.2	0.0	0.0	1584.2	40.6	0.0
JUL	3.1	10.1	215	13.2	5.6	1.3	472	29.0	0.0	0.0	1578.0	23.5	-17.1
AUG	0.4	1.2	26	1.6	4.6	0.7	324	19.9	0.0	7.1	1571.7	11.6	-11.9
SEP	2.5	0.6	52	3.1	3.4	0.4	44	2.6	0.0	0.0	1571.7	11.7	0.1
OCT	1.7	4.7	104	6.4	2.3	0.3	0	0.0	0.0	0.0	1575.3	17.8	6.1
NOV	1.4	4.1	92	5.5	1.8	0.3	0	0.0	0.0	0.0	1577.8	23.0	5.2
DEC	1	4.6	91	5.6	0.8	0.2	0	0.0	0.0	0.0	1580.0	28.4	5.4
TOTAL	28.7	45.3		74.0	33.8	7.0		61.6	0.0	7.1			12.5
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>													
JAN	3.1	0.0	50	3.1	0.6	0.1	0	0.0	0.0	0.0	1575.9	18.9	3.0
FEB	4.7	0.0	85	4.7	0.7	0.1	0	0.0	0.0	0.0	1578.0	23.5	4.6
MAR	10.7	0.0	174	10.7	1.3	0.3	0	0.0	0.0	0.0	1582.0	33.9	10.4
APR	9.7	0.0	163	9.7	2.7	0.7	0	0.0	2.3	0.0	1584.2	40.6	6.7
MAY	12.2	0.0	198	12.2	3.4	0.9	8	0.5	10.8	0.0	1584.2	40.6	0.0
JUN	13.3	1.2	244	14.5	4.3	1.1	87	5.2	8.2	0.0	1584.2	40.6	0.0
JUL	9	1.2	166	10.2	4.8	1.1	265	16.3	7.5	0.0	1579.0	25.9	-14.7
AUG	1.1	1.2	37	2.3	3.9	0.7	179	11.0	0.0	0.0	1574.6	16.5	-9.4
SEP	7.1	0.6	129	7.7	2.9	0.5	24	1.4	0.0	0.0	1577.5	22.3	5.8
OCT	4.8	0.0	78	4.8	2.0	0.4	0	0.0	0.0	0.0	1579.3	26.7	4.4
NOV	4.1	0.0	69	4.1	1.5	0.3	0	0.0	0.5	0.0	1580.6	30.0	3.3
DEC	2.8	0.0	46	2.8	0.7	0.2	0	0.0	2.6	0.0	1580.6	30.0	0.0
TOTAL	82.6	4.2		86.8	28.8	6.4		34.4	31.9	0.0			14.1

## KIRWIN RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR SPILL 1000	RESERVOIR REQUIREMENT SHORTAGE 1000	END OF MONTH ELEV	CONT 1000	RESERVOIR CHANGE 1000
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	3	0.2	0.9	0.1	0	0.0	0.0	0.0	1702.1	14.5	0.1
FEB	7	0.4	1.1	0.1	0	0.0	0.0	0.0	1702.3	14.8	0.3
MAR	10	0.6	1.9	0.2	0	0.0	0.0	0.0	1702.6	15.2	0.4
APR	12	0.7	4.3	0.5	0	0.0	0.0	0.0	1702.8	15.4	0.2
MAY	18	1.1	5.3	0.6	8	0.5	0.0	0.0	1702.8	15.4	0.0
JUN	15	0.9	6.6	0.7	87	5.2	0.0	1.4	1700.0	11.8	-3.6
JUL	15	0.9	7.5	0.7	192	11.8	0.0	11.6	1700.0	11.8	0.0
AUG	10	0.6	6.6	0.7	192	11.8	0.0	11.8	1699.9	11.7	-0.1
SEP	5	0.3	5.0	0.5	52	3.1	0.0	3.1	1699.7	11.5	-0.2
OCT	3	0.2	3.4	0.3	0	0.0	0.0	0.0	1699.6	11.4	-0.1
NOV	5	0.3	2.1	0.2	0	0.0	0.0	0.0	1699.7	11.5	0.1
DEC	3	0.2	1.1	0.1	0	0.0	0.0	0.0	1699.8	11.6	0.1
TOTAL		6.4	45.6	4.7		32.4	0.0	27.9			-2.8
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	15	0.9	0.8	0.1	0	0.0	0.0	0.0	1702.6	15.2	0.8
FEB	23	1.3	1.0	0.1	0	0.0	0.0	0.0	1703.5	16.4	1.2
MAR	36	2.2	1.7	0.2	0	0.0	0.0	0.0	1704.8	18.4	2.0
APR	40	2.4	3.8	0.5	0	0.0	0.0	0.0	1706.0	20.3	1.9
MAY	63	3.9	4.7	0.7	7	0.4	0.0	0.0	1707.6	23.1	2.8
JUN	52	3.1	5.9	0.9	74	4.4	0.0	0.0	1706.4	20.9	-2.2
JUL	50	3.1	6.7	0.8	192	11.8	0.0	0.4	1700.0	11.8	-9.1
AUG	34	2.1	5.9	0.6	166	10.2	0.0	8.7	1700.0	11.8	0.0
SEP	18	1.1	4.5	0.4	8	0.5	0.0	0.0	1700.1	12.0	0.2
OCT	11	0.7	3.0	0.3	0	0.0	0.0	0.0	1700.5	12.4	0.4
NOV	15	0.9	1.9	0.2	0	0.0	0.0	0.0	1701.0	13.1	0.7
DEC	13	0.8	1.0	0.1	0	0.0	0.0	0.0	1701.6	13.8	0.7
TOTAL		22.5	40.9	4.9		27.3	0.0	9.1			-0.6
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	46	2.8	0.7	0.1	0	0.0	0.0	0.0	1703.9	17.1	2.7
FEB	76	4.2	0.9	0.1	0	0.0	0.0	0.0	1706.6	21.2	4.1
MAR	120	7.4	1.5	0.2	0	0.0	0.0	0.0	1710.3	28.4	7.2
APR	134	8.0	3.5	0.7	0	0.0	0.0	0.0	1713.2	35.7	7.3
MAY	211	13.0	4.3	1.1	5	0.3	0.0	0.0	1717.0	47.3	11.6
JUN	175	10.4	5.3	1.5	59	3.5	0.0	0.0	1718.5	52.7	5.4
JUL	166	10.2	6.0	1.8	168	10.3	0.0	0.0	1718.0	50.8	-1.9
AUG	115	7.1	5.3	1.5	119	7.3	0.0	0.0	1717.5	49.1	-1.7
SEP	61	3.6	4.0	1.1	7	0.4	0.0	0.0	1718.1	51.2	2.1
OCT	39	2.4	2.7	0.8	0	0.0	0.0	0.0	1718.6	52.8	1.6
NOV	52	3.1	1.7	0.5	0	0.0	0.0	0.0	1719.3	55.4	2.6
DEC	41	2.5	0.9	0.3	0	0.0	0.0	0.0	1719.9	57.6	2.2
TOTAL		74.7	36.8	9.7		21.8	0.0	0.0			43.2

## WEBSTER RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR REQUIREMENT SPILL 1000		END OF MONTH ELEV CONT		RESERVOIR CHANGE
	CFS	AF	INCHES	AF	CFS	AF	AF	1000 AF	FT	1000 AF	1000 AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	3	0.2	0.9	0.1	0	0.0	0.0	0.0	1865.3	10.3	0.1
FEB	5	0.3	1.1	0.1	0	0.0	0.0	0.0	1865.5	10.5	0.2
MAR	8	0.5	2.0	0.2	0	0.0	0.0	0.0	1865.7	10.8	0.3
APR	10	0.6	4.4	0.5	0	0.0	0.0	0.0	1865.8	10.9	0.1
MAY	15	0.9	5.7	0.6	15	0.9	0.0	0.0	1865.3	10.3	-0.6
JUN	12	0.7	7.2	0.8	101	6.0	0.0	3.2	1863.0	7.4	-2.9
JUL	11	0.7	7.9	0.8	236	14.5	0.0	14.5	1863.0	7.3	-0.1
AUG	7	0.4	7.2	0.7	236	14.5	0.0	14.5	1862.7	7.0	-0.3
SEP	3	0.2	5.4	0.5	25	1.5	0.0	1.5	1862.4	6.7	-0.3
OCT	2	0.1	3.6	0.3	0	0.0	0.0	0.0	1862.2	6.5	-0.2
NOV	3	0.2	2.2	0.2	0	0.0	0.0	0.0	1862.2	6.5	0.0
DEC	3	0.2	1.2	0.1	0	0.0	0.0	0.0	1862.3	6.6	0.1
TOTAL		5.0	48.7	4.9		37.4	0.0	33.7			-3.6
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	11	0.7	0.8	0.1	0	0.0	0.0	0.0	1865.7	10.8	0.6
FEB	18	1.0	1.0	0.1	0	0.0	0.0	0.0	1866.3	11.7	0.9
MAR	28	1.7	1.7	0.2	0	0.0	0.0	0.0	1867.4	13.2	1.5
APR	40	2.4	4.0	0.5	0	0.0	0.0	0.0	1868.6	15.1	1.9
MAY	59	3.6	5.1	0.7	13	0.8	0.0	0.0	1869.9	17.2	2.1
JUN	42	2.5	6.4	0.8	74	4.4	0.0	0.0	1868.2	14.5	-2.7
JUL	41	2.5	7.1	0.8	208	12.8	0.0	4.0	1863.0	7.4	-7.1
AUG	24	1.5	6.4	0.6	161	9.9	0.0	9.0	1863.0	7.4	0.0
SEP	13	0.8	4.8	0.5	5	0.3	0.0	0.0	1863.0	7.4	0.0
OCT	8	0.5	3.2	0.3	0	0.0	0.0	0.0	1863.2	7.6	0.2
NOV	10	0.6	2.0	0.2	0	0.0	0.0	0.0	1863.5	8.0	0.4
DEC	10	0.6	1.1	0.1	0	0.0	0.0	0.0	1863.9	8.5	0.5
TOTAL		18.4	43.6	4.9		28.2	0.0	13.0			-1.7
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	52	3.2	0.8	0.1	0	0.0	0.0	0.0	1867.5	13.3	3.1
FEB	79	4.4	0.9	0.1	0	0.0	0.0	0.0	1870.2	17.6	4.3
MAR	124	7.6	1.6	0.2	0	0.0	0.0	0.0	1874.3	25.0	7.4
APR	178	10.6	3.6	0.6	0	0.0	0.0	0.0	1878.9	35.0	10.0
MAY	265	16.3	4.6	1.0	7	0.4	0.0	0.0	1884.6	49.9	14.9
JUN	192	11.4	5.8	1.5	42	2.5	0.0	0.0	1887.0	57.3	7.4
JUL	181	11.1	6.5	1.7	125	7.7	0.0	0.0	1887.5	59.0	1.7
AUG	106	6.5	5.8	1.6	101	6.2	0.0	0.0	1887.1	57.7	-1.3
SEP	64	3.8	4.4	1.2	2	0.1	0.0	0.0	1887.9	60.2	2.5
OCT	36	2.2	2.9	0.8	0	0.0	0.0	0.0	1888.3	61.6	1.4
NOV	49	2.9	1.8	0.5	0	0.0	0.0	0.0	1889.0	64.0	2.4
DEC	44	2.7	1.0	0.3	0	0.0	0.0	0.0	1889.7	66.4	2.4
TOTAL		82.7	39.6	9.6		16.9	0.0	0.0			56.2



## WACONDA LAKE OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR SPILL 1000	RESERVOIR REQUIREMENT SHORTAGE 1000	END OF MONTH ELEV	CONT 1000	RESERVOIR CHANGE 1000
	CFS	AF	INCHES	AF	CFS	AF	AF	AF	FT	AF	AF
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	36	2.2	0.8	0.7	8	0.5	0.0	0.0	1450.4	160.8	1.0
FEB	54	3.0	1.0	0.9	9	0.5	0.0	0.0	1450.6	162.4	1.6
MAR	101	6.2	1.9	1.6	3	0.2	0.0	0.0	1451.0	166.8	4.4
APR	106	6.3	4.8	4.2	2	0.1	0.0	0.0	1451.2	168.8	2.0
MAY	122	7.5	5.9	5.1	7	0.4	0.0	0.0	1451.4	170.8	2.0
JUN	104	6.2	7.5	6.5	42	2.5	0.0	0.0	1451.1	168.0	-2.8
JUL	169	10.4	8.9	7.5	156	9.6	0.0	0.0	1450.4	161.3	-6.7
AUG	62	3.8	7.6	6.1	124	7.6	0.0	0.0	1449.4	151.4	-9.9
SEP	47	2.8	6.0	4.7	24	1.4	0.0	0.0	1449.1	148.1	-3.3
OCT	37	2.3	3.9	3.0	3	0.2	0.0	0.0	1449.0	147.2	-0.9
NOV	42	2.5	2.1	1.6	7	0.4	0.0	0.0	1449.1	147.7	0.5
DEC	33	2.0	1.0	0.8	10	0.6	0.0	0.0	1449.1	148.3	0.6
TOTAL		55.2	51.5	42.7		24.0	0.0	0.0			-11.5
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	96	5.9	0.7	0.6	3	0.2	0.0	0.0	1450.8	164.9	5.1
FEB	144	8.0	0.9	0.8	5	0.3	0.0	0.0	1451.5	171.8	6.9
MAR	273	16.8	1.7	1.5	2	0.1	0.0	0.0	1452.9	187.0	15.2
APR	284	16.9	4.3	4.1	0	0.0	0.0	0.0	1454.0	199.8	12.8
MAY	329	20.2	5.2	5.3	3	0.2	0.0	0.0	1455.2	214.5	14.7
JUN	279	16.6	6.7	7.0	32	1.9	2.8	0.0	1455.6	219.4	4.9
JUL	452	27.8	7.9	8.3	112	6.9	12.6	0.0	1455.6	219.4	0.0
AUG	166	10.2	6.7	7.0	89	5.5	0.0	0.0	1455.4	217.1	-2.3
SEP	128	7.6	5.4	5.6	17	1.0	0.0	0.0	1455.5	218.1	1.0
OCT	99	6.1	3.5	3.6	0	0.0	1.2	0.0	1455.6	219.4	1.3
NOV	113	6.7	1.9	1.9	3	0.2	28.9	0.0	1453.6	195.1	-24.3
DEC	89	5.5	0.9	0.9	5	0.3	4.3	0.0	1453.6	195.1	0.0
TOTAL		148.3	45.7	46.6		16.6	49.8	0.0			35.3
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	356	21.9	0.7	0.6	0	0.0	0.0	0.0	1452.3	181.1	21.3
FEB	533	29.6	0.8	0.8	2	0.1	14.7	0.0	1453.6	195.1	14.0
MAR	1008	62.0	1.5	1.5	2	0.1	36.1	0.0	1455.6	219.4	24.3
APR	1050	62.5	3.9	4.0	2	0.1	58.4	0.0	1455.6	219.4	0.0
MAY	1213	74.6	4.7	4.9	2	0.1	69.6	0.0	1455.6	219.4	0.0
JUN	1032	61.4	6.0	6.3	20	1.2	53.9	0.0	1455.6	219.4	0.0
JUL	1675	103.0	7.1	7.4	70	4.3	91.3	0.0	1455.6	219.4	0.0
AUG	615	37.8	6.0	6.3	57	3.5	28.0	0.0	1455.6	219.4	0.0
SEP	471	28.0	4.8	5.0	10	0.6	22.4	0.0	1455.6	219.4	0.0
OCT	366	22.5	3.1	3.3	2	0.1	19.1	0.0	1455.6	219.4	0.0
NOV	415	24.7	1.7	1.7	0	0.0	47.3	0.0	1453.6	195.1	-24.3
DEC	330	20.3	0.8	0.8	2	0.1	19.4	0.0	1453.6	195.1	0.0
TOTAL		548.3	40.9	42.6		10.2	460.2	0.0			35.3

## CEDAR BLUFF RESERVOIR OPERATION ESTIMATES - 2005

MONTH	INFLOW MEAN 1000		EVAPORATION 1000		RELEASE REQUIREMENT MEAN 1000		RESERVOIR REQUIREMENT SPILL 1000 AF	SHORTAGE 1000 AF	END OF MONTH		RESERVOIR CHANGE 1000 AF
	CFS	AF	INCHES	AF	CFS	AF			ELEV FT	CONT AF	
<b>REASONABLE MINIMUM INFLOW CONDITIONS</b>											
JAN	2	0.1	1.1	0.5	0	0.0	0.0	0.0	2134.8	116.8	-0.4
FEB	2	0.1	1.3	0.5	0	0.0	0.0	0.0	2134.8	116.4	-0.4
MAR	2	0.1	2.1	0.9	0	0.0	0.0	0.0	2134.6	115.6	-0.8
APR	3	0.2	5.4	2.3	0	0.0	0.0	0.0	2134.2	113.5	-2.1
MAY	7	0.4	6.4	2.7	5	0.3	0.0	0.0	2133.7	110.9	-2.6
JUN	7	0.4	7.9	3.2	5	0.3	0.0	0.0	2133.1	107.8	-3.1
JUL	7	0.4	9.6	3.8	13	0.8	0.0	0.0	2132.2	103.6	-4.2
AUG	5	0.3	8.2	3.1	11	0.7	0.0	0.0	2131.4	100.1	-3.5
SEP	2	0.1	7.0	2.6	5	0.3	0.0	0.0	2130.8	97.3	-2.8
OCT	2	0.1	4.9	1.8	2	0.1	0.0	0.0	2130.4	95.5	-1.8
NOV	2	0.1	2.3	0.8	2	0.1	0.0	0.0	2130.2	94.7	-0.8
DEC	2	0.1	1.3	0.5	2	0.1	0.0	0.0	2130.1	94.2	-0.5
TOTAL		2.4	57.3	22.7		2.7	0.0	0.0			-23.0
<b>MOST PROBABLE INFLOW CONDITIONS</b>											
JAN	5	0.3	1.0	0.4	0	0.0	0.0	0.0	2134.9	117.1	-0.1
FEB	7	0.4	1.1	0.5	0	0.0	0.0	0.0	2134.9	117.0	-0.1
MAR	13	0.8	1.9	0.8	0	0.0	0.0	0.0	2134.9	117.0	0.0
APR	22	1.3	4.9	2.1	0	0.0	0.0	0.0	2134.7	116.2	-0.8
MAY	31	1.9	5.7	2.5	3	0.2	0.0	0.0	2134.6	115.4	-0.8
JUN	34	2.0	7.1	3.1	3	0.2	0.0	0.0	2134.3	114.1	-1.3
JUL	44	2.7	8.6	3.7	11	0.7	0.0	0.0	2134.0	112.4	-1.7
AUG	29	1.8	7.4	3.1	7	0.4	0.0	0.0	2133.6	110.7	-1.7
SEP	12	0.7	6.3	2.6	3	0.2	0.0	0.0	2133.2	108.6	-2.1
OCT	7	0.4	4.4	1.8	2	0.1	0.0	0.0	2132.9	107.1	-1.5
NOV	7	0.4	2.1	0.8	2	0.1	0.0	0.0	2132.8	106.6	-0.5
DEC	5	0.3	1.1	0.5	2	0.1	0.0	0.0	2132.7	106.3	-0.3
TOTAL		13.0	51.7	21.9		2.0	0.0	0.0			-10.9
<b>REASONABLE MAXIMUM INFLOW CONDITIONS</b>											
JAN	28	1.7	0.9	0.4	0	0.0	0.0	0.0	2135.2	118.5	1.3
FEB	38	2.1	1.0	0.4	0	0.0	0.0	0.0	2135.5	120.2	1.7
MAR	65	4.0	1.7	0.8	0	0.0	0.0	0.0	2136.1	123.4	3.2
APR	108	6.4	4.4	2.0	0	0.0	0.0	0.0	2136.9	127.8	4.4
MAY	155	9.5	5.1	2.4	3	0.2	0.0	0.0	2138.1	134.7	6.9
JUN	166	9.9	6.4	3.2	3	0.2	0.0	0.0	2139.2	141.2	6.5
JUL	213	13.1	7.7	4.0	3	0.2	0.0	0.0	2140.6	150.1	8.9
AUG	148	9.1	6.6	3.5	0	0.0	0.0	0.0	2141.5	155.7	5.6
SEP	61	3.6	5.6	3.0	2	0.1	0.0	0.0	2141.6	156.2	0.5
OCT	24	1.5	4.0	2.1	2	0.1	0.0	0.0	2141.4	155.5	-0.7
NOV	34	2.0	1.8	1.0	2	0.1	0.0	0.0	2141.6	156.4	0.9
DEC	24	1.5	1.0	0.5	2	0.1	0.0	0.0	2141.7	157.3	0.9
TOTAL		64.4	46.1	23.3		1.0	0.0	0.0			40.1

**TABLE 5****FLOOD DAMAGES PREVENTED BY NEBRASKA-KANSAS PROJECTS RESERVOIRS**

RESERVOIR	DURING FY 2004	PRIOR TO 2004	ACCUMULATED TOTAL
BONNY	\$4,000	\$2,685,000	\$2,689,000
ENDERS	\$5,000	\$3,276,000	\$3,281,000
SWANSON	\$3,000	\$19,063,000	\$19,066,000
HUGH BUTLER	\$3,000	\$2,571,000	\$2,574,000
HARRY STRUNK	\$16,000	\$4,908,000	\$4,924,000
KEITH SEBELIUS	\$4,000	\$3,954,000	\$3,958,000
HARLAN COUNTY	\$5,000	\$150,085,000	\$150,090,000
LOVEWELL	\$113,000	\$146,495,000	\$146,608,000
KIRWIN	\$9,000	\$86,850,000	\$86,859,000
WEBSTER	\$5,000	\$110,308,000	\$110,313,000
WACONDA	\$142,000	\$1,213,053,000	\$1,213,195,000
CEDAR BLUFF	\$3,000	\$128,887,000	\$128,890,000
TOTAL	\$312,000	\$1,872,135,000	\$1,872,447,000

Estimates of damages prevented are received from the Army Corps of Engineer's Kansas City District Office. The Accumulated Totals date from 1951 through 2004. Cumulative totals are revised by the Corps of Engineers in some cases to reflect data not previously included in the reporting and may not match previous cumulative totals.

Construction Cost of storage dams was \$208,954,130.

The reservoirs upstream of Harlan County Lake did not receive benefits for damages prevented from 1972 to 1993.

TABLE 6  
WATER DIVERTED IN 2004 AND THE  
ESTIMATED DIVERSION FOR 2005  
(Units - Acre-Feet)




Irrigation District and Canal	2004 Irrigation Operations		10-Year Average Diversion (1994-2003)		2004 Diversion	Estimated Diversion in 2005
	From	To				
Mirage Flats Irrigation District						
Mirage Flats Canal	7/11	9/2	13,212		8,553	9,000
Ainsworth Irrigation District						
Ainsworth Canal	5/6	9/23	72,466		84,275	80,000
Twin Loups Irrigation District						
Above Davis Creek	5/11	9/23	40,591	*	51,880	51,000
Below Davis Creek	5/11	9/22	37,599	*	43,729	46,000
Total Twin Loups Irrigation District			78,190		95,609	97,000
Frenchman Valley Irrigation District						
Culbertson Canal	3/17	9/7	9,178		8,674	8,500
H & RW Irrigation District						
Culbertson Extension Canal	Did not run.		8,985		0	0
Frenchman-Cambridge Irrigation District						
Meeker-Driftwood Canal	Did not run.		23,903		0	0
Red Willow Canal	Did not run.		6,218		0	0
Bartley Canal	Did not run.		7,182		0	0
Cambridge Canal	6/21	9/3	23,960		21,964	20,000
Total Frenchman-Cambridge Irrigation District			61,263		21,964	20,000
Almena Irrigation District						
Almena Canal	Did not run.		4,836		0	0
Bostwick Irrigation District in Nebraska						
Franklin Canal	Did not run.		30,006		0	0
Naponee Canal	Did not run.		2,704		0	0
Franklin Pump Canal	Did not run.		3,067		0	0
Superior Canal	5/24	9/16	13,627		5,800	5,800
Courtland Canal (Nebraska)	Did not run.		2,105		0	0
Total Bostwick Irrigation District in Nebraska			51,509		5,800	5,800
Kansas-Bostwick Irrigation District						
Courtland Canal above Lovewell	7/1	11/15	27,375		3,268	3,000
Courtland Canal below Lovewell	5/13	8/30	47,304		30,134	30,000
Total Kansas-Bostwick Irrigation District			74,679		33,402	33,000
Kirwin Irrigation District						
Kirwin Canal	7/20	8/20	21,521		7,937	0
Webster Irrigation District						
Osborne Canal	7/20	8/19	14,178		4,253	0
Glen Elder Irrigation District	5/25	9/21	5,749		6,991	8,000
TOTAL			415,766		277,458	261,300

\* Average diversion is from 1995 through 2004 for Twin Loups and Glen Elder Irrigation Districts.

**TABLE 7**  
**NEBRASKA-KANSAS PROJECTS**  
**Summary of Precipitation, Reservoir Storage and Inflows**  
**CALENDAR YEAR 2004**




Reservoir	Total Precip. Inches	Percent Of Average %	Storage 12-31-03 AF	Storage 12-31-04 AF	Gain or Loss AF	Maximum Content AF	Storage Date	Minimum Content AF	Storage Date	Total Inflow AF	Percent Of Most Probable %
Box Butte	16.15	94	6,895	7,768	873	11,893	MAY 19	3,423	AUG 31	12,527	75
Merritt	24.21	120	68,831	69,110	279	74,781	JUN 21	29,330	SEP 15	180,572	96
Calamus	20.86	88	87,654	100,649	12,995	129,667	MAY 23	67,235	SEP 21	249,768	94
Davis Creek	20.58	87	10,111	9,345	-766	31,123	JUN 28	7,423	SEP 10	51,783	107
Bonny	15.60	90	16,726	13,754	-2,972	17,318	MAY 6	13,719	DEC 23	5,390	39
Enders	22.77	120	11,267	11,632	365	12,175	MAY 1	11,210	SEP 21	4,876	28
Swanson	28.43	142	26,599	30,489	3,890	32,168	JUL 26	26,577	JAN 2	12,714	27
Hugh Butler	21.70	110	15,587	18,387	2,800	18,571	AUG 2	15,607	JAN 1	9,632	61
Harry Strunk	24.66	120	21,540	21,177	-363	31,860	JUN 20	13,755	SEP 3	28,707	81
Keith Sebelius	23.11	93	9,172	8,247	-925	9,649	APR 15	8,107	NOV 8	3,704	49
Harlan County	22.83	100	113,346	107,050	-6,296	117,883	MAY 23	107,050	DEC 26	25,099	18
Lovewell	30.73	113	28,358	15,904	-12,454	42,173	JUL 10	12,512	NOV 15	30,821	54
Kirwin	21.51	92	24,575	14,414	-10,161	25,264	MAR 9	14,400	NOV 10	4,009	18
Webster	21.47	91	19,143	10,153	-8,990	19,437	MAR 5	10,113	OCT 6	4,033	22
Waconda	24.41	95	168,625	159,801	-8,824	179,256	JUL 31	159,504	DEC 25	49,217	33
Cedar Bluff	19.51	92	130,225	117,211	-13,014	130,282	MAR 1	117,211	DEC 27	10,496	81

# BOX BUTTE RESERVOIR ACTUAL OPERATION






# BOX BUTTE RESERVOIR

## 2005 OPERATION PLAN






# MERRITT RESERVOIR ACTUAL OPERATION








# MERRITT RESERVOIR

## 2005 OPERATION PLAN






# CALAMUS RESERVOIR ACTUAL OPERATION






# CALAMUS RESERVOIR

## 2005 OPERATION PLAN






# DAVIS CREEK RESERVOIR ACTUAL OPERATION






# DAVIS CREEK RESERVOIR

## 2005 OPERATION PLAN






# BONNY RESERVOIR

## ACTUAL OPERATION






# BONNY RESERVOIR

## 2005 OPERATION PLAN






# ENDERS RESERVOIR ACTUAL OPERATION








# ENDERS RESERVOIR




## 2005 OPERATION PLAN






# SWANSON LAKE ACTUAL OPERATION



# SWANSON LAKE 2005 OPERATION PLAN






# HUGH BUTLER LAKE ACTUAL OPERATION






# HUGH BUTLER LAKE

## 2005 OPERATION PLAN






# HARRY STRUNK LAKE ACTUAL OPERATION



# HARRY STRUNK LAKE

## 2005 OPERATION PLAN













# KEITH SEBELIUS LAKE

## 2005 OPERATION PLAN






# HARLAN COUNTY LAKE ACTUAL OPERATION






# HARLAN COUNTY LAKE

## 2005 OPERATION PLAN






# LOVEWELL RESERVOIR ACTUAL OPERATION






# LOVEWELL RESERVOIR




## 2005 OPERATION PLAN






# KIRWIN RESERVOIR ACTUAL OPERATION



# KIRWIN RESERVOIR 2005 OPERATION PLAN






# WEBSTER RESERVOIR ACTUAL OPERATION











# WEBSTER RESERVOIR 2005 OPERATION PLAN



# WACONDA LAKE ACTUAL OPERATION






# WACONDA LAKE 2005 OPERATION PLAN






# CEDAR BLUFF RESERVOIR

## ACTUAL OPERATION




# CEDAR BLUFF RESERVOIR

## 2005 OPERATION PLAN



# MIRAGE FLATS IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	1.57	1.28	1.14	1.20	1.22	1.28	1.13	1.12	0.90	0.77
DELIVERED af/acre	0.74	0.64	0.70	0.69	0.74	0.75	0.70	0.63	0.42	0.32
EFFICIENCY	48%	50%	61%	58%	61%	58%	62%	56%	47%	41%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 25,800 AF  
 NORMAL YEAR 14,800 AF  
 WET YEAR 1,300 AF

# AINSWORTH IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	2.00	2.07	1.75	1.87	2.09	2.36	2.20	2.67	2.31	2.48
DELIVERED af/acre	1.37	1.42	1.03	1.13	1.37	1.49	1.38	1.83	1.52	1.59
EFFICIENCY	68%	68%	59%	60%	66%	63%	63%	68%	66%	64%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 0 AF  
 NORMAL YEAR 0 AF

# TWIN LOUPS IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	1.76	1.10	1.47	1.52	1.23	1.60	1.76	1.87	1.84	1.75
DELIVERED af/acre	1.17	0.60	0.74	0.60	0.67	0.94	0.88	1.09	1.07	1.00
EFFICIENCY	66%	54%	51%	40%	55%	59%	50%	58%	58%	58%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 0 AF  
 NORMAL YEAR 0 AF



# FRENCHMAN VALLEY IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	1.11	1.17	1.14	1.11	0.93	1.12	0.81	1.05	2.97	4.24
DELIVERED af/acre	0.50	0.50	0.57	0.50	0.59	0.54	0.36	0.34	1.18	1.19
EFFICIENCY	45%	43%	50%	45%	63%	48%	45%	32%	40%	28%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 34,500 AF  
 NORMAL YEAR 21,800 AF  
 WET YEAR 7,700 AF

# H AND RW IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	1.09	1.10	1.28	1.03	1.19	0.91	0.65	0.00	0.00	0.00
DELIVERED af/acre	0.48	0.43	0.55	0.52	0.39	0.39	0.24	0.00	0.00	0.00
EFFICIENCY	44%	39%	43%	51%	33%	43%	37%	0%	0%	0%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 43,800 AF  
 NORMAL YEAR 27,700 AF  
 WET YEAR 9,800 AF

# FRENCHMAN-CAMBRIDGE IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	1.92	1.17	1.79	1.66	1.29	1.56	1.19	1.12	1.15	1.45
DELIVERED af/acre	1.17	0.61	1.16	1.00	0.80	0.96	0.70	0.67	0.63	0.74
EFFICIENCY	61%	52%	65%	60%	62%	61%	58%	61%	55%	52%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 43,000 AF  
 NORMAL YEAR 0 AF

# ALMENA IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	0.89	1.00	1.81	0.97	1.12	1.17	1.07	0.73	2.02	0.00
DELIVERED af/acre	0.37	0.35	0.72	0.34	0.42	0.48	0.39	0.34	1.05	0.00
EFFICIENCY	41%	35%	40%	35%	38%	41%	36%	46%	52%	0%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 24,100 AF  
 NORMAL YEAR 19,200 AF  
 DRY YEAR 3,600 AF

# BOSTWICK IRRIGATION DISTRICT - NEBRASKA

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	2.73	2.05	2.33	2.33	2.44	2.97	2.10	1.91	1.25	1.85
DELIVERED af/acre	1.05	0.61	0.86	0.86	0.93	1.19	0.84	0.96	0.52	0.47
EFFICIENCY	39%	30%	37%	37%	38%	40%	40%	50%	42%	25%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 62,300 AF  
 NORMAL YEAR 15,800 AF

# KANSAS-BOSTWICK IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	2.28	2.03	1.91	1.96	2.07	2.33	1.86	1.84	1.46	1.38
DELIVERED af/acre	1.22	1.16	1.04	1.07	1.15	1.42	1.00	1.11	0.79	0.65
EFFICIENCY	53%	57%	55%	55%	56%	61%	54%	61%	54%	47%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 83,900 AF  
 NORMAL YEAR 15,000 AF

# KIRWIN IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	2.69	2.56	2.65	2.48	2.49	2.80	2.44	2.27	1.73	1.23
DELIVERED af/acre	1.21	0.99	1.04	1.01	0.95	1.37	1.04	1.27	0.88	0.49
EFFICIENCY	45%	39%	39%	41%	38%	49%	43%	56%	51%	40%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 27,900 AF  
 NORMAL YEAR 9,100 AF

# WEBSTER IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.




	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	3.55	2.86	2.68	2.52	2.54	2.98	2.83	2.71	1.83	1.35
DELIVERED af/acre	1.04	1.07	1.00	1.00	0.81	1.19	1.14	1.22	0.97	0.50
EFFICIENCY	29%	37%	37%	40%	32%	40%	40%	45%	53%	37%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 33,700 AF  
 NORMAL YEAR 13,000 AF



# GLEN ELDER IRRIGATION DISTRICT

CANAL DIV., FARM DEL., AND ACRES IRRIG.



	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
DIVERTED af/acre	0.00	0.00	2.45	1.41	1.76	2.72	2.10	2.86	2.10	1.93
DELIVERED af/acre	0.00	0.00	0.73	0.71	0.80	1.28	0.75	1.27	1.01	0.58
EFFICIENCY	0%	0%	30%	51%	45%	47%	36%	44%	48%	30%

FORECASTED SHORTAGES (2005)  
 DRY YEAR 0 AF  
 NORMAL YEAR 0 AF