



## **Cost Analysis of NO<sub>x</sub> Control Alternatives for Stationary Gas Turbines**

**Contract No. DE-FC02-97CHIO877**

*Prepared for:*

**U.S. Department of Energy**  
Environmental Programs  
Chicago Operations Office  
9800 South Cass Avenue  
Chicago, IL 60439

*Prepared by:*

**ONSITE SYCOM Energy  
Corporation**  
701 Palomar Airport Road,  
Suite 200  
Carlsbad, California 92009

November 5, 1999



# **Cost Analysis of NO<sub>x</sub> Control Alternatives for Stationary Gas Turbines**

**Contract No. DE-FC02-97CHIO877**

*Prepared by:*

Bill Major, Project Manager  
**ONSITE SYCOM Energy Corporation**  
701 Palomar Airport Road, Suite 200  
Carlsbad, California 92009  
Phone: 760-931-2400

Bill Powers, Principal Technical Investigator  
**Powers Engineering**

# TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY</b> .....	<b>S-1</b>
<b>1.0 INTRODUCTION</b> .....	<b>1-1</b>
1.1 Project Objective .....	1-1
1.2 Recent NO <sub>x</sub> Emission Control Developments .....	1-2
1.2.1 DLN Technology.....	1-2
1.2.2 Catalytic Combustion.....	1-4
1.2.3 Selective Catalytic Reduction .....	1-5
1.2.4 SCONO <sub>x</sub> <sup>TM</sup> Catalytic Absorption System .....	1-6
<b>2.0 TECHNICAL DISCUSSION</b> .....	<b>2-1</b>
2.1 Introduction To Gas Turbines .....	2-1
2.1.1 Technology Description .....	2-1
2.1.2 Gas Turbine Types .....	2-2
2.2 NO <sub>x</sub> Formation In Gas Turbines .....	2-3
2.3 Factors That Affect NO <sub>x</sub> Formation In Gas Turbines .....	2-4
2.3.1 Combustor Design.....	2-4
2.3.2 Power Output Level.....	2-4
2.3.3 Type of Fuel .....	2-5
2.3.4 Ambient Conditions .....	2-6
2.3.5 Operating Cycles .....	2-6
2.4 BACT/LAER Determinations .....	2-6
2.5 NO <sub>x</sub> Emission Control Technologies .....	2-7
2.5.1 Water/Steam Injection.....	2-8
2.5.2 Dry Low NO <sub>x</sub> (DLN) Combustors .....	2-8
2.5.3 Catalytic Combustion.....	2-10
2.5.4 Selective Catalytic Reduction .....	2-11
2.5.5 SCONO <sub>x</sub> <sup>TM</sup> Catalytic Absorption System .....	2-12
2.5.6 Rich-Quench-Lean Combustors .....	2-13
<b>3.0 NO<sub>x</sub> CONTROL COST ETIMATES</b> .....	<b>3-1</b>
3.1 Methodology .....	3-1
3.2 Uncontrolled NO <sub>x</sub> Emission Rate .....	3-1
3.3 NO <sub>x</sub> Control Technology Cost Estimates.....	3-2
3.3.1 DLN Cost Estimates.....	3-3
3.3.2 Solar Turbines Water Injection and DLN Cost Estimate .....	3-3
3.3.3 Rolls-Royce Allison DLN Cost Estimate.....	3-4
3.3.4 GE LM2500 Water Injection and DLN Cost Estimate .....	3-5

**TABLE OF CONTENTS (cont.)**

3.3.5	GE Frame 7FA DLN Cost Estimate.....	3-5
3.3.6	Calytica Combustor Cost Estimate.....	3-5
3.3.7	MHIA Conventional SCR Cost Estimate.....	3-6
3.3.8	KTI Low Temperature SCR Cost Estimate.....	3-7
3.3.9	Engelhard High Temperature SCR Cost Estimate .....	3-7
3.3.10	SCONO <sub>x</sub> <sup>TM</sup> Cost Estimate .....	3-7
3.4	Results and Conclusions .....	3-8
<b>Appendix A NO<sub>x</sub> Control Technology Cost Comparison Tables .....</b>		<b>A-1</b>
<b>Appendix B References .....</b>		<b>B-1</b>

## TABLES

S-1	Summary of Cost Impact Factors For Selected NO <sub>x</sub> Control Technologies .....	S-2
2-1	Summary of Recent Gas Turbine BACT/LAER Determinations .....	2-7
3-1	Summary of Turbine Models Used in the Cost Comparison .....	3-2
3-2	Incremental Water Injection and DLN Costs .....	3-3
3-3	Comparison of 1993 and 1999 NO <sub>x</sub> Control Costs for Gas Turbines .....	3-9
A-1	Summary of Cost Impact Factors For Selected NO <sub>x</sub> Control Technologies .....	A-2
A-2	1999 DLN Cost Comparison.....	A-3
A-3	1999 Catalytic Combustion Cost Comparison .....	A-4
A-4	1999 Water/Steam Injection Cost Comparison.....	A-5
A-5	1999 Conventional SCR Cost Comparison.....	A-6
A-6	1999 High Temperature SCR Cost Comparison .....	A-7
A-7	1999 SCONO <sub>x</sub> <sup>TM</sup> Cost Comparison .....	A-8
A-8	1999 Low Temperature SCR Cost Comparison.....	A-9

## FIGURES

S-1	1999 Comparison of NO <sub>x</sub> Control Technologies .....	S-3
S-2	1993 EPA Comparison of NO <sub>x</sub> Control Technologies.....	S-4
2-1	Components of a Gas Turbine.....	2-2

## PREFACE

*This report was prepared by ONSITE SYCOM Energy Corporation as an account of work sponsored by the U.S. Department of Energy. Bill Powers, Principal of Powers Engineering, was the primary investigator for the technical analysis.*

*The information and results contained in this work illustrate the performance and cost range for gas turbine NO<sub>x</sub> control technologies. It is intended to establish a dialogue among interested parties to examine the environmental impacts and regulatory implications of air-borne emissions from advanced gas turbine systems. Mention of trade names and commercial products is not intended to constitute endorsement or recommendation for use.*

## ACKNOWLEDGEMENTS

*ONSITE SYCOM would like to acknowledge the participation of the following individuals whose assistance and contribution was greatly appreciated.*

*Bill Powers, Principal, Powers Engineering, who was the principal contributor*

*Rich Armstrong, GE Power Systems*

*Bill Binford, Rolls-Royce Allison*

*Fred Booth, Engelhard*

*Tom Gilmore, Kinetics Technology International*

*Patricia Hoffman, Program Manager, Office of Industrial Technologies, U.S. DOE*

*Mark Krush, Siemens- Westinghouse*

*Ray Patt, GE Industrial and Marine*

*Boris Reyes, Goal Line Environmental Technologies*

*Chuck Solt, Catalytica Combustion Systems*

*Stephen Waslo, Senior Program Manager, U.S. DOE, Chicago Operations Office*

*Leslie Witherspoon, Solar Turbines*

*Sam Yang, Mitsubishi Heavy Industries America*

## EXECUTIVE SUMMARY

This study compares the costs of the principal emission control technologies being employed or nearing commercialization for control of oxides of nitrogen (NO<sub>x</sub>) in stationary gas turbines. Cost data is expressed as “\$/ton NO<sub>x</sub> removed” (“\$/ton”) and “¢/kWh” for gas turbines in the 5 MW, 25 MW and 150 MW output ranges. The reference document for this study is the “Alternative Control Techniques Document – NO<sub>x</sub> Emissions from Stationary Gas Turbines” EPA-453/R-93-007, (“1993 NO<sub>x</sub> ACT document”) prepared by the U.S. EPA in 1993. Gas turbine manufacturers and NO<sub>x</sub> control technology vendors that participated in the 1993 study were contacted to determine current costs. The NO<sub>x</sub> control technologies evaluated in the 1993 NO<sub>x</sub> ACT document include water/steam injection, dry low NO<sub>x</sub> (DLN) combustion, and selective catalytic reduction (SCR). Current cost data is also provided for new control technologies that were not available in 1993, including low and high temperature SCR, catalytic combustion, and SCONO<sub>x</sub><sup>™</sup>.

Shown in Table S-1, cost data is developed in “\$/ton” and “¢/kWh” formats. The “\$/ton” values indicate the typical cost of a control technology to remove a ton of NO<sub>x</sub> from the exhaust gas. The “\$/ton” value is determined by dividing the owning cost of the control technology by the tons of NO<sub>x</sub> removed. Owning costs consist of capital, operating and maintenance costs. A “\$/ton” value that is relatively lower means that the technology is more efficient in removing NO<sub>x</sub> than alternative control technologies.

The “\$/ton” value is a useful comparative indicator when the inlet and outlet concentrations are the same for each group of technologies being evaluated. NO<sub>x</sub> can be controlled to within a feasible limit for a specific control technology and is largely independent of a gas turbine’s uncontrolled NO<sub>x</sub> emission rate. Therefore the uncontrolled NO<sub>x</sub> exhaust concentrations must be considered when evaluating the “\$/ton” cost effectiveness values applied to different makes/models of turbines to obtain a meaningful comparison.

**Table S-1**  
**Cost Impact Factors for Selected NO<sub>x</sub> Control Technologies (1999)**

Turbine Output	5 MW Class		25 MW Class		150 MW Class	
	\$/ton	¢/kWh	\$/ton	¢/kWh	\$/ton	¢/kWh
Median value						
NO <sub>x</sub> EMISSION CONTROL TECHNOLOGY						
DLN (25 ppm)	260	0.075	210	0.124	122 *	0.054 *
Catalytic Combustion (3 ppm)	957	0.317	692	0.215	371	0.146
Water/Steam Injection (42 ppm)	1,652	0.410	984	0.240	476	0.152
Conventional SCR (9 ppm)	6,274	0.469	3,541	0.204	1,938	0.117
High Temperature SCR (9 ppm)	7,148	0.530	3,841	0.221	2,359	0.134
SCONO <sub>x</sub> (2 ppm)	16,327	0.847	11,554	0.462	6,938	0.289
Low Temperature SCR (9 ppm)	5,894	1.060	2,202	0.429		

\* 9-25 ppm

"¢/kWh" based on 8,000 full load hours


The “¢/kWh” value provides the electricity cost impact of a particular NO<sub>x</sub> control technology, and is independent of the tons of NO<sub>x</sub> removed. The “¢/kWh” represents a unit cost for NO<sub>x</sub> control that must be added to other owning costs associated with the gas turbine project. The “¢/kWh” value is determined by dividing the owning cost of the NO<sub>x</sub> control technology by the amount of electricity generated by the gas turbine. A comparison between “¢/kWh” values is most meaningful for technologies that control NO<sub>x</sub> to an equivalent “ppm” concentration.

When performing cost impact comparisons among technologies that do not control NO<sub>x</sub> with an equivalent inlet/outlet emission rate, it must be recognized that there may be capital and operating cost adjustments required to perform the analysis on an equivalent basis. In this study, capital and operating costs provided by manufacturers were restricted to turbine projects readily available at the time of the inquiry and explains the use of various gas turbine models and inlet/outlet NO<sub>x</sub> emission rates. Manufacturers that consider certain cost numbers as proprietary also prevented an equitable comparison in some cases.




Figures S-1 and S-2 compare the “¢/kWh” values developed in this study and from the 1993 NO<sub>x</sub> ACT document, respectively. Controlled NO<sub>x</sub> concentrations are indicated below each technology in the figures. In general, results shown in the figures are ordered from highest cost to lowest cost impact.

The “\$/ton” and “¢/kWh” cost impact factors are based on 8,000 full load operating hours, as used in the 1993 NO<sub>x</sub> ACT document. The majority of base-loaded gas turbines typically operate at lower full load hours; therefore actual cost impacts could be significantly higher.



**Figure S-1. 1999 Comparison of NO<sub>x</sub> Control Technologies**



**Figure S-2. 1993 EPA Comparison of NO<sub>x</sub> Control Technologies**

The “¢/kWh” values for water/steam injection have remained fairly constant between the 1993 NO<sub>x</sub> ACT document and the evaluation performed in this study. This is consistent with the fact that water/steam injection was a mature technology in 1993. Considerable innovation has occurred with DLN and SCR and this is reflected in a 50-100% reduction in the “¢/kWh” values for these two technologies between 1993 and 1999.

High temperature SCR is only about 10 percent more costly than conventional SCR. Low temperature SCR and SCONO<sub>x</sub><sup>TM</sup> are typically 2 times more costly than conventional SCR. Each SCR technology fills a unique technical “niche”; cost impact may be of secondary significance. Low temperature SCR is the only SCR technology that can operate effectively below 400 °F. High temperature SCR is the only SCR technology that can operate effectively from 800 to 1,100 °F. SCONO<sub>x</sub><sup>TM</sup> is the only post-combustion NO<sub>x</sub> control technology that does not require ammonia injection to achieve NO<sub>x</sub> levels less than 5 ppm and can operate effectively from 300-700°F.

Projected costs for catalytic combustors indicate that the “¢/kWh” cost is 2 to 3 times higher than a DLN combustor alone. The catalytic combustor can achieve NO<sub>x</sub> levels of less than 3 ppm, while the most advanced DLN combustor can achieve NO<sub>x</sub> levels down to 9 ppm. To reach NO<sub>x</sub> levels below 5 ppm, the DLN-equipped turbine requires post-combustion NO<sub>x</sub> control device such as SCR or SCONO<sub>x</sub><sup>™</sup>. Catalytic combustion is not commercialized and the durability of the catalyst is unproved. In addition, the capital cost of adding catalytic combustion to a turbine combustor will be a strong function of individual turbine designs and therefore will vary significantly.

Figure S-1 indicates that the cost impact is highest when emission control technologies are applied to small industrial turbines (5 MW); a conclusion that was applicable in the 1993 NO<sub>x</sub> ACT document as well. This is particularly true for the post-combustion technologies (SCR and SCONO<sub>x</sub><sup>™</sup>) where the cost impact is roughly twice that for larger turbines (25 MW and 150 MW). In ozone non-attainment areas, strict environmental regulations have mandated add-on controls for gas turbines. These regulations have a disproportionate impact on the construction of small gas turbine systems that may be too expensive to build when add-on controls are mandated.

DLN technology and prospects for catalytic combustion exhibit lower cost impacts than add-on controls for both small and large gas turbines as shown in Figure S-1. Research and development has focused on these technologies to further improve the environmental signature of gas turbines. As an example, a new generation of gas turbines and emission control technologies is being developed with the assistance of the U.S. Department of Energy (DOE) under the Advanced Turbine Systems (ATS) program. These gas turbines will exhibit significantly improved environmental and efficiency characteristics over currently available systems. These systems are being developed during a period of electric utility restructuring and proliferation of gas turbines for base-load power. The coming competitive power industry offers opportunities for both small and large gas turbine systems, filling niche markets - distributed generation and IPP/merchant plants, respectively. Although economics may favor development, the former market, distributed generation, is threatened by strict environmental regulations that impose costly post-combustion emission controls.

Advanced DLN and the development of catalytic combustion are both being funded by the ATS program and hope to significantly reduce the cost impact disparity between small and large gas turbines. Based on the results of this study, it is proposed that regulators consider the significant emission reductions achievable with advanced DLN and potentially with catalytic combustion and re-examine the need for costly post-combustion treatment in light of economic and performance factors, especially for small gas turbines.

## 1.0 INTRODUCTION

### 1.1 Project Objective

The use of stationary gas turbines for power generation has been growing rapidly with continuing trends predicted well into the future. Factors that are contributing to this growth include advances in turbine technology, operating and siting flexibility and low capital cost.

Restructuring of the electric utility industry will provide new opportunities for on-site generation. In a competitive market, it may be more cost effective to install small distributed generation units (like gas turbines) within the grid rather than constructing large power plants in remote locations with extensive transmission and distribution systems. For the customer, on-site generation will provide added reliability and leverage over the cost of purchased power.

One of the key issues that is addressed in virtually every gas turbine application is emissions, particularly NO<sub>x</sub> emissions. Decades of research and development have significantly reduced the NO<sub>x</sub> levels emitted from gas turbines from uncontrolled levels. Emission control technologies are continuing to evolve with older technologies being gradually phased-out while new technologies are being developed and commercialized.

A new generation of small scale power technologies is being developed in response to customer needs for cost effective energy options and more stringent environmental policy. A collaborative effort between industry and the U.S. Department of Energy (DOE) is the Advanced Turbine Systems Program (ATS). This program is tasked with the development and commercialization of the next generation of utility and industrial gas turbines. The benefits of the new technologies include reduced operating costs, improved power quality and reliability, and lower air emissions. General Electric, Siemens-Westinghouse, Solar Turbines, and Rolls-Royce Allison are participating in ATS projects designed to improve turbine efficiency and/or reduce NO<sub>x</sub> emissions through improvements in DLN combustor technology or catalytic combustion.

The objective of this study is to determine and compare the cost of NO<sub>x</sub> control technologies for three size ranges of stationary gas turbines: 5 MW, 25 MW and 150 MW. The purpose of the comparison is to evaluate the cost effectiveness and impact of each control technology as a function of turbine size. The NO<sub>x</sub> control technologies evaluated in this study include:

- Lean premix combustion, also known as “dry low NO<sub>x</sub>” (DLN) combustion;
- Catalytic combustion;
- Water/steam injection;
- Selective catalytic reduction (SCR) – low temperature, conventional, high temperature;
- SCONO<sub>x</sub><sup>TM</sup>

It has been recognized that add-on emission control technologies are cost prohibitive in small gas turbine sizes, however, they have been mandated by stringent regional air quality regulations in many parts of the country. In a coming competitive power market, the opportunities for small turbine installations will grow, however, the economics of these projects will be negatively impacted by such regulations. This study updates the cost factors (“\$/ton” and “¢/kWh”) among the various control technologies using as a reference, the U.S. EPA Office of Air Quality Planning and Standards (OAQPS) document, “Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Stationary Gas Turbines,” EPA-453/R-93-007, January 1993 (“1993 NO<sub>x</sub> ACT document”.)

## **1.2 Recent NO<sub>x</sub> Emission Control Developments**

### **1.2.1 DLN Technology**

The 1993 NO<sub>x</sub> ACT document was published at the inception of DLN combustor commercialization. In the intervening six years, DLN combustors have largely replaced water injection and steam injection as the primary combustion modification to control NO<sub>x</sub> emissions.

The majority of commercially available DLN combustors achieve NO<sub>x</sub> reduction to 25 ppmv. Only General Electric has consistently demonstrated 9 ppmv on its large gas turbines. Achieving

lower emission levels will be primarily reflected by higher incremental O&M costs associated with controls and tuning rather than capital cost impacts. The combustor and fuel metering system will require precise control and more vigilance by operators to maintain 9 ppmv.

The gas turbine manufacturers have funded DLN research and development with assistance from the DOE through its ATS program. Under the ATS program, GE and Siemens-Westinghouse have selected a closed-loop steam cooling system for their utility-class advanced combined cycle turbines. Program objectives are to develop combined cycle units with: 1) 10 percent increase in combined cycle efficiency to approximately 60 percent, 2) NO<sub>x</sub> levels of 9 ppm or less, and CO levels less than 20 ppm without post combustion NO<sub>x</sub> controls, 3) ability to fire synthetic gas from coal or biomass in the future, and 4) reliability, availability, and maintainability (RAM) at least as good as current gas turbine models.

Solar Turbines, a manufacturer of small industrial gas turbines, has developed a high efficiency turbine in partnership with the ATS program. The 4.2 MW Mercury 50 gas turbine uses a recuperator to achieve 40 percent thermal efficiency in simple cycle operation. The first unit is scheduled for operation in 1999. The Mercury incorporates advanced DLN features to minimize NO<sub>x</sub> emissions. These advances include combustor liner modifications and variable geometry injectors. The emission goal of the Mercury 50 program is 9 ppm NO<sub>x</sub>.

Under a separate grant from the U.S. DOE, Rolls-Royce Allison developed a retrofit DLN silo combustor for its 501K (3-6MW) gas turbine known as the "Green Thumb" combustor. The combustor attained the 9 ppm NO<sub>x</sub> target in bench scale laboratory testing, but saw high emissions of CO (> 50 ppm) and unburned hydrocarbons (> 30 ppm). DOE is planning a field test of the Green Thumb concept.

## 1.2.2 Catalytic Combustion

Development of catalytic combustion is being funded by the DOE ATS program and is not yet commercialized in the marketplace. Catalytic technology features “flameless” combustion that occurs in a series of catalytic reactions to limit the temperature in the combustor. Catalytic combustors capable of achieving NO<sub>x</sub> levels below 3 ppm are entering commercialization. Catalytica Combustion Systems, Inc., Mountain View, CA, (Catalytica) has developed their Xonon™ catalytic combustion system, an all-metal catalyst substrate that eliminates the potential problems associated with the limitations of high temperature ceramic substrates. Maximum temperature reached in the catalyst is limited to approximately 1,700 °F to avoid damaging the metal substrate. All fuel and air is added upstream of the catalyst. Approximately 50 percent of the fuel is oxidized in the catalyst limiting the temperature rise to about 1,700 °F. The remaining 50 percent of the fuel is oxidized downstream of the catalyst. Catalytic combustion is one of the most promising new technologies to meet ever stricter emission limits.

Catalytica performed a successful 1,000 hour test of its Xonon™ catalytic combustor in a 1.5 MW Kawasaki gas turbine that concluded in mid-November 1997. Another 1.5 MW Kawasaki turbine located at a cogeneration plant in Santa Clara, California has been equipped with a catalytic combustor that began operation in October 1998. A 20 MW Turbo Power FT4 operated by the city of Glendale, CA, will also be retrofitted with a catalytic combustor in 1999. Xonon™ catalytic combustors have been tested in large GE turbines at the GE test facility in Schenectady, New York. NO<sub>x</sub> averaged less than 3 ppm and CO less than 5 ppm (corrected to 15 percent O<sub>2</sub>) during a test on a Frame 9E turbine. GE recently announced a Memorandum of Understanding with Catalytica to develop catalytic combustors for all GE turbine models through Frame 7E (78 MW). A second manufacturer of catalytic combustors, Precision Combustion, Inc. (New Haven, CT), has demonstrated the ability to operate on liquid fuel without significant NO<sub>x</sub> formation.

Catalytic combustion must be integrated with the combustor design of individual gas turbine models. Depending on the type of combustor design, development costs and subsequent



modification costs to the turbine may vary significantly among models and the various OEM gas turbine manufacturers. Durability of the catalyst module has not yet been proven and is major milestone towards commercialization.

### **1.2.3 Selective Catalytic Reduction**

The primary post-combustion NO<sub>x</sub> control method in use today is selective catalytic reduction (SCR). Ammonia is injected into the flue gas and reacts with NO<sub>x</sub> in the presence of a catalyst to produce N<sub>2</sub> and H<sub>2</sub>O. The SCR system is located in the exhaust path, typically within the HRSG where the temperature of the exhaust gas matches the operating temperature of the catalyst. The operating temperature of conventional SCR systems ranges from 400 – 800 °F. In the past two years, the cost of conventional SCR has dropped significantly. Catalyst innovations have been a principal driver, resulting in a 20 percent reduction in catalyst volume and cost with no change in performance.

Low temperature SCR, operating in the 300 – 400 °F temperature range, was commercialized in 1995 and is currently in operation on approximately twenty gas turbines. Low temperature SCR is ideal for retrofit applications where it can be located downstream of the HRSG. The relatively low operating temperature of the catalyst avoids the potentially expensive retrofit of the HRSG to locate the catalyst within the HRSG as would be required with conventional SCR.

High temperature SCR installations, operating in the 800–1,100 °F temperature range, have increased significantly from the single installation cited in the 1993 NO<sub>x</sub> ACT document. The high operating temperature permits the catalyst to be placed directly downstream of the turbine exhaust flange without tempering the exhaust with a HRSG. High temperature SCR is used on base-loaded simple cycle gas turbines where there is no HRSG.

#### **1.2.4 SCONO<sub>x</sub><sup>TM</sup> Catalytic Absorption System**

SCONO<sub>x</sub><sup>TM</sup>, patented by Goaline Environmental Technologies, is a post-combustion alternative to SCR that has been demonstrated to reduce NO<sub>x</sub> emissions to less than 1 ppm and almost 100% removal of CO. SCONO<sub>x</sub><sup>TM</sup> combines catalytic conversion of CO and NO<sub>x</sub> with an absorption/regeneration process that eliminates the ammonia reagent found in SCR technology. The SCONO<sub>x</sub><sup>TM</sup> system is generally located within the HRSG and under special circumstances may be located downstream of the HRSG. The system operates between 300-700°F. SCONO<sub>x</sub><sup>TM</sup> has been in operation on a General Electric LM2500 in the Los Angeles area since 1996. A second SCONO<sub>x</sub><sup>TM</sup> system is installed on a Solar Centaur 50 turbine located in Massachusetts. SCONO<sub>x</sub><sup>TM</sup> was identified as “Lowest Achievable Emission Rate (LAER)” technology for gas turbine NO<sub>x</sub> control by U.S. EPA Region 9 in 1998.

## **2.0 TECHNICAL DISCUSSION**

### **2.1 Introduction to Gas Turbines**


Over the last two decades, the gas turbine has seen tremendous development and market expansion. Whereas gas turbines represented only 20 percent of the power generation market twenty years ago, they now claim approximately 40 percent of new capacity additions. Some forecasts predict that gas turbines may furnish more than 80 percent of all new U.S. generation capacity in coming decades. Gas turbines have been long used by utilities for peaking capacity, however, with changes in the power industry and increased efficiency, the gas turbine is now being dispatched for baseload power. Much of this growth can be accredited to large (>50 MW) combined cycle plants which exhibit low capital cost (less than \$550/kW) and high thermal efficiency. Manufacturers are offering new and larger capacity turbines that operate at higher efficiencies.

Gas turbine development accelerated in the 1930's as a means of propulsion for jet aircraft. It was not until the early 1980's that the efficiency and reliability of gas turbines had progressed such that they were widely adopted for stationary power applications. Gas turbines range in size from 30 kW (microturbines) to 250 MW (industrial frames).

#### **2.1.1 Technology Description**

The thermodynamic cycle associated with the majority of gas turbines is the Brayton cycle, an open-cycle using atmospheric air as the working fluid. An open cycle means that the air is passed through the turbine only once. The thermodynamic steps of the Brayton cycle includes: 1) compression of atmospheric air, 2) introduction and ignition of fuel and 3) expansion of the heated combustion gases through the gas producing and power turbines. A stationary gas turbine consists of a compressor, combustor and a power turbine, as shown in Figure 2-1. The compressor provides pressurized air to the combustor where fuel is burned. Hot combustion gases leave the combustor and enter the turbine section where the gases are expanded across the

power turbine blades to rotate one or more shafts. These drive shafts power the compressor and the electric generator or prime mover. The simple cycle thermal efficiency of a gas turbine can range from 25 percent in small units to 40 percent or more in recuperated cycles and large high temperature units. The thermal efficiency of the most advanced combined cycle gas turbine plants is approaching 60 percent. The thermal efficiency of cogeneration applications can approach 80 percent where a major portion of the waste heat in the turbine exhaust is recovered to produce steam.



**Figure 2-1. Components of a Gas Turbine**

### 2.1.2 Gas Turbine Types

Aeroderivative gas turbines used for stationary power are adapted from their jet engine counterparts. These turbines are light weight and thermally efficient, however, are limited in capacity. The largest aeroderivatives are approximately 40 MW in capacity today. Many aeroderivative gas turbines for stationary applications operate with compression ratios of up to 30:1 requiring an external fuel gas compressor. With advanced system developments, aeroderivatives are approaching 45 percent simple cycle efficiencies.

Industrial or frame gas turbines are available between 1 MW to 250 MW. They are more rugged, can operate longer between overhauls, and are more suited for continuous base-load operation, however, they are less efficient and much heavier than the aeroderivative. Industrial gas turbines generally have more modest compression ratios of up to 16:1 and often do not require an external

compressor. Industrial gas turbines are approaching simple cycle efficiencies of up to approximately 40 percent and in combined cycles can approach 60 percent.

Small industrial gas turbines are being successfully used for onsite power generation and as mechanical drivers. Small gas turbines are used to drive compressors along natural gas pipelines to transport product across the country. In the petroleum industry they drive gas compressors to maintain well pressures. In the steel industry they drive air compressors used for blast furnaces. With the coming competitive electricity market, many experts believe that installation of small industrial gas turbines will proliferate as a cost effective alternative to grid power.

## **2.2 NO<sub>x</sub> Formation in Gas Turbines**

There are two mechanisms by which NO<sub>x</sub> is formed in turbine combustors: 1) the oxidation of atmospheric nitrogen found in the combustion air (thermal NO<sub>x</sub> and prompt NO<sub>x</sub>), and 2) the conversion of nitrogen chemically bound in the fuel (fuel NO<sub>x</sub>).

Thermal NO<sub>x</sub> is formed by a series of chemical reactions in which oxygen and nitrogen present in the combustion air dissociate and subsequently react to form NO<sub>x</sub>. The major contributing chemical reactions are known as the Zeldovich mechanism that occur in the high temperature area of the gas turbine combustor. The Zeldovich mechanism postulates that thermal NO<sub>x</sub> formation increases exponentially with increases in temperature and linearly with increases in residence time.

Prompt NO<sub>x</sub>, a form of thermal NO<sub>x</sub>, is formed in the proximity of the flame front as intermediate combustion products such as HCN, N, and NH that are oxidized to form NO<sub>x</sub>. Prompt NO<sub>x</sub> is formed in both fuel-rich flames zones and dry low NO<sub>x</sub> (DLN) combustion zones. The contribution of prompt NO<sub>x</sub> to overall NO<sub>x</sub> emissions is relatively small in conventional near-stoichiometric combustors, but this contribution is a significant percentage of overall thermal NO<sub>x</sub> emissions in DLN combustors. For this reason, prompt NO<sub>x</sub> becomes an important consideration for DLN combustor designs, establishing a minimum NO<sub>x</sub> level attainable in lean mixtures.

Fuel NO<sub>x</sub> is formed when fuels containing nitrogen are burned. Molecular nitrogen, present as N<sub>2</sub> in some kinds of natural gas, does not contribute significantly to fuel NO<sub>x</sub> formation. Some low-Btu synthetic fuels contain nitrogen in the form of ammonia (NH<sub>3</sub>). Other low-Btu fuels such as sewage and process waste-stream gases also contain nitrogen. When these fuels are burned, the nitrogen bonds break and some of the resulting free nitrogen oxidizes to form NO<sub>x</sub>. With excess air, the degree of fuel NO<sub>x</sub> formation is primarily a function of the nitrogen content in the fuel. The fraction of fuel-bound nitrogen (FBN) converted to fuel NO<sub>x</sub> decreases with increasing nitrogen content, although the absolute magnitude of fuel NO<sub>x</sub> increases. For example, a fuel with 0.01 percent nitrogen may have 100 percent of its FBN converted to fuel NO<sub>x</sub>, whereas a fuel with a 1.0 percent FBN may have only a 40 percent conversion rate. Natural gas typically contains little or no FBN. As a result, when compared to thermal NO<sub>x</sub>, fuel NO<sub>x</sub> is not a major contributor to overall NO<sub>x</sub> emissions from stationary gas turbines firing natural gas.

## **2.3 Factors that Affect NO<sub>x</sub> Formation in Gas Turbines**

The level of NO<sub>x</sub> formation in a gas turbine is unique to each gas turbine model and operating mode. The primary factors that determine the amount of NO<sub>x</sub> generated are the combustor design, fuel type, ambient conditions, operating cycles, and the power output of the turbine. These factors are discussed below.

### **2.3.1 Combustor Design**

The design of the combustor is the most important factor influencing the formation of NO<sub>x</sub>. Control of the air/fuel ratio, extent of pre-combustion mixing, operating load, introduction of cooling air, flame temperature and residence time are design parameters associated with combustor design that affect NO<sub>x</sub> formation.

### **2.3.2 Power Output Level**

The power output of a gas turbine is directly related to the firing temperature, which is directly related to flame temperature and the rate of thermal NO<sub>x</sub> formation. In conventional combustors, including DLN combustors operating at less than 50 percent load, fuel is injected into the base of the combustor. Air is injected along the length of the combustor to provide both combustion air and "quenching air" to cool the combustor exhaust gas before it reaches the turbine blades. A fuel rich environment is maintained in the immediate vicinity of the fuel injector. As the fuel diffuses into the combustion/cooling air supply, combustion takes place. At low loads, the reaction kinetics are such that combustion proceeds at a relatively rich fuel ratio and combustion products are quenched rapidly. At high load, the flame front reaches its maximum size and length. There is also greater turbulence in the combustor, resulting in a greater percentage of the fuel being combusted in "hot spots" at or near stoichiometric conditions with less air available to quench the products of combustion. As a result, NO<sub>x</sub> emissions are greatest at high load.

### **2.3.3 Type of Fuel**

NO<sub>x</sub> emissions vary depending on fuel type. For gaseous fuels, the constituents in the gas can significantly affect NO<sub>x</sub> emissions levels. Gaseous fuel mixtures containing hydrocarbons with molecular weights higher than that of methane (such as ethane, propane and butane) burn at higher flame temperatures and can increase NO<sub>x</sub> emissions greater than 50 percent over NO<sub>x</sub> levels for methane. Refinery gases and some unprocessed field gases contain significant levels of these higher molecular weight hydrocarbons.

Conversely, gaseous fuels that contain significant inert gases, such as CO<sub>2</sub>, generally produce lower NO<sub>x</sub> emissions. These inert gases absorb heat during combustion, thereby lowering flame temperatures and reducing NO<sub>x</sub> emissions. Examples include air-blown gasifier fuels and some field gases.

Combustion of hydrogen produces high flame temperatures and gases with significant hydrogen content produce relatively high NO<sub>x</sub> emissions. Distillate oil burns at a flame temperature that is approximately 150 °F higher than that of natural gas and produces higher NO<sub>x</sub> emissions. Low-

Btu fuels such as coal gas burn with lower flame temperatures and produce lower thermal NO<sub>x</sub> emissions.

### **2.3.4 Ambient Conditions**

Ambient conditions that affect NO<sub>x</sub> emissions are humidity, temperature, and pressure. Humidity has the greatest effect since water vapor quenches combustion temperatures that reduces thermal NO<sub>x</sub> formation. At low humidity levels, NO<sub>x</sub> emissions increase with increases in ambient temperature. At high humidity levels, changes in ambient temperature has a varied effect on NO<sub>x</sub> formation. At high humidity levels and low ambient temperatures, NO<sub>x</sub> emissions increase with increasing temperature. Conversely, at high humidity levels and ambient temperatures above 50 °F, NO<sub>x</sub> emissions decrease with increasing temperature. Higher ambient pressure causes elevated temperature levels in the combustor, promoting NO<sub>x</sub> formation.

### **2.3.5 Operating Cycles**

NO<sub>x</sub> emissions from identical turbines used in simple cycle, combined cycle, and cogeneration cycles are essentially equivalent and independent of downstream exhaust gas temperature reductions. Duct burners are typically used in combined cycle and cogeneration installations to boost exhaust gas temperature upstream of the HRSG. Duct burner emissions are controlled by post-combustion control systems such as SCR or low NO<sub>x</sub> duct burners that guarantee emission levels as low as 0.08 lb NO<sub>x</sub> per MMBtu heat input. Duct burner NO<sub>x</sub> emission test results included in the 1993 NO<sub>x</sub> ACT document indicate that in some cases NO<sub>x</sub> emissions are reduced across the duct burner. The reason for this net NO<sub>x</sub> reduction is not known, but is believed to be a result of a reburning process in which intermediate combustion products from the duct burner interact with the NO<sub>x</sub> already present in the gas turbine exhaust.

## **2.4 BACT/LAER Determinations**

A listing of recent BACT/LAER Clearinghouse entries for gas turbine installations is shown in Table 2-1. A permit limit of 2.0 ppm NO<sub>x</sub> at 15 percent O<sub>2</sub> is currently the lowest “demonstrated



in practice” NO<sub>x</sub> emission rate. To achieve NO<sub>x</sub> concentrations below 25 ppm, SCR was employed at all sites. Older projects typically used water/steam injection as a pre-treatment while new projects had turbines equipped with DLN in combination with SCR.

**Table 2-1  
Summary of Recent Gas Turbine BACT/LAER Determinations**

Site	Turbine	Rated Output (MW)	Emission Limits (ppm corrected to 15 percent O <sub>2</sub> )						Year Permitted
			NO <sub>x</sub>	CO	VOC	PM <sub>10</sub>	SO <sub>2</sub>	NH <sub>3</sub>	
<b>California:</b>									
ARCO Carson	GE Frame 6	45	3.5	Not requested					1997
Federal Cogen	GE LM5000	34	2.5 2.0	Not requested					1996 1998
Badger Creek	GE Frame 6	48	3.8	11	5.3	NG	NG	20	1994
Goal Line, Escondido	GE LM6000	42	5	25	NG	NG	NG	10	1992
Northern CA Power	GE Frame 6	45	3.0	6.0	0.29 lb/MM Btu	NG	NG	25	1991
<b>Other States:</b>									
Brooklyn Navy Yard, NY	Seimens V84.2	106	3.5 (gas) 10 (oil)	Not requested					1995
K/B Syracuse, NY	Seimens V64.3	63	25	Not requested					1994
Lockport Cogen, NY	GE Frame 6	45	42	Not requested					1993
Tenaska, WA	GE Frame 7FA	164	7.0	Not requested					1992
Sithe, NY	GE Frame 7FA	164	4.5	Not requested					1992

NG: natural gas

## 2.5 NO<sub>x</sub> Emission Control Technologies

The most common NO<sub>x</sub> control method for new combined cycle power plants is a DLN combustor combined with SCR to maintain NO<sub>x</sub> emission levels at or below 5 ppm. Steam or water injection combined with SCR is also used at a number of existing installations to maintain

NO<sub>x</sub> emission levels at or below 5 ppm. Often the decision to use water or steam injection over DLN is based on end-user familiarity and the slightly lower first cost of the water/steam injection system. Various gas turbine NO<sub>x</sub> emission control technologies are discussed below.

### **2.5.1 Water/Steam Injection**

Water or steam injection is a very mature technology, having been used since the 1970's to control NO<sub>x</sub> emissions from gas turbines. Simultaneous mixing of fuel and air and subsequent combustion results in localized fuel-rich zones within the combustor that yield high flame temperatures. Injecting water or steam into the flame area of the combustor provides a heat sink that lowers the flame temperature and reduces thermal NO<sub>x</sub> formation. The "water-to-fuel ratio" (WFR) has a direct impact on the controlled NO<sub>x</sub> emission rate and is generally controlled by the turbine inlet temperature and ambient temperature. Products of incomplete combustion, carbon monoxide (CO) and unburned hydrocarbons (UHC) increase as more water or steam is added to quench the peak flame temperature. Based on Solar Turbines' experience, WFR's of up to 0.6-0.8 generally result in little or no increase in CO and UHC. A WFR above 0.8 generally produces an exponential rise in the CO and UHC emission rates.

Water impingement on the combustor liner limits the maximum practical water injection rate, as direct water impingement results in rapid liner wear. Impingement is not an issue with steam injected turbines meaning that significantly higher steam mass flow rates are practical in steam injected turbines.

The high cost of producing large amounts of purified water or steam, water impingement, and control of CO and UHC emissions have slowed the use of water/steam injection systems in favor of DLN combustors over the last five years.

### **2.5.2 Dry Low NO<sub>x</sub> (DLN) Combustors**

DLN combustor technology premixes air and a lean fuel mixture that significantly reduces peak flame temperature and thermal NO<sub>x</sub> formation. Conventional combustors are diffusion

controlled where fuel and air are injected separately. Combustion occurs locally at stoichiometric interfaces resulting in hot spots that produce high levels of NO<sub>x</sub>. In contrast, DLN combustors generally operate in a premixed mode where air and fuel are mixed before entering the combustor. The underlying principle is to supply the combustion zone with a completely homogenous, lean mixture of fuel and air. DLN combustor technology generally consists of hybrid combustion, combining diffusion flame (for low loads) plus DLN flame combustor technology (for high loads.) Due to the flame instability limitations of the DLN combustor below approximately 50 percent of rated load, the turbine is typically operated in a conventional diffusion flame mode until the load reaches approximately 50 percent. As a result, NO<sub>x</sub> levels rise when operating under low load conditions. For a given turbine, the DLN combustor volume is typically twice that of a conventional combustor.

A notable exception to this is the sequential combustion DLN technology developed by ABB for the GT24 (166 MW) and GT26 (241 MW) power generation turbines. Combustion takes place in the primary DLN combustor (EV™) followed by fuel addition in a second (SEV™) combustion chamber located aft of the first row of turbine blades. This DLN technology was commercialized in 1997 and permits DLN operation across the load range of the turbine.

O&M costs for turbines equipped with DLN can be significantly higher than predicted due to a variety of factors including replacement of blades and vanes, redesigned bearings, lift pumps and combustor sensitivity to changes in fuel composition. The high operating temperatures of advanced turbines can cause creep damage in the first stage blades, requiring frequent inspections and blade replacement. Another issue with DLN combustors is “flashback,” where fuel upstream of the burner ignites prematurely damaging turbine components. DLN combustors tend to create harmonics in the combustor that result in significant vibration and acoustic noise.

Virtually all DLN combustors in commercial operation are designed for use with gaseous fuels. Some manufacturers are now offering dual fuel (gas and diesel) DLN combustors. DLN operation on liquid fuels has been problematic due to issues involving liquid evaporation and auto-ignition.

DLN combustion is essentially free of carbon formation especially when gaseous fuels are used. The absence of carbon not only eliminates soot emissions but also greatly reduces the amount of heat transferred to the combustor liner walls by radiation and the amount of air needed for liner wall cooling. More air is available for lowering the temperature of the combustion zone and improving the flow pattern in the combustor.

At very lean premix conditions, the formation of  $\text{NO}_x$  is nearly independent of residence time meaning that under these conditions, DLN systems can also achieve low levels of CO and UHC which require long residence times in the combustor for effective reduction.

GE Power Systems, Siemens-Westinghouse, and ABB have concentrated on turbines greater than 50 MW for their DLN development. It is likely that these DLN improvements will eventually become available in smaller gas turbines. GE has reduced  $\text{NO}_x$  emissions from 25 ppm to 9-15 ppm in its “can-annular” DLN combustor for its “Frame” industrial gas turbines. GE has guaranteed 9 ppm  $\text{NO}_x$  for a limited number of Frame 6 and Frame 7 turbine installations with rated outputs from 70 to 171 MW, respectively. Although hardware costs are approximately the same whether the turbine is guaranteed at 9 or 15 ppm, O&M cost is increased at the lower emission rate due to more rigorous maintenance requirements.

### **2.5.3 Catalytic Combustion**

The strong dependence of  $\text{NO}_x$  formation on flame temperature means that  $\text{NO}_x$  emissions are lowest when the combustor is operating close to the lean flameout limit. One method of extending the lean flameout limit to lower fuel-air ratios is by incorporating a combustion-enhancing catalyst within the combustor. Catalytic combustion is a flameless process, allowing fuel oxidation to occur at temperatures approximately 1,800 °F lower than those of conventional combustors. Catalytic combustors are being developed to control  $\text{NO}_x$  emissions down to 3 ppm. Preliminary test data indicates that catalytic combustion exhibits low vibration and acoustic noise that are one-tenth to one-hundredth the levels measured in the same turbine equipped with DLN combustors.

One problem with catalytic combustors is the potential auto-ignition of the fuel upstream of the catalyst. Although the air-fuel ratios are well below the lean flammability limit and in theory should not be susceptible to auto-ignition, local pockets of rich fuel mixtures can exist near the fuel injector and ignite. Mixing must be achieved quickly to prevent fuel rich pockets from forming. Optimum catalyst performance also requires the inlet air-fuel mixture to be of completely uniform temperature, composition, and velocity profile since this assures effective use of the entire catalyst area and prevents damage to the substrate due to local high gas temperatures.

A major unknown with catalytic combustors is the durability of the catalyst. Research suggests that the catalyst will deteriorate during prolonged operation at high temperature. Thermal degradation results from loss of surface area caused by sintering and volatilization of active metals, such as platinum, which oxidizes at temperatures above 2,010 °F.

#### **2.5.4 Selective Catalytic Reduction (SCR)**

The SCR process consists of injecting ammonia upstream of a catalyst bed. NO<sub>x</sub> combines with the ammonia and is reduced to molecular nitrogen in the presence of the catalyst. SCR is capable of over 90 percent NO<sub>x</sub> reduction and can be combined with DLN or water/steam injection to achieve NO<sub>x</sub> outlet concentrations of 5 ppm or less at 15 percent O<sub>2</sub> when firing on natural gas. Titanium oxide is the SCR catalyst material most commonly used, however, vanadium pentoxide, noble metals, and zeolites are also used. For conventional SCR catalysts, the catalyst reactor is normally mounted on a “spool piece” located within the HRSG at a location where the gas temperature is between 600 to 750 °F.

A certain amount of ammonia “slips” through the process unreacted. Local regulations usually limit ammonia slip to 10-20 ppm at 15 percent O<sub>2</sub>. Ammonia passing through the SCR and emitted to atmosphere can combine with nitrate (NO<sub>3</sub>) or sulfate (SO<sub>4</sub>) in the ambient air to form a secondary particulate, either ammonium nitrate or ammonium bisulfate. The formation of ammonium bisulfate while firing on diesel fuel with a high sulfur content has been responsible

for fouling HRSG tubes downstream of the SCR. Operating data indicates that a sulfur limit of 0.05 percent will prevent HRSG tube fouling .

The Northern California Power (NCP) combined-cycle power plant located in the San Joaquin Valley, CA is a 45 MW facility consisting of a single GE Frame 6 turbine using steam injection and SCR to achieve a permitted NO<sub>x</sub> limit of 3.0 ppm. The NCP installation achieves the 3.0 ppm NO<sub>x</sub> level through very high rates of ammonia injection, having an ammonia slip limit of 25 ppm. The combined cycle power plant at the Brooklyn Navy Yard that became operational in 1996 has 106 MW Siemens V84.2 water-injected gas turbines equipped with SCR to achieve the 3.5 ppm NO<sub>x</sub> permit limit.

### **2.5.5 SCONO<sub>x</sub><sup>TM</sup> Catalytic Absorption System**

In 1998, the U.S. EPA certified an innovative catalytic NO<sub>x</sub> reduction technology, SCONO<sub>x</sub><sup>TM</sup>, as a “demonstrated in practice” LAER-level technology for gas turbine NO<sub>x</sub> reduction to below 5 ppm. SCONO<sub>x</sub><sup>TM</sup> employs a precious metal catalyst and a NO<sub>x</sub> absorption/regeneration process to convert CO and NO<sub>x</sub> to CO<sub>2</sub>, H<sub>2</sub>O and N<sub>2</sub>. NO<sub>x</sub> binds to the potassium carbonate absorbent coating the surface of the oxidation catalyst in the SCONO<sub>x</sub><sup>TM</sup> reactor. Each “can” within the reactor becomes saturated with NO<sub>x</sub> over time and must be desorbed. Regeneration is accomplished by isolating the can via stainless steel louvers and injecting hydrogen diluted with steam. Hydrogen is generated at the site with a small reformer that uses natural gas and steam as input streams. The hydrogen concentration of the reformed gas is typically 5 percent. The hydrogen reacts with the absorbed NO<sub>x</sub> to form N<sub>2</sub> and H<sub>2</sub>O, regenerating the potassium carbonate for another absorption cycle. The principal advantages of the SCONO<sub>x</sub><sup>TM</sup> technology over SCR are the elimination of ammonia emissions and the simultaneous reduction of CO, VOCs and NO<sub>x</sub>.

A SCOSO<sub>x</sub><sup>TM</sup> catalytic coating can also be added to the oxidation catalyst to effectively remove SO<sub>2</sub> from the exhaust gas. If an SO<sub>2</sub> absorbent is added, the “can” is desorbed in the same

manner, resulting in the formation of H<sub>2</sub>S. Regeneration gases are then passed through an H<sub>2</sub>S scrubber to remove the captured sulfur.

A GE LM5000 (32 MW) turbine located at the Federal Cogeneration facility in the Los Angeles area was retrofitted with a SCONO<sub>x</sub><sup>TM</sup> catalytic NO<sub>x</sub> reduction system in 1996. This installation demonstrated a 2.5 ppm NO<sub>x</sub> standard over a six-month period from December 1996 to June 1997. In 1998 over a six month period, the same installation achieved emission rates that are consistently at or below 2.0 ppm. U.S. EPA Region 9 has identified SCONO<sub>x</sub><sup>TM</sup> as a “demonstrated in practice” Lowest Achievable Emission Rate (LAER)-level control technology based on this six-month compliance demonstration. A second SCONO<sub>x</sub><sup>TM</sup> installation is operational on a Solar Centaur 50 turbine located at an industrial facility in Massachusetts.

### **2.5.6 Rich-Quench-Lean (RQL) Combustors**

RQL combustion is not yet commercially available and is therefore not presented in the cost comparison. However, because RQL promises to achieve significant emission reductions, it is discussed herein as an important new technology that requires monitoring. The RQL concept is under development and uses staged burning to achieve low NO<sub>x</sub> emission levels. Combustion is initiated in a fuel-rich primary zone that reduces NO<sub>x</sub> formation by lowering both the flame temperature and the available O<sub>2</sub>. The hydrocarbon reactions proceed rapidly, causing depletion of O<sub>2</sub> that inhibits NO<sub>x</sub> formation. Higher fuel-air ratios is limited by excessive soot and smoke formation.

As the fuel-rich combustion products flow out of the primary zone, jets of air rapidly reduce the gas temperature to a level at which NO<sub>x</sub> formation is minimal. Transition from a rich zone to a lean zone must take place rapidly to prevent NO<sub>x</sub> formation. The ability to achieve near-instantaneous mixing in this “quick quench” region is the key to the success of the RQL concept. An important design consideration is controlling the temperature of the lean-burn zone. The temperature must be high enough to eliminate any remaining CO and UHC, however, not too high so as to limit the formation of thermal NO<sub>x</sub>.

Most of the research conducted indicates that the RQL concept has potential for ultra-low NO<sub>x</sub> combustion. RQL requires only one stage of fuel injection that simplifies fuel metering. Significant improvements in the quench mixer design are necessary before this technology is ready for commercialization. Other inherent problems include high soot formation in the rich primary zone that promotes high flame radiation and exhaust smoke. These problems are exacerbated by long residence times, unstable recirculation patterns, and non-uniform mixing.



## 3.0 NO<sub>x</sub> CONTROL COST ESTIMATES

### 3.1 Methodology

Tables A-1 through A-7 (Appendix A) provide detailed cost estimates and cost impact factors (“\$/ton” and “¢/kWh”) for each NO<sub>x</sub> control technology evaluated in this study.

The cost estimation procedure used in this study is provided in the EPA’s Control Cost Manual, 5th Edition (1996). Capital costs are estimated as the sum of the purchased equipment cost, taxes and freight charges, and installation costs. Purchased equipment costs are based on quotes provided by equipment manufacturers. Taxes, freight, and installation costs are estimated as fixed fractions of purchased equipment cost based on OAQPS cost factors. O&M costs are based on manufacturer or operator estimates (when available) or OAQPS cost factors. The OAQPS estimates an accuracy of  $\pm 30$  percent for the factored cost estimation procedure. The annualized capital cost of the installed control equipment is based on a 15-year, 10 percent capital recovery factor as used in the 1993 NO<sub>x</sub> ACT document. EPA capital cost factors for modular, prefabricated control equipment have been used except for low temperature SCR which have been installed in retrofit applications and require considerable modifications.

### 3.2 Uncontrolled NO<sub>x</sub> Emission Rate

The uncontrolled NO<sub>x</sub> emission rates used in this study are referenced from Tables 6-12 through 6-14 of the 1993 NO<sub>x</sub> ACT document. The uncontrolled NO<sub>x</sub> emission rates of different turbine models vary considerably from 134 ppm (Solar Centaur 50) to 430 ppm (ABB GT8). NO<sub>x</sub> control cost effectiveness (“\$/ton”) will be significantly less for turbines with very high uncontrolled NO<sub>x</sub> emissions even though the annualized cost of the NO<sub>x</sub> control system may be comparable to other turbines in its output range.

### 3.3 NO<sub>x</sub> Control Technology Cost Estimates

A discussion of the cost estimates obtained from various manufacturers of gas turbines and NO<sub>x</sub> control technologies are found in the following subsections. Table 3-1 summarizes the turbine models in each power output class that were used for the NO<sub>x</sub> technology comparisons. Note that information obtained from manufacturers was restricted to turbine projects readily available at the time of the inquiry and explains why there is not emission technology information provided for each gas turbine model listed in Table 3-1.

**Table 3-1  
Summary of Turbine Models Used in the Cost Comparison**

	MW Output (approx)	DLN	Catalytic Combustion	Water/Steam Injection	Conventional SCR	High Temp SCR	SCONO <sub>x</sub> <sup>™</sup>	Low Temp SCR
Allison 501-KB5	4			X				X
Allison 501-KB7	5	X						
Solar Centaur 50	4	X		X	X		X	
Solar Taurus 60	5	X				X		
Generic	5		X					
GE LM2500	23	X		X	X	X	X	X
GE Frame 5	26		X					
GE Frame 7FA	170	X	X		X	X	X	
GE MS70001F	160			X				

The cost estimates do not include the cost of continuous emissions monitoring (CEM). Although CEM systems are required for SCONO<sub>x</sub> and SCR for process reasons, CEM systems are typically required on all base-loaded gas turbine systems to comply with local air permitting regulations and affect all control technologies equally.

### 3.3.1 DLN Cost Estimates

The cost of DLN combustors can vary dramatically for the same size turbine offered by different manufacturers. As an example, the incremental cost of a DLN combustor for a new Solar Taurus 60 turbine (5.2 MW) is approximately \$180,000. The incremental cost of a DLN combustor for a Rolls-Royce Allison 501-KB7 turbine (5.1 MW) is \$20,000. The cost discrepancy is related to performance capabilities, design complexity and reliability/maintenance factors.

There have been significant changes in DLN unit cost and manufacturer's NO<sub>x</sub> emission guarantees since the 1993 NO<sub>x</sub> ACT document was published. The available data used in the 1993 NO<sub>x</sub> ACT document may have been limited to a single turbine manufacturer, especially for DLN technology, which was just being commercialized at the time. The DLN annual cost for small turbines (5 MW) has dropped by about 50 percent compared to information in the 1993 NO<sub>x</sub> ACT document. The current DLN cost for 25 MW turbines appears relatively unchanged. DLN costs were not presented for large turbines (150 MW) in the 1993 NO<sub>x</sub> ACT document. DLN cost data is now available for a number of large turbines. The current cost of DLN for the GE Frame 7FA (170 MW) is used in this study.

### 3.3.2 Solar Turbines Water Injection and DLN Cost Estimate

Solar Turbines provided the incremental cost of water injection and DLN compared to a conventional diffusion combustor for two turbine models as shown in Table 3-2.

**Table 3-2**  
**Incremental Water Injection and DLN Costs**

Turbine Model	Size (MW)	Fuel	Price Range (\$million)	Incremental Cost for Water Injection	Incremental Cost for DLN
Centaur 50	4.3	natural gas	1.5-3.4	\$45,000-\$96,000	\$145,000-\$190,000
Taurus 60	5.2	natural gas	1.7-3.6	\$45,000-\$96,000	\$165,000-\$190,000

The Solar DLN combustor has been in commercial operation since 1992 and is described in the 1993 NO<sub>x</sub> ACT document. The combustor operates in conventional diffusion flame mode over the 0 to 50 percent load range. The DLN injectors operate over the 50 to 100 percent load range. The Solar DLN combustor is designed to operate in harsh unattended environments in electrical generation and mechanical drive applications. R&D efforts have focused on producing a robust DLN combustor with the reliability and durability of conventional combustors. Many of Solar's customers are in the gas and oil industry who require very reliable turbines.

Solar Turbines indicates that there is an incremental cost for routine O&M of the DLN combustors compared to their conventional combustor. The company also indicated that major overhaul of the DLN is more expensive than major overhaul of a conventional combustor. The differential maintenance and overhaul cost between DLN and conventional combustor is considered proprietary by Solar Turbines and is not included in the cost estimate. Therefore, the estimated cost effectiveness (\$/ton) and electricity impact (¢/kWhr) for the Solar Turbine DLN models in Appendix A, Table A-2 are low relative to the other turbine models in the table.

### **3.3.3 Rolls-Royce Allison DLN Cost Estimate**

The Rolls-Royce Allison DLN combustor, known as the LE4, entered commercial operation in 1996. The LE4 is a much simpler unit than Solar's DLN combustor since a conventional diffusion injector is used. The Rolls-Royce Allison combustor is designed for a different market that does not require the same level of investment undertaken by Solar Turbines. The LE4 is specifically designed for baseload industrial power applications and has very little turndown capability. The incremental cost of a LE4 combustor for a Rolls-Royce Allison 501-KB7 turbine (5.1 MW) is \$20,000. Incremental annual O&M costs are estimated at \$4/fired-hour or approximately \$32,000/yr and currently exceed the LE4 capital cost. The high O&M cost is primarily related to the fuel management system, however, incremental O&M costs are expected to drop to below \$1/fired-hour in the near future.

### **3.3.4 GE LM2500 Water Injection and DLN Cost Estimate**

GE Industrial and Marine indicated that the incremental capital cost of water injection for the LM2500 (23 MW) is \$100,000.

The incremental capital cost of a DLN combustor for the LM2500 is \$800,000. The incremental O&M cost for a LM2500 was estimated at \$10-20/fired-hour that includes the cost of periodic major overhaul of the DLN combustor. The LM2500 is an aeroderivative turbine with an annular combustor. Combustor overhaul is more complex in the LM2500 than in an industrial turbine equipped with can-annular combustors, such as the General Electric Frame 7FA, since the individual combustor “cans” are modular and can be removed and replaced quickly.

### **3.3.5 GE Frame 7FA DLN Cost Estimate**

GE Power Systems indicated that the cost to replace an existing steam-injected Frame 7FA combustor with a DLN combustor is \$4,500,000 (installed). A definitive O&M cost for the Frame 7FA equipped with DLN has not been determined by GE Power Systems. GE Power Systems indicated that large baseload units such as the Frame 7FA are provided with spare combustors that are typically rotated every 8,000 to 12,000 hours. Combustor rotation eliminates the need for a separate 30,000 to 40,000 hour major combustor overhaul as is typical with smaller industrial units equipped with annular combustors.

### **3.3.6 Catalytica Combustor Cost Estimate**

Catalytica provided estimates based on the anticipated performance of their Xonon™ catalytic combustion technology which is not fully commercialized. The cost estimates assume catalyst replacement on an annual basis, however, catalyst life is currently being tested at several gas turbine installations. Catalyst durability is an important milestone towards commercialization that has not been currently demonstrated.

Catalytica provided “production run” cost estimates of their catalyst module including an allowance for turbine package modifications. Their cost does not include development costs which could be substantial for turbine OEMs depending on specific turbine and combustor designs. The costs provided by Catalytic do not imply that their technology will be applied to the engines represented in the comparison in Table A-3.

Catalyst life is estimated at one (1) year based on a guaranteed life offered by Catalytica.

### **3.3.7 MHIA Conventional SCR Cost Estimate**

Mitsubishi Heavy Industries America (MHIA) is the principal supplier of conventional SCR to the gas turbine market in the U.S. According to MHIA, advances in SCR technology in the past two years have resulted in a 20 percent reduction in the amount of catalyst required to achieve a given NO<sub>x</sub> target level. In addition, experience gained in the design and installation of SCR units has lowered engineering costs. These two factors have substantially reduced the cost of SCR systems since the 1993 NO<sub>x</sub> ACT document. Operating costs have been reduced through innovations such as using hot flue gas to pre-heat ammonia injection air which lowers the power requirements of the ammonia injection system. Manufacturer’s data uses water/steam injection as an upstream treatment (42 ppm of NO<sub>x</sub> inlet to SCR).

Conventional SCR must be placed between sections of the HRSG so that the catalyst operates at the correct temperature. Obviously, this requirement is more cost effective when the HRSG is fitted in the shop rather than in a field retrofit. The cost estimate presented in Appendix A does not include any additional costs associated with modifying the HRSG to accept the SCR. The cost of this modification is dependent on the particular design and in many cases is not a significant cost adder.

Catalyst life is estimated at seven (7) years based on industry operating experience and is not a guaranteed life offered by SCR manufacturers.

### **3.3.8 Tecnip Low Temperature SCR Cost Estimate**

Tecnip (formerly Kinetics Technology International) manufactures a low temperature SCR that is designed for retrofit installations with single digit NO<sub>x</sub> emission targets. Low temperature SCR systems are installed downstream of an existing HRSG and avoid modification of the HRSG that would be required to accommodate a conventional SCR system. Manufacturer's data uses no pre-treatment for NO<sub>x</sub>.

### **3.3.9 Engelhard High Temperature SCR Cost Estimate**

The high temperature SCR provided by Engelhard uses a zeolite catalyst to permit continuous operation at temperatures up to 1,100 °F. The high temperature resistance of the zeolite catalyst allows for SCR installations on base-loaded simple cycle gas turbines (no heat recovery.) Simple cycle gas turbines generally have exhaust temperatures ranging from 950 to 1,050 °F at rated load. At part loads, exhaust temperatures can be 100 °F higher than rated conditions and can cause performance to decline. Prolonged exposure over 1,100°F can cause slightly lower performance due to thermal aging. To prevent damage at sustained part load operation where temperatures will be above 1,100°F, a tempering air system may be included to moderate exhaust temperatures. Manufacturer's data uses water/steam injection as an upstream treatment (42 ppm of NO<sub>x</sub> inlet to SCR).

### **3.3.10 SCONO<sub>x</sub><sup>TM</sup> Cost Estimate**

The cost of the SCONO<sub>x</sub><sup>TM</sup> system has remained relatively constant since its introduced in 1996. The technology has witnessed several design changes since its inception that have had positive and negative impacts to cost; two examples follow. The original unit was designed with a “space velocity” of 30,000 ft<sup>3</sup> hour exhaust gas per /ft<sup>3</sup> catalyst (ft<sup>3</sup>-hour/ft<sup>3</sup>). The space velocity has since been reduced to 20,000 ft<sup>3</sup>-hour/ft<sup>3</sup> to meet the standard NO<sub>x</sub> emission outlet guarantee of 2 ppm. Two actuators instead of one control the isolation louvers for each catalyst module to improve reliability.

Note that the  $\text{SCONO}_x^{\text{TM}}$  cost estimate used for the 150 MW gas turbine size classification was obtained for an 83 MW turbine and scaled accordingly. Manufacturer's data uses 25 ppm of  $\text{NO}_x$  inlet, achieved with DLN as an upstream pre-treatment.

Most applications place the  $\text{SCONO}_x^{\text{TM}}$  system between sections of the HRSG so that the catalyst operates at the correct temperature. According to the manufacturer,  $\text{SCONO}_x^{\text{TM}}$  can be reliably operated throughout a range of 300-700°F, meaning that the technology may be installed downstream of the HRSG. The cost estimate presented in Appendix A does not include any additional costs associated with modifying the HRSG to accept  $\text{SCONO}_x^{\text{TM}}$  since the cost adder is dependent on the specific application and may be relatively low or not applicable.

### **3.4 Results and Conclusions**

Table 3-3 summarizes the “cost per ton of  $\text{NO}_x$  removed” (\$/ton) and the “electricity cost impact” (“\$/kWh”) for each  $\text{NO}_x$  control technology. The cost comparisons assume natural gas fuel.

The cost effectiveness of a technology - “\$/ton” indicates the typical cost of a technology to remove a ton of  $\text{NO}_x$  from the exhaust gas. The “\$/ton” value is determined by dividing the owning cost of the  $\text{NO}_x$  control technology by the tons of  $\text{NO}_x$  removed. Owning costs consist of capital, operating and maintenance costs. The “\$/ton” value is a useful comparative indicator when the inlet and outlet  $\text{NO}_x$  concentrations are the same for each group of technologies being evaluated.  $\text{NO}_x$  can be controlled to within a feasible limit for a particular technology and is largely independent of a gas turbine's uncontrolled  $\text{NO}_x$  emission rate. Therefore the uncontrolled  $\text{NO}_x$  exhaust concentrations must be considered when evaluating the “\$/ton” cost effectiveness values applied to different makes/models of turbines to obtain a meaningful comparison. For example, SCR is typically used on installations that are also controlled by water/steam injection or DLN. Conventional SCR inlet concentrations typically range from 25 to 42 ppm (corrected to 15 percent  $\text{O}_2$ ). In contrast, all low temperature SCR installations to date have been installed on uncontrolled turbines with  $\text{NO}_x$  concentrations ranging from 100 to 132 ppm. As a result, the low temperature SCR has a favorable “\$/ton” cost effectiveness when



compared to the conventional SCR, although the “¢/kWh” cost of the low temperature SCR is significantly higher.

The “¢/kWh” value provides the electricity cost impact of a particular NO<sub>x</sub> control technology and is independent of the tons of NO<sub>x</sub> removed. The “¢/kWh” represents a unit cost for NO<sub>x</sub> control that must be added to other owning costs associated with the gas turbine project. The “¢/kWh” value is determined by dividing the owning cost of the NO<sub>x</sub> control technology by the amount of electricity generated by the gas turbine. A comparison between “¢/kWh” values is most meaningful for technologies that control NO<sub>x</sub> to an equivalent “ppm” concentration.

**Table 3-3**  
**Comparison of 1993 and 1999 NO<sub>x</sub> Control Costs for Gas Turbines**

NO <sub>x</sub> Control Technology	Turbine Output (MW)	Emission Reduction (ppm)	1993		1999	
			\$/ton	¢/kWh	\$/ton	¢/kWh
Water/steam	4-5	unc. → 42	1,750-2,100	0.47-0.50	1,500-1,900	0.39-0.43
DLN	4-5	unc. → 42	820-1,050	0.16-0.19	NA <sup>b</sup>	NA
DLN	4-5	unc. → 25	NA <sup>b</sup>	NA	270-300	0.06-0.09
Catalytic <sup>a</sup>	4-5	unc. → 3	NA	NA	1,000	0.32
Low temp. SCR	4-5	42 → 9	NA	NA	5,900	1.06
Conventional SCR	4-5	42 → 9	9,500-10,900	0.80-0.93	6,300	0.47
High temp. SCR	4-5	42 → 9	9,500-10,900	0.80-0.93	7,100	0.53
SCONO <sub>x</sub> <sup>™</sup>	4-5	25 → 2	NA	NA	16,300	0.85
Water/steam	20-25	unc. → 42	980-1,100	0.24-0.27	980	0.24
DLN	20-25	unc. → 25	530-1,050	0.16-0.19	210	0.12
Catalytic <sup>a</sup>	20-25	unc. → 3	NA	NA	690	0.22
Low temp. SCR	20-25	42 → 9	NA	NA	2,200	0.43
Conventional SCR	20-25	42 → 9	3,800-10,400	0.30-0.31	3,500	0.20
High temp. SCR	20-25	42 → 9	3,800-10,400	0.30-0.31	3,800	0.22
SCONO <sub>x</sub> <sup>™</sup>	20-25	25 → 2	NA	NA	11,550 <sup>c</sup>	0.46 <sup>c</sup>
Water/steam	160	unc. → 42	480	0.15	480 <sup>d</sup>	0.15 <sup>d</sup>
DLN	170	unc. → 25	NA	NA	124	0.05
DLN	170	unc. → 9	NA	NA	120	0.055
Catalytic <sup>a</sup>	170	unc. → 3	NA	NA	371	0.15
Conventional SCR	170	42 → 9	3,600	0.23	1,940	0.12
High temp.	170	42 → 9	3,600	0.23	2,400	0.13

SCR						
SCONO <sub>x</sub> <sup>TM</sup>	170	25 → 2	NA	NA	6,900 <sup>c</sup>	0.29 <sup>c</sup>

Notes:

- (a) Costs are estimated, based on Catalytica's "Xonon<sup>TM</sup>" catalytic combustor technology which is just entering commercial service. Annualized cost estimates provided by the manufacturer are not based on "demonstrated in practice" installations.
- (b) "NA" means technology that was not available in 1993, or technology that is obsolete in 1999.
- (c) The SCONO<sub>x</sub><sup>TM</sup> manufacturer provided a quote for a 83 MW unit. The quote has been scaled to the appropriate unit size.
- (d) The one baseload Frame 7F installed in 1990 is the only baseload 7F turbine that is equipped with steam injection. All subsequent 7F and 7FA baseload machines have been equipped with DLN. For this reason, the 1993 figures are assumed to be unchanged for steam injection.

The estimated cost impact factors ("\$/ton" and "¢/kWh") are based on 8,000 full load operating hours, as used in the 1993 NO<sub>x</sub> ACT document. The majority of base-loaded gas turbines typically operate at lower full load hours that can significantly increase the magnitude of the cost impact.

Observation of the resulting "¢/kWh" values in Table 3-3 indicates that the cost impact is highest for small turbines (5 MW) and lowest for large turbines (150 MW). This result is true across all technology types except for the DLN comparison. This finding appears to be related to the turbines compared and the available cost data rather than DLN technology. The GE LM2500 (25 MW output class) is an aeroderivative turbine with annular combustors that require higher incremental maintenance than the larger 150 MW GE gas turbines that use "can" type combustors the latter of which are easily replaced at lower cost. This explains the relatively high "¢/kWh" value for the LM2500. The "¢/kWh" value estimated for the Solar 5 MW turbine probably underestimates true costs. The cost estimate prepared for the Solar DLN combustor does not include an incremental maintenance component unlike the estimates prepared for the Rolls-Royce Allison 501-KB7 and the other 25 MW and 150 MW turbines. Solar Turbines has stated that there is an incremental maintenance and overhaul cost increase associated with their DLN combustor as compared to a conventional combustor, the cost of which is proprietary.

Direct comparisons can be made between 1993 and 1999 costs for water/steam injection, DLN and conventional SCR. Information was not available for low and high temperature SCR, SCONO<sub>x</sub><sup>TM</sup>, and catalytic combustion in the 1993 NO<sub>x</sub> ACT document.

The “¢/kWh” values for water/steam injection have remained fairly constant between the 1993 NO<sub>x</sub> ACT document and the evaluation performed in this study. This is consistent with the fact that water/steam injection was a mature technology in 1993. Considerable innovation has occurred with DLN and SCR, and this is reflected in a 50-100% reduction in the “¢/kWh” values for these two technologies between 1993 and 1999.

High temperature SCR is only about 10 percent more costly than conventional SCR. Low temperature SCR and SCONO<sub>x</sub><sup>TM</sup> are typically 2 times more costly than conventional SCR. Each of these technologies fills a unique technical “niche”; cost impact may be of secondary significance. Low temperature SCR is the only SCR technology that can operate effectively below 400 °F. High temperature SCR is the only SCR technology that can operate effectively from 800 to 1,100 °F. SCONO<sub>x</sub><sup>TM</sup> is the only post-combustion NO<sub>x</sub> control technology that does not require ammonia injection to achieve NO<sub>x</sub> levels less than 5 ppm.

Projected costs for catalytic combustors indicate that the “¢/kWh” cost is 2 to 3 times higher than a DLN combustor alone. The catalytic combustor can achieve NO<sub>x</sub> levels of less than 3 ppm while the most advanced DLN combustor can achieve NO<sub>x</sub> levels down to 9 ppm. To reach NO<sub>x</sub> levels below 5 ppm, the DLN-equipped turbine requires post-combustion NO<sub>x</sub> control device such as SCR or SCONO<sub>x</sub><sup>TM</sup>.

The cost impact is highest when emission control technologies are applied to small industrial turbines (5 MW); a conclusion that was applicable in the 1993 NO<sub>x</sub> ACT document as well. This is particularly true for the SCR and SCONO<sub>x</sub><sup>TM</sup> technologies where the cost impact is roughly twice that for larger turbines (25 MW and 150 MW). In ozone non-attainment areas, strict environmental regulations have mandated add-on controls for gas turbines. These regulations have a disproportionate impact on the construction of small gas turbine systems that may be too expensive to build when add-on controls are mandated.

DLN technology and catalytic combustion (potentially) exhibit lower cost impacts for both small and large gas turbines as shown in Figure S-1. Research and development has focused on these technologies to further improve the environmental signature of gas turbines. As an example, a

new generation of gas turbines and emission control technologies is being developed with the assistance of the U.S. Department of Energy (DOE) under the Advanced Turbine Systems (ATS) program. These gas turbines will exhibit significantly improved environmental and efficiency characteristics over currently available systems. These systems are being developed during a period of electric utility restructuring and proliferation of gas turbines for base-load power. The coming competitive power industry offers opportunities for both small and large gas turbine systems, filling niche markets - distributed generation and IPP/merchant plants, respectively. Although economics may favor development, the former market, distributed generation, is threatened by strict environmental regulations that impose costly post-combustion emission controls.

Advanced DLN and the development of catalytic combustion are both being funded by the ATS program and hope to significantly reduce the cost impact disparity between small and large gas turbines. Based on the results of this study, it is proposed that regulators consider the significant emission reductions achievable with advanced DLN and potentially with catalytic combustion and re-examine the need for costly post-combustion treatment in light of economic and performance factors, especially for small gas turbines.

## **APPENDIX A**

### **NO<sub>x</sub> CONTROL TECHNOLOGY COST COMPARISON TABLES**

**TABLE A-1**  
**SUMMARY OF COST IMPACT FACTORS FOR**  
**SELECTED NO<sub>x</sub> CONTROL TECHNOLOGIES (1999)**

Turbine Output	5 MW Class		25 MW Class		150 MW Class	
	\$/ton	¢/kWh	\$/ton	¢/kWh	\$/ton	¢/kWh
Median value						
NO <sub>x</sub> EMISSION CONTROL TECHNOLOGY						
DLN (25 ppm)	260	0.075	210	0.124	122 *	0.054 *
Catalytic Combustion (3 ppm)	957	0.317	692	0.215	371	0.146
Water/Steam Injection (42 ppm)	1,652	0.410	984	0.240	476	0.152
Conventional SCR (9 ppm)	6,274	0.469	3,541	0.204	1,938	0.117
High Temperature SCR (9 ppm)	7,148	0.530	3,841	0.221	2,359	0.134
SCONO <sub>x</sub> (2 ppm)	16,327	0.847	11,554	0.462	6,938	0.289
Low Temperature SCR (9 ppm)	5,894	1.060	2,202	0.429		

\* 9-25 ppm

"¢/kWh" based on 8,000 full load hours

**TABLE A-2  
1999 DLN COST COMPARISON**

**(Incremental Annual Cost Compared to Conventional Uncontrolled Diffusion Combustor)**

		5 MW Class			25 MW Class	150 MW Class	
Turbine Model		Allison 501-KB7	Solar Centaur 50	Solar Taurus 60	GE LM2500	GE Frame 7FA	GE Frame 7FA
Turbine Output		4.9 MW	4.0 MW	5.2 MW	22.7 MW	169.9 MW	169.9 MW
Heat Rate	Btu/kWhr	12,400	12,400	11,240	9,220	9,481	9,481
Heat Content	Btu/lb	20,160	20,610	20,610	20,610	20,610	20,610
Fuel flow	lb/hr	3,014	2,407	2,836	10,155	78,157	78,157
Hours of Operation	hrs	8,000	8,000	8,000	8,000	8,000	8,000
Fuel flow	MMBtu/yr	486,080	396,800	467,584	1,674,352	12,886,575	12,886,575
<b>CAPITAL COST</b>		\$20,000	\$190,000	\$190,000	\$800,000	\$4,500,000	\$4,750,000
<b>ANNUAL COST</b>							
Equipment Life	yrs	15	15	15	15	15	15
Interest Rate	%	10%	10%	10%	10%	10%	10%
Capital Recovery Factor		0.1315	0.1315	0.1315	0.1315	0.1315	0.1315
Capital Recovery		\$2,629	\$24,980	\$24,980	\$105,179	\$591,632	\$624,500
Catalyst Replacement		\$0	\$0	\$0	\$0	\$0	\$0
Other Parts and Repairs		\$32,000	proprietary	proprietary	\$120,000	\$120,000	\$120,000
Total Annual Cost		\$34,629	\$24,980	\$24,980	\$225,179	\$711,632	\$744,500
Uncontrolled	ppmv	155	134	143	174	210	210
Uncontrolled	tons/yr	154.4	106.6	134.1	584.1	5,426	5,426
Controlled	ppmv	25	25	25	25	25	9
Controlled	tons/yr	24.9	19.9	23.4	83.9	645.9	232.5
NOx Removed	tons/yr	129.5	86.7	110.6	500.2	4779.9	5193.3
<b>Cost Effectiveness</b>	<b>\$/ton</b>	<b>\$267</b>	<b>\$288</b>	<b>\$226</b>	<b>\$210</b>	<b>\$124</b>	<b>\$120</b>
<b>Electricity Cost Impact</b>	<b>¢/kWhr</b>	<b>0.088</b>	<b>0.078</b>	<b>0.060</b>	<b>0.124</b>	<b>0.052</b>	<b>0.055</b>

Note: O&M cost for LM2500 DLN used for Frame 7FA as default.

**TABLE A-3  
1999 CATALYTIC COMBUSTION COST COMPARISON**

**(Incremental Annual Cost Compared to Conventional Uncontrolled Diffusion  
Combustor)**

		5 MW Class	25 MW Class	150 MW Class
Turbine Model		Generic	GE Frame 5	GE Frame 7FA
Turbine Output		5.2 MW	26.3 MW	169.9 MW
Heat Rate	Btu/kWhr	11,240	12,189	9,481
Heat Content	Btu/lb	20,610	20,610	20,610
Fuel flow	lb/hr	2,836	15,554	78,157
Hours of Operation	hrs	8,000	8,000	8,000
Fuel flow	MMBtu/yr	467,584	2,564,626	12,886,575
<b>CAPITAL COST</b>		<b>\$217,100</b>	<b>\$523,808</b>	<b>\$1,443,629</b>
<b>ANNUAL COST</b>				
Equipment Life	yrs	15	15	15
Interest Rate	%	10%	10%	10%
Capital Recovery Factor		0.1315	0.1315	0.1315
Capital Recovery		\$28,543	\$68,867	\$189,799
Catalyst Replacement		\$66,100	\$253,740	\$1,193,676
Other Parts and Repairs		\$8,320	\$42,080	\$271,840
Annual Maintenance Contract		\$5,000	\$5,000	\$5,000
Major Failure Impact		\$15,293	\$61,052	\$265,425
Taxes and Insurance		\$8,684	\$20,952	\$57,745
Total Annual Cost		\$131,940	\$451,691	\$1,983,486
Uncontrolled	ppmv	150	130	210
Uncontrolled	tons/yr	140.6	668.5	5,426
Controlled	ppmv	3	3	3
Controlled	tons/yr	2.8	15.4	77.5
NOx Removed	tons/yr	137.8	653.0	5348.3
<b>Cost Effectiveness</b>	<b>\$/ton</b>	<b>\$957</b>	<b>\$692</b>	<b>\$371</b>
<b>Electricity Cost Impact</b>	<b>¢/kWhr</b>	<b>0.317</b>	<b>0.215</b>	<b>0.146</b>

Note: O&M cost for LM2500 DLN used for Frame 7FA as default.  
Costs based on Catalytica Combustion Systems's Xonon™ technology.



**TABLE A-4  
1999 WATER/STEAM INJECTION COST**

		5 MW Class		25 MW Class	150 MW Class*
		Water Injection	Water Injection	Water Injection	Steam Injection
Turbine Model		Solar Centaur 50	Allison 501-KB5	GE LM2500	GE MS7001F
Turbine Output		4.2 MW	4.0 MW	22.7 MW	161 MW
Heat Rate	Btu/kW/hr	11,700	12,700	9,220	9,500
Heat Content	Btu/lb	20,610	20,610	20,610	20,610
Fuel flow	lb/hr	2,404	2,465	10,155	74,212
Hours of Operation	hrs	8,000	8,000	8,000	8,000
Fuel flow	MMBtu/yr	396,396	406,400	1,674,352	12,236,000
lb water/lb fuel		0.61	0.8	0.73	1.34
Water flow	gpm	2.93	3.95	14.83	198.97
Water Treatment Capacity	gpm	4.92	6.62	24.87	333.67
<b>CAPITAL COST</b>					
Injection Nozzles		\$96,000	\$0	\$107,500	\$1,130,000
Injection System		\$20,700	\$27,800	\$104,500	
Total Injection System		\$117,000	\$27,800	\$212,000	\$1,130,000
Water Treatment System		\$97,400	\$113,000	\$219,000	\$802,000
Total System		\$214,400	\$140,800	\$431,000	\$1,932,000
Taxes and Freight		\$17,200	\$11,300	\$34,500	\$154,600
Installation - Direct		\$50,000	\$50,000	\$209,475	\$938,970
Installation - Indirect		\$56,300	\$40,400	\$227,700	\$1,003,400
Contingency		\$67,600	\$48,500	\$180,500	\$805,800
Total		\$405,500	\$291,000	\$1,083,175	\$4,834,770
<b>ANNUAL QUANTITIES</b>					
Percent Performance Loss		3.50%	3.50%	3.50%	1.00%
Energy Content	Btu/cubic ft	940	940	940	940
Unit Fuel Cost	\$/1000 cuft	3.88	3.88	3.88	3.88
Unit Electricity Cost	\$/kWhr	0.06	0.06	0.06	0.06
Water Waste		29%	29%	29%	29%
Water Cost	\$/1000 gal	0.384	0.384	0.384	0.384
Water Treatment Cost	\$/1000 gal	1.97	1.97	1.97	1.97
Labor Cost	\$/1000 gal	0.7	0.7	0.7	0.7
Water Disposal Cost	\$/1000 gal	3.82	3.82	3.82	3.82
G&A, taxes, insurance	%	4%	4%	4%	4%
Equipment Life	yrs	15	15	15	15
Interest Rate	%	10%	10%	10%	10%
Capital Recovery Factor		0.1315	0.1315	0.1315	0.1315
<b>ANNUAL COSTS</b>					
Fuel Penalty		\$35,000	\$47,000	\$177,000	\$677,000
Pumping Electricity		\$227	\$305	\$1,146	\$15,376
Added Maintenance		\$16,000	\$24,000	\$28,000	\$0
Plant Overhead		\$4,800	\$7,200	\$8,400	\$0
Water Cost		\$698	\$938	\$3,527	\$47,309
Water Treatment Cost		\$3,579	\$4,813	\$18,093	\$242,704
Labor Cost		\$1,272	\$1,710	\$6,429	\$43,120
Water Disposal Cost		\$1,560	\$2,098	\$7,887	\$105,799
G&A, taxes, insurance		\$16,220	\$11,640	\$43,327	\$193,391
Capital Recovery		\$53,000	\$38,000	\$142,000	\$636,000
Total Annual Cost		\$132,000	\$138,000	\$436,000	\$1,961,000
Uncontrolled	ppmv	134	155	174	210
Uncontrolled	tons/yr	106	126	584	5152
Controlled	ppmv	42	42	42	42
Controlled	tons/yr	33	34	141	1030
NOx Removed	tons/yr	73	92	443	4122
<b>Cost Effectiveness</b>	<b>\$/ton</b>	<b>\$1,805</b>	<b>\$1,499</b>	<b>\$984</b>	<b>\$476</b>
<b>Electricity Cost Impact</b>	<b>¢/kWhr</b>	<b>0.390</b>	<b>0.431</b>	<b>0.240</b>	<b>0.152</b>

\* (1993 data) Only the first baseload Frame 7F turbine (operational in 1990) has been sold with steam injection. All subsequent baseload units are equipped with DLN.

**TABLE A-5  
1999 CONVENTIONAL SCR COST COMPARISON**

			5 MW Class	25 MW Class	150 MW Class
Turbine Model			Solar Centaur 50	GE LM2500	GE Frame 7FA
Turbine Output			4.2 MW	23 MW	161 MW
Direct Capital Costs (DC):	<u>Source</u>				
Purchased Equip. Cost (PE):	MHIA				
Basic Equipment (A):	MHIA		\$240,000	\$660,000	\$2,100,000
Ammonia injection skid and storage	0.00 x A	MHIA	included	included	included
Instrumentation	0.00 x A	OAQPS	included	included	included
Taxes and freight:	0.08 A x B	OAQPS	\$19,015	\$52,746	\$169,530
PE Total:			\$256,704	\$712,066	\$2,288,649
Direct Installation Costs (DI):*					
Foundation & supports:	0.08 x PE	OAQPS	\$20,536	\$56,965	\$183,092
Handling and erection:	0.14 x PE	OAQPS	\$35,939	\$99,689	\$320,411
Electrical:	0.04 x PE	OAQPS	\$10,268	\$28,483	\$91,546
Piping:	0.02 x PE	OAQPS	\$5,134	\$14,241	\$45,773
Insulation:	0.01 x PE	OAQPS	\$2,567	\$7,121	\$22,886
Painting:	0.01 x PE	OAQPS	\$2,567	\$7,121	\$22,886
DI Total:			\$77,011	\$213,620	\$686,595
DC Total:			\$333,716	\$925,686	\$2,975,244
Indirect Costs (IC):					
Engineering:	0.10 x PE	OAQPS	\$25,670	\$71,207	\$100,000
Construction and field expenses:	0.05 x PE	OAQPS	\$12,835	\$35,603	\$114,432
Contractor fees:	0.10 x PE	OAQPS	\$25,670	\$71,207	\$228,865
Start-up:	0.02 x PE	OAQPS	\$5,134	\$14,241	\$45,773
Performance testing:	0.01 x PE	OAQPS	\$2,567	\$7,121	\$22,886
Contingencies:	0.03 x PE	OAQPS	\$7,701	\$21,362	\$68,659
IC Total:			\$79,578	\$220,741	\$580,616
Total Capital Investment (TCI = DC + IC):			\$413,294	\$1,146,427	\$3,555,861
Direct Annual Costs (DAC):					
Operating Costs (O):	24 hrs/day, 7 days/week, 50 weeks/yr				
Operator:	0.5 hr/shift: 25 \$/hr for operator pay	OAQPS	\$13,125	\$13,125	\$13,125
Supervisor:	15% of operator	OAQPS	\$1,969	\$1,969	\$1,969
Maintenance Costs (M):					
Labor:	0.5 hr/shift 25 \$/hr for labor pay	OAQPS	\$13,125	\$13,125	\$13,125
Material:	100% of labor cost:	OAQPS	\$13,125	\$13,125	\$13,125
Utility Costs:	0% thermal eff 600 (F) operating temp				
Gas usage	0.0 (MMcf/yr) 1,000 (Btu/ft3) heat value				
Gas cost	3,000 (\$/MMcf)	variable			
Perf. loss:	0.5%				
Electricity cost	0.06 (\$/kwh) performance loss cost penalty	variable	\$10,584	\$57,960	\$405,720
Catalyst replace:	assume 30 ft <sup>3</sup> catalyst per MW, \$400/ft <sup>3</sup> , 7 yr. life	MHIA	\$10,352	\$56,690	\$396,833
Catalyst dispose:	\$15/ft <sup>3</sup> *30 ft <sup>3</sup> /MW*MW*.2054 (7 yr amortized)	OAQPS	\$388	\$2,126	\$14,881
Ammonia:	360 (\$/ton) [tons NH <sub>3</sub> = tons NO <sub>x</sub> * (17/46)]	variable	\$3,510	\$14,820	\$108,257
NH <sub>3</sub> inject skid:	5 (kW) blower 5 kw (NH <sub>3</sub> /H <sub>2</sub> O pump)	MHIA	\$5,040	\$7,560	\$27,720
Total DAC:			\$71,219	\$180,500	\$994,755
Indirect Annual Costs (IAC):					
Overhead:	60% of O&M	OAQPS	\$24,806	\$24,806	\$24,806
Administrative:	0.02 x TCI	OAQPS	\$8,266	\$22,929	\$71,117
Insurance:	0.01 x TCI	OAQPS	\$4,133	\$11,464	\$35,559
Property tax:	0.01 x TCI	OAQPS	\$4,133	\$11,464	\$35,559
Capital recovery:	10% interest rate, 15 yrs - period 0.13 x TCI	OAQPS	\$52,976	\$143,272	\$415,329
Total IAC:			\$94,314	\$213,935	\$582,370
Total Annual Cost (DAC + IAC):			\$165,533	\$394,435	\$1,577,125
NO <sub>x</sub> Emission Rate (tons/yr) at 42 ppm:			33.4	141.0	1030.0
NO <sub>x</sub> Removed (tons/yr) at 9 ppm, 79% removal efficiency			26.4	111.4	813.7
<b>Cost Effectiveness (\$/ton):</b>			<b>\$6,274</b>	<b>\$3,541</b>	<b>\$1,938</b>
<b>Electricity Cost Impact (¢/kwh):</b>			<b>0.469</b>	<b>0.204</b>	<b>0.117</b>

\*Assume modular SCR is inserted into existing HRSG spool piece

**TABLE A-6  
1999 HIGH TEMPERATURE SCR COMPARISON**

		5 MW Class	25 MW Class	150 MW Class
Turbine Model		Solar Taurus 60	GE LM2500	GE Frame 7FA
Turbine Output		5.0 MW	23 MW	170 MW
Direct Capital Costs (DC):	<u>Source</u>			
Purchased Equip. Cost (PE):	Engelhard			
Basic Equipment (A):	Engelhard	\$380,000	\$730,000	\$3,000,000
Ammonia injection skid and storage	Engelhard	included	included	included
Instrumentation	OAQPS	included	included	included
Taxes and freight:	OAQPS	\$30,000	\$58,400	\$240,000
PE Total:		\$405,000	\$788,400	\$3,240,000
Direct Installation Costs (DI):*				
Foundation & supports:	0.08 x PE OAQPS	\$32,400	\$63,072	\$259,200
Handling and erection:	0.14 x PE OAQPS	\$56,700	\$110,376	\$453,600
Electrical:	0.04 x PE OAQPS	\$16,200	\$31,536	\$129,600
Piping:	0.02 x PE OAQPS	\$8,100	\$15,768	\$64,800
Insulation:	0.01 x PE OAQPS	\$4,050	\$7,884	\$32,400
Painting:	0.01 x PE OAQPS	\$4,050	\$7,884	\$32,400
DI Total:		\$121,500	\$236,520	\$972,000
DC Total:		\$526,500	\$1,024,920	\$4,212,000
Indirect Costs (IC):				
Engineering:	0.10 x PE OAQPS	\$40,500	\$78,840	\$324,000
Construction and field expenses:	0.05 x PE OAQPS	\$20,250	\$39,420	\$162,000
Contractor fees:	0.10 x PE OAQPS	\$40,500	\$78,840	\$324,000
Start-up:	0.02 x PE OAQPS	\$8,100	\$15,768	\$64,800
Performance testing:	0.01 x PE OAQPS	\$4,050	\$7,884	\$32,400
Contingencies:	0.03 x PE OAQPS	\$12,150	\$23,652	\$97,200
IC Total:		\$125,550	\$244,404	\$1,004,400
Total Capital Investment (TCI = DC + IC):		\$652,050	\$1,269,324	\$5,216,400
Direct Annual Costs (DAC):				
Operating Costs (O):	24 hrs/day, 7 days/week, 50 weeks/yr			
Operator:	0.5 hr/shift: 25 \$/hr for operator pay	OAQPS	\$13,125	\$13,125
Supervisor:	15% of operator	OAQPS	\$1,969	\$1,969
Maintenance Costs (M):				
Labor:	0.5 hr/shift 25 \$/hr for labor pay	OAQPS	\$13,125	\$13,125
Material:	100% of labor cost:	OAQPS	\$13,125	\$13,125
Utility Costs:	0% thermal eff 600 (F) operating temp			
Gas usage	0.0 (MMcf/yr) 1,000 (Btu/ft <sup>3</sup> ) heat value			
Gas cost	3,000 (\$/MMcf)	variable		
Perf. loss:	0.5%			
Electricity cost	0.06 (\$/kwh) performance loss cost penalty	variable	\$12,600	\$57,960
Catalyst replace:	assume 30 ft <sup>3</sup> catalyst per MW, \$400/ft <sup>3</sup> , 7 yr. life	Engelhard	\$25,675	\$70,863
Catalyst dispose:	\$15/ft <sup>3</sup> *30 ft <sup>3</sup> /MW *MW*.2054 (7 yr amortized)	OAQPS	\$462	\$2,126
Ammonia:	360 (\$/ton) [tons NH <sub>3</sub> = tons NO <sub>x</sub> * (17/46)]	variable	\$4,141	\$14,820
NH <sub>3</sub> inject skid:	** (kW) blower 5 kw (NH <sub>3</sub> /H <sub>2</sub> O pump)	Engelhard	\$5,040	\$7,560
Total DAC:			\$89,262	\$194,672
Indirect Annual Costs (IAC):				
Overhead:	60% of O&M	OAQPS	\$24,806	\$24,806
Administrative:	0.02 x TCI	OAQPS	\$13,041	\$25,386
Insurance:	0.01 x TCI	OAQPS	\$6,521	\$12,693
Property tax:	0.01 x TCI	OAQPS	\$6,521	\$12,693
Capital recovery:	10% interest rate, 15 yrs - period			
0.13 x TCI		OAQPS	\$82,352	\$157,566
Total IAC:			\$133,240	\$233,145
Total Annual Cost (DAC + IAC):			\$222,502	\$427,818
NO <sub>x</sub> Emission Rate (tons/yr) at 42 ppm:		39.4	141.0	1030.0
NO <sub>x</sub> Removed (tons/yr) at 9 ppm, 79% removal efficiency		31.1	111.4	813.7
<b>Cost Effectiveness (\$/ton):</b>		<b>\$7,148</b>	<b>\$3,841</b>	<b>\$2,359</b>
<b>Electricity Cost Impact (¢/kwh):</b>		<b>0.530</b>	<b>0.221</b>	<b>0.134</b>

\*Assume modular SCR is inserted upstream of HRSG or for a simple cycle gas turbine.

\*\* 5, 10, 15 kW blower for 5, 25, 150 MW gas turbine respectively

**TABLE A-7**  
**1999 SCONOX™ COST COMPARISON**

		5 MW Class	25 MW Class	150 MW Class
Turbine Model		Solar Centaur 50	GE LM2500	GE Frame 7FA
Turbine Output		4.2 MW	23 MW	170 MW
Direct Capital Costs (DC):	<u>Source</u>			
Purchased Equip. Cost (PE):	Goalline			
Basic Equipment (A):	Goalline	\$620,000	\$1,960,000	\$7,700,000
Ammonia injection skid and storage	0.00 x A Goalline	included	included	included
Instrumentation	0.00 x A OAQPS	included	included	included
Taxes and freight:	0.08 A x B OAQPS	\$49,760	\$157,105	\$612,238
PE Total:		\$671,760	\$2,120,916	\$8,265,208
Direct Installation Costs (DI):*				
Foundation & supports:	0.08 x PE OAQPS	\$53,741	\$169,673	\$661,217
Handling and erection:	0.14 x PE OAQPS	\$94,046	\$296,928	\$1,157,129
Electrical:	0.04 x PE OAQPS	\$26,870	\$84,837	\$330,608
Piping:	0.02 x PE OAQPS	\$13,435	\$42,418	\$165,304
Insulation:	0.01 x PE OAQPS	\$6,718	\$21,209	\$82,652
Painting:	0.01 x PE OAQPS	\$6,718	\$21,209	\$82,652
DI Total:		\$201,528	\$636,275	\$2,479,562
DC Total:		\$873,288	\$2,757,191	\$10,744,770
Indirect Costs (IC):				
Engineering:	0.10 x PE OAQPS	\$67,176	\$212,092	\$826,521
Construction and field expenses:	0.05 x PE OAQPS	\$33,588	\$106,046	\$413,260
Contractor fees:	0.10 x PE OAQPS	\$67,176	\$212,092	\$826,521
Start-up:	0.02 x PE OAQPS	\$13,435	\$42,418	\$165,304
Performance testing:	0.01 x PE OAQPS	\$6,718	\$21,209	\$82,652
Contingencies:	0.03 x PE OAQPS	\$20,153	\$63,627	\$247,956
IC Total:		\$208,246	\$657,484	\$2,562,214
Total Capital Investment (TCI = DC + IC):		\$1,081,534	\$3,414,675	\$13,306,985
Direct Annual Costs (DAC):				
Operating Costs (O):	24 hrs/day, 7 days/week, 50 weeks/yr			
Operator:	0.5 hr/shift: 25 \$/hr for operator pay OAQPS	\$13,125	\$13,125	\$13,125
Supervisor:	15% of operator OAQPS	\$1,969	\$1,969	\$1,969
Maintenance Costs (M):				
Labor:	0.5 hr/shift: 25 \$/hr for labor pay OAQPS	\$13,125	\$13,125	\$13,125
Material:	100% of labor cost: OAQPS	\$13,125	\$13,125	\$13,125
Utility Costs:				
Perf. loss:	0.5%			
Electricity cost:	0.06 (\$/kwh) performance loss cost penalty variable	\$10,584	\$57,960	\$428,400
Catalyst replace:	** kcfh/MW	\$25,880	\$106,295	\$785,655
Catalyst dispose:	precious metal recovery = 1/3 replace cost variable	-\$8,618	-\$35,396	-\$261,623
H2 carrier steam:	*** lb/hr (93 lb/hr steam/MW @ \$.006/lb) variable	\$19,686	\$107,806	\$796,824
H2 reforming:	**** CH4 ft3/hr (14ft3/hr/MW @ \$.00388/ft3) variable	\$1,916	\$10,495	\$77,569
H2 skid demand:	***** kW (0.6 kW/MW capacity)	\$1,270	\$6,955	\$51,408
Total DAC:		\$92,063	\$295,458	\$1,919,577
Indirect Annual Costs (IAC):				
Overhead:	60% of O&M OAQPS	\$24,806	\$24,806	\$24,806
Administrative:	0.02 x TCI OAQPS	\$21,631	\$68,293	\$266,140
Insurance:	0.01 x TCI OAQPS	\$10,815	\$34,147	\$133,070
Property tax:	0.01 x TCI OAQPS	\$10,815	\$34,147	\$133,070
Capital recovery:	10% interest rate, 15 yrs - period 0.13 x TCI OAQPS	\$138,791	\$434,965	\$1,646,226
Total IAC:		\$206,858	\$596,358	\$2,203,312
Total Annual Cost (DAC + IAC):		\$298,921	\$891,816	\$4,122,889
NO <sub>x</sub> Emission Rate (tons/yr) at 25 ppm:		19.9	83.9	645.9
NO <sub>x</sub> Removed (tons/yr) at 2 ppm, 92% removal efficiency		18.3	77.2	594.2
<b>Cost Effectiveness (\$/ton):</b>		<b>\$16,327</b>	<b>\$11,554</b>	<b>\$6,938</b>
<b>Electricity Cost Impact (¢/kwh):</b>		<b>0.847</b>	<b>0.462</b>	<b>0.289</b>

\* Assume modular SCONOX unit is inserted downstream of HRSG

\*\* 400, 300, 300 kcfh/MW for 5, 25, 150 MW class respectively (s.v.=20kcfh/ft3, \$1,500/ft3 catalyst, 7 yr. life)

\*\*\* 391, 2139, 15810 lb/hr for 5, 25, 150 MW class respectively

\*\*\*\* 59, 322, 2380 CH4ft3/hr for 5, 25, 150 MW class respectively

\*\*\*\*\* 3, 14, 102 kW for 5, 25, 150 MW class respectively

**TABLE A-8  
1999 LOW TEMPERATURE SCR COMPARISON**

			5 MW Class	25 MW Class
Turbine Model			Solar Centaur 50	GE LM2500
Turbine Output			4.0 MW	25 MW
Direct Capital Costs (DC):		<u>Source</u>		
Purchased Equip. Cost (PE):		KTI		
Basic Equipment (A):		KTI	\$700,000	\$1,714,894
Ammonia injection skid and storage	0.00 x A	KTI	included	included
Instrumentation	0.00 x A	OAQPS	included	included
Taxes and freight:	0.08 A x B	OAQPS	\$56,000	\$137,192
PE Total:			\$756,000	\$1,852,085
Direct Installation Costs (DI):*	Allison	Turbo Power		
Foundation & supports:	0.30 x PE	0.08 x PE	OAQPS	\$226,800
Handling and erection:	0.30 x PE	0.14 x PE	OAQPS	\$226,800
Electrical:	0.04 x PE	0.04 x PE	OAQPS	\$30,240
Piping:	0.02 x PE	0.02 x PE	OAQPS	\$15,120
Insulation:	0.01 x PE	0.01 x PE	OAQPS	\$7,560
Painting:	0.01 x PE	0.01 x PE	OAQPS	\$7,560
DI Total:			\$514,080	\$555,626
DC Total:			\$1,270,080	\$2,407,711
Indirect Costs (IC):				
Engineering:	0.10 x PE	0.30 x PE	OAQPS	\$75,600
Construction expenses:	0.05 x PE	0.30 x PE	OAQPS	\$37,800
Contractor fees:	0.10 x PE	0.10 x PE	OAQPS	\$75,600
Start-up:	0.02 x PE	0.02 x PE	OAQPS	\$15,120
Performance testing:	0.01 x PE	0.01 x PE	OAQPS	\$7,560
Contingencies:	0.03 x PE	0.03 x PE	OAQPS	\$22,680
IC Total:			\$234,360	\$1,407,585
Total Capital Investment (TCI = DC + IC):			\$1,504,440	\$3,815,296
Direct Annual Costs (DAC):				
Operating Costs (O):	24 hrs/day, 7 days/week, 50 weeks/yr			
Operator:	0.5 hr/shift:	25 \$/hr for operator pay	OAQPS	\$13,125
Supervisor:	15% of operator		OAQPS	\$1,969
Maintenance Costs (M):				
Labor:	0.5 hr/shift	25 \$/hr for labor pay	OAQPS	\$13,125
Material:	100% of labor cost:		OAQPS	\$13,125
Utility Costs:	0% thermal eff	600 (F) operating temp		
Gas usage	0.0 (MMcf/yr)	1,000 (Btu/ft <sup>3</sup> ) heat value		
Gas cost	3,000 (\$/MMcf)		variable	\$0
Perf. loss:	0.5%			
Electricity cost	0.06 (\$/kwh) performance loss cost penalty		variable	\$10,080
Catalyst replace:	assume 30 ft <sup>3</sup> catalyst per MW, \$400/ft <sup>3</sup> , 7 yr. life		MHIA	\$9,859
Catalyst dispose:	\$15/ft <sup>3</sup> *30 ft <sup>3</sup> /MW*MW*.2054 (7 yr amortized)		OAQPS	\$370
Ammonia:	360 (\$/ton) [tons NH <sub>3</sub> = tons NO <sub>x</sub> * (17/46)]		variable	\$8,040
NH <sub>3</sub> inject skid:	5 (kW) blower	5 kw (NH <sub>3</sub> /H <sub>2</sub> O pump)	MHIA	\$5,040
Total DAC:			\$74,733	\$180,500
Indirect Annual Costs (IAC):				
Overhead:	60% of O&M		OAQPS	\$24,806
Administrative:	0.02 x TCI		OAQPS	\$30,089
Insurance:	0.01 x TCI		OAQPS	\$15,044
Property tax:	0.01 x TCI		OAQPS	\$15,044
Capital recovery:	10% interest rate, 15 yrs - period			
Capital recovery:	0.13 x TCI		OAQPS	\$196,498
Total IAC:			\$281,482	\$670,928
Total Annual Cost (DAC + IAC):			\$356,215	\$901,207
NO <sub>x</sub> Emission Rate (tons/yr) at 100, 132 ppm, respectively:			76.5	518.0
NO <sub>x</sub> Removed (tons/yr) at 9 ppm, 79% removal efficiency			60.4	409.2
<b>Cost Effectiveness (\$/ton):</b>			<b>\$5,894</b>	<b>\$2,202</b>
<b>Electricity Cost Impact (¢/kwh):</b>			<b>1.060</b>	<b>0.429</b>

\*Assume modular SCR is placed downstream of HRSG

## APPENDIX B

### REFERENCES

1. Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Stationary Gas Turbines, U.S. EPA, Office of Air Quality Planning and Standards, EPA-453/R-93-007, January 1993.
2. EPA 453/B-96-001, OAQPS Cost Control Manual - 5th Edition, U.S. EPA, Office of Air Quality Planning and Standards, February 1996.
3. Lefebvre, A. H., The Role of Fuel Preparation in Low-Emission Combustion, Journal of Engineering for Gas Turbines and Power, American Society of Mechanical Engineers, Volume 117, pp. 617-654, October 1995.
4. 1995 Diesel and Gas Turbine Worldwide Catalog, Diesel and Gas Turbine Publications, Brookfield, WI.
5. Phone conversation with C. Solt, Catalytica Combustion Systems, December, 1998.
6. Phone conversation with L. Witherspoon, Solar Turbines, January 1999.
7. Phone conversation with B. Reyes, Goal Line Environmental Technologies, January 1999.
8. Phone conversation with R. Patt, GE Industrial and Marine, January 1999.
9. Phone conversation with B. Binford, Rolls-Royce Allison, January 1999.
10. Phone conversation with S. Yang, Mitsubishi Heavy Industries America, January 1999.
11. Phone conversation with T. Gilmore, Kinetics Technology International, January 1999.
12. Phone conversation with R. Armstrong, GE Power Systems, February 1999.
13. Phone conversation with M. Krush, Siemens-Westinghouse, February 1999.
14. Phone conversation with F. Booth, Engelhard, February 1999.
15. Phone conversation with S. van der Linden, ABB, February 1999.