

ATTACHMENT 71111.23

INSPECTABLE AREA: Temporary Plant Modifications

CORNERSTONES: Mitigating Systems (90%)
Barrier Integrity (10%)

INSPECTION BASES: Temporary modifications to risk-significant SSCs may adversely affect their availability, reliability or functional capability. A temporary modification may result in a departure from the design basis and system success criteria. Temporary or unrecognized risk changes due to the modification may evolve into high risk configurations. This inspectable area verifies aspects of the associated cornerstones for which there are no indicators to measure performance.

LEVEL OF EFFORT: Periodically screen active temporary modifications on systems which are ranked high in risk. Review the details of 2 to 4 temporary modifications a year for a 1-unit site; 3 to 5 for a 2-unit site; or 4 to 6 for a 3-unit site, respectively. Although the sample sizes are an annual goal, the inspection effort can be distributed on a quarterly basis.

71111.23-01 INSPECTION OBJECTIVE

This inspection will verify that temporary modifications have not affected the safety functions of important safety systems.

71111.23-02 INSPECTION REQUIREMENTS

02.01 Selection of Temporary Modifications. Select temporary modifications to risk-significant systems. For purposes of this inspection, temporary modifications include jumpers, lifted leads, temporary systems, repairs, design modifications and procedure changes which can introduce changes to plant design or operations. Although the focus of this inspection is on active modifications, inspectors may choose to review a recently removed temporary modification for adequate restoration and testing.

02.02 Inspection

- a. Review the temporary modifications and associated 10 CFR 50.59 screening against the system design bases documentation, including Updated Final Safety Analysis Report (UFSAR) and Technical Specifications (TS). Verify that the modifications have not affected system operability/availability. See Inspection Procedure 71111.17, "Permanent Plant Modifications," for additional attributes which may be considered for review. Inspect only those attributes which are significant for the particular modification being reviewed.
- b. Verify that the installation and restoration of the temporary modifications (if accessible) are consistent with the modification documents. Verify configuration control of the modification is adequate by verifying that the plant documents, such

as drawings and procedures are updated including adequacy of operating and maintenance procedures.

- c. Review post-installation test results to confirm that the tests are satisfactory and the actual impact of the temporary modifications on the permanent systems and interfacing systems have been adequately verified by test. Also, review planned testing after removal of the temporary modifications.
- d. Verify that temporary modifications are identified on Control Room drawings and that appropriate tags are placed equipment being affected by the temporary modifications.
- e. Verify that licensee has evaluated the combined effects of the outstanding temporary modifications in regard to mitigating systems and the integrity of radiological barriers.
- f. Examine drawings, design and operating procedures, operations logs for evidence of temporary modifications that have not been so evaluated or categorized.

02.03 Problem Identification and Resolution. Verify that problems associated with temporary modifications are being identified by the licensee at an appropriate threshold and are properly addressed for resolution in the licensee corrective action program. See Inspection Procedure 71152, "Identification and Resolution of Problems," for additional guidance.

71111.23-03 INSPECTION GUIDANCE

03.01 General Guidance

For inspection guidance, see Table A below.

TABLE A

Cornerstone	Inspection Objective	Risk Priority	Example
Mitigating Systems	Identify temporary modifications which could affect the design basis or the functional capability of plant mitigating systems Emphasize modifications which affect high safety significant Maintenance Rule SSCs/functions or modifications which affect SSCs/functions with high PRA rankings	Temporary modifications which could affect the design bases and functional capability of interfacing systems	Use of alternate material when specified replacement parts are not available During outages: Temporary electrical power to equipment required to minimize shutdown risk Alternate water sources for equipment cooling or fire protection of equipment required to minimize shutdown risk

Cornerstone	Inspection Objective	Risk Priority	Example
Barrier Integrity	Identify temporary modifications which could affect the design basis or the functional capability of containment or reactor coolant system boundaries	Multiple temporary modifications to a single system or train, especially during outages Temporary modifications which require operator workarounds	Temporary changes to containment isolation motor operated valve designs. During outages: Temporary power improperly routed into containment when the ability to establish containment integrity is still required.

03.02 Specific Guidance

- a. The review of the design aspects of a temporary modifications should focus on conformance to relevant design criteria not the programmatic elements of licensee programs.
- b. The review of both the installation of and the restoration from a temporary modification is necessary to ensure that the impact on the operation of other equipment is what is expected and previously analyzed, and to verify all other unexpected effects were subsequently evaluated with the results being there is no significant impact on the safe operation of plant or equipment.
- c. The review of the post-installation test results is to ensure that the parent system remains operable and that its safety function has not been impaired.
- d. Identification of temporary modifications on drawings and at placement of appropriate tags equipment being affected by the temporary modification should make operators aware of their impact on the operation of plant equipment and components.
- e. The synergistic effects of outstanding temporary modifications is best judged based on whether there are new impediments to the safety functions of mitigating safety systems, degradation of radiological barriers, and an increase in the consequences of pertinent analyses in Chapter 15 of the FSAR.
- f. Focus more attention on identifying temporary modifications not previously identified by the licensee if there is no existing program tasked with making interested parties aware of the existence of all temporary modifications.

71111.23-04 RESOURCE ESTIMATE

The annual resource expenditure for this inspection procedure at a site is estimated to be on average: 17 to 27 hours for one unit; 20 to 32 hours for two units; and 27 to 41 hours for three units.

71111.23-05 COMPLETION STATUS

Inspection of the minimum sample size will constitute completion of this procedure in the Reactor Programs Systems (RPS). That minimum sample size will consist of the review of 2 temporary modifications for one unit; 3 temporary modifications for two units; and 4 temporary modifications for three units.

71111.23-06 REFERENCES

Inspection Procedure 71111, Attachment 17, "Permanent Plant Modifications"

Inspection Procedure 71152, "Identification and Resolution of Problems"

END

ATTACHMENT: Revision History

ATTACHMENT

Revision History - IP 71111.23

Commitment Tracking Number	Issue Date	Description of Change	Training Needed	Training Completion Date	Comment Resolution Accession Number
N/A	01/17/2002 CN 02-001	Revised to address regional comments on how to adequately determine the combined effects of several temporary modifications on the safe operation of the plant, and to provide some latitude in sample sizes and estimated resources.	NO	N/A	N/A
N/A	06/06/2005 CN 05-005	Revised to incorporate guidance regarding restoration of temporary plant modifications.	NO	N/A	N/A
N/A	01/05/2006 CN 06-001	Sample size and estimated inspection resource required to complete this IP was reduced because most plants do not have many temporary modifications to inspect. Completed historical CN search.	NO	N/A	N/A