

May 7, 2002

APPLICANT: Florida Power and Light Company (FPL)

FACILITIES: St. Lucie Nuclear Plant, Units 1 and 2

SUBJECT: PUBLIC EXIT MEETING WITH FLORIDA POWER AND LIGHT COMPANY ON  
THE SCOPING METHODOLOGY AUDIT FOR ST. LUCIE UNITS 1 AND 2  
LICENSE RENEWAL APPLICATION

The staff of the Nuclear Regulatory Commission held a public meeting on April 18, 2002, at the Florida Power and Light Company (FPL) Energy Encounter, 6501 South Ocean Drive, Jensen Beach, Florida. The purpose of the meeting was to present the preliminary results of the staff's audit of the scoping and screening methodology used to develop the St. Lucie Units 1 and 2 license renewal application. The list of attendees is attached.

Mr. Richard McIntyre, NRC, summarized the purpose of the audit and the material reviewed. He identified two requests for additional information and a confirmatory issue. The requests for additional information pertained to the recently issued staff interim guidance on:

1. Evaluating non-safety-related structures and components located near safety-related components to determine which additional structures or components meet the 10 CFR 54.4(a)(2) license renewal scoping criteria.
2. Evaluating, in the context of the station blackout rule, what portion of the offsite power system are within the scope of license renewal.

The confirmatory issue pertained to including a statement in the supplemental Updated Final Safety Analysis Report that license renewal activities would conform to 10 CFR Part 50 Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants." Mr. McIntyre concluded that the scoping and screening methodology appeared to be consistent with 10 CFR Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

Prior to issuance, the staff provided a draft of this meeting summary to the applicant for comment.

*/RA/*

Noel Dudley, Senior Project Manager  
License Renewal Section  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket Nos. 50-335 and 50-389  
Attachment: As stated  
cc w/Attachment: See next page

APPLICANT: Florida Power and Light Company (FPL)

FACILITIES: St. Lucie Nuclear Plant, Units 1 and 2

SUBJECT: PUBLIC EXIT MEETING WITH FLORIDA POWER AND LIGHT COMPANY ON THE SCOPING METHODOLOGY AUDIT FOR ST. LUCIE UNITS 1 AND 2 LICENSE RENEWAL APPLICATION

The staff of the Nuclear Regulatory Commission held a public meeting on April 18, 2002, at the Florida Power and Light Company (FPL) Energy Encounter, 6501 South Ocean Drive, Jensen Beach, Florida. The purpose of the meeting was to present the preliminary results of the staff's audit of the scoping and screening methodology used to develop the St. Lucie Units 1 and 2 license renewal application. The list of attendees is attached.

Mr. Richard McIntyre, NRC, summarized the purpose of the audit and the material reviewed. He identified two requests for additional information and a confirmatory issue. The requests for additional information pertained to the recently issued staff interim guidance on:

3. Evaluating non-safety-related structures and components located near safety-related components to determine which additional structures or components meet the 10 CFR 54.4(a)(2) license renewal scoping criteria.
4. Evaluating, in the context of the station blackout rule, what portion of the offsite power system are within the scope of license renewal.

The confirmatory issue pertained to including a statement in the supplemental Updated Final Safety Analysis Report that license renewal activities would conform to 10 CFR Part 50 Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants." Mr. McIntyre concluded that the scoping and screening methodology appeared to be consistent with 10 CFR Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

Prior to issuance, the staff provided a draft of this meeting summary to the applicant for comment.

*/RA/*

Noel Dudley, Senior Project Manager  
License Renewal Section  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket Nos. 50-335 and 50-389  
Attachment: As stated  
cc w/Attachment: See next page

**DISTRIBUTION:** See next page

Document Name: C:\ORPCheckout\FileNET\ML021280114.wpd

\*See attached sheets for concurrences.

OFFICE	PM:RLSB	LA	SC: RLEP	BC:RLEP
NAME	NDudley*	EHylton*	SHoffman	PTKuo
DATE	5/ 6/02	5/ 6/2	5/7/02	5/7/02

OFFICIAL RECORD COPY

DISTRIBUTION:

**HARD COPY**

RLEP RF

E. Hylton

**E-MAIL:**

PUBLIC

J. Johnson

W. Borchardt

D. Matthews

F. Gillespie

C. Grimes

RidsNrrDe

R. Barrett

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

C. Holden

P. Shemanski

H. Nieh

G. Holahan

S. Black

B. Boger

D. Thatcher

G. Galletti

C. Li

J. Moore

R. Weisman

M. Mayfield

A. Murphy

W. McDowell

S. Droggitis

S. Duraiswamy

RLEP Staff

-----

R. McIntyre

G. Galletti

P. Balmain

D. McCain

Scoping Methodology Audit Meeting Participants  
St. Lucie Units 1 and 2  
April 18, 2002

**NRC**

Rich McIntyre	NRR/DIPM/IQMB	Audit Team Leader
Greg Galletti	NRR/DIPM/IQMB	Operations Engineer
Peter Balmain	NRR/DIPM/IQMB	Operations Engineer
Thierry Ross	RII	Senior Resident Inspector
Noel Dudley	NRR/DRIP/RLEP	Sr. Project Manager

**Florida Power and Light Company**

Don Jernigan	FPL, Site Vice President, St. Lucie Nuclear Plant
Steve Hale	FPL
Jack Hoffman	FPL
T.L. Patterson	FPL
T.V. Abbatiello	FPL
Jim Chrulski	FPL
Chris Wasik	FPL

Mr. J. A. Stall  
Florida Power and Light Company

cc:

Mr. J. A. Stall  
Senior Vice President, Nuclear and Chief  
Nuclear Officer  
Florida Power and Light Company  
700 Universe Boulevard  
P.O. Box 029100  
Juno Beach, FL 33408-0420

Senior Resident Inspector  
St. Lucie Plant  
U.S. Nuclear Regulatory Commission  
P.O. Box 6090  
Jensen Beach, Florida 34957-2000

Mr. Craig Fugate, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, Florida 32399-2100

M. S. Ross, Attorney  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Douglas Anderson  
County Administrator  
St. Lucie County  
2300 Virginia Avenue  
Fort Pierce, Florida 34982

Mr. William A. Passetti, Chief  
Department of Health  
Bureau of Radiation Control  
2020 Capital Circle, SE, Bin #C21  
Tallahassee, Florida 32399-1741

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, Florida 32304

Mr. Donald E. Jernigan, Site Vice President  
St. Lucie Nuclear Plant  
Florida Power and Light Company  
6351 South Ocean Drive  
Jensen Beach, Florida 34957-2000

## ST. LUCIE PLANT

Mr. Steve Hale  
St. Lucie Nuclear Plant  
Florida Power and Light Company  
6351 South Ocean Drive  
Jensen Beach, Florida 34957-2000

Mr. R. G. West  
Plant General Manager  
St. Lucie Nuclear Plant  
Florida Power and Light Company  
6351 South Ocean Drive  
Jensen Beach, Florida 34957-2000

Mr. T.L. Patterson  
Licensing Manager  
St. Lucie Nuclear Plant  
Florida Power and Light Company  
6351 South Ocean Drive  
Jensen Beach, Florida 34957-2000

Mr. Don Mothena  
Manager, Nuclear Plant Support Services  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar  
Vice President - Nuclear Engineering  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. J. Kammel  
Radiological Emergency  
Planning Administrator  
Department of Public Safety  
6000 SE. Tower Drive  
Stuart, Florida 34997

Mr. Alan P. Nelson  
Nuclear Energy Institute  
1776 I Street, N.W., Suite 400  
Washington, DC 20006-3708  
APN@NEI.ORG

David Lewis  
Shaw Pittman, LLP  
2300 N Street, N.W.  
Washington, D.C. 20037