

APPENDIX A

NRC NEPA ISSUES FOR LICENSE RENEWAL OF NUCLEAR POWER PLANTS

Carolina Power and Light Company (CP&L) has prepared this environmental report in accordance with the requirements of U.S. Nuclear Regulatory Commission (NRC) regulation 10 CFR 51.53. NRC included in the regulation a list of National Environmental Policy Act (NEPA) issues for license renewal of nuclear power plants. [Table A-1](#) lists these 92 issues and identifies the section in which CP&L addressed each issue in the environmental report. For organization and clarity, CP&L has assigned a number to each issue and uses the issue numbers throughout the environmental report.

TABLE

**TABLE A-1
 RNP ENVIRONMENTAL REPORT DISCUSSION OF
 LICENSE RENEWAL NEPA ISSUES^a**

| | Issue | Category | Section of this Environmental Report |
|-----|---|----------|---|
| 1. | Impacts of refurbishment on surface water quality | 1 | 4.0 |
| 2. | Impacts of refurbishment on surface water use | 1 | 4.0 |
| 3. | Altered current patterns at intake and discharge structures | 1 | 4.0 |
| 4. | Altered salinity gradients | 1 | 4.0 |
| 5. | Altered thermal stratification of lakes | 1 | 4.0 |
| 6. | Temperature effects on sediment transport capacity | 1 | 4.0 |
| 7. | Scouring caused by discharged cooling water | 1 | 4.0 |
| 8. | Eutrophication | 1 | 4.0 |
| 9. | Discharge of chlorine or other biocides | 1 | 4.0 |
| 10. | Discharge of sanitary wastes and minor chemical spills | 1 | 4.0 |
| 11. | Discharge of other metals in waste water | 1 | 4.0 |
| 12. | Water use conflicts (plants with once-through cooling systems) | 1 | 4.0 |
| 13. | Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow) | 2 | 4.1 |
| 14. | Refurbishment impacts to aquatic resources | 1 | 4.0 |
| 15. | Accumulation of contaminants in sediments or biota | 1 | 4.0 |
| 16. | Entrainment of phytoplankton and zooplankton | 1 | 4.0 |
| 17. | Cold shock | 1 | 4.0 |
| 18. | Thermal plume barrier to migrating fish | 1 | 4.0 |
| 19. | Distribution of aquatic organisms | 1 | 4.0 |
| 20. | Premature emergence of aquatic insects | 1 | 4.0 |
| 21. | Gas supersaturation (gas bubble disease) | 1 | 4.0 |
| 22. | Low dissolved oxygen in the discharge | 1 | 4.0 |
| 23. | Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses | 1 | 4.0 |
| 24. | Stimulation of nuisance organisms (e.g., shipworms) | 1 | 4.0 |
| 25. | Entrainment of fish and shellfish in early life stages for plants with once-through and cooling pond heat dissipation systems | 2 | 4.2 |
| 26. | Impingement of fish and shellfish for plants with once-through and cooling pond heat dissipation systems | 2 | 4.3 |
| 27. | Heat shock for plants with once-through and cooling pond heat dissipation systems | 2 | 4.4 |

TABLE A-1 (Cont'd)
RNP ENVIRONMENTAL REPORT DISCUSSION OF
LICENSE RENEWAL NEPA ISSUES^a

| | Issue | Category | Section of this Environmental Report |
|-----|---|----------|---|
| 28. | Entrainment of fish and shellfish in early life stages for plants with cooling-tower-based heat dissipation systems | 1 | 4.0 |
| 29. | Impingement of fish and shellfish for plants with cooling-tower-based heat dissipation systems | 1 | 4.0 |
| 30. | Heat shock for plants with cooling-tower-based heat dissipation systems | 1 | 4.0 |
| 31. | Impacts of refurbishment on groundwater use and quality | 1 | 4.0 |
| 32. | Groundwater use conflicts (potable and service water; plants that use < 100 gpm) | 1 | 4.0 |
| 33. | Groundwater use conflicts (potable, service water, and dewatering; plants that use > 100 gpm) | 2 | 4.5 |
| 34. | Groundwater use conflicts (plants using cooling towers withdrawing make-up water from a small river) | 2 | 4.6 |
| 35. | Groundwater use conflicts (Ranney wells) | 2 | 4.7 |
| 36. | Groundwater quality degradation (Ranney wells) | 1 | 4.0 |
| 37. | Groundwater quality degradation (saltwater intrusion) | 1 | 4.0 |
| 38. | Groundwater quality degradation (cooling ponds in salt marshes) | 1 | 4.0 |
| 39. | Groundwater quality degradation (cooling ponds at inland sites) | 2 | 4.8 |
| 40. | Refurbishment impacts to terrestrial resources | 2 | 4.9 |
| 41. | Cooling tower impacts on crops and ornamental vegetation | 1 | 4.0 |
| 42. | Cooling tower impacts on native plants | 1 | 4.0 |
| 43. | Bird collisions with cooling towers | 1 | 4.0 |
| 44. | Cooling pond impacts on terrestrial resources | 1 | 4.0 |
| 45. | Power line right-of-way management (cutting and herbicide application) | 1 | 4.0 |
| 46. | Bird collisions with power lines | 1 | 4.0 |
| 47. | Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock) | 1 | 4.0 |
| 48. | Floodplains and wetlands on power line right-of-way | 1 | 4.0 |
| 49. | Threatened or endangered species | 2 | 4.10 |
| 50. | Air quality during refurbishment (non-attainment and maintenance areas) | 2 | 4.11 |
| 51. | Air quality effects of transmission lines | 1 | 4.0 |
| 52. | Onsite land use | 1 | 4.0 |

TABLE A-1 (Cont'd)
RNP ENVIRONMENTAL REPORT DISCUSSION OF
LICENSE RENEWAL NEPA ISSUES^a

| | Issue | Category | Section of this Environmental Report |
|-----|--|-----------------|---|
| 53. | Power line right-of-way land use impacts | 1 | 4.0 |
| 54. | Radiation exposures to the public during refurbishment | 1 | 4.0 |
| 55. | Occupational radiation exposures during refurbishment | 1 | 4.0 |
| 56. | Microbiological organisms (occupational health) | 1 | 4.0 |
| 57. | Microbiological organisms (public health) (plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river) | 2 | 4.12 |
| 58. | Noise | 1 | 4.0 |
| 59. | Electromagnetic fields, acute effects (electric shock) | 2 | 4.13 |
| 60. | Electromagnetic fields, chronic effects | NA ^b | 4.0 |
| 61. | Radiation exposures to public (license renewal term) | 1 | 4.0 |
| 62. | Occupational radiation exposures (license renewal term) | 1 | 4.0 |
| 63. | Housing impacts | 2 | 4.14 |
| 64. | Public services: public safety, social services, and tourism and recreation | 1 | 4.0 |
| 65. | Public services: public utilities | 2 | 4.15 |
| 66. | Public services: education (refurbishment) | 2 | 4.16 |
| 67. | Public services: education (license renewal term) | 1 | 4.0 |
| 68. | Offsite land use (refurbishment) | 2 | 4.17.1 |
| 69. | Offsite land use (license renewal term) | 2 | 4.17.2 |
| 70. | Public services: transportation | 2 | 4.18 |
| 71. | Historic and archaeological resources | 2 | 4.19 |
| 72. | Aesthetic impacts (refurbishment) | 1 | 4.0 |
| 73. | Aesthetic impacts (license renewal term) | 1 | 4.0 |
| 74. | Aesthetic impacts of transmission lines (license renewal term) | 1 | 4.0 |
| 75. | Design basis accidents | 1 | 4.0 |
| 76. | Severe accidents | 2 | 4.20 |
| 77. | Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste) | 1 | 4.0 |
| 78. | Offsite radiological impacts (collective effects) | 1 | 4.0 |
| 79. | Offsite radiological impacts (spent fuel and high-level waste disposal) | 1 | 4.0 |
| 80. | Nonradiological impacts of the uranium fuel cycle | 1 | 4.0 |
| 81. | Low-level waste storage and disposal | 1 | 4.0 |
| 82. | Mixed waste storage and disposal | 1 | 4.0 |
| 83. | Onsite spent fuel | 1 | 4.0 |

TABLE A-1 (Cont'd)
RNP ENVIRONMENTAL REPORT DISCUSSION OF
LICENSE RENEWAL NEPA ISSUES^a

| | Issue | Category | Section of this Environmental Report |
|-----|---|-----------------|---|
| 84. | Nonradiological waste | 1 | 4.0 |
| 85. | Transportation | 1 | 4.0 |
| 86. | Radiation doses (decommissioning) | 1 | 4.0 |
| 87. | Waste management (decommissioning) | 1 | 4.0 |
| 88. | Air quality (decommissioning) | 1 | 4.0 |
| 89. | Water quality (decommissioning) | 1 | 4.0 |
| 90. | Ecological resources (decommissioning) | 1 | 4.0 |
| 91. | Socioeconomic impacts (decommissioning) | 1 | 4.0 |
| 92. | Environmental justice | NA ^b | 2.6.2 |

a. Source: 10 CFR 51, Subpart A, Appendix A, Table B-1. (Issue numbers added to facilitate discussion.)

b. Not applicable. Regulation does not categorize this issue.

NEPA = National Environmental Policy Act.

APPENDIX B

NPDES PERMIT

The National Pollutant Discharge Elimination System (NPDES) permit for Carolina Power and Light Company's H. B. Robinson Steam Electric Plant is a large document. Only the cover page, providing the authority to discharge to Lake Robinson and Black Creek, and pages related to the Section 316(a) variance and Section 316 (b) determination are included in this Appendix.



National Pollutant Discharge Elimination System Permit

for Discharge to Surface Waters

This Permit Certifies That

*Carolina Power & Light Company
H.B. Robinson Steam Electric Plant*

has been granted permission to discharge from a facility located at

*Hartsville, South Carolina
Darlington County*

to receiving waters named

Lake Robinson and Black Creek

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, and III hereof. This permit is issued in accordance with the provisions of the Pollution Control Act of South Carolina (S.C. Code Sections 48-1-10 *et seq.*, 1976), Regulation 61-9 and with the provisions of the Federal Clean Water Act (PL 92-500), as amended, 33 U.S.C. 1251 *et seq.*, the "Act."

Marion F. Sadler, Jr., Director
Industrial, Agricultural, and Storm Water Permitting Division
Bureau of Water

Issued: *September 29, 1997*

Expires: *September 30, 2001*

Effective: *October 1, 1997*

Permit No.: *SC0002925*

Rationale
NPDES Permit No. SC0002925
CP&L Co./H.B. Robinson Steam Electric Plant
Darlington County

TME/8/97

This is a renewal of the above referenced NPDES permit.

I. Project Description:

The Carolina Power & Light Company, H.B. Robinson Steam Electric Plant (hereinafter referred to as the Permittee), operates a nuclear and coal-fired steam electric power generating facility (SIC 4911). The electrical generating capacity of Unit 1 is rated at 185 megawatts MWe and Unit 2 is rated at 730 MWe. The facility is located at SC Highway 151 and 23 in Hartsville, South Carolina. The effluent discharge from this facility is subject to the Steam Electric Power Generating Point Source Category (40 CFR Part 423). This facility discharges effluent through the following outfalls and corresponding locations:

| <u>Outfall</u> | <u>Latitude</u> | <u>Longitude</u> |
|----------------|-----------------|------------------|
| 001 | 34° 27' 30" | 80° 09' 45" |
| 002 | 34° 27' 30" | 80° 09' 45" |
| 003 | 34° 27' 30" | 80° 09' 45" |
| 005 | 34° 27' 30" | 80° 09' 45" |
| 006 | 34° 27' 30" | 80° 09' 45" |
| 007 | 34° 27' 30" | 80° 09' 45" |
| 008 | 34° 24' 00" | 80° 09' 07" |
| 009 | 34° 24' 00" | 80° 09' 07" |
| 011 | 34° 24' 00" | 80° 09' 07" |
| 013 | 34° 27' 30" | 80° 09' 45" |
| 014 | 34° 27' 30" | 80° 09' 45" |

The receiving waters are the Black Creek and Lake Robinson. The Black Creek is classified as Freshwaters by (Regulation 61-69). Lake Robinson, however, is not classified by SCDHEC; since Lake Robinson is a source of water to the Black Creek it shall be assumed to be similarly designated as a Freshwater. A Freshwater is suitable for primary contact recreation, secondary contact recreation, and as a source for drinking water after conventional treatment. A freshwaters are suitable for fishing and the survival and propagation of a balanced indigenous aquatic community of fauna and flora, as well as for industrial and agricultural uses.

II. General Information:

A. The facility contact and mailing address follows:

J. W. Moyer, General Manager
H.B. Robinson Steam Electric Plant
3581 West Entrance Road
Hartsville, South Carolina 29550

CP&L Co./H.B. Robinson Steam Electric Plant
Page 28 of 30

- a) The sanitary sludge may only be disposed of to the ash pond during periods when ash is being sluiced into the ash pond.
- b) A maximum of 10,000 gallons of sanitary sludge may be disposed of to the ash pond on a weekly basis. Also, when the surge, septic, and contact chambers are purged on a quarterly basis, a maximum of 24,000 additional gallons may be disposed of to the ash pond.

The Permittee will be required to obtain prior written approval for any other sludge disposal activities at this facility.

VI. Operator

The Permittee's present treatment system consists of sedimentation and neutralization. The highest classification of the operation of all treatment equipment is usually used to determine the operator requirement. Based on the wastewater treatment system classification, an operator with a Grade B-B or higher certification is required to accept the responsibility of inspections made by lower grade operators.

VII. Groundwater Monitoring

The Permittee shall monitor and report each of the four (4) groundwater monitoring wells semiannually for the following parameters:

| | |
|--|----------------------|
| Water Level, tenth/feet | Arsenic, total, mg/l |
| Total Dissolved Solids | Iron, total, mg/l |
| pH (field), standard units | Sulfate, mg/l |
| Specific Conductance (field), umhos/cm | Zinc, total, mg/l |

VIII. Previous Biological Studies

A. 316(a)

Studies of the thermal effects of the discharge were provided in support of the 316(a) variance request with a June 30, 1976 316(a) Demonstration. On November 15, 1977, a determination was made that the protection and propagation of a balanced, indigenous population of fish, shellfish, and other aquatic organisms in and on Lake Robinson will be assured by the continued operation of the H.B. Robinson Steam Electric Plant in its present once-through mode. Additionally, since 1976, the Permittee has been conducting an annual environmental monitoring reports of the Lake Robinson impoundment. To date, the 1986 Annual Environmental Monitoring Report has noted the worst case conditions (low pool, high ambient temperature, high discharge temperature). On May 20, 1994, Consent Agreement 94-034-W, which regard the temperature limits for Outfall 001, was finalized. This Consent Agreement adjusts the thermal limitations of the previous 316(a) variance to allow more gradual seasonal temperature limitations. On January 16, 1996, a meeting was held to discuss the Daily Average and Daily Maximum Heat Discharge Limitation on page 2 of the permit, it was determined that the Heat

CP&L Co./H.B. Robinson Steam Electric Plant
Page 29 of 30

Discharge Limitations were not necessary and that the existing temperature limits would protect the receiving water body. With the August 27, 1996 renewal application, additional reports and studies were provided and requested that the 316(a) variance be renewed, and that the two week steps of the previous permit be reduced to monthly transition. The thermal limitations shown in the Conclusion of Section III.B Temperature of the rationale were the monthly agreed upon thermal limitations with the renewal of the 316(a) variance.

B. 316(b)

Section 316(b) of the CWA requires that the location, design, construction and capacity of a cooling water intake structure reflect the best technology available for minimizing environmental impact. In addition, Section 316(b) of the CWA requires that the location, design, construction, and capacity of a cooling water intake structure reflect the best technology available for minimizing environmental impacts. On November 15, 1977, a determination was made that the lake was sustaining good populations of fish, including bluegill, and does not appear to adversely impacted by impingement. Also, the location, design, construction, and capacity of the cooling water intake structures at the H.B. Robinson Steam Electric Plant reflect the best technology available for minimizing adverse environmental impact.

IX. Co-Treatment

Where various wastes are combined for treatment and discharge, 40 CFR 423.13(h) requires that the quantity of each pollutant or pollutant property not exceed the specified limitation for that waste source. Applicable guideline concentrations were flow weighted in calculating final effluent concentrations.

X. Toxicity Testing

Since the chemical specific approach does not address all specific chemicals and their interactions with other components in the waste stream, a more comprehensive testing requirement is needed. To ensure that water quality is not deteriorated, whole effluent toxicity testing is being required at Outfalls 001 and 011 in accordance with procedures set out in The South Carolina Department of Health and Environmental Control Toxic Control Strategy for Wastewater Discharges, South Carolina Department of Health and Environmental Control, October 1990. These procedures require either acute or chronic toxicity testing based on whether a diffuser is used and the Instream Waste Concentration (IWC), which is calculated as follows:

IWC for the Discharge Canal to Lake Robinson:

$$\begin{aligned} \text{IWC} &= (\text{Effluent flow}/(\text{Dilution flow} + \text{Effluent flow})) \times 100 \\ &= (1.2608)/(209) \\ &= 0.6\% \end{aligned}$$

Based on State procedures, if a diffuser is not installed and the FWC is less than 1%, then acute toxicity testing is required. Therefore, acute toxicity screening at 100% effluent will be required to be conducted at a frequency of once per quarter.

APPENDIX C

SPECIAL-STATUS SPECIES CORRESPONDENCE

| <u>Letter</u> | <u>Page</u> |
|---|-------------|
| Letter, Fletcher (CP&L) to Banks (U.S. Fish and Wildlife Service), May 31, 2001 | C-2 |
| Letter, Gilbert (U.S. Fish and Wildlife Service) to Fletcher (CP&L) June 7, 2001 | C-4 |
| Letter Fletcher (CP&L) to Holling (SC Department of Natural Resources) May 31, 2001 | C-8 |
| Letter, Holling (SC Department of Natural Resources) to Fletcher (CP&L) June 4, 2001 | C-10 |



Serial: RNP-RA/01-0074

MAY 31 2001

Mr. Roger Banks
Field Supervisor
U. S. Fish and Wildlife Service
176 Croghan Spur Road
Suite 200
Charleston, SC 29407

**H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
REQUEST FOR INFORMATION ON
LISTED SPECIES AND IMPORTANT HABITATS**

Dear Mr. Banks:

Carolina Power & Light (CP&L) Company is preparing an application to the U. S. Nuclear Regulatory Commission (NRC) to renew the operating license for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, which expires on July 31, 2010. CP&L intends to submit this application for license renewal before the fourth quarter of 2002. As part of the license renewal process, the NRC requires, in 10 CFR 51.53(c)(3)(ii)(E), that applicants "assess the impact of the proposed action on threatened or endangered species in accordance with the Endangered Species Act." The NRC will consult with your office in accordance with Section 7 of the Endangered Species Act to determine if any listed species or critical habitat occurs in the project area. By contacting you early in the application process, CP&L hopes to identify any issues that need to be addressed or any information that your office may need to expedite the NRC consultation.

CP&L has operated HBRSEP and associated transmission lines, shown on the enclosed Figure 1, since 1970. The plant is in Darlington County, South Carolina, approximately 4.5 miles west northwest of the city of Hartsville. The plant is situated on the southwest shore of Lake Robinson, which was created by CP&L in 1959 to serve as a source of cooling water for power production. The plant site encompasses approximately 4800 acres including the lake.

Robinson Nuclear Plant
3681 West Entrance Road
Hartsville, SC 29550

Mr. Roger Banks
U. S. Fish and Wildlife Service
Serial: RNP-RA/01-0074
Page 2 of 2

The plant is connected to the regional electric transmission grid by 230 kilovolt transmission lines with intrasystem tie points at Darlington, SC, at Rockingham, NC, at Sumter, SC, at Florence, SC, and two lines that connect to CP&L's Darlington County plant which is located near HBRSEP.

There are no plans to substantively alter current operations over the license renewal period. No substantive disturbance of land is anticipated. The operation of HBRSEP through the license renewal term of an additional 20 years is not expected to adversely affect any threatened or endangered species. Inactive nesting sites of the red cockaded woodpecker have been identified on the HBRSEP site. CP&L has entered into the Safe Harbors Program to protect this habitat.

Please provide any information that you may have about any state or federally listed species or ecologically significant habitats that may occur on the 4800 acre HBRSEP site or along the associated transmission corridors shown on the enclosed Figures by July 30, 2001. A copy of this letter and your response will be included in the license renewal application that is submitted to the NRC. This request was discussed with you in a telephone conference with Mr. Jan S. Kozyra, CP&L, on May 29, 2001.

If you have any questions concerning this matter, please contact Mr. Kozyra at 843-857-1872.

Sincerely,



B. L. Fletcher, III
Manager – Regulatory Affairs

Enclosures

c: Mr. Henry Porter, DHEC



United States Department of the Interior

FISH AND WILDLIFE SERVICE
176 Croghan Spur Road, Suite 200
Charleston, South Carolina 29407

June 7, 2001

Mr. B. L. Fletcher, III
Carolina Power and Light, Inc.
Robinson Nuclear Plant
3581 West Entrance Road
Hartsville, SC 29550

Re: H. B. Robinson Steam Electric Plant, Unit No. 2 license renewal

Dear Mr. Fletcher:

We have reviewed the information received May 31, 2001 concerning the above-referenced project. The project seeks to renew the operating license of the H. B. Robinson Steam Electric Plant and associated transmission lines that have been in production since 1970. The plant itself covers an area approximately 4800 acres, including Lake Robinson, and is connected to the regional electric transmission grid by 230 kilovolt transmission lines with intra-system tie points at Darlington, SC, at Rockingham, NC, at Sumter, SC, at Florence, SC, and two lines that connect to CP&L's Darlington County plant which is located near HBRSEP. The following comments are provided in accordance with the Fish and Wildlife Coordination Act, as amended (16 U.S.C. 661-667e), and section 7 of the Endangered Species Act, as amended (16 U.S.C. 1531-1543).

We believe there is potential habitat for federally protected species and/or the presence of designated or proposed critical habitat within the action area of your proposed project. Staffing limitations currently prevent us from conducting a field inspection of the action area. Therefore, we are unable to provide you with site-specific comments at this time.

Without further analysis of the "effects of the action," (as defined by 50 CFR 402.02) on federally protected species we are unable to concur that the proposed action is not likely to adversely impact such species and/or critical habitat.

Therefore, we are providing a list of the federally endangered (E) and threatened (T) and candidate (C) species which potentially occur in Sumter, Darlington, Florence, and Lee Counties in South Carolina to aid you in determining the impacts your project may have on protected species. The list also includes species of concern under review by the Service. Species of

This is your future. Don't leave it blank. - Support the 2000 Census.

concern (SC) are not legally protected under the Endangered Species Act, and are not subject to any of its provisions, including Section 7, until they are formally proposed or listed as endangered/threatened. We are including these species in our response for the purpose of giving you advance notification. These species may be listed in the future, at which time they will be protected under the Endangered Species Act. Therefore, it would be prudent for you to consider these species early in project planning to avoid any adverse effects.

In-house surveys should be conducted by comparing the habitat requirements for the attached listed species with available habitat types at the project site. Field surveys for the species should be performed if habitat requirements overlap with that available at the project site. Surveys for protected plant species must be conducted by a qualified biologist during the flowering or fruiting period(s) of the species. Surveys for the red-cockaded woodpecker should be conducted in accordance with the "Guidelines for preparation of biological assessments and evaluations for the red-cockaded woodpecker" by Gary Henry. A copy of these guidelines is available from this office. Please notify this office with the results of any surveys for the below list of species and an analysis of the "effects of the action," as defined by 50 CFR 402.02 on any listed species including consideration of direct, indirect, and cumulative effects.

**South Carolina Distribution Records of
 Endangered, Threatened, Candidate and Species of Concern**

- E Federally endangered
- T Federally threatened
- P Proposed in the Federal Register
- CH Critical Habitat
- C The U.S. Fish and Wildlife Service or the National Marine Fisheries Service has on file sufficient information on biological vulnerability and threat(s) to support proposals to list these species
- S/A Federally protected due to similarity of appearance to a listed species
- SC Federal Species of concern. These species are rare or limited in distribution but are not currently legally protected under the Endangered Species Act.
- * Contact the National Marine Fisheries Service for more information on this species

These lists should be used only as a guideline, not as the final authority. The lists include known occurrences and areas where the species has a high possibility of occurring. Records are updated continually and may be different from the following.


| <u>County</u> | <u>Common Name</u> | <u>Scientific Name</u> | <u>Status</u> | <u>Occurrences</u> |
|-------------------|--------------------------|----------------------------------|---------------|--------------------|
| Darlington | Red-cockaded woodpecker | <i>Picoides borealis</i> | E | Known |
| | Shortnose sturgeon | <i>Acipenser brevirostrum*</i> | E | Possible |
| | Rough-leaved loosestrife | <i>Lysimachia asperulaefolia</i> | E | Known |
| | Awnead meadowbeauty | <i>Rhexia aristosa</i> | SC | Known |

| | | | | |
|-----------------|----------------------------|---|----|-------|
| | Carolina bogmint | <i>Macbridea caroliniana</i> | SC | Known |
| | Georgia lead-plant | <i>Amorpha georgiana</i> var. <i>georgiana</i> | SC | Known |
| | Rafinesque's big-eared bat | <i>Corynorhinus rafinesquii</i> | SC | Known |
| | Sandhills milkvetch | <i>Astragalus michauxii</i> | SC | Known |
| | Spring-flowering goldenrod | <i>Solidago verna</i> | SC | Known |
| | Well's pixie-moss | <i>Pyxidantha brevifolia</i> | SC | Known |
| | White false-asphodel | <i>Tofieldia glabra</i> | SC | Known |
| Florence | | | | |
| | Bald eagle | <i>Haliaeetus leucocephalus</i> | T | Known |
| | Red-cockaded woodpecker | <i>Picoides borealis</i> | E | Known |
| | Shortnose sturgeon | <i>Acipenser brevirostrum</i> * | E | Known |
| | Chaffseed | <i>Schwalbea americana</i> | E | Known |
| | Carolina bogmint | <i>Macbridea caroliniana</i> | SC | Known |
| | Georgia lead-plant | <i>Amorpha georgiana</i> var. <i>georgiana</i> | SC | Known |
| | Ovate catchfly | <i>Silene ovata</i> | SC | Known |
| Lee | | | | |
| | Red-cockaded woodpecker | <i>Picoides borealis</i> | E | Known |
| | Canby's dropwort | <i>Oxypolis canbyi</i> | E | Known |
| | Chaffseed | <i>Schwalbea americana</i> | E | Known |
| | Awnead meadowbeauty | <i>Rhexia aristosa</i> | SC | Known |
| Sumter | | | | |
| | Bald eagle | <i>Haliaeetus leucocephalus</i> | T | Known |
| | Red-cockaded woodpecker | <i>Picoides borealis</i> | E | Known |
| | Shortnose sturgeon | <i>Acipenser brevirostrum</i> * | E | Known |
| | Canby's dropwort | <i>Oxypolis canbyi</i> | E | Known |
| | Chaff-seed | <i>Schwalbea americana</i> | E | Known |
| | Dwarf burhead | <i>Echinodorus parvulus</i> | SC | Known |
| | Awnead meadowbeauty | <i>Rhexia aristosa</i> | SC | Known |
| | Boykin's lobelia | <i>Lobelia boykinii</i> | SC | Known |

We also recommend you contact the S.C. Department of Natural Resources (SCDNR), Data Manager, Wildlife Diversity Section, Columbia, SC 29202, concerning known populations of federal and/or state endangered or threatened species, and other sensitive species in the project area. Additional habitat information may also be available from SCDNR. The National Marine Fisheries Service, 9721 Executive Center Drive North, St. Petersburg, FL 33702-2449 should be contacted for consultation on species under their jurisdiction.

Your interest in ensuring the protection of endangered and threatened species and our nation's valuable wetland resources is appreciated. If you have any questions please contact Ms. Lori Duncan or Ms. Olivia Westbrook of my staff at (843) 727-4707 ext. 21. In future correspondence concerning the project, please reference FWS Log No. 4-6-01-I-285.

Sincerely yours,



Steven S. Gilbert
Acting Field Supervisor

SSG/LWD/OW



Serial: RNP-RA/01-0073

MAY 31 2001

Ms. Julie Holling
Data Manager
Wildlife Diversity Section
South Carolina Heritage Trust Program
South Carolina Department of Natural Resources
P. O. Box 167
Columbia, SC 29202

**H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
REQUEST FOR INFORMATION ON
LISTED SPECIES AND IMPORTANT HABITATS**

Dear Ms. Holling:

Carolina Power & Light (CP&L) Company is preparing an application to the U. S. Nuclear Regulatory Commission (NRC) to renew the operating license for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, which expires on July 31, 2010. CP&L intends to submit this application for license renewal before the fourth quarter of 2002. As part of the license renewal process the NRC requires, in 10 CFR 51.53(c)(3)(ii)(E), that applicants, "assess the impact of the proposed action on threatened or endangered species in accordance with the Endangered Species Act." The NRC will consult with the U. S. Fish and Wildlife Service in accordance with Section 7 of the Endangered Species Act, and may also seek your assistance in the identification of important species and habitats in the project area. By contacting you early in the application process, CP&L hopes to identify any issues that need to be addressed or any information that your office may need to expedite the NRC consultation.

CP&L has operated HBRSEP and associated transmission lines, shown on the enclosed Figure 1, since 1970. The plant is in Darlington County, South Carolina, approximately 4.5 miles west northwest of the city of Hartsville. The plant is situated on the southwest shore of Lake Robinson, which was created by CP&L in 1959 to serve as a source of cooling water for power production. The plant site encompasses approximately 4800 acres including the lake.

Robinson Nuclear Plant
3381 West Entrance Road
Hartsville, SC 29550

Ms. Julie Holling
South Carolina Heritage Trust Program
Serial: RNP-RA/01-0073
Page 2 of 2

The plant is connected to the regional electric transmission grid by 230 kilovolt transmission lines with intrasystem tie points at Darlington, SC, at Rockingham, NC, at Sumter, SC, at Florence, SC, and two lines that connect to CP&L's Darlington County plant which is located near HBRSEP.

There are no plans to substantially alter current operations over the license renewal period. No substantive additional disturbance of land is anticipated. The operation of HBRSEP through the license renewal term of an additional 20 years is not expected to adversely affect any threatened or endangered species. Inactive nesting sites of the red cockaded woodpecker have been identified on the HBRSEP site. CP&L has entered into the Safe Harbors Program to protect this habitat.

Please provide any information that you may have about any state or federally listed species or ecologically significant habitats that may occur on the 4800 acre HBRSEP site or along the associated transmission corridors, shown on the enclosed Figures, by July 31, 2001. The request was discussed with you in a telephone conference with Mr. Jan S. Kozyra, CP&L, on May 25, 2001. A copy of this letter and your response will be included in the license renewal application that will be submitted to the NRC.

If you have any questions concerning this matter, please contact Mr. Kozyra at 843-857-1872.

Sincerely,



B. L. Fletcher, III
Manager – Regulatory Affairs

Enclosures

c: Mr. H. Porter, DHEC

South Carolina Department of Natural Resources



Paul A. Sandier, Ph.D.
Director

William S. McTeer
Deputy Director for
**Wildlife and
Freshwater Fisheries**

June 4, 2001

B. L. Fletcher, III
Manager – Regulatory Affairs
CP&L, Robinson Nuclear Plant
3581 West Entrance Rd.
Hartsville, SC 29550

RE: H. B. Robinson Steam Electric Plant, Unit No. 2
Request for information on Listed Species and Important Habitat

Dear Mr. Fletcher,

The only information that I can provide is the known occurrences of rare, threatened and endangered species. Since a comprehensive biological inventory of the state has not been done, we rely on biologists to provide information for our database. We do not currently track habitat information.

I have checked our database, and there are two known occurrences within one mile of the HBRSEP. One, the federally endangered *Picoides borealis*, or Red-cockaded Woodpecker, is found west of the upper section of Lake Robinson (above SSR 346) on Sandhills State Forest property. The other occurrence is of *Condylura cristata* or Star-nosed Mole, a species of state concern. This occurrence is located North of Lake Robinson on Black Creek. Please understand that our database does not represent a comprehensive biological inventory of the state. Fieldwork remains the responsibility of the investigator.

If you need additional assistance, please contact me by phone at 803/734-3917 or by e-mail at JulieH@scdnr.state.sc.us.

Sincerely,

Julie Holling
SC Department of Natural Resources
Heritage Trust Program

APPENDIX D

MICROBIOLOGICAL ORGANISMS CORRESPONDENCE

| <u>Letter</u> | <u>Page</u> |
|---|-------------|
| Letter, Fletcher (CP&L) to Brown (SCDHEC), May 25, 2001 | D-2 |
| Letter, Brown (SCDHEC) to Fletcher (CP&L), May 25, 2001 | D-5 |



Serial: RNP-RA/01-0071

MAY 25 2001

Dr. John F. Brown
State Toxicologist
S. C. Department of Health and Environmental Control
Division of Health Hazard Evaluation
2600 Bull Street
Columbia, SC 29201

**H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
REQUEST FOR INFORMATION ON
THERMOPHILIC ORGANISMS**

Dear Dr. Brown:

Carolina Power & Light (CP&L) Company is preparing an application to the U. S. Nuclear Regulatory Commission (NRC) to renew the operating license for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, which expires on July 31, 2010. CP&L intends to submit this application for license renewal by the fourth quarter of 2002.

As part of the license renewal process, the NRC requires, in 10 CFR 51.53(c)(3)(ii)(G), that applicants provide, "... an assessment of the impact of the proposed action on public health from thermophilic organisms in the affected water." The NRC regulation states that, "these organisms are not expected to be a problem at most operating plants," but states further that, "without site-specific data, it is not possible to predict the effects generically."

CP&L has operated HBRSEP since 1970. The plant is in Darlington County, South Carolina, approximately 4.5 miles west-northwest of the city of Hartsville, South Carolina. The plant is situated on the southwest shore of Lake Robinson, which was created by CP&L in 1959 to serve as a source of cooling water for power production. The plant cooling system withdraws water from Lake Robinson and returns it to the lake via a discharge canal approximately 4.2 miles long. Discharge limits and monitoring requirements are set forth in NPDES Permit No. SC0002925 issued by the South Carolina Department of Health and Environmental Control (SCDHEC).


Robinson Nuclear Plant
3591 West Entrance Road
Hartsville, SC 29550

Dr. John F. Brown
South Carolina Department of Health and Environmental Control
Serial: RNP-RA/01-0071
Page 2 of 2

CP&L requests any information that SCDHEC may have compiled on the occurrence of thermophilic microorganisms in Lake Robinson, including the results of any monitoring or special studies that might have been conducted by SCDHEC or its contractors. CP&L is particularly interested in determining if there is a concern about the possible presence of *naegleria fowleri* in the lake. CP&L would appreciate a response by July 31, 2001. This request was discussed with you during a telephone conversation with Mr. Jan S. Kozyra, CP&L, on May 25, 2001.

If you have any questions concerning this matter, please contact Mr. Kozyra at 843-857-1872.

Very truly yours,


B. L. Fletcher, III
Manager – Regulatory Affairs

JSK/jsk

c: Mr. H. Porter, DHEC

bc: Mr. H. K. Chernoff
Mr. T. B. Clements
Mr. J. Cudworth, Tetra Tech NUS



May 25, 2001

Mr. B.L. Fletcher, III
Robinson Nuclear Plant
3581 West Entrance Road
Hartsville, SC 29550

Dear Mr. Fletcher:

Thank you for your letter requesting DHEC public health concerns regarding thermophilic microorganisms associated with cooling water releases from nuclear power generation plants.

While some microorganisms associated with thermal water discharges, especially related to air conditioning cooling towers, have been demonstrated to have deleterious human health effects, these events have occurred rarely and none have been identified with heated water sources associated with nuclear power plants, to my knowledge. Pathogenic species of Legionella bacteria and Naegleria amoeba have been identified in heated cooling waters associated with nuclear plants. In most cases, the heated waters showed a very small increase (approximately 10-fold) over unheated source waters, but were substantially higher in source waters in a few cases.

The most likely exposure to Legionella aerosol would be to workers within the plant. This would not impact the general public beyond the plant boundaries. A similar exposure possibility exists for Naegleria, with a slightly greater exposure potential for swimmers. The potential public health hazard from pathogenic microorganisms whose abundance might be promoted by artificial warming of recreational waters is largely theoretical and not substantiated by available data. There is some justification for providing appropriate respiratory and dermal protection for workers regularly exposed to known contaminated water, but there seems no significant threat to off-site persons near such heated recreational waters. Routine monitoring for pathogenic microorganisms could be established if suspicious illnesses arose or if there were significant community concerns. Contact me at 803-896-9723, if you desire additional discussion of this matter.

Sincerely,

A handwritten signature in black ink that reads "John F. Brown, DVM, PhD".

John F. Brown, DVM, PhD
State Toxicologist

pc: H.J. Porter, Hazardous/Infectious Waste/Land & Waste Management/DHEC

APPENDIX E

CULTURAL RESOURCES CORRESPONDENCE

| <u>Letter</u> | <u>Page</u> |
|---|-------------|
| Letter, Fletcher (CP&L) to Brock (SC Department of Archives and History), May 31, 2001 | E-2 |
| Letter, Brock (SC Department of Archives and History) to Fletcher (CP&L), August 8, 2001 | E-5 |



Serial: RNP-RA/01-0072

MAY 31 2001

Ms. Nancy Brock
State Historic Preservation Office - Review and Compliance
South Carolina Department of Archives and History
Archives & History Center
8301 Parklane Road
Columbia, SC 29223

**H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
REQUEST FOR INFORMATION ON
HISTORIC AND ARCHAEOLOGICAL RESOURCES**

Dear Ms. Brock:

Carolina Power & Light (CP&L) Company is preparing an application to the U. S. Nuclear Regulatory Commission (NRC) to renew the operating license for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, which expires on July 31, 2010. CP&L intends to submit this application for license renewal by the fourth quarter of 2002. As part of the license renewal process, the NRC requires, in 10 CFR 51.53(c)(3)(ii)(K), that applicants "assess whether any historic or archaeological properties will be affected by the proposed project." The NRC may also request an informal consultation with your office at a later date in accordance with Section 106 of the National Historic Preservation Act of 1966, as amended (16 USC 470) and the Federal Advisory Council on Historic Preservation regulations (36 CFR 800). By contacting you early in the application process, CP&L hopes to identify any issues that need to be addressed or any information that your office may need to expedite the NRC consultation.

CP&L has operated HBRSEP, Unit No. 2 and associated transmission lines, shown on the enclosed Figure 1, since 1970. The plant is in Darlington County, South Carolina, approximately 4.5 miles west northwest of the city of Hartsville, South Carolina. The plant is situated on the southwest shore of Lake Robinson, which was created by CP&L in 1959 to serve as a source of cooling water for power production. The plant site encompasses approximately 4800 acres including the lake.

Ms. Nancy Brock
State Historic Preservation Office
Serial: RNP-RA/01-0072
Page 2 of 2

The Robinson Plant is connected to the regional electric transmission grid by 230 kilovolt transmission lines with intrasystem tie points at Darlington, SC, at Rockingham, NC, at Sumter, SC, at Florence, SC, and two lines that connect to CP&L's Darlington County plant which is located near HBRSEP.

Using the National Register Information System (NRIS) on-line database, a list of sites on the National Register of Historic Places within a six-mile radius of the plant has been compiled. CP&L also has visited your office to review relevant materials. In addition, the project has been discussed with the South Carolina Institute of Archaeology and Anthropology, and files have been reviewed to identify archaeological sites in the vicinity of the plant.

CP&L believes that the operation of HBRSEP, Unit No. 2, through the license renewal term of an additional 20 years, will not have an adverse effect on historic or cultural resources in the region. There are no plans to substantially alter current operations over the license renewal period. No substantive additional disturbance of land is anticipated.

Please notify us of any concerns you may have about historic or archaeological properties in the site vicinity or confirming the conclusion that operation of HBRSEP over the license renewal term would have no effect on any historic or archaeological properties in South Carolina. Area maps are enclosed to aid you in locating HBRSEP. CP&L would appreciate a response by July 31, 2001. A copy of this letter and your response will be included in the license renewal application that will be submitted to the NRC. This request was discussed with you in a telephone conference with Mr. Jan S. Kozyra, CP&L, on May 29, 2001.

If you have any questions concerning this matter, please contact Mr. Kozyra at 843-857-1872.

Sincerely,




B. L. Fletcher, III
Manager – Regulatory Affairs

Enclosures

c: Mr. H. Porter, DHEC

bc: Mr. H. K. Chernoff
Mr. T. B. Clements
Mr. J. Cudworth, Tetra Tech NUS



August 8, 2001

Mr. B. L. Fletcher, III
Manger – Regulatory Affairs
Robinson Nuclear Plant
3581 W. Entrance Road
Hartsville, SC 29550

Re: Robinson Nuclear Plant
Darlington County

Dear Mr. Fletcher:

Thank you for your letter of May 31, which we received by fax transmittal on August 8, regarding the proposed renewal of the operating license for the Robinson Nuclear Plant in Darlington County.

It does not appear, based on the information provided, that any properties listed on or determined eligible for inclusion in the National Register of Historic Places will be affected. Since the license renewal does not involve new construction, archaeological sites should not be affected.

These comments are provided as evidence of your consultation with the State Historic Preservation Office. If you have questions, please don't hesitate to call me at 803/896-6169.

Sincerely,

Nancy Brock, Coordinator
Review and Compliance Programs
State Historic Preservation Office

APPENDIX F

SEVERE ACCIDENT MITIGATION ALTERNATIVES

TABLE OF CONTENTS

| <u>Section</u> | <u>Page</u> |
|--|-------------|
| F.1 Methodology..... | 1 |
| F.1.1 RNP Specific SAMA | 2 |
| F.2 RNP PSA Model..... | 2 |
| F.2.1 Power Uprate..... | 3 |
| F.3 Level 3 PSA Analysis | 3 |
| F.3.1 Analysis | 3 |
| F.3.2 Population | 4 |
| F.3.3 Site Parameters..... | 5 |
| F.3.4 Results | 7 |
| F.4 Baseline Risk Monetization | 7 |
| F.4.1 Off-site Exposure Cost | 7 |
| F.4.2 Off-Site Exposure Cost..... | 7 |
| F.4.3 Off-Site Economic Cost Risk (OECR)..... | 8 |
| F.4.4 On-Site Exposure Cost Risk..... | 8 |
| F.4.5 On-Site Cleanup and Decontamination Cost..... | 9 |
| F.4.6 Replacement Power Cost..... | 10 |
| F.4.7 Total | 11 |
| F.5 Phase I SAMA Analysis..... | 11 |
| F.5.1 SAMA Identification | 11 |
| F.5.2 Screening | 12 |
| F.6 Phase II SAMA Analysis..... | 12 |
| F.6.1 Phase II SAMA number 1: Prevent charging pump flow diversion from the relief valves | 13 |
| F.6.2 Phase II SAMA number 2: Improved ability to cool the residual heat removal heat exchangers | 14 |
| F.6.3 Phase II SAMA number 3: Increase frequency for valve leak testing | 16 |
| F.6.4 Phase II SAMA Number 4: Improved MSIV Design..... | 17 |
| F.6.5 Phase II SAMA Number 5: Install a digital feedwater upgrade | 18 |
| F.6.6 Phase II SAMA Number 6: Replace current PORVs with larger ones such that only one is required for successful feed and bleed..... | 19 |
| F.6.7 Phase II SAMA Number 7: Implement an RWST make-up procedure | 20 |
| F.6.8 Phase II SAMA Number 8: Create Automatic Swap Over to Recirculation on RWT Depletion | 21 |
| F.6.9 Phase II SAMA Number 9: Train operations crew for response to inadvertent actuation signals | 23 |
| F.6.10 Phase II SAMA Analysis Summary..... | 23 |
| F.7 Uncertainty Analysis..... | 24 |
| F.8 Conclusions..... | 25 |
| F.9 Tables and Figures | 27 |
| F.10 References | 108 |

List of Tables

| <u>Table</u> | <u>Page</u> |
|--|-------------|
| Table F-1 Estimated population distribution within a 10-mile radius of RNP, year 2030 | 28 |
| Table F-2 Estimated population distribution within a 50-mile radius of RNP, year 2030 | 29 |
| Table F-3 Estimated annual population growth rate within a 10-mile radius of RNP | 30 |
| Table F-4 Estimated annual population growth rate within a 10 to 50-mile radius of RNP | 31 |
| Table F-5. Estimated RNP core inventory. | 32 |
| Table F-6. MACCS release categories vs. RNP release categories. | 33 |
| Table F-7 Results of RNP Level 3 PSA analysis | 34 |
| Table F-8 Phase I SAMA..... | 35 |
| Table F-9 Phase II SAMA..... | 101 |

List of Figures

| <u>Figure</u> | <u>Page</u> |
|-----------------------------------|-------------|
| Figure F-1 SAMA Screening Process | 107 |

Appendix F

Severe Accident Mitigation Alternatives

The severe accident mitigation alternatives (SAMA) analysis discussed in 4.20 is presented below.

F.1 METHODOLOGY

The methodology selected for this analysis involves identifying SAMA candidates that have the highest potential for reducing core damage frequency and person-rem and determining whether or not the implementation of those candidates is beneficial on a cost-risk reduction basis. This process consists of the following steps:

- RNP Probabilistic Safety Assessment (PSA) Model – Use the RNP PSA model as the basis for the analysis ([Section F.2](#)).
- Level 3 PSA Analysis – Use RNP Level 1 and 2 PSA output and site-specific meteorology, demographic, land use, and emergency response data as input in performing a Level 3 probabilistic safety assessment (PSA) using the MELCOR Accident Consequences Code System Version 2 (MAACS2) ([Section F.3](#)).
- Baseline Risk Monetization – Use NRC regulatory analysis techniques, calculate the monetary value of the unmitigated RNP severe accident risk. This becomes the maximum averted cost-risk that is possible ([Section F.4](#)).
- Phase I SAMA Analysis – Identify potential SAMA candidates based on RNP, NRC, and industry documents. Screen out Phase 1 SAMA candidates that are not applicable to the RNP design or are of low benefit in pressurized water reactors (PWRs) such as RNP, candidates that have already been implemented at RNP or whose benefits have been achieved at RNP using other means, and candidates whose estimated cost exceeds the maximum possible averted cost-risk ([Section F.5](#)).
- Phase II SAMA Analysis – Calculate the risk reduction attributable to each remaining SAMA candidate and compare to a more detailed cost analysis to identify any net cost benefit. Probabilistic safety assessment (PSA) insights are also used to screen SAMA candidates in this phase ([Section F.6](#)).
- Uncertainty Analysis – Evaluate how a reduced discount value might affect the cost/benefit analyses and the effect of limiting the analyses to accident sequences that only contribute to the large early release frequency (LERF) ([Section F.7](#)).
- Conclusions – Summarize results and identify conclusions ([Section F.8](#)).

The steps outlined above are described in more detail in the subsections of this appendix and [Figure F-1](#) provides a graphical representation of the SAMA process.

F.1.1 RNP SPECIFIC SAMA

The initial list of Severe Accident Mitigation Alternative candidates for RNP was developed from lists of SAMAs at other nuclear power plants (References 56, 9, 5, 7, 4, 12, 13, and 14), NRC documents (References 1, 2, 3, 6, 8, 15, 16, and 19), and documents related to advanced power reactor designs (ABWR SAMAs) (References 17, 10, and 11). In addition, plant specific analyses (References 20, 21) have been used to identify potential SAMAs which address RNP vulnerabilities. This process is considered to adequately address the requirement of identifying significant safety improvements that could be performed at RNP. The initial SAMA list, Table F-8, includes a column which documents the reference sources for each individual SAMA.

The RNP IPEEE (Reference 21) also identified potential opportunities for plant improvements. As a result of the Seismic and Fire Analysis, potential plant changes were considered and dispositioned according to their importance.

Given the existing assessments of external events and internal fires at RNP, the cost benefit analysis uses the internal events PSA as the basis for measuring the impact of SAMA implementation. No fire or external events models are used in this analysis as the fire and IPEEE programs are considered to have already addressed potential plant improvements related to those categories.

F.2 RNP PSA MODEL

The RNP IPE model (Reference 20) was submitted to the NRC in August of 1992.

MOR99 is the most recent RNP PSA model of record. After a minor correction (described below), it served as the base case for SAMA core damage frequency (CDF) and LERF calculations and as the model and database that were modified for all calculations shown in Section F.6. The MOR99 baseline CDF is 4.32×10^{-05} per year. The baseline LERF is 5.59×10^{-06} per year based on corrections performed on the MOR99 LERF model. These corrections include the re-labeling of plant damage states (PDS) and an alteration in the truncation process.

It was determined that plant damage states were being incorrectly assigned in the MOR 99 model. A temporary fix has been adopted to obtain the appropriate cutsets. This fix requires that X-PDSX14B be re-assigned to X-PDSX14C, and X-PDSX14E be re-assigned to X-PDSX14F.

An additional change was identified that has no quantitative impact. Plant damage state X-PDS12C has been changed to X-PDS12O.

The truncation process has also been updated. Previously, the LERF cutset file was re-truncated at is 4.0×10^{-09} after the application of the PDS fractions. This is judged to

remove legitimate cutsets that fall below a cutoff limit chosen based on quantification time. The re-truncation was not performed for the LERF calculations in this analysis so that all LERF cutsets are retained after application of the PDS fractions.

F.2.1 POWER UPRATE

The proposed approximately 1.7% power uprate plan for Carolina Power and Light's (CP&L's) Robinson Plant was reviewed to determine the potential impact on the RNP probabilistic safety assessment (PSA).

The methodology consisted of an examination of the current RNP PSA documentation to assess the impact of the following changes on the PSA elements:

- Hardware changes
- Procedural changes
- Set point changes
- Power level change

These changes were interpreted in terms of their effects on the PSA model that can then be used to assess whether there are any potential resulting risk profile changes.

The PSA success criteria still provides a relatively large best estimate safety margin (generally on the order of 20 to 50%). Based on the inherent safety margins in the PSA success criteria, relatively small changes in power (~1.7%) should have minimal impact on the success criteria used in the PSA for mitigation systems.

This review determined that the only potential impact of the proposed power uprate on the PSA model would be the timing of the switchover from the injection mode to the recirculation mode of safety injection. Due to the very small magnitude of the proposed change, any such impact should be negligible. This impact would be seen in the Human Reliability Analysis (HRA) and in the results rather than in the construction of these sequences.

The only quantitative difference identified for the SAMA evaluation due to power uprate is in the calculation of replacement power costs. A scaling factor is required to fit the calculation to a given plant based on net electric output. The post power uprate output of 738 MWe [Reference 70] is used for the analysis.

F.3 LEVEL 3 PSA ANALYSIS

F.3.1 ANALYSIS

The MACCS2 code (Reference 59) was used to perform the level 3 probabilistic safety assessment (PSA) for the RNP. The input parameters given with the MACCS2 "Sample Problem A," which included the NUREG-1150 flood model (Reference 60), formed the basis for the present analysis. These generic values were supplemented with parameters specific to RNP and the surrounding area. Site-specific data included

population distribution, economic parameters, and agricultural production. Plant-specific release data included the time-nuclide distribution of releases, release frequencies, and release locations. The behavior of the population during a release (evacuation parameters) was based on plant and site-specific set points (i.e., declaration of a General Emergency) and emergency planning zone (EPZ) evacuation time estimates (Reference 61). These data were used in combination with site-specific meteorology to simulate the probability distribution of impact risks (exposure and economic) to the surrounding (within 50 miles) population from the large early release accident sequences at RNP.

F.3.2 POPULATION

The population surrounding the plant site was estimated for the year 2030. The distribution was given in terms of population at distances to 1, 2, 3, 4, 5, 10, 20, 30, 40 and 50 miles from the plant and in the direction of each of the 16 compass points (i.e., N, NNE, NE...NNW). The total population for the 160 sectors (10 distances × 16 directions) in the region was estimated as 1,160,726, the distribution of which is given in Tables F-1 and F-2.

Population projections within 50 miles of RNP were determined using a geographic information system (GIS), U.S Nuclear Regulatory Commission (NRC) sector population data for 1990, and population growth rates based on 1990 and 2000 county-level census data. Population sectors were created for 16 sectors at an interval of 1 mile from 0 to 5 miles, the interval from 5 to 10 miles and at 10-mile intervals from 10 miles to 50 miles. The counties were combined with the sectors to determine what counties fell within each sector. The area of each county within a given sector was calculated to determine the area fraction of a county or counties that comprise each sector. The decennial growth rate for each county was converted to an equivalent annual growth rate. The annual growth rate in each sector was then calculated by the sum of the products of the annual growth rate of each county within a sector and the fraction of the area in that sector occupied by that county. This weighted-average annual growth rate for each sector is given in Tables F-3 and F-4.

The NRC 1990 sector population data for RNP provided in NUREG/CR-6525 (Reference 57) was projected to the year 2030 using the county area-weighted-average annual growth rate in each sector. The county populations in 1990 and 2000 are provided in Reference 58. It was assumed that the annual population growth rate would remain constant to that reported between 1990 and year 2000. Using the sector specific population growth rates, projections were made for the year 2030 by multiplying the 1990 sector population data by the annual growth rate raised to the power of 40 (2030-1990 = 40).

F.3.3 SITE PARAMETERS

Economy

MACCS2 requires the spatial distribution of certain economic data (fraction of land devoted to farming, annual farm sales, fraction of farm sales resulting from dairy production, and property value of farm and non-farm land) in the same manner as the population. This was done by specifying the data for each of the 20 counties surrounding the plant, to a distance of 50 miles. The values used for each of the 160 sectors was then the data corresponding to that county which made up a vast majority of the land in that sector. For 24 sectors, no county encompassed more than two thirds of the area, so conglomerate data (weighted by the fraction of each county in that sector) was defined.

In addition, generic economic data that are applied to the region as a whole were revised from the MACCS2 sample problem input when better information was available. These revised parameters include per diem living expenses (applied to owners of interdicted properties and relocated populations), relocation costs (for owners of interdicted properties), value of farm and non-farm wealth, and fraction of farm wealth from improvements (e.g., buildings, equipment).

Agriculture

Agricultural production information was taken from the 1997 Agricultural Census (Reference 64). Production within 50 miles of the site was estimated based on those counties within this radius. Production in those counties, which lie partially outside of this area, was multiplied by the fraction of the county within the area of interest. Cotton and tobacco, non-foods, were harvested from 18 percent of the croplands within 50 miles of the site. Of the food crops, legumes (35 percent of total cropland, consisting mainly of soybeans) and grain (34 percent of the total cropland, made up of corn and wheat) were harvested from the largest areas.

The lengths of the growing seasons for grains, roots, and legumes were obtained from Reference 65. The duration of the growing season for the remaining crop categories (pasture, stored forage, green leafy vegetables, and other food crops) were taken to be the same as those used previously at a site in the neighboring state of Georgia (Reference 66).

Nuclide Release

The core inventory at the time of the accident was based on the input supplied in the MACCS User's Guide (Reference 59). The core inventory corresponds to the end-of-cycle values for a 3412-MWth PWR plant. A scaling factor of 0.686 was used to provide a representative core inventory of 2339-MWth at RNP. Table F-5 gives the estimated RNP core inventory. Release frequencies (3.74×10^{-8} , 1.81×10^{-7} , 0, 3.7×10^{-6} , 1.28×10^{-6} , and 3.94×10^{-7} for sequences RC-2, RC-2B, RC-4, RC-4C, RC-5, and RC-5C,

respectively) and nuclide release fractions (of the core inventory) were analyzed to determine the sum of the exposure (50-mile dose) and economic (50-mile economic costs) risks from these large early release sequences. RNP nuclide release categories were related to the MACCS categories as shown in [Table F-6](#).

Where appropriate, multiple release duration periods were defined which represented the duration of each category's releases. Each RNP category corresponded with a single release duration (either puff or continuous); MACCS category Te required multiple releases.

The reactor building has a diameter of 133.5 feet and a height of 128.5 feet. All releases were modeled as occurring at ground level. The thermal content of each of the releases was conservatively assumed as to be the same as ambient; i.e., buoyant plume rise was not modeled.

Evacuation

Reactor trip for each sequence was taken as time zero relative to the core containment response times. A General Emergency is declared when plant conditions degrade to the point where it is judged that there is a credible risk to the public. For example, sequence RC-2 involves a Large Break LOCA with failure of containment isolation. The core is estimated to uncover at about 9 minutes into the event with core damage and fission product release from the fuel estimated to occur at 15 minutes; a General Emergency is declared at 15 minutes (after reactor trip) for Sequence RC-2. The general emergency declaration for sequences RC-2B, RC-4, RC-4C, RC-5, and RC-5C would be at 3, 8.5, 8.5, 5, and 5 hours, respectively.

The MACCS2 User's Guide input parameters of 95 percent of the population within 10 miles of the plant (Emergency Planning Zone) evacuating and 5 percent not evacuating were employed. These values have been used in similar studies (e.g., Hatch, Calvert Cliffs, References [66](#) and [67](#)) and are conservative relative to the NUREG-1150 study, which assumed evacuation of 99.5 percent of the population within the emergency planning zone (Reference [60](#)). The evacuees are assumed to begin evacuation 30 minutes (Reference [61](#)) after a General Emergency has been declared and are evacuated at a radial speed of 0.28 m/sec. This speed is taken from the minimum speed from any evacuation zone under adverse weather conditions.

Meteorology

Annual meteorology data sets from 1995 through 1999 were investigated for use in MACCS2. The 1998 data set was found to result in the largest doses and was subsequently used to create the one-year sequential hourly data set used in MACCS2. Wind speed and direction from the 9.3-meter sensor were combined with precipitation (hourly cumulative) and atmospheric stability (specified according to the vertical temperature gradient as measured between the 60.8-meter and 9.3-meter levels). Hourly stability was classified according to the scheme used by the NRC (Reference [68](#)).

Atmospheric mixing heights were specified for AM and PM hours. These values were taken as 400 and 1380 meters, respectively (Reference 74).

F.3.4 RESULTS

The resulting annual risk from RNP early release sequences RC-2, RC-2B, RC-4, RC-4C, RC-5, and RC-5C (and their sum) are provided in Table F-7. The largest risk is from RC-5 as it has a relatively high release frequency and large radionuclide release. The two next largest contributors to risk are release categories RC-4C and RC-5C. Together, they yield approximately the same economic cost-risk as RC-5, but only about 82% of the RC-5 population dose-risk.

In total, these 3 sequences account for greater than 90% of the risks from these large early releases.

Quantification of the base case shows a baseline Core Damage Frequency (CDF) of 4.32×10^{-5} /yr based on 1,274 cutsets (accident scenarios). The baseline Large Early Release Frequency (LERF) is 5.59×10^{-6} /yr based on 1374 cutsets. MACCS2 calculated the annual baseline population dose risk within 50 miles at 5.840 person-rem. The total annual economic risk was calculated at \$9,530.

F.4 BASELINE RISK MONETIZATION

F.4.1 OFF-SITE EXPOSURE COST

This section explains how CP&L calculated the monetized value of the status quo (i.e., accident consequences without SAMA implementation). CP&L also used this analysis to establish the maximum benefit that a SAMA could achieve if it eliminated all RNP risk.

F.4.2 OFF-SITE EXPOSURE COST

The baseline annual off-site exposure risk was converted to dollars using the NRC's conversion factor of \$2,000 per person-rem (Reference 52), and discounting to present value using NRC standard formula (Reference 52):

$$W_{\text{pha}} = C \times Z_{\text{pha}}$$

Where:

| | | |
|------------------|---|---|
| W_{pha} | = | monetary value of public health risk after discounting |
| C | = | $[1 - \exp(-rt_f)]/r$ |
| t_f | = | years remaining until end of facility life = 20 years |
| r | = | real discount rate (as fraction) = 0.07/year |
| Z_{pha} | = | monetary value of public health (accident) risk per year before discounting (\$/year) |

The Level 3 analysis showed an annual off-site population dose risk of 5.84 person-rem. The calculated value for C using 20 years and a 7 percent discount rate is approximately 10.76. Therefore, calculating the discounted monetary equivalent of accident risk involves multiplying the dose (person-rem per year) by \$2,000 and by the C value (10.76). The calculated off-site exposure cost is \$125,711.

F.4.3 OFF-SITE ECONOMIC COST RISK (OECR)

The Level 3 analysis showed an annual off-site economic risk of \$9,530. Calculated values for off-site economic costs caused by severe accidents must be discounted to present value as well. This is performed in the same manner as for public health risks and uses the same C value. The resulting value is \$102,570.

F.4.4 ON-SITE EXPOSURE COST RISK

Occupational health was evaluated using the NRC methodology in Reference 52, which involves separately evaluating “immediate” and long-term doses.

Immediate Dose - For the case where the plant is in operation, the equation that NRC recommends using (Reference 52) is:

Equation 1:

$$W_{IO} = R\{(FD_{IO})_S - (FD_{IO})_A\} \{[1 - \exp(-rt_f)]/r\}$$

Where:

- W_{IO} = monetary value of accident risk avoided due to immediate doses, after discounting
- R = monetary equivalent of unit dose (\$/person-rem)
- F = accident frequency (events/yr)
- D_{IO} = immediate occupational dose (person-rem/event)
- S = subscript denoting status quo (current conditions)
- A = subscript denoting after implementation of proposed action
- r = real discount rate
- t_f = years remaining until end of facility life.

The values used in the RNP analysis are:

- R = \$2,000/person-rem
- r = 0.07
- D_{IO} = 3,300 person-rem/accident (best estimate)
- t_f = 20 years (license extension period)
- F = 4.32×10^{-5} (total core damage frequency)

For the basis discount rate, assuming F_A is zero, the best estimate of the immediate dose cost is:

$$\begin{aligned} W_{IO} &= R (FD_{IO})_S \{ [1 - \exp(-rt_f)]/r \} \\ &= 2,000 * 4.32 \times 10^{-5} * 3,300 * \{ [1 - \exp(-0.07 * 20)]/0.07 \} \\ &= \$3,069 \end{aligned}$$

Long-Term Dose - For the case where the plant is in operation, the NRC equation (Reference 52) is:

Equation 2:

$$W_{LTO} = R \{ (FD_{LTO})_S - (FD_{LTO})_A \} \{ [1 - \exp(-rt_f)]/r \} \{ [1 - \exp(-rm)]/rm \}$$

Where:

$$\begin{aligned} W_{IO} &= \text{monetary value of accident risk avoided long-term doses,} \\ &\quad \text{after discounting, \$} \\ m &= \text{years over which long-term doses accrue} \end{aligned}$$

The values used in the RNP analysis are:

$$\begin{aligned} R &= \$2,000/\text{person-rem} \\ r &= 0.07 \\ D_{LTO} &= 20,000 \text{ person-rem/accident (best estimate)} \\ m &= \text{"as long as 10 years"} \\ t_f &= 20 \text{ years (license extension period)} \\ F &= 4.32 \times 10^{-5} \text{ (total core damage frequency)} \end{aligned}$$

For the basis discount rate, assuming F_A is zero, the best estimate of the long-term dose is:

$$\begin{aligned} W_{LTO} &= R (FD_{LTO})_S \{ [1 - \exp(-rt_f)]/r \} \{ [1 - \exp(-rm)]/rm \} \\ &= 2,000 * 4.32 \times 10^{-5} * 20,000 * \{ [1 - \exp(-0.07 * 20)]/0.07 \} \{ [1 - \exp(-0.07 * 10)]/0.07 * 10 \} \\ &= \$13,375 \end{aligned}$$

Total Occupational Exposure - Combining Equations 1 and 2 above and using the above numerical values, the total accident related on-site (occupational) exposure avoided (W_O) is:

$$W_O = W_{IO} + W_{LTO} = (\$3,069 + \$13,375) = \$16,444$$

F.4.5 ON-SITE CLEANUP AND DECONTAMINATION COST

The net present value that NRC provides for cleanup and decontamination for a single event is \$1.1 billion, discounted over a 10-year cleanup period (Reference 52). NRC uses the following equation to integrate the net present value over the average number of remaining service years:

$$U_{CD} = [PV_{CD}/r][1-\exp(-rt_f)]$$

Where:

$$\begin{aligned} PV_{CD} &= \text{net present value of a single event} \\ r &= \text{real discount rate} \\ t_f &= \text{years remaining until end of facility life.} \end{aligned}$$

The values used in the RNP analysis are:

$$\begin{aligned} PV_{CD} &= \$1.1 \times 10^9 \\ r &= 0.07 \\ t_f &= 20 \end{aligned}$$

The resulting net present value of cleanup integrated over the license renewal term, $\$1.18 \times 10^{10}$, must be multiplied by the total core damage frequency of 4.32×10^{-5} to determine the expected value of cleanup and decontamination costs. The resulting monetary equivalent is \$511,453.

F.4.6 REPLACEMENT POWER COST

Long-term replacement power costs was determined following the NRC methodology in Reference 52. The net present value of replacement power for a single event, PV_{RP} , was determined using the following equation:

$$PV_{RP} = [\$1.2 \times 10^8 / r] * [1 - \exp(-rt_f)]^2$$

Where:

$$\begin{aligned} PV_{RP} &= \text{net present value of replacement power for a single event, (\$)} \\ r &= 0.07 \\ t_f &= 20 \text{ years (license renewal period)} \end{aligned}$$

To attain a summation of the single-event costs over the entire license renewal period, the following equation is used:

$$U_{RP} = [PV_{RP} / r] * [1 - \exp(-rt_f)]^2$$

Where:

$$U_{RP} = \text{net present value of replacement power over life of facility (\$-year)}$$

After applying a correction factor to account for RNP's size relative to the "generic" reactor described in NUREG/BR-0184 (Reference 52) (i.e., 738 MWe/910 MWe), the replacement power costs are determined to be 6.40×10^9 (\$-year). Multiplying this value by the CDF (4.32×10^{-5}) results in a replacement power cost of \$276,435.

F.4.7 TOTAL

The sum of the baseline costs is as follows:

| | | |
|------------------------|---|------------------|
| Off-site exposure cost | = | \$125,711 |
| Off-site economic cost | = | \$102,570 |
| On-site exposure cost | = | \$16,444 |
| On-site cleanup cost | = | \$511,453 |
| Replacement Power cost | = | <u>\$276,435</u> |
| Total cost | = | \$1,032,613 |

CP&L rounded this value up to \$1,033,000 to use in screening out SAMAs as economically infeasible. The averted cost-risk calculations account for this rounding such that it does not impact the result. This cost estimate was used in screening out SAMAs that are not economically feasible; if the estimated cost of implementing a SAMA exceeded \$1,033,000 it was discarded from further analysis. Exceeding this threshold would mean that a SAMA would not have a positive net value even if it could eliminate all severe accident costs. On the other hand, if the cost of implementation is less than this value, then a more detailed examination of the potential fractional risk benefit that can be attributed to the SAMA is performed.

F.5 PHASE I SAMA ANALYSIS

F.5.1 SAMA IDENTIFICATION

The initial list of Severe Accident Mitigation Alternative candidates for RNP was developed from lists of SAMAs at other nuclear power plants (References [56](#), [9](#), [5](#), [7](#), [4](#), [12](#), [13](#), and [14](#)), NRC documents (References [1](#), [2](#), [3](#), [6](#), [8](#), [15](#), [16](#), and [19](#)), and documents related to advanced power reactor designs (ABWR SAMAs) (References [17](#), [10](#), and [11](#)). In addition, plant specific analyses (References [20](#), [26](#)) have been used to identify potential SAMAs which address RNP vulnerabilities. This process is considered to adequately address the requirement of identifying significant safety improvements that could be performed at RNP. The initial SAMA list, [Table F-8](#), includes a column which documents the reference sources for each individual SAMA.

The RNP IPEEE (Reference [21](#)) also identified potential opportunities for plant improvements. As a result of the Seismic and Fire Analysis, potential plant changes were considered and dispositioned according to their importance.

Given the existing assessments of external events and internal fires at RNP, the cost benefit analysis uses the internal events PSA as the basis for measuring the impact of SAMA implementation. No fire or external events models are used in this analysis as the fire and IPEEE programs are considered to have already addressed potential plant improvements related to those categories.

F.5.2 SCREENING

An initial list of SAMA candidates is presented in [Table F-8](#). This initial list was then screened to remove those candidates that were not applicable to RNP due to design differences or high implementation cost. In addition, SAMAs were eliminated if they were related to changes that would be made during the design phase of a plant rather than to an existing plant. These would typically screen on high cost, but they are categorized separately for reference purposes. The SAMA screening process is summarized in [Figure F-1](#).

A majority of the SAMAs were removed from further consideration as they did not apply to the Westinghouse 3 Loop PWR design used at RNP. The SAMA candidates that were found to be implemented at RNP were screened from further consideration.

The SAMAs related to design changes prior to construction (primarily consisting of those candidates taken from the ABWR SAMAs) were removed as they were not applicable to an existing site. Any candidate known to have an implementation cost that far exceeds any possible risk benefit is screened from further analysis. Any SAMA candidates that were sufficiently similar to other SAMA candidates were treated in the same manner to those that they were related to either combined or screened from further consideration.

A preliminary cost estimate was prepared for each of the remaining candidates to focus on those that had the possibility of having a positive benefit and to eliminate those whose costs were beyond the possibility of any corresponding benefit (as determined by the RNP baseline screening cost). When the screening cutoff of \$1,033,000 was applied, a majority of the remaining SAMA candidates were eliminated, as their implementation costs were more expensive than the maximum postulated benefit associated with the elimination of all risk associated with full power internal events. This left 9 candidates for further analysis. Those SAMAs that required a more detailed cost benefit analysis are evaluated in [Section F.6](#). A list of these SAMAs is provided in [Table F-9](#).

F.6 PHASE II SAMA ANALYSIS

It was possible to screen some of the remaining SAMA candidates from further analysis based on plant specific insights regarding the risk significance of the systems that would be affected by the proposed SAMAs. The SAMAs related to non-risk significant systems were screened from a detailed cost benefit analysis as any change in the reliability of these systems is known to have a negligible impact on the PSA evaluation. [Table F-9](#) comments explain the bases for these screenings.

For each of the remaining SAMA candidates that could not be eliminated based on screening cost or PSA/application insights, a more detailed conceptual design was prepared along with a more detailed estimated cost. This information was then used to evaluate the effect of the candidates' changes upon the plant safety model.

The final cost-risk based screening method used to determine the desirability of implementing the SAMA is defined by the following equation:

$$\text{Net Value} = (\text{baseline cost-risk of plant operation} - \text{cost-risk of plant operation with SAMA implemented}) - \text{cost of implementation}$$

If the net value of the SAMA is negative, the cost of implementation is larger than the benefit associated with the SAMA and the SAMA is not considered beneficial. The baseline cost-risk of plant operation was derived using the methodology presented in Section F.4. The cost-risk of plant operation with the SAMA implemented is determined in the same manner with the exception that the PSA results reflect the application of the SAMA to the plant (the baseline input is replaced by the results of a PSA sensitivity with the SAMA change in effect).

Subsections F.6.1 – F.6.9 describe the detailed cost benefit analysis that was used to determine how the remaining candidates were ultimately treated.

F.6.1 PHASE II SAMA NUMBER 1: PREVENT CHARGING PUMP FLOW DIVERSION FROM THE RELIEF VALVES

Description: This SAMA modification would reduce the frequency of the loss of RCP seal cooling if relief valve opening causes a flow diversion large enough to prevent RCP seal injection.

While the flow diversion through a relief valve failure mode is not directly modeled in the RNP PSA, it is considered to be subsumed by the event for common cause failure of charging pump seal injection (JCCFICVABC). The maximum possible risk reduction for this SAMA was obtained by setting JCCFICVABC to zero.

Model changes that were made to the PSA to represent the implementation of this SAMA at RNP are shown below:

Phase II SAMA Number 1 Model Changes

| Gate and / or Basic Event ID and Description | Description of Change |
|--|-----------------------|
| Basic event JCCFICVABC (RCP A,B,&C INJ. CV COMMON CAUSE FAILURE TO OPEN) | Set to zero |

PSA Model Results for Phase II SAMA Number 1

The results from this case indicate no reduction in CDF ($CDF_{new} = 4.32 \times 10^{-05}$ per year) and no reduction in LERF ($LERF_{new} = 5.59 \times 10^{-06}$ per year). The results of the cost benefit analysis are shown below:

Phase II SAMA Number 1 Net Value

| Base Case: Cost-Risk for RNP | SAMA 1 Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|---|---|-------------------------------|-----------------------------------|--------------------------------|
| \$1,033,000 | \$1,033,000 | \$0 | Not Required | Not Cost Beneficial |

This SAMA has no impact on the calculated CDF or on the LERF cutsets. Implementation of this SAMA, therefore, would not be cost beneficial for RNP.

F.6.2 PHASE II SAMA NUMBER 2: IMPROVED ABILITY TO COOL THE RESIDUAL HEAT REMOVAL HEAT EXCHANGERS

Description: This SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the Fire Water System to the RHR heat exchangers.

A new basic event, FP-RHR (Operators Fail To Align The Fire Water System To The RHR Heat Exchangers), was created. Four new gates, SAMA02A (Failure of Cooling To RHR Heat Exchanger A), SAMA02B#RB (Failure of Cooling To RHR Heat Exchanger A), SAMA02B (Failure of Cooling To RHR Heat Exchanger B) and SAMA02B#RB (Failure of Cooling To RHR Heat Exchanger B) were created. Gate SAMA02A is an AND gate with inputs of FP-RHR and existing gate K2401 (CCW TO HX A FAILS). Gate SAMA02A#RB is an AND gate with inputs of FP-RHR and existing gate K2401#RB (CCW TO HX A FAILS). Gate SAMA02B is an AND gate with inputs of FP-RHR and existing gate K2501 (CCW TO HX B FAILS). Gate SAMA02B#RB is an AND gate with inputs of FP-RHR and existing gate K2501#RB (CCW TO HX B FAILS). Gate SAMA02A was substituted in the logic for gate K2401, gate SAMA02A#RB was substituted in the logic for gate K2401#RB, gate SAMA02B was substituted in the logic for gate K2501 and gate SAMA02B#RB was substituted in the logic for gate K2501#RB.

The maximum possible risk reduction for this SAMA was obtained by setting FP-RHR to zero.

The model changes that were made to the PSA to represent the implementation of this SAMA at RNP are shown below:

Phase II SAMA Number 2 Model Changes

| Gate and / or Basic Event ID and Description | Description Of Change |
|---|---------------------------------------|
| New basic event FP-RHR (Operators Fail To Align The Fire Water System To The RHR Heat Exchangers) | Set to zero |
| New gate SAMA02A (Failure of Cooling To RHR Heat Exchanger A) | AND FP-RHR K2401 |
| New gate SAMA02A#RB (Failure of Cooling To RHR Heat Exchanger A) | AND FP-RHR K2401#RB |
| New gate SAMA02B (Failure of Cooling To RHR Heat Exchanger B) | AND FP-RHR K2501 |
| New gate SAMA02B#RB (Failure of Cooling To RHR Heat Exchanger B) | AND FP-RHR K2501#RB |
| Gate L14D#HR (NO FLOW FROM RHR TRAIN A LOW HEAD RECIRC) | Deleted K2401 and added SAMA02A |
| L14DSD (NO FLOW FROM RHR TRAIN A) | Deleted K2401 and added SAMA02A |
| LRHXA#R (NO FLOW FROM RHR HX OR PUMP A) | Deleted K2401 and added SAMA02A |
| L14E#R (NO FLOW FROM RHR TRAIN B) | Deleted K2501 and added SAMA02B |
| L14ESD (NO FLOW FROM RHR TRAIN B) | Deleted K2501 and added SAMA02B |
| LRHXB#R (NO FLOW FROM RHR HX OR PUMP B) | Deleted K2501 and added SAMA02B |
| LRHXA#RB (NO FLOW FROM RHR HX OR PUMP A) | Deleted K2401#RB and added SAMA02A#RB |
| LRHXB#RB (NO FLOW FROM RHR HX OR PUMP B) | Deleted K2501#RB and added SAMA02B#RB |

PSA Model Results for Phase II SAMA Number 2

The results from this case indicate about a 3.0 percent reduction in CDF ($CDF_{new} = 4.19 \times 10^{-05}$ / year) and a 15.2 percent reduction in LERF ($LERF_{new} = 4.74 \times 10^{-06}$ / year). The results of the cost benefit analysis are shown below:

Phase II SAMA Number 2 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost-Risk | Cost of Implementation | Net Value |
|-------------------------------------|--------------------------|--------------------------|-------------------------------|----------------------------|
| \$1,033,000 | \$993,437 | \$39,563 | Not Required | Not Cost Beneficial |

Implementation of this SAMA would consist of modifying the fire water system to provide for a supply point where temporary hoses could be attached quickly somewhere

near the RHR heat exchangers, modifying existing piping to the RHR heat exchanger with similar fittings for hoses, testing of the new connections, writing procedures, and, operator training. It is estimated that these actions would be substantially in excess of the \$39,563 averted cost-risk. This SAMA would not be cost beneficial for RNP.

F.6.3 PHASE II SAMA NUMBER 3: INCREASE FREQUENCY FOR VALVE LEAK TESTING

Description: This SAMA could reduce the interfacing systems loss of coolant accident (ISLOCA) initiating event frequency.

To calculate the maximum possible impact of this SAMA, initiating event percent ISLOCA (INTERFACING SYSTEMS LOCA OCCURS OUTSIDE CONTAINMENT) was set to zero. This is the equivalent of assuming that every potential ISLOCA could be prevented by increasing the frequency of valve leak testing.

The model changes that were made to the PSA to represent the implementation of this SAMA at RNP are shown below:

| <u>Phase II SAMA Number 3 Model Changes</u> | |
|--|------------------------------|
| Gate and / or Basic Event ID and Description | Description of Change |
| Initiating Event %ISLOCA (INTERFACING SYSTEMS LOCA OCCURS OUTSIDE CONTAINMENT) | Set to zero |

PSA Model Results for Phase II SAMA Number 3

The results from this case indicate about a 2.8 percent reduction in CDF ($CDF_{new} = 4.20 \times 10^{-05}$ / year) and a 24.2 percent reduction in LERF ($LERF_{new} = 4.24 \times 10^{-06}$ / year). The results of the cost benefit analysis are shown in below:

Phase II SAMA Number 3 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|---|------------------------------|-------------------------------|-----------------------------------|-------------------|
| \$1,033,000 | \$892,545 | \$140,455 | >\$280,000 | -\$139,545 |

Implementation of this SAMA would involve numerous procedure changes and potential increases to shop manpower to meet increased surveillance testing requirements. In addition, further testing would require another scheduled plant shutdown as the valve testing requires access to areas within the biological shield. A shutdown for this purpose would require multiple days off-line. For this analysis, a single day of lost power is conservatively used as the cost of implementation. Based on the insured value of a day of replacement power (\$280,000) from Reference 72, the net value for

this SAMA is about-\$140,000. This SAMA is clearly not cost beneficial based on these parameters.

The impact of this SAMA is also judged to be greatly over estimated in this evaluation. The increased test frequency was assumed to eliminate ALL risk from ISLOCAs, which is not realistic. The typical process for developing the ISLOCA initiating event frequency also suggests that valve testing increases the likelihood of an ISLOCA event. Once the contribution of valve misalignment outweighs the benefit gained by identifying potential valve failures, the valve test become detrimental. Increasing the valve test frequency at RNP may actually increase the risk of an ISLOCA event.

F.6.4 PHASE II SAMA NUMBER 4: IMPROVED MSIV DESIGN

Description: This SAMA would install new, improved MSIVs of higher reliability.

There are six basic events associated with the RNP MSIVs. Each of the three MSIVs has one basic event for its failure to close on demand and one basic event for transferring closed during operation. To calculate the maximum possible impact of this SAMA, all six of these basic events were set to zero. This is the equivalent of assuming that the new MSIVs would be perfectly reliable.

The model changes that were made to the PSA to represent the implementation of this SAMA at RNP are shown below:

| <u>Phase II SAMA Number 4 Model Changes</u> | |
|--|------------------------------|
| Gate and / or Basic Event ID and Description | Description of Change |
| Basic Event QAVV1-3AFF (MSIV MS-V1-3A FAILS TO CLOSE ON DEMAND) | Set to zero |
| Basic Event QAVV1-3BFF (MSIV MS-V1-3B FAILS TO CLOSE ON DEMAND) | Set to zero |
| Basic Event QAVV1-3CFF (MSIV MS-V1-3C FAILS TO CLOSE ON DEMAND) | Set to zero |
| Basic Event QAVV1-3AFN (PNEUMATIC VALVE MS-V1-3A TRANSFERS CLOSED) | Set to zero |
| Basic Event QAVV1-3BFN (PNEUMATIC VALVE MS-V1-3B TRANSFERS CLOSED) | Set to zero |
| Basic Event QAVV1-3BFN (PNEUMATIC VALVE MS-V1-3B TRANSFERS CLOSED) | Set to zero |

PSA Model Results for Phase II SAMA Number 4

The results from this case indicate no reduction in CDF ($CDF_{new}=4.32 \times 10^{-05}$ / year) and no reduction in LERF ($LERF_{new} = 5.59 \times 10^{-06}$ / year). The results of the cost benefit analysis are shown below:

Phase II SAMA Number 4 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|---|------------------------------|-------------------------------|-----------------------------------|--------------------------------|
| \$1,033,000 | \$1,033,000 | \$0 | Not Required | Not Cost Beneficial |

This SAMA has no impact on the calculated CDF or on the LERF cutsets. Implementation of this SAMA, therefore, would not be cost beneficial for RNP.

F.6.5 PHASE II SAMA NUMBER 5: INSTALL A DIGITAL FEEDWATER UPGRADE

Description: This SAMA would reduce the chance of a loss of main feedwater following a plant trip by installing a digital feedwater control system.

To calculate the maximum possible impact of this SAMA, initiating events %T4 (LOSS OF MAIN FEEDWATER) and %T4A (PARTIAL LOSS OF MAIN FEEDWATER) were set to zero. This is the equivalent of assuming that the new digital control system perfectly controlled main feedwater at all times.

The changes made to the RNP PSA model to simulate the implementation of this SAMA are shown below:

Phase II SAMA Number 5 Model Changes

| Gate and / or Basic Event ID and Description | Description of Change |
|---|------------------------------|
| Initiating Event %T4 (LOSS OF MAIN FEEDWATER) | Set to zero |
| Initiating Event %T4A (PARTIAL LOSS OF MAIN FEEDWATER) | Set to zero |

PSA Model Results for Phase II SAMA Number 5

The results from this case indicate about a 3.9 percent reduction in CDF ($CDF_{new} = 4.15 \times 10^{-05}$ / year) and no reduction in LERF ($LERF_{new} = 5.59 \times 10^{-06}$ / year). The results of the cost benefit analysis are shown below:

Phase II SAMA Number 5 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|---|------------------------------|-------------------------------|-----------------------------------|--------------------------------|
| \$1,033,000 | \$1,001,294 | \$31,706 | Not Required | Not Cost Beneficial |

The cost of installing a digital feedwater control system would be far in excess of the averted cost-risk of \$31,706. This SAMA would not be cost beneficial for RNP.

F.6.6 PHASE II SAMA NUMBER 6: REPLACE CURRENT PRESSURIZER PORVS WITH LARGER ONES SUCH THAT ONLY ONE IS REQUIRED FOR SUCCESSFUL FEED AND BLEED

Description: This SAMA would reduce the dependencies required for successful feed and bleed. There are two PORVs and three SRVs for RCS pressure control. RNP PSA model currently requires two PORVs for successful feed and bleed.

This SAMA would require replacing the two existing PORVs with higher capacity valves. To simulate the implementation of this SAMA, gate R3000 (1 OF 2 PORV S FAIL TO OPEN MANUALLY) was replaced with existing gate R2000 (2 OF 2 PORVs FAIL TO OPEN MANUALLY) at gate #TH (EVENT H - FAILURE OF PRIMARY BLEED).

The changes made to the RNP PSA model to simulate the implementation of this SAMA are shown below:

Phase II SAMA Number 6 Model Changes

| Gate and / or Basic Event ID and Description | Description of Change |
|---|--|
| #TH (EVENT H - FAILURE OF PRIMARY BLEED) | Replaced input R3000 (1 OF 2 PORV S FAIL TO OPEN MANUALLY) with input R2000 (2 OF 2 PORVs FAIL TO OPEN MANUALLY) |

PSA Model Results for Phase II SAMA Number 6

The results from this case indicate about a 1.8 percent reduction in CDF ($CDF_{new} = 4.24 \times 10^{-05}$ / year) and no reduction in LERF. The results of the cost benefit analysis are shown below:

Phase II SAMA Number 6 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|------------------------------------|----------------------|-----------------------|---------------------------|--------------------------------|
| \$1,033,000 | \$1,018,073 | \$14,927 | Not Required | Not Cost Beneficial |

The averted cost-risk is relatively small for this SAMA with respect to the resources required for a significant plant hardware modification (i.e., replacement of the PORVs with higher capacity valves). No detailed cost of implementation was derived, as the cost of the hardware changes would clearly be larger than the averted cost-risk.

F.6.7 PHASE II SAMA NUMBER 7: IMPLEMENT AN RWST MAKE-UP PROCEDURE

Description: This SAMA would potentially decrease CDF from ISLOCA scenarios, some smaller break LOCA scenarios, and SGTRs by implementing a procedure to refill the RWST.

The RWST is capable of being refilled at a rate of about 100 gpm. The RNP PSA contains logic for refilling the RWST during late (i.e., long-term) core damage sequences. This logic is in the form of gate #RYL (FAILURE TO PROVIDE LONG TERM RCS MAKEUP FOR LATE SEQUENCES). #RYL is an AND gate with HEP event OPER-80 (OPERATORS FAIL TO PROVIDE LONG-TERM MAKEUP) and recovery event R-RWST (RECOVERY OF FAILURE TO REFIL THE RWST FOR LATE SEQUENCES). To calculate the maximum possible impact of this SAMA, basic event R-RWST was set to zero. This is the equivalent of assuming that the operators are able to refill the RWST during all late core damage sequences.

The changes made to the RNP PSA model to simulate the implementation of this SAMA are shown below:

Phase II SAMA Number 7 Model Changes

| Gate and / or Basic Event ID and Description | Description of Change |
|---|--------------------------|
| R-RWST (RECOVERY OF FAILURE TO REFIL THE RWST FOR LATE SEQUENCES) | Set to zero |

PSA Model Results for Phase II SAMA Number 7

The results from this case indicate about a 0.46 percent reduction in CDF ($CDF_{new} = 4.30 \times 10^{-05}$ / year) and a 5.9 percent reduction in LERF ($LERF_{new} = 5.26 \times 10^{-06}$ / year). The results of the cost benefit analysis are shown below:

Phase II SAMA Number 7 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|------------------------------------|----------------------|-----------------------|---------------------------|-----------|
| \$1,033,000 | \$1,000,529 | \$32,471 | \$50,000 | -17,529 |

At a minimum, the implementation of this SAMA would involve creating a new procedure for refilling the RWST during accident scenarios using the existing low capacity fill system. This implementation was estimated conservatively low at \$50,000.

The averted cost-risk is relatively small for this SAMA with respect to the resources required for any significant plant hardware modifications (e.g., a higher capacity RSWT fill system). No detailed cost of implementation of a new fill system was derived, as the cost of the hardware changes would clearly be larger than the averted cost-risk.

The negative net value of this SAMA candidate indicates that its implementation would not be cost beneficial to RNP.

F.6.8 PHASE II SAMA NUMBER 8: CREATE AUTOMATIC SWAP OVER TO RECIRCULATION ON RWST DEPLETION

Description: The purpose of this SAMA is to improve the reliability of the transition to re-circulation mode after depletion of the RWST. RNP requires a manual swap to re-circulation mode that could be improved by automating RWST isolation (to prevent air entrainment in the RHR and charging pumps) and the opening of the sump suction valves (to provide a water source for the pumps).

The changes made to the RNP PSA model to simulate full automatic swap over to re-circulation mode are summarized below.

Phase II SAMA Number 8 Model Changes

| System: Basic Events | Original Value | Revised Value |
|---------------------------|-----------------------|-----------------------|
| X-OR-0003: OPER-DE OPER-1 | 7.5×10^{-05} | 2.6×10^{-08} |
| X-OA-0001: OPER-1 | 1.2×10^{-02} | 5.0×10^{-05} |
| X-OM-0001: OPER-1 | 6.6×10^{-03} | 5.0×10^{-05} |
| X-OS-0003: OPER-SD OPER-1 | 3.1×10^{-05} | 1.0×10^{-08} |
| X-OS-0001: OPER-1 | 3.8×10^{-03} | 5.0×10^{-05} |

Phase II SAMA Number 8 Model Changes

| System: Basic Events | Original Value | Revised Value |
|---|-----------------------|-----------------------|
| X-OR-0001: OPER-1 | 3.8×10^{-03} | 5.0×10^{-05} |
| X-OQ-0102: OPER-SD OPER-1 | 3.1×10^{-05} | 1.0×10^{-08} |
| X-OQ-0004: OPER-1 | 3.8×10^{-03} | 5.0×10^{-05} |
| X-OT-0012: OPER-18A OPER-18B OPER-1 | 1.9×10^{-07} | 2.6×10^{-09} |
| X-OT-0004: OPER-1 | 3.8×10^{-03} | 5.0×10^{-05} |
| X-OS-0017: OPER-SD OPER-18A OPER-18B OPER-1 | 5.3×10^{-05} | 5.2×10^{-09} |
| X-OA-0002: OPER-7 | 7.2×10^{-03} | 5.0×10^{-05} |

The plant changes are characterized by reducing the operator actions for aligning recirculation to very low values. OPER-1 and OPER-7 represent the manual action to align recirculation mode. As the RNP PSA model addresses operator actions with a post processor recovery file, the operator actions have been altered by manipulating the Joint Human Error Probabilities (JHEPs) that are assigned to the operator action groups containing the OPER-1 and OPER-7 actions. Note that the only JHEPs requiring modification are those that appear in the final cutset files.

The revised JHEPs are provided above and have been calculated assuming that the OPER-1 and OPER-7 events are hardware failures with a failure probability of 5.0×10^{-05} .

The cost of implementation for this SAMA has been estimated to be \$264,750 (Engineering Judgement). This estimate does not include costs for operator re-training, procedure changes, document and database updating, simulator modification and certain installation costs, such as for temporary shielding and scaffolding.

PSA Model Results for Phase II SAMA Number 8

The results from this case indicate about a 4.9 percent reduction in CDF ($CDF_{new}=4.11E-5/yr$) and a 16.8 percent reduction in LERF ($LERF_{new}=4.65E-6/yr$). The results of the cost-benefit analysis are shown below.

Phase II SAMA Number 8 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|---|------------------------------|-------------------------------|-----------------------------------|------------------|
| \$1,033,000 | \$975,115 | \$58,885 | \$264,750 | -\$205,865 |

The negative net value for this SAMA indicates that the proposed change would not be cost beneficial.

F.6.9 PHASE II SAMA NUMBER 9: TRAIN OPERATIONS CREW FOR RESPONSE TO INADVERTENT ACTUATION SIGNALS

Description: This SAMA would improve chances of a successful response to the loss of two 120 VAC buses, which may cause inadvertent signal generation.

The only scenarios in the RNP PSA that would cause a simultaneous failure of two instrument buses are the common cause failure events for Instrument Buses 1 and 4 (CCCF1&4BUS) and Instrument Buses 2 and 3 (CCCF2&3BUS). To simulate the implementation of this SAMA, these two common cause events were set to zero.

The changes made to the RNP PSA model to simulate the implementation of this SAMA are shown below:

Phase II SAMA Number 9 Model Changes

| Gate Or Event Id and Description: | Description of Change: |
|--|------------------------|
| Common Cause Event CCCF1&4BUS (COMMON CAUSE FAILURE OF 2 OF 2 INSTRUMENT BUSES 1 & 4) | Set to zero |
| Common Cause Event CCCF2&3BUS (COMMON CAUSE FAILURE OF 2 OF 2 INSTRUMENT BUSES 2 & 3) | Set to zero |

PSA Model Results for Phase II SAMA Number 9

The results from this case indicate no reduction in CDF ($CDF_{new}=4.32 \times 10^{-05}$ / year) and no reduction in LERF ($LERF_{new} = 5.59 \times 10^{-06}$ / year). The results of the cost benefit analysis are shown below.

Phase II SAMA Number 9 Net Value

| Base Case: Cost-Risk for RNP | Cost-Risk for RNP | Averted Cost- Risk | Cost of Implementation | Net Value |
|------------------------------------|----------------------|-----------------------|---------------------------|--------------------------------|
| \$1,033,000 | \$1,033,000 | \$0 | Not Required | Not Cost Beneficial |

This SAMA has no impact on the calculated CDF or on the LERF cutsets. Implementation of this SAMA, therefore, would not be cost beneficial.

F.6.10 PHASE II SAMA ANALYSIS SUMMARY

The SAMA candidates which could not be eliminated from consideration by the baseline screening process or other PSA insights required the performance of a detailed analysis of the averted cost-risk and SAMA implementation costs. SAMA candidates are potentially justified only if the averted cost-risk resulting from the modification is greater

than the cost of implementing the SAMA. None of the SAMAs analyzed were found to be cost-beneficial as defined by the methodology used in this study. However, this evaluation should not necessarily be considered a definitive guide in determining the disposition of a plant modification that has been analyzed using other engineering methods. These results are intended to provide information about the relative estimated risk benefit associated with a plant change or modification compared with its cost of implementation and should be used as an aid in the decision making process. The results of the detailed analysis are shown below:

Summary of the Detailed SAMA Analyses

| Phase II SAMA ID | Averted Cost- Risk | Cost of Implementation | Net Value | Cost Beneficial? |
|------------------|--------------------|------------------------|------------|------------------|
| 1 | \$0 | Not Required | \$0 | No |
| 2 | \$39,563 | Not Required | N/A | No |
| 3 | \$140,455 | \$280,000 | -\$139,545 | No |
| 4 | \$0 | Not Required | \$0 | No |
| 5 | \$31,706 | Not Required | N/A | No |
| 6 | \$14,927 | Not Required | N/A | No |
| 7 | \$32,472 | \$50,000 | -\$17,528 | No |
| 8 | \$58,885 | \$264,750 | -\$205,865 | No |
| 9 | \$0 | Not Required | \$0 | No |

F.7 UNCERTAINTY ANALYSIS

The following two uncertainties were further investigated as to their impact on the overall SAMA evaluation:

- Assume a discount rate of 3 percent, instead of 7 percent used in the original base case analysis.
- Investigate the impact for limiting the analysis to only those sequences that result in a Large Early Release.

The first item was investigated by re-calculating the total averted cost-risk associated with eliminating all severe accident risk with an assumed discount rate of 3 percent. The revised analysis results in a total averted cost of \$1,254,000 compared to the base case value of \$1,033,000. This represents a 21 percent increase in the total averted cost. The Phase 1 SAMA list was reviewed to see if any of the items screened would be impacted by this uncertainty in the assumed discount rate. Two SAMAs were potentially impacted, Phase I SAMAs 123 and 164. SAMA 123 requires installation of a unique, independent AC power system for the RHR system. The original estimate provided from Reference 17 was \$1.2 million; however, this is considered to greatly underestimate the cost of implementing this SAMA. Given that use of the three percent real discount rate only indicates a net value of \$54,000, this SAMA is still not considered to be cost beneficial. Given the diversity of the on-site AC system at RNP

(three EDGs), a detailed cost benefit analysis would clearly show a minimal benefit from the implementation of this SAMA. SAMA 164 involves the addition of a larger CST tank to provide increased capacity for injection. Using Reference 17, an estimate for implementation of \$1,000,000 was obtained and judged to be in excess of the total averted cost-risk for RNP. With a 21 percent increase in the total cost, it is still judged that the addition of a larger capacity CST (or RWST) tank would exceed the benefit obtained by the modification as the cost of implementation in Reference 17 is considered to be a low end estimate. In addition, increasing the cost benefit of those items analyzed in Phase II by 21 percent would not impact the overall conclusions summarized in Section F.6.

The second uncertainty involves an investigation into the accident sequences selected for the SAMA evaluation. LERF is used as one of the measures to estimate the cost benefit of implementing potential plant modifications. The Robinson SAMA evaluation has focused on those accident sequences that only contribute to the LERF. For Robinson, the Large Early Release Frequency represents approximately 13 percent of the total Core Damage Frequency. The remaining sequences involve accidents that do not contribute to LERF and would be made up of a significant fraction of sequences that do not result in containment failure. Some portion of these non-LERF cases would involve a potential late release of radionuclides from the containment. One major difference between these sequences and the LERF events is that natural removal of airborne fission products could occur over the period from vessel breach to containment failure. In fact, it has been calculated that for many PWR containments, late containment failure could occur on the order of 48 hours after accident initiation. This extended time would provide for removal and decay of radionuclides prior to release from containment.

To provide an assessment of the non-LERF events, the consequences of a late containment failure case were analyzed and combined with the LERF results. As a bounding estimate, a representative non-LERF source term (RC-1B) was chosen to represent non-LERF releases at the non-LERF release frequency ($1.72E-5/\text{yr}$). The maximum averted cost-risk was then re-calculated including these non-LERF accidents and found to result in an increase of 20 percent. The resulting maximum averted cost-risk was \$1.2 million. This is a rather modest increase, and similar to the uncertainty on the discount rate, would not be expected to significantly impact the screening process. In addition, the conclusions summarized in Section F.6 would not be changed due to this uncertainty.

F.8 CONCLUSIONS

The benefits of revising the operational strategies in place at RNP and/or implementing hardware modifications can be evaluated without the insight from a risk-based analysis. Use of the PSA in conjunction with cost benefit analysis methodologies has, however, provided an enhanced understanding of the effects of the proposed changes relative to the cost of implementation and projected impact on a much larger future population. The results of this study indicate that of the identified potential improvements that can

be made at RNP, none are cost beneficial based on the methodology applied in this analysis.

F.9 TABLES AND FIGURES

**TABLE F-1
 ESTIMATED POPULATION DISTRIBUTION WITHIN A
 10-MILE RADIUS OF RNP, YEAR 2030**

| Sector | 0-1 mile | 1-2 miles | 2-3 miles | 3-4 miles | 4-5 miles | 5-10 miles | 10-mile total |
|---------------|-----------------|------------------|------------------|------------------|------------------|-------------------|----------------------|
| N | 0 | 0 | 0 | 444 | 42 | 218 | 704 |
| NNE | 0 | 47 | 361 | 119 | 162 | 382 | 1,071 |
| NE | 0 | 113 | 125 | 4 | 114 | 916 | 1,272 |
| ENE | 8 | 151 | 389 | 861 | 54 | 1,792 | 3,255 |
| E | 25 | 0 | 426 | 548 | 1,248 | 4,322 | 6,569 |
| ESE | 35 | 134 | 80 | 895 | 2,112 | 9,778 | 13,034 |
| SE | 52 | 61 | 238 | 1,083 | 2,205 | 4,156 | 7,795 |
| SSE | 20 | 68 | 437 | 858 | 335 | 1,527 | 3,245 |
| S | 56 | 32 | 85 | 63 | 121 | 896 | 1,253 |
| SSW | 35 | 56 | 80 | 18 | 132 | 749 | 1,070 |
| SW | 166 | 80 | 110 | 127 | 135 | 461 | 1,079 |
| WSW | 172 | 248 | 317 | 7 | 37 | 251 | 1,032 |
| W | 63 | 217 | 67 | 68 | 45 | 580 | 1,040 |
| WNW | 0 | 28 | 12 | 0 | 18 | 1,020 | 1,078 |
| NW | 133 | 172 | 0 | 0 | 17 | 1,127 | 1,449 |
| NNW | 0 | 0 | 0 | 156 | 0 | 80 | 236 |
| Total | 765 | 1,407 | 2,727 | 5,251 | 6,777 | 28,255 | 45,182 |

**TABLE F-2
 ESTIMATED POPULATION DISTRIBUTION WITHIN A
 50-MILE RADIUS OF RNP, YEAR 2030**

| Sector | 0-10 miles | 10-20 miles | 20-30 miles | 30-40 miles | 40-50 miles | 50-mile total |
|---------------|-------------------|--------------------|--------------------|--------------------|--------------------|----------------------|
| N | 704 | 1,437 | 7,422 | 13,131 | 10,338 | 33,032 |
| NNE | 1,071 | 2,899 | 8,656 | 7,222 | 28,646 | 48,494 |
| NE | 1,272 | 1,833 | 12,578 | 5,814 | 26,859 | 48,356 |
| ENE | 3,255 | 3,083 | 4,436 | 17,165 | 34,682 | 62,621 |
| E | 6,569 | 3,998 | 1,015 | 2,514 | 28,864 | 42,960 |
| ESE | 13,034 | 22,582 | 41,588 | 8,028 | 17,933 | 103,165 |
| SE | 7,795 | 4,563 | 59,971 | 16,342 | 11,945 | 100,616 |
| SSE | 3,245 | 5,929 | 7,279 | 11,656 | 16,954 | 45,063 |
| S | 1,253 | 2,210 | 5,502 | 4,897 | 16,772 | 30,634 |
| SSW | 1,070 | 9,346 | 5,509 | 82,645 | 10,627 | 109,197 |
| SW | 1,079 | 3,530 | 6,479 | 10,852 | 12,935 | 34,875 |
| WSW | 1,032 | 2,077 | 40,592 | 26,542 | 59,261 | 129,504 |
| W | 1,040 | 3,812 | 4,288 | 4,057 | 3,866 | 17,063 |
| WNW | 1,078 | 1,808 | 10,996 | 18,764 | 37,600 | 70,246 |
| NW | 1,449 | 1,746 | 4,570 | 18,823 | 54,475 | 81,063 |
| NNW | 236 | 912 | 11,406 | 19,729 | 171,554 | 203,837 |
| Total | 45,182 | 71,765 | 232,287 | 268,181 | 543,311 | 1,160,726 |

**TABLE F-3
 ESTIMATED ANNUAL POPULATION GROWTH RATE
 WITHIN A 10-MILE RADIUS OF RNP**

| Sector | 0-1 mile | 1-2 miles | 2-3 miles | 3-4 miles | 4-5 miles | 5-10 miles |
|---------------|-----------------|------------------|------------------|------------------|------------------|-------------------|
| N | 1.0086 | 1.0088 | 1.0103 | 1.0104 | 1.0104 | 1.0104 |
| NNE | 1.0086 | 1.0086 | 1.0090 | 1.0100 | 1.0104 | 1.0104 |
| NE | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0088 | 1.0096 |
| ENE | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 |
| E | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 |
| ESE | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 |
| SE | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 |
| SSE | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 |
| S | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0087 |
| SSW | 1.0086 | 1.0086 | 1.0086 | 1.0087 | 1.0087 | 1.0088 |
| SW | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0087 |
| WSW | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0086 | 1.0118 |
| W | 1.0086 | 1.0086 | 1.0089 | 1.0098 | 1.0103 | 1.0139 |
| WNW | 1.0086 | 1.0087 | 1.0102 | 1.0104 | 1.0104 | 1.0104 |
| NW | 1.0086 | 1.0092 | 1.0104 | 1.0104 | 1.0104 | 1.0104 |
| NNW | 1.0086 | 1.0092 | 1.0104 | 1.0104 | 1.0104 | 1.0104 |

**TABLE F-4
 ESTIMATED ANNUAL POPULATION GROWTH RATE
 WITHIN A 10 TO 50-MILE RADIUS OF RNP**

| Sector | 0-10 miles | 10-20 miles | 20-30 miles | 30-40 miles | 40-50 miles |
|---------------|-------------------|--------------------|--------------------|--------------------|--------------------|
| N | See Table F-3 | 1.0104 | 1.0098 | 1.0074 | 1.0087 |
| NNE | See Table F-3 | 1.0104 | 1.0092 | 1.0059 | 1.0056 |
| NE | See Table F-3 | 1.0103 | 1.0049 | 0.9997 | 1.0056 |
| ENE | See Table F-3 | 1.0092 | 1.0004 | 0.9984 | 1.0087 |
| E | See Table F-3 | 1.0086 | 1.0039 | 1.0029 | 1.0056 |
| ESE | See Table F-3 | 1.0086 | 1.0090 | 1.0082 | 1.0049 |
| SE | See Table F-3 | 1.0086 | 1.0095 | 1.0096 | 1.0092 |
| SSE | See Table F-3 | 1.0086 | 1.0081 | 1.0088 | 1.0047 |
| S | See Table F-3 | 1.0087 | 1.0079 | 1.0046 | 1.0126 |
| SSW | See Table F-3 | 1.0088 | 1.0055 | 1.0019 | 1.0036 |
| SW | See Table F-3 | 1.0090 | 1.0106 | 1.0074 | 1.0104 |
| WSW | See Table F-3 | 1.0168 | 1.0190 | 1.0188 | 1.0118 |
| W | See Table F-3 | 1.0190 | 1.0190 | 1.0155 | 1.0056 |
| WNW | See Table F-3 | 1.0187 | 1.0143 | 1.0121 | 1.0087 |
| NW | See Table F-3 | 1.0126 | 1.0116 | 1.0164 | 1.0303 |
| NNW | See Table F-3 | 1.0104 | 1.0103 | 1.0314 | 1.0390 |

**TABLE F-5
ESTIMATED RNP CORE INVENTORY**

| Nuclide | Core Inventory (Becquerels) | Nuclide | Core Inventory (Becquerels) |
|---------|--------------------------------|---------|--------------------------------|
| Co-58 | 2.21X10 ¹⁶ | Te-131m | 3.21X10 ¹⁷ |
| Co-60 | 1.69X10 ¹⁶ | Te-132 | 3.20X10 ¹⁸ |
| Kr-85 | 1.70X10 ¹⁶ | I-131 | 2.20X10 ¹⁸ |
| Kr-85m | 7.95X10 ¹⁷ | I-132 | 3.24X10 ¹⁸ |
| Kr-87 | 1.45X10 ¹⁸ | I-133 | 4.65X10 ¹⁸ |
| Kr-88 | 1.96X10 ¹⁸ | I-134 | 5.10X10 ¹⁸ |
| Rb-86 | 1.30X10 ¹⁵ | I-135 | 4.38X10 ¹⁸ |
| Sr-89 | 2.46X10 ¹⁸ | Xe-133 | 4.65X10 ¹⁸ |
| Sr-90 | 1.33X10 ¹⁷ | Xe-135 | 8.73X10 ¹⁷ |
| Sr-91 | 3.17X10 ¹⁸ | Cs-134 | 2.97X10 ¹⁷ |
| Sr-92 | 3.29X10 ¹⁸ | Cs-136 | 9.03X10 ¹⁶ |
| Y-90 | 1.43X10 ¹⁷ | Cs-137 | 1.66X10 ¹⁷ |
| Y-91 | 3.00X10 ¹⁸ | Ba-139 | 4.31X10 ¹⁸ |
| Y-92 | 3.31X10 ¹⁸ | Ba-140 | 4.26X10 ¹⁸ |
| Y-93 | 3.74X10 ¹⁸ | La-140 | 4.36X10 ¹⁸ |
| Zr-95 | 3.79X10 ¹⁸ | La-141 | 4.00X10 ¹⁸ |
| Zr-97 | 3.95X10 ¹⁸ | La-142 | 3.85X10 ¹⁸ |
| Nb-95 | 3.58X10 ¹⁸ | Ce-141 | 3.88X10 ¹⁸ |
| Mo-99 | 4.18X10 ¹⁸ | Ce-143 | 3.77X10 ¹⁸ |
| Tc-99m | 3.61X10 ¹⁸ | Ce-144 | 2.34X10 ¹⁸ |
| Ru-103 | 3.12X10 ¹⁸ | Pr-143 | 3.70X10 ¹⁸ |
| Ru-105 | 2.03X10 ¹⁸ | Nd-147 | 1.65X10 ¹⁸ |
| Ru-106 | 7.08X10 ¹⁷ | Np-239 | 4.43X10 ¹⁹ |
| Rh-105 | 1.40X10 ¹⁸ | Pu-238 | 2.51X10 ¹⁵ |
| Sb-127 | 1.91X10 ¹⁷ | Pu-239 | 5.67X10 ¹⁴ |
| Sb-129 | 6.77X10 ¹⁷ | Pu-240 | 7.15X10 ¹⁴ |
| Te-127 | 1.85X10 ¹⁷ | Pu-241 | 1.20X10 ¹⁷ |
| Te-127m | 2.44X10 ¹⁶ | Am-241 | 7.95X10 ¹³ |
| Te-129 | 6.36X10 ¹⁷ | Cm-242 | 3.04X10 ¹⁶ |
| Te-129m | 1.68X10 ¹⁷ | Cm-244 | 1.78X10 ¹⁵ |

TABLE F-6
MACCS RELEASE CATEGORIES VS. RNP RELEASE CATEGORIES

| MACCS Release Categories | RNP Release Categories |
|----------------------------|---|
| Xe/Kr | 1 – noble gases |
| I | 2 – CsI |
| Cs | 2 & 6 – CsI and CsOH |
| Te | 3 & 11- TeO ₂ & Te ₂ |
| Sr | 4 – SrO |
| Ru | 5 – MoO ₂ (not used) |
| La | 8 – La ₂ O ₃ (not used) |
| Ce | 9 – CeO ₂ (not used) |
| Ba | 7 – BaO (not used) |
| Sb (supplemental category) | 10 – Sb (not used) |

**TABLE F-7
 RESULTS OF RNP LEVEL 3 PSA ANALYSIS**

| Sequence: | RC-2 | RC-2B | RC-4 | RC-4C | RC-5 | RC-5C | Sum of annual risk |
|-----------------------------------|-----------------------|-----------------------|-------------|--------------|-------------|-----------------------|---------------------------|
| Population dose risk (person-rem) | | | | | | | |
| 0-50 miles | 2.39x10 ⁻² | 2.79x10 ⁻¹ | 0.000 | 1.56 | 3.04 | 9.38x10 ⁻¹ | 5.84 |
| Total economic cost risk (\$) | | | | | | | |
| 0-50 miles | 42 | 722 | 0 | 3,081 | 4,345 | 1,340 | 9,530 |

**TABLE F-8
PHASE I SAMA**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|---|--|--------------------------|--|--------------------------------------|---|-----------------------|-------------------------|
| Improvements Related to RCP Seal LOCAs (Loss of CCW or SW) | | | | | | | |
| 1 | Cap downstream piping of normally closed component cooling water drain and vent valves. | 1 | SAMA would reduce the frequency of a loss of component cooling event, a large portion of which was derived from catastrophic failure of one of the many single isolation valves. | #3 - Already implemented at Robinson | Drawing 5379-376 indicates that most of the vents and drains are already capped. | Reference 41 | N/A |
| 2 | Enhance loss of component cooling procedure to facilitate stopping reactor coolant pumps. | 2 | SAMA would reduce the potential for reactor coolant pump (RCP) seal damage due to pump bearing failure. | #3 - Already implemented at Robinson | For example, AOP - 014 (Rev. 17), Step 4 Section A, directs the operators to stop all RCPs. | Reference 22 | N/A |
| 3 | Enhance loss of component cooling procedure to present desirability of cooling down reactor coolant system (RCS) prior to seal LOCA. | 2 | SAMA would reduce the potential for RCP seal failure. | #3 - Already implemented at Robinson | This SAMA may not be applicable to Robinson. Loss of CCW would not necessarily result in challenge to the RCP seals, since either seal injection or CCW is sufficient to protect our seals. And, since alternate cooling of charging pumps is possible, loss of CCW does not equal loss of seal injection. See item #5. | Reference 20 | N/A |
| 4 | Provide additional training on the loss of component cooling. | 2 | SAMA would potentially improve the success rate of operator actions after a loss of component cooling (to restore RCP seal damage). | #3 - Already implemented at Robinson | Sufficient training is provided. | Reference 40 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|--------------------------------------|--|-----------------------|-------------------------|
| 5 | Provide hardware connections to allow another essential raw cooling water system to cool charging pump seals. | 1 2 | SAMA would reduce effect of loss of component cooling by providing a means to maintain the centrifugal charging pump seal injection after a loss of component cooling. | #3 - Already implemented at Robinson | Hose connections are available to allow Service Water, Fire Water, or Potable Water to supply cooling water to the charging pumps on loss of CCW. This SAMA is considered to be adequately addressed by these two independent, backup water supplies to CCW. | Reference 22 | N/A |
| 6 | Procedure changes to allow cross connection of motor cooling for RHR/SW pumps. | 12 | SAMA would allow continued operation of both RHR/SW pumps on a failure of one train of SW. | #1 - N/A | The "equivalent" pumps for Robinson, the Component Cooling Water pumps, do not require cooling from any other system. | Reference 20 | N/A |
| 7 | Proceduralize shedding component cooling water loads to extend component cooling heatup on loss of essential raw cooling water. | 2 | SAMA would increase time before the loss of component cooling (and reactor coolant pump seal failure) in the loss of essential raw cooling water sequences. | #3 - Already implemented at Robinson | For example, AOP - 014 (Rev. 17), Step 6 of Section D, directs the operators to shed excess loads. | Reference 22 | N/A |
| 8 | Increase charging pump lube oil capacity. | 2 | SAMA would lengthen the time before centrifugal charging pump failure due to lube oil overheating in loss of CC sequences. | #1 - N/A | In the event of CCW failure, hose connections allow the use of fire water or SW as a backup cooling supply. In addition, for scenarios where CPs are transferring borated water from the RWST to the RCS, the CPs may be able to continue to cool the RCP seals. | Reference 23 (A.18) | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|--|-----------------------|-------------------------|
| 9 | Eliminate the RCP thermal barrier dependence on component cooling such that loss of component cooling does not result directly in core damage. | 2 | SAMA would prevent the loss of recirculation pump seal integrity after a loss of component cooling. | #3 - Already implemented at Robinson | Refer to #3 | Reference 20 | N/A |
| 10 | Add redundant DC control power for PSW pumps C & D. | 3 | SAMA would increase reliability of PSW and decrease core damage frequency due to a loss of SW. | #3 - Already implemented at Robinson | The "D" service water pump currently has dual power and control power supplies. Additionally, the SW system consists of two independent trains, with different power sources, that are/can be crosstied. | Reference 20 | N/A |
| 11 | Create an independent RCP seal injection system, with a dedicated diesel. | 1 | SAMA would add redundancy to RCP seal cooling alternatives, reducing CDF from loss of component cooling or service water or from a station blackout event. | #5 - Cost would be more than risk benefit | While seal injection is an important function, the cost estimate for installation of new seals alone exceeds \$2.5 million. A new, independent seal injection system is judged to greatly exceed this cost and the maximum averted cost risk of \$1,033,000. | Reference 19 | N/A |
| 12 | Use existing hydro-test pump for RCP seal injection. | 4 | SAMA would provide an independent seal injection source, without the cost of a new system. | #1 - N/A | Plant currently has 3 positive displacement charging pumps. There is no existing installed hydro pump. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|-----------------------|-------------------------|
| 13 | Replace ECCS pump motor with air-cooled motors. | 1 14 | SAMA would eliminate ECCS dependency on component cooling system (but not on room cooling). | #5 - Cost would be more than risk benefit | Based on engineering judgement, the cost of this enhancement is expected to greatly exceed the maximum averted cost risk that could be gained by its implementation. Installation of an additional Service Water pump has been estimated at \$5.9 million; this change is considered to be similar to installing new ECCS pumps. While new piping and power supplies would not have to be installed to support the new ECCS pumps, unneeded piping would have to be removed and capped and the number of new ECCS pumps is five compared with only one in the reference case. | Reference 17 | N/A |
| 14 | Install improved RCS pumps seals. | 1 | SAMA would reduce probability of RCP seal LOCA by installing RCP seal O-ring constructed of improved materials | #3-Already implemented at Robinson | RCP pump "B" and "C" seals have already been replaced. The pump "A" seal is scheduled to be replaced in a future outage. The new seals are capable of withstanding temperatures of 550 degrees F. | Plant modifications | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|--|-----------------------|-------------------------|
| 15 | Install additional component cooling water pump. | 1 | SAMA would reduce probability of loss of component cooling leading to RCP seal LOCA. | #5 - Cost would be more than risk benefit | Based on engineering judgement, the cost of this enhancement is expected to greatly exceed the maximum averted cost risk (\$1,033,000) that could be gained by its implementation. Installation of an additional Service Water pump has been estimated at \$5.9 million; this change is considered to be similar to installing a new CCW pump. | Reference 17 | N/A |
| 16 | Prevent centrifugal charging pump flow diversion from the relief valves. | 1 | SAMA modification would reduce the frequency of the loss of RCP seal cooling if relief valve opening causes a flow diversion large enough to prevent RCP seal injection. | #6 - Retain | Will likely be screened in Phase 2 due to low risk significance as CP (charging pump) and CCW both provide cooling to the RCPs while CP is dependent on CCW for pump cooling. CCW is the important system. | N/A | 1 |
| 17 | Change procedures to isolate RCP seal letdown flow on loss of component cooling, and guidance on loss of injection during seal LOCA. | 1 | SAMA would reduce CDF from loss of seal cooling. | #3 - Already implemented at Robinson | AOP-014 (Rev. 17) directs isolation of RCP seal letdown flow. | Reference 22 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|---|-----------------------------|-------------------------|
| 18 | Implement procedures to stagger high-pressure safety injection (HPSI) pump use after a loss of service water. | 1 | SAMA would allow HPSI to be extended after a loss of service water. | #4-No significant safety benefit | This SAMA does not place the reactor in a stable condition. Credit would be in the form of a delay in core damage that would allow increased time to repair the SW system. This type of action is not credited in the PSA and the SAMA would yield no measurable safety benefit. | N/A | N/A |
| 19 | Use fire protection system pumps as a backup seal injection and high-pressure makeup. | 1 | SAMA would reduce the frequency of the RCP seal LOCA and the SBO CDF. | #5 - Cost would be more than risk benefit | Fire protection is a low head system at Robinson and cannot be used as a HP injection source. Modifications to convert it to a high pressure system would be a high cost improvement. The use of fire water for RCP seal injection would not be preferred since this is unborated lake water. | Refer to SAMA 179 | N/A |
| 20 | Enhance procedural guidance for use of cross-tied component cooling or service water pumps. | 1 14 | SAMA would reduce the frequency of the loss of component cooling water and service water. | #3 - Already implemented at Robinson | The pump trains in each of these systems are normally cross-tied and run in parallel. | Reference 23, Appendix A.11 | N/A |
| 21 | Procedure enhancements and operator training in support system failure sequences, with emphasis on anticipating problems and coping. | 1 2 14 20 | SAMA would potentially improve the success rate of operator actions subsequent to support system failures. | #2 - Similar item is addressed under other proposed SAMAs | See 20, 27, 30, 90, 95, 96, 97, 103 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|-----------------------|-------------------------|
| 22 | Improved ability to cool the residual heat removal heat exchangers. | 1 | SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the fire protection system or by installing a component cooling water cross-tie. | #6 - Retain | CCW pump trains are already cross-tied. Modification of the fire protection system, another existing system or addition of a new system to provide redundant cooling is expected to exceed the estimated maximum averted cost-risk. | N/A | 2 |
| 23 | 8.a. Additional Service Water Pump | 17 | SAMA would conceivably reduce common cause dependencies from SW system and thus reduce plant risk through system reliability improvement. | #5 - Cost would be more than risk benefit | The cost of implementing this SAMA has been estimated at approximately \$5.9 million and is greater than the maximum averted cost-risk (\$1,033,000). | Reference 17 | N/A |
| 24 | Create an independent RCP seal injection system, without dedicated diesel | 19 | This SAMA would add redundancy to RCP seal cooling alternatives, reducing the CDF from loss of CC or SW, but not SBO. | #5 - Cost would be more than risk benefit | Calvert Cliffs Nuclear Power Plant estimated the cost of installing new seals that do not require cooling to be greater than \$2.5 million. Based on this estimate and engineering judgement, the cost of installing a completely new and independent seal injection system would significantly exceed the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|---|--|--------------------------|--|--------------------------------------|--|-----------------------|-------------------------|
| Improvements Related to Heating, Ventilation, and Air Conditioning | | | | | | | |
| 25 | Provide reliable power to control building fans. | 2 | SAMA would increase availability of control room ventilation on a loss of power. | #3 - Already implemented at Robinson | The important HVAC components for Robinson (EDG room cooling) are supplied by Class 1E power and are considered to be reliable power sources. | Reference 20 | N/A |
| 26 | Provide a redundant train of ventilation. | 1 | SAMA would increase the availability of components dependent on room cooling. | #3 - Already implemented at Robinson | Redundancy currently exists in equipment rooms where it is needed for accident mitigation. | Reference 20 | N/A |
| 27 | Procedures for actions on loss of HVAC. | 12 14 | SAMA would provide for improved credit to be taken for loss of HVAC sequences (improved affected electrical equipment reliability upon a loss of control building HVAC). | #3 - Already implemented at Robinson | Internal analyses for SBO indicates that only the control room requires cooling. Provisions exist for opening cabinet doors, providing aux ventilation, etc. | Reference 25 | N/A |
| 28 | Add a diesel building switchgear room high temperature alarm. | 1 14 | SAMA would improve diagnosis of a loss of switchgear room HVAC. Option 1: Install high temp alarm. Option 2: Redundant louver and thermostat | #3 - Already implemented at Robinson | The EDG rooms are already equipped with high temperature alarms. | Reference 26 | N/A |
| 29 | Create ability to switch fan power supply to DC in an SBO event. | 1 | SAMA would allow continued operation in an SBO event. This SAMA was created for reactor core isolation cooling system room at Fitzpatrick Nuclear Power Plant. | #1 - N/A | The control room is the only room that needs cooling for an SBO. It is already provided. | Reference 27 | N/A |
| 30 | Enhance procedure to instruct operators to trip unneeded RHR/CS pumps on loss of room ventilation. | 12 | SAMA increases availability of required RHR/CS pumps. Reduction in room heat load allows continued operation of required RHR/CS pumps, when room cooling is lost. | #1 - N/A | Neither the CS nor RHR pumps are dependent on room cooling at Robinson. | Reference 18 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|--|--|--------------------------|--|---|---|-----------------------|-------------------------|
| 31 | Stage backup fans in switchgear (SWGR) rooms | 19 | This SAMA would provide alternate ventilation in the event of a loss of SWGR Room ventilation | #1 - N/A | Robinson system descriptions indicate that room cooling is not required in the 4 kV bus room due to its volume and construction characteristics. | Reference 27 | N/A |
| Improvements Related to Ex-Vessel Accident Mitigation/Containment Phenomena | | | | | | | |
| 32 | Delay containment spray actuation after large LOCA. | 2 14 | SAMA would lengthen time of RWST availability. | #3 - Already implemented at Robinson | SAM-6 provides guidance to limit containment spray flow to preserve RWST. | Reference 24 | N/A |
| 33 | Install containment spray pump header automatic throttle valves. | 4 8 | SAMA would extend the time over which water remains in the RWST, when full CS flow is not needed | #2 - Similar item is addressed under other proposed SAMAs | See 32 | N/A | N/A |
| 34 | Install an independent method of suppression pool cooling. | 5 6 | SAMA would decrease the probability of loss of containment heat removal. For PWRs, a potential similar enhancement would be to install an independent cooling system for sump water. | #5 - Cost would be more than risk benefit | Installation of a new, independent, sump water cooling system is similar in scope to installing a new containment spray system, which has been estimated to cost approximately \$5.8 million. This exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 35 | Develop an enhanced drywell spray system. | 5 6 14 | SAMA would provide a redundant source of water to the containment to control containment pressure, when used in conjunction with containment heat removal. | #3 - Already implemented at Robinson | Addressed in SAM-6. Also, see SAMAs 32, 33 | Reference 24 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|-----------------------|-------------------------|
| 36 | Provide dedicated existing drywell spray system. | 5 6 | SAMA would provide a source of water to the containment to control containment pressure, when used in conjunction with containment heat removal. This would use an existing spray loop instead of developing a new spray system. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 35 | Reference 24 | N/A |
| 37 | Install an unfiltered hardened containment vent. | 5 6 14 | SAMA would provide an alternate decay heat removal method for non-ATWS events, with the released fission products not being scrubbed. | #5 - Cost would be more than risk benefit | The long time periods associated with the need to vent with this type of containment would rule out any contribution to LERF, which dominates the offsite consequences. In addition, the estimated cost of installing an unfiltered containment vent (\$3.1 million) is greater than the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 38 | Install a filtered containment vent to remove decay heat. | 5 6 | SAMA would provide an alternate decay heat removal method for non-ATWS events, with the released fission products being scrubbed. Option 1: Gravel Bed Filter Option 2: Multiple Venturi Scrubber | #1 - N/A | The long time periods associated with the need to vent with this type of containment would rule out any contribution to LERF, which dominates the offsite consequences. In addition, the estimated cost of installing a filtered containment vent (\$5.7 million) is significantly greater than the maximum averted cost-risk. | Reference 19 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|---|-----------------------|-------------------------|
| 39 | Install a containment vent large enough to remove ATWS decay heat. | 5 6 | Assuming that injection is available, this SAMA would provide alternate decay heat removal in an ATWS event. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 37, 38 | Reference 19 | N/A |
| 40 | Create/enhance hydrogen recombiners with independent power supply. | 5 11 | SAMA would reduce hydrogen detonation at lower cost. Use either 1) a new independent power supply 2) a nonsafety-grade portable generator 3) existing station batteries 4) existing AC/DC independent power supplies. | #3 - Already implemented at Robinson | Hydrogen recombiners are addressed in SAM-7. Power requirements are discussed along with methods for returning system to service. | Reference 24 | N/A |
| 41 | Install hydrogen recombiners. | 11 | SAMA would provide a means to reduce the chance of hydrogen detonation. | #3 - Already implemented at Robinson | Robinson currently has access to hydrogen recombiners. | Reference 24 | N/A |
| 42 | Create a passive design hydrogen ignition system. | 4 | SAMA would reduce hydrogen denotation system without requiring electric power. | #2 - Similar item is addressed under other proposed SAMAs | Alternate methods of hydrogen control are addressed in SAM-7. Also see SAMA #40 | Reference 19 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------------|---|--------------------------------|--|---|--|---|-------------------------------|
| 43 | Create a large concrete crucible with heat removal potential under the basemat to contain molten core debris. | 5 6 | SAMA would ensure that molten core debris escaping from the vessel would be contained within the crucible. The water cooling mechanism would cool the molten core, preventing a melt-through of the basemat. | #5 - Cost would be more than risk benefit | Core retention devices have been investigated in previous studies. IDCOR concluded that "core retention devices are not effective risk reduction devices for degraded core events". Other evaluations have shown the worth value for a core retention device to be on the order of \$7000 (averted cost-risk) compared to an estimated implementation cost of over \$1 million (per unit). | Supplement 2 to NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, December 1999 for Oconee Nuclear Station, and IDCOR Technical Summary Report, November 1984 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|---|-------------------------|
| 44 | Create a water-cooled rubble bed on the pedestal. | 5 6 | SAMA would contain molten core debris dropping on to the pedestal and would allow the debris to be cooled. | #5 - Cost would be more than risk benefit | Core retention devices have been investigated in previous studies. IDCOR concluded that "core retention devices are not effective risk reduction devices for degraded core events". Other evaluations have shown the worth value for a core retention device to be on the order of \$7000 (averted cost-risk) compared to an estimated implementation cost of over \$1 million (per unit). | Supplement 2 to NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, December 1999 for Oconee Nuclear Station, and IDCOR Technical Summary Report, November 1984 | N/A |
| 45 | Provide modification for flooding the drywell head. | 5 6 | SAMA would help mitigate accidents that result in the leakage through the drywell head seal. | #1 - N/A | This is a BWR issue. PWR containment does not include an equivalent structure/component that this modification could be applied to and is screened from further consideration. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|---|-------------------------|
| 46 | Enhance fire protection system and/or standby gas treatment system hardware and procedures. | 6 | SAMA would improve fission product scrubbing in severe accidents. | #1 - N/A | Current Fire Protection and Standby Gas Treatment Systems (for BWRs) do not have sufficient capacity to handle the loads from severe accidents that result in a bypass or breach of the containment. Loads produced as a result of RPV or containment blowdown would require large filtering capacities. These filtered vented systems have been previously investigated and found not to provide sufficient cost benefit. | IDCOR Technical Summary Report, November 1984 | N/A |
| 47 | Create a reactor cavity flooding system. | 1 3 7 8 14 | SAMA would enhance debris coolability, reduce core concrete interaction, and provide fission product scrubbing. | #5 - Cost would be more than risk benefit | The estimated cost of implementation for this SAMA is \$8.75 million, which greatly exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 48 | Create other options for reactor cavity flooding. | 1 14 | SAMA would enhance debris coolability, reduce core concrete interaction, and provide fission product scrubbing. | #3 - Already implemented at Robinson | SAM-4 addresses various alternative methods for injecting into containment. | Reference 24 | N/A |
| 49 | Enhance air return fans (ice condenser plants). | 1 | SAMA would provide an independent power supply for the air return fans, reducing containment failure in SBO sequences. | #1 - N/A | Robinson is not an ice condenser plant. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|---|-------------------------|
| 50 | Create a core melt source reduction system. | 9 | SAMA would provide cooling and containment of molten core debris. Refractory material would be placed underneath the reactor vessel such that a molten core falling on the material would melt and combine with the material. Subsequent spreading and heat removal from the vitrified compound would be facilitated, and concrete attack would not occur. | #5 - Cost would be more than risk benefit | Core retention devices have been investigated in previous studies. IDCOR concluded that "core retention devices are not effective risk reduction devices for degraded core events". Other evaluations have shown the worth value for a core retention device to be on the order of \$7000 compared to an estimated implementation cost of over \$1 million. | Supplement 2 to NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, December 1999 for Oconee Nuclear Station, and IDCOR Technical Summary Report, November 1984 | N/A |
| 51 | Provide a containment inerting capability. | 7 8 | SAMA would prevent combustion of hydrogen and carbon monoxide gases. | #1 - N/A | Not considered viable in a large volume containment where access may be required. | N/A | N/A |
| 52 | Use the fire protection system as a backup source for the containment spray system. | 4 | SAMA would provide redundant containment spray function without the cost of installing a new system. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 35 | N/A | N/A |
| 53 | Install a secondary containment filtered vent. | 10 | SAMA would filter fission products released from primary containment. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 38 | N/A | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|---|---|-----------------------|-------------------------|
| 54 | Install a passive containment spray system. | 10 | SAMA would provide redundant containment spray method without high cost. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 35 | N/A | N/A |
| 55 | Strengthen primary/secondary containment. | 10 11 | SAMA would reduce the probability of containment overpressurization to failure. | #5 - Cost would be more than risk benefit | Reference 17 discusses the cost of increasing the containment pressure capacity, which is effectively strengthening the containment. This cost is estimated assuming the change is made during the design phase whereas for Robinson, the changes would have to be made as a retrofit. The cost estimated for the ABWR was \$12 million and it is judged that to properly retrofit an existing containment that the cost would be greater. This cost of implementation for this SAMA exceeds the maximum averted cost-risk (\$1,033,000). | Reference 17 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|---|-------------------------|
| 56 | Increase the depth of the concrete basemat or use an alternative concrete material to ensure melt-through does not occur. | 11 | SAMA would prevent basemat melt-through. | #5 - Cost would be more than risk benefit | Core retention devices have been investigated in previous studies. IDCOR concluded that "core retention devices are not effective risk reduction devices for degraded core events". Other evaluations have shown the worth value for a core retention device to be on the order of \$7000 compared to an estimated implementation cost of over \$1 million/site. | Supplement 2 to NUREG-1437, Generic Environmental Impact Statement for License renewal of Nuclear Plants, December 1999 for Oconee Nuclear Station, and IDCOR Technical Summary Report, November 1984 | N/A |
| 57 | Provide a reactor vessel exterior cooling system. | 11 | SAMA would provide the potential to cool a molten core before it causes vessel failure, if the lower head could be submerged in water. | #5 - Cost would be more than risk benefit | This has been estimated to cost \$2.5 million and exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 58 | Construct a building to be connected to primary/secondary containment that is maintained at a vacuum. | 11 | SAMA would provide a method to depressurize containment and reduce fission product release. | #5 - Cost would be more than risk benefit | Based on engineering judgement, the cost of this enhancement is expected to greatly exceed the maximum averted cost risk (\$1,033,000). | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|--------------------------------------|--|-----------------------|-------------------------|
| 59 | Refill CST | 14 16 | SAMA would reduce the risk of core damage during events such as extended station blackouts or LOCAs which render the suppression pool unavailable as an injection source due to heat up. | #3 - Already implemented at Robinson | This capability exists. Like most plants, Robinson has the capability to supply makeup from the SW system. However, SW is dependent on AC power. Plant procedures also provide for adding makeup using firewater supplied by the diesel fire pump. | Reference 25 | N/A |
| 60 | Maintain ECCS suction on CST | 14 16 | SAMA would maintain suction on the CST as long as possible to avoid pump failure as a result of high suppression pool temperature | #3 - Already implemented at Robinson | Procedures call for utilizing the CST until AFW suction is no longer possible. SAM-4 addresses various alternative methods and limitations for injecting into containment. | Reference 28 | N/A |
| 61 | Modify containment flooding procedure to restrict flooding to below top of active fuel | 14 | SAMA would avoid forcing containment venting | #1 - N/A | Not applicable to the Robinson design. | Reference 20 | N/A |
| 62 | Enhance containment venting procedures with respect to timing, path selection and technique. | 14 | SAMA would improve likelihood of successful venting strategies. | #3 - Already implemented at Robinson | These steps are addressed in the SAMGs. | Reference 29 | N/A |
| 63 | 1.a. Severe Accident EPGs/AMGs | 17 | SAMA would lead to improved arrest of core melt progress and prevention of containment failure | #3 - Already Implemented at Robinson | The SAMGs have been implemented at Robinson. | Reference 24 | N/A |
| 64 | 1.h. Simulator Training for Severe Accident | 17 | SAMA would lead to improved arrest of core melt progress and prevention of containment failure | #3 - Already Implemented at Robinson | These steps are addressed in the SAMGs. | Reference 24 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|--|-----------------------|-------------------------|
| 65 | 2.g. Dedicated Suppression Pool Cooling | 17 | SAMA would decrease the probability of loss of containment heat removal. While PWRs do not have suppression pools, a similar modification may be applied to the sump. Installation of a dedicated sump cooling system would provide an alternate method of cooling injection water. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 34 | N/A | N/A |
| 66 | 3.a. Larger Volume Containment | 17 | SAMA increases time before containment failure and increases time for recovery | #5 - Cost would be more than risk benefit | RNP is already a large, dry containment. Further enlargement of the containment would be similar in scope to the ABWR design change SAMA to implement a larger volume containment, but would likely exceed the \$8 million estimate for that change as a retrofit would be required. This is greater than the maximum averted cost-risk (\$1,033,000 million). | Reference 17 | N/A |
| 67 | 3.b. Increased Containment Pressure Capability (sufficient pressure to withstand severe accidents) | 17 | SAMA minimizes likelihood of large releases | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 55 | N/A | N/A |
| 68 | 3.c. Improved Vacuum Breakers (redundant valves in each line) | 17 | SAMA reduces the probability of a stuck open vacuum breaker. | #1 - N/A | This is a BWR issue. PWR containment does not include an equivalent structure/component that this modification could be applied to and is screened from further consideration. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|--------------------------------------|---|-----------------------|-------------------------|
| 69 | 3.d. Increased Temperature Margin for Seals | 17 | This SAMA would reduce containment failure due to drywell head seal failure caused by elevated temperature and pressure. | #1 - N/A | High temperature containment seal failure is not an issue for a large, dry containment; computed containment temperatures are generally below the failure threshold. | Reference 20 | N/A |
| 70 | 3.e. Improved Leak Detection | 17 | This SAMA would help prevent LOCA events by identifying pipes which have begun to leak. These pipes can be replaced before they break. | #3 - Already implemented at Robinson | Leak rates from the primary system are already monitored as part of technical specifications requirements and instrumentation is available to identify leaks. Enhancing the procedures or equipment is possible, but the reduction in the LOCA frequency resulting from these changes is judged to be negligible. | Reference 30 | N/A |
| 71 | 3.f. Suppression Pool Scrubbing | 17 | Directing releases through the suppression pool will reduce the radionuclides allowed to escape to the environment. | #1 - N/A | This is a BWR issue. PWR containment does not include an equivalent structure/component that this modification could be applied to and is screened from further consideration. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|---|-----------------------|-------------------------|
| 72 | 3.g. Improved Bottom Penetration Design | 17 | SAMA reduces failure likelihood of RPV bottom head penetrations | #8 - ABWR design issue; not practical | This is primarily a BWR issue. The mechanisms of vessel breach due to contact with core debris are more of a concern with the larger penetrations present in the BWR bottom head design. Also, this is considered to be an initial design issue rather than a mod due to the prohibitive cost. Screened from further consideration. | Reference 17 | N/A |
| 73 | 4.a. Larger Volume Suppression Pool (double effective liquid volume) | 17 | SAMA would increase the size of the suppression pool so that heatup rate is reduced, allowing more time for recovery of a heat removal system | #1 - N/A | This is a BWR issue. PWR containment does not include an equivalent structure/component that this modification could be applied to and is screened from further consideration. | Reference 20 | N/A |
| 74 | 5.a/d. Unfiltered Vent | 17 | SAMA would provide an alternate decay heat removal method with the released fission products not being scrubbed. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 37 | N/A | N/A |
| 75 | 5.b/c. Filtered Vent | 17 | SAMA would provide an alternate decay heat removal method with the released fission products being scrubbed. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 38 and 53 | N/A | N/A |
| 76 | 6.a. Post Accident Inerting System | 17 | SAMA would reduce likelihood of gas combustion inside containment | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 51 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---------------------------------------|--------------------------|--|---|--|--------------------------|-------------------------|
| 77 | 6.b. Hydrogen Control by Venting | 17 | Prevents hydrogen detonation by venting the containment before combustible levels are reached. | #3 - Already Implemented at Robinson | The SAMG developers have considered the possibility of venting for hydrogen control, but the actions considered most appropriate for Robinson do not include venting for control. Hydrogen ignition and hydrogen recombination are directed to maintain low hydrogen concentrations within containment during an accident. | Reference 24 | N/A |
| 78 | 6.c. Pre-inerting | 17 | SAMA would reduce likelihood of gas combustion inside containment | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 51 and 76 | N/A | N/A |
| 79 | 6.d. Ignition Systems | 17 | Burning combustible gases before they reach a level which could cause a harmful detonation is a method of preventing containment failure. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 42 | N/A | N/A |
| 80 | 6.e. Fire Suppression System Inerting | 17 | Use of the fire protection system as a back up containment inerting system would reduce the probability of combustible gas accumulation. This would reduce the containment failure probability for small containments (e.g. BWR MKI) | #1 - N/A | This is a BWR issue. PWR containments are large and that would require extremely costly modifications to impose and would inhibit access to the containment. Screened from further consideration. | See SAMAs 51, 76, and 78 | N/A |
| 81 | 7.a. Drywell Head Flooding | 17 | SAMA would provide intentional flooding of the upper drywell head such that if high drywell temperatures occurred, the drywell head seal would not fail. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 45 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|-------------------------------------|--------------------------|---|---|--|-------------------------------------|-------------------------|
| 82 | 7.b. Containment Spray Augmentation | 17 | This SAMA would provide additional means of providing flow to the containment spray system. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 32, 33, 35, 36, 52, 54 | N/A | N/A |
| 83 | 12.b. Integral Basemat | 17 | | #8 - ABWR design issue; not practical | This is a SAMA that was considered for ABWR design. It is not practical to backfit this modification into a plant which is already built and operating. | Reference 17, Engineering Judgement | N/A |
| 84 | 13.a. Reactor Building Sprays | 17 | This SAMA provides the capability to use firewater sprays in the reactor building to mitigate release of fission products into the Rx Building following an accident. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 32, 33, 35, 36, 52, 54, 82 | N/A | N/A |
| 85 | 14.a. Flooded Rubble Bed | 17 | SAMA would contain molten core debris dropping on to the pedestal and would allow the debris to be cooled. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 44 | N/A | N/A |
| 86 | 14.b. Reactor Cavity Flooder | 17 | SAMA would enhance debris coolability, reduce core concrete interaction, and provide fission product scrubbing. | #2 - Similar item is addressed under other proposed SAMAs | Addressed in SAMAs 47 & 57 | N/A | N/A |
| 87 | 14.c. Basaltic Cements | 17 | SAMA minimizes carbon dioxide production during core concrete interaction. | #8 - ABWR design issue; not practical | This is a SAMA which was considered for ABWR design. It is not practical to backfit this modification into a plant which is already built and operating. | Reference 17, Engineering Judgement | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|--|--|--------------------------|---|---|---|-----------------------|-------------------------|
| 88 | Provide a core debris control system | 19 | (Intended for ice condenser plants): This SAMA would prevent the direct core debris attack of the primary containment steel shell by erecting a barrier between the seal table and the containment shell. | #1 - N/A | Robinson is not an ice condenser plant. | Reference 20 | N/A |
| 89 | Add ribbing to the containment shell | 19 | This SAMA would reduce the risk of buckling of containment under reverse pressure loading. | #2 - Similar item is addressed under other proposed SAMAs | This item is similar in nature to SAMA 55, but for protection against negative pressure. Using SAMA 55 as an upper bound and a relatively simple modification such as SAMA 37 as a lower bound, the cost of performing structural enhancements to the containment building which will significantly strengthen the containment is judged to exceed the maximum averted cost-risk (\$1,033,000). | References 17 and 19 | N/A |
| Improvements Related to Enhanced AC/DC Reliability/Availability | | | | | | | |
| 90 | Proceduralize alignment of spare diesel to shutdown board after loss of offsite power and failure of the diesel normally supplying it. | 1 3 7 | SAMA would reduce the SBO frequency. | #3 - Already implemented at Robinson | Robinson has 2 EDGs and one SBO diesel, and the use is proceduralized. | Reference 31 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|---|-----------------------|-------------------------|
| 91 | Provide an additional diesel generator. | 1 3 7 11 14 | SAMA would increase the reliability and availability of onsite emergency AC power sources. | #5 - Cost would be more than risk benefit | The cost of installing an additional diesel generator has been estimated at over \$20 million in Reference 19. This cost of implementation for this SAMA greatly exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 92 | Provide additional DC battery capacity. | 1 3 7 11 12 | SAMA would ensure longer battery capability during an SBO, reducing the frequency of long-term SBO sequences. | #5 - Cost would be more than risk benefit | The cost of implementation for this SAMA has been estimated to be \$1.88 million in Reference 19. This exceeds the maximum averted cost-risk (\$1,033,000) | Reference 19 | N/A |
| 93 | Use fuel cells instead of lead-acid batteries. | 11 | SAMA would extend DC power availability in an SBO. | #5 - Cost would be more than risk benefit | The cost of implementation for this SAMA has been estimated to be \$2 million in Reference 19. This exceeds the maximum averted cost-risk for (\$1,033,000) | Reference 19 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|--------------------------------------|--|-----------------------|-------------------------|
| 94 | Procedure to cross-tie high-pressure core spray diesel. | 1 | SAMA would improve core injection availability by providing a more reliable power supply for the high-pressure core spray pumps. | #3 - Already implemented at Robinson | Previous regulatory concerns with an automatic bus transfer for SI pump B make this undesirable. Note that one of the three SI pumps can be powered from either Emergency Bus E1 or E2, but this requires manual action. Only one pump is needed for accident mitigation | Reference 20 | N/A |
| 95 | Improve 4.16-kV bus cross-tie ability. | 1 14 | SAMA would improve AC power reliability. | #1 - N/A | See #94. The ability to crosstie non-ESF 4kV buses would result in little benefit since Robinson has only one transformer supplying offsite power. It is possible to backfeed and power the 4.16 kV buses. | Reference 20 | N/A |
| 96 | Incorporate an alternate battery charging capability. | 1 8 9 14 | SAMA would improve DC power reliability by either cross-tying the AC busses, or installing a portable diesel-driven battery charger. | #3 - Already implemented at Robinson | Plant modification M-940 removed tie cables between Station Battery A and B and installed a redundant battery charger for each train. The On-Site Emergency DC Power System consists of 2 redundant 100 percent capacity 125V DC safety trains, each with 2 charges. | Reference 47 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|--------------------------------------|--|-----------------------------|-------------------------|
| 97 | Increase/improve DC bus load shedding. | 1 8 14 | SAMA would extend battery life in an SBO event. | #3 - Already implemented at Robinson | This has been investigated and current load shed procedures are adequate. | Reference 25 | N/A |
| 98 | Replace existing batteries with more reliable ones. | 11 14 | SAMA would improve DC power reliability and thus increase available SBO recovery time. | #3 - Already implemented at Robinson | Reliable batteries are already installed. | Reference 23, Appendix A.12 | N/A |
| 99 | Mod for DC Bus A reliability. | 1 | SAMA would increase the reliability of AC power and injection capability. Loss of DC Bus A causes a loss of main condenser, prevents transfer from the main transformer to offsite power, and defeats one half of the low vessel pressure permissive for LPCI/CS injection valves. | #1 - N/A | Loss of a single DC bus does not prevent alignment of off-site power to the start-up transformer (E2 is already aligned to the offsite source) and the Reactor Safeguards Actuation System (plant logic) consists of 2 independent, redundant divisions. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|-----------------------------|-------------------------|
| 100 | Create AC power cross-tie capability with other unit. | 1 8 9 14 | SAMA would improve AC power reliability. | #5 - Cost would be more than risk benefit | Robinson is a 2 unit site, with an adjacent coal plant. In addition, combustion turbines exist at nearby Darlington. However, no equipment is installed that would allow a direct connection between the plants' emergency AC buses. Power can be provided through the switchyard, but these sources are not available by definition in a LOOP event. Installation of direct connections between the plants' AC buses is a major modification considered to be greater in scope than SAMA 123. Reference 17 estimates the cost of a dedicated RHR power supply to be \$1.2 million. This is considered to be a lower bound estimate for an inter-plant AC crosstie. The cost of this SAMA is greater than the RNP maximum averted cost-risk. | Reference 73 | N/A |
| 101 | Create a cross-tie for diesel fuel oil. | 1 | SAMA would increase diesel fuel oil supply and thus diesel generator, reliability. | #3 - Already implemented at Robinson | | Reference 23, Appendix A.11 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|-----------------------|-------------------------|
| 102 | Develop procedures to repair or replace failed 4-kV breakers. | 1 | SAMA would offer a recovery path from a failure of the breakers that perform transfer of 4.16-kV non-emergency busses from unit station service transformers, leading to loss of emergency AC power. | #3 - Already implemented at Robinson | Plant has maintenance procedures for 4 kv breakers. | PM-466,468, and 469. | N/A |
| 103 | Emphasize steps in recovery of offsite power after an SBO. | 1 14 | SAMA would reduce human error probability during offsite power recovery. | #3 - Already implemented at Robinson | Refer to procedures EPP-25 and OP-603. | EPP-25, OP-603 | N/A |
| 104 | Develop a severe weather conditions procedure. | 1 13 | For plants that do not already have one, this SAMA would reduce the CDF for external weather-related events. | #3 - Already implemented at Robinson | Refer to procedure OMM-021. | OMM-021 | N/A |
| 105 | Develop procedures for replenishing diesel fuel oil. | 1 | SAMA would allow for long-term diesel operation. | #3 - Already implemented at Robinson | | Reference 32 | N/A |
| 106 | Install gas turbine generator. | 1 14 | SAMA would improve onsite AC power reliability by providing a redundant and diverse emergency power system. | #5 - Cost would be more than risk benefit | The cost of installing a diverse, redundant, gas turbine generator is similar in scope to installing a new diesel generator. The cost of installing an additional diesel generator has been estimated at over \$20 million in Reference 19. This cost of implementation for this SAMA greatly exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|---|---|-----------------------|-------------------------|
| 107 | Create a backup source for diesel cooling. (Not from existing system) | 1 | This SAMA would provide a redundant and diverse source of cooling for the diesel generators, which would contribute to enhanced diesel reliability. | #5 - Cost would be more than risk benefit | A potential enhancement would be to make them air cooled such that the do not rely on any service water systems for cooling. The cost of implementation is estimated to be \$1.7 million per diesel. This SAMA exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 108 | Use fire protection system as a backup source for diesel cooling. | 1, 20 | This SAMA would provide a redundant and diverse source of cooling for the diesel generators, which would contribute to enhanced diesel reliability. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 107 | Reference 20 | N/A |
| 109 | Provide a connection to an alternate source of offsite power. | 1 | SAMA would reduce the probability of a loss of offsite power event. | #3 - Already implemented at Robinson | Refer to #95. OP-602 allows backfeeding as alternate source of off-site power. See also EPP-25. | OP-602 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|---|---|-----------------------|-------------------------|
| 110 | Bury offsite power lines. | 1 | SAMA could improve offsite power reliability, particularly during severe weather. | #5 - Cost would be more than risk benefit | While the actual cost of this SAMA will vary depending on site characteristics, the cost of burying offsite power lines has been estimated at a cost significantly greater than \$25 million for another US PWR. Implementing this SAMA at Robinson is considered to be within the same order of magnitude and exceeds the maximum averted cost-risk for the plant (\$1,033,000). | Reference 19 | N/A |
| 111 | Replace anchor bolts on diesel generator oil cooler. | 1 | Millstone Nuclear Power Station found a high seismic SBO risk due to failure of the diesel oil cooler anchor bolts. For plants with a similar problem, this would reduce seismic risk. Note that these were Fairbanks Morse EDGs. | #1 - N/A | The Robinson IPEEE included an assessment of the plant's ability to cope with seismic events. No changes were identified for the EDG oil coolers and are considered to be sufficient. | Reference 21 | N/A |
| 112 | Change undervoltage (UV), auxiliary feedwater actuation signal (AFAS) block and high pressurizer pressure actuation signals to 3-out-of-4, instead of 2-out-of-4 logic. | 1 | SAMA would reduce risk of 2/4 inverter failure. | #1 - N/A | Robinson does not have 4 inverters, nor do they have 4 train logic for AFW or pressurizer pressure. RNP has 2/3 logic for UV, keylock for AFW block, and 2/3 logic for high pressurizer pressure. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|--|--------------------------------------|-------------------------|
| 113 | Provide DC power to the 120/240-V vital AC system from the Class 1E station service battery system instead of its own battery. | 12 | SAMA would increase the reliability of the 120V AC Bus. | #3 - Already implemented at Robinson | Inverter "A" is powered from 125V DC PP A and inverter "B" is powered from 125V DC MCC "B" | Reference 23, Appendix A.11 and A.12 | N/A |
| 114 | Bypass Diesel Generator Trips | 14 16 | SAMA would allow D/Gs to operate for longer. | #3 - Already implemented at Robinson | Robinson utilizes a "Trip Defeat" function for trips except overspeed. See TS Bases 3.8.1 | TS Bases 3.8.1 | N/A |
| 115 | 2.i. 16 hour Station Blackout Injection | 17 | SAMA includes improved capability to cope with longer station blackout scenarios. | #2 - Similar item is addressed under other proposed SAMAs | Part of 128 | N/A | N/A |
| 116 | 9.a. Steam Driven Turbine Generator | 17 | This SAMA would provide a steam driven turbine generator, which uses reactor steam and exhausts to the suppression pool. If large enough, it could provide power to additional equipment. | #5 - Cost would be more than risk benefit | The cost of installing a steam driven turbine generator is greater in scope than installing a new diesel generator due to the interface with the plant's steam system. The cost of installing an additional diesel generator has been estimated at over \$20 million in Reference 19. This cost of implementation for this SAMA is expected to exceed even this estimate and is considerably greater than the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|---|-----------------------|-------------------------|
| 117 | 9.b. Alternate Pump Power Source | 17 | This SAMA would provide a small dedicated power source such as a dedicated diesel or gas turbine for the feedwater or condensate pumps, so that they do not rely on offsite power. | #2 - Similar item is addressed under other proposed SAMAs | Firewater pump provides low pressure injection without offsite power (#52). Additional or passive high pressure systems addressed in other SAMAs, as is motor driven FW pump. | Reference 20 | N/A |
| 118 | 9.d. Additional Diesel Generator | 17 | SAMA would reduce the SBO frequency. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 90, 91 | N/A | N/A |
| 119 | 9.e. Increased Electrical Divisions | 17 | SAMA would provide increased reliability of AC power system to reduce core damage and release frequencies. | #8 - ABWR design issue; not practical | This is a SAMA which was considered for ABWR design. It is not practical to backfit this modification into a plant which is already built and operating. | N/A | N/A |
| 120 | 9.f. Improved Uninterruptable Power Supplies | 17 | SAMA would provide increased reliability of power supplies supporting front-line equipment, thus reducing core damage and release frequencies. | #4 - No significant safety benefit | Uninterruptable power supplies are not modeled in the RNP PSA, so it is not possible to obtain a risk delta for this SAMA. The risk involved with these power supplies is judged to be small. | Reference 20 | N/A |
| 121 | 9.g. AC Bus Cross-Ties | 17 | SAMA would provide increased reliability of AC power system to reduce core damage and release frequencies. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 95 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|--|-----------------------|-------------------------|
| 122 | 9.h. Gas Turbine | 17 | SAMA would improve onsite AC power reliability by providing a redundant and diverse emergency power system. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 106 | N/A | N/A |
| 123 | 9.i. Dedicated RHR (bunkered) Power Supply | 17 | SAMA would provide RHR with more reliable AC power. | #2 - Similar item is addressed under other proposed SAMAs | This is estimated to cost more than \$1.2 million, which is greater than the maximum averted cost risk for Robinson (\$1,033,000). | Reference 17 | N/A |
| 124 | 10.a. Dedicated DC Power Supply | 17 | This SAMA addresses the use of a diverse DC power system such as an additional battery or fuel cell for the purpose of providing motive power to certain components (e.g., RCIC). | #5 - Cost would be more than risk benefit | The cost of implementation for this mod is estimated at \$3 million, which is greater than the maximum averted cost-risk for Robinson (\$1,033,000). | Reference 17 | N/A |
| 125 | 10.b. Additional Batteries/Divisions | 17 | This SAMA addresses the use of a diverse DC power system such as an additional battery or fuel cell for the purpose of providing motive power to certain components (e.g., RCIC). | #2 - Similar item is addressed under other proposed SAMAs | Part of 124 | N/A | N/A |
| 126 | 10.c. Fuel Cells | 17 | SAMA would extend DC power availability in an SBO. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 93 | N/A | N/A |
| 127 | 10.d. DC Cross-ties | 17 | This SAMA would improve DC power reliability. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 96 | N/A | N/A |
| 128 | 10.e. Extended Station Blackout Provisions | 17 | SAMA would provide reduction in SBO sequence frequencies. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 29, 90, 92, 93, 97, 98, 103, 105 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|--|--|--------------------------|--|---|--|-----------------------|-------------------------|
| 129 | Add an automatic bus transfer feature to allow the automatic transfer of the 120V vital AC bus from the on-line unit to the standby unit | 19 | Plants are typically sensitive to the loss of one or more 120V vital AC buses. Manual transfers to alternate power supplies could be enhanced to transfer automatically. | #1 - N/A | Robinson is not a multi-unit site; screened from further analysis. | Reference 20 | N/A |
| Improvements in Identifying and Mitigating Containment Bypass | | | | | | | |
| 130 | Install a redundant spray system to depressurize the primary system during a steam generator tube rupture (SGTR). | 1 | SAMA would enhance depressurization during a SGTR. | #3 - Already implemented at Robinson | Robinson currently has three methods of pressure reduction already, normal spray, PORVs, and Auxiliary spray (from charging pumps). See also EPP-19 if there is no pressure control. | Reference 20, EPP-19 | N/A |
| 131 | Improve SGTR coping abilities. | 1 4 11 | SAMA would improve instrumentation to detect SGTR, or additional system to scrub fission product releases. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 133, 134, 135, 136, 137 | N/A | N/A |
| 132 | Add other SGTR coping abilities. | 4 10 11 | SAMA would decrease the consequences of an SGTR. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 130 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|--|------------------------|-------------------------|
| 133 | Increase secondary side pressure capacity such that an SGTR would not cause the relief valves to lift. | 10 11 | SAMA would eliminate direct release pathway for SGTR sequences. | #5 - Cost would be more than risk benefit | Based on engineering judgement, increasing the secondary side pressure capacity is not feasible as it would require extensive upgrades to the secondary system. The cost of this modification would greatly exceed the maximum averted cost-risk for Robinson (\$1,033,000). | Engineering judgement. | N/A |
| 134 | Replace steam generators (SG) with a new design. | 1 | SAMA would lower the frequency of an SGTR. | #5 - Cost would be more than risk benefit | The cost of installing new steam generators is estimated to exceed \$100 million. This is far greater than the maximum averted cost risk for (\$1,033,000). | Reference 19 | N/A |
| 135 | Revise emergency operating procedures to direct that a faulted SG be isolated. | 1 | SAMA would reduce the consequences of an SGTR. | #3 - Already implemented at Robinson | SAM-5 provides guidance for isolating the faulted steam generator. | Reference 24 | N/A |
| 136 | Direct SG flooding after a SGTR, prior to core damage. | 10 | SAMA would provide for improved scrubbing of SGTR releases. | #3 - Already implemented at Robinson | SAM-5 provides guidance for mitigating the releases from the SG. Included in the strategy is restoring the SG water level. | Reference 24 | N/A |
| 137 | Implement a maintenance practice that inspects 100 percent of the tubes in a SG. | 11 | SAMA would reduce the potential for an SGTR. | #3 - Already implemented at Robinson | RNP currently inspects 100 percent of the tubes over an interval of 3 outages. | Reference 78 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|------------------------|-------------------------|
| 138 | Locate residual heat removal (RHR) inside of containment. | 10 | SAMA would prevent intersystem LOCA (ISLOCA) out the RHR pathway. | #5 - Cost would be more than risk benefit | For an existing plant, the cost of moving an entire system is judged to greatly exceed the maximum averted cost-risk (\$1,033,000). | Engineering judgement. | N/A |
| 139 | Install additional instrumentation for ISLOCAs. | 3 4 7 8 | SAMA would decrease ISLOCA frequency by installing pressure of leak monitoring instruments in between the first two pressure isolation valves on low-pressure inject lines, RHR suction lines, and HPSI lines. | #5 - Cost would be more than risk benefit | The cost of implementation for this SAMA has been estimated at \$2.3 million in Reference 19. This is greater than the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 140 | Increase frequency for valve leak testing. | 1 | SAMA could reduce ISLOCA frequency. | #6 - Retain | N/A | N/A | 3 |
| 141 | Improve operator training on ISLOCA coping. | 1 | SAMA would decrease ISLOCA effects. | #3 - Already implemented at Robinson | ISLOCA coping is covered in SACRM-1. | SACRM-1 | N/A |
| 142 | Install relief valves in the CC System. | 1 | SAMA would relieve pressure buildup from an RCP thermal barrier tube rupture, preventing an ISLOCA. | #3 - Already implemented at Robinson | CCW system currently includes relief valves to limit pressure. | Reference 33 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|-----------------------|-------------------------|
| 143 | Provide leak testing of valves in ISLOCA paths. | 1 | SAMA would help reduce ISLOCA frequency. At Kewaunee Nuclear Power Plant, four MOVs isolating RHR from the RCS were not leak tested. | #2 - Similar item is addressed under other proposed SAMAs | A similar configuration exists at RNP. The NRC is aware of the issue and has accepted the RNP IST program due to the impracticality of testing. Addition of test taps for these valves is considered to be qualitatively addressed by SAMA 139 and quantitatively bounded by SAMA 140 (Phase 2 SAMA 3). The averted cost-risk based on implementing SAMA 143 would be a fraction of this number and is clearly less than the cost required to modify the RHR piping, upgrade procedures, and train personnel on the equipment. This SAMA is screened from further review | N/A | N/A |
| 144 | Revise EOPs to improve ISLOCA identification. | 1 | SAMA would ensure LOCA outside containment could be identified as such. Salem Nuclear Power Plant had a scenario where an RHR ISLOCA could direct initial leakage back to the pressurizer relief tank, giving indication that the LOCA was inside containment. | #2 - Similar item is addressed under other proposed SAMAs | Refer to #141 | N/A | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|--------------------|---|-----------------------|-------------------------|
| 145 | Ensure all ISLOCA releases are scrubbed. | 1 | SAMA would scrub all ISLOCA releases. One example is to plug drains in the break area so that the break point would be covered with water. | #1 - N/A | <p>This SAMA is judged not to be practically applicable to an operating plant.</p> <ul style="list-style-type: none"> • Systems installed to flood break areas would be cost prohibitive. • Constructing reservoirs around piping with ISLOCA pathways would be cost prohibitive. • Plugging room drains may not be cost prohibitive, but the plant was designed with drains to prevent flooding areas containing required equipment. This may be more detrimental than beneficial. In addition, the flood rate may not be great enough to submerge the break point prior to release. <p>No practical means of reducing risk at an operating plant have been identified.</p> | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|-----------------------|-------------------------|
| 146 | Add redundant and diverse limit switches to each containment isolation valve. | 1 | SAMA could reduce the frequency of containment isolation failure and ISLOCAs through enhanced isolation valve position indication. | #4 - No significant safety benefit. | The failures addressed by this SAMA are not contributors to the CDF or LERF. The benefit gained by redundant and diverse limits switches would be in an operator recovery action. Given the failure of the primary equipment used for isolation valve indication, the operator would identify a mispositioned valve using the redundant indicators. This level of detail is not included in the model and would be dominated by other failure modes | Reference 20 | N/A |
| 147 | Early detection and mitigation of ISLOCA | 14 16 | SAMA would limit the effects of ISLOCA accidents by early detection and isolation | #2 - Similar item is addressed under other proposed SAMAs | Refer to #141 | N/A | N/A |
| 148 | 8.e. Improved MSIV Design | 17 | | #6 - Retain | N/A | N/A | 4 |
| 149 | Proceduralize use of pressurizer vent valves during steam generator tube rupture (SGTR) sequences | 19 | Some plants may have procedures to direct the use of pressurizer sprays to reduce RCS pressure after an SGTR. Use of the vent valves would provide a back-up method. | #3 - Already implemented at Robinson | SAM-2 provides guidance for RCS depressurization and specifically addresses the SGTR case. | Reference 24 | N/A |
| 150 | Implement a maintenance practice that inspects 100 percent of the tubes in an SG | 19 | This SAMA would reduce the potential for a tube rupture. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 137 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|---|--|--------------------------|---|---|---|-----------------------|-------------------------|
| 151 | Locate RHR inside of containment | 19 | This SAMA would prevent ISLOCA out the RHR pathway. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 138 | N/A | N/A |
| 152 | Install self-actuating containment isolation valves | 19 | For plants that do not have this, it would reduce the frequency of isolation failure. | #3 - Already implemented at Robinson | Plant currently has automatic isolation of containment. See UFSAR 6.4 and 7.3 | UFSAR 6.4 and 7.3 | N/A |
| Improvements in Reducing Internal Flooding Frequency | | | | | | | |
| 153 | Modify swing direction of doors separating turbine building basement from areas containing safeguards equipment. | 1 | SAMA would prevent flood propagation, for a plant where internal flooding from turbine building to safeguards areas is a concern. | #3 - Already implemented at Robinson | The Robinson IPE, Reference 20, analyzed the importance of internal floods to core damage accidents. As a result of that evaluation, the cost effective means of reducing flooding risk were identified. Additional modifications were judged not to be necessary | Reference 20 | N/A |
| 154 | Improve inspection of rubber expansion joints on main condenser. | 1 14 | SAMA would reduce the frequency of internal flooding, for a plant where internal flooding due to a failure of circulating water system expansion joints is a concern. | #3 - Already implemented at Robinson | The Robinson IPE, Reference 20, analyzed the importance of internal floods to core damage accidents. As a result of that evaluation, the cost effective means of reducing flooding risk were identified. Additional modifications were judged not to be necessary | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|--------------------------------------|---|----------------------------------|-------------------------|
| 155 | Implement internal flood prevention and mitigation enhancements. | 1 | This SAMA would reduce the consequences of internal flooding. | #3 - Already implemented at Robinson | The Robinson IPE, Reference 20, analyzed the importance of internal floods to core damage accidents. As a result of that evaluation, procedures were developed for coping with flooding scenarios. | References 20, 79, 80, 81 and 82 | N/A |
| 156 | Implement internal flooding improvements such as those implemented at Fort Calhoun. | 1 | This SAMA would reduce flooding risk by preventing or mitigating rupture in the RCP seal cooler of the component cooling system ISLOCA in a shutdown cooling line, an auxiliary feedwater (AFW) flood involving the need to remove a watertight door. | #3 - Already implemented at Robinson | The Robinson IPE, Reference 20, analyzed the importance of internal floods to core damage accidents. As a result of that evaluation, the cost effective means of reducing flooding risk were identified. Additional modifications were judged not to be necessary | Reference 20 | N/A |
| 157 | Shield electrical equipment from potential water spray | 14 | SAMA would decrease risk associated with seismically induced internal flooding | #3 - Already implemented at Robinson | The Robinson IPE, Reference 20, analyzed the importance of internal floods to core damage accidents. As a result of that evaluation, the cost effective means of reducing flooding risk were identified. Additional modifications were judged not to be necessary | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|--|---|--------------------------|---|--------------------------------------|---|----------------------------|-------------------------|
| 158 | 13.c. Reduction in Reactor Building Flooding | 17 | This SAMA reduces the Reactor Building Flood Scenarios contribution to core damage and release. | #3 - Already implemented at Robinson | The Robinson IPE, Reference 20, analyzed the importance of internal floods to core damage accidents. As a result of that evaluation, procedures were developed to mitigate internal floods. | Reference 20 | N/A |
| Improvements Related to Feedwater/Feed and Bleed Reliability/Availability | | | | | | | |
| 159 | Install a digital feedwater upgrade. | 1 | This SAMA would reduce the chance of a loss of main feedwater. | #6 - Retain | After plant trip AFW would be used. Robinson has 1 turbine driven and two motor driven Auxiliary Feedwater Pumps. | N/A | 5 |
| 160 | Perform surveillances on manual valves used for backup AFW pump suction. | 1 | This SAMA would improve success probability for providing alternative water supply to the AFW pumps. | #3 - Already implemented at Robinson | Valves that provide suction from SW are tested per OST-701-6. | OST-701-6 | N/A |
| 161 | Install manual isolation valves around AFW turbine-driven steam admission valves. | 1 | This SAMA would reduce the dual turbine-driven AFW pump maintenance unavailability. | #1 - N/A | Robinson has 1 turbine driven and two motor driven Auxiliary Feedwater Pumps. | Reference 23, Appendix A.5 | N/A |
| 162 | Install accumulators for turbine-driven AFW pump flow control valves (CVs). | 4 8 | This SAMA would provide control air accumulators for the turbine-driven AFW flow CVs, the motor-driven AFW pressure CVs and SG power-operated relief valves (PORVs). This would eliminate the need for local manual action to align nitrogen bottles for control air during a LOOP. | #3 - Already implemented at Robinson | CVs use hydraulic oil. AFW had flow limiting devices installed. Normal motive source for PORVs is Instrument Air. An accumulator is in series with alternate motive source provided by the instrument air system. | References 36 and 37 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|---|-----------------------|-------------------------|
| 163 | Install separate accumulators for the AFW cross-connect and block valves | 19 | This SAMA would enhance the operator's ability to operate the AFW cross-connect and block valves following loss of air support. | #3 - Already implemented at Robinson | The AFW system can be initiated and controlled automatically or manually. Loss of instrument air has no effect on the steam driven pump since it fails safe at a regulated pump speed of 9400 rpm. | Reference 36 and 37 | N/A |
| 164 | Install a new condensate storage tank (CST) | 19 | Either replace the existing tank with a larger one, or install a back-up tank. | #5 - Cost would be more than risk benefit | Reference 17 indicates that the cost of installing a new CST is \$1 million. This is considered to be a lower bound estimate and it is judged that the actual cost would exceed the maximum averted cost-risk for Robinson (\$1,033,000). | Reference 17 | N/A |
| 165 | Provide cooling of the steam-driven AFW pump in an SBO event | 19 | This SAMA would improve success probability in an SBO by: (1) using the FP system to cool the pump, or (2) making the pump self cooled. | #3 - Already implemented at Robinson | Pump is self cooled | Reference 20 | N/A |
| 166 | Proceduralize local manual operation of AFW when control power is lost. | 19 | This SAMA would lengthen AFW availability in an SBO. Also provides a success path should AFW control power be lost in non-SBO sequences. | #3 - Already implemented at Robinson | This is already done for SDAFWP. | AP-402 | N/A |
| 167 | Provide portable generators to be hooked into the turbine driven AFW, after battery depletion. | 19 | This SAMA would extend AFW availability in an SBO (assuming the turbine driven AFW requires DC power) | #1 - N/A | DC power is not needed for SDAFWP. Pump can be started manually; see FRP H.1. | FRP H.1 | N/A |
| 168 | Add a motor train of AFW to the Steam trains | 19 | For PWRs that do not have any motor trains of AFW, this would increase reliability in non-SBO sequences. | #3 - Already implemented at Robinson | Robinson has 1 turbine driven and two motor driven Auxiliary Feedwater Pumps. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|------------------------|-------------------------|
| 169 | Create ability for emergency connections of existing or alternate water sources to feedwater/condensate | 19 | This SAMA would be a back-up water supply for the feedwater/condensate systems. | #3 - Already implemented at Robinson | Service Water can be connected to Auxiliary Feedwater. | Reference 20 | N/A |
| 170 | Use FP system as a back-up for SG inventory | 19 | This SAMA would create a back-up to main and AFW for SG water supply. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 169 | N/A | N/A |
| 171 | Procure a portable diesel pump for isolation condenser make-up | 19 | This SAMA would provide a back-up to the city water supply and diesel FP system pump for isolation condenser make-up. | #1 - N/A | Robinson does not have an Isolation Condenser system. | Reference 20 | N/A |
| 172 | Install an independent diesel generator for the CST make-up pumps | 19 | This SAMA would allow continued inventory make-up to the CST during an SBO. | #3 - Already implemented at Robinson | No auto-refill during SBO, but the diesel fire pump is available as a long-term supply to the AFW suction header in an SBO. | Reference 20 | N/A |
| 173 | Change failure position of condenser make-up valve | 19 | This SAMA would allow greater inventory for the AFW pumps by preventing CST flow diversion to the condenser if the condenser make-up valve fails open on loss of air or power. | #3 - Already implemented at Robinson | CST is required to maintain sufficient inventory for 2 hours of AFW operation. Then, Service Water provides backup to AFW and is virtually an unlimited supply. | Reference 46 | N/A |
| 174 | Create passive secondary side coolers. | 19 | This SAMA would reduce CDF from the loss of Feedwater by providing a passive heat removal loop with a condenser and heat sink. | #5 - Cost would be more than risk benefit | This SAMA would require major modifications to be made to the plant and the cost would far exceed the maximum averted cost-risk (\$1,033,000). | Engineering judgement. | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|---|--|--------------------------|---|---|---|---------------------------------|-------------------------|
| 175 | Replace current PORVs with larger ones such that only one is required for successful feed and bleed. | 19 | This SAMA would reduce the dependencies required for successful feed and bleed. | #6 - Retain | There are 2 PORVs and 3 SRVs for RCS pressure control. Section A.8.1.4 of the PSA system notebook requires 2 PORVs for successful feed and bleed per FRP-H.1. | Reference 23 (A.8) | 6 |
| 176 | Install motor-driven feedwater pump. | 1 12 | SAMA would increase the availability of injection subsequent to MSIV closure. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 168 | N/A | N/A |
| 177 | Use Main FW pumps for a Loss of Heat Sink Event | 20 | This SAMA involves a procedural change that would allow for a faster response to loss of the secondary heat sink. Use of only the feedwater booster pumps for injection to the SGs requires depressurization to about 350 psig; before the time this pressure is reached, conditions would be met for initiating feed and bleed. Using the available turbine driven feedwater pumps to inject water into the SGs at a high pressure rather than using the feedwater booster alone allows injection without the time consuming depressurization. | #3 - Already implemented at Robinson | The "Response to Loss of Secondary Heat Sink" FRP #1 has been updated to direct use of the turbine driven feedwater pumps as the primary SG injection source. | Reference 69 | N/A |
| Improvements in Core Cooling Systems | | | | | | | |
| 178 | Provide the capability for diesel driven, low pressure vessel make-up | 19 | This SAMA would provide an extra water source in sequences in which the reactor is depressurized and all other injection is unavailable (e.g., FP system) | #5 - Cost would be more than risk benefit | Based on engineering judgement and similarities to SAMA 179, the installation of a new, diesel driven, low pressure injection system is judged to greatly exceed the maximum averted cost-risk (\$1,033,000). | Engineering judgement, SAMA 179 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|--|-----------------------|-------------------------|
| 179 | Provide an additional HPSI pump with an independent diesel | 19 | This SAMA would reduce the frequency of core melt from small LOCA and SBO sequences | #5 - Cost would be more than risk benefit | The cost of implementation for this SAMA has been estimated to be between \$5 and \$10 million (Reference 19). This greatly exceeds the maximum averted cost-risk (\$1,033,000). | Reference 19 | N/A |
| 180 | Install an independent AC HPSI system | 19 | This SAMA would allow make-up and feed and bleed capabilities during an SBO. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 179 | N/A | N/A |
| 181 | Create the ability to manually align ECCS recirculation | 19 | This SAMA would provide a back-up should automatic or remote operation fail. | #3 - Already implemented at Robinson | Actions for alignment to recirculation are currently manual controls. | Reference 28 | N/A |
| 182 | Implement an RWT make-up procedure | 19 | This SAMA would decrease CDF from ISLOCA scenarios, some smaller break LOCA scenarios, and SGTR. | #6 - Retain | RNP has a RWST fill system at about 100 gpm. | N/A | 7 |
| 183 | Stop low pressure safety injection pumps earlier in medium or large LOCAs. | 19 | This SAMA would provide more time to perform recirculation swap over. | #3 - Already implemented at Robinson | Refer to EPP-9 | EPP-9 | N/A |
| 184 | Emphasize timely swap over in operator training. | 19 | This SAMA would reduce human error probability of recirculation failure. | #3 - Already implemented at Robinson | Currently addressed in training. | Reference 40 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|--|---|-----------------------------|-------------------------|
| 185 | Upgrade Chemical and Volume Control System to mitigate small LOCAs. | 19 | For a plant like the AP600 where the Chemical and Volume Control System cannot mitigate a Small LOCA, an upgrade would decrease the Small LOCA CDF contribution. | #5 - Cost would be more than risk benefit. | Upgrading the CVCS to be capable of mitigating a small LOCA would require replacement of the CVCS pumps, piping, and power supply support. This is equivalent to installing a new HP injection system. Reference 17 estimates the cost of a new, passive HP system at \$1.7 m. This is judged to be a lower bound for an active high-pressure system. | Reference 17. | N/A |
| 186 | Install an active HPSI system. | 19 | For a plant like the AP600 where an active HPSI system does not exist, this SAMA would add redundancy in HPSI. | #3 - Already implemented at Robinson | The charging pumps provide high pressure injection for Robinson. | Reference 22, Appendix A.18 | N/A |
| 187 | Change "in-containment" RWT suction from 4 check valves to 2 check and 2 air operated valves. | 19 | This SAMA would remove common mode failure of all four injection paths. | #1 - N/A | Robinson does not have a pathway equivalent for which such a modification would provide a benefit. | Reference 20 | N/A |
| 188 | Replace 2 of the 4 safety injection (SI) pumps with diesel-powered pumps. | 19 | This SAMA would reduce the SI system common cause failure probability. This SAMA was intended for the System 80+, which has four trains of SI. | #1 - N/A | This is a system 80+ specific issue. Robinson does not have 4 trains of SI. | Reference 20 | N/A |
| 189 | Align low pressure core injection or core spray to the CST on loss of suppression pool cooling. | 19 | This SAMA would help to ensure low pressure ECCS can be maintained in loss of suppression pool cooling scenarios. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 190 | Raise high pressure core injection/reactor core isolation cooling backpressure trip setpoints | 19 | This SAMA would ensure high pressure core injection/reactor core isolation cooling availability when high suppression pool temperatures exist. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|--|------------------------|-------------------------|
| 191 | Improve the reliability of the automatic depressurization system. | 19 | This SAMA would reduce the frequency of high pressure core damage sequences. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 192 | Disallow automatic vessel depressurization in non-ATWS scenarios | 19 | This SAMA would improve operator control of the plant. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 193 | Create automatic swap over to recirculation on RWT depletion | 19 | This SAMA would reduce the human error contribution from recirculation failure. | #6 - Retain | N/A | Reference 20 | 8 |
| 194 | Proceduralize intermittent operation of HPCI. | 1 | SAMA would allow for extended duration of HPCI availability. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 195 | Increase available net positive suction head (NPSH) for injection pumps. | 1 | SAMA increases the probability that these pumps will be available to inject coolant into the vessel by increasing the available NPSH for the injection pumps. | #5 - Cost would be more than risk benefit | Requires major plant modifications such as new RHR pumps, moving the RHR pumps, a new sump design, or a larger RWST (only applicable for injection phase). The cost of these changes would exceed the maximum averted cost-risk (\$1,033,000). | Engineering judgement. | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|--------------------------------------|---|-----------------------|-------------------------|
| 196 | Modify Reactor Water Cleanup (RWCU) for use as a decay heat removal system and proceduralize use. | 1 | SAMA would provide an additional source of decay heat removal. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. An "equivalent" system, the Chemical and Volume Control System, is already used in a heat removal process at Robinson. Any modifications to further enhance the DHR ability of the system would likely cost more than the maximum averted cost-risk for the plant. Screened from further analysis. | Reference 20 | N/A |
| 197 | CRD Injection | 14 16 | SAMA would supply an additional method of level restoration by using a non-safety system. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 198 | Condensate Pumps for Injection | 14 16 | SAMA to provide an additional option for coolant injection when other systems are unavailable or inadequate | #3 - Already implemented at Robinson | Robinson allows injection to the SGs with the condensate pumps when depressurized to about 600 psi. | References 20 and 69 | N/A |
| 199 | Align EDG to CRD for Injection | 14 16 | SAMA to provide power to an additional injection source during loss of power events | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|---|--|-----------------------|-------------------------|
| 200 | Re-open MSIVs | 14 16 | SAMA to regain the main condenser as a heat sink by re-opening the MSIVs. | #1 - N/A | This is a long-term issue and will have no impact on LERF. PSA model credits use of steam dumps for transients. SG PORVs or safeties provide a reliable method to reject heat from the secondary side. | Reference 20 | N/A |
| 201 | Bypass RCIC Turbine Exhaust Pressure Trip | 14 16 | SAMA would allow RCIC to operate longer. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 202 | 2.a. Passive High Pressure System | 17 | SAMA will improve prevention of core melt sequences by providing additional high pressure capability to remove decay heat through an isolation condenser type system | #5 - Cost would be more than risk benefit | The cost of this enhancement has been estimated to be \$1.7 million in Reference 17. This is greater than the maximum averted cost-risk (\$1,033,000). | Reference 17 | N/A |
| 203 | 2.c. Suppression Pool Jockey Pump | 17 | SAMA will improve prevention of core melt sequences by providing a small makeup pump to provide low pressure decay heat removal from the RPV using the suppression pool as a source of water. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 204 | 2.d. Improved High Pressure Systems | 17 | SAMA will improve prevention of core melt sequences by improving reliability of high pressure capability to remove decay heat. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 179, 180, 186, 202, 205 | N/A | N/A |
| 205 | 2.e. Additional Active High Pressure System | 17 | SAMA will improve reliability of high pressure decay heat removal by adding an additional system. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 179, 180, 186, 202 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|---|-----------------------|-------------------------|
| 206 | 2.f. Improved Low Pressure System (Firepump) | 17 | SAMA would provide fire protection system pump(s) for use in low pressure scenarios. | #4 - No significant safety benefit | This is directed at BWRs. Injection of non-borated lake water into the PWR primary system would inject positive reactivity. | N/A | N/A |
| 207 | 4.b. CUW Decay Heat Removal | 17 | This SAMA provides a means for Alternate Decay Heat Removal. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 196. The CUW system in ABWR is equivalent to the RWCU system. | N/A | N/A |
| 208 | 4.c. High Flow Suppression Pool Cooling | 17 | SAMA would improve suppression pool cooling. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 209 | 8.c. Diverse Injection System | 17 | SAMA will improve prevention of core melt sequences by providing additional injection capabilities. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 178, 179, 180, 186, 202, 205, 206 | N/A | N/A |
| 210 | Alternate Charging Pump Cooling | 20 | This SAMA will improve the high pressure core flooding capabilities by providing the SI pumps with alternate gear and oil cooling sources. Given a total loss of Chilled Water, abnormal operating procedures would direct alignment of preferred Demineralized Water or the Fire System to the Chilled Water System to provide cooling to the SI pumps' gear and oil box (and the other normal loads). | #3 - Already implemented at Robinson | An abnormal operating procedure (AOP-022) has been implemented at Robinson to direct alignment of alternate cooling to the SI pumps on loss of the normal supply. | References 20 and 80 | N/A |
| 211 | Not Used. | | | | | | |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|--|---|--------------------------|---|--------------------------------------|---|-------------------------------|-------------------------|
| Instrument Air/Gas Improvements | | | | | | | |
| 212 | Modify EOPs for ability to align diesel power to more air compressors. | 19 | For plants that do not have diesel power to all normal and back-up air compressors, this change would increase the reliability of IA after a LOOP. | #3 - Already implemented at Robinson | Ability exists to feed A and B air compressors from ESF busses. | Reference 34 | N/A |
| 213 | Replace old air compressors with more reliable ones | 19 | This SAMA would improve reliability and increase availability of the IA compressors. | #3 - Already implemented at Robinson | C air compressor has been replaced with D, and primary AC has been replaced. | Plant modifications | N/A |
| 214 | Install nitrogen bottles as a back-up gas supply for safety relief valves. | 19 | This SAMA would extend operation of safety relief valves during an SBO and loss of air events (BWRs). | #3 - Already implemented at Robinson | Pressurizer PORVs are on a hard-piped nitrogen system with gas bottle backup, capable of air backup. Secondary PORVs are air with nitrogen backup. | Reference 36 and Reference 37 | N/A |
| 215 | Allow cross connection of uninterruptable compressed air supply to opposite unit. | 12 13 | SAMA would increase the ability to vent containment using the hardened vent. | #1 - N/A | Robinson is not a multi-unit site; screened from further analysis. | Reference 20 | N/A |
| 216 | Not Used | | | | | | |
| ATWS Mitigation | | | | | | | |
| 217 | Install MG set trip breakers in control room | 19 | This SAMA would provide trip breakers for the MG sets in the control room. In some plants, MG set breaker trip requires action to be taken outside of the control room. Adding control capability to the control room would reduce the trip failure probability in sequences where immediate action is required (e.g., ATWS). | #4 - No significant safety benefit | Providing a switch in the Main Control Room to allow timely operation of the MG Set breakers during an ATWS would improve the reliability of a successful manual reactor trip. However, the accident sequences requiring this action are below the truncation limit of the model and are not included in the cutsets. No measurable benefit would be gained from this change. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|---|--|-----------------------|-------------------------|
| 218 | Add capability to remove power from the bus powering the control rods | 19 | This SAMA would decrease the time to insert the control rods if the reactor trip breakers fail (during a loss of FW ATWS which has a rapid pressure excursion) | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 217 | N/A | N/A |
| 219 | Create cross-connect ability for standby liquid control trains | 19 | This SAMA would improve reliability for boron injection during an ATWS event. | #1 - N/A | This is a BWR issue; PWRs have diverse means of injecting borated water into the RCS during an ATWS. | Reference 20 | N/A |
| 220 | Create an alternate boron injection capability (back-up to standby liquid control) | 19 | This SAMA would improve reliability for boron injection during an ATWS event. | #1 - N/A | This is a BWR issue; PWRs have diverse means of injecting borated water into the RCS during an ATWS. | Reference 20 | N/A |
| 221 | Remove or allow override of low pressure core injection during an ATWS | 19 | On failure on high pressure core injection and condensate, some plants direct reactor depressurization followed by 5 minutes of low pressure core injection. This SAMA would allow control of low pressure core injection immediately. | #1 - N/A | This is a BWR issue. PWRs do not implement the same logic for governing low pressure injection that is used in BWRs. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|--------------------------------------|--|-----------------------|-------------------------|
| 222 | Install a system of relief valves that prevents any equipment damage from a pressure spike during an ATWS | 19 | This SAMA would improve equipment availability after an ATWS. | #3 - Already implemented at Robinson | Robinson meets the requirements of 10CFR50.62 by use of AMSAC (ATWS Mitigation System Actuation Circuitry) as described in UFSAR Section 7.8. This is considered to address the potential for overpressurization by providing a diverse, automatic system to shut down the reactor and initiate Emergency Feedwater Flow to the SGs given ATWS conditions. | Reference 38 | N/A |
| 223 | Create a boron injection system to back up the mechanical control rods. | 19 | This SAMA would provide a redundant means to shut down the reactor. | #3 - Already implemented at Robinson | Robinson already has the capability for injection from the RWST and the boric acid tanks. | Reference 20 | N/A |
| 224 | Provide an additional instrument system for ATWS mitigation (e.g., ATWS mitigation scram actuation circuitry). | 19 | This SAMA would improve instrument and control redundancy and reduce the ATWS frequency. | #3 - Already implemented at Robinson | Refer to SAMA 222 | N/A | N/A |
| 225 | Increase the safety relief valve (SRV) reseal reliability. | 1 | SAMA addresses the risk associated with dilution of boron caused by the failure of the SRVs to reseal after standby liquid control (SLC) injection. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 226 | Use control rod drive (CRD) for alternate boron injection. | 1 14 | SAMA provides an additional system to address ATWS with SLC failure or unavailability. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|---------------------------|---|--------------------------|--|---|--|-----------------------|-------------------------|
| 227 | Bypass MSIV isolation in Turbine Trip ATWS scenarios | 14 | SAMA will afford operators more time to perform actions. The discharge of a substantial fraction of steam to the main condenser (i.e., as opposed to into the primary containment) affords the operator more time to perform actions (e.g., SLC injection, lower water level, depressurize RPV) than if the main condenser was unavailable, resulting in lower human error probabilities | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 228 | Enhance operator actions during ATWS | 14 | SAMA will reduce human error probabilities during ATWS | #3 - Already implemented at Robinson | Extensive training is already performed. | Reference 40 | N/A |
| 229 | Guard against SLC dilution | 14 16 | SAMA to control vessel injection to prevent boron loss or dilution following SLC injection. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |
| 230 | 11.a. ATWS Sized Vent | 17 | This SAMA would be provide the ability to remove reactor heat from ATWS events. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 39 | N/A | N/A |
| 231 | 11.b. Improved ATWS Capability | 17 | This SAMA includes items which reduce the contribution of ATWS to core damage and release frequencies. | #2 - Similar item is addressed under other proposed SAMAs | Addressed by SAMAs 222, 223, 224 | N/A | N/A |
| Other Improvements | | | | | | | |
| 232 | Provide capability for remote operation of secondary side relief valves in an SBO | 19 | Manual operation of these valves is required in an SBO scenario. High area temperatures may be encountered in this case (no ventilation to main steam areas), and remote operation could improve success probability. | #3 - Already implemented at Robinson | Valves are located outside with their controls located at a distance. | Reference 25 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------------|---|--------------------------------|--|---|--|-------------------------------------|-------------------------------|
| 233 | Create/enhance RCS depressurization ability | 19 | With either a new depressurization system, or with existing PORVs, head vents, and secondary side valve, RCS depressurization would allow earlier low pressure ECCS injection. Even if core damage occurs, low RCS pressure would alleviate some concerns about high pressure melt ejection. | #5 - Cost would be more than risk benefit | Reference 19 estimates the cost of this SAMA to range between \$500,000 and \$4.6 million. For Robinson, more effective depressurization capabilities would require significant hardware changes and/or additions on top of the analysis that would be required to implement the change. The cost estimate for the modification is considered to be on the high end of the range provided in Reference 19. The cost of implementation for this SAMA is judged to greatly exceed the maximum averted cost-risk (\$1,033,000). | Reference 19, engineering judgement | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|--|--------------------------------------|--|-------------------------------|-------------------------|
| 234 | Make procedural changes only for the RCS depressurization option | 19 | This SAMA would reduce RCS pressure without the cost of a new system | #3 - Already implemented at Robinson | RCS depressurization has been enhanced at Robinson through the implementation of procedural revisions (in the EOP for "Response to Loss of Secondary heat Sink") that move critical depressurization steps so that they will be performed earlier in the accident. These steps direct the operators to re-energize any pressurizer PORV block valves that were closed and racked-out to isolate a leaking PORV. This change will allow the operators more time to prepare for feed and bleed before total loss of the secondary heat sink. | Reference 39 | N/A |
| 235 | Defeat 100 percent load rejection capability. | 19 | This SAMA would eliminate the possibility of a stuck open PORV after a LOOP, since PORV opening would not be needed. | #1 - N/A | The PORVs are included on the pressurizer, in part, to prevent overpressurization. It is judged that the defeating this function would be more detrimental than beneficial. RNP does not currently have 100 percent load rejection. | Reference 36 and Reference 38 | N/A |
| 236 | Change control rod drive flow CV failure position | 19 | Change failure position to the "fail-safest" position. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | Reference 20 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|---|--|-----------------------|-------------------------|
| 237 | Install secondary side guard pipes up to the MSIVs | 19 | This SAMA would prevent secondary side depressurization should a steam line break occur upstream of the main steam isolation valves. This SAMA would also guard against or prevent consequential multiple SGTR following a Main Steam Line Break event. | #5 - Cost would be more than risk benefit | The RNP PSA concluded that the frequency of steam line breaks upstream of the MSIVs was sufficiently small, when compared to other faults, to be excluded from consideration. Multiple SGTRs are not analyzed in the RNP PSA. | Reference 52 | N/A |
| 238 | Install digital large break LOCA protection | 19 | Upgrade plant instrumentation and logic to improve the capability to identify symptoms/precursors of a large break LOCA (leak before break). | #3 - Already implemented at Robinson | Existence of leakage from RCS to the containment is detected by several methods outlined in UFSAR. | Reference 43 | N/A |
| 239 | Increase seismic capacity of the plant to a high confidence, low pressure failure of twice the Safe Shutdown Earthquake. | 19 | This SAMA would reduce seismically - induced CDF. | #9 - IPEEE | Seismic issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. This SAMA was considered in the System 80+ original design submittal and is not applicable to an existing plant. | Reference 21 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|--|--------------------------|---|--------------------|---|-----------------------|-------------------------|
| 240 | Enhance the reliability of the demineralized water (DW) make-up system through the addition of diesel-backed power to one or both of the DW make-up pumps. | 19 | Inventory loss due to normal leakage can result in the failure of the CC and the SRW systems. Loss of CC could challenge the RCP seals. Loss of SRW results in the loss of three EDGs and the containment air coolers (CACs). | #1 - N/A | Loss of CCW doesn't result in RCP seal challenge for RNP. Note: DW and SW are not connected. Normal leakage from CCW is low and makeup infrequently required. Also, makeup to CCW is from Primary Water system; DW is the alternate. Control is local manual. This SAMA would have limited benefit. | Reference 23 (A.10) | N/A |
| 241 | Increase the reliability of safety relief valves by adding signals to open them automatically. | 12 | SAMA reduces the probability of a certain type of medium break LOCA. Hatch evaluated medium LOCA initiated by an MSIV closure transient with a failure of SRVs to open. Reducing the likelihood of the failure for SRVs to open, subsequently reduces the occurrence of this medium LOCA. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | N/A | N/A |
| 242 | Reduce DC dependency between high-pressure injection system and ADS. | 1 | SAMA would ensure containment depressurization and high-pressure injection upon a DC failure. | #1 - N/A | This is a BWR issue not applicable to the Robinson design. Screened from further analysis. | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|--|-----------------------|-------------------------|
| 243 | Increase seismic ruggedness of plant components. | 11 13 14 | SAMA would increase the availability of necessary plant equipment during and after seismic events. | #9 - IPEEE | Seismic issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. This SAMA was considered in the System 80+ original design submittal and is not applicable to an existing plant. | Reference 21 | N/A |
| 244 | Enhance RPV depressurization capability | 14 15 | SAMA would decrease the likelihood of core damage in loss of high pressure coolant injection scenarios | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 233 | N/A | N/A |
| 245 | Enhance RPV depressurization procedures | 14 15 | SAMA would decrease the likelihood of core damage in loss of high pressure coolant injection scenarios | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 234 | N/A | N/A |
| 246 | Replace mercury switches on fire protection systems | 14 | SAMA would decrease the probability of spurious fire suppression system actuation given a seismic event. | #9 - IPEEE | Seismic issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. | Reference 21 | N/A |
| 247 | Provide additional restraints for CO ₂ tanks | 14 | SAMA would increase availability of fire protection given a seismic event. | #9 - IPEEE | Seismic issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. | Reference 21 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|--------------------|--|-----------------------|-------------------------|
| 248 | Enhance control of transient combustibles | 14 | SAMA would minimize risk associated with important fire areas. | #9 - IPEEE | Fire issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. | Reference 21 | N/A |
| 249 | Enhance fire brigade awareness | 14 | SAMA would minimize risk associated with important fire areas. | #9 - IPEEE | Fire issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. | Reference 21 | N/A |
| 250 | Upgrade fire compartment barriers | 14 | SAMA would minimize risk associated with important fire areas. | #9 - IPEEE | Fire issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. | Reference 21 | N/A |
| 251 | Enhance procedures to allow specific operator actions | 14 | SAMA would minimize risk associated with important fire areas. | #9 - IPEEE | Fire issues were examined in the Robinson IPEEE and the cost-effective means of reducing plant risk were implemented as part of the program. | Reference 21 | N/A |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|---|--------------------------------------|--|-----------------------|-------------------------|
| 252 | Develop procedures for transportation and nearby facility accidents | 14 | SAMA would minimize risk associated with transportation and nearby facility accidents. | #4 - No significant safety benefit | Special event procedures may be pursued, but the contribution from these events is considered to be low and not risk significant. The IPEEE addressed these types of accidents and generally concluded that they did not impact the CDF. | Reference 21 | N/A |
| 253 | Enhance procedures to mitigate Large LOCA | 14 | SAMA would minimize risk associated with Large LOCA | #3 - Already implemented at Robinson | EPP-9 currently addresses this. | EPP-9 | N/A |
| 254 | 1.b. Computer Aided Instrumentation | 17, 20 | SAMA will improve prevention of core melt sequences by making operator actions more reliable. | #3 - Already implemented at Robinson | SPDS provides graphic control room indication of critical system operability based on a variety of digital and analog inputs. This system is integrated with the plant computer and is used to provide operators with plant data in an easy to use format. | Reference 71 | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|-------------------------------------|-------------------------|
| 255 | 1.c/d. Improved Maintenance Procedures/Manuals | 17 | SAMA will improve prevention of core melt sequences by increasing reliability of important equipment | #3 - Already implemented at Robinson | The maintenance rule has been implemented in the industry. Root cause analysis is required as part of this program and will result in procedure enhancements to improve equipment reliability where they are necessary and where they will be effective in reducing maintenance errors. | Engineering judgement, 10 CFR 50.65 | N/A |
| 256 | 1.e. Improved Accident Management Instrumentation | 17 | SAMA will improve prevention of core melt sequences by making operator actions more reliable. | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 254 | N/A | N/A |
| 257 | 1.f. Remote Shutdown Station | 17 | | #3 - Already implemented at Robinson | Robinson has procedures for remote shutdown and remote shutdown stations. | Reference 44 and 45 | N/A |
| 258 | 1.g. Security System | 17, 20 | Improvements in the site's security system would decrease the potential for successful sabotage. | #1 - N/A to SAMA evaluation | Sabotage is not included in the PSA model. | N/A | N/A |
| 259 | 2.b. Improved Depressurization | 17 | SAMA will improve depressurization system to allow more reliable access to low pressure systems. | #2 - Similar item is addressed under other proposed SAMAs | Addressed in SAMAs 237, 240 and 241 | N/A | N/A |
| 260 | 2.h. Safety Related Condensate Storage Tank | 17 | SAMA will improve availability of CST following a Seismic event | #2 - Similar item is addressed under other proposed SAMAs | See SAMA 164 | N/A | N/A |

**TABLE F-8
PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|------------------------|---|--------------------------|--|---|---|-------------------------------------|-------------------------|
| 261 | 4.d. Passive Overpressure Relief | 17 | | #3 - Already implemented at Robinson | Safety valves are installed. | Reference 23 | N/A |
| 262 | 8.b. Improved Operating Response | 17 | | #3 - Already implemented at Robinson | The development of enhanced procedures combined with simulator training at Robinson is judged to address this issue. | Engineering judgement. | N/A |
| 263 | 8.d. Operation Experience Feedback | 17 | | #3 - Already implemented at Robinson | The Maintenance Rule requires tracking component performance. This issue is judged to be addressed by the Maintenance Rule. | Engineering judgement, 10 CFR 50.65 | N/A |
| 264 | 8.e. Improved SRV Design | 17 | This SAMA would improve SRV reliability, thus increasing the likelihood that sequences could be mitigated using low pressure heat removal. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 221, 237 | N/A | N/A |
| 265 | 12.a. Increased Seismic Margins | 17 | This SAMA would reduce the risk of core damage and release during seismic events. | #2 - Similar item is addressed under other proposed SAMAs | See SAMAs 111, 239 | N/A | N/A |
| 266 | 13.b. System Simplification | 17 | This SAMA is intended to address system simplification by the elimination of unnecessary interlocks, automatic initiation of manual actions or redundancy as a means to reduce overall plant risk. | #2 - Similar item is addressed under other proposed SAMAs | Addressed by SAMAs 13, 107, 113, 146, 194, 237, 238 | N/A | N/A |
| 267 | Train operations crew for response to inadvertent actuation signals | 19 | This SAMA would improve chances of a successful response to the loss of two 120V AC buses, which may cause inadvertent signal generation. | #6 - Retain | N/A | N/A | 9 |

**TABLE F-8
 PHASE I SAMA (Cont'd)**

| Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Screening Criteria | Disposition | Disposition Reference | Phase II SAMA ID number |
|---------------------------------------|--|---|--|-------------------------------|--|----------------------------------|--|
| 268 | Install tornado protection on gas turbine generators | 19 | This SAMA would improve onsite AC power reliability. | #9 - IPEEE | The Robinson IPEEE addressed the potential impact caused by tornadoes and high winds. The conclusion was that the plant could withstand the effects of the design tornado without endangering the health and safety of the public. | Reference 21 | N/A |

**TABLE F-9
 PHASE II SAMA**

| Phase II SAMA ID number | Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Potential Cost | Comment | Phase 2 Disposition |
|-------------------------|------------------------|--|--------------------------|--|----------------|---|--|
| 1 | 16 | Prevent centrifugal charging pump flow diversion from the relief valves. | 1 | SAMA modification would reduce the frequency of the loss of RCP seal cooling if relief valve opening causes a flow diversion large enough to prevent RCP seal injection. | Not Required | While the flow diversion through a relief valve failure mode is not directly modeled in the RNP PSA, it is considered to be subsumed by the event for common cause failure of charging pump seal injection (JCCFICVABC). The maximum possible risk reduction for this SAMA was obtained by setting JCCFICVABC to zero. This action had no impact on the calculated CDF or on the LERF cutsets. Therefore, this SAMA has no impact on calculated risk. | Not cost beneficial See Section F.6.1 |

**TABLE F-9
 PHASE II SAMA (Cont'd)**

| Phase II SAMA ID number | Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Potential Cost | Comment | Phase 2 Disposition |
|-------------------------|------------------------|---|--------------------------|--|----------------|---|--|
| 2 | 22 | Improved ability to cool the residual heat removal heat exchangers. | 1 | SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the fire protection system or by installing a component cooling water cross-tie. | Not Required | The failure to supply cooling to the RHR heat exchangers is dominated by the operator action for CCW alignment. Failure of the operator to align one cooling source greatly limits the probability of successfully performing what is essentially the same action using another source of water (i.e., the level of dependence between the actions is defined as "high" or "complete"). Thus, modifications that would allow a physically independent system, such as Fire Water, to be aligned for RHR heat exchanger cooling would provide minimal benefit. The averted cost-risk for this SAMA is negligible and this candidate is screened from further review. | Not Cost Beneficial See Section F.6.2 |

**TABLE F-9
 PHASE II SAMA (Cont'd)**

| Phase II SAMA ID number | Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Potential Cost | Comment | Phase 2 Disposition |
|--------------------------------|-------------------------------|--|---------------------------------|--|-----------------------|---|--|
| 3 | 140 | Increase frequency for valve leak testing. | 1 | SAMA could reduce ISLOCA frequency. | \$50,000 | To calculate the maximum possible impact of this SAMA, initiating event percent ISLOCA (INTERFACING SYSTEMS LOCA OCCURS OUTSIDE CONTAINMENT) was set to zero. This is the equivalent of assuming that every potential ISLOCA could be prevented by increasing the frequency of valve leak testing. This resulted in a 3 percent reduction in CDF. | Cost Beneficial See Section F.6.3 |
| 4 | 148 | Improved MSIV Design | 17 | | Not Required | There are six basic events associated with the RNP MSIVs. Each of the three MSIVs has one basic event for its failure to close on demand and one basic event for transferring closed during operation. To calculate the maximum possible impact of this SAMA, all six of these basic events were set to zero. This is the equivalent of assuming that the new MSIVs would be perfectly reliable. This resulted in no impact to CDF or LERF. | Not Cost Beneficial See Section F.6.4 |

**TABLE F-9
 PHASE II SAMA (Cont'd)**

| Phase II SAMA ID number | Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Potential Cost | Comment | Phase 2 Disposition |
|--------------------------------|-------------------------------|--|---------------------------------|---|-----------------------|---|--|
| 5 | 159 | Install a digital feedwater upgrade. | 1 | This SAMA would reduce the chance of a loss of main feedwater. | Not Required | One of the purposes of installing a digital feedwater control system would be to increase the reliability / availability of main feedwater. To calculate the maximum possible impact of this SAMA, initiating events percent T4 (LOSS OF MAIN FEEDWATER) and percent T4A (PARTIAL LOSS OF MAIN FEEDWATER) were set to zero. This is the equivalent of assuming that the new digital control system perfectly controlled main feedwater at all times. This resulted in a 4.2 percent reduction in CDF. | Not Cost Beneficial See Section F.6.5 |
| 6 | 175 | Replace current PORVs with larger ones such that only one is required for successful feed and bleed. | 19 | This SAMA would reduce the dependencies required for successful feed and bleed. | Not Required | There are 2 PORVs and 3 SRVs for RCS pressure control. Two 2 PORVs are required for successful feed and bleed. Gate R3000 (1 OF 2 PORV S FAIL TO OPEN MANUALLY) was replaced with gate R2000 (2 OF 2 PORVs FAIL TO OPEN MANUALLY) at gate #TH (EVENT H - FAILURE OF PRIMARY BLEED) to simulate the implementation of this SAMA. The result was a 2.1 percent reduction in CDF. | Not Cost Beneficial See Section F.6.6 |


**TABLE F-9
PHASE II SAMA (Cont'd)**

| Phase II SAMA ID number | Phase I SAMA ID number | SAMA title | Source Reference of SAMA | Result of potential enhancement | Potential Cost | Comment | Phase 2 Disposition |
|-------------------------|------------------------|---|--------------------------|---|----------------|---|--|
| 7 | 182 | Implement an RWST make-up procedure | 19 | This SAMA would decrease CDF from ISLOCA scenarios, some smaller break LOCA scenarios, and SGTR. | \$50,000 | RNP has a RWST fill system at about 100 gpm. Use of this system is credited for appropriate late core damage sequences. R-RWST (RECOVERY OF FAILURE TO REFILL THE RWST FOR LATE SEQUENCES) was set to zero to simulate implementation of this SAMA. The result was a 0.7 percent reduction in CDF. | Not Cost Beneficial See Section F.6.7 |
| 8 | 193 | Create automatic swap over to recirculation on RWT depletion. | 19 | This SAMA would reduce the human error contribution from recirculation failure. | \$264,750 | The implementation of this SAMA is estimated to yield an averted cost-risk of \$58,885. | Not Cost Beneficial See Section F.6.8 |
| 9 | 267 | Train operations crew for response to inadvertent actuation signals | 19 | This SAMA would improve chances of a successful response to the loss of two 120V AC buses, which may cause inadvertent signal generation. | Not Required | The only scenarios in the RNP PSA that would cause a simultaneous failure of two instrument buses are the common cause failure events for Instrument Buses 1 and 4 (CCCF1&4BUS) and Instrument Buses 2 and 3 (CCCF2&3BUS). To simulate the implementation of this SAMA, these two common cause events were set to zero. This resulted in no reduction of CDF or LERF. | Not Cost Beneficial See Section F.6.9 |

Notes to Table F-8

- #1 Not applicable to the RNP Design
- #2 Similar item is addressed under other proposed SAMAs
- #3 Already implemented at Robinson
- #4 No significant safety benefit associated with the systems / items associated with this SAMA
- #5 The cost of implementation is greater than the cost-risk averted for the plant change or modification
- #6 Retain
- #7 Requested additional information from Robinson
- #8 ABWR design issue; not practical
- #9 IPEEE

**FIGURE F-1
SAMA SCREENING PROCESS**



F.10 REFERENCES

1. NUREG-1560, "Individual Plant Examination Program: Perspectives on Reactor Safety and Plant Performance," Volume 2, NRC, December 1997.
2. Letter from Mr. M. O. Medford (Tennessee Valley Authority) to NRC Document Control Desk, dated September 1, 1992, "Watts Bar Nuclear Plant Units 1 and 2 – Generic Letter (GL) – Individual Plant Examination (IPE) for Severe Accident Vulnerabilities – Response".
3. NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," Volume 1, Table 5.36 Listing of SAMDAs considered for the Comanche Peak Steam Electric Station, NRC, May 1996.
4. Letter from Mr. D. E. Nunn (Tennessee Valley Authority) to NRC Document Control Desk, dated October 7, 1994, "Watts Bar Nuclear Plant (WBN) Units 1 and 2 – Severe Accident Mitigation Design Alternatives (SAMDA) – Response to Request for Additional Information (RAI)".
5. "Cost Estimate for Severe Accident Mitigation Design Alternatives, Limerick Generating Station for Philadelphia Electric Company," Bechtel Power Corporation, June 22, 1989.
6. NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," Volume 1, Table 5.35, Listing of SAMDAs considered for the Limerick, NRC, May 1996.
7. Letter from Mr. W. J. Museler (Tennessee Valley Authority) to NRC Document Control Desk, dated October 7, 1994, "Watts Bar Nuclear Plant (WBN) Units 1 and 2 – Severe Accident Mitigation Design Alternatives (SAMDA)."
8. NUREG-0498, "Final Environmental Statement related to the operation of Watts Bar Nuclear Plant, Units 1 and 2," Supplement No. 1, NRC, April 1995.
9. Letter from Mr. D. E. Nunn (Tennessee Valley Authority) to NRC Document Control Desk, dated June 30, 1994. "Watts Bar Nuclear Plant (WBN) Unit 1 and 2 – Severe Accident Mitigation Design Alternatives (SAMDAs) Evaluation from Updated Individual Plant Evaluation (IPE)."
10. Letter from N. J. Liparulo (Westinghouse Electric Corporation) to NRC Document Control Desk, dated December 15, 1992, "Submittal of Material Pertinent to the AP600 Design Certification Review."
11. NUREG-1462, "Final Safety Evaluation Report Related to the Certification of the System 80+ Design," NRC, August 1994.

12. Letter from Georgia Power Company to U.S. Nuclear Regulatory Commission. Subject: Plant Hatch - Units 1 and 2, Individual Plant Examination Submittal, December 11, 1992.
13. Letter from Georgia Power Company to U.S. Regulatory Commission. Subject: Edwin I. Hatch Nuclear Plant, Response to Generic Letter 88-20, Supplement 4. Submitting the Edwin I. Hatch Individual Plant Examination for External Events (IPEEE). January 26, 1996.
14. PBAPS Report on Accident Management Insights (includes disposition of IPE/PRA Level 1 and 2 insights and IPEEE insights).
15. U.S Nuclear Regulatory Commission Generic Letter 88-20, Supplement 1.
16. U.S Nuclear Regulatory Commission Generic Letter 88-20, Supplement 2.
17. GE Nuclear Energy, "Technical Support Document for the ABWR," 25A5680, Rev. 1, November 1994.
18. H.B. Robinson Steam Electric Plant Unit No. 2 Probabilistic Safety Assessment, Appendix A.15, "HVAC System", Carolina Power and Light Company, version 0, August 1992.
19. Calvert Cliffs Application for License Renewal, Attachment 2, Appendix F, "Severe Accident Mitigation Alternatives Analysis", April 1998.
20. Letter, R. B. Starkey, Jr. (CP&L) to United States Nuclear Regulatory Commission Document Control Desk, *Submittal of the RNP Steam Electric Plant Unit No. 2 Individual Plant Examination (IPE)*, Carolina Power & Light Company, Serial NLS-92-246, August 31, 1992 (NOTE: The complete RNP IPE was attached to this letter).
21. H.B. Robinson Steam Electric Plant Unit No. 2 Individual Plant Examination for External Events Submittal, Carolina Power & Light Company, June 1995.
22. H.B. Robinson Steam Electric Plant Unit No. 2, Plant Operating Manual, AOP-014, Component Cooling Water System Malfunction, Rev 17.
23. H.B. Robinson -PRA-AN-A631, RNP Steam Electric Plant Unit No. 2 Individual Plant Examination, Appendix A, August 1992.
24. RNP Steam Electric Plant Unit No. 2, Plant Operating Manual, Severe Accident Management, SAM-1 through SAM-8.
25. EPP-1, End Path Procedure for Loss of AC Power, Rev 29.
26. APP-010, Annunciator Panel Procedure, HVAC-Emerg. Generator Misc Systems, Rev 33.

27. 8S19-P-101, RNP, Unit No. 2, Station Blackout Coping Analysis Report, Rev 5.
28. EPP-9, End Path Procedure for Transfer to Cold Leg Recirc, Rev 26.
29. SACM-2, Severe Accident Challenge Management, Depressurize Containment.
30. UFSAR Section 5.2.5.
31. EPP-22, End Path Procedure for Energizing Plant Equipment Using Dedicated Shutdown Diesel Generator, Rev 17.
32. OP-909, Operating Procedure, Fuel Oil System, Rev 29.
33. DBD SD-13 (pages 36-37), Design Basis Document, Component Cooling Water System, Rev 6.
34. EDP-003, Electrical Distribution Procedure, MCC-Buses, Rev 25.
35. Not Used.
36. DBD SD-25, Design Basis Document, Main Steam System, Rev 3.
37. UFSAR Section 5.2.2.2.
38. UFSAR Section 10.4.
39. FRP-H1, Function Restoration Procedure, Response to Loss of Secondary Heat Sink, Rev 16.
40. H.B. Robinson Steam Electric Plant Unit No. 2 Full Scope Scenario FSS-SEG-006, et al., "Loss of LCW", "Swap Over to Recirculation, and "ATWS".
41. Drawing 5379-376.
42. FRP-S1, Function Restoration Procedure, Response to Nuclear Power Generation/ATWS.
43. UFSAR Section 5.2.5.
44. AOP-004, Control Room Inaccessibility.
45. Dedicated Shutdown Procedure, DSP-002.
46. Bases for TS Section 3.7.
47. DBD SD-16, Design Basis Document, Electrical Power Distribution System Rev 2.
48. Generic Issue Documentation on Reactor Containment Isolation, GID/90-181/00/RCI, Rev 5.

49. Not Used.
50. Not Used.
51. Not Used.
52. U.S. Nuclear Regulatory Commission, "Regulatory Analysis Technical Evaluation Handbook," NUREG/BR-0184, 1997.
53. Brenda Mozafari (United States Nuclear Regulatory Commission) to C. R. Dietz (Carolina Power and Light), Request of Additional Information on Individual Plant Examination Submittal for RNP Steam Electric Plant, Unit 2 - Generic Letter 88-20 (TAC No. M74460), July 7, 1993.
54. Brenda Mozafari (United States Nuclear Regulatory Commission) to C. S. Hinnant (Carolina Power and Light), Safety Evaluation of the RNP Steam Electric Plant, Unit 2 Individual Plant Examination (IPE) Submittal - Internal Events (TAC No. M74460), August 17, 1994.
55. Energy Research, Incorporated, Safety Evaluation of the RNP Steam Electric Plant, Unit 2 Individual Plant Examination (IPE) Submittal - External Events, ERI/NRC 96-506.
56. Edwin I. Hatch Nuclear Plant Application for License Renewal, Environmental Report, Appendix D, Attachment F, February 2000.
57. NUREG/CR-6525, "SECPOP90: Sector Population, Land Fraction, and Economic Estimation Program," U.S. Nuclear Regulatory Commission, Washington, D.C., September 1997.
58. U.S. Census Bureau, Census 2000 Redistricting Data (P.L. 94-171) Summary File and 1990 Census. Table 1 – Counties in Alphabetic Sort within State, 1990 and 2000 Population, Numeric and Percent Change: 1990 to 2000. Internet Release date: April 2, 2001. Available online at:
<http://www.census.gov/population/cen2000/phc-t4/tab01.xls>.
59. Chanin, D. and Young, M., Code Manual for MACCS2: Volume 1, User's-Guide, SAND 97-0594, 1997.
60. NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," U. S. Nuclear Regulatory Commission, Washington, D.C., June 1989.
61. Evacuation Time Estimates for the RNP Steam Electric Plant, Plume Exposure Pathway, Emergency Planning Zone, HMM Associates, June 1987.
62. NUREG/CR-6525, "SECPOP90: Sector Population, Land Fraction, and Economic Estimation Program," U.S. Nuclear Regulatory Commission, Washington, D.C., September 1997.

63. U.S. Census Bureau, Census 2000 Redistricting Data (P.L. 94-171) Summary File and 1990 Census. Table 1 – Counties in Alphabetic Sort within State, 1990 and 2000 Population, Numeric and Percent Change: 1990 to 2000. Internet Release date: April 2, 2001. Available online at:
<http://www.census.gov/population/cen2000/phc-t4/tab01.xls>.
64. U.S. Department of Agriculture, "1997 Census of Agriculture," National Agricultural Statistics Service, 1998.
65. U.S. Department of Agriculture, "Usual Planting and Harvesting Dates for Crops in South Carolina," National Agricultural Statistics Service,
<http://www.nass.usda.gov/sc/pltdnum.htm>.
66. Southern Nuclear Operating Company, "Severe Accident Mitigation Alternatives at the Edwin I. Hatch Nuclear Plant." Attachment F of Appendix D (Applicant's Environmental Report - Operating License Renewal Stage) of Edwin I. Hatch Nuclear Plant Application for License Renewal. February 2000.
67. NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Calvert Cliffs Nuclear Power Plant," Supplement 1, U.S. Nuclear Regulatory Commission, Washington, D.C., February 1999.
68. John E. Till and H. Robert Meyer, Radiological Assessment, A Textbook on Environmental Dose Analysis, NUREG/CR-3332, ORNL-5968, p.2-23, September 1983, prepared for USNRC, Washington, D.C.).
69. H.B. Robinson Steam Electric Plant Unit No. 2 Plant Operation Manual, Volume 3, Part 4, Function Restoration Procedure FRP-H.1, "Response to Loss of Secondary Heat Sink", Revision 16.
70. H.B. Robinson Steam Electric Plant Unit No. 2, Task Report 31, "MUR Power Uprate", Project No. 10046-018, Revision 0.
71. H.B. Robinson Steam Electric Plant Unit No. 2 Plant Operating Manual, Volume 7, Part 1, System Configuration Management and Control SCM-003, "Plant Computer Systems Database Control Procedure", Revision 14.
72. Progress Energy, Inc., "Progress Energy Year 2000 Annual Report, Notes to Consolidated Financial Statements".
73. H.B. Robinson Steam Electric Plant Unit No. 2 Updated Final Safety Analysis Report, Figure 8.1.2-1, "230 and 115 kv Switchyard Development Diagram", CP&L Company, Revision 17.
74. Mixing Heights, Wind Speeds, and Potential for Urban Pollution Throughout the Contiguous United States, George C. Holzworth, EPA, Office of Air Programs, Research Triangle Park, North Carolina, January 1972.

75. Not Used.

76. Not Used.

77. Not Used.

78. Letter, T.M. Wilkerson (CP&L) to United States Nuclear Regulatory Commission Document Control Desk, Response to Generic Letter 97-05 "Steam Generator Tube Inspection Techniques", Carolina Power and Light Company, Serial RNP-RA/98-0040, March 16, 1998.

79. H.B. Robinson Steam Electric Plant Unit No. 2, Plant Operating Manual Volume 3, Part 5, Abnormal Operating Procedure, AOP-014 "Component Cooling Water System Malfunction", Revision 19.

80. H.B. Robinson Steam Electric Plant Unit No. 2, Plant Operating Manual Volume 3, Part 5, Abnormal Operating Procedure, AOP-22 "Loss of Service Water", Revision 24.

81. H.B. Robinson Steam Electric Plant Unit No. 2, Plant Operating Manual Volume 3, Part 5, Abnormal Operating Procedure, AOP-032 "Response to Flooding from the Fire Protection System", Revision 5.

82. H.B. Robinson Steam Electric Plant Unit No. 2, Plant Operating Manual Volume 3, Part 5, Abnormal Operating Procedure, AOP-008 "Accidental Release of Liquid Waste", Revision 9.