


Fermi 2

1Q/2000 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Unplanned scrams	0	1.0	0	0	0
Critical hours	2160.0	2138.7	2208.0	2209.0	2184.0
Indicator value	2.9	3.8	1.7	0.8	0.8

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Scrams	0	0	0	0	0
Indicator value				0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Unplanned power changes	0	0	1.0	0	0
Critical hours	2160.0	2138.7	2208.0	2209.0	2184.0
Indicator value	1.9	1.0	1.7	0.8	0.8

Licensee Comments: none

Safety System Unavailability, Emergency AC Power, >2EDG



Thresholds: White > 2.5% Yellow > 10.0% Red > 20.0%

Notes


Safety System Unavailability, Emergency AC Power, >2EDG	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Train 1					
Planned unavailable hours	0	29.00	0	8.51	63.03
Unplanned unavailable hours	96.10	0	0	0	0
Fault exposure hours	0	0	0	0	667.88
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2183.00	2208.00	2209.00	2184.00
Train 2					
Planned unavailable hours	0	35.90	0	10.85	60.73
Unplanned unavailable hours	0	0	0	0	4.80
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2183.00	2208.00	2209.00	2184.00
Train 3					
Planned unavailable hours	0	0	27.60	5.91	87.41
Unplanned unavailable hours	0	0	13.10	0	0
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2183.00	2208.00	2209.00	2184.00
Train 4					
Planned unavailable hours	0	29.80	0	6.33	84.73
Unplanned unavailable hours	0	0	56.70	14.12	0
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2183.00	2208.00	2209.00	2184.00
Indicator value				1.2%	2.1%

Licensee Comments:

1Q/98: WANO Performance Indicator Program data submitted in accordance with NEI 99-02 Draft Rev. D

1Q/98: WANO Performance Indicator Program data submitted in accordance with NEI 99-02 Draft Rev. D

Safety System Unavailability, High Pressure Injection System (HPCI)




Thresholds: White > 4.0% Yellow > 12.0% Red > 50.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPCI)	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Train 1					
Planned unavailable hours	7.23	81.85	4.42	9.12	128.19
Unplanned unavailable hours	13.13	40.08	19.93	0	0.60
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2138.70	2208.00	2209.00	2184.00
Indicator value				3.6%	2.5%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (RCIC)



Thresholds: White > 4.0% Yellow > 12.0% Red > 50.0%

Notes


Safety System Unavailability, Heat Removal System (RCIC)	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Train 1					
Planned unavailable hours	14.80	4.00	81.50	10.50	33.60
Unplanned unavailable hours	27.00	0	0	0	9.70
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2138.70	2208.00	2209.00	2184.00
Indicator value				1.9%	1.9%

Licensee Comments:

2Q/99: WANO Performance Indicator Program data submitted in accordance with NEI 99-02 Draft Rev. D

4Q/97: WANO Performance Indicator Program data submitted in accordance with NEI 99-02 Draft Rev. D

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Train 1					
Planned unavailable hours	0.53	0.77	13.50	0.98	33.00
Unplanned unavailable hours	0	0	0	0	9.01
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2183.00	2208.00	2209.00	2184.00
Train 2					
Planned unavailable hours	0.75	15.58	2.02	2.00	32.13
Unplanned unavailable hours	0	0	0	0	0.13
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2160.00	2183.00	2208.00	2209.00	2184.00
Indicator value				0.3%	0.5%

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0


Notes

Safety System Functional Failures (BWR)	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Safety System Functional Failures	0	0	1	2	1
Indicator value	0	0	1	3	4

Licensee Comments:

1Q/00: Licensee Event Report 2000-001: Both Divisions of Low Pressure Coolant Injection inoperable for approximately 8 minutes due to loss of power to the Division 1 LPCI Inboard Isolation Valve.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	4/99	5/99	6/99	7/99	8/99	9/99	10/99	11/99	12/99	1/00	2/00	3/00
Maximum activity	0.001700	0.001600	0.001300	0.002000	0.001900	0.001800	0.001500	0.001400	0.001300	0.001150	0.001150	0.001280
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0.9	0.8	0.7	1.0	1.0	0.9	0.8	0.7	0.7	0.6	0.6	0.6

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/99	5/99	6/99	7/99	8/99	9/99	10/99	11/99	12/99	1/00	2/00	3/00
Maximum leakage	1.630	1.630	1.630	1.630	1.610	1.610	1.620	1.630	1.600	1.600	1.610	1.610
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.5	6.5	6.5	6.5	6.4	6.4	6.5	6.5	6.4	6.4	6.4	6.4

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Successful opportunities	0	7.0	6.0	10.0	0
Total opportunities	0	8.0	8.0	10.0	0
Indicator value				93.2%	93.9%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Participating Key personnel				46.0	40.0
Total Key personnel				51.0	49.0
Indicator value				90.2%	81.6%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Successful siren-tests	177	176	173	163	337
Total sirens-tests	177	177	177	177	354
Indicator value	96.5%	98.4%	98.7%	97.3%	95.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
High radiation area occurrences	0	0	0	1	0
Very high radiation area occurrences	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0
Indicator value	1	1	0	1	1

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
RETS/ODCM occurrences	0	0	0	0	0
Indicator value	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index



Thresholds: White > 0.080


Notes

Protected Area Security Performance Index	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
IDS compensatory hours	755.11	257.72	285.30	315.12	232.30
CCTV compensatory hours	31.4	15.5	31.6	0.2	0.1
IDS normalization factor	1.90	1.90	1.90	1.90	1.92
CCTV normalization factor	1.0	1.0	1.0	1.0	1.0
Index Value	0.051	0.047	0.050	0.053	0.035

Licensee Comments:

1Q/00: IDS normalization factor changed due to Alternate Access Portal open in March in preparation for refuel outage.

Personnel Screening Program




Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Program failures	0	0	0	0	0
Indicator value	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	1Q/99	2Q/99	3Q/99	4Q/99	1Q/00
Program Failures	0	0	0	0	0
Indicator value	0	0	0	0	0

Licensee Comments: none

▲ [PI Summary](#) | [Inspection Findings Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 1, 2002