


Farley 1

1Q/2002 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Unplanned scrams	1.0	0	0	0	0	0	0	0
Critical hours	882.7	2208.0	2209.0	2160.0	2183.0	2208.0	1257.2	2160.0
Indicator value	1.0	1.0	1.0	0.9	0	0	0	0

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Unplanned power changes	1.0	3.0	0	0	1.0	0	0	0
Critical hours	882.7	2208.0	2209.0	2160.0	2183.0	2208.0	1257.2	2160.0
Indicator value	3.1	6.2	5.1	3.8	3.2	0.8	0.9	0.9

Licensee Comments: none

Safety System Unavailability, Emergency AC Power, >2EDG




Thresholds: White > 2.5% Yellow > 10.0% Red > 20.0%

Notes

Safety System Unavailability, Emergency AC Power, >2EDG	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Train 1								
Planned unavailable hours	8.00	132.50	193.50	124.90	1.30	20.30	0	0.50
Unplanned unavailable hours	0	0.60	0	0.30	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Train 2								
Planned unavailable hours	3.20	0	0.80	11.90	24.80	0.80	0	1.10
Unplanned unavailable hours	0	0	11.10	0	0	121.10	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Train 3								
Planned unavailable hours	0	0	0.70	1.30	1.00	1.30	0	13.70
Unplanned unavailable hours	0	13.50	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	1215.90	0	0	0	0
Required hours	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Indicator value	2.7%	2.9%	2.8%	1.4%	1.4%	1.5%	1.5%	1.6%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPSI)




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPSI)	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Train 1								
Planned unavailable hours	2.20	5.40	6.40	5.70	4.40	2.80	3.90	5.50
Unplanned unavailable hours	0	0.60	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	882.70	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Train 2								
Planned unavailable hours	6.80	3.30	6.20	5.60	9.00	6.30	2.30	7.20
Unplanned unavailable hours	0	0	0.30	0.30	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	882.70	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Indicator value	0.3%	0.2%	0.2%	0.2%	0.2%	0.2%	0.2%	0.2%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (AFW)




Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Train 1								
Planned unavailable hours	4.60	6.00	17.70	5.70	4.40	2.80	2.60	5.50
Unplanned unavailable hours	0	0.60	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	882.70	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Train 2								
Planned unavailable hours	9.20	3.90	7.30	7.30	2.60	5.30	2.30	7.20
Unplanned unavailable hours	0	0	0.30	0.40	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	882.70	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Train 3								
Planned unavailable hours	0	1.50	38.10	2.00	0.50	0.40	1.60	0.90
Unplanned unavailable hours	0	0	0	16.00	0	33.20	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	882.70	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Indicator value	0.3%	0.3%	0.4%	0.4%	0.4%	0.4%	0.4%	0.4%

Licensee Comments: none

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Train 1								
Planned unavailable hours	2.60	13.50	7.80	19.80	20.70	3.30	16.40	6.00
Unplanned unavailable hours	0	0.60	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Train 2								
Planned unavailable hours	11.60	15.20	6.60	26.30	9.40	15.80	3.10	18.70
Unplanned unavailable hours	0	0	0.30	0.30	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1257.20	2160.00
Indicator value	0.3%	0.3%	0.3%	0.4%	0.4%	0.4%	0.4%	0.5%

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Safety System Functional Failures	1	0	0	0	0	0	1	0
Indicator value	1	1	1	1	0	0	1	1

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/00	5/00	6/00	7/00	8/00	9/00	10/00	11/00	12/00	1/01	2/01	3/01
Maximum activity	N/A	N/A	0.007439	0.006018	0.004440	0.005290	0.005990	0.006200	0.005943	0.007291	0.008625	0.009230
Technical specification limit	N/A	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	N/A	N/A	1.5	1.2	0.9	1.1	1.2	1.2	1.2	1.5	1.7	1.8

Reactor Coolant System Activity	4/01	5/01	6/01	7/01	8/01	9/01	10/01	11/01	12/01	1/02	2/02	3/02
Maximum activity	0.010230	0.007577	0.006459	0.006865	0.006441	0.006811	0.006216	0.001900	0.002883	0.003025	0.003698	0.003825
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	2.0	1.5	1.3	1.4	1.3	1.4	1.2	0.4	0.6	0.6	0.7	0.8

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	4/00	5/00	6/00	7/00	8/00	9/00	10/00	11/00	12/00	1/01	2/01	3/01
Maximum leakage	N/A	0.069	0.017	0.012	0.020	0.012	0.018	0.012	0.012	0.015	0.016	0.012
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	N/A	0.7	0.2	0.1	0.2	0.1	0.2	0.1	0.1	0.2	0.2	0.1

Reactor Coolant System Leakage	4/01	5/01	6/01	7/01	8/01	9/01	10/01	11/01	12/01	1/02	2/02	3/02
Maximum leakage	0.018	0	0.012	0.013	0.011	0.012	0.012	0	0	0	0	0
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0	0.1	0.1	0.1	0.1	0.1	0	0	0	0	0

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Successful opportunities	15.0	65.0	56.0	9.0	37.0	61.0	38.0	6.0
Total opportunities	18.0	66.0	58.0	10.0	38.0	64.0	42.0	6.0
Indicator value	93.9%	95.6%	95.8%	95.8%	95.8%	95.8%	95.0%	95.0%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Participating Key personnel	121.0	141.0	103.0	94.0	97.0	97.0	99.0	102.0
Total Key personnel	121.0	143.0	103.0	95.0	103.0	100.0	100.0	103.0
Indicator value	100.0%	98.6%	100.0%	98.9%	94.2%	97.0%	99.0%	99.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Successful siren-tests	48	42	45	42	45	41	45	42
Total sirens-tests	48	42	45	42	45	42	45	42
Indicator value	98.9%	98.9%	100.0%	100.0%	100.0%	99.4%	99.4%	99.4%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	1	1	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index



Thresholds: White > 0.080


Notes

Protected Area Security Performance Index	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
IDS compensatory hours	231.40	119.10	88.37	172.90	70.80	71.96	44.90	82.60
CCTV compensatory hours	0	20.7	9.3	136.8	216.4	475.5	20.5	18.9
IDS normalization factor	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70
CCTV normalization factor	1.2	1.2	1.2	1.0	1.0	1.0	1.0	1.0
Index Value	0.021	0.018	0.017	0.030	0.037	0.061	0.061	0.051

Licensee Comments:

- 1Q/02: CCTV historical normalization factor corrected from 1.2 to 1. Comp hours unchanged. Color unaffected.
- 4Q/01: CCTV normalization factor corrected Q12002 from 1.2 to 1.0. Comp hours unchanged. Color unaffected.
- 3Q/01: CCTV normalization factor corrected - Q12002 from 1.2 to 1.0. Comp hours unchanged. Color unaffected.
- 2Q/01: CCTV normalization factor corrected Q12002 from 1.2 to 1.0. Comp hours unchanged. Color unaffected.
- 1Q/01: CCTV normalization factor corrected Q12002 from 1.2 to 1.0. Comp hours unchanged. Color unaffected.

Personnel Screening Program




Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Program failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02
Program Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

▲ [PI Summary](#) | [Inspection Findings Summary](#) | [Reactor Oversight Process](#)

Last Modified: May 1, 2002