


Davis-Besse

2Q/2005 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Unplanned scrams	0	0	0	0	1.0	0	0	0
Critical hours	0	0	287.3	2183.0	2132.7	2209.0	1603.9	2183.0
Indicator value	N/A	N/A	N/A	0	1.5	1.0	0.9	0.9

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Unplanned power changes	0	0	1.0	0	0	0	0	0
Critical hours	0	0	287.3	2183.0	2132.7	2209.0	1603.9	2183.0
Indicator value	N/A	N/A	N/A	2.8	1.5	1.0	0	0

Licensee Comments: none

Safety System Unavailability, Emergency AC Power




Thresholds: White > 2.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Emergency AC Power	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Train 1								
Planned unavailable hours	0	0.80	29.20	5.40	76.70	31.20	5.60	65.70
Unplanned unavailable hours	0	0	0	15.70	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1616.20	953.30	2184.00	2183.00	2208.00	2209.00	1771.50	2183.00
Train 2								
Planned unavailable hours	1.80	0	7.30	35.30	10.30	71.70	4.70	19.80
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1011.30	1401.80	2184.00	2183.00	2208.00	2209.00	2108.00	2183.00
Indicator value	0.8%	0.7%	0.8%	0.8%	0.8%	0.8%	0.8%	1.0%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPSI)




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPSI)	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Train 1								
Planned unavailable hours	9.10	0	0	10.80	31.60	2.40	0	3.00
Unplanned unavailable hours	0	0	0	0	0	0	0	10.20
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	377.70	213.30	2063.50	2183.00	2208.00	2209.00	1705.80	2183.00
Train 2								
Planned unavailable hours	3.50	0	0.60	16.40	6.90	0.40	0.50	42.10
Unplanned unavailable hours	0	0	0	6.80	0	0	0	10.30
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	377.70	147.20	2063.50	2183.00	2208.00	2209.00	1705.80	2183.00
Indicator value	0.3%	0.4%	0.2%	0.4%	0.5%	0.5%	0.4%	0.6%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (AFW)




Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Train 1								
Planned unavailable hours	6.65	2.53	12.30	23.40	32.20	22.70	8.90	46.50
Unplanned unavailable hours	18.12	0	22.90	0	0	0	0	8.70
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	377.68	92.07	1656.30	2183.00	2208.00	2209.00	1705.80	2183.00
Train 2								
Planned unavailable hours	0.72	0	9.80	23.90	37.10	24.60	24.80	11.10
Unplanned unavailable hours	0	0	31.90	0	0	0	8.40	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	377.68	92.07	1656.30	2183.00	2208.00	2209.00	1705.80	2183.00
Train 3								
Planned unavailable hours	0	0	0	13.70	0	0	4.90	1.10
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	377.68	92.07	1656.30	2183.00	2208.00	2209.00	1705.80	2183.00
Indicator value	0.6%	0.7%	1.0%	1.0%	1.2%	1.0%	1.1%	1.0%

Licensee Comments: none

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Train 1								
Planned unavailable hours	3.80	0	2.60	26.90	4.10	13.50	2.80	13.90
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1662.60	943.40	2184.00	2183.00	2208.00	2209.00	2068.30	2183.00
Train 2								
Planned unavailable hours	1.50	0	2.80	15.50	24.10	1.00	61.90	24.10
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1136.30	1477.90	2184.00	2183.00	2208.00	2209.00	2160.00	2183.00
Indicator value	0.2%	0.2%	0.1%	0.3%	0.2%	0.2%	0.4%	0.5%

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Safety System Functional Failures	1	1	0	0	0	0	0	0
Indicator value	4	4	4	2	1	0	0	0

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/03	8/03	9/03	10/03	11/03	12/03	1/04	2/04	3/04	4/04	5/04	6/04
Maximum activity	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0.006300	0.007400	0.007600
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0.6	0.7	0.8

Reactor Coolant System Activity	7/04	8/04	9/04	10/04	11/04	12/04	1/05	2/05	3/05	4/05	5/05	6/05
Maximum activity	0.008300	0.009100	0.009400	0.010400	0.011000	0.010000	0.009700	0.011000	0.011000	0.012000	0.012000	0.013000
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.8	0.9	0.9	1.0	1.1	1.0	1.0	1.1	1.1	1.2	1.2	1.3

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/03	8/03	9/03	10/03	11/03	12/03	1/04	2/04	3/04	4/04	5/04	6/04
Maximum leakage	N/A	N/A	0.100	N/A	N/A	N/A	0.069	0.099	0.071	0.062	0.070	0.064
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	N/A	N/A	1.0	N/A	N/A	N/A	0.7	1.0	0.7	0.6	0.7	0.6
Reactor Coolant System Leakage	7/04	8/04	9/04	10/04	11/04	12/04	1/05	2/05	3/05	4/05	5/05	6/05
Maximum leakage	0.068	0.202	0.089	0.090	0.102	0.112	0.104	0.122	0.073	0.091	0.193	0.491
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.7	2.0	0.9	0.9	1.0	1.1	1.0	1.2	0.7	0.9	1.9	4.9

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Successful opportunities	17.0	48.0	0	16.0	23.0	46.0	16.0	38.0
Total opportunities	19.0	50.0	0	16.0	25.0	46.0	16.0	39.0
Indicator value	90.8%	93.2%	93.2%	94.2%	94.0%	96.2%	96.5%	96.7%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Participating Key personnel	64.0	65.0	63.0	66.0	63.0	66.0	71.0	88.0
Total Key personnel	64.0	66.0	64.0	66.0	65.0	69.0	72.0	88.0
Indicator value	100.0%	98.5%	98.4%	100.0%	96.9%	95.7%	98.6%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Successful siren-tests	147	147	201	98	147	152	160	216
Total sirens-tests	147	147	201	147	147	152	162	216
Indicator value	99.7%	99.7%	100.0%	92.4%	92.4%	92.4%	91.6%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	1	1	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.