

2Q/2006 ROP Performance Indicators Summary

Physical Protection information not publicly available.

San Onofre 3	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Seabrook 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Sequoyah 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Sequoyah 2	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
South Texas 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
South Texas 2	G	G	G	G	W	G	G	G	G	G	G	G	G	G	G	G
Summer	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Surry 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Surry 2	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Susquehanna 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Susquehanna 2	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Three Mile Island 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Turkey Point 3	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Turkey Point 4	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Vermont Yankee	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Vogtle 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Vogtle 2	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Waterford 3	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Watts Bar 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G
Wolf Creek 1	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G	G

Legend:	R=Red	W=White	T=Thresholds under development	I=Insufficient data to calculate PI	N=Not Applicable	D=Discrepant
	Y=Yellow	G=Green			U=Unique Design	
IE01	= Unplanned Scrams per 7000 Critical Hours			IE02	= Scrams with Loss of Normal Heat Removal	
IE03	= Unplanned Power Changes			MS01	= Emergency AC Power System	
MS02	= High Pressure Injection System			MS03	= Heat Removal System	
MS04	= Residual Heat Removal System			MS05	= Safety System Functional Failures	
BI01	= Reactor Coolant System Specific Activity			BI02	= Reactor Coolant System Leakage	
EP01	= Drill/Exercise Performance			EP02	= ERO Drill Participation	
EP03	= Alert and Notification System			OR01	= Occupational Exposure Control Effectiveness	
PR01	= RETS/ODCM Radiological Effluent					

