


Browns Ferry 2

4Q/2007 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Unplanned scrams	0	0	0	0	1.0	0	0	0
Critical hours	2160.0	2072.9	2208.0	1950.1	1180.7	1832.1	2124.2	2209.0
Indicator value	0.8	0.8	0	0	0.9	1.0	1.0	1.0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Unplanned power changes	1.0	0	0	0	0	3.0	0	0
Critical hours	2160.0	2072.9	2208.0	1950.1	1180.7	1832.1	2124.2	2209.0
Indicator value	1.7	0.8	0.8	0.8	0	2.9	3.0	2.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Scrams with complications				0	0	0	0	0
Indicator value							0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	2	1	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
UAI (Δ CDF)		-3.30E-08	-3.30E-08	-3.30E-08	-2.80E-08	2.10E-08	2.10E-08	2.50E-08
URI (Δ CDF)		-3.10E-07	-3.10E-07	-3.10E-07	-3.10E-07	-4.70E-07	-4.70E-07	-6.20E-07
PLE		NO	NO	NO	NO	NO	NO	NO
Indicator value		-3.43E-07	-3.43E-07	-3.43E-07	-3.38E-07	-4.49E-07	-4.49E-07	-5.95E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
UAI (Δ CDF)		-9.20E-09	-9.20E-09	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08
URI (Δ CDF)		2.80E-09	2.80E-09	2.80E-09	2.80E-09	2.80E-09	2.80E-09	2.80E-09
PLE		NO	NO	NO	NO	NO	NO	NO
Indicator value		-6.40E-09	-6.40E-09	-9.20E-09	-9.20E-09	-9.20E-09	-9.20E-09	-9.20E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
UAI (Δ CDF)		-2.00E-08	-2.00E-08	-2.00E-08	-7.00E-09	-8.30E-09	-8.20E-09	-1.30E-08
URI (Δ CDF)		-4.20E-08	-4.20E-08	-4.00E-08	-4.40E-08	-4.40E-08	-4.40E-08	-4.40E-08
PLE		NO	NO	NO	NO	NO	NO	NO
Indicator value		-6.20E-08	-6.20E-08	-6.00E-08	-5.10E-08	-5.23E-08	-5.22E-08	-5.70E-08


Licensee Comments:

3Q/07: RCIC pump was listed as a motor driven pump when it should be a turbine driven pump. Device record corrected. Reference PER 136362

2Q/07: A review of U2 and U3 MSPI baseline data entered in the CDE database identified several discrepancies with U2 and U3 MSPI Basis Documents. Unlocked to correct. Reference BFN PER 127680

2Q/06: A review of U2 and U3 MSPI baseline data entered in the CDE database identified several discrepancies with U2 and U3 MSPI Basis Documents. Unlocked to correct. Reference BFN PER 127680

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
UAI (ΔCDF)		2.50E-07	2.50E-07	2.80E-07	3.30E-07	3.20E-07	3.60E-07	2.70E-07
URI (ΔCDF)		-9.70E-08	-9.60E-08	-9.80E-08	-8.40E-08	-8.70E-08	-8.80E-08	-8.80E-08
PLE		NO	NO	NO	NO	NO	NO	NO
Indicator value		1.53E-07	1.54E-07	1.82E-07	2.46E-07	2.33E-07	2.72E-07	1.82E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > $1.00E-6$ Yellow > $1.00E-5$ Red > $1.00E-4$

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
UAI (Δ CDF)		$1.20E-07$	$1.30E-07$	$6.80E-08$	$1.30E-07$	$1.30E-07$	$1.60E-07$	$1.60E-07$
URI (Δ CDF)		$8.20E-10$	$2.70E-08$	$2.10E-08$	$4.70E-08$	$2.40E-08$	$2.40E-08$	$2.40E-08$
PLE		NO	NO	NO	NO	NO	NO	NO
Indicator value		$1.21E-07$	$1.57E-07$	$8.90E-08$	$1.77E-07$	$1.54E-07$	$1.84E-07$	$1.84E-07$

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06
Maximum activity	0.000035	0.000032	0.000038	0.000038	0.000038	0.000044	0.000036	0.000036	0.000034	0.000036	0.000054	0.000045
Technical specification limit	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum activity	0.000087	0.000045	N/A	N/A	0.000047	0.000035	0.000034	0.000040	0.000033	0.000034	0.000042	0.000036
Technical specification limit	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
Indicator value	0	0	N/A	N/A	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06
Maximum leakage	2.200	2.190	2.220	2.290	2.300	2.000	2.020	1.880	2.410	2.350	1.860	1.880
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.3	7.3	7.4	7.6	7.7	6.7	6.7	6.3	8.0	7.8	6.2	6.3

Reactor Coolant System Leakage	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum leakage	2.160	1.930	0	1.330	1.710	1.830	1.740	1.820	1.740	1.660	1.640	1.610
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.2	6.4	0	4.4	5.7	6.1	5.8	6.1	5.8	5.5	5.5	5.4

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Successful opportunities	0	15.0	44.0	24.0	0	7.0	8.0	55.0
Total opportunities	0	16.0	44.0	24.0	0	8.0	8.0	56.0
Indicator value	97.8%	97.4%	97.8%	98.9%	98.9%	98.3%	98.3%	98.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Participating Key personnel	66.0	73.0	69.0	68.0	63.0	66.0	66.0	68.0
Total Key personnel	67.0	73.0	69.0	68.0	65.0	67.0	67.0	68.0
Indicator value	98.5%	100.0%	100.0%	100.0%	96.9%	98.5%	98.5%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
Successful siren-tests	799	896	793	798	797	795	798	698
Total sirens-tests	800	900	800	800	800	800	800	700
Indicator value	99.7%	99.7%	99.6%	99.6%	99.5%	99.5%	99.6%	99.6%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.