

to be added to the distribution, please contact the Office of the Secretary, Washington, DC 20555 (301-415-1969). In addition, distribution of this meeting notice over the Internet system is available. If you are interested in receiving this Commission meeting schedule electronically, please send an electronic message to [dkw@nrc.gov](mailto:dkw@nrc.gov).

Dated: September 20, 2003.

**D.L. Gamberoni,**

*Technical Coordinator, Office of the Secretary.*

[FR Doc. 03-24348 Filed 9-23-03; 12:03 pm]

BILLING CODE 7590-01-M

## NUCLEAR REGULATORY COMMISSION

### Draft Construction Inspection Program for Reactors Built Under 10 CFR Part 52; Reopening of Comment Period

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Draft document; reopening of the comment period.

**SUMMARY:** On May 30, 2003, the Nuclear Regulatory Commission (NRC) issued the "Draft 10 CFR Construction Inspection Program Framework Document," which set forth the basis for the construction inspection program for reactors built under 10 CFR part 52. The framework document details the proposed audits and inspections to be conducted by the NRC during the Early Site Permit (ESP) and Combined License (COL) phases. The document also discusses how the NRC staff will verify satisfactory completion of the inspections, tests, analyses, and acceptance criteria (ITAAC) and review operational programs. The original request for comments was contained in an announcement of a public workshop on issues related to the construction inspection program for reactors built under 10 CFR part 52 (68 FR 34012). The comment period expired on September 15, 2003. Comment periods for several other documents related to construction of reactors under 10 CFR part 52 were also occurring during the same time period. In order to allow all stakeholders an opportunity to provide comments on the Construction Inspection Program Framework Document, the Commission has decided to reopen the comment period until October 30, 2003. The draft document is available for public inspection in the NRC Public Document Room located at One White Flint North, 11555 Rockville Pike, Public File Area O1 F21, Rockville, Maryland, or from the Publicly Available Records (PARS)

component of NRC's Agencywide Documents Access and Management System (ADAMS) (#ADAMS ML031400849). ADAMS is accessible from the NRC Web site, <http://www.nrc.gov>, in the Public Electronic Reading Room. For more information, contact the NRC Public Document Room (PDR) reference staff at 1-800-397-4209 or 202-634-3273 or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

**DATES:** Submit comments on the Draft Construction Inspection Program Framework Document by October 30, 2003. Comments received after the due date will be considered if it is practical to do so, but the Commission is able to assure consideration only for comments received on or before this date.

**ADDRESSES:** Submit written comments on the draft guidance to: Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, Mail Stop T6-D59, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

Comments may be hand-delivered to the NRC at 11545 Rockville Pike, Rockville, Maryland, between 7:45 a.m. and 4:15 p.m. on Federal workdays. Comments may be submitted electronically by the Internet to the NRC at [nrcprep@nrc.gov](mailto:nrcprep@nrc.gov). All comments received by the Commission, including those made by Federal, State, and local agencies, Indian tribes, and other interested persons, will be made available electronically at the Commission's Public Document Room in Rockville, Maryland, or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS).

**FOR FURTHER INFORMATION, CONTACT:** Ms. Mary Ann M. Ashley, Inspection Program Branch, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Ms. Ashley may be reached at (301) 415-1073 or by e-mail at [mab@nrc.gov](mailto:mab@nrc.gov).

Dated at Rockville, Maryland, this 15th day of September 2003.

For the Nuclear Regulatory Commission.

**Stuart A. Richards,**

*Chief, Inspection Program Branch, Division of Inspection Program Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 03-24203 Filed 9-24-03; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

### Notice of Availability of Model Application Concerning Technical Specification Improvement To Eliminate Hydrogen Recombiner Requirement, and Relax the Hydrogen and Oxygen Monitor Requirements for Light Water Reactors Using the Consolidated Line Item Improvement Process

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of availability.

**SUMMARY:** Notice is hereby given that the staff of the Nuclear Regulatory Commission (NRC) has prepared a model safety evaluation (SE), a model no significant hazards consideration (NSHC) determination, and a model application relating to the elimination of hydrogen recombiner requirements, and relaxation of the hydrogen and oxygen monitor requirements for Light Water Reactors (LWRs). The purpose of these models is to permit the NRC to efficiently process amendments that propose to remove requirements for hydrogen recombiners, and hydrogen and oxygen monitors from Technical Specifications (TS). Licensees of nuclear power reactors to which the models apply may request amendments using the model application.

**DATES:** The NRC staff issued a **Federal Register** Notice (67 FR 50374, August 2, 2002) soliciting comments on a model safety SE and a model NSHC determination for the elimination of requirements for hydrogen recombiners, and hydrogen and oxygen monitors from TS. The NRC staff hereby announces that the attached model SE and model NSHC determination (which differ only slightly from the versions previously published) may be referenced in plant-specific applications to eliminate requirements for hydrogen recombiners, and hydrogen and oxygen monitors from TS. The staff has posted a model application on the NRC web site to assist licensees in using the consolidated line item improvement process (CLIP) to apply for the proposed TS change. The NRC staff can most efficiently consider applications based upon the model application if the application is submitted within a year of this **Federal Register** Notice.

**FOR FURTHER INFORMATION CONTACT:** William Reckley, Mail Stop: O-7D1, Division of Licensing Project Management, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, telephone 301-415-1323.

**SUPPLEMENTARY INFORMATION:****Background**

Regulatory Issue Summary 2000–06, “Consolidated Line Item Improvement Process for Adopting Standard Technical Specification Changes for Power Reactors,” was issued on March 20, 2000. The CLIIP is intended to improve the efficiency of NRC licensing processes. This is accomplished by processing proposed changes to the standard technical specifications (STS) in a manner that supports subsequent license amendment applications. The CLIIP includes an opportunity for the public to comment on proposed changes to the STS following a preliminary assessment by the NRC staff and finding that the change will likely be offered for adoption by licensees. The NRC staff evaluates any comments received for a proposed change to the STS and either reconsiders the change or proceeds with announcing the availability of the change for proposed adoption by licensees. Those licensees opting to apply for the subject change to TS are responsible for reviewing the staff’s evaluation, referencing the applicable technical justifications, and providing any necessary plant-specific information. Each amendment application made in response to the notice of availability will be processed and noticed in accordance with applicable rules and NRC procedures.

This notice involves the elimination of requirements for hydrogen recombiners, and hydrogen and oxygen monitors in TS for LWRs. This proposed change was proposed for incorporation into the STS and is designated TSTF–447, Revision 1. TSTF–447, Revision 1 is supported by the implementation of a revision to 10 CFR 50.44, “Standards for Combustible Gas Control System in Light-Water-Cooled Power Reactors.” The amended standards eliminated the need for requirements for hydrogen recombiners and for hydrogen and oxygen monitors in TS. TSTF–447, Revision 1 can be viewed on the NRC Web site ([www.nrc.gov](http://www.nrc.gov)).

**Applicability**

This proposed change to remove requirements for hydrogen recombiners, and hydrogen and oxygen monitors from TS is applicable to LWRs (i.e., all operating plants).

To efficiently process the incoming license amendment applications, the staff requests each licensee applying for the changes addressed by TSTF–447, Revision 1 using the CLIIP to address the following plant-specific verifications and regulatory commitments. The CLIIP does not prevent licensees from

requesting an alternative approach or proposing the changes without the requested verifications and regulatory commitments. Variations from the approach recommended in this notice may, however, require additional review by the NRC staff and may increase the time and resources needed for the review. In making the requested regulatory commitments, each licensee should state: (1) That the subject capability exists (or will be developed) and will be maintained; (2) where the capability or procedure will be described (e.g., severe accident management guidelines, emergency operating procedures, emergency plan implementing procedures); and (3) a schedule for implementation. The amendment request need not provide details about designs or procedures.

Each licensee should verify that it has, and make a regulatory commitment to maintain (or make a regulatory commitment to develop and maintain):

- a. A hydrogen monitoring system capable of diagnosing beyond design-basis accidents; and
- b. An oxygen monitoring system capable of verifying the status of the inert containment for plant designs with an inerted containment. (for applicable boiling water reactors)

**Public Notices**

In a notice in the **Federal Register** dated August 2, 2002 (67 FR 50374), the staff requested comment on the use of the CLIIP to process requests to delete hydrogen recombiner, and hydrogen and oxygen monitor requirements from TS.

TSTF–447, Revision 1, and documents associated with the revision of 10 CFR 50.44 may be examined, and/or copied for a fee, at the NRC’s Public Document Room, located at One White Flint North, Public File Area O1 F1, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records are accessible electronically from the ADAMS Public Library (the Electronic Reading Room) component on the NRC Web site ([www.nrc.gov](http://www.nrc.gov)).

The staff received one comment (from an individual licensee) following the notice soliciting comments about modifying the TS requirements regarding hydrogen recombiners, and hydrogen and oxygen monitors for LWRs. The comment on the model SE was offered, and is summarized and discussed below:

1. *Comment:* A licensee recommended that the SE also include conclusions as to the acceptability of eliminating containment purging as the design basis method for post-loss-of-coolant accident (LOCA) hydrogen

control. Some licensees use containment purging as the design basis method for compliance with the current 10 CFR 50.44, rather than hydrogen recombiners. Although the containment purge requirements were not incorporated into the TS, as was done for hydrogen recombiners, the requirement for purging exists in docketed commitments to the NRC and in the Final Safety Analysis Report (FSAR). The process of changing the FSAR and the docketed commitments would be simplified if the NRC SE included consideration of containment purging.

*Response:* The NRC model SE only addresses requirements in the STS or plant-specific TS. In this case, the NRC model SE is for the elimination of the requirements of hydrogen recombiners, and hydrogen and oxygen monitors from TS. Since containment purging requirements are not in the STS, the NRC model SE did not make conclusions about the acceptability of eliminating containment purging as the design basis method for post-LOCA hydrogen control. However, the following statement from the Statements of Considerations was added to the model SE to address the comment:

\* \* \* the Commission eliminated the hydrogen release associated with a design-basis LOCA from § 50.44 and the associated requirements that necessitated the need for the hydrogen recombiners and the backup hydrogen vent and purge systems.

In addition, the staff has made some minor changes to the model SE as a result of internal reviews. A specific change involves the reference to Criterion 2 (10 CFR 50.36(c)(2)(ii)(B)) as the basis for retention of primary containment oxygen concentration in the TS. In the model SE, the staff had proposed to change the basis to Criterion 4 (10 CFR 50.36(c)(2)(ii)(D)) since combustible gas generated from severe accidents was not risk significant for Mark I and II containments, provided that the required inerted atmosphere was maintained. Criterion 4 is intended to capture those constraints that probabilistic risk assessment or operating experience show to be significant to public health and safety, consistent with the Commission’s Probabilistic Risk Assessment (PRA) Policies. Upon further review by the staff, it was determined that the basis for the primary containment oxygen concentration should remain Criterion 2 since the typical Updated FSAR Chapter 6 analyses assume that the primary containment is inerted when a design basis LOCA occurs. Therefore, primary containment oxygen concentration is a

process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.

Licenses wishing to eliminate the requirements for hydrogen recombiners, and hydrogen and oxygen monitors from TS must submit an application in accordance with applicable regulatory requirements. As described in the model application prepared by the staff, licensees may reference the following model SE, NSHC determination, and environmental assessment in their plant-specific applications to eliminate the TS requirements for hydrogen recombiners, and hydrogen and oxygen monitors.

**Model Safety Evaluation—U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Consolidated Line Item Improvement, Technical Specification Task Force (TSTF) Change TSTF-447, Revision 1, Elimination of Requirements for Hydrogen Recombiners and Change of Requirements for Hydrogen and Oxygen Monitors**

*1.0 Introduction*

By application dated [], [Licensee] (the licensee) requested changes to the Technical Specifications (TSs) for [Plant]. The proposed changes would delete the TS requirements associated with hydrogen recombiners, and hydrogen [and oxygen] monitors.

The Nuclear Regulatory Commission (NRC) has revised 10 CFR 50.44, "Standards for Combustible Gas Control System in Light-Water-Cooled Power Reactors." The amended standards eliminated the requirements for hydrogen recombiners and relaxed the requirements for hydrogen and oxygen monitoring. In letters dated December 17, 2002, and May 12, 2003, the Nuclear Energy Institute (NEI) Technical Specification Task Force (TSTF) proposed to remove requirements for hydrogen recombiners and hydrogen and oxygen monitors from the standard technical specifications (STS) (NUREGs 1430-1434) on behalf of the industry to incorporate the amended standards. This proposed change is designated TSTF-447.

The NRC staff prepared this model safety evaluation (SE) for the elimination of requirements regarding containment hydrogen recombiners and the removal of requirements from TS for containment hydrogen and oxygen monitors and solicited public comment (67 FR 50374, published August 2, 2002) in accordance with the

Consolidated Line Item Improvement Process (CLIIP). The use of the CLIIP in this matter is intended to help the NRC to efficiently process amendments that propose to remove the hydrogen recombiner and hydrogen and oxygen monitor requirements from TS.

Licenses of nuclear power reactors to which this model applies were informed [FR] that they could request amendments conforming to the model, and, in such requests, should confirm the applicability of the SE to their reactors and provide the requested plant-specific verifications and commitments.

*2.0 Background*

Regulatory Issue Summary 2000-06, "Consolidated Line Item Improvement Process for Adopting Standard Technical Specification Changes for Power Reactors," was issued on March 20, 2000. The CLIIP is intended to improve the efficiency of NRC licensing processes. This is accomplished by processing proposed changes to the STS in a manner that supports subsequent license amendment applications. The CLIIP includes an opportunity for the public to comment on proposed changes to the STS following a preliminary assessment by the NRC staff and finding that the change will likely be offered for adoption by licensees. The NRC staff evaluates any comments received for a proposed change to the STS and either reconsiders the change or proceeds with announcing the availability of the change for proposed adoption by licensees. Those licensees opting to apply for the subject change to TS are responsible for reviewing the staff's evaluation, referencing the applicable technical justifications, and providing any necessary plant-specific information. Each amendment application made in response to the notice of availability would be processed and noticed in accordance with applicable rules and NRC procedures.

The Commission's regulatory requirements related to the content of TS are set forth in 10 CFR 50.36. This regulation requires that the TSs include items in five specific categories. These categories include (1) Safety limits, limiting safety system settings and limiting control settings, (2) limiting conditions for operation (LCO), (3) surveillance requirements, (4) design features, and (5) administrative controls. However, the regulation does not specify the particular TSs to be included in a plant's license.

Additionally, 10 CFR 50.36(c)(2)(ii) sets forth four criteria to be used in determining whether an LCO is required

to be included in the TS. These criteria are as follows:

1. Installed instrumentation that is used to detect, and indicate in the control room, a significant abnormal degradation of the reactor coolant pressure boundary.
2. A process variable, design feature, or operating restriction that is an initial condition of a design-basis accident or transient analysis that assumes either the failure of or presents a challenge to the integrity of a fission product barrier.
3. A structure, system, or component that is part of the primary success path and which functions or actuates to mitigate a design-basis accident or transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.
4. A structure, system or component which operating experience or probabilistic risk assessment has shown to be significant to public health and safety.

Existing LCOs and related surveillances included as TS requirements which satisfy any of the criteria stated above must be retained in the TSs. Those TS requirements which do not satisfy these criteria may be relocated to other licensee-controlled documents.

As part of the rulemaking that revised 10 CFR 50.44, the Commission retained requirements for ensuring a mixed atmosphere, inerting Mark I and II containments, and providing hydrogen control systems capable of accommodating an amount of hydrogen generated from a metal-water reaction involving 75 percent of the fuel cladding surrounding the active fuel region in Mark III and ice condenser containments. The Commission eliminated the design-basis loss-of-coolant accident (LOCA) hydrogen release from 10 CFR 50.44 and consolidated the requirements for hydrogen and oxygen monitoring to 10 CFR 50.44 while relaxing safety classifications and licensee commitments to certain design and qualification criteria. The Commission also relocated without change the hydrogen control requirements in 10 CFR 50.34(f) to 10 CFR 50.44 and the high point vent requirements from 10 CFR 50.44 to 10 CFR 50.46a.

*3.0 Evaluation*

The ways in which the requirements and recommendations for combustible gas control were incorporated into the licensing bases of commercial nuclear power plants varied as a function of when plants were licensed. Plants that were operating at the time of the Three Mile Island (TMI), Unit 2 accident are

likely to have been the subject of confirmatory orders that imposed the combustible gas control functions described in NUREG-0737, "Clarification of TMI Action Plan Requirements," as obligations. The issuance of plant specific amendments to adopt these changes, which would remove hydrogen recombiner and hydrogen and oxygen monitoring controls from TS, supersede the combustible gas control specific requirements imposed by post-TMI confirmatory orders.

### 3.1 Hydrogen Recombiners

The revised 10 CFR 50.44 no longer defines a design-basis LOCA hydrogen release, and eliminates requirements for hydrogen control systems to mitigate such a release. The installation of hydrogen recombiners and/or vent and purge systems required by 10 CFR 50.44(b)(3) was intended to address the limited quantity and rate of hydrogen generation that was postulated from a design-basis LOCA. The Commission has found that this hydrogen release is not risk-significant because the design-basis LOCA hydrogen release does not contribute to the conditional probability of a large release up to approximately 24 hours after the onset of core damage. In addition, these systems were ineffective at mitigating hydrogen releases from risk-significant beyond design-basis accidents. Therefore, the Commission eliminated the hydrogen release associated with a design-basis LOCA from 10 CFR 50.44 and the associated requirements that necessitated the need for the hydrogen recombiners and the backup hydrogen vent and purge systems. As a result, the staff finds that requirements related to hydrogen recombiners no longer meet any of the four criteria in 10 CFR 50.36(c)(2)(ii) for retention in TS and may be relocated to other licensee-controlled documents for all plants.

### 3.2 Hydrogen Monitoring Equipment

Section 50.44(b)(1), the STS, and plant-specific TS currently contain requirements for monitoring hydrogen. Licensees have also made commitments to design and qualification criteria for hydrogen monitors in Item I.F.1, Attachment 6 of NUREG-0737 and Regulatory Guide (RG) 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident." The hydrogen monitors are required to assess the degree of core damage during a beyond design-basis accident and confirm that random or deliberate ignition has taken place. If an explosive

mixture that could threaten containment integrity exists during a beyond design-basis accident, then other severe accident management strategies, such as purging and/or venting, would need to be considered. The hydrogen monitors are needed to implement these severe accident management strategies.

With the elimination of the design-basis LOCA hydrogen release, hydrogen monitors are no longer required to mitigate design-basis accidents and, therefore, the hydrogen monitors do not meet the definition of a safety-related component as defined in 10 CFR 50.2. RG 1.97 recommends classifying the hydrogen monitors as Category 1. RG 1.97 Category 1, is intended for key variables that most directly indicate the accomplishment of a safety function for design-basis accident events and, therefore, are items usually addressed within TS. As part of the rulemaking to revise 10 CFR 50.44, the Commission found that the hydrogen monitors no longer meet the definition of Category 1 in RG 1.97. The Commission concluded that Category 3, as defined in RG 1.97, is an appropriate categorization for the hydrogen monitors because the monitors are required to diagnose the course of beyond design-basis accidents. Hydrogen monitoring is not the primary means of indicating a significant abnormal degradation of the reactor coolant pressure boundary. Section 4 of Attachment 2 to SECY-00-0198, "Status Report on Study of Risk-Informed Changes to the Technical Requirements of 10 CFR Part 50 (Option 3) and Recommendations on Risk-Informed Changes to 10 CFR 50.44 (Combustible Gas Control)," found that the hydrogen monitors were not risk-significant. Therefore, the staff finds that hydrogen monitoring equipment requirements no longer meet any of the four criteria in 10 CFR 50.36(c)(2)(ii) for retention in TS and, therefore, may be relocated to other licensee-controlled documents.

[**Note:** The elimination of Post-Accident Sampling System requirements from some plant-specific TS (and associated CLIP notices) indicated that during the early phases of an accident, safety-grade hydrogen monitors provide an adequate capability for monitoring containment hydrogen concentration. The staff has subsequently concluded that Category 3 hydrogen monitors also provide an adequate capability for monitoring containment hydrogen concentration during the early phases of an accident.]

However, because the monitors are required to diagnose the course of beyond design-basis accidents, each licensee should verify that it has, and make a regulatory commitment to maintain, a hydrogen monitoring system

capable of diagnosing beyond design-basis accidents.

### 3.3 Oxygen Monitoring Equipment (for applicable plants)

STS and plant-specific TS currently require oxygen monitoring to verify the status of the inert containment. Combustible gases produced by beyond design-basis accidents involving both fuel-cladding oxidation and core-concrete interaction would be risk-significant for plants with Mark I and II containments if not for the inerted containment atmospheres. If an inerted containment was to become de-inerted during a beyond design-basis accident, then other severe accident management strategies, such as purging and venting, would need to be considered. The oxygen monitors are needed to implement these severe accident management strategies. Oxygen concentration also appears extensively in the emergency procedure guidelines/severe accident guidelines of plants with inerted containment atmospheres.

With the elimination of the design-basis LOCA hydrogen release, the oxygen monitors are no longer required to mitigate design-basis accidents and, therefore, the oxygen monitors do not meet the definition of a safety-related component as defined in 10 CFR 50.2. RG 1.97 recommends that, for inerted containment plants, the oxygen monitors be Category 1 which is intended for key variables that most directly indicate the accomplishment of a safety function for design-basis accident events. As part of the rulemaking to revise 10 CFR 50.44, the Commission found that Category 2, as defined in RG 1.97, is an appropriate categorization for the oxygen monitors, because the monitors are required to verify the status of the inert containment. Oxygen monitoring is not the primary means of indicating a significant abnormal degradation of the reactor coolant pressure boundary. Oxygen monitors have not been shown by a probabilistic risk assessment to be risk-significant. Therefore, the staff finds that oxygen monitoring equipment requirements no longer meet any of the four criteria in 10 CFR 50.36(c)(2)(ii) for retention in TS and, therefore, may be relocated to other licensee-controlled documents.

However, for plant designs with an inerted containment, each licensee should verify that it has, and make a regulatory commitment to maintain, an oxygen monitoring system capable of verifying the status of the inert containment. In addition, separate requirements for primary containment oxygen concentration will be retained in

TS for plant designs with an inerted containment. The basis for retention of this requirement in TS is that it meets Criterion 2 of 10 CFR 50.36(c)(2)(ii) in that it is a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier. This is based on the fact that calculations typically included in Chapter 6 of Updated Final Safety Analysis Reports assume that the primary containment is inerted, that is, oxygen concentration < 4.0 volume percent, when a design basis LOCA occurs.

[The deletion of the requirements for the hydrogen recombiner and hydrogen [and oxygen] monitors resulted in numbering and formatting changes to other TS, which were otherwise unaffected by this proposed amendment. The NRC staff has confirmed that the related changes are appropriate and do not affect the technical requirements.]

#### 4.0 Verifications and Commitments

As requested by the staff in the notice of availability for this TS improvement, the licensee has addressed the following plant-specific verifications and commitments.

4.1 Each licensee should verify that it has, and make a regulatory commitment to maintain, a hydrogen monitoring system capable of diagnosing beyond design-basis accidents.

The licensee has verified that it has a hydrogen monitoring system capable of diagnosing beyond design-basis accidents. The licensee has committed to maintain the hydrogen monitors within its [specified document or program]. The licensee has [implemented this commitment or will implement this commitment by (specific date)].

4.2 For plant designs with an inerted containment, each licensee should verify that it has, and make a regulatory commitment to maintain, an oxygen monitoring system capable of verifying the status of the inert containment. (for applicable plants)

The licensee has verified that it has an oxygen monitoring system capable of verifying the status of the inert containment. The licensee has committed to maintain the oxygen monitors within its [specified document or program]. The licensee has [implemented this commitment or will implement this commitment by (specific date)].

The NRC staff finds that reasonable controls for the implementation and for subsequent evaluation of proposed changes pertaining to the above regulatory commitments are provided by the licensee's administrative processes, including its commitment management program. Should the licensee choose to incorporate a regulatory commitment into the emergency plan, final safety analysis report, or other document with established regulatory controls, the associated regulations would define the appropriate change-control and reporting requirements. The staff has determined that the commitments do not warrant the creation of regulatory requirements which would require prior NRC approval of subsequent changes. The NRC staff has agreed that NEI 99-04, Revision 0, "Guidelines for Managing NRC Commitment Changes," provides reasonable guidance for the control of regulatory commitments made to the NRC staff. (See Regulatory Issue Summary 2000-17, "Managing Regulatory Commitments Made by Power Reactor Licensees to the NRC Staff," dated September 21, 2000.) The commitments should be controlled in accordance with the industry guidance or comparable criteria employed by a specific licensee. The staff may choose to verify the implementation and maintenance of these commitments in a future inspection or audit.

#### 5.0 State Consultation

In accordance with the Commission's regulations, the [State ] State official was notified of the proposed issuance of the amendment. The State official had [(1) no comments or (2) the following comments—with subsequent disposition by the staff].

#### 6.0 Environmental Consideration

The amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (FR [citation and date]). Accordingly, the amendment meets the eligibility criteria

for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

#### 7.0 Conclusion

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

#### Model No Significant Hazards Consideration Determination

*Description of Amendment Request:* The proposed amendment deletes requirements from the Technical Specifications to maintain hydrogen recombiners and hydrogen [and oxygen] monitors. Licensees were generally required to implement upgrades as described in NUREG-0737, "Clarification of TMI [Three Mile Island] Action Plan Requirements," and Regulatory Guide (RG) 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident." Implementation of these upgrades was an outcome of the lessons learned from the accident that occurred at TMI, Unit 2. Requirements related to combustible gas control were imposed by Order for many facilities and were added to or included in the technical specifications (TS) for nuclear power reactors currently licensed to operate. The revised 10 CFR 50.44, "Standards for Combustible Gas Control System in Light-Water-Cooled Power Reactors," eliminated the requirements for hydrogen recombiners and relaxed safety classifications and licensee commitments to certain design and qualification criteria for hydrogen and oxygen monitors.

*Basis for proposed no significant hazards consideration determination:* As required by 10 CFR 50.91(a), an analysis of the issue of no significant hazards consideration is presented below:

*Criterion 1—The Proposed Change Does Not Involve a Significant Increase in the Probability or Consequences of an Accident Previously Evaluated*

The revised 10 CFR 50.44 no longer defines a design-basis loss-of-coolant

accident (LOCA) hydrogen release, and eliminates requirements for hydrogen control systems to mitigate such a release. The installation of hydrogen recombiners and/or vent and purge systems required by 10 CFR 50.44(b)(3) was intended to address the limited quantity and rate of hydrogen generation that was postulated from a design-basis LOCA. The Commission has found that this hydrogen release is not risk-significant because the design-basis LOCA hydrogen release does not contribute to the conditional probability of a large release up to approximately 24 hours after the onset of core damage. In addition, these systems were ineffective at mitigating hydrogen releases from risk-significant accident sequences that could threaten containment integrity.

With the elimination of the design-basis LOCA hydrogen release, hydrogen [and oxygen] monitors are no longer required to mitigate design-basis accidents and, therefore, the hydrogen monitors do not meet the definition of a safety-related component as defined in 10 CFR 50.2. RG 1.97 Category 1, is intended for key variables that most directly indicate the accomplishment of a safety function for design-basis accident events. The hydrogen [and oxygen] monitors no longer meet the definition of Category 1 in RG 1.97. As part of the rulemaking to revise 10 CFR 50.44 the Commission found that Category 3, as defined in RG 1.97, is an appropriate categorization for the hydrogen monitors because the monitors are required to diagnose the course of beyond design-basis accidents. [Also, as part of the rulemaking to revise 10 CFR 50.44, the Commission found that Category 2, as defined in RG 1.97, is an appropriate categorization for the oxygen monitors, because the monitors are required to verify the status of the inert containment.]

The regulatory requirements for the hydrogen [and oxygen] monitors can be relaxed without degrading the plant emergency response. The emergency response, in this sense, refers to the methodologies used in ascertaining the condition of the reactor core, mitigating the consequences of an accident, assessing and projecting offsite releases of radioactivity, and establishing protective action recommendations to be communicated to offsite authorities. Classification of the hydrogen monitors as Category 3, [classification of the oxygen monitors as Category 2] and removal of the hydrogen [and oxygen] monitors from TS will not prevent an accident management strategy through the use of the SAMGs, the emergency plan (EP), the emergency operating procedures (EOP), and site survey

monitoring that support modification of emergency plan protective action recommendations (PARs).

Therefore, the elimination of the hydrogen recombiner requirements and relaxation of the hydrogen [and oxygen] monitor requirements, including removal of these requirements from TS, does not involve a significant increase in the probability or the consequences of any accident previously evaluated.

*Criterion 2—The Proposed Change Does Not Create the Possibility of a New or Different Kind of Accident From Any Previously Evaluated*

The elimination of the hydrogen recombiner requirements and relaxation of the hydrogen [and oxygen] monitor requirements, including removal of these requirements from TS, will not result in any failure mode not previously analyzed. The hydrogen recombiner and hydrogen [and oxygen] monitor equipment was intended to mitigate a design-basis hydrogen release. The hydrogen recombiner and hydrogen [and oxygen] monitor equipment are not considered accident precursors, nor does their existence or elimination have any adverse impact on the pre-accident state of the reactor core or post accident confinement of radionuclides within the containment building.

Therefore, this change does not create the possibility of a new or different kind of accident from any previously evaluated.

*Criterion 3—The Proposed Change Does Not Involve a Significant Reduction in the Margin of Safety*

The elimination of the hydrogen recombiner requirements and relaxation of the hydrogen [and oxygen] monitor requirements, including removal of these requirements from TS, in light of existing plant equipment, instrumentation, procedures, and programs that provide effective mitigation of and recovery from reactor accidents, results in a neutral impact to the margin of safety.

The installation of hydrogen recombiners and/or vent and purge systems required by 10 CFR 50.44(b)(3) was intended to address the limited quantity and rate of hydrogen generation that was postulated from a design-basis LOCA. The Commission has found that this hydrogen release is not risk-significant because the design-basis LOCA hydrogen release does not contribute to the conditional probability of a large release up to approximately 24 hours after the onset of core damage.

Category 3 hydrogen monitors are adequate to provide rapid assessment of

current reactor core conditions and the direction of degradation while effectively responding to the event in order to mitigate the consequences of the accident. The intent of the requirements established as a result of the TMI, Unit 2 accident can be adequately met without reliance on safety-related hydrogen monitors.

[Category 2 oxygen monitors are adequate to verify the status of an inerted containment.]

Therefore, this change does not involve a significant reduction in the margin of safety. [The intent of the requirements established as a result of the TMI, Unit 2 accident can be adequately met without reliance on safety-related oxygen monitors.] Removal of hydrogen [and oxygen] monitoring from TS will not result in a significant reduction in their functionality, reliability, and availability.

Based upon the reasoning presented above and the previous discussion of the amendment request, the requested change does not involve a significant hazards consideration.

Dated at Rockville, Maryland, this 12th day of September 2003.

For the Nuclear Regulatory Commission.

**Herbert N. Berkow,**

*Director, Project Directorate IV, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 03-24204 Filed 9-24-03; 8:45 am]

**BILLING CODE 7590-01-P**

---

## SECURITIES AND EXCHANGE COMMISSION

### Submission for OMB Review; Comment Request

Upon written request, copies available from: Securities and Exchange Commission, Office of Filings and Information Services, Washington, DC 20549.

Extension:

Form T-1, OMB Control No. 3235-0110, SEC File No. 270-121.

Form T-2, OMB Control No. 3235-0111, SEC File No. 270-122.

Form T-3, OMB Control No. 3235-0105, SEC File No. 270-123.

Form T-4, OMB Control No. 3235-0107, SEC File No. 270-124.

Notice is hereby given that pursuant to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 *et seq.*) the Securities and Exchange Commission ("Commission") has submitted to the Office of Management and Budget the requests for extension of the previously approved collections of information discussed below.

Form T-1 (OMB 3235-0110; SEC File No. 270-121) is a statement of eligibility