



DEPARTMENT OF HEALTH & HUMAN SERVICES

Public Health Service

FDA/DDM HFA-305

SEP 16 2003 10 29 03 SEP 17 11 53

Food and Drug Administration  
Center for Devices and  
Radiological Health  
2098 Gaither Road  
Rockville, MD 20850

Ref: FDA Docket No. 00V-1281  
Accession No. 00A0845-01

Ms. Marguerite Mohny  
Entertainment Coordinator  
La Curacao Department Store  
1605 West Olympic Boulevard, Suite 600  
Los Angeles, California 90015

Dear Ms. Mohny:

In accordance with 21 CFR 1010.4(c)(1) notice is given that the petition of La Curacao Department Store, dated August 14, 2003, for a renewal of their variance, Number 00V-1281, from 21 CFR 1040.11(c) of the performance standard for laser products is approved. This variance will allow the introduction into commerce of the laser light show products described in paragraph D below.

A. Variance Number

00V-1281

B. Effective Date

In accordance with 21 CFR 1010.4(c)(1), this variance renewal shall become effective on the date of this letter.

C. Termination Date

This variance shall be terminated after August 17, 2005.

D. Product for Which Variance is Granted

This variance is granted for the Class IV laser light displays assembled and produced by La Curacao Department Store. The laser displays will incorporate a certified LaserMedia model LM-10 laser projection system containing a certified argon/krypton laser.

The laser light displays will be presented from a fixed installation as a store display for an indefinite duration. The effects employed may be front or rear screen projections, multiple reflection/diffraction effects, reflections from stationary mirrors, fiber optic projections, and enhanced scattering effects.

E. Provision from Which Variance is Granted

This variance is granted from 21 CFR 1040.11(c) of the performance standard for laser products requiring that each demonstration laser product shall comply with all of the applicable requirements of 21 CFR 1040.10 for a Class I, IIa, II, or IIIa laser product and shall

00V-1281

VRA 2

not permit human access to laser radiation in excess of the accessible emission limits of Class I and, if applicable, Class IIa, Class II, or Class IIIa.

**F. Conditions under Which Variance is Granted**

In lieu of the requirements referred to in Item E above, the conditions as specified below in Variance Attachment A and Variance Attachment B shall apply to the products and devices manufactured under this variance and to the shows assembled and produced under this variance.

**G. Basis for Approval of Variance**


In accordance with 21 CFR 1010.4(a)(2), it has been determined that the product is required to perform a necessary function or is intended for a special purpose which cannot be performed or accomplished with equipment meeting the requirements referred to in Item E. Suitable means of radiation safety and protection will be provided by constraints on the physical and optical design, and by warnings in the user/purchaser information.

**H. Certification Label**

The certification label required by 21 CFR 1010.2 shall be modified in accordance with 21 CFR 1010.4(d) to state: This product complies with performance standards for laser products under 21 CFR Part 1040 except with respect to those characteristics authorized by Variance Number 00V-1281 effective August 17, 2000.

This variance action is available for public disclosure in the Food and Drug Administration (FDA) Dockets Management Branch and a notice of availability will be published in the Federal Register. The variance will remain in effect until the termination date unless a determination is made that the variance should be amended or withdrawn to protect the public health and safety.

Sincerely yours,



Timothy A. Ulatowski  
Director  
Office of Compliance  
Center for Devices and  
Radiological Health

cc: FDA Division of Dockets Management, Docket No. 00V-1281

Attachments A and B

Variance Attachment A  
Variance No. 00V-1281  
LAQC (La Curacao Department Store)

1. This variance is not transferable to any other firm or person and applies only to the specific products identified in the variance.
2. All laser products, systems, shows, and projectors shall be certified to comply with applicable requirements of 21 CFR 1040.10 and the conditions of this variance and be reported as required by 21 CFR 1002.10 and 1002.12 using the reporting guides provided for such purpose. These actions shall be accomplished prior to any introduction into commerce.
3. Effects not specifically indicated in this variance approval shall not be performed. Any additional effects require the submission of an amendment request (using Form 3147 or in accordance with 21 CFR 1010.4) and the filing of product reports or supplements as applicable.
4. Laser projection systems and light shows manufactured, assembled, produced, or distributed under this variance shall not be transferred to any other party until the recipient has demonstrated that they have a variance, as required, in effect that permits them to produce certified laser light shows incorporating these laser projection systems. A notation of the recipient's variance number and its effective date, as applicable, shall be entered and retained in the records of compliance test results required by 21 CFR 1002.30.
5. Scanning, projection, or reflection of laser and collateral radiation (light show radiation) into audience or other accessible uncontrolled areas shall not be permitted except for diffuse reflections produced by the atmosphere, added atmospheric scattering media, and target screens.
6. Access to radiation levels in excess of the limits of Class I by any person other than operators, performers, or employees shall not be permitted at any point less than 3.0 meters above any surface upon which such persons are permitted to stand or 2.5 meters below or in lateral separation from any place where such persons are permitted to be. Operators, performers, and employees shall not be required or allowed to view radiation above the limits of Class I or be exposed to radiation above the limits of Class II.

7. Any product which relies on scanning to meet access, exposure, or product class limits shall incorporate a scanning safeguard system which directly senses scanner motion and which will react fast enough to preclude exceeding the applicable limit.
8. All laser light shows shall be under the direct and personal control of a trained, competent operator(s). The operator(s) shall:
  - (a) be an employee of the variance holder who shall be responsible for the training and conduct of the operator;
  - (b) be located where all beam paths can be directly observed at all times; and
  - (c) immediately terminate the emission of light show radiation in the event of any unsafe condition and, for open air shows, at the request of any air traffic control officials.
9. The maximum laser projector output power shall not exceed the level required to obtain the intended effects.
10. The projection system (i.e., the projector and all other components used to produce the lighting effects) shall be securely mounted or immobilized to prevent unintended movement or misalignment.

Electronic controls and circuits shall be adequately shielded to prevent electromagnetic sources (e.g., walkie-talkies, head-set radios, wireless microphones, cellular telephones, etc.) in the vicinity of the projector, its active projection heads, and control system(s) from causing the laser emissions to be misdirected from their intended target area.

Beam masking to prevent projections into prohibited areas or directions or overfilling of screens, beam stops, targets, etc. shall be incorporated as an inherent part of the system design. Such devices may be adjustable if the system's intended use environment requires such capability.

11. In addition to the requirements of 21 CFR 1040.10(h), the manufacturer of laser projectors/systems shall provide to parties who purchase, lease, or borrow the equipment, adequate user's instructions for safe installation and operation. These instructions shall also explain the responsibility of the recipient as an independent light show manufacturer to submit the required reports and apply for and obtain a variance from the Center for Devices and Radiological Health (CDRH) prior to the introduction into commerce of any laser light shows.

12. The requirements of 21 CFR 1002.30(a)(1) and (2) shall be accomplished through the use of written procedures for setup, alignment, testing, and performance of each show. These procedures shall be in sufficient detail to ensure compliance with 21 CFR 1040.10, the conditions of this variance, and any emergency shutdown requirements, and the control of access to radiation areas using the procedures described in the ANSI Z136.1-1993 Standard For The Safe Use of Lasers (available from The Laser Institute of America, 1242 Research Parkway, Suite 130, Orlando, Florida 32826) or any other equivalent user consensus standard and, where applicable, State or local requirements.

Laser radiation areas which can contain radiation levels above Class I or II as applicable, shall be clearly identified by the posting of warning signs and/or restricting access through physical means (such as pressure switches, photocells, barriers, guards, etc.). These requirements apply to temporary areas (such as during setup and alignment procedures) and to final or permanent areas.

The variance holder shall retain the records of these procedures and the results of all tests as required by 21 CFR 1002.31. A copy of the variance application, the approval letter, current procedures, and records relating to each particular show shall be with the operator or other responsible individual and shall be made available for inspection by FDA and other responsible authorities.

13. Advance written notification shall be made as early as possible to appropriate Federal, State, and local authorities providing show itinerary with dates and locations clearly and completely identified, and a basic description of proposed effects including a statement of the maximum power output intended. Such notifications shall be made, but not necessarily be limited, to:
  - (a) The Center for Devices and Radiological Health (CDRH), Office of Compliance (address below) and the Electro Optic Specialist responsible for the location of the show (addresses below) providing the initial and closing dates for fixed installations and the itinerary for mobile shows. In addition, unless all aspects of each show have been reported and the Accession Number(s) clearly referenced, each notice shall include detailed descriptions of each show and a listing of all effects to be performed in sufficient detail to confirm compliance with the regulations and this variance. To be considered timely, this written notice must be submitted 30 days prior to the opening of the subject show or, when the show becomes known to the manufacturer less than 30 days prior to the show date, the required information must be provided verbally in an immediate phone call to CDRH and also confirmed in the formal written notice that includes the date of the phone notification and the name of the official to whom the information was given.

- (b) The Federal Aviation Administration (FAA) and the Department of Defense (DOD) for any projections into open airspace at any time (i.e., including setup, alignment, rehearsals, performances, etc.). If the FAA or DOD objects to any laser effects, the objections shall be resolved and any conditions requested by FAA and DOD will be adhered to. If these conditions can not be met, the objectionable effects shall be deleted from the show.
  
- (c) State and local radiation control offices/agencies for all shows to be performed within their jurisdictions. All requirements of State and local law shall be satisfied and any objections raised by local authorities shall be resolved or the effects deleted.

Unless otherwise specified by regulation (e.g., variance applications), all correspondence to be provided to the CDRH shall be addressed to:

Center for Devices and Radiological Health  
Office of Compliance (HFZ-342)  
2098 Gaither Road  
Rockville, MD 20850  
Phone: Voice: (301) 594-4654  
FAX: (301) 594-4672

## REGIONAL ELECTRO-OPTICS SPECIALISTS

06/26/2003

For States: ME, NH, VT, MA, NY, CT, RI

Captain Max Lager, EOS 781-279-1675 x1754  
FDA (HFR-NE25) 781-279-1687 (fax)  
1 Montvale Avenue  
Stoneham, MA 02180-3542 [mlager@ora.fda.gov](mailto:mlager@ora.fda.gov)

For States: NJ, DE, MD, DC, VA, TN, NC, SC, GA, FL, PR, AL, MS, LA

SE Region, EOS 404-253-1171  
FDA (HFR-SE18) 404-253-1207 (fax)  
60 8th Street NE  
Atlanta, GA 30309

For States: PA, WV, KY, OH, IN, IL, MI, WI, MN, ND, SD

James E. Frye, EOS 513-679-2700 x149  
FDA (HFR-CE450) 513-679-2772 (fax)  
6751 Steger Drive  
Cincinnati, OH 45237 [jfrye@ora.fda.gov](mailto:jfrye@ora.fda.gov)

For States: IA, MO, AR, NE, KS, OK, TX, WY, CO, NM, UT

SW Region, EOS 214-253-4930  
FDA (HFR-SW19) 214-253-4960 (fax)  
4040 N. Central Expressway, Suite 900  
Dallas, TX 75204

For States: MT, ID, OR, WA, AK

Suzie Kent, EOS 208-334-1054  
FDA (HFR-PA3505) 208-334-1053 (fax)  
304 North 8th Street, Suite 147  
Boise, ID 83702 [skent@ora.fda.gov](mailto:skent@ora.fda.gov)

For States: AZ, Southern California

Frank Eng, EOS 408-291-7548 x15  
FDA (HFR-PA1530) 408-291-7228 (fax)  
96 N. Third St., Room 325  
San Jose, CA 95112 [feng@ora.fda.gov](mailto:feng@ora.fda.gov)

For States: Northern CA, NV, HI

Gary Zaharek, EOS 408-291-7548 x12  
FDA (HFR-PA1530) 408-291-7228 (fax)  
96 N. Third Street  
San Jose, CA 95112 [gzaharek@ora.fda.gov](mailto:gzaharek@ora.fda.gov)

Reserve EOS - NE Region

Emir Galevi 781-729-5700 x 724  
FDA/WEAC (HFR-NE480) 781-729-3593 (fax)  
109 Holton Street  
Winchester, MA 01890 [egalevi@ora.fda.gov](mailto:egalevi@ora.fda.gov)

Variance Attachment B  
Variance No. 00V-1281  
LAQC

This attachment provides the list of information to be provided to the Federal Aviation Administration (FAA) and the Department of Defense (DOD) in notifications of outdoor laser light shows (demonstrations) which cause projections into the sky. This information is required to permit FAA and DOD jointly to do the aeronautical study necessary to determine whether or not the proposed effects are objectionable.

CONTENT OF NOTIFICATIONS

- a. Proponent notifications to the FAA regional office will include the following information on all proposed outdoor demonstrations:
  1. Laser group/company (point of contact).
  2. Business addresses.
  3. Telephone number.
  4. CDRH Variance number and expiration date.
  5. Date(s) and time(s) of setup and alignment.
  6. Date(s) and time(s) of shows(s).
    - (a) Show length
    - (b) Running time.
  7. Location of the show.
    - (a) Show place name and address.
    - (b) Latitude and longitude of show place in Degrees, Minutes and Seconds.
    - (c) Maps (USGS 7.5 Quadrangle or acceptable alternate).
  8. Class/Type of Laser (CW or Pulsed\*)
  9. Maximum emitted power (watts)/repetition frequency (kHz) at the projector as certified to CDRH.
  10. Azimuth direction of beams.
  11. Elevation of beams in degrees above the horizon.
    - (a) maximum
    - (b) minimum
  12. Beam divergence (milliradians).
  13. Maximum distance from source for irradiance of  $2.6 \text{ mW/cm}^2$ ,  $100 \text{ } \mu\text{W/cm}^2$ , and  $5 \text{ } \mu\text{W/cm}^2$  based on maximum emitted power.
  14. Maximum altitude above source for irradiance of  $2.6 \text{ mW/cm}^2$ ,  $100 \text{ } \mu\text{W/cm}^2$ , and  $5 \text{ } \mu\text{W/cm}^2$  based on maximum emitted power.
  15. A diagram depicting all beam arrays terminated/unterminated.
  16. Laser safety officer/operator:
    - (a) Local address and phone number, to include an operational telephone number at the site.
    - (b) Additional safety procedures:
      - (1) Communications procedures during the show.
      - (2) Visual aircraft spotters.
      - (3) Other.



17. Quality Assurance Program, describing physical/procedural control of:
  - (a) laser power
  - (b) beam divergence
  - (c) azimuth and elevation of beam paths
  - (d) beam termination surfaces
  - (e) emergency shutdown procedures

Note: Repetitive pulsed laser data (e.g., equipment type, pulse duration, etc.) shall be validated by the CDRH, and shall accompany submission to the FAA.

- b. Supplementary information if applicable. Include the CDRH letter validating the measures which result in a smaller affected area than that shown in the Laser Projector Power/Range Table (Table 34-8, FAA Order 7400.2D, Chg.1).

#### SUBMISSION OF PROPOSAL

- a. The last condition of Attachment A of the variance requires that you provide written notification to the Federal Aviation Administration (FAA) and the Department of Defense (DOD) and satisfy any requirements they may specify before conducting an outdoor laser light show.
- b. In detail, this requirement means that:
  1. All notifications are to be directed to the Air Traffic Division at the FAA regional office having jurisdiction over the area where the laser show will take place.
  2. FAA needs at least 30 days advance notice to process a request and conduct an aeronautical study. The FAA recognizes that industry conditions may not always permit the advance notice desired. While FAA endeavors to accommodate all requests, proper conduct of the aeronautical study to determine airspace effects is essential to air safety. This is particularly true when the nature of the demonstration is in close proximity to an airport or would necessitate protection of large amounts of airspace. In these cases, it may be impossible for the FAA to respond to short-notice requests.
  3. Notifications are required for all demonstrations in which laser light beams may be directed or reflected into airspace (including set-up, alignment, and rehearsals). Notifications should contain sufficient technical information to allow proper evaluation. The primary concern is the range and elevation from the source of the airspace which may be affected by the display.
  4. A proponent wishing to provide supplementary information about measures which will result in a smaller actual danger area than that shown in the Laser System Range Table (Table 34-8, FAA Order 7400.2D, Chg.1) should submit the data in advance to CDRH for review. CDRH will validate the information and issue a letter to the proponent to include with their notification to the FAA.