



Iowa

Min. system size for which
an economizer is required:

Region 1: 135,000 Btu/hr

Region 2: No requirement

ASHRAE 90.1-1999 Climate Zones - DRAFT

Sep 6 14:57 2002

