



IN REPLY REFER TO: MT-450

United States Department of the Interior

BUREAU OF RECLAMATION

Great Plains Region

Montana Area Office

P.O. Box 30137

Billings, Montana 59107-0137



January 24, 2008

FAXOGRAM: Water Order Change

To: Chief, Power Supply and Billing Division, WAPA, Watertown, South Dakota
Attention: F-6001
Chief, Power Dispatching Branch, WAPA, Loveland, Colorado
Attention: J-4120
Facilities Manager, Helena, Montana
Attention: MT-682, MT669
Project Manager, Mills, Wyoming
Attention: WY-4000, WY-4100, WY-6400
PPL Energy Plus, LLC, Butte, Montana
Attention: Resource Coordinator, Lance Elias

From: Reservoir and River Operations, Billings, Montana

Subject: **Canyon Ferry Water Release Order - CFR No. 08-11**

CURRENT RESERVOIR CONDITIONS:

Elevation: 3782.27; Storage: 1,424,705 acre-feet; River Release: 3,100 cfs; Inflow: 1,310 cfs;

GENERAL COMMENTS:

A cold front is forecast to into Montana over the next few days, causing much of the water released to the Missouri River to form into ice storage. PPL-MT has requested the releases from Canyon Ferry to the Missouri River to be increased and maintained at higher flows through January 30 to enable the river to freeze over at a higher level and reduce the potential for ice jam flooding to occur. In response, the following operation changes are required at Canyon Ferry Dam and Powerplant

CANYON FERRY RELEASES AND OPERATIONS: All times are Mountain Standard Time (MST)

At 0100 hour on Saturday, January 26, 2008:

*Maintain releases through the river outlet gates at 0 cfs.
Maintain releases through the spillway gates at 0 cfs.
Increase turbine releases to 3,600 cfs (\approx 850 MW-Hrs/day using 102.1 cfs/mw).
Maintain release for Helena Valley Project at 0 cfs.
Increase average daily release to the Missouri River to about 3,600 cfs.
Increase average total release from Canyon Ferry to about 3,600 cfs.*

At 0100 hour on Thursday, January 31, 2008:

*Maintain releases through the river outlet gates at 0 cfs.
Maintain releases through the spillway gates at 0 cfs.
Decrease turbine releases to 3,100 cfs (\approx 730 MW-Hrs/day using 102.1 cfs/mw).
Maintain release for Helena Valley Project at 0 cfs.
Decrease average daily release to the Missouri River to about 3,100 cfs.
Decrease average total release from Canyon Ferry to about 3,100 cfs.*

/S/ Tim H. Felchle