

The Greenidge Multi-Pollutant Control Project: Demonstration of an Innovative Retrofit Option for Smaller Coal-Fired Power Plants

Dan Connell

CONSOL Energy Inc. Research & Development




Energy Technology Group Luncheon, Pittsburgh Section, American Chemical Society
March 20, 2008

Greenidge Multi-Pollutant Control Project

- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory
 - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO₂, mercury, acid gases (SO₃, HCl, HF), and particulate matter from smaller coal-fired EGUs

Existing U.S. Coal-Fired EGUs

50-300 MW_e



Existing U.S. Coal-Fired EGUs

50-300 MW_e

- ~ 420 units not equipped with FGD, SCR, or Hg control
 - Represent almost 60 GW of installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- Difficult to retrofit for deep emission reductions
 - Large capital costs
 - Space limitations
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - CAIR, Hg MACT, CAVR, state regulations
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)

- Dresden, NY
- Commissioned in 1953
- 107 MW_e (EIA net winter capacity)
- Reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD – mid/high-sulfur coal to meet permit limit of 3.8 lb SO₂/MMBtu




Design Objectives

- Deep emission reductions
- Low capital costs
- Small space requirements
- Applicability to high-sulfur coals
- Low maintenance requirements
- Operational flexibility

Multi-Pollutant Control Process

- Combustion modifications
 - Low-NO_x burners and overfire air
 - Installed outside of DOE scope
- NO_xOUT CASCADE[®] hybrid SNCR/SCR (Fuel Tech)
 - Urea-based, in-furnace selective non-catalytic reduction
 - Single-bed, in-duct selective catalytic reduction
- Activated carbon injection
- Turbosorp[®] circulating fluidized bed dry scrubber (Austrian Energy / Babcock Power Environmental)
- Pulsejet baghouse

Process Flow Diagram



Hybrid NO_x Control

■ Combustion Modifications

- Replace coal, combustion air, and overfire air nozzles
- Improve fuel/air mixing, burner exit velocity, secondary airflow control, and upper furnace mixing; reduce CO
- Reduce NO_x to 0.25 lb/MMBtu


■ SNCR

- $\text{CO}(\text{NH}_2)_2 + 2 \text{NO} + \frac{1}{2} \text{O}_2 \rightarrow 2 \text{N}_2 + \text{CO}_2 + 2 \text{H}_2\text{O}$
- Reduce NO_x by ~ 42.5% (to 0.144 lb/MMBtu)

■ SCR


- $4 \text{NO} + 4 \text{NH}_3 + \text{O}_2 \rightarrow 4 \text{N}_2 + 6 \text{H}_2\text{O}$
- $\text{NO} + \text{NO}_2 + 2 \text{NH}_3 \rightarrow 2 \text{N}_2 + 3 \text{H}_2\text{O}$
- Reduce NO_x by > 30% (to ≤ 0.10 lb/MMBtu)

SNCR for Hybrid System




- Hybrid SNCR operates at lower temperature than stand-alone SNCR
 - Enables greater NO_x reduction and better urea utilization by SNCR
 - Provides ammonia slip for additional NO_x reduction by SCR

Single-Bed, In-Duct SCR



- Compact design
 - Bed depth ~ 1.3 m
 - Cross section ~ 45' x 14'
- No ammonia injection grid
- Designed for lower NO_x removal efficiency than conventional SCR
- Includes Delta Wing™ static mixers to improve reagent, flow, temperature, and ash distribution

Turbosorp[®] System




- Completely dry
- Separate control of hydrate, water, and recycled solid injection
- High solids recirculation
- Applicable to high-sulfur coals
- 15-25% lower reagent consumption than spray dryers
- Low capital and maintenance costs relative to other FGD technologies

Circulating Fluidized Bed Dry Scrubber Chemistry




AES Greenidge Installation




- Small footprint
- Carbon steel construction
- Includes:
 - Activated carbon injection system
 - Onsite lime hydration system
 - Eight-compartment pulsejet fabric filter
 - Booster fan
- Uses existing stack (liner not required)
- Projected Ca/S is 1.6-1.7 mol/mol for design fuel

Design Features for Mercury Control



Project Schedule



2002-2005

2006

2007

2008

Pre-Award Activities

Design/Procurement

Construction

Sign Cooperative Agreement (5/19)

Tie-In Outage

Operation & Testing

Guarantee

Process Performance

Follow-up

Guarantee Tests


March-May 2007, 2.4-3.2% Sulfur Eastern U.S. Bituminous Coal

Parameter	Performance Target	Measured Performance
NO _x emission rate	≤ 0.10 lb/mmBtu	0.10 lb/mmBtu*
SO ₂ removal	≥ 95%	96%
Hg removal	≥ 90%	
Activated C Injection		≥94%
No Activated C Injection		≥95%
SO ₃ removal	≥ 95%	97%
HCl removal	≥ 95%	97%
HF removal	≥ 95%	Indeterminate

* Performance of hybrid NO_x control system has been affected by large particle ash and ammonia slip. Plant typically operates at 0.10-0.15 lb/mmBtu to maintain acceptable combustion characteristics.

NO_x Emission Rate


March 28, 2007



NO_x Removal Across SCR


March 28, 2007 – Three-Test Average

SCR – Top View



Ammonia Slip Testing Results

EPA CTM 027, Air Heater Inlet




O&M Experience – Large Particle Ash




- Decreased NO_x removal efficiency
- Increased urea consumption, ammonia slip
- Increased pressure drop
- Forced outages for catalyst cleaning

O&M Experience – Large Particle Ash (continued)




NO_x Emissions vs. Load

January 2008




SO₂ Removal Performance

January 2008




Turbosorp[®] System Turndown



Hydrated Lime Utilization


October 2007 Testing

■ Product Ash Analysis ◆ Hydrator Data



Hg Testing Results

Ontario Hydro Method




Plant Conditions During Hg Tests

Parameter	Range
Coal Hg content (lb / TBtu)	6.4 – 13.7
Coal S content (lb SO ₂ / mmBtu)	3.7 – 4.9
Coal Cl content (wt. %, dry)	0.07 – 0.11
Gross generation (MW)	56.4 – 108.7
Fly ash unburned carbon (%)	9.2 – 25.3
Activated carbon injection rate (lb / mmacf)	0 - 3
SO ₂ removal efficiency (%)	92.9 – 99.0
Scrubber outlet temperature (°F)	158.6 – 165.2


SO₃ Testing Results

Controlled Condensation Method




HCl Testing Results

EPA Method 26A



Particulate Testing Results

EPA Method 5/17, Full Load



New baghouse significantly reduces particulate matter emissions relative to old ESP, in spite of increased particle loading from Turbosorp[®] scrubber

Error bars represent ± 1 standard deviation

Turbosorp[®] Product Ash

- Similar to spray dryer ash
- Dry powder (~1% moisture)
- Contains CaSO_3 , CaSO_4 , fly ash, CaCO_3 , $\text{Ca}(\text{OH})_2$, CaO , CaCl_2 , CaF_2 , inerts
- AES Greenidge sends to landfill (adjacent to plant site)
- Potential uses
 - Mine reclamation
 - Structural / flowable fill
 - Manufactured aggregate
- Leachable Hg (EPA Method 1312) is below detection limit
 - <1.2 % of total Hg in ash (3 samples)



O&M Experience - Turbosorp®

- Lime hydration system
 - Most maintenance-intensive part of Turbosorp® system
 - Can use delivered / stored hydrate to allow offline maintenance
 - Issues encountered to-date
 - Plugging in hydrated lime classifier
 - Water overfed to hydrator
 - Freezing of lines and valves
 - Balls escaped from ball mill
 - Failed bucket elevator shaft
 - Improvements
 - Adjusted classifier rotary feeder to reduce accumulation of fines
 - Modified logic for hydrator water feed
 - Increased onsite hydrate storage capacity



O&M Experience - Turbosorp[®]

(continued)

- Turbosorp[®] water injection lance
 - Changed about once per week
 - Retrofitted with high pressure quick disconnects
- Ash recycle and disposal system
 - Ash silo vents tend to plug
 - Some problems with freezing / clogging dosing valves
- Baghouse
 - Compressed air demand greater than expected
 - Temporary / permanent compressor capacity added
- No condensation issues encountered in absorber or baghouse



Economics

AES Greenidge Design Case

Constant 2005 Dollars

	EPC Capital Cost (\$/kW)	Fixed & Variable O&M Cost (\$/MWh)	Total Levelized Cost
NO _x Control	114 ^a	1.25	\$3,504 / ton NO ₂
SO ₂ Control	229 ^b	6.14	\$567 / ton SO ₂
Hg Control (incremental)	6	0 ^c	\$1,567 / lb Hg

^aIncludes combustion modifications, SNCR, in-duct SCR, static mixers, and LPA removal system

^bIncludes scrubber, process water system, lime storage and hydration system, baghouse, ash recirculation system, and booster fan

^cBased on performance testing results to-date

Assumptions: Plant size = 107 MW net, Capacity factor = 80%, Coal sulfur = 4.0 lb SO₂/mmBtu, SNCR NSR = 1.35, Ca/S = 1.65, 50% Urea = \$1.35/gal, Quicklime = \$115/ton, Waste disposal = \$17/ton, Internal COE = \$40/MWh, Plant life = 20 years, Fixed charge factor = 13.05%, AFUDC = 2.35%, Other assumptions based on Greenidge design basis, common cost estimating practices, and market prices

Economics

NO_x Control

	\$/MWh	\$/ton NO ₂ removed
Levelized Capital (TCR)	\$2.24	\$2,252
Fixed O&M	\$0.39	\$395
Variable O&M	\$0.85	\$858
Urea	\$0.62	\$626
Replacement Catalyst	\$0.17	\$168
Power/Water	\$0.06	\$64
Total Levelized Cost	\$3.49	\$3,504

- Improved dispatch economics relative to purchasing allowances

Economics

SO₂ Control

	\$/MWh	\$/ton SO ₂ removed
Levelized Capital (TCR)	\$4.54	\$241
Fixed O&M	\$0.88	\$47
Variable O&M	\$5.26	\$279
Lime + Waste Disposal	\$4.53	\$241
Power/Water	\$0.61	\$32
Baghouse Bags/Cages	\$0.12	\$6
Total Levelized Cost	\$10.68	\$567

- Improved dispatch economics relative to purchasing allowances
- Hg, acid gas, and improved primary particulate control for “free”

Summary

- Greenidge MPC process uniquely designed to meet needs of smaller coal-fired units

- Deep emission reductions
- Low capital costs
- Small space requirements
- Applicability to high-sulfur coals
- Low maintenance requirements
- Operational flexibility
- Improved dispatch economics



- Performance testing results to-date are generally encouraging

- Demonstrated attainment of performance guarantees for NO_x , SO_2 , Hg, and acid gases
- SO_2 removal efficiencies >95% routinely achieved
- All tests have shown >90% Hg capture without ACI
- Particulate matter emissions significantly reduced

Summary

- O&M challenges thus far
 - Large particle ash plugging in-duct SCR catalyst
 - Difficult to attain 0.10 lb/mmBtu NO_x emissions while maintaining good combustion, low ammonia slip
 - Lime hydration system is rather maintenance intensive



- Additional testing planned through summer 2008
 - Reduced load testing
 - Parametric scrubber testing
 - Follow-up testing

Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.