

Design of an Integrated Multi-Pollutant Control System for Reducing Emissions of SO₂, NO_x, Hg, Acid Gases, and Particulate Matter from Smaller Coal-Fired Power Plants

Daniel P. Connell

CONSOL Energy Inc. Research & Development

Douglas J. Roll, P.E., and William B. Rady

AES Greenidge LLC

Richard F. Abrams

Babcock Power Environmental Inc.

AFS Fall Topical Conference
Separations Processes for the Power Generation Industry
October 17-18, 2006, Pittsburgh, PA

The Greenidge Multi-Pollutant Control Project

■ Power Plant Improvement Initiative


- Cost-shared collaboration between U.S. DOE and industry
- Commercial demonstration of coal-based technologies
- Goal: Help to ensure the reliability of the nation's energy supply by improving the efficiency, cost-competitiveness, and environmental performance of new and existing coal-fired electric generating facilities

■ Greenidge Project

- DOE Cooperative Agreement signed May 2006
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x , SO_2 , mercury, acid gases (SO_3 , HCl , HF), and particulate matter from smaller coal-fired power plants

Existing U.S. Coal-Fired EGUs

50-300 MW_e



Existing U.S. Coal-Fired EGUs


50-300 MW_e

- ~ 440 units not equipped with FGD or SCR
 - Represent ~ 60 GW of installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- Difficult to retrofit for deep emission reductions
 - Large capital costs
 - Space limitations
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - CAIR, CAMR, state regulations
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)

- Dresden, NY
- Commissioned in 1953
- 107 MWe (net) reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Current emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD - mid-sulfur coal to meet permit limit of 3.8 lb/MMBtu

AES Greenidge Unit 4 (Boiler 6)



Multi-Pollutant Control Process

- Combustion modifications (outside DOE scope)
- Hybrid SNCR / SCR
 - Urea-based, in-furnace selective non-catalytic reduction
 - Single-bed, in-duct selective catalytic reduction
- Activated carbon injection
- Turbosorp[®] circulating fluidized bed dry scrubber
- Baghouse

Greenidge Project Performance Targets


Fuel: 2-4% sulfur bituminous coal, up to 10% biomass

| Parameter | Goal |
|---------------------------|-----------------------------|
| NO _x | ≤ 0.10 lb/MMBtu (full load) |
| SO ₂ | ≥ 95% removal |
| Hg | ≥ 90% removal |
| SO ₃ , HCl, HF | ≥ 95% removal |


Capital (EPC) Cost: ~ \$330 / kW

Footprint: ~ 0.4 acre


Organization



Project Schedule



Process Flow Diagram



Hybrid NO_x Control

■ Combustion Modifications

- Replace coal, combustion air, and overfire air nozzles
- Improve fuel/air mixing, burner exit velocity, secondary airflow control, and upper furnace mixing; reduce CO
- Reduce NO_x to 0.25 lb/MMBtu


■ SNCR

- $\text{CO}(\text{NH}_2)_2 + 2 \text{NO} + \frac{1}{2} \text{O}_2 \rightarrow 2 \text{N}_2 + \text{CO}_2 + 2 \text{H}_2\text{O}$
- Reduce NO_x by ~ 42.5% (to 0.144 lb/MMBtu)

■ SCR

- $4 \text{NO} + 4 \text{NH}_3 + \text{O}_2 \rightarrow 4 \text{N}_2 + 6 \text{H}_2\text{O}$
- $6 \text{NO}_2 + 8 \text{NH}_3 \rightarrow 7 \text{N}_2 + 12 \text{H}_2\text{O}$
- Reduce NO_x by > 30% (to ≤ 0.10 lb/MMBtu)

SNCR for Hybrid System




■ Greenidge Design:


- 2 Levels of Wall Injectors (Higher Temperature)
- 2 Multiple Nozzle Lances in Convective Pass (Lower Temperature)

Delta Wing™ Static Mixers

- Homogeneous flue gas at catalyst face
 - $\text{NO}_x / \text{NH}_3$ mole ratio $\pm 5\%$ RMS deviation
 - Velocity $\pm 12\%$ RMS deviation
 - Temperature ± 30 °F
- Minimize NH_3 slip
- Maintain mixing at reduced load operation
- Maintain ash entrainment and distribution



Single-Bed, In-Duct SCR



Bed Depth

~ 1.3 m

SO₂ → SO₃

< 1.0 %


NH₃ Slip

< 2 ppmv

NO_x Removal

> 30%

Circulating Fluidized Bed Dry Scrubber Process Concept




- Completely dry
- Separate control of reagent, water, and recycled solid injection
- High solids recirculation
- Applicable to high-sulfur coals
- 15-25% lower reagent consumption than SDA
- Low capital and maintenance costs relative to other FGD technologies

Circulating Fluidized Bed Dry Scrubber Chemistry



Reactivation of Recycled Reagent



Reaction after first pass

Water added to surface during recirculation

Sulfite crystal forms, exposing fresh surfaces

Turbosorp[®] System at AES Greenidge



- On-site lime hydration system
- 8-compartment pulse jet fabric filter
- Projected Ca/S of 1.5-1.6

Mercury Control

- Expect $\geq 90\%$ removal with low carbon injection rate
 - Similarity to SCR / SDA / FF with bituminous coal
 - Field sampling shows 90% Hg removal often achieved with no ACI
 - Projected activated carbon requirement: 0 – 3.5 lb/MMacf
- SCR catalyst
 - Oxidize Hg^0 to Hg^{2+}
- Activated carbon injection
 - Adsorb Hg^0 and Hg^{2+}
- Circulating fluidized bed dry scrubber / baghouse
 - Reduce temperature (~ 170 °F)
 - Facilitate contact between Hg and carbon, fly ash, $\text{Ca}(\text{OH})_2$
 - Filter caking
 - Recirculation = high sorbent residence time

Challenges / Uncertainties

- Performance with 2-4% sulfur eastern bituminous coal
 - Ammonium bisulfate formation / fouling
 - SO₂ capture and required Ca/S ratio
- Hg removal performance
 - Extent of Hg⁰ oxidation at high space velocities in single-bed catalyst
 - Carbon injection requirements
- Control of integrated system, especially during load swings / cycling
 - Effect of NH₃ slip on unit operability
- Effect of biomass co-firing

Concluding Thoughts

- Innovative approach to multi-pollutant control that provides a low-capital-cost retrofit option for smaller coal-fired units
 - Emission reduction targets:
(2-4% sulfur coal, up to 10% biomass)
 - NO_x to ≤ 0.10 lb/MMBtu
 - SO₂ and acid gases by > 95%
 - Hg by > 90%
 - Improved control of fine particulate matter
 - Capital cost: ~ \$330/kW (delivered + erected) for 100 MW unit
 - Footprint: ~ 0.4 acres for 100 MW unit
 - Operational flexibility
- Actual performance data will be available soon
 - System fully operational by beginning of 2007
 - Initial performance results in early-to-mid 2007
 - Long-term performance results and actual operating costs in mid-2008