

AES Greenidge Multi-Pollutant Control Project

Douglas J. Roll, P.E., and William B. Rady

AES Greenidge LLC

Daniel P. Connell

CONSOL Energy Inc. Research & Development

Richard F. Abrams

Babcock Power Environmental Inc.

Air & Waste Management Luncheon Meeting

December 13, 2006

Rochester, New York

The Greenidge Multi-Pollutant Control Project

■ Power Plant Improvement Initiative

- Cost-shared collaboration between U.S. DOE and industry
- Commercial demonstration of coal-based technologies
- Goal: Help to ensure the reliability of the nation's energy supply by improving the efficiency, cost-competitiveness, and environmental performance of new and existing coal-fired electric generating facilities


■ Greenidge Project

- DOE Cooperative Agreement signed May 2006
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x , SO_2 , mercury, acid gases (SO_3 , HCl , HF), and particulate matter from smaller coal-fired power plants

AES Greenidge Unit 4 (Boiler 6)

- Dresden, NY
- Commissioned in 1953
- 107 MWe (net) reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Current emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD - mid-sulfur coal to meet permit limit of 3.8 lb/MMBtu

AES Greenidge Unit 4 (Boiler 6)





Multi-Pollutant Control Process

- Combustion modifications
- Hybrid SNCR / SCR
 - Urea-based, in-furnace selective non-catalytic reduction
 - Single-bed, in-duct selective catalytic reduction
- Activated carbon injection
- Turbosorp[®] circulating fluidized bed dry scrubber
- Baghouse

Greenidge Project Performance Targets


Fuel: 2-4% sulfur bituminous coal, up to 10% biomass

Parameter	Goal
NO _x	≤ 0.10 lb/MMBtu (full load)
SO ₂	≥ 95% removal
Hg	≥ 90% removal
SO ₃ , HCl, HF	≥ 95% removal


Capital (EPC) Cost: ~ \$330 / kW

Footprint: ~ 0.4 acre


Organization



Project Schedule



Process Flow Diagram



Hybrid NO_x Control

■ Combustion Modifications

- Replace coal, combustion air, and overfire air nozzles
- Improve fuel/air mixing, burner exit velocity, secondary airflow control, and upper furnace mixing; reduce CO
- Reduce NO_x to 0.25 lb/MMBtu


■ SNCR

- $\text{CO}(\text{NH}_2)_2 + 2 \text{NO} + \frac{1}{2} \text{O}_2 \rightarrow 2 \text{N}_2 + \text{CO}_2 + 2 \text{H}_2\text{O}$
- Reduce NO_x by ~ 42.5% (to 0.144 lb/MMBtu)

■ SCR

- $4 \text{NO} + 4 \text{NH}_3 + \text{O}_2 \rightarrow 4 \text{N}_2 + 6 \text{H}_2\text{O}$
- $6 \text{NO}_2 + 8 \text{NH}_3 \rightarrow 7 \text{N}_2 + 12 \text{H}_2\text{O}$
- Reduce NO_x by > 30% (to ≤ 0.10 lb/MMBtu)

SNCR for Hybrid System




- Greenidge Design:


- 2 Levels of Wall Injectors (Higher Temperature)
- 2 Multiple Nozzle Lances in Convective Pass (Lower Temperature)

Delta Wing™ Static Mixers

- Homogeneous flue gas at catalyst face
 - $\text{NO}_x / \text{NH}_3$ mole ratio $\pm 5\%$ RMS deviation
 - Velocity $\pm 12\%$ RMS deviation
 - Temperature ± 30 °F
- Minimize NH_3 slip
- Maintain mixing at reduced load operation
- Maintain ash entrainment and distribution



Single-Bed, In-Duct SCR



Bed Depth

~ 1.3 m

SO₂ → SO₃

< 1.0 %

NH₃ Slip

< 2 ppmv

NO_x Removal

> 30%




10/13/2006



12/01/2006

Circulating Fluidized Bed Dry Scrubber Process Concept



- Completely dry
- Separate control of reagent, water, and recycled solid injection
- High solids recirculation
- Applicable to high-sulfur coals
- 15-25% lower reagent consumption than SDA
- Low capital and maintenance costs relative to other FGD technologies

Turbosorp[®] System at AES Greenidge



- On-site lime hydration system
- 8-compartment pulse jet fabric filter
- Projected Ca/S of 1.5-1.6

Mercury Control

- Expect $\geq 90\%$ removal with low carbon injection rate
 - Similarity to SCR / SDA / FF with bituminous coal
 - Field sampling shows 90% Hg removal often achieved with no ACI
 - Projected activated carbon requirement: 0 – 3.5 lb/MMacf
- SCR catalyst
 - Oxidize Hg^0 to Hg^{2+}
- Activated carbon injection
 - Adsorb Hg^0 and Hg^{2+}
- Circulating fluidized bed dry scrubber / baghouse
 - Reduce temperature (~ 170 °F)
 - Facilitate contact between Hg and carbon, fly ash, $\text{Ca}(\text{OH})_2$
 - Filter caking
 - Recirculation = high sorbent residence time



12/08/2006