

Mercury Removal Performance of the Greenidge Multi-Pollutant Control System



Daniel P. Connell and James E. Locke
CONSOL Energy Inc., Research & Development



Douglas J. Roll, P.E.
AES Greenidge LLC



Wolfe P. Huber, P.E.
*U.S. Department of Energy, National Energy
Technology Laboratory*



Richard F. Abrams
Babcock Power Environmental Inc.

Greenidge Multi-Pollutant Control Project

- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory
 - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO₂, mercury, acid gases (SO₃, HCl, HF), and particulate matter from smaller coal-fired EGUs

Existing U.S. Coal-Fired EGUs

50-300 MW_e



Existing U.S. Coal-Fired EGUs

50-300 MW_e

- ~ 420 units not equipped with FGD, SCR, or Hg control
 - Represent almost 60 GW of installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- Difficult to retrofit for deep emission reductions
 - Large capital costs
 - Space limitations
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - CAIR, CAMR, CAVR, state regulations
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)

- Dresden, NY
- Commissioned in 1953
- 107 MW_e (net) reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD – mid/high-sulfur coal to meet permit limit of 3.8 lb SO₂/MMBtu



Design Objectives

- Deep emission reductions
- Low capital costs
- Small space requirements
- Applicability to high-sulfur coals
- Low maintenance requirements
- Operational flexibility

Multi-Pollutant Control System

- Combustion modifications
 - Low-NO_x burners and overfire air
- Hybrid SNCR / SCR
 - Single-bed, in-duct SCR fed by NH₃ slip from urea-based SNCR



- Activated carbon injection
- Turbosorp[®] circulating fluidized bed dry scrubber
 - Separate injection of water and dry hydrated lime
 - Includes onsite lime hydrator
- Pulsejet baghouse
 - ~95% of solids recycled to scrubber via air slides
 - Booster fan installed downstream


Guarantee Testing Results

March – May 2007, 2.4-3.2% Sulfur Eastern U.S. Bituminous Coal

Parameter	Performance Target	Measured Performance
NO _x emission rate	≤ 0.10 lb/mmBtu	0.10 lb/mmBtu*
SO ₂ removal	≥ 95%	96%
SO ₃ removal	≥ 95%	97%
HCl removal	≥ 95%	97%
HF removal	≥ 95%	Indeterminate

* Performance of hybrid NO_x control system has been affected by large particle ash and ammonia slip. Plant typically operates at 0.10-0.15 lb/mmBtu to maintain acceptable combustion characteristics.

Design Features for Mercury Control



Hg Reduction Target: $\geq 90\%$ (coal-to-stack)

Mercury Testing Methodology

■ Flue gas measurements

- Ontario Hydro Method (ASTM D 6784-02)
- Liquid samples analyzed by CVAAS (3/07) or CVAFS (10/07-11/07)
- Particulate samples analyzed per ASTM D 6414 or ASTM D 6722

■ Coal samples


- Collected at beginning / middle of each test (composite of all feeders)
- Analyzed for Hg by ASTM D 6722

■ QA/QC

- Pre- and post-test leak checks
- O₂ monitored at meter exhaust
- ICV standards, duplicate/triplicate analyses, matrix spikes, digestion duplicates, digestion spikes; 100±10% RPD or recovery required
- Material balance performed for each test




Mercury Removal Efficiency



Plant Conditions During Hg Tests


Parameter	Range
Coal Hg content (lb / TBtu)	6.4 – 13.7
Coal S content (lb SO ₂ / mmBtu)	3.7 – 4.9
Coal Cl content (wt. %, dry)	0.07 – 0.11
Gross generation (MW)	56.4 – 108.7
Fly ash unburned carbon (%)	9.2 – 25.3
Activated carbon injection rate (lb / mmacf)	0 - 3
SO ₂ removal efficiency (%)	92.9 – 99.0
Scrubber outlet temperature (°F)	158.6 – 165.2

Mercury Material Balances



* Preliminary Result

Mercury Reduction Over Baseline Full-Load Data



Leachability of Captured Hg from Turbosorp[®] Product Ash

Synthetic Precipitation Leaching Procedure (EPA Method 1312)

	11/14/07	11/15/07	11/16/07
Hg in product ash sample, mg/kg	0.464	0.602	0.667
Hg leached from sample, mg/kg	<0.007	<0.007	<0.007
Hg leached from sample, %	<1.51	<1.16	<1.05

Process Economics

Constant 2005 Dollars

	Capital Cost (\$/kW)	Fixed & Variable O&M Cost (\$/MWh)	Total Levelized Cost (\$/ton removed)
NO _x Control	106	1.19	\$3,290 / ton NO ₂
SO ₂ Control	229	5.23	\$513 / ton SO ₂
Hg Control (incremental) ^a	0	0	0

Assumptions: Plant size = 107 MW, Capacity factor = 80%, Coal sulfur = 4.0 lb SO₂/mmBtu, Baseline NO_x emission rate = 0.30 lb/mmBtu, SNCR normalized stoichiometric ratio = 1.5, Ca/S = 1.55, Quicklime = \$110/ton, Urea (50% w/w) = \$1.25/gal, Waste disposal = \$12/ton, Plant life = 20 years, Fixed charge factor = 13.05%, Other assumptions based on common estimating practices and current market prices

^aBased on performance testing results to-date

Conclusions

- Greenidge MPC process uniquely designed to meet needs of smaller coal-fired units
 - Demonstrated > 95% SO₂ removal and > 60% NO_x removal with capital cost of ~ \$340/kW and footprint of ~ 0.5 acre for 107 MW unit
 - Deep SO₃ and HCl removal and reduced PM emissions are zero cost co-benefits
- Testing results have shown deep Hg removal efficiency
 - Greater than 90% removal efficiency observed in all 19 tests completed thus far, regardless of operating conditions
 - Average demonstrated full-load removal efficiency (> 96%) represents > 94% reduction over baseline
- Projected incremental cost for 90% Hg capture is \$0
 - Ten full-load tests and four reduced-load tests have shown > 90% Hg capture with no activated carbon injection

Future Plans

- Testing and evaluation will continue at AES Greenidge Unit 4 through October 2008
- Additional Hg tests will focus on:
 - Hg removal with biomass co-firing
 - Hg speciation and role of the in-duct SCR in oxidizing Hg
 - Hg removal as a function of fly ash unburned carbon content, fuel, load, and scrubber operating conditions
 - Stability of the captured Hg in the scrubber solids / ash



Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.