

Initial Cost and Performance Results from the Greenidge Multi-Pollutant Control Project

Daniel P. Connell

CONSOL Energy Inc. Research & Development

Douglas J. Roll, P.E., and William B. Rady

AES Greenidge LLC

Richard F. Abrams

Babcock Power Environmental Inc.

Wolfe P. Huber, P.E.

U.S. Department of Energy, National Energy Technology Laboratory


Greenidge Multi-Pollutant Control Project



- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory
 - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO₂, mercury, acid gases (SO₃, HCl, HF), and particulate matter from smaller coal-fired power plants

Existing Coal-Fired EGUs

50-300 MW_e




Existing Coal-Fired EGUs

50-300 MW_e


- ~ 440 units not equipped with FGD, SCR, or Hg control
 - Represent ~ 60 GW of installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - CAIR, CAMR, CAVR, state regulations
- Difficult to retrofit for deep emission reductions
 - Large capital costs
 - Space limitations
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)

- Dresden, NY
- Commissioned in 1953
- 107 MW_e (net) reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD - mid-sulfur coal to meet permit limit of 3.8 lb SO₂/MMBtu



AES Greenidge Unit 4 (Boiler 6)



Unit 4
(Boiler 6)

Unit 4 Stack


Unit 4
Existing ESP

Demonstration
Site

Multi-Pollutant Control Process

- Combustion modifications (outside DOE scope)
- Hybrid SNCR / SCR
 - Urea-based, in-furnace selective non-catalytic reduction
 - Single-bed, in-duct selective catalytic reduction
- Activated carbon injection
- Turbosorp[®] circulating fluidized bed dry scrubber
- Baghouse

Process Flow Diagram



Single-Bed SCR




Reactor Cross Section: 45' x 14'

Bed Depth: 1330 mm



- Fed by NH_3 slip from SNCR
- NO_x Reduction: $\geq 30\%$
- $\text{SO}_2 \rightarrow \text{SO}_3$: $\leq 1.0\%$
- NH_3 slip from SCR: ≤ 2 ppmv

Turbosorp[®] System



- Completely dry
- Separate control of reagent, water, and recycled solid injection
- High solids recirculation
- Applicable to high-sulfur coals
- 15-25% lower reagent consumption than SDA
- Low capital and maintenance costs relative to other FGD technologies

Performance Targets

Fuel: 2-4% sulfur bituminous coal, up to 10% biomass

Parameter	Goal
NO_x	≤ 0.10 lb/MMBtu (full load)
SO_2	$\geq 95\%$ removal
Hg	$\geq 90\%$ removal
SO_3 , HCl, HF	$\geq 95\%$ removal

Assumptions

Base Plant

Plant Size	107 MW _e (net)
Fuel	90% coal / 10% biomass
Fuel HHV	12,426 Btu/lb
Fuel Sulfur Content	2.5% (w/w as fired)
Baseline NO _x Emissions	0.30 lb/MMBtu (as NO ₂)
Annual Capacity Factor	80%

Assumptions

Financing

- Constant 2005 dollars
- 20-year plant life
- 1.67-year construction period
- 7.09% discount rate (before tax)
 - 45% debt @ 9% nominal return
 - 10% preferred stock @ 8.5% nominal return
 - 45% common stock @ 12% nominal return
 - 3.0% inflation
- Tax Rates
 - 35% federal, 4% state, 2% property

Fixed Charge Factor: 13.05%
AFUDC: 2.35%

Assumptions

O&M Costs

Urea (50% w/w, \$/gal)	\$1.25
Quicklime (\$/ton)	\$110
Powdered Activated Carbon (\$/lb)	\$0.45
Electricity (\$/MWh)	\$30
Plant Service Water (\$/1000 gal)	\$0.20
Replacement Catalyst (\$/layer)	\$300,000
Baghouse Bags/Cages (\$/bag+cage)	\$140
Waste Disposal (\$/ton)	\$12
Operating Labor (\$/hr)	\$35

Economic Projections

Overall System – Summary

	\$MM/y	\$/MWh
Levelized Capital	\$5.02	\$6.70
Fixed O&M	\$0.88	\$1.17
Variable O&M	\$4.23	\$5.64
Total Levelized Cost	\$10.13	\$13.51

Economic Projections

Overall System – Capital

	\$MM	\$/kW _{net}
Total Plant Cost (TPC)	\$36.3	\$339
Total Plant Investment (TPI)	\$37.2	\$347
Total Capital Requirement (TCR)	\$38.5	\$360

- ~40% less than estimated cost of \$540/kW_{net} for full SCR + wet scrubber

Notes:


TPI = TPC x (100% + AFUDC), TCR = TPI + Pre Production Cost + Inventory Capital,
Pre-Production Cost = 0.02 x TPI + (Annual O&M Cost) ÷ 12, Inventory Capital = 0.005 x TPC,
Full SCR + wet scrubber cost estimated using Integrated Environmental Control Model

Economic Projections

Overall System – Fixed O&M

Assumptions


- Operating Labor
 - 16 h/day
- Maintenance Labor & Materials
 - 1.5% of TPC
 - 40% labor, 60% materials
- Administrative & Support Labor
 - 30% of total labor



- Fixed O&M costs expected to be less than for competing technologies
- Actual costs will be determined during 20-month operation period

Economic Projections


Overall System – Variable O&M



Assumptions: SNCR NSR = 1.50, catalyst life = 3 yr, Ca/S molar ratio (inlet SO₂) = 1.55, CaO purity = 95% (w/w), PAC feed rate = 3.5 lb/MMacf, baghouse bag / cage life = 5 yr

Variable O&M Costs

Sensitivity to Urea and Lime Consumption



Variable O&M Costs

Mercury Control

- System design favors high baseline Hg removal without activated carbon injection
 - Hg oxidation across in-duct SCR catalyst
 - Low temperature (~170 °F) in scrubber / baghouse
 - High residence time for fly ash and Ca(OH)₂ in scrubber / baghouse
 - Similar to SCR / SDA / FF with bituminous coal
 - Field sampling shows 90% Hg removal often achieved with no ACI
- Expect $\geq 90\%$ removal with low carbon injection rate
 - Projected activated carbon requirement: 0.0 – 3.5 lb/MMacf
- Economic projections assume maximum rate
 - Activated carbon accounts for \$0.37/MWh of variable O&M cost
 - Actual cost likely to be less than this - will be determined as part of DOE demonstration project

Economic Projections

NO_x Control Only

	\$/MWh	\$/ton NO ₂ removed
Levelized Capital	\$2.08	\$2,086
Fixed O&M	\$0.36	\$365
Variable O&M	\$0.83	\$839
Urea	\$0.64	\$643
Replacement Catalyst	\$0.13	\$134
Power/Water	\$0.06	\$62
Total Levelized Cost	\$3.27	\$3,290

- Improved dispatch economics relative to purchasing allowances

Economic Projections


SO₂ Control Only

	\$/MWh	\$/ton SO ₂ removed
Levelized Capital	\$4.52	\$238
Fixed O&M	\$0.79	\$42
Variable O&M	\$4.44	\$233
Lime + Waste Disposal	\$3.90	\$205
Power/Water	\$0.42	\$22
Baghouse Bags/Cages	\$0.12	\$6
Total Levelized Cost	\$9.75	\$513

- Improved dispatch economics relative to purchasing allowances
- Acid gas control and improved primary particulate control for “free”

SO₂ Control Costs

Sensitivity to Coal Sulfur Content



Conclusions

Greenidge Multi-Pollutant Control System

- Capital cost of \$339/kW_{net} for 107 MW unit (2005\$)
 - About 40% less than estimated cost of full SCR + wet scrubber
- Projected total levelized cost of \$13.51/MWh (2.5%-sulfur fuel)
- Footprint of < 0.5 acre
- Deep emission reductions
 - NO_x to ≤ 0.10 lb/MMBtu (full load)
 - SO₂ and acid gases by ≥ 95%
 - Hg by ≥ 90%
- Helps to enable 20-30 year life extension
- Improves dispatch economics



Project Status and Plans

- System started up in early 2007
- 20-month period of operation and testing underway
- Specific goals:
 - Confirm emissions reduction performance
 - Determine / optimize reagent consumption rates
 - Characterize Hg removal co-benefits, ACI requirements
 - Determine actual fixed O&M costs
 - Assess effects of fuel / load
 - Evaluate balance-of-plant impacts

Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.