

The Greenidge Multi-Pollutant Control Project: Performance and Cost Results from the First Year of Operation



Daniel P. Connell and James E. Locke
CONSOL Energy Inc., Research & Development



Douglas J. Roll, P.E.
AES Greenidge LLC



Richard F. Abrams and Roderick Beittel
Babcock Power Environmental Inc.




Wolfe P. Huber, P.E.
U.S. Department of Energy, National Energy Technology Laboratory

Greenidge Multi-Pollutant Control Project

- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory
 - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO₂, mercury, acid gases (SO₃, HCl, HF), and particulate matter from smaller coal-fired EGUs

Existing U.S. Coal-Fired EGUs

50-300 MW_e



Existing U.S. Coal-Fired EGUs

50-300 MW_e


- ~ 420 units not equipped with FGD, SCR, or Hg control
 - Represent almost 60 GW of installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- Difficult to retrofit for deep emission reductions
 - Large capital costs
 - Space limitations
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - State and federal
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)


- Dresden, NY
- Commissioned in 1953
- 107 MW_e (EIA net winter capacity)
- Reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD – mid/high-sulfur coal to meet permit limit of 3.8 lb SO₂/mmBtu



Process Flow Diagram




Hybrid NO_x Control System




- Combustion Modifications
 - Low-NO_x burners, SOFA
 - Reduce NO_x to 0.25 lb/mmBtu
- SNCR
 - Three zones of urea injection
 - Provide NH₃ slip for SCR (NO_xOUT CASCADE®)
 - Reduce NO_x by ~ 42.5% (to 0.14 lb/mmBtu)
- SCR
 - Single catalyst layer (1.3 m)
 - Cross section = 45' x 14'
 - Fed by NH₃ slip from SNCR
 - Reduce NO_x by ≥ 30% (to ≤ 0.10 lb/mmBtu)

Turbosorp[®] Circulating Dry Scrubber



- Completely dry
- Separate control of hydrated lime, water, and recycled solids injection
- High solids recirculation
- Small footprint
- Carbon steel construction
- No wet stack
- Few moving parts
- Projected Ca/S is 1.6-1.7 mol/mol for design fuel

Design Features for Mercury Control



Guarantee Testing Results


March-May 2007, 2.4-3.2% Sulfur Eastern U.S. Bituminous Coal

Parameter	Performance Target	Measured Performance
NO _x emission rate	≤ 0.10 lb/mmBtu	0.10 lb/mmBtu
SO ₂ removal	≥ 95%	96%
Hg removal	≥ 90%	
Activated C Injection		≥ 94%
No Activated C Injection		≥ 95%
SO ₃ removal	≥ 95%	97%
HCl removal	≥ 95%	97%
HF removal	≥ 95%	Indeterminate

Performance of hybrid NO_x control system has been affected by large particle ash and ammonia slip. Plant typically operates at 0.10-0.15 lb/mmBtu to maintain acceptable combustion characteristics.

NO_x Emissions vs. Load

January - June 2008




Large Particle Ash

The Problem




- More pressure drop
- Less NO_x removal
- More urea consumption
- More ammonia slip

The Solution




Ammonia Slip Parametric Testing

Nov 2007 / May 2008, EPA CTM 027, Air Heater Inlet




SO₂ Removal Performance

January - June 2008




Lime Utilization

June 2008 Parametric Testing



Mercury Testing Results

Ontario Hydro Method



SO₃ Testing Results

Controlled Condensation Method

Summary Data from 42 Tests
May 2007 - June 2008

	Scrubber Inlet, ppmvd @ 3% O₂	Stack, ppmvd @ 3% O₂	Removal Efficiency, %
Average	14.1	0.7	95.3
Range	4.7 – 28.7	0.1 – 1.7	78.8 – 99.4

HCl Testing Results


U.S. EPA Method 26A

Summary Data from 18 Tests
March 2007 - May 2008

	Scrubber Inlet, ppmvd @ 3% O₂	Stack, ppmvd @ 3% O₂	Removal Efficiency, %
Average	36.9	1.4	96.2
Range	26.1 – 48.6	0.2 – 2.9	89.5 – 99.4

Particulate Testing Results

EPA Method 5/17, Full Load



New baghouse significantly reduces particulate matter emissions relative to old ESP, in spite of increased particle loading from Turbosorp[®] scrubber

Error bars represent ± 1 standard deviation

Turbosorp[®] System O&M Experience

- O&M handled by existing plant staff
- Lime hydration system is most maintenance-intensive part
 - Use delivered / stored hydrated lime to allow offline maintenance
 - Most problems involve ball mill and classifier
- Had to add compressed air capacity to satisfy baghouse demand
- Flue gas recycle not used because of problems with reverse flow
- Occasional issues with plugging in the ash recirculation / disposal system
- No condensation issues in the scrubber or baghouse



Process Economics

AES Greenidge Unit 4 Design Case

Constant 2005 Dollars

	EPC Capital Cost (\$/kW)	Fixed & Variable O&M Cost (\$/MWh)	Total Levelized Cost
NO _x Control	114 ^a	1.23	\$3,487 / ton NO _x
SO ₂ Control	229 ^b	6.49	\$586 / ton SO ₂

^aIncludes combustion modifications, SNCR, in-duct SCR, static mixers, and LPA removal system

^bIncludes scrubber, process water system, lime storage and hydration system, baghouse, ash recirculation system, and booster fan

Assumptions: Plant size = 107 MW net, Capacity factor = 80%, Coal sulfur = 4.0 lb SO₂/mmBtu, SNCR NSR = 1.35, Ca/S = 1.68, 50% Urea = \$1.35/gal, Quicklime = \$115/ton, Waste disposal = \$17/ton, Internal COE = \$40/MWh, Plant life = 20 years, Fixed charge factor = 13.05%, AFUDC = 2.35%, Other assumptions based on Greenidge design basis, common cost estimating practices, and market prices

Summary

Results from AES Greenidge Unit 4 (107 MW)

- EPC capital cost = \$343/kW (2005)
- Footprint < 0.5 acre
- Performance tests have consistently shown:
 - $\geq 95\%$ SO₂ removal
(for coals up to 4.9 lb SO₂ / mmBtu)
 - $\geq 95\%$ Hg removal
(no activated carbon required)
 - PM emissions < 0.001 lb / mmBtu
 - Very low emissions of SO₃ and HCl
- NO_x emission profile significantly improved
- O&M handled by existing plant staff
- Plant continues to operate profitably (20-30 year life extension)
- Commercial viability demonstrated after a year of operation



Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.