

The Greenidge Multi-Pollutant Control Project: Demonstration Results and Deployment of Innovative Technology for Reducing Emissions from Smaller Coal-Fired Power Plants



Daniel P. Connell
CONSOL Energy Inc., Research & Development



Douglas J. Roll, P.E.
AES Greenidge LLC



Richard F. Abrams and Roderick Beittel
Babcock Power Environmental Inc.




Wolfe P. Huber, P.E.
*U.S. Department of Energy, National Energy
Technology Laboratory*

Greenidge Multi-Pollutant Control Project

- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory
 - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO₂, mercury, acid gases (SO₃, HCl, HF), and particulate matter from smaller coal-fired EGUs

Existing U.S. Coal-Fired EGUs

50-300 MW_e




- About 420 units (almost 60 GW) not equipped with FGD, SCR, or Hg control technology

AES Greenidge Unit 4 (Boiler 6)


- Dresden, NY
- Commissioned in 1953
- 107 MW_e (EIA net winter capacity)
- Reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD – mid/high-sulfur coal to meet permit limit of 3.8 lb SO₂/mmBtu



Process Flow Diagram




Hybrid NO_x Control System




- Combustion Modifications
 - Low-NO_x burners, SOFA
 - Reduce NO_x to 0.25 lb/mmBtu
- SNCR
 - Three zones of urea injection
 - Provide NH₃ slip for SCR (NO_xOUT CASCADE®)
 - Reduce NO_x by ~ 42.5% (to 0.14 lb/mmBtu)
- SCR
 - Single catalyst layer (1.3 m)
 - Cross section = 45' x 14'
 - Fed by NH₃ slip from SNCR
 - Reduce NO_x by ≥ 30% (to ≤ 0.10 lb/mmBtu)

Turbosorp[®] Circulating Dry Scrubber



- Completely dry
- Separate control of hydrated lime, water, and recycled solids injection
- High solids recirculation
- Small footprint
- Carbon steel construction
- No wet stack
- Few moving parts
- Projected Ca/S is 1.6-1.7 mol/mol for design fuel

Design Features for Mercury Control



Guarantee Testing Results

March-May 2007, 2.4-3.2% Sulfur Eastern U.S. Bituminous Coal


Parameter	Performance Target	Measured Performance
NO _x emission rate (high load)	≤ 0.10 lb/mmBtu	0.10 lb/mmBtu
SO ₂ removal	≥ 95%	96%
Hg removal ACI No ACI	≥ 90%	≥ 94% ≥ 95%
SO ₃ removal	≥ 95%	97%
HCl removal	≥ 95%	97%
HF removal	≥ 95%	Indeterminate

Long-Term Performance Results


Parameter	Test Period	Number of Tests	Measured Performance
NO _x emission rate (high load)	Aug 07 – Jul 08	continuous	0.14 lb/mmBtu
SO ₂ removal	Aug 07 – Jul 08	continuous	96%
Hg removal			
ACI	Mar 07 – Oct 07	5	94%
No ACI	Mar 07 – Jun 08	28	98%
SO ₃ removal	May 07 – Jun 08	42	95%
HCl removal	Mar 07 – Jun 08	30	97%
HF removal	Mar 07 – Jun 08	31	Indeterminate

Performance of hybrid NO_x control system has been affected by large particle ash and ammonia slip. Plant typically operates at 0.10-0.15 lb/mmBtu to maintain acceptable combustion characteristics.

NO_x Reduction Performance




SO₂ Removal Performance




Mercury Testing Results

Ontario Hydro Method or U.S. EPA Method 30B



Particulate Testing Results

EPA Method 5/17, Full Load



New baghouse significantly reduces particulate matter emissions relative to old ESP, in spite of increased particle loading from Turbosorp[®] scrubber

Error bars represent ± 1 standard deviation


Large Particle Ash

The Problem



- More pressure drop
- Less NO_x removal
- More urea consumption
- More ammonia slip

The Solution



Operating and Maintenance Experience

- O&M handled by existing plant staff
- Ammonia slip is higher than expected
- Lime hydration system is most maintenance-intensive part of process
 - Use delivered / stored hydrated lime to allow offline maintenance
 - Most problems involve ball mill and classifier
- Flue gas recycle not used because of problems with reverse flow
- Occasional issues with plugging in the ash recirculation / disposal system
- No condensation issues in the scrubber or baghouse



Process Economics

AES Greenidge Unit 4 Design Case

Constant 2005 Dollars

	EPC Capital Cost (\$/kW)	Fixed O&M Cost (\$/MWh)	Variable O&M Cost (\$/MWh)	Total Levelized Cost (\$/MWh)
NO _x Control	114 ^a	0.40	0.85	3.49
SO ₂ Control	229 ^b	0.87	5.41	10.82

^aIncludes combustion modifications, SNCR, in-duct SCR, static mixers, and LPA removal system


^bIncludes scrubber, process water system, lime storage and hydration system, baghouse, ash recirculation system, and booster fan

Assumptions: Plant size = 107 MW net, Capacity factor = 80%, Coal sulfur = 4.0 lb SO₂/mmBtu, SNCR NSR = 1.35, Ca/S = 1.65, 50% Urea = \$1.35/gal, Quicklime = \$115/ton, Waste disposal = \$17/ton, Internal COE = \$40/MWh, Plant life = 20 years, Fixed charge factor = 13.05%, AFUDC = 2.35%, Other assumptions based on AES Greenidge design basis, common cost estimating practices, and market prices

Additional Turbosorp[®] System Deployments

	AES Westover 8	GRU Deerhaven 2	First Light Mt. Tom 1
Unit Capacity (MWe)	84 (net)	248 (gross)	155 (gross)
Start-Up	Fall 2008	Spring 2009	Fall 2009
Inlet SO₂ (lb/mmBtu)	3.4	2.3-3.9	2.7-4.6
SO₂ Removal Goal (%)	≥ 95	≥ 95.6-97.4	≥ 95
Hydrator	No	2 x 100%	No
Existing ESP	Cold Side Abandon	Hot Side Retain	Cold Side Retain
New Baghouse	Yes	Yes	Yes
ACI System	No	Provisions	Yes
SCR	Yes	Yes	Existing

Additional Turbosorp[®] System Deployments



AES Westover

GRU Deerhaven



Summary

Results from AES Greenidge Unit 4 (107 MW)

- EPC capital cost = \$343/kW (2005)
- Footprint < 0.5 acre
- Performance tests have shown:
 - > 95% SO₂ removal
(for coals up to 4.8 lb SO₂ / mmBtu)
 - 98% Hg removal
(no activated carbon required)
 - PM emissions < 0.001 lb / mmBtu
 - ≥ 95% SO₃ and HCl removal
- NO_x emission profile significantly improved
- O&M handled by existing plant staff
- Plant continues to operate profitably (20-30 year life extension)
- Success has led to additional Turbosorp[®] deployments



Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.