

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Plant License Renewal Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, November 5, 2008

Work Order No.: NRC-2523

Pages 1-157



**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

November 5, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on November 5, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
SUBCOMMITTEE ON PLANT LICENSE RENEWAL

+ + + + +

VOGTLE ELECTRIC GENERATING PLANT

+ + + + +

WEDNESDAY, NOVEMBER 5, 2008

+ + + + +

The meeting came to order at 1:30 p.m.

in room T2B3 of Two White Flint, Rockville,  
Maryland. John Sieber, Chairman, Presiding.

PRESENT:

- JOHN D. SIEBER CHAIRMAN
- GEORGE E. APOSTOLAKIS MEMBER
- DENNIS C. BLEY MEMBER
- MARIO V. BONACA MEMBER
- CHARLES H. BROWN, JR. MEMBER
- OTTO L. MAYNARD MEMBER
- HAROLD B. RAY MEMBER
- MICHAEL T. RYAN MEMBER
- JOHN W. STETKAR MEMBER
- JOHN J. BARTON CONSULTANT
- CHRIS BROWN DESIGNATED FEDERAL OFFICIAL

CONTENTS

1

2 PRESENTATION BY CHALMER MYER ..... 7

3 PRESENTATION BY LEE MANSFIELD ..... 35

4 REVIEW OF SCR ..... 68

5 PRESENTATION BY DON ASHLEY ..... 69

6 QUESTIONS BY CHAIRMAN SEIBER ..... 139

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

**NEAL R. GROSS**  
 COURT REPORTERS AND TRANSCRIBERS  
 1323 RHODE ISLAND AVE., N.W.  
 WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

1:30 p.m.

1  
2  
3 CHAIRMAN SIEBER: The meeting will now  
4 come to order. This is a meeting of the Plant  
5 License Renewal Subcommittee. I am Jack Sieber,  
6 Chairman of the Vogtle Electric Generating Plant  
7 License Renewal Subcommittee. ACRS members in  
8 attendance are Otto Maynard, myself, John Stetkar,  
9 Bill Shack, Mario Bonaca, Mike Ryan, Harold Ray,  
10 Charles Brown, and our Consultant John Barton.

11 I would point out that Mr. Barton has  
12 submitted to us his consultants report dated 10/30  
13 which was, to my knowledge sent to all the members.  
14 I got copy of it.

15 There is a second report which I did not  
16 get until today dated October 31st and that can be  
17 made available to you during or after the meeting.

18 The purpose of this meeting is to review  
19 the license renewal application for the Vogtle  
20 Electric Generating Plant, the draft safety  
21 evaluation report, and the associated documents.

22 We will hear presentations from  
23 representations of the office of nuclear reactor  
24 regulation and the applicant Southern Nuclear  
25 Operating Company.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1           The subcommittee will gather  
2 information, analyze relevant issues and facts and  
3 formulate proposed position and actions appropriate  
4 for deliberation by the full committee.

5           The rules for participation in today's  
6 meeting were announced as part of the notice of this  
7 meeting previously published in the Federal Register  
8 on October 22, 2008. We have received no written  
9 comment or request for time to make oral statements  
10 from members of the public regarding today's  
11 meeting.

12           The transcript of the meeting is being  
13 kept and will be made available as stated in the  
14 Federal Register notice. Therefore we request that  
15 participants in this meeting use the microphones  
16 located throughout the meeting room when addressing  
17 the subcommittee.

18           Participants should first identify  
19 themselves and speak with sufficient clarity and  
20 volume so that they may be readily heard. Each of  
21 us has received an application, I think most of us  
22 on a disk, but I got one as a printed version  
23 probably due to my age and I have reviewed the  
24 application and I found it pretty well done.

25           We also received the safety evaluation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 report from the staff. I would point out that the  
2 safety evaluation report at this stage, at the  
3 subcommittee meeting stage is a draft and actually  
4 there are two parts. We've got one part on a disk,  
5 the second part was sent to us by email.

6 And unfortunately it was beyond the time  
7 for our ordinary review process which we expect to  
8 improve on. And we also got three pages of comments  
9 on our ACRS staff engineers.

10 The license application for renewal that  
11 we are to discuss today will follow the requirements  
12 of Title 10 Code of Federal Regulations Part 54 and  
13 I would point out that the Vogtle Plant Unit 1 is  
14 older than Unit 2 by two years. Unit 1 qualifies  
15 for the at least 20-year lifetime for application  
16 for license renewal. Unit 2 does not and therefore  
17 requires an exemption from Part 53 which I  
18 understand the staff is suggesting be approved.

19 I would like to -- as I look around the  
20 audience welcome members of the Beaver Valley Power  
21 Station staff who are here to watch what happens to  
22 Southern Nuclear Operating Company because I think  
23 they are next up for license renewal. And so I  
24 welcome the Beaver Valley staff to our meeting here.

25 I'd like to now proceed with the meeting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and I call upon Brian Holian of the Office of  
2 Nuclear Reactor Regulation to introduce both the  
3 staff and the applicants presented, Brian.

4 MR. HOLIAN: Good afternoon, thank you  
5 Jack. My name is Brian Holian, I'm the Director of  
6 the Division of License Renewal. I'd like to make  
7 some quick introductions of the staff and turn it  
8 over licensee.

9 This is the third application from  
10 Southern Company for license renewal. They  
11 successfully received a license for Hatch Farley and  
12 now coming before the staff for their final Plant,  
13 Vogtle.

14 To my immediate right is Dave Pelton,  
15 the Branch Chief responsible for the Vogtle Plant.  
16 To his right Dr. Sam Lee, the Deputy Director in  
17 License Renewal. And to the far right Donnie  
18 Ashley, the Senior Project Manager who has been in  
19 charge of the License Renewal Application in house.

20 There's one other individual in from  
21 Region II that I wanted to highlight in the back  
22 row, and that's the Senior Reactor Engineer Louis  
23 Lake from Division Reactor Safety in Region II  
24 responsible for inspection of the Vogtle Plant.  
25 You'll be hearing a lot more from both Donnie and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 Louis after licensee's presentation. Now with that  
2 I'd like to turn it over to Chalmer Myer, the  
3 Project Manager for License Renewal for Southern  
4 Company.

5 MR. MYER: Thank you Brian. As I said  
6 I'm Chalmer Myer and we are here and we appreciate  
7 the Chairman and ACRS members the opportunity to  
8 present our application to you this afternoon.

9 To go over my agenda first one of the  
10 things I want to do is introduce everybody from  
11 Southern Nuclear that's here today and we'll be  
12 providing a description Vogtle and a current  
13 operating status.

14 I'll provide highlights of the license  
15 renewal project and how we apply the GALL process.  
16 There were a couple of items that came up in Region  
17 II that we are going to address what actions we're  
18 taking and how these will be addressed during the  
19 license renewal in the future as well as current  
20 Plant operations.

21 For introductions I'd like the gentlemen  
22 at the table to introduce themselves.

23 MR. MANSFIELD: My name is Lee  
24 Mansfield, I'm the Engineering Support Manager of  
25 Plant Vogtle.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. TINER: My name is Todd Tiner, I'm  
2 the Site Vice President at Plant Vogtle.

3 MR. MYER: In our audience we have  
4 David Jones, David is our Vice President of  
5 Engineering for Southern Nuclear, and Mark Ajiluni.  
6 Mark is our Licensing Manager in Southern Nuclear.  
7 And Todd Youngblood, Todd is the Engineering  
8 Director at Vogtle. And Mike Macfarlane, Mike was  
9 the previous Project Manager for License Renewal.  
10 So we brought him in to answer any of the tough  
11 questions.

12 And next to him is Wayne Lunceford, he's  
13 our Mechanical Representative. Partha Ghosal,  
14 Partha is our Civil Representative. And until a few  
15 months ago he was the Chairman of the NEI Civil  
16 Structural Working Group for License Renewal.

17 Cary Martin is our electrical  
18 representative. John Hornbuckle is our PLAA  
19 representative and KC Harriston is an Attorney  
20 through Balch and Bingham who supports our project.  
21 And Lou Bohn is another mechanical representative,  
22 he's also up here running our backup slides. We  
23 have a slide for our presentation.

24 Vogtle is located in Burke County,  
25 Georgia near the Savannah River. The -- it is a two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 unit site. They are essentially identical.  
2 Westinghouse four Loop, PWR's they are currently  
3 rated for 3625 megawatts electrical.

4 This represents a recent power uprate  
5 for measurement and certainty recapture of 1.7  
6 percent. Both units are at approximately 1,250  
7 megawatts electric.

8 The ultimate heat sink for the plants  
9 are the nuclear service cooling water towers. These  
10 are seismic category one concrete structures with  
11 basins that hold all the water necessary for failed  
12 heat sink.

13 The Turbine Plant cycle cooling is  
14 provided by natural draft hyperbolic cooling towers.  
15 They make up for the -- the hyperbolic towers is  
16 from the Savannah River and make up to the ultimate  
17 heat sink is through well water.

18 The Plant was originally licensed to  
19 Georgia Power Company. But the current licensee and  
20 operator is Southern Nuclear Operating Company.  
21 Plant owners, primary owner being Georgia Power  
22 Company and other owners are Oglethorpe Power  
23 Corporations, the Municipal and Electric Authority  
24 of Georgia, and the City of Dalton, Georgia.

25 The licensing history for Vogtle the key

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 elements. We have a construction permit in 1974 and  
2 we received our operating license in 1987 for unit  
3 1, in 1989 for unit 2. We implemented a stretch  
4 power uprate of 4.5 percent in 1993 and as I stated  
5 then we transferred the license to Southern Nuclear  
6 Operating Company in 1997.

7 We submitted our license renewal  
8 application in June of 2007. And while that  
9 application was in review we submitted and received  
10 approval for our measurement uncertainty recapture  
11 uprate.

12 The current operating licenses will  
13 expire in 2027 and 2029 for units 1 and 2  
14 respectively. This is a two added year for Vogtle.  
15 We completed our 14th refuel outage of unit 1 in  
16 April of this year and just completed our 13th  
17 refueling outage for unit 2 this last month.

18 MR. BARTON: How long were those  
19 outages?

20 MR. MYER: Tom?

21 MR. MYNAN: The unit 1 outage was  
22 approximately 40 days. Major drive over the unit 1  
23 outage was the structural well overload project that  
24 we completed on Vogtle unit 1.

25 Unit 2's outage, the counting is still

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 out on it but I think it was 37 days and five hours  
2 was the duration of the Fall outage. The original  
3 duration for the outage was approximately 28 days.  
4 So we had some challenges with the outage.

5 MR. MYER: As I said, both units are  
6 currently at 100 percent power. The 18 month  
7 capability factor for unit 1 is 92 percent and a  
8 little over 90 percent for unit 2.

9 Now, we'll present our license renewal  
10 project. I really won't touch on the exemption for  
11 5417 C since Dr. Seiber has already talked about  
12 that.

13 I want to talk about a project team and  
14 how the strength of the team has led to our success.  
15 We did take advantage of our past experience with  
16 Hatch and Farley. Then I'll give some highlights of  
17 our scoping and AMR and AMP programs in how we apply  
18 GALL to the programs.

19 I'll spend a little bit of time talking  
20 about the types of exceptions we had to our Aging  
21 Management Programs to help you understand those.

22 One area that's had a lot of discussion  
23 I'm sure you're interested in is how we're  
24 addressing the metal fatigue and time limit aging  
25 analysis. So, we'll talk about that for a few

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 minutes. And then talk about how we're implementing  
2 commitments to ensure that license renewal is  
3 carried on beyond the period of extended operations.

4 As Dr. Seiber pointed out we received an  
5 exemption from 10 CFR 54.17 C based on similarity  
6 between unit 1 and unit 2. And unit 1 did have over  
7 20 years of operation prior to the application being  
8 submitted.

9 MEMBER MAYNARD: Can I ask why you felt  
10 it necessary to apply before the unit 2 got into the  
11 window there?

12 MR. MYER: Yes, we have a team that had  
13 completed the Hatch and Farley and in order to keep  
14 the team together we needed to move right into  
15 Vogtle. It would have been 2009 before we could  
16 submit on unit 2. We didn't get an exemption. And  
17 to keep the team together and apply that experience  
18 we requested the exemption.

19 As I said our license renewal team  
20 primarily consisted of personnel that had done  
21 Farley, and also several had done Hatch. I don't  
22 have the exact numbers on the ones that had worked  
23 on Hatch. But about two-thirds of our team had  
24 worked on Hatch and about 90 percent of the team had  
25 worked on Farley.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Somebody gave me a count today that  
2           totaled license renewal experience at the point that  
3           we submitted our application for Vogtle was a 140  
4           years of license renewal experience on the team. So  
5           there was considerable experience there.

6           We added Vogtle myself included in order  
7           to apply the knowledge of Vogtle and ensure that the  
8           Vogtle needs and plant processes were incorporated.  
9           Not only did we bring in that experience at the end  
10          of Farley we performed a self-assessment to identify  
11          lessons learned or things that we'd like to do  
12          better because Farley was a pretty great success,  
13          but we didn't want to set on our laurels on that.  
14          So we did self-assessment identified the number of  
15          improvements and moved on into Vogtle.

16          And on top of that recognized changes  
17          going on and continually changing in license renewal  
18          we have stayed abreast of what's going on in the  
19          industry. We've had members on all of the Working  
20          Groups that I pointed out that one of our members,  
21          one of our team members was a chairmen, I think  
22          we've had others through the course of the recent  
23          years that were chairmen on different committees.

24          I've been on the License Renewal Task  
25          force and many of you may recognize me because I've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 been to many of these meetings seeing what goes onto  
2 make sure we were prepared.

3 Additionally, we participated in a  
4 number of inspections and audits of our peer plants.  
5 So we understood what the NRC was looking for when  
6 they came out to do audits and inspections and we  
7 supported peer reviews of numerous applicants in the  
8 process of developing our applications.

9 So we knew what they were doing and knew  
10 and went back and made certain we addressed the same  
11 types of issues they were addressing.

12 In order to ensure that Vogtle was  
13 brought into this process -- and we have corporate  
14 owners as well as site owners. We had program  
15 owners all review their programs prior to submitting  
16 the application. We received a number of comments  
17 and incorporated them before the application went  
18 in.

19 And the program owners were deeply  
20 involved in all of the audits and inspections and  
21 basically all the comments that came from the NRC  
22 were responded to by program owners themselves so  
23 they are brought into what's been going on in the  
24 future.

25 We just wanted to highlight that we feel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 that all of these activities that we were doing to  
2 keep our team strong were shown to be successful by  
3 the fact that we've got a SER with no open items and  
4 no performatory items. We worked very hard to  
5 ensure that we respond to the NRC questions and  
6 comments.

7 Scoping highlights, we performed our  
8 scoping consistent with the NEI 9510 revision six.  
9 And revision six was endorsed by the NRC in red  
10 guide 1.188 revision one. We used a conservative  
11 spaces approach A2 scoping which is consistent with  
12 a lot of applicants, I'm not certain all.

13 But it's basic approach basically says  
14 that any non-safety related components or structures  
15 located in a space for safety related components and  
16 structures is included in the scope regardless of  
17 relative location of it's components.

18 Space is defined as a area that is  
19 bounded by walls, ceilings, and floors. One of the  
20 lessons learned that we brought out of Farley was to  
21 include A2 scoping on our mechanical number drawings  
22 and in addition to A1 and A3. It helped us to  
23 identify in scope components as well as assist with  
24 the NRCS's review of scoping greatly because it was  
25 all in one drawing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And another area of discussion that's  
2                   been pretty active recently has been station  
3                   blackout scoping. So I just wanted to address for  
4                   Vogtle, station blackout scoping or systems  
5                   structures and components is consistent with the  
6                   NRC's staff guidance and is consistent with the  
7                   revisions to the ISG's that are under review  
8                   currently.

9                   MR. HOLIAN: Was it that way originally  
10                  or did you have some discussions?

11                  MR. MYER: It's been that way every  
12                  since they submitted it. Our electrical engineers  
13                  saw what was happening and actually were in  
14                  agreement with the direction the staff was looking  
15                  for Vogtle. So they implemented that originally.

16                  MR. HOLIAN: Good.

17                  MR. MYER: Aging management reviews,  
18                  again we followed the NEI 9510 guidance. We made  
19                  extensive use of GALL, that's something I didn't  
20                  mention earlier is that during the revision to GALL  
21                  our personnel were very deeply involved with it.

22                  In fact, we had one who wrote the draft  
23                  of one of the sections of comments for NEI. And so  
24                  we were thoroughly familiar with it and made  
25                  extensive use of it. We also were very strict in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 our application of whether we would call ourselves  
2 consistent.

3 If we didn't force fit anything we ended  
4 up with 86 percent consistency with GALL. The non-  
5 consistent items are primarily -- we had material  
6 environment and aging effects. Primarily  
7 environment or aging effect is not in GALL.

8 Looking at these a lot of those will  
9 probably be picked up in revision to GALL. But some  
10 of them are just unique to Vogtle and I'm not  
11 certain would warrant being picked up in GALL and I  
12 think other applicants also will have unique  
13 environments or aging effects that won't go into  
14 GALL.

15 MR. HOLIAN: Well, what could have got  
16 my curiosity is the nitride-induced stress corrosion  
17 cracking from to exposure to auxiliary compound  
18 cooling water. And I wonder if somebody could tell  
19 me what's unique about your cooling water and this  
20 whole phenomena which is a new one to me.

21 MR. MYER: Well, the interesting thing  
22 is we are not unique except that we classified it as  
23 stress induced IGSCC, that's easier for me to say  
24 the letters.

25 It has occurred at other sites and they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 did not conclude that it was IGSCC but the  
2 phenomenon was the same.

3 MR. HOLIAN: Well how did you finger the  
4 nitride as the guilty party?

5 MR. MYER: There are some industry  
6 papers that have been written on carbon steel IGSCC  
7 and nitride has been the primary cause looking at  
8 the various chemistries. I don't have all of the  
9 background, it's been a long time since I read all  
10 of the research.

11 But back when this was first happening I  
12 was thoroughly familiar with it. And I went through  
13 -- the odd thing is I went through all of the  
14 chemistry reports for unit 1 and unit 2 because this  
15 has only occurred on unit 2. Our chemistry has been  
16 identical and we have actually had excellent  
17 maintenance of our nitrates and nitrides on both  
18 units.

19 So, that in itself would not have been  
20 the cause. But there are other agents that feed  
21 into this. One of them is an organic substance,  
22 plus you have to have high temperature, plus you  
23 have to have high stresses.

24 And we have not concluded as to what the  
25 cause was. But something is unique in unit 2 where

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we have some organic products as well as all of the  
2 others coming together.

3 And in particular it has been in high  
4 temperature areas that this has occurred such as let  
5 down heat exchange and down surge heat exchange. I  
6 think there may have been a couple of others, but  
7 it's typically going to be where the pipe is warmer  
8 than other areas.

9 I won't name other Plants, but there  
10 were other plants who have gone through the same  
11 thing and replaced the pipe, replaced the components  
12 and they just didn't call it this.

13 MR. HOLIAN: Do change material when you  
14 replace the pipe?

15 MR. MYER: We don't change the material.  
16 But we have instituted better weld control. A lot  
17 of the problems have been on pipe welds where we  
18 have backing rings. So the welding no longer  
19 allowed backing rings.

20 We replaced the let down heat exchanger  
21 and we went through a lot of stress relief on the  
22 welds to ensure that their -- the stresses were not  
23 as high. So we're basically taking measures in our  
24 construction processes to ensure that some of the  
25 factors that feed into this aren't there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Our license renewal program resulted in  
2           38 Aging Management Programs at Vogtle, 24 of these  
3           were existing and 15 of those required enhancements  
4           to meet license renewal requirements. We have 14  
5           new programs at the Plant.

6           Of the 38 programs 27 of them have been  
7           for GALL programs and those that were GALL programs  
8           would have only minor exceptions and I'll talk about  
9           those in a moment.

10           Of the 11 class specific programs to the  
11           extent possible we still use GALL attributes and  
12           defining them. But they were enough different from  
13           GALL that we called them Plant specific.

14           Our exceptions fell typically into these  
15           four areas. I think the first one has been commonly  
16           brought up before the committee. The use of a  
17           different code of standard. GALL currently  
18           identifies specific revisions, specific code years  
19           of various standards.

20           For example, the upper standard that we  
21           use for steam generators, they have a specific  
22           revision. Inevitably, those standards are going to  
23           evolve to incorporate lessons learned, new  
24           technologies, and Vogtle's intent is to stay at the  
25           forefront of maintaining their equipment with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 latest standards and the latest codes. In fact,  
2 some of these are even mandated by the regulatory  
3 requirements.

4 And so at the time we submitted the  
5 application a number of these programs were using  
6 later codes of standards than were called out in  
7 GALL. They actually in many cases exceeded what was  
8 called out in GALL, but they are exceptions.

9 We were fairly conservative in calling  
10 out what were exceptions. If we exceeded GALL we  
11 called it an exception. And a number of the things  
12 I want to point out is where we exceeded what's  
13 called out in GALL.

14 In the area of managed material or  
15 environment not in GALL this is specifically where  
16 we identified exceptions that were beyond GALL. We  
17 have stainless steel that we included in our very  
18 piping program. The GALL program doesn't have  
19 stainless steel in it.

20 We also included aluminum and elastomers  
21 in our external surfaces monitoring program that  
22 were not in the GALL program.

23 The amp scope differences. There were a  
24 number of types of amp scope differences. Again,  
25 some times it was beyond the requirements of GALL.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Our floor accelerated corrosion program we include  
2 locations that can't be modeled in that program  
3 which is beyond GALL.

4 We also include locations that are  
5 subject to wear by methods other than fact in our  
6 fact program. One area that we have less scope is  
7 that we didn't include our main steam nozzles  
8 because of the high sink quality in our sink  
9 generators.

10 Then the last was the use of alternative  
11 inspection methods. A couple of examples of this,  
12 our FAC program allows for opportunistic visual  
13 inspections to identify areas where FAC is occurring  
14 that may not have been identified otherwise.

15 If they open up a valve and see where  
16 the downstream of the valve and it's not in the FAC  
17 program or it's not subject to inspections in this  
18 term they will factor that back into the inspection  
19 program. That's actually in -- consistent with  
20 inset guidance for the FAC program.

21 Another area was our selective leaching  
22 program. Recognizing that this is an area where a  
23 lot of technology could be developed in the future.  
24 We have maintained the ability to implement new  
25 methods as technology develops in the future. This

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 is an area where EPRI is working pretty vigorously  
2 on for the industry right now.

3 MR. BARTON: I have a question on  
4 starting any measurement programs. The section on  
5 loss and materials due to pitting and corrosion,  
6 partially encased, enclosed stainless steel tanks  
7 with exposure to oil or water. I understand your  
8 construction to stainless steel line tanks within  
9 concrete.

10 But, the question I've got is is there  
11 any Aging Management Program in place for the  
12 internals of those things, diagrams, etcetera. I  
13 couldn't find that?

14 MR. MYER: Could you address that. I  
15 believe the diaphragms were --

16 MR. MANSFIELD: I thought I saw them. I  
17 think we have a program for the diaphragms.

18 MR. MYER: We have a program, but I  
19 don't --

20 MR. BARTON: Okay.

21 MR. MYER: -- but I don't think it's in  
22 license renewal, because were they short term?

23 MR. BOHN: The tank diaphragms are  
24 included in the periodic surveillance and  
25 preventative maintenance activities.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MYER: Okay, all right.

2 MR. BOHN: As far as the tank internals  
3 we got water chemistry, off the top of my head  
4 that's all I remember right now. I'd have to look  
5 at the specifics.

6 MR. MACFARLANE: This is Mike Macfarlane  
7 from Southern Nuclear. The tank diaphragms was  
8 actually a lesson learned out of Farley.

9 In fact, that came up in our regional  
10 inspection and we carried that forward into Vogtle.  
11 Including that was actually something that was added  
12 a little later in the game on Farley. Not all tanks  
13 have the diaphragm though, so there's --

14 MR. BARTON: I understand that.

15 MR. MACFARLANE: Okay.

16 MR. MYER: As I noted, the time limit on  
17 aging analysis for metal fatigue has gotten a lot of  
18 attention lately. There's a draft risk on the  
19 street that addresses a methodology that uses a  
20 single stress tensor versus the six stress tensors  
21 that would typically be applied by the code.

22 Vogtle currently uses FatiguePro which  
23 was developed by EPRI. And this is a piece of  
24 software that does use a single stress tensor. It  
25 uses it for stress based fatigue monitoring which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 primarily would be needed when we enter the period  
2 of extended operation and we would have to apply  
3 environmentally assisted fatigue.

4 At this point in time we can do our  
5 fatigue management by counting cycles to the design  
6 base of cycles and evaluating what effect that has  
7 on fatigue. But basically keeping CUF below one.

8 Looking at what's going on in the  
9 industry, the technology that we have currently. I  
10 know that EPRI is considering upgrading FatiguePro.  
11 There's other software out there currently that does  
12 use six stress tensors. And we're looking at 18  
13 years before we have to have it in place, or  
14 actually 16 since we made a commitment -- no it  
15 would be 18 because it will be 20 years from now, to  
16 have it in place for our period of extended  
17 operations.

18 Instead of trying to defend the current  
19 version of FatiguePro we've committed to implement a  
20 software that will be benchmarked using six stress  
21 tensors, or even later technology that's developed  
22 at that point. Computers are probably going to be  
23 faster and able to do more than they currently can.

24 But we will implement software that is  
25 endorsed by the NRC or at least meets their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 expectations with regards to appropriate stress  
2 tensors and bench marking.

3 MR. HOLIAN: Using that single compound  
4 that is no more correct today than it will be when  
5 you renew your license. How large are your margins  
6 to your current?

7 MR. MYER: We did some base lining and  
8 it was -- the factor I believe it was two or three  
9 times more conservative than what we were using.  
10 But we don't -- like I said at this point in time  
11 we're not using it as stress based --

12 MR. HOLIAN: You're just counting  
13 cycles?

14 MR. MYER: We're just counting cycles.  
15 We had actually moved in a couple of locations to  
16 stress based because we thought that would be  
17 appropriate. But we can use cycle counting so we're  
18 moving back to cycle counting under our current  
19 vices and approach because we're within the bounds  
20 of our current design on all of our locations.

21 MEMBER STETKAR: With respect to that  
22 though, I had a question because it came up during  
23 the staff audit the way that you're projecting  
24 cycles for the charging nozzles and let down.  
25 You're using kind of a creative way of counting long

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 term operating experience and weighting it basically  
2 one-fourth of shorter term operating experience.

3 If I understand that's the way you're  
4 doing and then projecting, or counting up a number  
5 of sort of weighted cycles and then projecting from  
6 that.

7 Could you explain a little bit the  
8 rationale behind that, because I didn't understand  
9 why the specific weighting factors and what the  
10 relevance of that whole process is. I mean I  
11 understand the results that come out from it, but  
12 I'm not compelled by the numbers.

13 MR. MYER: Well the intent was -- and  
14 there was a lot of discussion going on at the time  
15 that we submitted our application. But the intent  
16 is to write a projection of where the fatigue will  
17 be at, in this case year 60 and we're going to be  
18 calculating that number at the end of each cycle and  
19 if it ever projects based on that algorithm to be  
20 greater than one at year 60 then we'll start taking  
21 corrective action when it projects at that point.

22 MEMBER STETKAR: I understand, but what  
23 I'm asking is what's the basis for that algorithm.  
24 That's what's the basis for arbitrarily saying I'm  
25 only going to count this relatively large number of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cycles apparently and weight those one-fourth of --  
2 in that algorithm, weight them one-fourth compared  
3 to this other relatively small number of cycles just  
4 by virtue of time --

5 MR. MYER: I think part of what you're  
6 talking about is the original operation of Plant we  
7 went through a number of cycles that we now have  
8 modified our operating methods and won't repeat.  
9 But Jon Hornbuckle could probably provide more  
10 detail.

11 MR. HORNBUCKLE: I'm Jon Hornbuckle,  
12 Southern Nuclear. I'm not exactly sure I understand  
13 what your question is. But if I understand  
14 correctly the various locations that we project CDF  
15 for we had to go back and back calculate a  
16 projection of what the fatigue was up to the time we  
17 had data.

18 And then from the time we had data on  
19 we've got a calculated CUF and then our projections  
20 more heavily rely upon the period of time since we  
21 have data.

22 MEMBER STETKAR: That's true, but my  
23 question was in particular, for some let down line  
24 transience your old data are weighted very, very  
25 low. In some cases they are weighted zero. you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 basically discount the stuff. And the question is  
2 why, you know what's the basis for that.

3 What's the justification for it because  
4 you have a general algorithm that says before the  
5 time you had, let me call it relevant operating  
6 experience, you generally weight that one-fourth and  
7 from whatever that, was that 1995 or I can't  
8 remember the year --

9 MR. HORNBUCKLE: Yes, '95 was when we  
10 started collecting data.

11 MEMBER STETKAR: --'95 and '98 or  
12 something like that. And you wait to post that date  
13 three-fourths except in a few cases where you take  
14 the earlier experience and just basically discount  
15 it and throw it away, it's weighted zero.

16 And it didn't strike me -- I'd like to  
17 understand the basis for doing it.

18 MR. HORNBUCKLE: I think, I can't be a  
19 100 percent sure without spending a lot of time  
20 looking back at the data to understand. But as best  
21 I can recall the case you're talking about is the  
22 loss of let down cycles where we had maybe 20 times  
23 as many during that period of time before we had  
24 data as we've had since.

25 And it was basically the early years we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 had to learn to how operate the Plant and we had a  
2 lot of those events and we don't have very many of  
3 them anymore. And so for as far as projecting the  
4 rate of accumulation of cycles since we have data  
5 seems like a much more reasonable means of making  
6 that projection.

7 And we're not throwing out the others,  
8 we're keeping them in our base events in our base of  
9 our current CUF. We're just not using them to  
10 project how much CUF we're going to accumulate in  
11 the future.

12 MR. MYER: Specifically, if we started  
13 experiencing more of those events -- currently we're  
14 projecting a small number because we know that  
15 operations has been changed and they aren't  
16 occurring.

17 If we started having more events the  
18 algorithm would immediately project more events in  
19 the future. It would take the recent events and  
20 project those as being probable in the future.

21 So, unless we change our current  
22 performance the projection really is consistent with  
23 what we'd expect in the future. Whereas if it does  
24 change, because we're using the heavy weighting on  
25 recent events it would dramatically change our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 projection plan.

2 MEMBER STETKAR: I guess I didn't, in  
3 the things I read I didn't -- you mentioned a couple  
4 of times you changed operations performance and that  
5 might be a real forcing function for why the  
6 frequency is different.

7 In the things I read it more seemed to  
8 rely on the fact that you didn't really know how to  
9 categorize the previous events that -- I didn't read  
10 in anything that said that there was a fundamental  
11 way, different way of doing operations. It seemed  
12 more of a data characterization problem and you  
13 decided to characterize it as not counted.

14 MR. MYER: I think in the cases of loss  
15 of let down there -- while we don't have a specific  
16 change of procedures the fact that we have a lot of  
17 events early on and the events have gone away and  
18 also we've had industry experience that pointed to  
19 the fact that we needed to cut down the cycles on  
20 the let down and charging nozzles we recognized that  
21 we successfully, with recent history reduced them.

22 But even if you looked at the algorithm,  
23 the one you're talking about one-quarter versus a  
24 larger number or three-quarters for the recent  
25 events that's because we really do weight current

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 events both if the number of events increases or if  
2 the number of events decreases.

3 MEMBER STETKAR: I understand that,  
4 except that that algorithm is applied differently --

5 MR. MYER: Right, I understand.

6 MEMBER STETKAR: -- in a few cases.  
7 And the three-quarter weighting is adjusted.

8 MR. MYER: It was basically that when we  
9 looked at data that just didn't meet the normal  
10 pattern we thought through it and said it doesn't  
11 make sense to apply it.

12 MEMBER STETKAR: You changed the  
13 algorithm?

14 MR. MYER: That's right.

15 CHAIRMAN SIEBER: But, it appeared to me  
16 though that the choices you made as to how you would  
17 distribute the data was sort of arbitrary.

18 MEMBER STETKAR: That's what more I was  
19 getting to is why was the algorithm changed in  
20 particular for those --

21 CHAIRMAN SIEBER: Yes, I understand the  
22 theory.

23 MR. MYER: It was basically an  
24 engineering judgement by the stress experts that  
25 were doing this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: As engineering  
2 judgements?

3 MR. MYER: That's right.

4 MEMBER STETKAR: Thanks.

5 CHAIRMAN SIEBER: You did not attempt to  
6 go back to the operating history of the Plant logs  
7 and so forth?

8 MR. MYER: In order to develop the  
9 existing usage yes, we've gone through all the Plant  
10 logs and when we first implemented FatiguePro  
11 Westinghouse went through all of their Plant logs  
12 and identified the number of cycles that they had  
13 gone through.

14 In many cases --

15 CHAIRMAN SIEBER: But they do have a  
16 handle on how many you had?

17 MR. MYER: Yes, we do. In many cases,  
18 and this also applies back to that, because we were  
19 working off of Plant logs and not actual  
20 temperatures we took a conservative view of every  
21 one that occurred prior to implementing the  
22 software.

23 CHAIRMAN SIEBER: The full cycle.

24 MR. MYER: That's right.

25 CHAIRMAN SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MYNAN: Just so that maybe -- when  
2 we talk about this operations procedures or how we  
3 operate the plant the fundamental difference that  
4 came out several years after we went commercial was  
5 that we as a station did not understand that when  
6 you lost let down our operating principle was to  
7 isolate charging.

8 That was what we would do. And what  
9 would happen is the charging nozzle of course would  
10 be hot, you lose the let down, it cools off and if  
11 you isolate the charging distance proximity to the  
12 loops it would heat back up and then you put  
13 charging back in and it cools back down and then you  
14 put let down in and it heats back up.

15 So you almost go through three cycles  
16 the way for one event. And so we changed our  
17 operating procedures on how we address a loss of let  
18 down to leave about five to ten gallon minutes of  
19 charging above seal injection that we can handle  
20 with our excess let down that keeps the nozzle cool  
21 so we don't go through two more cycles.

22 That was the predominant driver that  
23 allowed us to eliminate a lot of the cycles that we  
24 were taking on the nozzles.

25 MR. MYER: We have identified 39

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 commitments that have been made to enhance aging  
2 management at Vogtle. These commitments were  
3 entered in our Vogtle commitment tracking program.

4 This is a database that's fleet wide  
5 database used at all three sites and it linked  
6 action items, work orders, commitments, and we will  
7 also issue a program manual that will link all of  
8 these documents so that we have a strong basis to  
9 ensure that future owners of the programs know what  
10 their commitments are, know what actions need to be  
11 taken to make sure that we implement the programs as  
12 we enter the period of extended operation.

13 With that I'm going to ask that Lee  
14 Mansfield talk about the results of the Region II  
15 site inspection.

16 MR. MANSFIELD: Thank you, Chalmer. We  
17 had two inspections in 2008 at Plant Vogtle by the  
18 Region. One was during our refueling outage in the  
19 Spring on unit 1. One was a team inspection, a  
20 license renewal inspection in the Summer in May and  
21 June.

22 Out of that came two enhancements to two  
23 existing programs. One was the boric acid corrosion  
24 control program. One was the full box monitoring  
25 program. I'll talk a bit about those.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The boric acid corrosion control program  
2 specifically the inspectors, concluded that the  
3 program would adequately manage the boric acid  
4 corrosion, if any boric acid corrosion issues we  
5 might have.

6           However, they did notice, the inspectors  
7 noticed a non-boric acid residue in containment  
8 deposits on different components that could  
9 potentially mask boric acid leaks and boric acid  
10 corrosion.

11           This was principally a result of our  
12 essential cooling water system, nuclear service  
13 cooling water system having a lot of condensation in  
14 containment.

15           The containment temperatures typically  
16 around 100 degrees, this system runs anywhere from  
17 65 to 80 depending on the time of year. So the  
18 temperature difference results in this uninsulated  
19 pipe quite a bit of condensation.

20           And the actual material that we're  
21 talking about is trolytriazole which is a corrosion  
22 inhibitor that we put in this nuclear service  
23 cooling water system. MR. BARTON: So that's the  
24 white film that they saw?

25           MR. MANSFIELD: Yes sir, that is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 white film sir.

2 MR. BARTON: That was internal. So  
3 unless that leaks in that system?

4 MR. MANSFIELD: That's correct, when you  
5 have leaks, you know be they small or large then  
6 this condensation which is occurring on, you know  
7 like 3,600 or so lanyard feet of pipe spreads it  
8 out. So that was the cause, you know it was small  
9 leaks and then getting distributed by this  
10 condensation.

11 MR. BARTON: How come you guys didn't  
12 clean it up before the NRC found it?

13 MR. MANSFIELD: Well, we actually have  
14 been cleaning it up. We have a program in place --  
15 we know coming into outages where we want to go work  
16 on our clean up and repair and painting.

17 We also do inspections to see what's new  
18 and we re-prioritize it as we come into an outage.  
19 So right now it's an ongoing recovery process.  
20 We've done it the last several outages. In fact,  
21 I've got a picture coming up here I'll show you what  
22 we know we can do as far as recovering the piping.

23 I'll go ahead and tell you the  
24 corrective actions. Some implemented and some being  
25 implemented are systematic inspections that we do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 every outage, cleaning, repainting. And I'll tell  
2 you our inspections are at the beginning of the  
3 outage and then at the end of the outage.

4 MR. HOLIAN: And the leaks are from  
5 valve packing or something?

6 MR. MANSFIELD: Valve packing, it could  
7 be from a flange connection. It could be minor  
8 leaks over the years from our containment coolers  
9 that our service water passes through.

10 So, there's nothing real prevalent about  
11 what the leak is. But any time it happens it's got  
12 this material in it. It's out in the atmosphere and  
13 it turns white.

14 MEMBER MAYNARD: And the coolers  
15 themselves, don't they have a drain system through  
16 the --

17 MR. MANSFIELD: Yes sir, the coolers  
18 have a collection system that's part of our textbook  
19 monitoring for containment leakage. And but the  
20 collection system is really centered under the two  
21 bundles and not on the ends. And when we've had  
22 leaks they've been on the ends coolers.

23 So that collection system wasn't telling  
24 us, it doesn't tell us through the cycle that we've  
25 got, you know leakage on those coolers. We don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 have any leakage on those coolers right now. We  
2 have over the years, but we've also had, you know  
3 minor leaks and packing of flanges etcetera.

4 We have made procedure changes to ensure  
5 that in our boric acid corrosion control program  
6 that, you know the owners and the site personnel  
7 recognize that, you know because of this  
8 configuration and the potential for leaks there  
9 could be some masking. So, we don't want them to  
10 get complacent about what this white material is.  
11 We've also done, we've also done enhanced  
12 communication with out personnel through briefings  
13 during the outage, through communications, you know  
14 electronic communications.

15 We've also, we are also putting in our  
16 training programs specific issues, you know specific  
17 topics about this because as we go through this  
18 recovery period we want to make sure no one ignores  
19 any of these locations.

20 On our boric acid corrosion control  
21 program now that really wasn't necessarily focused  
22 on this before is clearly looking at all of those  
23 issues when their looking for boric acid leaks only  
24 to make sure that we don't confuse two and ignore  
25 the wrong one.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   This first photo is just an example of  
2 what this white material looks like. You know boric  
3 acid is white and crystalline. And at a distance this  
4 staining looks like it could possibly be the second.  
5 And you see some corrosion there on the bulking  
6 materials.

7                   MEMBER STETKAR: Back up, what are we  
8 looking at. I recognize the pipe but, it looks like  
9 we're looking at the bottom side of some concrete.  
10 It's an eye beam, it's hard to figure out how  
11 leakage from pipes get under the bottom side of an  
12 eye beam.

13                   MR. MANSFIELD: Well are we looking down  
14 or are we looking up?

15                   MR. MYER: It drips down and hangs there  
16 and then evaporates and then you leave the deposit.

17                   MEMBER STETKAR: So the leaking pipe is  
18 somewhere out of site above the eye beam?

19                   MR. MANSFIELD: Yes, I mean there's --  
20 as I said there's a tremendous amount of this pipe  
21 and this piping goes through a lot of components and  
22 containment.

23                   The next picture is just an example  
24 though of how we're -- where the process of recovery  
25 area is. We attacked the most prevalent issues and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the ones most likely to mask boric acid corrosion.  
2 And we clean, we repaint, we replace materials as we  
3 need to.

4 CHAIRMAN SIEBER: What you are doing is  
5 cleaning up and painting things, but the leaks are  
6 still there. And what are you doing to fix the  
7 leaks?

8 MR. MANSFIELD: Well I tell you, there's  
9 two things. We're evaluating, insulating all of  
10 that piping which is a big job and a big deal. But  
11 we have that in --

12 CHAIRMAN SIEBER: What will that do,  
13 mask the leaking?

14 MR. BARTON: Collect the leakage in the  
15 insulation?

16 CHAIRMAN SIEBER: Right.

17 MR. MANSFIELD: Just to keep the  
18 condensation from occurring on the piping. Not to  
19 stop the leakage out of the system. All right, the  
20 leakage out of the system is you know part of our  
21 normal inspection and maintenance.

22 MEMBER MAYNARD: Minimizes the spread of  
23 --

24 MR. MANSFIELD: That's exactly right.

25 MEMBER MAYNARD: -- but it doesn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 eliminate it.

2 CHAIRMAN SIEBER: Well, the basic  
3 problem is this leak, okay. And the problem that  
4 appears on the surface is you've got a lot of  
5 residue, okay.

6 So you're cleaning up the residue, but  
7 what I want to know about is how you're fixing the  
8 basic problem?

9 MR. MANSFIELD: The -- you want to add  
10 to this Tom?

11 MR. MYNAN: Yes, the biggest issue that  
12 we have with this particular system is the  
13 dissimilar metals that we have on the coolers  
14 themselves. The header joints are made of stainless  
15 steel while the tubing is made out of cooper.

16 And the braising of the tubes to the  
17 distribution header, the braising is coming loose.  
18 Now the tubes are flared inside the header. So as  
19 long as the system remains pressurized the flair  
20 kind of seals it off and the leaks appear to go  
21 away.

22 The problem is when we get to outages or  
23 what not if we shut the train down and the internal  
24 pressure reduces inside these coolers they have a  
25 tendency to leak when we start the system back up.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   We have a long range plan for  
2 replacement of all of these coolers with an  
3 alternative type to get rid of the dissimilar metal  
4 welds. It is a tremendous job in that we have eight  
5 containment coolers and two aux coolers and I think  
6 on each containment cooler we have 16 sub-coolers.

7                   So, in the interim, as we kind of rank  
8 the level of leakage of the coolers from  
9 unacceptable to we can tolerate and replacing them  
10 with the existing designs if we have spares. And in  
11 the long range plan we intend to go replace these  
12 coolers with an alternative type to eliminate the  
13 issue.

14                   So, but it's a dissimilar weld issue.  
15 They are on the ends. They are not in the  
16 collection tank. And, you know this particular  
17 issue is a lot more prevalent if you look at the  
18 joints up on the tubes themselves. So that's my  
19 understanding of where we're at.

20                   The reason I know about this is that  
21 when this came up in the Spring my organization took  
22 this very seriously and I personally went in and  
23 looked at all of the issues inside unit 1 and make  
24 sure I understood the magnitude of the issue.

25                   And then during and after the outage I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 got with our engineering director Todd Youngblood  
2 and with Lee and said what are the different issues  
3 here, what are we looking at, what do we do going  
4 forward and you know we came up with a pretty  
5 aggressive plan to clean up, insulate, and then  
6 integrate into the plan the replacement of these  
7 coolers over the long range life of the plan.

8 MR. BARTON: Notice of violation always  
9 got my attention too.

10 MR. MYNAN: You know its, you know when  
11 I went in and looked at it, I mean I go into  
12 containment every outage. I've looked at it a  
13 thousand times and it just didn't strike me as an  
14 issue and it's because you live it day in and day  
15 out.

16 When you have an external person come in  
17 and point it out it's like hey, and ask that  
18 question and a light bulb goes on. You know it took  
19 us all back and said whoa, you know we need to go  
20 after this.

21 And I did go in and inspect level two in  
22 the Fall outage. So I understand the issue and I  
23 assure you that we've got money and plans in place  
24 to address this issue.

25 MEMBER MAYNARD: I understand the issue

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 around the cooler itself. But if you were  
2 considering insulating a lot of pipe, which to me  
3 indicates that you also must be having some leakage,  
4 I won't call it significant, but you must have  
5 leakage in other locations.

6 And if were just right at the cooler it  
7 looks like you would be able to isolate that in ways  
8 easier than insulating all of your piping area.

9 MR. MANSFIELD: I mean we do have and  
10 have had leaks on valves, packing leaks, gwinet  
11 leaks, etcetera on that essential cooling water  
12 system that is away from the cooler. So the answer  
13 to your question is yes.

14 And it's not that there is a particular  
15 problem there, it's such a big system with so many  
16 components and is in so much of containment that  
17 when there is a leak in these coolers as Tom said,  
18 there's so many of them and they are spread all over  
19 and there's leakage from a cooler and then you know  
20 it can be spread a lot of different ways on the way  
21 down.

22 CHAIRMAN SIEBER: Do you think  
23 insulating pipes will mask the leakage so that you  
24 have nice clean looking insulation going on  
25 underneath?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MYER: This is stainless steel pipe.  
2 And so we wouldn't be masking going on inside. And  
3 in fact the purpose of the insulation as I said,  
4 stops the condensation so that there is no spread.

5 If we have leaking valves and other  
6 leaking components that's picked up as part of the  
7 normal inspections of the system.

8 MR. MYNAN: The piping that we have the  
9 biggest problem with -- which our contractors like,  
10 is we actually pipe in chill water into our  
11 containment during the fueling outages and basically  
12 air conditioned containment.

13 And it goes to one specific cooler and  
14 it's at the highest elevation in containment and --  
15 but it's also the largest. And that particular  
16 piping is the one that sweats the most and it's  
17 during the refueling outage.

18 And it looks really bad because of the  
19 measures we've got to take to try to collect all the  
20 condensation that drips down to the lower levels of  
21 containment and the spread of contamination.

22 So, that's the one we want to go after  
23 first, although we do see issues I would see when  
24 it's hot out and it gets cold out and the  
25 containment air temperature starts to go we do see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 some evidence on all the other piping as well.  
2 But I don't think that's as big an issue as this  
3 chill water piping.

4 MR. MANSFIELD: I agree, I agree.

5 CHAIRMAN SIEBER: Well I lived in  
6 Augusta for a couple of years, I know it gets hot.

7 MEMBER STETKAR: Let me ask you one  
8 thing. I think you took an exception to visual  
9 inspection of the reactor vessel at boric acid  
10 corrosion because of stainless insulation or  
11 something like that, accessibility for high dose or  
12 something like that, is that correct.

13 I was curious as to what fraction or  
14 where -- you know what fraction of the service area  
15 and here that insulation was. The sense that I had  
16 it was some sort of localized area.

17 MR. LUNCEFORD: Wayne Lunceford,  
18 Southern Nuclear. The situation is that there's  
19 less than one percent of the head that you cannot  
20 see if you do not remove the reflective metal  
21 insulation on the top head.

22 And so there's about, I believe a ten  
23 man room of dose that's required to access this.  
24 Less than one percent of the head and you can see  
25 360 degrees around every head penetration, you can.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And so the less than one percent is away  
2 from those areas where the leakage would initiate.  
3 And so that was a relaxation from the older  
4 requirements.

5                   MEMBER STETKAR: I just wanted to --  
6 thanks.

7                   MR. MANSFIELD: The second issue brought  
8 up by the inspection was the water fountain in the  
9 pull box. We have -- our in scope median voltage  
10 cables at Vogtle are all in tunnels and aren't  
11 subject to getting water in them or near them with  
12 one exception and that's where this pull box came  
13 into play.

14                   We have non-safety related 4 KV cables  
15 that run out to our high voltage switch yard for  
16 switching that supports station black out. In fact  
17 Lou, if you'll put that picture up there.

18                   Here we go. I'm going to step up here  
19 because our pointer is not working too well.

20                   MR. MYER: You can't do that Lee. You  
21 need to stay here where the mic is.

22                   MR. MANSFIELD: All right.

23                   MR. MYER: I'll point to it.

24                   MR. MANSFIELD: There you go. What  
25 we're looking at is our high voltage switch yard is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to our left looking at the picture and our low  
2 voltage switch yard is to the right. So the Plant  
3 is to the right.

4 We have a two feeder cables coming from  
5 unit 1 and unit 2 that come out from right to left  
6 on this picture and come out to that pull box that  
7 has the four cones on it. Then those two cables  
8 come over and feed these two 4160 to 480 volt  
9 transformers and then the power is fed out to the  
10 high voltage switch art for switching operations.

11 Water was found in the pull box there  
12 with the cones on it. And our corrective action for  
13 that is we now have a quarterly inspection pump out  
14 if necessary of that pull box. We also are trending  
15 the results from that and that's really to make sure  
16 that quarterly is often enough.

17 MR. BARTON: That program has been  
18 implemented?

19 MR. MANSFIELD: The program is in place  
20 now.

21 MR. BARTON: Thank you.

22 MR. MANSFIELD: Yes sir.

23 MEMBER STETKAR: You're still doing  
24 though just the ten year insulation check on those  
25 cables. Is that correct, no feel that there is a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 need to increase the frequency of the insulation?

2 MR. MYER: No, at this time -- this  
3 would be consistent with what other plants have  
4 found, because these are non-safe related they are  
5 in station blackout. So we implement the testing,  
6 ten year testing as part of license renewal as we  
7 prepare for licensee period.

8 Now there's no expectation right now  
9 that they have any problems based on industry  
10 experience. But we are -- knowing that these  
11 emergents would be questionable in the future we're  
12 going to work to keep them dry.

13 MEMBER MAYNARD: What's the source of  
14 the water.

15 MR. MANSFIELD: I'm going to ask for our  
16 support. I don't believe that we have, that we know  
17 for sure that the source of the water other than  
18 ground water leaking into the box.

19 We don't believe it's leaking in from  
20 the top through rain water. Would you like to add  
21 to that?

22 MR. MARTIN: Cary Martin with the  
23 Electrical Group. The water that's coming into  
24 those boxes is ground water. Those boxes were not  
25 designed with any kind of mastics, or you know water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 proofing on them.

2 They are just concrete boxes and ground  
3 water can seep into them. Many of them have little  
4 one by one sumps to collect the water at the bottom  
5 and let it drain away. But this one is not working  
6 and we're going to work on it.

7 MEMBER STETKAR: You mentioned and the  
8 inspection report also mentioned that the safety  
9 related cables are in tunnels and therefore they are  
10 not susceptible to water intrusion. There is actual  
11 operating -- you don't find any water in those  
12 tunnels at all, drains.

13 MEMBER MAYNARD: These particular cables  
14 -- I believe that they were providing power to the  
15 switch house to support switching when you need to  
16 recover your off site power.

17 MR. MANSFIELD: That's correct.

18 MEMBER MAYNARD: They are not  
19 instrumentation type cables that are actually  
20 providing some power. But it is not a main power  
21 cable.

22 CHAIRMAN SIEBER: You don't happen to  
23 have a drawing of your switch art schematic?

24 MR. MANSFIELD: We have it in the cable.

25 It's 2.1 --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MYER: It's really hard to see --

2 CHAIRMAN SIEBER: -- yes, I know. I  
3 brought this. So 2.1-17, that's even harder to see.  
4 I take it you have two off site power sources?

5 MR. MYER: That's correct. Cary, you  
6 want to --

7 CHAIRMAN SIEBER: One goes to Clark Hill  
8 Reservoir through Augusta and the other goes to  
9 South West of the Plant. Is that correct?

10 MR. MYER: I believe that's correct.  
11 That's -- I can't remember the name of the line now,  
12 but yes.

13 CHAIRMAN SIEBER: When you define the  
14 scope of station blackout, saying the scope of  
15 license renewal where on that chart do you say is in  
16 scope and -- you know I see the dividing line that  
17 is the theoretical dividing line between the high  
18 voltage and the plant type switch gear.

19 But I'd like to know where your  
20 restoration circuit is for station black out on that  
21 chart.

22 MR. MARTIN: Cary Martin again. It goes  
23 all the way out to the power circuit breakers. The  
24 230 kV power circuit breakers.

25 CHAIRMAN SIEBER: Could you stand up

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there and go through it because there is a bunch of  
2 --

3 MR. MARTIN: It's a red color and the  
4 feeder cable goes in between two 230 kV breakers and  
5 we actually included both of those breakers in the  
6 scope because there wasn't a preferred line up. So  
7 we actually have both of these are in and then this  
8 is the other source.

9 It comes up here and again it's between  
10 two 230 kV power circuit breakers. So we included  
11 both of those. So we actually have four breakers.

12 CHAIRMAN SIEBER: And so you're looking  
13 -- you're Aging Management Program for that is the  
14 passive parts of it.

15 MR. MARTIN: That's correct.

16 CHAIRMAN SIEBER: The foundations and  
17 support --

18 MR. MARTIN: The breakers are in scope,  
19 but they are screened back.

20 CHAIRMAN SIEBER: Okay, I can see why I  
21 couldn't find it on here because yours is colored.  
22 This one is not, okay. Could you, while you're  
23 relaxing back here take a pencil or something and  
24 color that in for me.

25 MR. MARTIN: We'll get you a larger

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 colored copy.

2 CHAIRMAN SIEBER: Even larger, okay. I  
3 would take a regular full sized.

4 MR. MYER: We actually will give you a  
5 copy of this drawing at the completion of this. We  
6 have one of the handouts. Anything we've shown you  
7 on this screen we're going to have you a copy of.  
8 So you'll have that one.

9 CHAIRMAN SIEBER: Well, you can see the  
10 source of my confusion.

11 MR. MYER: Yes, now I understand.

12 CHAIRMAN SIEBER: Okay.

13 MR. MYER: In summary, we had --

14 MR. BARTON: I have a question.

15 MR. MYER: Yes.

16 MR. BARTON: It's on the inspection  
17 report items. Your inspection report talks about a  
18 past of numerous leaks in varied fire protection  
19 piping.

20 Now, my question to you is what's the  
21 cause, poor insulation, unstable ground, whatever.  
22 But what are you doing to ensure that you have  
23 reliability of your underground buried fire  
24 protection piping, because the question I got after  
25 we announced the inspection report is, you know how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 do I know that this piping isn't going to fall apart  
2 because of poor insulation or whatever.

3           Whatever the root cause of all of these  
4 leaks is. I don't understand. Can you tell me,  
5 talk about that a little bit?

6           MR. MANSFIELD: We have a buried piping  
7 program in place right now where we used to do  
8 inspections on a number of systems including fire  
9 protection. So that's in place as we speak.

10           We do periodic pressure testing of the  
11 system. I don't know, and I'll ask for some help if  
12 anyone knows. I don't know if we have a root cause  
13 for the leakage other than it's carbon steel piping  
14 buried underground. I'm sorry, cast iron piping.

15           MR. MYER: Going back through the  
16 history of the Plant I guess initially there were  
17 probably a number of poor insulation items that came  
18 up and were fixed early on.

19           A lot of the art is not in the seismic  
20 backfill and so there is some amount of settling  
21 that's going to be expected as you have in about any  
22 kind of mechanical cast iron joints.

23           And so periodically we have some leakage  
24 of them. I know that we -- the complainant  
25 considered a number of different options to try and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 identify them when their small leaks. But any leaks  
2 that would start to have an impact on the system  
3 shows up through the jockey pump coming on more  
4 frequently or running continuously.

5 And all of those monitorings will drive  
6 them to start searching for leaks. There is  
7 technology out there now and I know the Plant has  
8 used it to go out and find leaks that are not  
9 showing up above ground. And they are doing that.  
10 They are pretty aggressive in keeping the system.

11 MR. BARTON: Do you really monitor the  
12 fire protection planting which has a history of  
13 reflecting leaks. Do you view their program and are  
14 satisfied that they are doing an adequate program on  
15 fire protection planting. You made an issue in your  
16 reflection report of various leaks in the piping  
17 system over a long period of time. So, I don't  
18 where you guys stand on it.

19 MR. LAKE: My name is Louis Lake, I was  
20 the lead inspector for the NRC inspection. We  
21 looked at their Aging Management Program and their  
22 current programs in monitoring the fire protection  
23 and we find that the programs are adequate.

24 We actually did do a visual inspection  
25 on the inside diameter of disassembled fire

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 protection piping to look at the condition internal  
2 in the pipe separate from the mechanical connections  
3 of the cast iron.

4 And the condition -- internal condition  
5 of fire protection piping at the site was, it almost  
6 looked pristine as if it was brand new. So, there -  
7 - as far as looking for leaks as a result of failed  
8 piping aside from the mechanical connections I think  
9 their program that they have identified in their  
10 Aging Management Program and their current fire  
11 protection program surveillances are adequate in  
12 identifying any problems with the fire protection  
13 system.

14 MR. MYNAN: I would just add, in this  
15 particular area we have a fairly, we've had a number  
16 of issues is we've had the main header that goes all  
17 the way around the perimeter of the power bar. But  
18 then we have a number of lines that tape off and go  
19 to remote locations within the owner patrolled area.

20 The main one, that's the long one goes  
21 out to our fire training facility which is almost a  
22 mile through the pine trees and all the way out  
23 there.

24 What we have observed is when we start  
25 our fire pumps, for whatever reason there's some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 water hammer that occurs down on that end of the  
2 piping which is where most of the leaks, in fact we  
3 just had a pretty significant one here a few months  
4 back that actually caused a big sink hole in the  
5 parking lot. But that's where we're seeing the  
6 issues when we talk about the majority of the leak  
7 issues that we have.

8 The reason we're kind of trying to  
9 manage our way through it a little bit more rather  
10 than just fixing a piece at a time and not fix the  
11 bigger issue is we're trying to work through the  
12 interface with a potential for new units because  
13 this line goes right across the foot print for the  
14 new operating units.

15 So we're trying to decide does that, do  
16 we need something separate or do we want to put  
17 something interim in to try to manage this issue and  
18 then meet the needs for potential units on Vogtle  
19 three and four, so that's my understanding of the  
20 biggest issue we have with underground piping.

21 MEMBER MAYNARD: Okay, do you have the  
22 ability to isolate that fire?

23 MR. MYNAN: Yes, we do. But when we do  
24 it we take a hit on our insurance because it also  
25 goes to our warehouse.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER MAYNARD: I understand, but I'm  
2 worried about the impact on Plant fire protection.

3                   MR. MYNAN: Yes, we can isolate it and  
4 we don't have -- in fact, this recent one we had  
5 outside the gate we were in a 24-hour shut down  
6 until we could get the line isolated and then  
7 recover the line piping within the power block.

8                   So, but we have several post indicator  
9 valves that we can isolate and isolate that section  
10 of the piping. But as I mentioned we don't like to  
11 leave it isolated because it's an issue of  
12 insurance.

13                   MEMBER MAYNARD: Looks like it's  
14 important to resolve that for both the commercial  
15 and safety standpoint.

16                   MEMBER MYNAN: Yes, yes I agree with  
17 you.

18                   CHAIRMAN SIEBER: I have a couple of  
19 more questions to ask. One of them relates to  
20 license renewal and one is a result of curiosity.

21                   Relating to license renewal, underneath  
22 your Plant is about a thousand foot thick lens of  
23 sand down to bedrock. What steps do you take to  
24 measure the settlement of Plant buildings  
25 individually and all together so that you don't end

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 up with stresses and stains from piping and conduit  
2 and so forth that go from building to building?

3 MR. MYER: We've got a pretty extensive  
4 monitoring program. We've got about 160 points that  
5 we monitor. They've been monitoring them since day  
6 one. I believe now all but 16 of them are on a five  
7 year cycle because settlement has reduced to a level  
8 that we've got approval for five years and 16 are  
9 still on a one year cycle.

10 CHAIRMAN SIEBER: But you have seen  
11 settlements since the Plant was built?

12 MR. MYER: Yes, and as would be expected  
13 early on it was significant and it's leveled off.  
14 And like I say, most locations it's now been so  
15 quiet that we've gone onto a five year cycle.

16 CHAIRMAN SIEBER: You do that with  
17 surveying instruments or highway survey type  
18 instruments?

19 MR. MYER: I'm not sure if it's highway,  
20 but it's Georgia Power Company does it, yes.

21 CHAIRMAN SIEBER: Right, it's highway.  
22 I would presume that the settlements that you  
23 measure are relative to some base point in the  
24 Plant?

25 MR. MYER: That's right, we'll measure a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 base point and then we'll use targets on buildings  
2 that are built off that one base point. And that  
3 base point, it's relative location does tend to some  
4 times vary from measurement to measurement with the  
5 overall site. But all of the readings are off the  
6 one base point.

7 CHAIRMAN SIEBER: That would be my  
8 concern.

9 MR. MYER: Right.

10 CHAIRMAN SIEBER: And the other concern  
11 is the frequency with which you measure because it  
12 does impact the structures.

13 MR. MYER: Right.

14 CHAIRMAN SIEBER: And you -- I'm sure  
15 you have from seismic reconstruction -- separation  
16 between buildings with the seal in between?

17 MR. MYER: In all the locations we have  
18 allowable -- differential settlement all redefined  
19 based on the stressing in the piping. It's been a  
20 couple of years since I looked at the data, but we  
21 really haven't had much relevant settlement.

22 But there were only a handful that the  
23 stresses were even to 50 percent of the allowable  
24 for the differential that we had.

25 CHAIRMAN SIEBER: Yes, but that's added

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on to all the other stresses.

2 MR. MYER: Yes, that was 50 percent of  
3 what we allowed in settlement which is a small  
4 margin of the stresses we have --

5 CHAIRMAN SIEBER: Of the total stresses  
6 --

7 MR. MYER: Right.

8 CHAIRMAN SIEBER: -- piping can take.  
9 Now my curiosity question is, the picture the  
10 planter I take it's a submerged right behind the  
11 cooler point?

12 MR. MYER: That's correct.

13 CHAIRMAN SIEBER: And behind the -- or  
14 beyond East of the Savannah River is the Savannah  
15 River Plain with the Department of Energy?

16 MR. MYER: That's correct.

17 CHAIRMAN SIEBER: And on the horizon  
18 there I can see a white building?

19 MR. MYER: That is the cooling tower for  
20 the K-reactor.

21 CHAIRMAN SIEBER: Is that a hazard in  
22 your emergency plan?

23 MR. MYNAN: No, it was never placed in  
24 operation.

25 CHAIRMAN SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. MYNAN: They spent \$300 million  
2 dollars and then cancelled the production program.

3 CHAIRMAN SIEBER: It actually doesn't  
4 operate that way?

5 MR. MYNAN: No.

6 CHAIRMAN SIEBER: Okay, thank you, I've  
7 also been there and I thought that's what it was but  
8 I didn't know whether it was operation or not. But  
9 you're supposed to take into account hazards that  
10 are close to your Plant and or nearby on  
11 transportation. Savannah River doesn't have a lot  
12 of transportation, so --

13 MR. MYNAN: No, we actually meet with  
14 them every six months with their emergency response  
15 team is pretty interesting mainly because of the  
16 number of deer hunters that they have over there and  
17 how they can manage it.

18 But when we meet with them actually the  
19 hazardous material to have over there doesn't really  
20 pose any sort of large area release threat to our  
21 station.

22 Believe it or not, I know it's kind of  
23 surprising the first time they told me, it's because  
24 of all the tension on the ground, you know we  
25 actually pose a bigger threat to them which is why

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we meet with them.

2 CHAIRMAN SIEBER: Your emergency plan  
3 coordinated so that the incident that your plant you  
4 notify them?

5 MR. MYNAN: Yes, yes.

6 CHAIRMAN SIEBER: And they take action,  
7 okay.

8 MR. MYNAN: Like I said we drill with  
9 them at least once a year. But then we also  
10 interface with them twice a year, once at our site,  
11 and then we actually meet at their emergency  
12 response. All of the emergency directors go over  
13 and meet with them at their response center.

14 CHAIRMAN SIEBER: Now, Barnwell is about  
15 35 miles to the Northeast?

16 MR. MYNAN: Well, yes.

17 CHAIRMAN SIEBER: Okay, thank you.

18 MR. MYER: In summary, as I shared we  
19 had a very experienced team that created a high  
20 quality license renewal application. We made  
21 extensive use of the GALL and we're very familiar  
22 with it.

23 We had what I would consider thorough  
24 and successful audits and inspections of the Plant.  
25 And throughout the inspections and audit I think our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 license and renewal team was highly responsive to  
2 the NRC and I think that was exemplified by us not  
3 having any open items or confirmatory items. And we  
4 believe that Vogtle is prepared to manage aging  
5 beyond 40 years, thank you.

6 MR. BARTON: I have a question.

7 MR. MYER: Yes.

8 MR. BARTON: You had a chemistry upset  
9 or something with steam generators a while back. I  
10 don't remember the details of that, but do you still  
11 have the original steam generators or have you  
12 changed them out?

13 MR. MANSFIELD: No, we still have the  
14 original steam generators.

15 MR. BARTON: So have them for another --  
16 okay, no reason to change them as you see in the  
17 future?

18 MR. MANSFIELD: There may be a change  
19 out in the future, but we don't anticipate it at  
20 this point based on the degradation we're seeing on  
21 the tubes and on the structure.

22 MR. BARTON: All right, I just wondered  
23 with the chemistry upset whether it was some long  
24 term damage and you saw a need to replace it. Okay,  
25 thanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HOLIAN: Do you use sink injections?

2 MR. MANSFIELD: We do.

3 MR. HOLIAN: And you've been doing that  
4 for a long time?

5 MR. MANSFIELD: What the last cycle of  
6 the generator, is that about --

7 MR. MYNAN: We did mid-cycle injection  
8 because of issues we saw with AOA if we tried to do  
9 beginning of cycle. This recent core design on  
10 Vogtle one we started zinc injections at the  
11 beginning of cycle and we started zinc injections on  
12 unit 2 as well so we could get full cycles since  
13 injection on primary side. So, these would be the  
14 first operating cycles that we've full cycle zinc  
15 injections.

16 MR. MACFARLANE: Just to touch on your  
17 question about steam generators. Now this is Mike  
18 MacFarlane with Southern Nuclear. And we did do a  
19 chemical cleaning on the secondary side of that  
20 generator, those generators.

21 And also the Vogtle has the monolyth  
22 generator which has the thoroughly treated 600 tubes  
23 and stainless steel support plates. And so it is a  
24 little bit of a generation beyond what the early  
25 generation PWR's had. So it is a --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: Not good enough.

2 MR. MACFARLANE: Well I understand that,  
3 but that's why at this time it still hasn't had the  
4 problems that some of the others have had yet.

5 MEMBER MAYNARD: Are all the tubes  
6 thermally in yield?

7 MR. MACFARLANE: That's correct.

8 MEMBER MAYNARD: Well some of the  
9 earlier ones --

10 MR. MACFARLANE: They are thermally  
11 treated as opposed to mechanical yield. I mean the  
12 term for those tubes would be thermally treated.

13 CHAIRMAN SIEBER: Any other questions  
14 from the committee members?

15 (No response.)

16 CHAIRMAN SIEBER: If not we'll rule a  
17 bit early, but the chance are we may finish early.  
18 So, I'll like to take a break until five minutes  
19 after 3:00 p.m.

20 (Whereupon, off the record from 2:43  
21 p.m. until 3:05 p.m.)

22 CHAIRMAN SIEBER: I'd like you all to  
23 take your seats so that we can continue our  
24 meeting. And I'd like to return to Brian to say  
25 a couple of things before we start on this fast

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 review of the SCR. Brian?

2 MR. HOLIAN: Good, thank you. Just a  
3 couple of items before I turn it over to Don  
4 Ashley, the Senior PM in charge of Vogtle.

5 One is really I wanted to commend  
6 Donnie also as he's here as we've had Plants  
7 extend into ASOB proceedings and the like,  
8 Donnie's had not only Vogtle application but  
9 also the Oyster Creek application. So you know,  
10 a lot of work on his plate and I just wanted to  
11 highlight that to the committee.

12 MEMBER MAYNARD: Did he deserve all that  
13 punishment.

14 MR. HOLIAN: And he's coping just fine  
15 with that, how about that. The other thing I wanted  
16 to mention and I did mention the staff here and I  
17 just wanted to mention we do have a lot of technical  
18 members from the staff, both branch chiefs and  
19 technical members from the technical divisions also.  
20 I won't mention them.

21 But just remind them as they get up and  
22 answer questions to make sure you give your name and  
23 division for the record.

24 The other item I wanted to mention was,  
25 you know we did get the committee a draft, SCR and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 even on the licensee slides they mentioned 39  
2 commitments and you might notice from our list in  
3 Appendix A there's 41 numbered there.

4 Most of you probably caught that there  
5 were two numbers missing. So really technically  
6 there's only 39 there, numbers through 41 and that's  
7 part of the tech editing that we still picked up  
8 that you didn't see, but we are finalizing and  
9 picking up those kinds of corrections. So, the  
10 commitments do match 39 and I just want to just  
11 mention that.

12 And finally, I did want to highlight to  
13 the committee you do have us back again tomorrow for  
14 a license renewal status update. We'll be covering  
15 just the program in general. Things like the IG  
16 report, things like the GALL update where we're  
17 going with that, license renewal guidance documents,  
18 how we're updating that for both us and the industry  
19 and also touching on schedules and what we have in  
20 house. So we look forward to that tomorrow  
21 afternoon also.

22 And with that I'll turn it over to  
23 Donnie Ashley.

24 MR. ASHLEY: Thank you sir, good  
25 afternoon, my name is Donnie Ashley. I am a Project

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Manager for the Vogtle Electric Generating Plant  
2 license renewal project.

3 I along with other members of the staff  
4 will discuss our review of the Vogtle license  
5 renewal application as documented in the draft SER  
6 which you've been provided.

7 I'll begin with a brief overview of the  
8 application itself and the renewal effort followed  
9 by the scoping and straining review results. The  
10 audit inspections, the audit and inspections will be  
11 discussed next. Mr. Louis Lake who you've met  
12 already is a lead inspector for the Region II  
13 Inspection Team and he's here to discuss that  
14 inspection result. I'll then continue with the  
15 discussion of the SER audits and results of sections  
16 three and four of the SER.

17 The renewal application was submitted in  
18 June of 2007. As was mentioned earlier the unit 2  
19 Vogtle only had 18 years experience and the reg's do  
20 indeed require 20. The applicant requested and was  
21 granted an exemption in January 2007 to that  
22 requirement or prior to the submittal of the  
23 application for both units.

24 The application was accepted in August  
25 of 2007 and had a Federal register notice published

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 at that time. Subsequent to the receipt of the LRA  
2 the measurement uncertainty recapture that Mr. Myer  
3 spoke of earlier was granted and that changed the  
4 power level from what was shown in the application  
5 from 3565 megawatts thermal to 3625.

6 On the safety evaluation report the  
7 staff was aided with audit reviews and additional  
8 information provided by the applicant in response to  
9 87 RAI items, and a 173 audit questions from the  
10 audit itself.

11 These audit questions make up the Q&A  
12 database which was included in the audit summary  
13 report that was provided to you.

14 When considering notes A through E of  
15 the AMR line items we've got approximately 87  
16 percent of the line items as being consistent with  
17 GALL.

18 The information collected from the audit  
19 and RAI responses were used extensively in the  
20 development of the draft SER. And as Brian  
21 mentioned, in actuality of the 39 commandments the  
22 applicants did not use two numbers when the  
23 application was submitted.

24 We changed Appendix A in our working  
25 draft for the final version to show that commitment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 number ten and commitment number 22 were not used at  
2 Vogtle. The SER contained no open items and no  
3 confirmatory items.

4 MR. BARTON: I have a question, does SER  
5 section 33225 talk about hardening and loss of  
6 strength due to elastomer degradation. And there's  
7 a discussion in there and I thought I read the SER  
8 was issued, had been issued without this item being  
9 resolved and yet I only find the open line. Was  
10 this issue resolved?

11 MR. ASHLEY: It came up as a RAI during  
12 the audits and at the time that the draft was made  
13 that had not been finished. But subsequently, the  
14 next paragraph --

15 MR. BARTON: Okay, because I kept  
16 looking for an open item. This stated that this was  
17 not resolved at the time, all right. But it is  
18 resolved?

19 MR. ASHLEY: It is now sir.

20 MR. BARTON: Okay.

21 MR. ASHLEY: As Brian mentioned and as  
22 part of the comments that you had provided back on  
23 review of some of the staff you did see some editing  
24 remarks in the draft and those have subsequently  
25 been removed and corrected.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BARTON: Thank you, that's half the  
2 one I listed comments against you guys. But, since  
3 you said you've taken care of all of that I guess I  
4 won't bore you with them later and they will remain  
5 in my report because I won't take it --

6 MR. ASHLEY: It just gives you room for  
7 others. The specific audit -- excuse me, I'm on the  
8 wrong slide here. In the audit and review, the  
9 audit summary report, I'm sorry was made publicly  
10 available in September of '08 and it includes the  
11 review results, the Q&A database, and the list of  
12 the documents that were reviewed by the team.

13 MR. BARTON: Did your summary report  
14 have any meat in it or was it just 62 pages of  
15 things that you reviewed, but did not get the whole  
16 report?

17 MR. ASHLEY: The Q&A database was the  
18 vast part of it. It's a little different than what  
19 you probably have seen in the past. It's now a  
20 summary report and I believe that Brian will  
21 probably be talking about those later on rather than  
22 a input directly to the SCR that you --

23 MR. BARTON: I just wanted to know value  
24 it was because all I got was 62 pages with a lit of  
25 all the documents you reviewed at the site. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 don't know what value this is.

2 MR. MEDOFF: To address your comment,  
3 this is Jim Medoff of the staff, I'm acting brand  
4 chief for Jerry Dozer today whose the branch priest  
5 for the technical review staff. And I'm also the  
6 senior technical reviewer for Vogtle.

7 With respect to the audit summary report  
8 we did it a little bit of different for Vogtle  
9 because we were changing our process to the new  
10 processes so that it's commending with the Beaver  
11 Valley application.

12 So for Vogtle, for the audit report the  
13 decision was made to only list -- give you a list of  
14 the documents we looked at and to include the  
15 question list that we sent to the applicant and put  
16 their responses that they submitted back to us in  
17 the audit report.

18 And then to address the questions that  
19 we asked during the audit we wrote them up in the  
20 SCR product. So, any of the questions that you see  
21 in the database should be written up in the SCR.

22 MR. ASHLEY: Section 2 of the SCR  
23 discusses structures and components subject to the  
24 aging management review. It has to do specifically  
25 with scoping methodology for the license renewal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 application and it covers the plant level scoping  
2 results of the relevant systems and structures.

3 The staff found the results by the  
4 Applicant also meet the review criteria in the  
5 standard of view plan and in accordance with the  
6 agency.

7 In the structures and components section  
8 for 2.3 there was 98 mechanical systems, 34 of which  
9 were balance of plant systems. The staff believes  
10 that the available guidance that the applicant used  
11 in identifying such components is adequate.

12 There was three opponents added to the  
13 system. The non-ESF, Exhaust Fan Housing, and unit  
14 heaters were added as a missile barrier function to  
15 make up air duct for the electrical vent system has  
16 an A-2 scoping issue. And the chiller compressor  
17 components, housing filters and dryers were added to  
18 the scope as a result of RAI's.

19 In Section 2.4 in scoping and screening  
20 there was no emissions of structural components  
21 within the scope of license renewal. 2.5 and  
22 electrical instrumentation and control we again saw  
23 no emission of electrical and instrumentation  
24 components that we didn't scope.

25 I'd like to ask Mr. Lake now if he would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 go ahead and discussion the inspections.

2 MR. LAKE: My name is Louis Lake, I'm a  
3 Senior Reactor Inspector from Region II of the  
4 division of reactor safety. And I was the  
5 inspection team leader for the on-site inspections  
6 for license renewal.

7 MR. BARTON: I have a question, the  
8 cover letter on the inspection report stated the  
9 Plant equipment was being maintained adequately.

10 MR. LAKE: Yes.

11 MR. BARTON: My question is, and I'm not  
12 trying to be smart here. Does that mean the  
13 equipment is being maintained in accordance with  
14 your expectations or barely satisfactory?

15 MR. LAKE: No, it was in accordance with  
16 our expectations.

17 MR. BARTON: Now, the reason I ask you  
18 that is because on page two of the report they say  
19 the Plant equipment is being maintained adequately  
20 "in most of the Plant."

21 MR. LAKE: Yes.

22 MR. BARTON: What does that mean?

23 MR. LAKE: Well, we went on further to  
24 clarify that due to the results of previous NRC  
25 inspections inside containment that resulted in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 notice of violation that the condition of the  
2 components inside containment weren't necessarily  
3 something that we could ignore and we felt we had to  
4 address.

5 Now, the reaction by the licensee  
6 satisfied our concerns and the corrective actions  
7 that he is taking also satisfied what our  
8 expectations were.

9 MR. BARTON: So it was really pertaining  
10 to the issue you found with the white stuff in the  
11 container?

12 MR. LAKE: That's correct.

13 MR. BARTON: All right, because I was  
14 wondering -- I wanted to make sure you weren't  
15 talking about, you know like out buildings or  
16 auxiliary buildings other than the main power block  
17 that you didn't find conditions there to your  
18 expectations. I just wanted to make sure that's not  
19 the issue.

20 MR. LAKE: That is not the issue.

21 MR. BARTON: Okay.

22 MR. LAKE: This slide is kind of left  
23 over from some previous, older presentations and  
24 it's geared towards ACR's members who may remember  
25 some scoping issues that -- or scoping that we had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 when we did our onsite inspections.

2 And basically they have been revised and  
3 our scope for the onsite inspections were reduced  
4 when it came to reviewing the components that  
5 belonged in the license renewal program.

6 We used to almost duplicate what NRR did  
7 in identifying components. And since then the  
8 manual chapters 2516 has been revised. It was about  
9 three or four years ago. And we now concentrate and  
10 put our focus on 10 CFR 54.482 situations which are  
11 specifically, we are non-safety related components  
12 that could effect safety the way the equipment  
13 functions.

14 We put our resources towards that  
15 review. And again, this may be a slide that has  
16 fulfilled it's purpose up to this point in time. I  
17 think most of the CRS members probably remember the  
18 revision in this scoping, but that was the intent of  
19 this slide.

20 NRC inspection manual chapter 2516, it  
21 provides the policy and the guidance for the review  
22 and inspection activities associated with license  
23 renewal inspections. And the NRC staff verifies the  
24 accuracy of the license Aging Management Program  
25 associated with the applicant's request for license

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 renewal under 10 CFR part 54.

2 Now, the inspections that are referenced  
3 in the manual chapter are conducted in accordance  
4 with inspection procedure IP 71002. And it's to  
5 verify that the applicants license renewal program  
6 including the support activities are implemented  
7 consistent with the requirements of 10 CFR part 54.

8 This includes the guidance that requires  
9 us to prepare and submit an inspection plan. We  
10 also schedule our inspections to support the NRR  
11 review in a culmination of a draft SER.

12 The resources that we use consist of a  
13 team typically of five members. However, I was  
14 fortunate in having the support of seven inspectors  
15 and the reason for this is that it facilitated the  
16 training of new license renewal inspectors and also  
17 the sharing of inspections between regions.

18 The team included one inspection from  
19 Region I and one inspector from Region III. Also  
20 included in our team was a member of the ACR staff  
21 who not only observed our activities but also  
22 participated by conducting some of the inspections.

23 I'd like to thank Chris Brown for his  
24 excellent support during the inspections. The  
25 objective of these inspections are focused on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Aging Management Programs and it's to confirm that  
2 the existing Aging Management Programs are working  
3 well and also to examine the applicants plans for  
4 establishing new Aging Management Programs and/or  
5 enhancing existing ones.

6 The inspection is typically two weeks in  
7 length and those two weeks are separated by a week  
8 back at the regional headquarters in Atlanta where  
9 we review what we had found up to that point in  
10 time. And also maybe revise our plans for the  
11 remaining inspections.

12 We review the 100 percent of the  
13 applicants Aging Management Programs. The  
14 inspection requirements and the inspection procedure  
15 requires that the sample programs, that we had  
16 enough staff and resources and time that we did all  
17 38 management programs.

18 And we did that to verify that the aging  
19 effects will be managed so that there is reasonable  
20 assurance that the intended function would be  
21 maintained consistent with the current licensing  
22 basis throughout the period of extended operation.

23 We also interviewed personnel and we  
24 examined records. The records of past tests,  
25 surveillances, operating experiences and corrective

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 actions from the existing Aging Management Programs.

2 Also, we examined implementation plans  
3 for existing programs new and expanded Aging  
4 Management Programs. We verified the inclusion of  
5 future tasks were included and established in site  
6 task commitment tracking systems.

7 We also verified material conditions of  
8 the plant was being adequately maintained by  
9 conducting plant walk downs, including walk downs of  
10 the containment during outages when the containment  
11 was open.

12 Now the containment was not open during  
13 our inspection, it was only open that -- by  
14 refueling outage prior to our inspection for unit 1  
15 and unit 2 was after our inspection. I'll go  
16 through that discussion later.

17 The Aging Management Program inspection  
18 was conducted on site from May 19th to June 6, 2008.  
19 As I said before with the week in Atlanta for  
20 documentation review and analysis.

21 The inspection team concluded that  
22 existing programs are generally functioning well at  
23 the aging management portions of the license renewal  
24 activities were conducted as described in the  
25 application. And that there is reasonable assurance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that aging effects would be properly managed  
2 throughout the period of extended operation.

3 In walking down Plant systems and  
4 examining Plant equipment the inspectors found no  
5 significant adverse conditions except for some  
6 degradation noted in material condition of surfaces  
7 inside containment due to general corrosion that  
8 I'll cover in more detail later. It appears plant  
9 equipment was being adequately maintained.

10 The applicant had established  
11 implementation plans in the action requests system  
12 to track the committed future actions for license  
13 renewal to ensure that they are completed.

14 We concentrated heavily on that issue  
15 because their extended period of operation is so far  
16 away you're talking about 2027, and you know this  
17 system needs to be very comprehensive and be able to  
18 track that, you know they do what they said they  
19 were going to do when the time comes.

20 We did not have an observation on that  
21 and recommended that they do make some enhancements  
22 in that and be clearer on what they put in their  
23 implementation program.

24 Region II will follow up with future  
25 inspections. Mainly in the 2026 and 2027 time frame

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and we'll be using inspection procedure 7003 and  
2 inspection scheduled after license application  
3 approval and just prior to the period of extended  
4 operations.

5 MEMBER STETKAR: In the SER you mention  
6 only, back to the cable issue again, you mention  
7 only the two year inspection requirement for the  
8 underground cable. I looked for -- since the  
9 applicant apparently made a commitment to change  
10 their inspection philosophy I looked to see how that  
11 was referenced in the SER and it isn't.

12 The SER talks only about ten year  
13 inspection events, you know testing of insulation  
14 and the standard two year inspection. Under the  
15 discussions of operating experience, under  
16 discussions of inspection results and things like  
17 that.

18 I was curious why that information  
19 didn't filter into the SER for that particular  
20 program?

21 MR. ROGERS: May I help with that one?

22 MR. LAKE: Sure.

23 MR. ROGERS: I'm bill Rogers, I'm in the  
24 division of license renewal in the interim review  
25 branch. And this issue is currently being looked at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 extensively by the staff and we really have it  
2 divided up into two areas.

3           The current Plant operation which is  
4 currently in the part 50 basement, also under  
5 license renewal. And it's being addressed in both  
6 areas. If the inspection team is doing inspections  
7 to find the adverse conditions that might be  
8 addressed by the region during current operation.

9           In addition, at headquarters the  
10 division of engineering, the electrical branch, is  
11 also issued some generic communications in this area  
12 related to water in the manhole and cable conditions  
13 in general.

14           One of those is generic letter 200701  
15 which was inaccessible or underground power cable  
16 failures that disabled accident mitigation systems  
17 or caused plant transients. And that was issued on  
18 February 7, 2007. And that generic letter requested  
19 of the licensee's was to provide us information  
20 specifically to cable failures. And part of that  
21 would be due to significant moisture or submergence.

22           The licensee's have all responded to  
23 that generic letter, that information is being  
24 gathered, it's currently under review by a division  
25 of engineering and they are putting together a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 position on, I guess on our analysis and review of  
2 that.

3 Now, in license renewal space for part  
4 54 the staff has addressed the water in the manhole  
5 issue and the corresponding raceways in the GALL  
6 report which is Section 1183 which relates to  
7 inaccessible cables.

8 And part of that section requires that  
9 if you are to use that program that you do the two  
10 testing points which one is prior to the point of  
11 extended operation and one is to follow-up ten years  
12 later during the period of extended operation.

13 So, the three points of 1183 requires,  
14 as I said the cable tested prior to the period of  
15 extended operation to determine functionality. And  
16 it's significant moisture determined during the  
17 required periodic inspections of the manholes.

18 Then the period of this inspection would  
19 be required to be increased accordingly. And the  
20 corrective actions would expect to be taken to  
21 remove the water when discovered.

22 So that is our staff's position on the  
23 two different periods of operation. Does that help?

24 MEMBER STETKAR: Partly except that the  
25 SER makes no mention of a variable inspection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 frequency for water accumulation as a function of  
2 operating experience. It just says the inspection  
3 team looked at the operating experience and the  
4 staff has found the two year inspection frequency to  
5 be acceptable.

6 MR. ROGERS: Okay, maybe I can get  
7 someone else to address that specifically.

8 MR. LAKE: Just to elaborate on that too  
9 --

10 MEMBER STETKAR: I understand the  
11 difference between current operations. But I'm  
12 looking at this document which is, you know SER --

13 MR. LAKE: I was going to say that --

14 MEMBER STETKAR: -- 19 years from now or  
15 whatever it is supposed to apply to.

16 MR. LAKE: -- I was going to say in our  
17 inspection report itself I think we refer to them  
18 going to a quarterly frequency. And then if  
19 conditions permit they can then go to the two year.

20 MEMBER STETKAR: And I guess my  
21 curiosity is why that didn't get reflected back into  
22 the SER, because as I read the SER I could have  
23 taken verbatim what they had in the license renewal  
24 application and pasted it in here and it's pretty  
25 much repeated without that additional information

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 which I think is useful information.

2 MR. ASHLEY: Part of that is timing.  
3 During the issuance of the inspection report and the  
4 creation of the draft. Also, Roy Mathew --

5 MR. MATHEW: This is Roy Mathew from  
6 Electrical Grants. When I was in the license  
7 renewal branch I did review this program. During  
8 our audit we looked at the two cables that was in  
9 the scope of this program.

10 During that time frame we didn't see any  
11 water. So you didn't reflect anything in the ACR.  
12 But if you look at the AMP, Aging Management Program  
13 you see they had to maintain -- they have to inspect  
14 the manholes for a period of at least a minimum of  
15 two years and their collective action is supposed to  
16 take care of the frequency. If the applicant finds  
17 water in the manhole they have to adjust the  
18 frequency accordingly.

19 So the water issue was not discussed in  
20 the SER because at that time we didn't have any  
21 information or the operating experience that  
22 reviewed suggest that they had water. So, the  
23 Region subsequently they did the inspection. They  
24 found they identified the water issue.

25 MR. HOLIAN: This is Brian Holian, I'd

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 expect, other than the timing issue, that we could  
2 pick that up in the SER and make it complete story  
3 of it. So I accept that --

4 MEMBER STETKAR: It is truly a timing  
5 issue, although there is --

6 MR. HOLIAN: -- I accept that. You  
7 know, that shows that coordination I think it's  
8 known to the staff. But for completeness we'll take  
9 that comment. I agree in expanding that inspection.

10 MEMBER STETKAR: I find the inspection  
11 is really, really useful. But I hope that the  
12 results from those inspections and commitments based  
13 on those instructions are actually folded back into  
14 the SER.

15 MR. MATHEW: But, I want to make a  
16 point. Inspections are identifying issues with the,  
17 you know manholes that's being in the water. We are  
18 from the electrical branch part of part 50  
19 activities. The licensees are expected to maintain  
20 the cable qualification to the environment that they  
21 are in.

22 So, part of the part 15 regulatory  
23 requirements they ask supposed to qualify those  
24 cables for that, if it is finished under subversive  
25 conditions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HOLIAN: This Brian Holian again.  
2 Billy Rogers mentioned that and the staff sometimes  
3 tries to cut it between part 50 and part 54. And I  
4 think what the committee is looking for is a, you  
5 realize that might be acceptable according to the  
6 GALL criteria, but put reality and truth into what  
7 their program is like at the site. So, you know we  
8 can expand that.

9 MR. LAKE: Okay, during our inspections  
10 you identified some enhancements I'd like to  
11 discuss, at least two of those enhancements and  
12 they've been discussed at length earlier by the  
13 licensee, but I'd just like to give you our  
14 inspection results as we saw them.

15 And specifically the AMP, the Aging  
16 Management Program for medium voltage non-safety  
17 related cables it's a new program that commits the  
18 licensee to establish a program to take periodic  
19 actions to prevent normally energized medium voltage  
20 underground cable from a manning submerged in water  
21 for a long period of time.

22 At this point I'd like to say that the  
23 cable that was used for these 4 kV lines, the two 4  
24 kV lines in question was not designed for  
25 continually being submerged. We got that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 information from the licensee.

2 And there are only two underground  
3 cables in the scope of the program that run from the  
4 turbine building to the 4 kV switch yard as was  
5 presented earlier.

6 Those cables go through three pull  
7 boxes. I know that they showed you one, that was  
8 the one that probably had the most water in it.  
9 But, there were two others that did have water in  
10 it. And we identified those and these tables are  
11 needed as they stated for recovery from loss of off  
12 site power.

13 And originally the applicant had  
14 established a once every four year preventative  
15 maintenance task of pumping any existing water from  
16 electrical cables outdoor pull boxes. I know that,  
17 you know we identified that this four year  
18 frequency, when it came to the Aging Management  
19 Program was revised to two years. And Plant records  
20 show that cable pull boxes at this Plant are often  
21 found with various amounts of water. That the three  
22 that contained the 4 kV cables in the scope of the  
23 licensee renewal program were just pumped in June of  
24 2007 and again during our inspection in 2008.

25 And Plant records reflect a history of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 repeated attempts at establishing different measures  
2 to prevent pull boxes from flooding or to  
3 periodically remove water.

4 The applicant enhanced their program and  
5 the Aging Management Program to initially inspect  
6 the pull boxes as we stated before on a quarterly  
7 basis. And to consider modifications to prevent  
8 continual unacceptable flooding.

9 MEMBER STETKAR: In your inspection  
10 report I thought it mentioned that you thought, or at  
11 least there was some indication that it was actually  
12 rain water initiated because the covers on the pull  
13 boxes weren't water tight.

14 MR. LAKE: And they aren't.

15 MEMBER STETKAR: But you didn't say it  
16 was groundwater related. There are different  
17 implications there.

18 MR. LAKE: There are, and their pull  
19 boxes, the covers to those pull boxes are not  
20 sealed, they are not water tight. However, I think  
21 the way they are designed, the amount of rain water  
22 that can get in will be minimal.

23 But it doesn't totally exclude it. And  
24 I think that was the intent of making that statement  
25 in the inspection report.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER RAY: Well wait a minute. If it  
2 is groundwater what's the relevance of how often  
3 they pump it out. Let's suppose you pump it out  
4 once a month and it fills it back up the next day  
5 until whatever the groundwater level is.

6                   What's -- there's nothing to answer the  
7 question how long the cables are sitting in water  
8 here. Just because you pump it out once a month,  
9 once a year, once every two years, once -- what  
10 difference does it make?

11                  MEMBER BROWN: It seems to me in fact  
12 that the cables should be qualified for immersion  
13 because it is frequently found immersed in water.

14                  MEMBER RAY: Yes, it may be immersed six  
15 hours after you pump it out. What --

16                  MEMBER BONACA: And furthermore, I mean  
17 even if we recognize this as a part of a license  
18 renewal program the question I have is will you do  
19 something about it now in this current 20 years of  
20 operation. I mean that's the best practice I would  
21 expect, you know if the program is unacceptable as  
22 is, when you go to license renewal you've found that  
23 it probably is unacceptable now.

24                  MR. LAKE: We asked that question during  
25 our inspection and they have -- yes Chalmer?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MYER: I need to interject because  
2 Cary in using the term -- this is Chalmer Myer and  
3 Cary Martin had used in the term groundwater was  
4 really referring to water that goes into the ground  
5 from rain.

6 The groundwater level at Vogtle is not  
7 that high. So this is not normal groundwater that  
8 we're not going to have the pull box refilling  
9 everyday from groundwater. But his terminology was  
10 getting to the top when you have a heavy rain just  
11 the ground itself is soaked, it's going to come into  
12 the pull box.

13 MEMBER BROWN: Did you inspect it  
14 everyday for months to make sure that's the  
15 circumstance, you just saying the groundwater is not  
16 -- you know it's below the bottom of the pull boxes

17 MR. MYER: We do know the groundwater --  
18 I don't have the water level at the site. But we do  
19 know it's well below that level, yes.

20 MEMBER BONACA: We have been told in  
21 previous meetings on the same issue that the concern  
22 here is the wetting and drying. Okay, and the  
23 frequency of wetting and drying which means your  
24 challenge is the cable because of this condition.

25 Okay, not necessarily purely water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 immersion. And here you have the condition where  
2 you are likely to have the sequence of the wetting  
3 and drying the cable.

4 MR. LAKE: Perhaps my presentation might  
5 lead you to believe that they always find these  
6 cables emerged. What we intended to present was  
7 that the pull boxes have water in them, not  
8 necessarily submerging the cables every time it's  
9 inspected.

10 However, it was -- one of the pull  
11 boxes, the one that they put up in the picture when  
12 we did the inspections, the cables were submerged.

13 As far as we could tell that was the  
14 only time in looking at previous results of their  
15 inspections that the cables actually were submerged.

16 But, as part of that corrective action  
17 what they are doing is more frequently looking at  
18 the pull boxes for evidence of water. The cables  
19 that were in the pull boxes where they weren't  
20 submerged looked, from a visual inspection because  
21 we were able to look at them, as being in good  
22 condition. It didn't seem like they were constantly  
23 being wetted and dried and wetted and dried.

24 However, the fact that there was some  
25 water in the pull boxes did require them to take

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 some action.

2 CHAIRMAN SIEBER: Well with the number  
3 of times that this has come up, now I think we're  
4 dealing with a generic issue as much as we are a  
5 Vogtle issue. I also think we're dealing with a  
6 current operation issue as much if not more so than  
7 license renewal.

8 I think the staff is working on this,  
9 but my concern is, most of what I keep hearing  
10 relative to inspections and things don't really  
11 address how often in the wetting and drying of the  
12 cable and stuff. If we look once a month we really  
13 don't know what happened in the meantime there.

14 I think part of the staffs pursuit in a  
15 -- first of all we need to determine what is the  
16 safety significance of this. And then the other is  
17 what programs are really needed in the collective  
18 and then taking care of it because I haven't heard  
19 anything that convinces me from any of the Plants  
20 that the inspection period -- you know how do we get  
21 to that and assure ourselves that that inspection  
22 period is adequate. I haven't heard anything yet,  
23 so I'll -- I do have as much of a generic issue as  
24 anything.

25 MR. HOLIAN: It is, this is Brian Holian

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 again in license renewal. I'm aware of a couple of  
2 items. This has come up at previous meetings here.  
3 George Wilson, the branch chief for electrical is  
4 not here. But Sheila Raz is back, but two things, I  
5 know that we're working a draft generic letter on  
6 this. I know they've got NEI's attention. So we  
7 are looking at it as a part 50 issue. Go ahead.

8 MR. MATHEW: Okay, we are going to issue  
9 generic letter, response summary report. That will  
10 be issued within a week or so. That will capture  
11 some of the recommendations the staff has.

12 Based on the research we found there are  
13 286 failures and these failures have been increased,  
14 the 20th going up. So, the staff is planning to  
15 issue a regulatory guide that stipulates the  
16 attributes for a condition monitoring program for  
17 cables.

18 So, this will address -- right now there  
19 are no guidance in the industry to provide what  
20 consists of a good cable monitoring program. So  
21 that's one recommendation that we have.

22 The second recommendation that we have,  
23 we are planning to revise the technical oversight  
24 process procedures to provide additional guidance to  
25 the inspectors with respect to inspecting their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 manholes, how they deal with -- if they found water  
2 in the manholes and the cable qualifications.

3 The third thing we are trying to do is  
4 we are going to advise the region staff to continue  
5 issuing enforcement, part of the part 50  
6 regulations. Interesting regulations occurs,  
7 licensees to maintain their qualifications to  
8 cables.

9 So, there are regulations that are  
10 occurred to be followed under the current licensing  
11 term. So these are some of the recommendations and  
12 you will be seeing the report most likely within a  
13 week.

14 MEMBER RYAN: One of the things that I  
15 think is important is to maybe think of this from a  
16 geo-sciences perspective as well as the engineering  
17 perspective.

18 We've used a lot of terms like  
19 groundwater rain water, infiltration, saturated  
20 zone, aquifer and all of that. And all of those are  
21 in different places in Vogtle I'm sure.

22 So, I think it's important for the staff  
23 to work with the licensees that have these issues  
24 and really come to a dictionary that you can all  
25 agree on as this is what we are describing when we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 say x, whatever x might be like groundwater.

2 I know a little bit about the  
3 groundwater in that part of the country from being  
4 in South Carolina at Ten Nuclear for about almost 15  
5 years.

6 A one inch rain, a five inch rain, and a  
7 ten inch rain, and a 17 inch rain which I monitored  
8 once all have different impacts on these kind of  
9 near surface systems and containments.

10 So, a single rain event doesn't trigger  
11 it. A half inch rain event may not be important.  
12 But a three inch rain event may be important, or a  
13 cumulative rain event over a month of some number  
14 versus some other number. Those kind of things I  
15 think you need to think carefully about because just  
16 going out and saying monthly and doing an inspection  
17 may be meaningless to really understanding trends,  
18 because the trend is not based on the calendar. The  
19 trend is based on water falling out of the sky.

20 So, I think, I just offer you that  
21 insight that some of the geo-sciences folks that may  
22 be in the other branches or, you know you can call  
23 on, I would say particularly the low-level waste  
24 branch there with a few folks that might be helpful  
25 to give this problem a little shape so that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 licensees can say, oh if we do these types of things  
2 we can really, you know understand what's physically  
3 happening in the system.

4 And I guess I leave you with that  
5 thought. What you really want to find here is  
6 what's the system you're trying to understand the  
7 behavior of. And it's a little bit more complicated  
8 than just a monthly inspections of is there water in  
9 the sump or not.

10 MR. MATHEW: Actually what we had  
11 planned to do is the engineering staff is working  
12 with the research staff to come up with the  
13 regulatory guidance. We expect to issue this by  
14 the end of the next year, that's the plan.

15 We have obtained the necessary feedback  
16 on the guidance we're going to issue. Again, the  
17 concern the staff has if a cable is submerged and if  
18 the cable is not qualified for that environment the  
19 cable can deteriorate with an inadequate monitoring  
20 program you cannot tell how the cable is going to  
21 perform.

22 MEMBER RYAN: And again, that's kind of  
23 the engineering side of if it's wet is that a safety  
24 significant issue and how much and what were the  
25 issues there. I'm kind of accepting that part of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 something that's of interest to the staff.

2 And then how do you get measurables or  
3 indicators that really tell you we've got a huge  
4 problem, a little problem or a episodic issue that  
5 we can deal with in some simple way. That's really  
6 when you get to define how the system is behaving  
7 and it's not just the matter of annual rain fall.  
8 It's even driven.

9 Whether or not a basin fills up is based  
10 on has it been dry for six months and now we have  
11 three inches of rain or we had three inches of rain  
12 every month for the last six months. That's a big  
13 difference in how these sumps are going to respond  
14 in terms of filling or not filling.

15 So, I just offer that insight to maybe  
16 give you some things to think about as you begin to  
17 study the problem and come up with measurable that  
18 will be meaningful to the staff and understandable  
19 for the licensee.

20 MEMBER RAY: The pull boxes isn't  
21 necessarily the only point that water can accumulate  
22 the conduits between the pull boxes fill up with  
23 water and you never see it in the pull boxes.

24 In the case of Vogtle do we know if  
25 these are normal energized --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Yes, they are because  
2 the screening criteria requires them to only look --  
3 in scope has to be energized greater than 25 percent  
4 of the time.

5 MR. MATHEW: But, actually for license  
6 renewal purpose the scope of cables are really  
7 limited. In case of Vogtle not only two cables in  
8 the scope of license renewal.

9 MEMBER RAY: And I understood that part,  
10 but I just wondered if these are normally energized?

11 MR. MATHEW: Yes, these are normally  
12 energized because these are the power supply to all  
13 the control circuits, or you know the model upright  
14 disconnectors and 480 volt control panels in the  
15 search yard. So they are all energized all the  
16 time.

17 MEMBER RAY: So, it's better in that  
18 they normally energized than that they are not  
19 energized obviously?

20 MR. MATHEW: Right.

21 CHAIRMAN SIEBER: I'm confident this  
22 will be resolved by 2027 when they --

23 MR. HOLIAN: Well you're a confident guy  
24 are you.

25 MEMBER STETKAR: For my own information,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I haven't seen the -- I haven't read the generic  
2 letter I listed here. When you asked the licensees  
3 for their experience you mentioned 200 some odd  
4 number of cable failures.

5 What was the scope of information that  
6 you were asking for. Was it safety related cables,  
7 was it cables that are normally energy, you know --

8 MR. MATHEW: We asked the licensees to  
9 provide information of the power cables where all  
10 tech categories, you know, AC, DC, all outages.  
11 Within the scope of maintenance rule. That was the  
12 criteria that we used.

13 So, if a cable is occurred to me a  
14 safety function or some function part of the  
15 maintenance rule then they have to look at those  
16 cables. So, it went beyond the safety letters.

17 MEMBER STETKAR: Okay, thanks.

18 MEMBER BROWN: This is they are  
19 separated by being underground and buried or over  
20 head --

21 MR. MATHEW: No, these are all  
22 underground, all buried, right.

23 MR. LAKE: The next item that I wanted  
24 to discuss was what was again was discussed by the  
25 licensee previously and that is conditions in site

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       containment.

2                   I can start out with the boric acid  
3       program. In doing so I'd like to pass these two  
4       photos around. There's a photo and a angle globe  
5       valve showing what that white residue looks like on  
6       a component. And the second photo really is a gate  
7       valve where you do you have boric acid leaking,  
8       however minor you have it leaking from the packing  
9       and that's to represent how you could easily  
10      mistaken boric acid in this residue.

11                  Now during the past unit 1 refueling  
12      outage which occurred before our inspection NRC  
13      walked down the containment, identified a white  
14      crystalline coating in significant portions of the  
15      containment.

16                  This condition was also identified on  
17      unit 2 during a recent NRC inspection, but that was  
18      conducted subsequent to our license renewal  
19      inspection.

20                  The coating was found on an emergency  
21      core cooling accumulators. The coating was also on  
22      the containment decking, on valves, piping supports,  
23      bolting, electrical boxes. It was on pretty much  
24      anything you could see in the containment and these  
25      photos are to represent the conditions that we saw

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is typical in both containments.

2 The white residue is similar to boric  
3 acid residue in that it diminishes the ability to  
4 detect boric acid leaking as previously described  
5 and discussed at some length by the licensee.

6 But, also what we'd like to discuss is  
7 we identified general corrosion caused by large  
8 amounts of condensation from chiller leaks. Chill  
9 water piping as discussed previously during outages  
10 sweat quiet a lot and do cause a lot of corrosion in  
11 containment. And the corrosion can be seen on  
12 structural steel, grading, on valves, bare piping,  
13 piping supports, bolting, electrical cable, junks  
14 and boxes as represented by the photos that I'm  
15 passing around.

16 Now, as a result of the white residue  
17 and it's interference with our boric acid  
18 inspections there was a, what's termed a green non-  
19 sited violation for inadequate procedures in the  
20 boric acid program. That was issued and it was  
21 incorporated into our inspection report for that  
22 outage.

23 Now, this type of violation is very low  
24 safety significance and mainly we determine that  
25 because they do do chemical sampling on the white

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 residue to determine it's not boric acid and we  
2 haven't identified any real corrosion as a result of  
3 the white residue.

4 Also, they have long term improvement  
5 plan as mentioned previously. They have assigned a  
6 manager to a project. They are creating the  
7 repetitive task to identify corrosion issues in the  
8 containment. They are issuing the communications to  
9 the Plant on the issue.

10 They gradually are performing corrective  
11 maintenance on the areas of the corrosion as  
12 presented earlier. And they are going to determine  
13 techniques to remove the film if they can.

14 I know that they are looking into that.  
15 They don't want to go ahead and just abrasively  
16 remove this film because you could do more damage  
17 trying to remove the film than not. And I -- we  
18 determine that trying to remove the film does  
19 require a lot of evaluation to determine the right  
20 way to do it.

21 And they are also developing designs to  
22 insulate the piping that's causing all the  
23 condensation during outages and prevent sweating of  
24 that piping.

25 CHAIRMAN SIEBER: The coating that was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 found, I think according to the applicant was due to  
2 an additive that they are adding to the cooling  
3 water?

4 MR. LAKE: That's correct, the chiller  
5 system has a chemical additive and apparently when  
6 that does leak and evaporates it leaves this white  
7 crystalline coating.

8 CHAIRMAN SIEBER: I should perhaps --

9 MR. LAKE: That's not easily removed  
10 unfortunately.

11 CHAIRMAN SIEBER: Yes, I should have  
12 probably asked the applicant this question. But is  
13 there some other chemical additive you can use to  
14 accomplish the same purpose that doesn't leave the  
15 film?

16 MR. LAKE: I've seen other chemicals  
17 used at other Plants, but I think we'll ask if the  
18 applicant has considered other chemicals.

19 MR. MYER: I think first of all this  
20 treatment is highly successful in doing what it's  
21 supposed to do and the residue in the containment as  
22 Louis pointed out --

23 CHAIRMAN SIEBER: Do two things  
24 successfully.

25 MR. MYER: But it also is -- it has not,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it doesn't have a corrosive effect in the  
2 containment. It does have the problem of appearing  
3 to be boric acid which actually based on our  
4 corrective action just makes more work for us to  
5 address it as if it is boric acid instead of  
6 treating it as if it's not.

7 But, I don't know that we're prepared  
8 right now to make a commitment to look at other  
9 chemicals because this primary function is a system,  
10 as an inhibitor is there are a lot of chemicals you  
11 might use that may not be as effective as that.

12 CHAIRMAN SIEBER: Yes, on the other hand  
13 if it's causing you the problem you may want to just  
14 think about that and maybe do something about it.

15 MEMBER MAYNARD: Is the corrosion that  
16 we're seeing being caused by this or just because  
17 water is getting --

18 MR. MYER: The pictures you've got with  
19 corrosion in other areas is primarily the  
20 condensation because there is a tremendous amount of  
21 condensation --

22 MEMBER MAYNARD: Well changing chemical  
23 wouldn't really change that.

24 MR. MYER: That's correct.

25 CHAIRMAN SIEBER: Well, that brings up

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the other question. In your inspection report on  
2 paragraph eight you talk about coatings, you know  
3 like protective coatings like paint and so forth.

4 What is the current condition of  
5 protective coatings in containment and then outside  
6 of containment. I mean are they postured where  
7 chemical attack can have raw metal to work on?

8 MR. LAKE: I -- going by the inspection  
9 report of a inspectors that --

10 CHAIRMAN SIEBER: It doesn't really say.

11 MR. LAKE: Yes, going by the inspection  
12 report of inspectors that did the walk down during  
13 the refueling outages the corrosion that you're  
14 seeing in those pictures are representative of what  
15 they saw.

16 They did not see a lot of peeling, they  
17 did not see a lot of coating, degradation aside from  
18 the corrosion you're looking at.

19 CHAIRMAN SIEBER: Okay.

20 MR. BARTON: The question is one picture  
21 nuke services close cooling water valve. It looks  
22 like the packing gland is completely corroded and  
23 won't move.

24 MR. LAKE: I'm sorry?

25 MR. BARTON: Am I looking at a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 completely corroded packing gland and packing nuts  
2 that looks like it was corroded and were never  
3 moved. What am I looking at here?

4 CHAIRMAN SIEBER: That's not boric acid.  
5 The other one is boric acid.

6 MR. BARTON: No, I know but I'm looking  
7 at the condition of the pack plant because the  
8 material condition -- I don't get you. That to me  
9 looks like it's a completely corroded packing liner.

10 And the other valve has got a chain on  
11 running through the yoke of the valve. What's the  
12 chain there for. Is that normal Plant practice to  
13 run a chain through the yoke of the valve, or I  
14 don't get it. I have problems with both of those  
15 pictures.

16 MR. LAKE: I don't have an answer as to  
17 what the common practice is for that chain going  
18 through the yoke.

19 MR. BARTON: But what about the packing  
20 liner. That's a material condition issue in my  
21 mind.

22 MR. LAKE: I don't specifically know --

23 MR. BARTON: I don't even see the  
24 threads on the -- am I looking at the threads to  
25 adjust the packing liner, but there's no threads

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 left. What am I looking at. I'm just wondering how  
2 good you painted material condition of the Plant and  
3 then you hand out pictures like this for us to look  
4 at which are terrible.

5 MR. LAKE: Well, again, that particular  
6 valve is being corroded as a result of the  
7 condensation --

8 MR. BARTON: I don't care what's causing  
9 it. I'm just looking at material conditions of the  
10 valve. But can I adjust the backing on this valve  
11 and I would say hell no. But yet you don't make  
12 issues of -- I don't know.

13 I just don't know what you're coming  
14 from material condition I think that's not a good  
15 material condition issue. I don't know how many  
16 more there are in the Plant like that that you guys  
17 found or didn't find. So I don't really know what  
18 to think about your inspection report now.

19 CHAIRMAN SIEBER: I guess that in every  
20 Plant that I have been a number of them and I don't  
21 recall seeing in these Plants that I've been in this  
22 coating from the additive.

23 MR. LAKE: That was the first time I  
24 came across it as well.

25 MEMBER STETKAR: Just out of curiosity,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 and I'll ask the licensee, I've heard several things  
2 here with additives and some people talk about  
3 chilled water systems with condensation on the  
4 chilled water piping and additives to chilled water  
5 systems. Other people have talked about leaks on  
6 nuclear service cooling water connections to large  
7 numbers of coolers in the containment with  
8 condensations on piping.

9 What system, is it chilled water or is  
10 it nuclear service cooling water has the additive  
11 and where is the additive coming from. Is it the  
12 chilled water system or is it the nuclear service  
13 cooling water system.

14 MR. MYNAN: This is Tom Mynan, what we  
15 do during normal Plant operations we supply  
16 containment with nuclear service cooling water where  
17 we shut down for refueling outage we have one aux  
18 cooler that normally gets nuclear service cooling  
19 water that we isolate and we flange in this spool  
20 pieces chilled water to that cooler and during  
21 outage operation that cooler gets chilled water.

22 And there is a flushing procedure and  
23 other things that we go through so as to not to mix  
24 the different chemicals between the two close loop  
25 systems. NCOW uses trollytriazole and the chill

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 water uses the nitrite treatment. Does that answer  
2 your question?

3 MEMBER STETKAR: I think so.

4 MR. MYNAN: It's the same pipe but it  
5 serves two purposes online and offline.

6 MR. HOLIAN: This is Brian Holian again,  
7 maybe we could get the committee some more  
8 information on you know vice one inspection report,  
9 that kind of accumulation. You'll be getting a few  
10 slides here in a minute about plan indicators. I  
11 just looked ahead you see a lot of green indicators  
12 on this Plant.

13 So there are other inspection reports I  
14 think that would tend towards looking for some of  
15 the aspects of performance that might show up if you  
16 had inoperable valves or maybe a performance  
17 indicator that might turn white. It doesn't look  
18 like it's at that, but we could probably get the  
19 committee some more information on an assessment of  
20 reports including, you know maintenance inspection  
21 reports.

22 CHAIRMAN SIEBER: Well, I guess I can  
23 conclude something from all of this. From what  
24 we've seen and what we've read it looks like there's  
25 a problem that exists including the attitude that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 used.

2 And it has an effect on the material  
3 condition of the Plant. The Plant is only 20 years  
4 old. We're asking -- or the applicant is asking for  
5 permission to run the Plant for twice as long as  
6 it's already run and so if you don't have a good  
7 corrective action and stop this, you know there's --  
8 some place along the line there's going to be  
9 serious problems.

10 And I think if the Aging Management  
11 Program in order to correct this condition to me  
12 does not seem aggressive enough to solve the  
13 problem. And I think that that should result in  
14 additional attention by the staff.

15 MR. LAKE: The staff -- I'm sorry, sorry  
16 to interrupt. No, the Region II staff is monitoring  
17 all the follow-up that their conducting for this  
18 project that they started. We know that there is  
19 some short-term things that they are doing such as  
20 attacking the various areas in containment to  
21 improve the material condition.

22 But even in doing long term fixes as  
23 well as trying to insulate the lines that are  
24 causing all the condensation and containments. And  
25 we do monitor that. We monitor that by the resident

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inspectors and we also monitor that every time we go  
2 out during refueling outages to do walk downs up at  
3 containment and other areas of the Plant.

4 So, we are monitoring and following  
5 their progress along these corrective actions.

6 CHAIRMAN SIEBER: Well, the hopeful  
7 thing would be that there is progress. But right  
8 now it seems like the corrective actions are not  
9 adequate to reverse the direction or the trend that  
10 we apparently see.

11 And like I say the Plant is 20 years  
12 old. The average between the two plants and their  
13 asking to run it an additional 40 years and a lot  
14 can happen in that amount of time. And if we say  
15 what their doing now is adequate and it continues in  
16 the vein that it's progressing at this moment then I  
17 think that there's a problem someplace ahead due to  
18 corrosion.

19 MR. BARTON: Also, I'm sure inspectors  
20 go into containment each time there's a refueling  
21 outage and do an inspection in containment or  
22 walkthrough, right?

23 MR. LAKE: They do.

24 MR. BARTON: All right, now this stuff  
25 that you found and made a big deal of in this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inspection report somewhere I read that this has  
2 been since the Plant started operating.

3 Now, why wasn't this a big deal before  
4 your inspection report because I think some damage  
5 has been done to Plant equipment in there as a  
6 result of this and this has been a long standing  
7 issue at this site.

8 Your inspection report even says that  
9 inspectors noted or something that this has been  
10 like this since the initial operation.

11 MR. LAKE: And as I stated before we do  
12 interview personnel during these inspections and in  
13 interviewing those personnel they indicated that  
14 there has been a long standing condition that they  
15 have gotten used to seeing. And I think Mike had  
16 also presented that.

17 MR. BARTON: Well, that hasn't done a  
18 job either because they should have notified -- I  
19 mean they should have made an issue of this thing  
20 long before it got this bad.

21 So, I just question what's really going  
22 on there, how adequate is the inspection program  
23 going and you know if there are issues like this in  
24 the plant. I mean this is a material -- I think is  
25 a serious material condition issue. So, I question

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the adequacy of the inspection program and why you  
2 guys were even looking out when you've been  
3 containment each refueling outage.

4 CHAIRMAN SIEBER: Any other comments on  
5 Plant area review one?

6 MR. HOLIAN: This is Brian Holian, you  
7 know we will take that comment and work with the  
8 region, but also with the division for monitoring  
9 the rack oversight process. And you know look at  
10 whether I know on an annual basis they'll re-  
11 baseline.

12 And I don't know if ACRS gets briefed on  
13 that for are we spending inspection resources in  
14 areas that aren't having benefits. And we can  
15 report back to the committee on whether they have  
16 looked at general corrosion aspects and are we doing  
17 enough on regular routine inspections.

18 MR. LAKE: The next share is a slides  
19 where we represent the current performance in ERO  
20 space and as it's presented in our performance  
21 grading. And as you can see all of the areas for  
22 the cornerstones of the ROP are all in green which  
23 indicate that the licensee is performing in  
24 accordance with the requirements.

25 And that they in their performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 matrix they would stay in what's known as the  
2 licensee's action column as opposed to additional  
3 columns. If performance is unacceptable they would  
4 go into various columns where they would get greater  
5 attention by the NRC.

6 I don't know if you want me to go  
7 through the details of the current performance  
8 indicators. But, the fact that they are all green  
9 right now and they are performing -- well the grey  
10 ones mean that that's no --

11 MR. BARTON: There's no findings except  
12 there's two green findings. That's what they are  
13 telling you.

14 MR. LAKE: But they're still -- I didn't  
15 realize that when it was put up there.

16 MR. PELTON: This is Dave Pelton, the  
17 brace chief under license renewal. Under the  
18 reactive oversight program which you are probably  
19 all well aware the performance indicators that are  
20 green by definition meet the NRC's requirements.

21 However, findings that are green  
22 indicate that they do not meet NRC expectations and  
23 so let's just keep that in mind as you --

24 CHAIRMAN SIEBER: Green means there is a  
25 finding. Grey means there isn't one?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PELTON: That's correct.

2 CHAIRMAN SIEBER: Okay, and so you've  
3 got two findings both of which were low safety --

4 MR. LAKE: Very low safety, that's  
5 correct.

6 CHAIRMAN SIEBER: One in barrier  
7 integrity and the other one in mitigating systems?

8 MEMBER BROWN: And what's the nature of  
9 the finding?

10 MR. LAKE: I'm sorry?

11 MEMBER BROWN: What is the nature of the  
12 findings?

13 MR. LAKE: The findings that were green  
14 consisted of one violation of 10 CFR 50 Appendix B  
15 criteria. And 11 for failure to establish adequate  
16 test control measures for text spec surveillance.

17 There was another one in the capability  
18 of the aux sea water system to meet the design and  
19 licensing requirements. That was also a green  
20 finding.

21 There was a NCV, a non-site evaluation  
22 for, as we stated the boric acid -- identification  
23 of the boric acid. On unit 2 -- that was on unit  
24 one. On unit 2 there was one NCV, non-site  
25 evaluation for failure of adequate control,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 transient combustibles.

2 There was another NCV for violation  
3 again of Appendix B criteria 10 for failure to  
4 establish adequate testing control measures similar  
5 to the one that they found on unit 1 was common.

6 Capability of aux water system to meet  
7 design. Again, that was also identified on unit 2.  
8 There was a safety shut down practice not consistent  
9 with the analysis that was identified as a NCV, non-  
10 site evaluation.

11 Then there was one more non-site  
12 evaluation that had to do with emergency lights not  
13 installed as required in a fire protection program.  
14 Any other questions?

15 (No response.)

16 CHAIRMAN SIEBER: Thank you, thank you  
17 very much. Appreciate it.

18 MR. ASHLEY: Section three of the SER,  
19 Section 3.01 talks about the format of the  
20 application and then the staff review process in  
21 Section 3.0.2.

22 Section 3.0.3 has to do with Aging  
23 Management Programs. Mr. Myer talked about the  
24 numbers of programs that they had that were Plant  
25 specific as well as the new programs in those that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are associated with -- that are consistent with  
2 GALL.

3 MEMBER BONACA: Going back to the slide  
4 from before. You told us that there was going to be  
5 seven percent consistency with GALL.

6 MR. ASHLEY: That's when you look at the  
7 individual line items. These are the programs that  
8 contain the line items.

9 MEMBER BONACA: Okay.

10 MR. ASHLEY: So we didn't look at it  
11 consistent from a program aspect. We drilled down  
12 to look at the line items.

13 MEMBER BONACA: So if you have a program  
14 which has exceptional enhancements do you consider  
15 it consistent with GALL. I'm trying to understand  
16 how to relate these numbers to those line items.

17 MR. ASHLEY: It's difficult.

18 MEMBER BONACA: Yes, right.

19 MR. ASHLEY: It's difficult to relate  
20 them to the line items themselves. You have to go  
21 in and look at each individual line item to get that  
22 consistency percentage.

23 MEMBER BONACA: Okay.

24 MR. ASHLEY: This is strictly from the  
25 program aspect. The next few slides that I'll show

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you has to do with our listing of the systems that  
2 were reviewed.

3 In all cases the reviewers, when they  
4 went through all of these systems looked at the  
5 cumulative fatigue damage, loss of materials,  
6 reduction in heat transfer, stress corrosion  
7 cracking, and quality assurance for AG management.

8 And Section 3.1 covered the reactor  
9 vessel and reactor coolant system. 3.2 covered the  
10 engineering safety feature systems. 3.3 was aging  
11 management auxiliary systems. And part of the  
12 additional information that you were given was  
13 specifically on 3.3.2.2 which consisted of AMR  
14 results that were consistent with GALL for which  
15 further evaluation is recommended. Those systems  
16 were reviewed and then provided to you in a separate  
17 package.

18 They also looked at cumulative fatigue  
19 damage, reduction of heat transfer due to fouling,  
20 cracking due to SCC, and hardening and loss of  
21 strength due to elastomer degradation. The loss of  
22 materials were also considered for each of the  
23 systems.

24 The steam and power conversion systems  
25 were reviewed as well. And one thing that's a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 little different in this particular system, the  
2 condensate system was reviewed as part of the feed  
3 water system rather than a separate system.

4 Aging management of containment  
5 structures and component supports in Section 3.5 was  
6 reviewed. One of the things of interest has been  
7 the in scope inaccessible concrete. And we wanted  
8 to make sure that we provided you with the specific  
9 information from this section.

10 The substance criteria for pH chlorides  
11 and sulfates were met in all situations and there  
12 was two tests performed in 2005 and 2007. They both  
13 did meet the acceptance criteria.

14 Section 3.6, aging management electrical  
15 and instrumentation and control systems. This also  
16 included the inaccessible medium voltage cables.  
17 And we had -- in the review of this section and the  
18 other section we had several RAIs that they  
19 applicant responded to that were specifically  
20 addressed for elastomers.

21 MR. BARTON: I have a question a second.  
22 In the -- as I review it it looks like there were  
23 four programs listed that managed aging effects,  
24 electrical, and INC system components. I can only  
25 find description and discussion on one of those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 programs, loosening and bolted connections.

2 Now, was I missing another page or  
3 something, because I only saw you discussing one of  
4 the four programs?

5 MR. ASHLEY: We should have covered them  
6 all. And they should be within that section.

7 MR. BARTON: Maybe you want to look  
8 because I saw one. I'm talking about page 3.5.18 in  
9 your SER.

10 MR. ASHLEY: I'll have to go back and  
11 look sir.

12 MR. BARTON: Okay.

13 MR. ASHLEY: I will verify that.

14 MR. BARTON: All right, thank you.

15 MR. ASHLEY: Before I get into Section 4  
16 on the time limited aging analysis I'd like to ask  
17 Dave Pelton if he would address the subcommittee.

18 MR. PELTON: Hi, this is Dave Pelton,  
19 branch chief license renewal. I just wanted to  
20 bring a relatively, well somewhat recent issue to  
21 the attention of the committee.

22 Staff has been taking a look at  
23 operating experience related to the use of Boral and  
24 spent fuel pools. As you may or may not know there  
25 has been a past history not only with boral flex and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 degradation, but also with some blistering or  
2 swelling with boral.

3           What we've done and in specific with  
4 Vogtle is we took a look at, there's been fuel  
5 pools. Unit 1 fuel pool does include boral  
6 material. And their criticality analysis for that  
7 pool takes credit for the boral.

8           Our SER documents the Aging Management  
9 Program for that material and it does it in kind of  
10 a three part method. It looks at the water  
11 chemistry control that's applied. It also looks at  
12 corrective action program for the licensee to  
13 identify any issues and take action. And then it  
14 also requires the licensee to consider operating  
15 experience and take action as appropriate. And also  
16 you may note that commitment 37 also requires  
17 license or reinforces the need to do that.

18           What we're going to -- what the staff is  
19 doing is with all of these recent Palisades issue  
20 with some more blistering. We're going to look at  
21 that, not only generically, but also specific to  
22 Vogtle to make sure that the Aging Management  
23 Program that we currently -- that's currently in the  
24 SER continues to meet staff expectation given some  
25 of the more recent experience.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And then as appropriate or if necessary  
2 we have the request for additional information  
3 process we can use to ask additional questions of  
4 the licensee and make sure that we're satisfied that  
5 the program is adequate.

6                   MR. MEDOFF: Let me just expand on that.  
7 Al Heizer is running division of component  
8 integrity, steam generator integrity and chemical  
9 engineering branch, and they are considering putting  
10 out an ISG on Boral degradation. So, that may come  
11 forth in the near future.

12                   So, that's an additional measure that  
13 we're taking to address operating experience with  
14 Boral.

15                   CHAIRMAN SIEBER: Do you get blistering  
16 mainly from chemistry and I presume when there's  
17 neutron gorging generating heating and gas which  
18 should be at a very low level at a spent fuel  
19 outage.

20                   MR. MEDOFF: Emma, would you like to  
21 address that please. This is Emma Wong of the  
22 division of component integrity.

23                   MS. WONG: Could you repeat the  
24 question. I could barely hear it.

25                   CHAIRMAN SIEBER: Well, the question was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 more of a comment. But, the major cause of  
2 blistering in Boral is water chemistry to my  
3 understanding.

4 But, if there is significant neutron  
5 fields you generate helium and gas that is within  
6 the matrix of the material which can collect them  
7 also cause blistering. I presume that this is all a  
8 water chemistry problem in a spent fuel pool,  
9 because the activity in the spent fuel pool should  
10 be neutron activities and should be pretty low. Is  
11 that correct?

12 MR. MEDOFF: Emily, is he on the money?

13 MS. WONG: Yes, he's correct.

14 MR. MEDOFF: Okay.

15 CHAIRMAN SIEBER: Now, I guess my other  
16 comment is that this is generic to -- this has been  
17 around for a long time. This is generic to Plants  
18 that use Boral.

19 So, my question is is it part of license  
20 renewal or is a generic issue that needs to be dealt  
21 with soon, but outside of license renewal process?

22 MR. PELTON: I think right now we're  
23 trading -- right now we're looking at it -- well  
24 there's a -- I'll let Alan Hiser talk first and then  
25 I'll kind of give you what our assessment was, at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 least recently.

2 MR. HISER: Alan Hiser from the chemical  
3 engineering branch, NRR. We're taking a look at  
4 that now because clearly there's nothing that  
5 changes magically with license renewal.

6 So, we're taking a look at the impacts  
7 on the current licensing periods for Plants as well.  
8 We don't have anything at this point on an  
9 assessment of that.

10 CHAIRMAN SIEBER: Let me ask another  
11 sort of mechanistic question. When you get the  
12 blisters do the blisters break and fall off and you  
13 lose the Boral. Does it lose it's structural  
14 integrity or does it just look bad?

15 MR. MEDOFF: That I can't answer.

16 MR. HISER: That's again something that  
17 we would take a look at. Just understand what the  
18 overall impacts are.

19 CHAIRMAN SIEBER: It's long term.

20 MR. PELTON: That's right, and as with  
21 any, you know kind of, as you said this isn't  
22 necessarily a brand new issue. But how we're  
23 looking at it and how it relates to license renewal  
24 we're just taking another look at it.

25 It's a somewhat emerging over the last

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 couple of weeks working closely with Alan's group.  
2 And we just want to make sure that we get our arms  
3 around it and fully understand it if any impact at  
4 all on Vogtle and then also generically.

5 So, we just wanted to make sure you  
6 folks were aware that it was something we were going  
7 to look at and may or may not come up -- well we'll  
8 probably -- we will readdress it at the full  
9 committee meeting so we can give you what we  
10 concluded.

11 CHAIRMAN SIEBER: Yes, well we need to  
12 decide amongst ourselves whether it's a license  
13 renewal issue or not because it impacts the kind of  
14 report that I write.

15 MR. MEDOFF: We've had a --

16 CHAIRMAN SIEBER: I think I'll wait to  
17 the full committee meeting and spend the entire  
18 night writing the report.

19 MR. MEDOFF: We have had other emerging  
20 issues in the past where they've put it into current  
21 operating space. A good example is when we had the  
22 nickel alloy cracking issues initially break out we  
23 put that in current operating space.

24 But since that time we've had some new  
25 requirements and we were able to use those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 requirements to update the GALL report and the GALL  
2 update.

3 So, when we get emerging issues like  
4 this it may very well be that we put it into current  
5 operating space. And once something gets  
6 established we'll use it to update the GALL report.

7 CHAIRMAN SIEBER: Thank you very much.

8 MR. ASHLEY: Section 4 of the SER  
9 contains the Time Limited Aging Analysis. The TLAA  
10 are Plant specific safety analysis that involved  
11 time limited assumptions defined by the current  
12 operating term.

13 The staff reviewed the information in  
14 the LRIA to determine whether the applicant has  
15 provided sufficient information according to 54.21  
16 C1 and C2.

17 The applicant evaluated it's  
18 calculations and analysis against the six criteria  
19 specified in 54.3. The TLAA criteria involves SSC's  
20 within the scope of license renewal, considers it's  
21 aging effect. It involves time limited assumptions  
22 defined by the current operating term. It's  
23 determined to be relevant by the applicant making it  
24 safety determination.

25 It involves conclusions and provides the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 basis for conclusions related to the capability of  
2 the SSC's to perform the intended functions. And  
3 finally, are contained or incorporated by reference  
4 into the current licensing basis.

5 In the TLAA's that were reviewed, we'll  
6 go over each of these as we go over through this  
7 section. The reactor vessel neutron embrittlement  
8 analysis, Section 4.2 of the SER, there were five  
9 reviews performed to evaluate the consequences of  
10 the neutron embrittlement as documented in the SER.

11 These are neutron fluence, adjusted  
12 reference temperature, pressurized thermal shock,  
13 and pressure temperature limits, and upper shelf  
14 energy.

15 The staff reviewed the license  
16 information and found only a statement that the  
17 fluence calculations adhered to the guidance and the  
18 regulatory guide 1.190.

19 The staff felt that that was not  
20 adequate and to conclude adherence to the reg guide,  
21 or whether the values listed actually accounted for  
22 the previously approved power uprate and the  
23 applicable number of the effective full power years  
24 of the calculated fluence values.

25 To complete the required information for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the review the staff calculated fluence values and  
2 the staff requested one reference to the  
3 calculations, two clarification for the listed  
4 fluence values as to whether they include the power  
5 uprate, and three clarification of the applicable  
6 EFP wise for the listed fluence values.

7 The applicants response provided the  
8 requested information and the staff concludes that  
9 the reactor neutron embrittlement analysis meet the  
10 review criteria in the standard review plan and in  
11 accordance with the rules.

12 The tables that we'll be looking at in  
13 the slides, the next slides are for 56.3 EFPY to  
14 account for the recent power uprate in the  
15 measurement uncertainty recovery.

16 While the w-cap values that are normally  
17 used are calculated for 57, this is acceptable  
18 because the 56.3 EFPY are still conservative with  
19 respect to expected values.

20 This graph represents the upper shelf  
21 energy decrease. The UOL use acceptance criteria is  
22 greater than 50 foot pounds. And if you'll note  
23 that Vogtle unit 1 is at 61 and unit 2 is at 56  
24 which meets the criteria.

25 CHAIRMAN SIEBER: Do I understand this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 chart properly where we're supposed to take column  
2 three number which is 70 and move it one case to  
3 track 12 and then up to 61?

4 MR. MEDOFF: That is 12 percent of the  
5 emission.

6 CHAIRMAN SIEBER: Got you.

7 MR. ASHLEY: Did you hear the 12  
8 percent?

9 CHAIRMAN SIEBER: Yes.

10 MR. ASHLEY: Okay, on reference  
11 temperature calculations again the screening  
12 criteria is less than 270 degrees and unit 1 is at  
13 123.3, unit 2 at 134.2 degrees.

14 The additional TLAs on metal fatigue  
15 analysis and the applicant discussed her cycle  
16 counting. And John Fair, did you have additional  
17 information for metal fatigue other than what's in  
18 the SER?

19 MR. FAIR: No, what's in the SER -- I'm  
20 sorry, no all I have is what's in the SER.

21 MR. ASHLEY: Were there any questions  
22 form that?

23 MR. ASHLEY: Section 4.4 of  
24 environmental qualification of electrical equivalent  
25 4.5 containment pertain to pre-stress and 4.6 the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       containment liner plate, metal containment and  
2       penetration fatigue.

3               Okay, Section 4.7 consists of Plant  
4       specific TLA's. And this shows the listing there.  
5       The Section 4.7.5 on under clad cracking of reactor  
6       pressure vessel. This was amended and added in a  
7       letter of March 20th for the closure head dome  
8       flanges. The primary inlet nozzles, primary outlet  
9       nozzles, and the RPV flanges.

10              These are SA 508 class two forgings  
11       whose internal cladding was welded using a high  
12       temp, excuse me high heat submerged art weld  
13       process.

14              MR. HOLIAN: How is the -- there's sort  
15       of a reference to a WCAP report for the week before  
16       break analysis. What are the assumptions in that  
17       week before break analysis that you use. Is there -  
18       - do you do an inspection or do you have a  
19       postulated crack?

20              MR. MEDOFF: The issue with the leak  
21       before break analysis is on the cast materials. If  
22       you get thermal aging they --

23              MR. HOLIAN: I was thinking with 182.

24              MR. MEDOFF: 182, my understanding I  
25       that the pervious office directors has put that as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 an emerging issue to assess the impact of the SCC on  
2 the -- when the leak before break analysis and  
3 that's being handled by the division of component  
4 integrity. So, I think we're going to have to go  
5 back and find out where they stand on that issue.

6 MR. ASHLEY: Did you have a follow-up,  
7 sir?

8 MR. MEDOFF: The officer director put it  
9 in current operating space so we're going to have to  
10 go back to them on that matter.

11 MR. ASHLEY: On the basis of this review  
12 the staff determines that the requirements of 10 CFR  
13 5429 A have been met.

14 Future commitments have been identified  
15 and a schedule is documented in the SCR such that  
16 there is reasonable assurance that the activities  
17 approved by the license renewal will continue to be  
18 conducted in course with the current licensing basis  
19 and changes associated with license renewal.

20 With that sir, it is my --

21 CHAIRMAN SIEBER: I see the last slide  
22 is the same three license conditions that has a  
23 memory license renewal.

24 MR. ASHLEY: Yes sir, those are the  
25 standard license renewals. That's the backup slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN SIEBER: Thank you.

2 MR. LAKE: If I may, could I maybe  
3 provide some clarifications on the photos showing  
4 that globe valve and the extensive corrosion that's  
5 shown on the bolting and the tacking plan. And also  
6 on the gape value showing the boric acid and  
7 leakage.

8 Now the intent of these photos was to  
9 show that you really have a hard time distinguishing  
10 between boric acid. But more importantly, where I  
11 got these photos from this is a licensee photo. It  
12 was actually identified. I'm looking at the back of  
13 it now. It was actually identified in 2006 as part  
14 of the boric acid program walk down where they  
15 identified these problems and took corrective  
16 action.

17 MR. BARTON: So the two year old picture  
18 has been corrected or is it still there after two  
19 years?

20 MR. LAKE: Well based -- I'm not going  
21 to positively say it has been corrected except to  
22 say what that program would require. And their  
23 program these pictures require just to be put into  
24 their boric acid corrective action program and you  
25 correct these prior to them going back up in power.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

So, this is from back, you know years ago. It doesn't necessarily represent what's out in the containment today on these two pictures.

Now the other pictures don't have any -- what's that?

CHAIRMAN SIEBER: It could be worse.

MR. LAKE: Oh.

CHAIRMAN SIEBER: Any other additional comments or statements from the staff?

MEMBER MAYNARD: I'm not sure -- I appreciate you bringing the pictures and showing them and I would hate to leave the impression we have where people won't bring us something. It would be nice if some of these could be put in better perspective.

MR. LAKE: That's true.

MEMBER MAYNARD: But I do appreciate you bringing the pictures and showing them to us. And I think that it's more than one inspection that ends up forming an overall basis of material condition and other things.

So I'll just pass that out. It would be nice to -- when bad pictures shown and can be put into perspective as to whether that's typical or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 whether that's an out liar or whatever it is.

2 MR. HOLIAN: We agree.

3 MEMBER BONACA: The question I have is  
4 are we aware of similar conditions in other Plants?

5 MR. LAKE: I have not read any  
6 inspection reports that identify similar conditions  
7 nor have I observed similar conditions.

8 MR. BARTON: Have you seen inspection  
9 reports that identified the condition you found  
10 during this outage which has been here since day one  
11 or since the Plant started operating?

12 MR. LAKE: The inspection reports that I  
13 have read, I've been with the NRC about three and a  
14 half years go back maybe two or three years ago.  
15 That's what I prepared in preparation for this  
16 license renewal inspection I went and read through  
17 these inspection reports.

18 MEMBER BONACA: I mean it was best to go  
19 back to get your position. It means some emphasis  
20 since then.

21 MR. PELTON: This is Dave Pelton again,  
22 you know Brian and I were just talking and you know  
23 he and I spent a lot of time up in Region I and have  
24 visited all of those sites and probably most of the  
25 sites around the country and I would not -- I don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 think we characterize that as a typical condition.

2 We certainly appreciate the view that  
3 you know our inspection conclusions are based on a,  
4 you know a mosaic of opportunities to review and  
5 inspect identify issues. And we also appreciate the  
6 need to -- you know if we're going to bring pictures  
7 in to make sure it tells a good story and that it  
8 captures, you know what message are we trying to  
9 send.

10 And you know what we're going to do, you  
11 know we'll make sure that we'll bring to you when we  
12 go over the final SER is just put everything in the  
13 perspective that it was intended to be and make sure  
14 that we tell the right story because we certainly  
15 don't want to leave you the impression that, you  
16 know that we're walking away from material condition  
17 issues that don't meet expectations or NRC  
18 requirements.

19 But we can certainly put it in the right  
20 perspective for you and will do that.

21 MR. BARTON: This raises the question  
22 about the IPC inspection program and also material  
23 condition in the Plant and what the corrective  
24 action programs are. I mean you saw something like  
25 this and it just opens up.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PELTON: And we appreciate that and  
2 we'll make sure we'll cover that for you.

3 CHAIRMAN SIEBER: Any additional  
4 questions from the members?

5 (No response.)

6 CHAIRMAN SIEBER: Well if not I'd like  
7 to ask each member a few questions and this will be  
8 complicated because it's a complicated way of doing  
9 business and the LROA review and approval process.

10 The first question I'd like the members  
11 to consider is do we need an interim order and just  
12 for information an interim order would tell the  
13 applicant or the staff or both if the ACRS  
14 subcommittee has identified one or more significant  
15 items not evaluated properly or corrective actions  
16 not identified or insufficient.

17 I think another reason for an interim  
18 letter would be deviation of the applicant or the  
19 staff from the requirements of 5054. And I think we  
20 write an interim letter this coming meeting that we  
21 would need an additional subcommittee meeting to  
22 determine that the issues that we raised in the  
23 interim letter if any are resolved.

24 Now, the answer to that probably one is  
25 no, we don't need an interim letter. Then we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to ask ourselves a second question and I would like  
2 each of you to address this. Do we have enough  
3 review material, and since some of it's late and  
4 came in pieces we may not have been able to assemble  
5 it all in our minds to make a final subcommittee  
6 finding and do -- if the answer to that is no, do we  
7 need another subcommittee meeting in order to be  
8 able to make such a finding and provide me with the  
9 advice that I would need in order to write a letter  
10 report appropriate for the full committee.

11 Now, the answer to one and two are both  
12 nay, no then I would like you to give me your  
13 comments as to the adequacy of the process in the  
14 case of Plant Vogtle and any issues that you believe  
15 should be included in the letter that the  
16 subcommittee would write and endorse and give it to  
17 the full committee for it's review and approval.

18 So, there's three things that I'm  
19 asking. Okay, do we need an interim letter, do we  
20 need additional time to review the material that  
21 we've gotten already since it came late and came in  
22 pieces, and lastly if you're satisfied with the  
23 material that you got the presentations today are  
24 there significant items that should be in our letter  
25 other than, you know we've reviewed all of this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 material and it's okay.

2 MEMBER MAYNARD: First of all we can't  
3 write a letter unless we have a portion of it set in  
4 the agenda for the full committee meeting.

5 CHAIRMAN SIEBER: Well, yes --

6 MEMBER MAYNARD: So it couldn't be this  
7 one.

8 CHAIRMAN SIEBER: But it's not going to  
9 be this meeting. It is going to be some meeting,  
10 okay when it comes up on the schedule. It will  
11 probably come up in March.

12 MEMBER MAYNARD: Jack, I'm just a little  
13 confused on your second item there and you stated it  
14 different. One you asked if we had enough material  
15 to draw a conclusion. The subcommittee does not  
16 have to draw a final conclusion. We will have a  
17 meeting at the full committee where we will discuss  
18 items that haven't been fully resolved or issues and  
19 stuff.

20 CHAIRMAN SIEBER: Well, I think that we  
21 can go to the full committee with that. But in  
22 order for me to properly present the review of this  
23 material you need to identify the items to which we  
24 don't agree.

25 MEMBER MAYNARD: And I'm --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: Or, with which we  
2 disagree among ourselves.

3 MEMBER BONACA: You would want more  
4 material only in case the answer to the first  
5 question was yes, right?

6 CHAIRMAN SIEBER: I don't expect  
7 additional material. But what we got was in pieces  
8 and not timely. And so the question is, have you  
9 had an opportunity to -- prior to this meeting and  
10 the information that you gathered during this  
11 meeting to be able to draw a conclusion.

12 And the answer is not what is your  
13 conclusion, but yes or no. George?

14 MR. APOSTOLAKIS: I'll pass.

15 CHAIRMAN SIEBER: Okay, --

16 MEMBER STETKAR: I don't think we need  
17 an interim letter.

18 CHAIRMAN SIEBER: Okay.

19 MEMBER STETKAR: If I could answer that  
20 question. I've received enough information and I  
21 guess I'd like to hear other members of the  
22 committee about whether they -- whether there is any  
23 consensus about any significant items to be  
24 included. I don't want to be conclusive at this  
25 stage, yes or no. But I don't have any that I offer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 at this point.

2 CHAIRMAN SIEBER: Okay, thank you.

3 MR. HOLIAN: I agree, I don't think we  
4 need an interim letter. I -- the areas, you know my  
5 primary interest -- if there was enough information  
6 available than what I have to look through perhaps a  
7 little more information at the full committee  
8 presentation on specific programs would be helpful  
9 to the full committee.

10 But, at the moment I --

11 CHAIRMAN SIEBER: Could you describe --  
12 it would help both the applicant and the staff for  
13 you to tell us what you'd like to hear more about.

14 MR. HOLIAN: Okay, I'd like to hear more  
15 about the cable program in particular.

16 CHAIRMAN SIEBER: We're going to do the  
17 members first and then I'll get to you, okay.

18 MR. HOLIAN: Jim sort of gave me a hint  
19 and in fact I shouldn't have stopped reading in the  
20 SER. I read the test from the SER and now I come to  
21 commitment 36 which says once the NRC has decided on  
22 a process to address this problem the licensee will  
23 do it.

24 Well, I guess I can't really expect the  
25 licensee to do much until you tell them what to do.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So, he's gone about as far as he can go at the  
2 moment.

3 So, I'm -- Commitment 36 is what?

4 MR. HOLIAN: This is a new commitment  
5 and it's once an onsite audit question 4.701. Once  
6 the NRC has adopted a process or accepted a process  
7 for addressing PWSCC at alloy 82 welds and all of  
8 the devaluations they'll do it.

9 CHAIRMAN SIEBER: Sounds good to me.

10 MR. HOLIAN: Sounds good to me.

11 MEMBER BLEY: Nothing new from me.

12 CHAIRMAN SIEBER: Dennis?

13 MR. RYAN: I just picked up on John  
14 Stetkar's comment. I think there's a more generic  
15 issue on how water gets into these piping systems  
16 whether it's ground water or rain water or both and  
17 what measurables and metrics are going to be  
18 important for the NRC to develop and to convey the  
19 licensee so they make a meaningful measurements on  
20 how the behavior of the system is progressing with  
21 time.

22 CHAIRMAN SIEBER: It's rain water  
23 because the manhole covers and there's no seal.

24 MR. RYAN: Usually.

25 CHAIRMAN SIEBER: Usually, you can lift

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       them off.

2                   MR. RYAN:  That's part of it, but the  
3       other part of it is, you know three inches of rain  
4       over a month versus three inches of rain in an hour  
5       kind of have different impacts on loading that  
6       system with water and I take the other point that  
7       was made earlier that some times it's in the pipes  
8       and not in the conduits and you know you've got to  
9       really think through the whole problem as a system.  
10      So, I think there's a bigger issue there for the  
11      staff to think about.

12                   CHAIRMAN SIEBER:  I think there's a  
13      different issue too.  A lot of the people look at  
14      the cable itself and say it can stand this kind of  
15      environment for this length of time and remain  
16      qualified and forget about this place.  The reason  
17      why your pull box is either to pull or to splice  
18      something.

19                   And you have to -- the splices are made  
20      on the job and you have to pay attention to how --

21                   MEMBER RYAN:  And I think that's exactly  
22      the point.  You know there's an engineering part of  
23      the problem and then there's a geo-sciences part of  
24      the problem, you have to put it all together.

25                   MEMBER RAY:  Well Jack, this is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 discussion I was eluding to and I thought we might  
2 have. You used the word qualified just then and I  
3 just wanted to point out that these are not required  
4 to be qualified.

5 And so part of my issue here is that I'd  
6 like us to discuss a little bit more is the function  
7 itself. I think Otto asked what's the safety  
8 function. I would echo that.

9 CHAIRMAN SIEBER: The control cables for  
10 breakage.

11 MEMBER RAY: Well I know, but the need  
12 for them to function is in the recovery from the  
13 loss of offsite power event. And I need to  
14 understand what the safety implications of that  
15 particular step are. I think I know, but I don't.  
16 This is not the place to get into that I think.

17 MEMBER STETKAR: I think there's a  
18 couple of things here that we have to be careful  
19 with. Specifically at Vogtle there are these two  
20 cables involved that are the offsite power recovery  
21 issue.

22 We've had other license renewal  
23 applicants come in where they have had similar  
24 problems with water accumulation for safety related  
25 cables that are not qualified. This is safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 related equipment cables that are not qualified to  
2 be used under water.

3 MEMBER RAY: No it isn't, no it isn't.

4 MEMBER STETKAR: No, no not at Vogtle.  
5 But other license renewals. In a generic sense this  
6 covers a broad spectrum of possible types of cables,  
7 possible types of applications, and different Plant  
8 specific configurations.

9 For this subcommittee today we're only  
10 interested in what's the problem at Vogtle. The  
11 generic sense is the bigger picture.

12 CHAIRMAN SIEBER: Let's be clear about  
13 the importance of the cables if they are control  
14 cables that offer breakers.

15 MEMBER RAY: These are power. I  
16 understand that, that's why I asked if they were  
17 energized.

18 MEMBER STETKAR: No, these are 4 kV  
19 power cables.

20 MEMBER RAY: That's right, 480 volt.

21 MEMBER STETKAR: But we've had for other  
22 license renewal applications, Vogtle not  
23 withstanding --

24 MEMBER BROWN: The last thing we talked  
25 about, the last Plant we talked about had 4 kV power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cables. But they were qualified. They said they  
2 were safe to work in stations like that.

3 MR. BLEY: I passed, but I had a generic  
4 issue since you brought up the generic side. Two  
5 comments, but it's not, I don't think it's a local  
6 issue, it's more general.

7 One is, we've heard a little bit about  
8 the issue of wetting and drying and wetting and I  
9 know there's work going on I think we need to  
10 understand what works going on and what applies.

11 Second, although I would have agreed  
12 with you a month ago that the reason there is a full  
13 boxes for a splice we'd see at least one with no  
14 splice in it. And maybe it's a long pull I'm not  
15 sure why it's that way. But, it's not always that  
16 there is a splice in there.

17 CHAIRMAN SIEBER: You need a place to  
18 pull it from. Okay, is it Otto's turn now?

19 MEMBER MAYNARD: It was a while ago too.

20 CHAIRMAN SIEBER: Yes, right you're  
21 going to have your turn.

22 MEMBER MAYNARD: I don't think there's a  
23 need for an interim letter and I think we have  
24 enough information to go ahead here.

25 I believe that the majority of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 issues that are really being discussed are generic  
2 issues and I think that they are current operating  
3 issues as opposed to license renewal. Maybe if you  
4 want to touch on it and stuff.

5 I do think they are important issues. I  
6 think we have to sort out as to what do we put as  
7 part of license renewal. And I really believe that  
8 this cable vaulting water and stuff I think is a  
9 current operating issue and I think it is a generic  
10 issue that none of us have our hands around as to  
11 the overall safety significance and what are the  
12 requirements and what really needs to be done.

13 And I certainly don't think that any of  
14 the monitoring programs that I've seen to date come  
15 anywhere close to -- if it is a safety problem I  
16 haven't seen any indication that the monitoring  
17 programs are really adequate for that right now.

18 But again, I think these are generic  
19 issues and I think we have to sort out as to what do  
20 we put into the license renewal review.

21 CHAIRMAN SIEBER: Yes, but just so they  
22 are given something about generic issues.

23 MEMBER MAYNARD: I think as far as for  
24 the next presentation and stuff I do think that  
25 since we walked about material conditions I think it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would be good for the staff to come and write a  
2 little bit more information on the overall material  
3 condition.

4 CHAIRMAN SIEBER: Probably in inside  
5 containment particularly.

6 MEMBER RAY: Is license renewal Otto or  
7 is a current issue?

8 MEMBER MAYNARD: Both.

9 MEMBER RAY: Well, I understand, he  
10 should say yes. But I just want to hear him.

11 MEMBER MAYNARD: Yes, and also because  
12 it's something, either way it's something that we  
13 put on the public record that I think is kind of  
14 left hanging a little bit there that I think needs  
15 to be tied up a little better for the public record.

16 CHAIRMAN SIEBER: Yes?

17 MEMBER MAYNARD: Yes.

18 MEMBER BROWN: Two things, as an  
19 electrical guy I don't like cables under water. I  
20 was --

21 CHAIRMAN SIEBER: You were in the Navy.

22 MEMBER BROWN: It's been a long time.

23 MR. BLEY: You're not touching those.

24 MEMBER BROWN: You're not immersed in  
25 water. So, pertaining to -- so under water we don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 worry about it. It's the ultimate heat sink result.

2 So, I've been surprised in two meetings  
3 now that there has been less information -- less --  
4 I don't -- this sounds negative and I didn't mean it  
5 to. But, I would have had -- personally I would  
6 have had more curiosity as to source, that's why I  
7 asked the question visa vie your point.

8 You know is it just stuff oozing up and  
9 it's -- they inspect it, suck it out and nobody  
10 looks at it for two months and then they see some  
11 more, then well that to me you ought to know how  
12 facts does it come back and what are the  
13 environmental conditions. We ought to know were  
14 it's coming from wand what's going on.

15 CHAIRMAN SIEBER: Yes, one day I pump it  
16 up.

17 MEMBER BROWN: I didn't answer your  
18 other question first. Maybe you ought to have a  
19 pump there all the time. I don't like water in my  
20 basements. So the sumps pup --

21 CHAIRMAN SIEBER: A couple of hundred --

22 MEMBER BROWN: No, I don't think there's  
23 a interim letter. I agree that this is more of a  
24 generic type issue than it is a licensing issue.  
25 So, I piggy back on Otto's. I won't repeat all of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those. But I'm a little surprised at the lack of  
2 curiosity, not meant to be negative, there's no  
3 spears being fired here. I mean it's just I like to  
4 know where stuff comes from.

5 And the material condition thing is  
6 interesting. If we had seen one of our Plants in  
7 that condition the CO would have been ripped off the  
8 ship. The plant would have been shut down and we  
9 would have gone -- now, all we did was see these  
10 pictures. So I have -- there's no context at all  
11 other than those what was done, when they were  
12 taken, where there mitigation things done and what  
13 have you.

14 It's just -- you don't -- and we've got  
15 40 more years that we're predictably looking at  
16 taking care of this. Now, are there mitigating  
17 actions you can take, yes. Can you replace stuff  
18 yes, but some of those are huge structures, tanks.  
19 It's not easy to do.

20 So, is that a licensing issue. I don't  
21 know, I don't have enough experience to being a  
22 newbie here for five months or whatever it is to say  
23 that I'm just disturbed by the expanse of those  
24 pictures. But the context is not there and so it's  
25 hard for me to make a judgement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So that's -- I would like to have  
2           somebody present to us a general context over a  
3           chronology of that as it gradually built the stuff.

4           For instance, if you looked at that  
5           valve was that -- you went back and looked at it  
6           today is it pristine and pretty. We don't know.

7           MR. BARTON: Well you have to wait until  
8           the next refueling outage.

9           MEMBER BROWN: Yes, so any way that's my  
10          comment. I don't know how the old -- I'd like some  
11          more advice from you with more experience in these  
12          commercial civilian plans than I have because I --  
13          we wouldn't have put up with that in a Naval Plant.

14          We had a lot of salt water we deal with  
15          and so we try to keep them so we can see what's  
16          going on.

17          MEMBER BONACA: I agree with everybody  
18          for no interim letter. I don't see any need for an  
19          interim letter and I think there is enough review  
20          material as Otto pointed out to deal with this  
21          issue.

22          I believe that the full committee would  
23          be interested in both issues that were discussed  
24          here. The splicing and the water standing, and the  
25          deposits and containment. The effect of that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 presence of deposits on the model casting problem.

2 So, I think that we need to bring that  
3 issue. I think that there are generic -- the first  
4 one there are no cables. Its' a generic issue right  
5 now. We always find it and what we heard often  
6 times is that simply we will not rest the frequency  
7 of inspections, that will do nothing.

8 I mean to go from two years to six  
9 months doesn't tell me anything about what's  
10 happening in between the drying and the wetting  
11 issue, it's a fundamental issue and how do you  
12 monitor that. How do you prevent that. So, that's  
13 pretty much it.

14 CHAIRMAN SIEBER: I still like Mike's  
15 ideas to figure out why it's getting in there. When  
16 do you know when to pump it out, know when to  
17 inspect and when to pump it out. If you have a hot  
18 dry summer, you don't have to pump.

19 Okay, John?

20 MR. BARTON: I think Otto and Josh  
21 covered what I was going to -- I don't think you  
22 need a letter to be written.

23 I think somebody needs to look at the  
24 SER and try to find out if they said there were a  
25 lot of issues with the SER that would -- and as far

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 as the another issue I have is what is the real  
2 overall condition of the Plant material conditional  
3 that I can look back through on the inspections and  
4 you know why wasn't this stuff picked up because  
5 it's in the same condition in unit 2, you know  
6 what's the effect on the corrective action program  
7 and things like this.

8 That's about the only issue I can come  
9 up with.

10 CHAIRMAN SIEBER: Okay, well thank you  
11 very much. I think that it might be a good idea to  
12 address two things from the same point of the  
13 applicant and the staff.

14 One of them is the water in the manhole  
15 issue. You may have some new ideas about -- after  
16 the four hours of discussion some new ideas about  
17 how you want to deal with it.

18 The other one is a trio condition in  
19 containment. I may have some new ideas about that  
20 and the third one would be, I think from the staff.

21 Let's take a look through the inspection  
22 reports to try and get a better handle on material  
23 condition so that we can make a judgement on this to  
24 whether to the Plant is to grading and we'll grade  
25 seriously by the Sergeant license renewal or not.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BARTON: I understand.

2 CHAIRMAN SIEBER: You need to cut her an  
3 assessment for overall material conditions.

4 MEMBER BROWN: I understand.

5 CHAIRMAN SIEBER: So, in addition to  
6 giving the broad over view like you are giving here  
7 for the record then we'll have less time, we're only  
8 going to have about an hour and a half or two hours.  
9 We'd like you to touch on those three subjects and  
10 for the applicant to touch on two of those three.  
11 So, with that being done let's finishing exactly on  
12 time.

13 MEMBER RAY: We are and I'm not going to  
14 delay us Jack, but I wanted to make one comment and  
15 that is -- there's been all this rhetoric about  
16 material conditions. Just remember, ALARA is a  
17 issue whenever you talk about having material  
18 condition Christine you're also got to demonstrate  
19 that it was consistent with ALARA.

20 CHAIRMAN SIEBER: One of the things I  
21 learned working in Power Plants for 38 years was if  
22 you have a clean plant it sort of goes a long way.

23 MEMBER RAY: Well, inside containment is  
24 a different story.

25 CHAIRMAN SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER RAY: Say one more time, ALARA is  
2 important. I didn't hear it mentioned. I think it  
3 should be mentioned.

4                   CHAIRMAN SIEBER: Okay, with that thank  
5 you very much both Southern Nuclear and the staff.  
6 This meeting is adjourned.

7                   (Whereupon, the meeting was  
8 adjourned at 5:02 p.m.)

9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

  
Eric Hendrixson  
Official Reporter  
Neal R. Gross & Co., Inc.





United States Nuclear Regulatory Commission

*Protecting People and the Environment*

**Advisory Committee on Reactor Safeguards (ACRS)  
License Renewal Subcommittee  
Vogtle Electric Generating Plant (VEGP)**

**Safety Evaluation Report (SER)**

November 5, 2008

Donnie J. Ashley, Project Manager  
Office of Nuclear Reactor Regulation

# Introduction

- Overview of VEGP license renewal review
- SER Section 2: Scoping and Screening review results
- License Renewal Audit and Inspection
- SER Section 3: Aging Management review results
- SER Section 4: Time-Limited Aging Analyses (TLAAs)

## Overview (LRA)

- License Renewal Application (LRA) submitted June 2007
  - Located 26 miles southeast of the Augusta, Georgia, in Burke County, Georgia
  - Westinghouse PWRs, carbon steel-lined concrete (DRYAMB) containment
  - Each Unit rated at 3565 megawatt thermal, 1208 megawatts electric (prior to MUR uprate.)
  - Unit 1 Facility Operating License Number NPF-68 expires January 16, 2027
  - Unit 2 Facility Operating License Number NPF-81 expires February 9, 2029

# Overview (SER)

- Safety Evaluation Report (SER) issued to the applicant
  - 87 RAI items issued
  - 173 Audit Questions
  - AMR line items  $\approx 87\%$  Consistent With GALL Report, Revision 1
  - 41 Commitments
  - Additional Components Brought Into Scope
  - No Open Items (OIs)
  - No Confirmatory Items

# Audits and Inspections

- Scoping and Screening Methodology Audit  
9/17 – 9/21, 2007
- Aging Management Program (AMP) Audit  
10/15 – 10/19, 2007
- Aging Management Review (AMR) Audit  
12/9 – 12/14, 2007
- Region II Inspection (Scoping and Screening & AMP)  
5/19/ – 06/06, 2008

# Audit and Review

- Audit Summary (ADAMS Accession No. ML080430373)
  - Publicly Available, Issued on September 30, 2008
  - Audit Summary Includes :
    - Audit and Review Results
    - Audit and Review Q&A Database
    - List of Documents Reviewed by the Audit and Review Team



## **SER Section 2: Structures and Components Subject to Aging Management Review**

### Section 2.1 Scoping and Screening Methodology

- Staff's audit and review concluded that the applicant's methodology is consistent with the requirements of 10 CFR 54.4 and 54.21.

### Section 2.2 Plant-Level Scoping Results

- Consistent with 10 CFR 54.4, the staff found no omission of plant-level scoping systems and structures within the scope of license renewal.



## **SER Section 2: Structures and Components Subject to Aging Management Review**

### Section 2.3 Scoping and Screening Results: Mechanical Systems

## 98 Mechanical Systems

– 34 BOP

- 100% Reviewed

- Based on RAIs, three ventilation components were added to the scope





## **SER Section 2: Structures and Components Subject to Aging Management Review**

### **Section 2.4 Scoping and Screening Results: Structures**

**No omission of structural components within the scope of license renewal**

## **SER Section 2: Structures and Components Subject to Aging Management Review**

### Section 2.5 – Electrical and Instrumentation and Control Systems

- No omission of electrical and instrumentation and control system components within the scope of license renewal



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# **License Renewal Inspections**

**Louis Lake**

**Region II  
Inspection Team Leader**



## License Renewal Inspections

- Scoping and Screening Inspection
- Objective
- Focus



## License Renewal Inspections Program Implementation

- License renewal chapter - MC 2516
- License renewal inspection procedure  
IP 71002



## Aging Management Programs (AMPs) Implementation

- Objective
- Examine records



## Aging Management Programs (AMPs) Implementation

- Examine implementation plans
- Verify material condition of plant was adequately maintained



## License Renewal Inspection

- AMP inspection May 19 – June 6, 2008
- Inspection concluded that existing programs for license renewal are generally functioning well.





## License Renewal Inspection

- Inspectors identified enhancements
  - Manhole flooding with Medium Voltage Non-Safety Related Cable
  - Condition inside containments




## License Renewal Inspection

- Applicant had established AMP implementation plans
- Region II will follow up on these issues during a future IP 71003 inspection


# Current Performance

- Green Pls & Findings
- Mid-Cycle Performance Review

# VEGP Units 1 and 2 Performance Indicators




# VEGP Unit-1 Findings



## Most Significant Inspection Findings

	Initiating Events	Mitigating Systems	Barrier Integrity	Emergency Preparedness	Occupational Radiation Safety	Public Radiation Safety	Security
3Q/2008	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
2Q/2008	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
1Q/2008	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
4Q/2007	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]

# VEGP Unit-2 Findings



**Most Significant Inspection Findings**

	Initiating Events	Mitigating Systems	Barrier Integrity	Emergency Preparedness	Occupational Radiation Safety	Public Radiation Safety	Security
3Q/2008	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
2Q/2008	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
1Q/2008	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
4Q/2007	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]

# Inspection Results

- No violations identified
- Inspection findings:
  - Condition of coatings inside containment
  - Manhole flooding

## SER Section 3: Aging Management Review Results

### Section 3.0.3 Aging Management Programs (AMPs) evaluated in the SER

	Plant specific	Consistent with GALL	With exception	With enhancement	With exception & enhancement
Existing	6	5	3	5	5
New	5	3	6	0	0



## **Section 3.1 Aging Management of Reactor Vessel, Reactor Vessel Internals, and Reactor Coolant System**

- reactor vessel
- reactor vessel internals
- RCS and connected lines (includes the reactor coolant pumps)
- pressurizer
- SGs

## **Section 3.2 Aging Management of Engineered Safety Features System**

- containment spray system
- emergency core cooling system

## 3.3 Aging Management of Auxiliary Systems

- fuel storage racks – new and spent fuel
- spent fuel cooling and purification system
- overhead heavy and refueling load handling systems
- nuclear service cooling water systems
- component cooling water system
- auxiliary component cooling water system
- turbine plant cooling water system
- river intake structure system
- compressed air systems
- chemical and volume control and boron recycle systems
- ventilation systems – control building (CB)
- ventilation systems – auxiliary building (AB)
- ventilation systems – containment building (CTB)
- ventilation systems – fuel handling building (FHB)
- ventilation systems – diesel generator building
- ventilation systems – auxiliary feedwater pumphouse
- ventilation systems – miscellaneous
- ventilation systems – radwaste buildings
- fire protection systems
- emergency diesel generator system
- demineralized water system
- hydrogen recombiner and monitoring system
- drain systems
- potable and utility water systems
- radiation monitoring system
- reactor makeup water storage tank and degasifier system
- sampling systems
- auxiliary gas systems
- chilled water systems
- waste management systems
- thermal insulation
- miscellaneous leak detection systems

## **3.4 Aging Management of Steam and Power Conversion Systems**

- main steam system
- feedwater system
- SG blowdown processing system
- auxiliary feedwater system
- auxiliary steam system

## **3.5 Aging Management of Containments, Structures, and Component Supports**

- containment structures
- auxiliary, control, fuel handling and equipment buildings
- emergency diesel generator structures
- turbine building
- tunnels and duct banks
- NSCW structures
- concrete tank and valve house structures
- switch yard structures
- fire protection structures
- radwaste structures
- auxiliary feedwater pump house structures
- component supports and bulk commodities

## Section 3.5 Aging Management of In-Scope Inaccessible Concrete

Testing performed in November 2005 and May 2007 found:

	Acceptance Criteria	VEGP (2005-2007)	
		min	max
pH	>5.5	5.77	8.24
Chlorides (ppm)	<500	1.95	8.71
Sulfates (ppm)	<1500	2.9	12.5

## **3.6 Aging Management of Electrical and Instrumentation and Controls System**

- cable connections (metallic parts) not subject to 10 CFR 50.49 EQ requirements
- conductor insulation for electrical cables and connections not subject to 10 CFR 50.49 EQ requirements
- conductor insulation for inaccessible medium-voltage cables not subject to 10 CFR 50.49 EQ requirements
- connector contacts for electrical connectors exposed to borated water leakage not subject to 10 CFR 50.49 EQ requirements
- fuse holders (not part of a larger assembly): insulation not subject to 10 CFR 50.49 EQ requirements
- fuse holders (not part of a larger assembly): metallic clamps
- high voltage insulators
- switchyard bus and connections
- transmission conductors and connections

## **SER Section 4: Time-Limited Aging Analyses**

- 4.1 TLAA Process
- 4.2 Reactor Vessel Neutron Embrittlement
- 4.3 Metal Fatigue
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Tendon Prestress
- 4.6 Containment Liner Plate Metal Containments and Penetration Fatigue
- 4.7 Other Plant Specific TLAA



## **Section 4.2 Reactor Vessel Neutron Embrittlement Analyses**

Reviews were performed to evaluate reactor vessel neutron fluence and the corresponding vessel embrittlement in terms of adjusted reference temperature (ART) and:

- Upper-shelf energy
- Pressurized thermal shock
- Pressure-temperature limits

The staff concludes that the reactor vessel neutron embrittlement analyses meet the review criteria in the Standard Review Plan.

## Upper Shelf Energy (USE) Decrease

Reactor vessel limiting material	Fluence x10 <sup>19</sup> n/cm <sup>2</sup> (E>1.0 MeV)	Unirradiated USE (ft-lb)	Predicted USE Decrease (10CFR50 apdx. G., %)	<u>56.3 EFPY</u> <u>Projected</u> <u>USE</u> <u>(ft-lb)</u>	<u>EOL USE</u> <u>Acceptance</u> <u>Criteria</u> <u>(ft-lb)</u>
Unit 1 Nozzle-to-Intermediate Shell Plate Circumferential weld 103-21	<b>0.0532</b>	<b>70</b>	<b>12</b>	<b>61</b>	<b>≥ 50</b>
Unit 2 Shell Course Weld 105-121A	<b>0.0455</b>	<b>64</b>	<b>11</b>	<b>56</b>	<b>≥ 50</b>

## Reactor Vessel RT<sub>PTS</sub>

	<u>60 calendar years</u> <u>56.3 EFPYs</u> Unit 1 / Unit 2	<u>RT<sub>PTS</sub></u> <u>10 CFR 50.61</u> <u>screening</u>
Fluence E > 1.0 MeV	3.2x10 <sup>19</sup> n/cm <sup>2</sup> / 3.02x10 <sup>19</sup> n/cm <sup>2</sup>	--
Calculated RT <sub>PTS</sub>	<b>123.3°F / 134.2°F</b>	<b>≤ 270°F</b>

- The limiting reactor vessel material is Intermediate Shell Plate Heat Number B8805-2 for Unit 1 and Nozzle Shell Course R3-3 for Unit 2.
- The calculational fluence methodology adheres to the guidance of RG 1.190.

## **Additional TLAAAs**

- 4.3 Metal Fatigue Analyses
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Tendon Prestress
- 4.6 Containment Liner Plate Metal Containments and Penetration Fatigue

## **4.7 Other Plant Specific TLAA**

- 4.7.1 Leak Before Break Analysis
- 4.7.2 Fuel Oil Storage Tank Corrosion Allowance
- 4.7.3 Steam Generator Tube, Loss of Material
- 4.7.4 Cold Overpressure Protection System
- 4.7.5 Underclad Cracking of Reactor Pressure Vessel



# Conclusion

On the basis of its review, the staff determines that the requirements of 10 CFR 54.29(a) have been met.



**U.S. NRC**

United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*

# License Conditions


- The first license condition requires the applicant to include the UFSAR supplement required by 10 CFR 54.21(d) in the next UFSAR update, as required by 10 CFR 50.71(e), following the issuance of the renewed license.
- The second license condition requires future activities identified in the UFSAR supplement to be completed prior to the period of extended operation.
- The third license condition requires that all capsules in the reactor vessel that are removed and tested meet the requirements of American Society for Testing and Materials (ASTM) E 185-82 to the extent practicable for the configuration of the specimens in the capsule. Any changes to the capsule insertion and withdrawal schedule, including use of spare capsules, must be approved by the staff prior to implementation. All capsules placed in storage must be maintained for future insertion. Any changes to storage requirements must be approved by the staff, as required by 10 CFR Part 50, Appendix H.



# Vogtle Electric Generating Plant

License Renewal ACR Subcommittee  
November 2008

Chalmers



# Agenda

---



- ◆ Introductions
- ◆ Description of VEGP and Current Status
- ◆ License Renewal Project
- ◆ Inspection Results (NRC Region II)
- ◆ Summation and Questions



# VEGP Representatives

---



- ◆ Tom Tynan, Site Vice President
- ◆ Lee Mansfield, Engineering Support Manager
- ◆ Chalmer Myer, License Renewal Project Manager

# Site Description

---



- ◆ Westinghouse (NSSS), Bechtel (AE)
- ◆ Two 4 Loop PWR Units
  - 3625 MWt
  - 1250 MWe
- ◆ Ultimate Heat Sink – NSCW Forced Draft Cooling Towers and Basins
- ◆ Turbine Cycle Cooling Provided By Natural Draft Towers

# Ownership

---



## ◆ Plant Licensee and Operator

- Southern Nuclear Operating Company

## ◆ Plant Owners

- Georgia Power Company (45.7%)
- Oglethorpe Power Corporation (30%)
- Municipal Electric Authority of Georgia (22.7%)
- City of Dalton, Georgia (1.6%)

# Licensing History

---



	Unit 1	Unit 2
◆ Construction Permit	June 1974	
◆ Operating License	Jan 1987	Feb 1989
◆ Stretch Power Uprate (4.5%)	March 1993	
◆ License Transfer to SNC	March 1997	
◆ LRA Submitted	June 2007	
◆ MUR Power Uprate (1.7%)	January 2008	
◆ Operating License Expires	Jan 2027	Feb 2029

# Current Plant Status

---



## ◆ Unit One

- Completed refueling outage 14 in April 2008
- 18 month average Capability Factor 92%

## ◆ Unit Two

- Completed refueling outage 13 in Oct. 2008
- 18 month average Capability Factor 90%

# VEGP License Renewal Project



---

## ◆ VEGP License Renewal

- 10 CFR 54.17(c) Exemption
- Project Team
- Scoping Highlights
- Aging Management Reviews
- Aging Management Programs
- VEGP AMP Exceptions
- Time Limited Aging Analyses
- Commitments



# VEGP License Renewal Project



## ◆ 10 CFR 54.17(c) Exemption

- NRC granted VEGP an exemption to 10 CFR 54.17(c) to submit Vogtle Unit 2 License Renewal Application prior to reaching 20 years remaining on the operating license
  - ◆ Basis: Unit 2 is the same design and construction as Unit 1

# VEGP License Renewal Project



## ◆ License Renewal Project Team

- In house project team
  - ◆ Core team from Hatch/Farley LR
  - ◆ Vogtle experience added for VEGP LR
  - ◆ Expanded on success of previous applications
- LR Team engaged with the industry
  - ◆ Working groups (NEI, EPRI)
  - ◆ Participated in audits/inspections of peer plants
  - ◆ Supported LR peer reviews
- Site program owners involved in process
- No SER open items

# VEGP License Renewal Project



## ◆ Scoping Highlights

- Performed consistent with NEI 95-10 Rev 6
- Conservative spaces based approach used for (a)(2) scoping for spatial interaction
- Mechanical boundary drawings included (a)(1), (a)(2) and (a)(3) scoped components
- SBO – Scoping of switchyard SSCs consistent with NRC Staff Guidance

# VEGP License Renewal Project



## ◆ Aging Management Reviews

- Followed NEI 95-10 guidance for AMRs
- Made extensive use of GALL
  - ◆ 86% of AMR items consistent with GALL
  - ◆ Non-GALL items primarily material, environment or aging effect not in GALL

# VEGP License Renewal Project



## ◆ Aging Management Programs

- 38 Aging Management Programs
  - ◆ 9 existing programs with no change
  - ◆ 15 existing programs with enhancements
  - ◆ 14 new programs
- 27 GALL Programs
  - ◆ Only minor exceptions
  - ◆ Plant specific programs incorporated GALL attributes where possible

# VEGP License Renewal Project



- 
- ◆ VEGP AMPs – Typical Exceptions to GALL
    - Use of a different version of a code or standard (consistent with VEGP CLB)
    - Manages material/environment not in GALL
    - AMP scope differences
    - Use of alternative inspection methods

# VEGP License Renewal Project



## ◆ Metal Fatigue

- VEGP program currently uses FatiguePro
- VEGP has committed to implement benchmarked software to manage fatigue prior to the period of extended operation.

# VEGP License Renewal Project



## ◆ Commitment Management

- 39 commitments made to enhance aging management at VEGP
- Commitments are tracked through Vogtle Commitment Tracking Program
- License Renewal Program Manual will link AMPs and commitments



# Inspection Results

---



## ◆ Region II Site Inspection

- Performed walkdown of Boric Acid Corrosion Control Program during 1R14 (April 2008)
- Team on site for two weeks in May/June 2008
- VEGP enhanced two existing programs as a result of comments from the inspectors

# Inspection Results



- ◆ Boric Acid Corrosion Control Program (BACCP)
  - Inspection concluded BACCP would adequately manage boric acid corrosion
  - However inspector noted non boric acid deposits from NSCW system condensation that could mask BAC
  - Corrective actions to be implemented
    - ◆ Systematic inspection, cleaning and repainting program
    - ◆ Procedure changes and enhanced communication
    - ◆ Evaluate system improvements to control condensate


# Inspection Results

---



# Inspection Results

---



# Inspection Results

---



## ◆ Medium Voltage Cables

- In scope medium voltage cables at VEGP are located in tunnels and not subject to submergence, with one exception
  - ◆ Non-safety related 4kV feeders to high voltage switchyard switch house
- Inspection found water in pull box near switch house
- Corrective action - implemented LR aging management program
  - ◆ Quarterly inspection
  - ◆ Trending of results

# Summary



- 
- ◆ Experienced team created high quality LRA
  - ◆ Extensive use made of GALL
  - ◆ Thorough and successful audits and inspection of the LRA and programs
  - ◆ VEGP responsive to NRC through out review
  - ◆ VEGP is prepared to manage aging beyond 40 years