

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
ESBWR Subcommittee

Docket Number: (n/a)

RECEIVED
JUN 12 2008

Location: Rockville, Maryland

Date: Tuesday, June 3, 2008

Work Order No.: NRC-2222

Pages 1-385

ORIGINAL

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
ESBWR SUBCOMMITTEE

June 3, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 3, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

MEETING

+ + + + +

ESBWR SUBCOMMITTEE

+ + + + +

TUESDAY,

JUNE 3, 2008

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 9:00 a.m., Michael Corradini, Chairman, presiding.

MEMBERS PRESENT:

MICHAEL CORRADINI	Chairman
SAID ABDEL-KHALIK	Member
GEORGE E. APOSTOLAKIS	Member
J. SAM ARMIJO	Member
DENNIS C. BLEY	Member
MARIO V. BONACA	Member
OTTO L. MAYNARD	Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBERS PRESENT: (cont'd)

2 DANA A. POWERS Member
3 WILLIAM J. SHACK Member
4 JOHN D. SIEBER Member
5 JOHN W. STETKAR Member

6 CONSULTANTS TO THE SUBCOMMITTEE:

7 THOMAS S. KRESS

8 ACRS STAFF PRESENT:

9 HAROLD J. VANDER MOLEN
10 HOSSEIN HAMZEHEE
11 MARK CARUSO
12 ROCKY FOSTER
13 AMY CUBBAGE
14 GEORGE THOMAS
15 ED FULLER
16 HOSSEIN ISMAILI
17 JIM XU
18 MIKE SNODDERLY

19 ALSO PRESENT:

20 RICK WACKOWIAK
21 GARY MILLER
22 CLEMENT RAJENDRA
23
24
25

TABLE OF CONTENTS

1		
2		<u>PAGE</u>
3	Opening Remarks and Objectives	4
4	Chapter 19	5
5	Chapter 22	274
6	Discussion	344
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		

TABLE OF CONTENTS

	<u>PAGE</u>
1	
2	
3	Opening Remarks and Objectives 4
4	Chapter 19 5
5	Chapter 22 274
6	Discussion 344
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

P-R-O-C-E-E-D-I-N-G-S

(9:00 a.m.)

CHAIRMAN CORRADINI: This meeting will come to order.

This is a meeting of the Advisory Committee on Reactor Safeguards, Subcommittee on the Economic -- on the ESBWR.

My name is Mike Corradini, Chair of the Subcommittee.

The Subcommittee members in attendance are: Said Abdel-Khalik, Sam Armijo, Otto Maynard, Bill Shack, John Sieber, and John Stetkar. Other members present are: George Apostolakis, Dennis Bley, Mario Bonaca, Dana Powers, and our consultant to the Committee, Tom Kress.

The purpose of this meeting is to discuss Chapters 19 and 22 of the chapters of the Safety Evaluation Report, with open items associated with the ESBWR design certification application. The Subcommittee will hear presentations by, and hold discussions with, representatives of the NRC staff and the ESBWR applicant, General Electric Hitachi Nuclear Energy, regarding these matters.

The Subcommittee will gather information, analyze relevant issues and facts, and formulate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 proposed positions and actions as appropriate for
2 deliberation by the full Committee.

3 Harold Vander Molen is the Designated
4 Federal Official for this meeting.

5 The rules for participation in today's
6 meeting have been announced as part of the notice of
7 this meeting previously published in the Federal
8 Register on May 20, 2008.

9 A transcript is being kept and will be
10 made available, as stated in the Federal Register
11 notice. It is requested that speakers first identify
12 themselves, and speak with sufficient clarity and
13 volume so that they can be readily heard.

14 We have not received any requests from
15 members of the public to make oral statements or
16 written comments. So we will proceed now with the
17 meeting, and I will call upon Rick Wackowiak of
18 General Electric Hitachi Nuclear Energy to begin.

19 Rick?

20 MR. WACKOWIAK: Good morning. My name is
21 Rick Wackowiak from General Electric Hitachi, and I am
22 the technical lead for the ESBWR PRA. With me today
23 I've got Gary Miller, Principal Engineer from the
24 ESBWR PRA, and then we have our cast off to the side
25 for help. If we get into any specific questions, then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we'll get to them as necessary.

2 This morning, and throughout the day, we
3 want to go through the SER with open items for the
4 ESBWR Chapters 19 and 22 -- is the staff's designation
5 for regulatory treatment of non-safety systems. In
6 our DCD, it's Chapter 19(a), Appendix A to Chapter 19.
7 So those mean the same thing.

8 The way we're going to go through this is
9 we're going to make our presentation this morning on
10 the PRA, and I believe that will get us through lunch.
11 And right after lunch staff will make their
12 presentation, and then we'll discuss any questions or
13 anything else that comes up from the Chapter 19
14 review.

15 This afternoon, then after that, we will
16 make a presentation -- our presentation on the RTNSS,
17 and that chapter of the SER -- 22 -- with open items,
18 and, once again, after that the staff will make their
19 presentation on the same chapter. We'll be here to
20 answer questions about that.

21 We have a lot of stuff to cover this
22 morning. Many of the -- many of you have seen a lot
23 of the things in the ESBWR PRA report itself. Back
24 in --

25 CHAIRMAN CORRADINI: 2006.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: -- 2006 I think is the
2 last time we talked about this, and we covered some
3 portions of the PRA, up through I believe the Level 1
4 quantification. And since then, we have submitted two
5 full revisions to the PRA. What we discussed before
6 was the last revision of Chapters 1 through 7,
7 finished that up later on with Chapters 8 through 21
8 in our report, and then Monday morning you received
9 the next revision of the PRA that is a full -- all now
10 22 chapters, and we'll talk about -- right toward the
11 end we'll talk about that.

12 MEMBER APOSTOLAKIS: Why were these
13 revisions taking place? You decided to change it, or
14 is it the result of interactions with the staff?

15 MR. WACKOWIAK: The DCD has been updated,
16 and so what -- the latest revision to the PRA covers
17 all of the changes that were made to the ESBWR from
18 the time we submitted the last -- or from the time we
19 submitted the last revision through being current with
20 what's in DCD Rev 5.

21 CHAIRMAN CORRADINI: So we're going to get
22 -- we have not got, but we're going to get --

23 MR. WACKOWIAK: Haven't gotten it yet.

24 CHAIRMAN CORRADINI: -- DCD 5 and the
25 associated change to the PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Right. So let me jump to
2 the bottom line on that -- on the Rev to the PRA.

3 MR. HAMZEHEE: Rick, I think -- I just
4 want to mention that one of the other reasons that you
5 came out with revisions are to also address some of
6 the staff's concerns and questions and those things.

7 MR. WACKOWIAK: Right. So it's two
8 reasons for having the revision.

9 We weren't going to spend a lot of time
10 talking about what was in that revision here today,
11 because mainly you haven't seen it. But I just would
12 like to go right to the bottom line for it. The
13 results and insights from the PRA, even though we did
14 some changes to the plant and resolved some issues,
15 they are essentially unchanged from the version of the
16 PRA that you see -- or that you have seen.

17 MEMBER APOSTOLAKIS: There is one more
18 kind of broad question. Since we don't have a plant
19 -- I mean, there were a lot of assumptions and
20 marketing analysis of the PRA, and so on. I don't
21 remember now -- if somebody actually buys a plant and
22 builds it, will there be a detailed PRA submitted to
23 the NRC, or is that out now? Yes, sir.

24 MR. HAMZEHEE: Rick, would you like to
25 respond, or do you want me --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: I'll respond the way that
2 I understand the current regulation. When somebody
3 buys and builds the ESBWR, they are required to
4 perform a site-specific detailed PRA that conforms to
5 all of the endorsed standards that are in effect one
6 year prior to fuel load.

7 But that -- there is no requirement that
8 that is to be submitted. It would be -- my
9 understanding is that it would be there for audit
10 purposes. You can come in and look at it. But I
11 don't believe that that's a submitted PRA according
12 to --

13 CHAIRMAN CORRADINI: Well, but if that day
14 comes, when that day comes --

15 MR. WACKOWIAK: When that day comes, yes.

16 CHAIRMAN CORRADINI: -- the results will
17 be available as part of the submittal. The PRA will
18 be onsite.

19 MR. WACKOWIAK: The results will be
20 available, that's correct.

21 MEMBER APOSTOLAKIS: But my question is
22 really: will there be another you?

23 MR. WACKOWIAK: Yes.

24 MEMBER APOSTOLAKIS: Or are we going to
25 have the situation where you are reviewing something

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and they would say, "Oh, no. But the design has been
2 certified. You are not supposed to talk about it."

3 MR. HAMZEHEE: Well, under Part 52 for the
4 COL applicants and COL holders, there are some
5 requirements for the PRA, one of which, as Rick said,
6 is that one year prior to the initial fuel load they
7 have to complete full-scope all-initiating event,
8 plant-specific PRAs, and submit the results and the
9 methodology to the staff for review. So that's a
10 requirement.

11 And what we have received so far, for
12 instance, as part of the COL application is that they
13 review the existing PRAs and then they evaluate it to
14 see how much additional work they have to perform to
15 make a plant-specific PRA.

16 MEMBER BLEY: Let me follow that with a
17 question, because we had heard some discussion of how
18 other issues with respect to COL would be handled, and
19 it sounded in other areas like there would just be an
20 exception report. It's the PRA for the design cert
21 with these 10 pages of changes. Is that the way it
22 works?

23 MR. HAMZEHEE: I'm sorry, Dennis. What is
24 the question? I was interrupted.

25 MEMBER BLEY: With other design issues,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they told us that when there's a COL they will refer
2 to the design certification and just identify areas
3 where there might be -- where there would be
4 differences. Is that the way this would work?

5 MR. HAMZEHEE: That's the way they have
6 done it in the last few submittal. But it comes to
7 the staff for review and evaluation. But they looked
8 at the existing PRA, the design certification PRA, and
9 then they determined whether or not that is sufficient
10 for their plant-specific application.

11 Now, two things they have to consider as
12 a minimum is the following. One, plant-specific
13 features and vulnerabilities; and number two is any
14 departure from design, from certified design, because
15 when COL application comes in they may or may not
16 follow all of the design certification features.

17 So if there are a number of departures or
18 changes, they have to evaluate them and tell us how
19 they have incorporated those into the risk
20 assessments.

21 MR. WACKOWIAK: I think we are talking
22 about two different things here, and we've kind of
23 mixed them up a little bit. We have the design
24 certification PRA, and that's based on the assumptions
25 that we made during this review, this design of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 planning.

2 The COLAs will also submit something that
3 addresses the PRA, and it's likely that they will just
4 submit the 10 pages and list exceptions, like you're
5 saying for a COLA, for an application. But, remember,
6 at the application stage, there still is no plant, and
7 there is -- it's still largely based on what we say
8 we're going to do in the design documents.

9 I think what Dr. Apostolakis was talking
10 about is after the plant is built, then what happens?
11 And at that point, that's when the new statutory
12 requirement for a site-specific PRA comes into play
13 that's based on the as-built and as-to-be-operated
14 plant, and it -- the scope of that is all endorsed PRA
15 standards that are in effect at the time.

16 And every four years each plant would have
17 to go through and say, "Is there a new standard?" So
18 is now -- is there a seismic PRA standard? Or is
19 there some new standard that's in effect? And every
20 four years the PRA would need to be updated to include
21 any new standards that are out there.

22 MEMBER APOSTOLAKIS: Now, let me give you
23 an example, so that I will understand better what the
24 plans are. Suppose after this PRA is completed for
25 the built plant, can we raise a question, for example,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 regarding the frequency of an initiating event that is
2 now in your PRA, or somebody will say, "Wait a minute.
3 This was in the design certification phase. You guys
4 reviewed it. You are not allowed to raise any
5 question now." Is that a fact or not?

6 MEMBER STETKAR: And when you think about
7 -- let me just add a little bit to help his. Not just
8 the frequency of an initiating event, but suppose
9 there is a piece of equipment in the current plant
10 design -- in the current plant design -- that is not
11 modeled in the current PRA. Are we at some later date
12 able to ask questions about why is that piece of
13 equipment not modeled? Or is this venue the only
14 chance that we have to ask that question?

15 MR. HAMZEHEE: The answer is yes, the
16 staff can ask that question, how come that piece of
17 equipment is not modeled in the PRA.

18 MEMBER STETKAR: But when, though? Now?

19 MR. HAMZEHEE: When they submit their COL
20 application, and then the Part 52 applies to COL
21 holder, so then there is some regulatory requirement
22 that says prior to initial fuel load you have to have
23 a plant-specific PRA which is reflective of your
24 current plant design.

25 MEMBER STETKAR: But the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: We are not going to have
2 access to that PRA.

3 MEMBER STETKAR: And that's not a change
4 to the design. That's not a site-specific change to
5 the plant design. This is a piece of equipment --
6 let's call it an X -- that is in the current design.
7 It is not in the current PRA.

8 It will be in the current design when Joe
9 buys the plant. Joe will not make any changes to X.
10 Joe will not modify the design of X. He will not
11 remove X. He will not get another X. And, therefore,
12 Joe has no site-specific reason to change the PRA for
13 X, because the PRA -- the design-certified PRA
14 theoretically accounted for X. However, it does not.

15 MR. HAMZEHEE: Yes, you --

16 MEMBER STETKAR: So how does the review
17 process, and when does the review process, identify
18 that deficiency?

19 CHAIRMAN CORRADINI: When should it
20 identify --

21 MEMBER STETKAR: When should it -- well,
22 when should it, or when will it?

23 MR. HAMZEHEE: Remember, also, there are
24 some requirements under Part 52 that the COL holder,
25 once it starts operating the plant, has to update and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 upgrade the PRA every four years consistent with the
2 endorsed standards and PRA code. So that's --

3 MEMBER STETKAR: This is consistent with
4 today's endorsed standards.

5 MR. HAMZEHEE: Correct.

6 MEMBER STETKAR: Not with the future
7 endorsed standards. Today's endorsed standards.

8 MEMBER SIEBER: There is actually a more
9 fundamental question. The PRA that we're going to
10 talk about today represents a PRA for a fictitious
11 plant and examines the boundaries, for example, the
12 site-specific boundaries, seismic conditions, and so
13 forth.

14 I could picture an applicant saying, "My
15 plant fits inside these boundaries, so the generic PRA
16 is good."

17 MEMBER STETKAR: Right. Exactly.

18 MEMBER SIEBER: And the only way we will
19 know whether that is true or not is to examine
20 whatever the staff does to audit the PRA, because you
21 won't have access to the PRA.

22 MEMBER APOSTOLAKIS: But we can go and
23 audit it ourselves, can't we?

24 MEMBER SIEBER: Well, I'm not sure exactly
25 what our bylaw says.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Yes, see, that's the
2 thing. Nobody seems to be sure.

3 Let me rephrase it slightly. If one
4 raises the question at that time, can either the staff
5 or the applicant say, "No, you cannot raise this
6 question because this issue was settled at the design
7 certification phase." Can they tell me that? Or I
8 can raise any question I want.

9 MEMBER SIEBER: Well, you can always raise
10 any question you want.

11 MEMBER APOSTOLAKIS: Yes, I'm worried
12 about --

13 (Laughter.)

14 Is it possible for them to say there has
15 been no plant-specific change from the generic PRA you
16 guys receive; therefore, you are not allowed to raise
17 this question?

18 CHAIRMAN CORRADINI: I guess my -- the
19 pragmatic part of me senses, George, that you can ask
20 the question. The applicant may choose not to answer
21 you, but we have the staff where we want them. So we
22 can keep on asking the staff until we're satisfied, I
23 would think. I would assume.

24 MR. HAMZEHEE: That's correct, and I --

25 CHAIRMAN CORRADINI: Is that the wrong

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 assumption? I think George's concern is that we will
2 be told legalistically we are essentially out of the
3 loop.

4 MEMBER APOSTOLAKIS: Yes. We don't have
5 the authority to ask this question. Is it clear to
6 you, Rick, what it's going to be?

7 MR. WACKOWIAK: Yes. I think I understand
8 what you're asking for, or what you are asking about.

9 MEMBER APOSTOLAKIS: Yes.

10 MR. WACKOWIAK: And there are other things
11 -- there are other things that I think help provide
12 that linkage. The PRA that -- the site-specific, as-
13 built, as-to-be-operated PRA will be required to meet
14 Reg. Guide 1.200 for use in applications, risk-
15 informed applications at the plant. And now I
16 understand that everything is a risk-informed
17 application, so it's to use for almost any licensing
18 action.

19 We have the maintenance rule, where the
20 PRA is used in the maintenance rule, and the DRAP --
21 one of the design reliability assurance program -- one
22 of the activities that is committed to by a COL
23 applicant is to go back with their as-built, as-to-be-
24 operated PRA and reconfirm the important components
25 that are in the DRAP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So I think there are enough other programs
2 that when you get down to using the PRA you have to
3 make sure that the PRA you have at the time is
4 appropriate for that use. The PRA that we're doing
5 here is appropriate for certifying a design of a
6 plant, and not necessarily appropriate for doing those
7 different applications.

8 MEMBER APOSTOLAKIS: The problem is that
9 the ACRS doesn't get involved with those applications.
10 We don't. We don't get involved in the actual
11 decisionmaking. We are approving the process. So can
12 someone, then, tell me at that future time, is it
13 possible someone will tell me, "This issue was settled
14 in 2008; you are not supposed to ask questions."

15 MR. CARUSO: Can I take a crack at that?
16 Mark Caruso from the staff. I think the -- what Rick
17 just said, the fact that the requirements -- the
18 regulations require that they meet the standards, and
19 we have the ASME standard and 1.200, which requires I
20 believe that they have a PRA that represents the as-
21 built, as-operated plant.

22 If there is a basis for, you know, some --
23 you know, we look at their design or their procedures,
24 or whatever. We go and audit or, you know, we look at
25 their peer-review results and we say, "Wait a minute.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You know, you guys do things this way. How can that
2 parameter or that frequency that you -- that they have
3 assumed in the design PRA apply? That's a valid
4 question, and we can ask that question. They can't
5 say, "No, you can't ask that question," because you
6 already approved that number five years ago. I
7 believe that's the case.

8 MEMBER APOSTOLAKIS: But you are saying
9 that I must justify my question.

10 MR. CARUSO: Yes.

11 MEMBER APOSTOLAKIS: And I'm saying, so
12 then the answer to my question is, no, you are not
13 allowed to raise an issue that was settled.

14 MR. CARUSO: No. I think we don't -- you
15 know, I mean, we're not -- we don't review --

16 MEMBER BONACA: I think there is a basic
17 difference between a defect or something missing in
18 the design and something missing in the PRA that
19 reflects the design. If there is a component that was
20 supposed to be there that is not modeled in the PRA,
21 it's a flaw in the PRA and I don't see why you should
22 not be asked a question. I mean, clearly you have a
23 flaws PRA, because --

24 MEMBER APOSTOLAKIS: But that flaw is
25 present today, and we will write a letter perhaps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 saying that the PRA is okay now. So if you approved
2 it today, why are you raising the issue two years down
3 the line? That is my question.

4 MEMBER SHACK: But it depends on what
5 you're using the PRA for. I mean, the kind of
6 questions we're answering now are, you know, are they
7 going to meet the Commission's safety goals, in all
8 likelihood? You know, have they addressed severe
9 accidents in some way? Whatever application they're
10 making of the PRA at that further time may require
11 more detail and more specificity about a particular
12 system than to answer those kinds of questions.

13 MR. KRESS: Once you certify a plant, I
14 don't think you can uncertify it. So --

15 MEMBER APOSTOLAKIS: I'm not talking about
16 uncertifying it. But a PRA is not -- anyway, I
17 mean --

18 MR. WACKOWIAK: So let me make sure, since
19 we have a lot of material to cover, I think you can
20 see by the size of the package there -- and hopefully
21 it will go -- some of this will go fast, but this is
22 a fundamental question that we need to look at. And
23 I think the first part of my presentation will
24 somewhat get into that.

25 And I think by having the PRA as part of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Chapter 19 of the DCD somewhat blurs the issue that
2 we're looking at here. What this PRA is is the risk
3 assessment that is being used to say that the design
4 can be certified. It's not a risk assessment for the
5 plant forever.

6 The application here is: are we going to
7 get a design certification? And the choices and
8 modeling and detail in the PRA is chosen so that we
9 can demonstrate that we meet the Commission's numeric
10 goals, and that we can identify the set of components
11 that we would think are in -- should be monitored
12 under the DRAP program, and a few other things that
13 we'll talk about on upcoming slides.

14 But the PRA is here to support the design
15 certification application. The PRA is not the PRA
16 that the plant will use forever.

17 MEMBER SIEBER: But I think it's fair to
18 say that an applicant desiring to build a plant will
19 take this PRA --

20 MR. WACKOWIAK: Sure.

21 MEMBER SIEBER: -- and say, "This PRA
22 bounds this design. So all I have to do is go and
23 look where my design differs from the certified
24 design, modify the PRA to take that into account."
25 That's the PRA of record.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 And then, later on you can say a couple of
2 things. One of them is, "I'd like to make a change
3 under 1.174, but I'm going to redo my whole PRA and
4 take into account specific plant conditions as opposed
5 to the generic ones." And squeeze in the boundary,
6 the risk goes down, the changes you make may be
7 riskier, but it fits 1.174.

8 MR. HAMZEHEE: That's correct.

9 MEMBER SIEBER: And I think that --

10 MR. HAMZEHEE: That's a fair -- that's
11 right.

12 MEMBER SIEBER: -- the way I understand
13 the regulations, that's allowed.

14 MR. HAMZEHEE: That is a fair summary.

15 MEMBER SIEBER: And the other question is:
16 you can go the other way and say, you know, we have a
17 cutoff in risk below which you don't consider. Well,
18 there's a pretty low cutoff point from individual
19 risk.

20 On the other hand, there may be thousands
21 or millions of ways, points of entry to get there.
22 And, therefore, it adds -- even though each individual
23 piece doesn't add much to the risk, in the aggregate
24 it adds a fair amount. So I think that's another
25 thing that needs to be examined carefully at this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 point in time.

2 CHAIRMAN CORRADINI: John?

3 MEMBER STETKAR: I think, listening to
4 this discussion, it's kind of interesting because what
5 I'm hearing is everyone is discussing about how the
6 PRA, as it exists today, may be changed in the future
7 to reflect the as-built, as-operated plant design.

8 Those changes that I have been hearing are
9 all discussions with regard to changes in things that
10 are in the PRA. Is the testing frequency the same in
11 the PRA as in the actual plant? Is the real valve X
12 in the plant the same as was assumed in the PRA?
13 Those are changes to things that are in the PRA.

14 No one -- and this is after 30 years of
15 doing risk assessment and seeing people use risk
16 assessment -- no one ever looks at changes to things
17 that are not in the PRA. No one ever does that,
18 unless they add a new valve, or a new pump, and say,
19 "Well, this is a new pump. I must put it in my PRA,
20 because it was obviously never in there."

21 If something is not in the PRA today, no
22 one will ever look at a change to the thing that is
23 not in the PRA, unless somebody actually changes that
24 physical piece of equipment. I guarantee, the staff
25 will not review it, the licensee will not look at it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 and ask the question of, "Why is this not in the PRA?"
2 Well, it was not in the PRA because the people who
3 developed the PRA for the certified design decided
4 that it did not need to be in the PRA. That's good
5 enough for me; I'm the licensee.

6 I've seen this for 30 years of people
7 using PRA. Things will not change in the future.
8 That's why I'm personally very concerned about
9 completeness in this PRA as it's developed today,
10 regardless of how it will be used in the future.

11 If it is not -- if it does not contain all
12 of the equipment in the plant, if it does not contain
13 all of the initiating events that can affect the
14 plant, if it does not contain all of the types of
15 testing and maintenance that can affect the plant, no
16 one will ever go back and add those in, because none
17 of the discussion that I've heard here for the last 20
18 minute has discussed people going back and adding
19 things into the PRA that is not there, except for
20 plant-specific hardware changes.

21 MR. WACKOWIAK: And I would disagree with
22 that, not that we didn't say it, but I would disagree
23 that that's -- that's not part of the process.

24 On the bottom of the slide here, the
25 updated as-built PRA prior to fuel load, that PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 needs to -- needs to meet all of the requirements in
2 Reg. Guide 1.200, and any other -- which will then, I
3 assume, subsume all of the rest of the endorsed
4 standards.

5 So, for example, right now there is no
6 standard -- endorsed standard for fire PRA. It's in
7 the works, but it's not there. In this particular
8 application, we tried to use as much information as
9 possible from that developing standard in generating
10 our fire PRA. But we couldn't do all of it. Some of
11 it the information just isn't there, and we'll talk
12 about that a little bit later. And some of it just
13 isn't settled in the industry yet.

14 However, when that standard is endorsed,
15 and we go back to do the as-built PRA, then everything
16 that -- in that standard, whether we model it or not
17 in the DCD PRA, would have to be included in the as-
18 built as to be operated in the PRA.

19 So that's how I think the -- "controls" is
20 the wrong word for it, but that's how we ensure that
21 going forward with the new plants is not going to be
22 like the last 30 years with the PRA, that once you
23 have something, that's it, and nobody wants to change
24 it. The Commission has tied the as-built plant PRAs
25 to the standards, and then the standards, as they are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 updated, the PRAs are required to update to meet those
2 standards every four years.

3 So I think that's how we get into that.
4 And if we tried today to build a PRA based on a lot of
5 things that some of it is knowable and some of it is
6 not knowable, and convince ourselves that we have
7 covered everything, I think we'll be making a mistake.
8 We can only cover the things that we know about.

9 Now, there are some examples here that
10 we'll have to get into. We've made some decisions in
11 this PRA about how to deal with certain failure modes
12 -- failure modes for equipment that hasn't been
13 specified, hasn't been purchased, no one has looked at
14 it, we don't have an owner's manual for the equipment,
15 and we do recognize that we have to do a failure modes
16 and effects analysis on that equipment.

17 And then, for the PRA you would adjust
18 based on the types of information you would find in
19 the FMEA for that equipment. And we see that
20 happening as a continuous process as we fill in the
21 detailed design of the plant, as we set up purchase
22 specifications, as we choose vendors to pick these
23 components, and try to do this little by little along
24 the way.

25 But it's the as-built PRA that -- at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 end that conforms to the standards that says, "You've
2 got to have your failure modes and effects analysis
3 for all of the components, and you have to have --
4 address those in your PRA." So I think we get there,
5 and I think -- and I think it's different than what
6 we've seen in the past. I think that there are new
7 regulations on this that help.

8 MEMBER POWERS: Let me ask you a question
9 about that. What you said is all true, I assume, and
10 it seems reasonable to me, but what perplexes me about
11 the presentation is that, given all of those
12 assumptions, given that there is no failure modes and
13 effects, the only thing I see in the PRA presentations
14 and bottom line numbers, you never go through and say,
15 "Okay. Here I have gone through and looked at my
16 performance metrics, and this particular piece of
17 equipment for which I have not specified, has not been
18 purchased, I do not have a user's manual, and I have
19 no failure modes and effects," turns out to be very
20 critical. And yet it never gets an answer.

21 Why is that? I mean, I see it nowhere.
22 Maybe I don't recognize it, but I never see things
23 like risk achievement worse or risk reduction worse
24 for these hypothetical pieces of equipment that are so
25 critical to these minuscule numbers that show up here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on the bottom line.

2 And it seems to me that that's the piece
3 of information that I want to see now, not in the
4 future, not when the plant gets built. I want to know
5 about it now.

6 MR. WACKOWIAK: Some of those things are
7 in Chapter 11 of the PRA. There is a section on
8 sensitivities and uncertainties. We addressed the
9 failure rates of the squib valves, which are the main
10 set of critical components that we're relying on. And
11 there is discussions throughout the different system
12 chapters, and in Chapter 11, that do give the risk
13 achievement worse and Fussell-Vesely's of the
14 components that we have modeled in the PRA.

15 And then, in the discussions -- and that's
16 both for the Level 1, and then I believe we also have
17 similar tables for components with respect to the
18 large release. But I'll have to -- some of those were
19 done in response to questions and not necessarily in
20 the final document.

21 But that type of thing is addressed, it is
22 discussed, and I think what you'll find in the set --
23 in the PRA of the assumptions and insights in each of
24 the chapters that we have -- we have a set of insights
25 and key assumptions from that chapter with respect to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that particular topic -- that those types of things
2 are discussed.

3 And then, the final piece of all of that
4 is in Chapter 17 of the DCD. You know, I thought out
5 these chapters and things a lot, so you've got to kind
6 of follow me. There is -- the DRAP is in there, and
7 the DRAP points to an evaluation, an expert panel
8 evaluation, using PRA as an input of the list of the
9 risk-significant components for the -- the risk
10 significance with respect to maintaining reliability
11 that we've assumed in the middle.

12 And that set of components, which will be
13 then verified by the as-built plant PRA, is carried
14 forward and monitored in the maintenance rule. But I
15 think we've got discussions of those sorts of things
16 in the document, and Chapter 11 would be the place to
17 start.

18 MR. HAMZEHEE: Rick has a lot of stuff to
19 cover. So if you don't mind, if we can get started,
20 and hopefully at some point we'll know more about what
21 he has done and we can ask more questions.

22 MEMBER STETKAR: Rick, before you start,
23 let me just ask you point blank -- I just want a yes
24 or no here. You mentioned the standards before.
25 Would you characterize the ESBWR PRA as its exists now

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 -- Level 1, internal event only -- Level 1, internal
2 event only -- as consistent with the standards in Reg
3 Guide 1.200?

4 MR. WACKOWIAK: Yes.

5 MEMBER STETKAR: Thank you. That helps.

6 MR. WACKOWIAK: Okay. So I think most of
7 the things on here we've already covered in one way or
8 another, but I want to make one last point on the
9 middle bullet there. The design PRA provides a
10 bounding assessment, provides the safety case for the
11 plant license.

12 If we consider this as a risk-informed
13 application, this PRA is helping us decide, does the
14 plant meet the safety goals? And there is other
15 details and things that are in there. We talk about
16 small numbers. Okay. Maybe the numbers are small,
17 but there are other things that we don't cover in the
18 PRA. You know, where it talks about the dinosaur-
19 killing meteor, those kinds of things, we don't have
20 those kinds of things in the PRA.

21 The things that historically have been
22 excluded, because they were low-level risk, we didn't
23 remodel those big common events to show that they are
24 still low risk. They're assumed to be the same as
25 existing plants for the most part.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What we did do is we tried to take our
2 events that are -- that do have high risk or
3 measurable risk in existing plants, and address,
4 through design, the features of the plant that we
5 would need to make those risks at about the same level
6 as the things that have always been historically
7 excluded as being acceptable risk.

8 So that's what we're trying to do. We're
9 trying to -- we're not trying to say this is the
10 number. We're trying to say that the things that have
11 historically been -- contributed to risk at nuclear
12 powerplants for this design should be on par with
13 things that are considered acceptable risk for having
14 a nuclear powerplant.

15 MEMBER STETKAR: Are you saying that you
16 believe that the actual core damage frequency, then --
17 the real core damage frequency -- is lower than the
18 estimate in the current PRA? Or could it be
19 substantially higher?

20 MR. WACKOWIAK: What I was trying to say
21 is that if the risk due to a -- well, let's come up
22 with one of these hypothetical scenarios. Currently,
23 nobody models a moderate meteor hitting the Atlantic
24 Ocean and causing a tsunami and wiping out the eastern
25 seaboard. Okay? That ESBWR probably would not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 survive that.

2 MEMBER STETKAR: Currently, people do
3 model seismic events, though, and you don't.

4 MR. WACKOWIAK: And there's a reason for
5 that. We can get into that later. But for that
6 particular piece, we don't model that. That's
7 considered an acceptable risk or else we wouldn't have
8 nuclear powerplants on the coast, and we don't change
9 that.

10 Now, for the things that you're talking
11 about here when we do have a seismic PRA standard and
12 it's implementable -- right now, the plant is on
13 paper. We can't go and walk it down. We can't -- we
14 can't tell how the thing was installed. We would be
15 guessing at anything for seismic risk at this point in
16 time.

17 MEMBER STETKAR: But you do have HCLPF
18 capacities, though, for all of the safety-related
19 equipment, and actual fragility curves for several of
20 the safety-related structures that seem to be derived
21 from fairly detailed analyses.

22 MR. WACKOWIAK: Yes. We --

23 MEMBER STETKAR: And we have experience
24 from doing seismic fragility analysis for a large
25 number of components and structures, and have general

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ratios of median capacities to HCLPF capacities, and
2 we have generic seismic hazard curves. So it's pretty
3 easy to actually try to quantify some -- perhaps an
4 upper bound, but some upper bound to the seismic risk.
5 It takes about, oh, 20 minutes.

6 Could be about a factor of 30 times higher
7 than the total core damage frequency from everything
8 else, if I did my 20-minute calculation correctly.
9 And yet it's not -- and I probably didn't do it
10 correctly, and it's probably a bit conservative. But
11 it could be several times higher than everything else
12 combined, and that might change a lot of your insights
13 about relative importance of various systems, various
14 design features, in the plant, because in fact a lot
15 of those decisions are based on those numbers, aren't
16 they?

17 MR. WACKOWIAK: They're based on some of
18 those numbers.

19 MEMBER STETKAR: Okay.

20 CHAIRMAN CORRADINI: Why don't you
21 continue.

22 MR. WACKOWIAK: Okay. I'll try to go
23 through the up-front stuff a little quicker now, so we
24 can get to the open items. One of the things that I
25 was trying to say here is that, like we've been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 talking about through this -- we were talking about
2 the design of the plant, some of the choices that we
3 made in the PRA were to not rely too much on human
4 actions.

5 That's the procedures column. And not --
6 and to use generic data based on historical equipment
7 performance, similar type equipment performance,
8 because now we're focusing on what choices are made in
9 the design, and we think we can make changes to the
10 plant that influence risk more by changing design.

11 And then, later, as the design is frozen
12 and actually built, and it's more than frozen at that
13 time -- cast in concrete -- we can look at things,
14 improving practices through procedures, and other
15 things in the man-machine interface, and improve
16 things with maintenance programs and things like that.

17 Our purpose here was to eliminate the
18 severe accident vulnerabilities that we had recognized
19 in the -- from the existing plants. We use a
20 systematic process for finding these things through
21 our PRA. We integrate the PRA into the entire design
22 process. We are -- as we go through the design
23 process, we make corrections to the design.

24 One of the things I mentioned in the
25 beginning was that the PRA results really didn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 change very much, even though when you look at the
2 list of things that changed from DCD Rev 4 to Rev 5
3 there are some fairly large things there that were in
4 there to address containment branch issues and other
5 things.

6 And in the end, the things that were in
7 there didn't affect the PRA as much, because we were
8 using the PRA to help guide how those different
9 changes were implemented. And it fit within the
10 envelope that we already had. It did not introduce
11 any new failure modes, and that sort of thing.

12 Once again, we used both quantitative and
13 qualitative PRA tools. A lot of -- we talk a lot
14 about the numbers, but the qualitative is also
15 important when you are working with a design and
16 something that isn't built yet.

17 And as I think we have said before, with
18 most of the people that are on this Committee, we have
19 a philosophy for our qualitative design that, where we
20 have a function, it's served by passive systems, and
21 then we apply active systems, one or more active
22 systems as a backup to that, and then we use diverse
23 support systems for all.

24 And what we find is, when we're coming up
25 with a conceptual design, as long as we follow this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sort of concept, we end up getting the numerical
2 results that we want in the end. So before we even
3 start designing something, if we look at it this way,
4 we are pretty sure that we're going to get to where we
5 want to be.

6 MEMBER APOSTOLAKIS: Can you give me an
7 example of a support system or a passive system?

8 MR. WACKOWIAK: Yes. You have to remember
9 that, through the evolution of these passive designs,
10 passive is -- passive things still move, and so our
11 squib valves are considered passive -- legislatively
12 passive, if you will -- because they are powered by
13 stored energy in the chemical charge in the squib and
14 then in the batteries that ignite that.

15 So the support system there would be the
16 DC power to ignite the squib charge. And so for
17 support and diverse support, we have our safety-
18 related DC power system that performs that function,
19 and then we also have a non-safety related system on
20 a different platform that also backs that up.

21 MEMBER SIEBER: Let me ask this question.
22 During ordinary operation, the operator in the control
23 room, if he is presented with the symptoms of an
24 accident in a plant, would first rely on active
25 systems -- diesel generators, pumps, valves, and so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 forth. To what extent do you take that into account
2 in your PRA analysis? And since these are categorized
3 as non-safety systems -- and, therefore, don't have
4 the controls that 1(a) systems have, nor the tech
5 specs -- how do you ensure that -- how do you
6 calculate the failure rate?

7 MR. WACKOWIAK: The way that the -- that
8 we're set up in the PRA is that some of these systems
9 are -- some of the active systems are automatic, and
10 some are not. Okay? We have reviewed -- for the ones
11 that are automatic, we have reviewed the importance of
12 the systems that are used to actuate those, and for
13 the important ones they make it into things like
14 either the tech specs -- once again, we'll talk about
15 some of our non-safety equipment. I think this
16 afternoon in RTNSS we'll talk about some of the non-
17 safety equipment that made it into tech specs.

18 We also have an availability controls
19 manual that addresses things that are important for
20 RTNSS, important to meeting the PRA's goals, but not
21 necessarily meet the threshold for tech specs. And
22 then, as I mentioned before, the DRAP, which folds
23 into the maintenance rule, covers most of the other
24 things.

25 I think as somebody mentioned here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 earlier, that it's real easy to get a lot of things to
2 be able to effect a number that is fairly small. And
3 so there are a lot of equipment that are going to be
4 monitored for availability and reliability in the
5 maintenance rule that address some of those things.

6 The other thing in the man-machine
7 interface that we are working with the human factors
8 engineers now is we find it important that when the
9 operators start to do something with the active
10 systems, that running those active systems doesn't
11 actually do something to disable the passive systems.

12 We've gone through and for the systems
13 that we have now, we have looked at -- and there's an
14 updated section in the new PRA of a systematic search
15 for adverse system interactions. If you turn this
16 system on, will it do anything to the passive systems?
17 Will it cause them to not function? And that
18 information is either being addressed through design
19 or it's being addressed through passing that
20 information back to the people who are developing the
21 emergency operating procedures and severe accident
22 procedures.

23 And we have had some examples I think that
24 we've talked about for those in the past, following
25 some sort of a -- now this is after a LOCA-type

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accident, if you will, the decision whether or not to
2 reduce pressure in the containment through using a
3 containment spray. That's something that they have to
4 really think about doing when you get into that
5 scenario, because the passive system relies on the
6 steam in the drywell to replenish the GDCS pools to
7 keep injection going into the core.

8 And if you use spray to knock down the
9 steam, you may lose injection. So you have -- the
10 procedures have to be crafted carefully that says,
11 "Before you spray, make sure you have an active
12 injection source." So those are the kinds of things
13 we look at, and we either address them through design
14 with interlocks and other things or we feed it back
15 into the human factors evaluation to make sure that
16 the procedures adequately reflect those.

17 So now, how do we get to that in the PRA
18 numbers? Some of those things we -- we didn't try to
19 model the operators going and actuating all of the
20 active systems possible to prevent the passive systems
21 from coming on. If there is a specific action that is
22 like the automatic high-pressure CRD pump is supposed
23 to come on, we might model an operator action to back
24 up that automatic action.

25 Or, in the case where we have a low

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pressure injection system, we would say, yes, the
2 operators will use -- will line up and use the low
3 pressure injection system from the suppression pool
4 into the reactor vessel. But there is only a handful
5 of those actions in the -- and any sort of other
6 things would be addressed in the adverse system
7 interaction.

8 MEMBER BLEY: Rick, where in the -- I
9 thought you said it was in the PRA. Where in the PRA
10 document do you describe this examination where you
11 look through all of those things and identify the
12 potential problems?

13 MR. WACKOWIAK: It wasn't -- that was one
14 of the open items that we had is it wasn't there
15 before. It was only in our internal documentation,
16 and now that's in 19(a) of --

17 MEMBER BLEY: 19(a).

18 MR. WACKOWIAK: That's right.

19 MEMBER BLEY: That's the one that has just
20 been released --

21 MR. WACKOWIAK: The one that has just been
22 released.

23 MEMBER BLEY: -- that we haven't seen
24 that.

25 MR. WACKOWIAK: Yes, that was -- in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 past, that was one of our open issues.

2 MEMBER BLEY: Related question, and you'll
3 get to initiating events somewhere here, but in your
4 initiating event discussion, you talk about lifting
5 them from essentially previous PRAs, and also by doing
6 something like a failure modes and effects analysis to
7 uphold the systems.

8 I didn't see any detailed look at how you
9 did that analysis through all of the systems. Where
10 is that in the PRA?

11 MR. WACKOWIAK: The screen of the systems
12 for initiating events.

13 MR. MILLER: That is in 19(a) as well,
14 yes.

15 MEMBER BLEY: So that wasn't in the one we
16 have looked at. But it is in the new one.

17 MR. MILLER: That has not changed in 19 --

18 MEMBER BLEY: It's in 19(a)?

19 MR. MILLER: It was in the text.

20 MEMBER BLEY: It's a text.

21 MEMBER STETKAR: There's kind of a
22 paragraph per system, and I don't remember the --

23 MEMBER BLEY: Oh, I saw that.

24 MEMBER STETKAR: -- the section.

25 MEMBER BLEY: But that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's not a
2 systematic --

3 MEMBER BLEY: What I'm looking for is
4 something -- that the impression I got from the
5 introduction was a systematic look, system by system.
6 We looked at each part of this system, and, you know,
7 here's what it could affect and here's how it could
8 lead to an initiator. So that is not in the PRA.

9 MR. WACKOWIAK: What you are looking for
10 I think requires more information about the actual
11 components in the system, and how the control systems
12 would respond to different upset conditions. What
13 we've assumed for right now, for those things, is that
14 a feedwater control system, feedwater heating system
15 for example, will probably behave like existing
16 feedwater heating systems, maybe better, maybe not,
17 but it would be subsumed into the historical loss of
18 feedwater.

19 MEMBER BLEY: All I saw was like a
20 paragraph that said, "Here is the things that might be
21 troublesome, but nothing that indicated how you had
22 gone through in a systematic way.

23 MR. WACKOWIAK: Okay.

24 MR. MILLER: Well, we did assess -- we did
25 ask a question of, you know, its relative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significance. The initiator itself -- was it
2 significant to the overall CDF, for example? Was this
3 failure mode a significant contributor? So we did
4 systematically go through and ask those questions.

5 MEMBER STETKAR: How do you know how
6 significant it is, if you haven't actually quantified
7 it in the PRA, a priori, given the very small numbers?
8 I've been doing this for 30 years, and I've always
9 been wrong when I tried to guess like that. I'm still
10 wrong.

11 MR. WACKOWIAK: The ones that we looked at
12 through that process were the ones that were modeled
13 in the PRA.

14 MEMBER STETKAR: Okay.

15 MR. WACKOWIAK: So your question from
16 before -- if it's not modeled --

17 MEMBER STETKAR: You don't know.

18 MR. WACKOWIAK: -- we would have had to
19 use some sort of a judgment to decide. And when we
20 used that judgment, that was when we were creating the
21 list of initiating events.

22 Okay. Is there any interest in going
23 through the features? I think everybody --

24 MEMBER STETKAR: Yes.

25 MR. WACKOWIAK: -- here has -- Yes. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: I have a question. On
2 the outlet of the GDCS pool, there is a normally open
3 manual valve. This drawing does not show that valve.
4 The PRA does not contain that valve. If that valve is
5 closed, it will disable the respective GDCS pool for
6 both short-term vessel injection and for containment
7 deluge. That could be quite interesting for the
8 combined pools B and C, because it will disable six
9 deluge valves and four injection paths.

10 The valve is not modeled in the PRA. If
11 you model it with a 10-year test interval, as it is
12 according to the tech specs, it will increase the
13 unavailability of each GDCS pool by a factor of 136
14 times higher than what is currently modeled in the
15 PRA. Why is that valve not modeled in the PRA?

16 MR. WACKOWIAK: That valve was initially
17 put into our screening model. And when we identified
18 it as an important valve, we provided to the HFE group
19 a requirement that that valve be instrumented, and
20 that there be procedural checklists in place with a
21 double signoff coming out of the outage for it.

22 And I'm trying to think -- there's one
23 other -- oh, yes. It's not only instrumented by
24 alarmed in the control room if it's in the wrong
25 position.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's if the valve stem
2 is in the wrong position.

3 MR. WACKOWIAK: That's correct.

4 MEMBER STETKAR: It doesn't tell you a
5 thing about the internals of the valve, does it?

6 MR. WACKOWIAK: That's correct. And our
7 thinking -- so that was -- when we got through those
8 three, that's how that manual valve screened. And in
9 looking at that, we also recognized that our check
10 valve data for those lines, which performs the same
11 function, we increase --

12 MEMBER STETKAR: No, it doesn't. If that
13 valve is closed, no water goes out of the tank. The
14 check valve prevents water from the vessel going back
15 to the tank. This prevents water going out of the
16 tank, if it's closed.

17 MEMBER APOSTOLAKIS: Can you show us where
18 the valve is? You can use a cursor maybe. I don't
19 know. It's over there.

20 MR. WACKOWIAK: Right here.

21 MEMBER APOSTOLAKIS: Okay.

22 MR. WACKOWIAK: Right under the word "GDCS
23 injection line."

24 MEMBER APOSTOLAKIS: Okay. Yes.

25 CHAIRMAN CORRADINI: Are you finished with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 your explanation? I guess I want to hear this one
2 completely through before we --

3 MR. WACKOWIAK: Yes.

4 CHAIRMAN CORRADINI: -- come after you.

5 MR. WACKOWIAK: So in our model, we model
6 the check valve. We model the check valve as needing
7 to open, as well as needing to prevent backflow.

8 MEMBER STETKAR: Be careful. You did not
9 model the check valve as needing to open. You modeled
10 the check valve failure to stay open.

11 MR. WACKOWIAK: Okay.

12 MEMBER STETKAR: You assumed it's normally
13 open. You did not model a check valve needing to
14 open.

15 MR. WACKOWIAK: Okay.

16 MEMBER STETKAR: Keep going. By the way,
17 this 136 is used in your own data for the failure
18 rates.

19 CHAIRMAN CORRADINI: Are you finished
20 explaining? Because I don't know if you are.

21 MR. WACKOWIAK: Well, where I was trying
22 to get to with that is we thought that the similar
23 components that had a similar function, in terms of
24 getting the water from the GDCS pool into the reactor,
25 including the check valve -- we'll look at the failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mode that was there, failed to remain open -- and the
2 squib valve, that those together provide a reasonable
3 probability for getting the -- for addressing that
4 particular failure mode.

5 Now, I understand that this manual valve
6 also addresses -- affects the BiMAC, and so we'll have
7 to go and look at that.

8 CHAIRMAN CORRADINI: Can I just rephrase
9 your answer? Because I want to make sure -- since I'm
10 not a PRA guy, and you guys -- the right hand of this
11 table is hot this whole day, urge -- charged up. So
12 are you saying that you didn't model it because the
13 failure probabilities of the two downstream valves
14 were large enough that they washed out even --

15 MR. WACKOWIAK: No.

16 CHAIRMAN CORRADINI: So what are you
17 saying?

18 MR. WACKOWIAK: What we said was initially
19 we modeled it. We identified it as important. So we
20 moved -- we added controls onto the valve -- the
21 indication, the alarms, and the procedures. And once
22 we got to all three of those things -- the indication,
23 the alarm, and the procedures -- the process that we
24 used says that that failure mode is a low enough
25 probability --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay.

2 MR. WACKOWIAK: -- because all we're not
3 covering is the stem separating from the disk. We are
4 not covering that particular failure mode.

5 MEMBER BLEY: That one does happen in the
6 real world, though.

7 MR. WACKOWIAK: Yes.

8 MEMBER BLEY: Often enough to be
9 troublesome.

10 MEMBER STETKAR: And the failure rate that
11 you use -- three times 10^{-8} -- is indeed derived from
12 data or observed events, exactly those types of
13 observed events. That failure rate is in the PRA
14 database for spurious closure of manual valves.

15 MEMBER ABDEL-KHALIK: Are there any cases
16 in which check valves are installed backwards?

17 MEMBER STETKAR: Now you would know this.

18 (Laughter.)

19 MR. WACKOWIAK: I am sure it can happen.
20 Now, one of --

21 MEMBER ABDEL-KHALIK: So let me just
22 continue, then. What happens if the check valve,
23 between the GDCS and the squib valve, is actually
24 installed backwards?

25 MR. WACKOWIAK: GDCS won't work.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Not just that.

2 MR. WACKOWIAK: Not just that?

3 MEMBER ABDEL-KHALIK: Right. Because it
4 would allow water from the vessel, then, to move in
5 the opposite direction. And if it's moving at a high
6 enough pressure, it would actually eject the water out
7 of the GDCS pool.

8 MR. WACKOWIAK: The ITAAC for GDCS is a
9 flow test into an open vessel from the GDCS pool into
10 the reactor. So that test will verify that the check
11 valve is installed properly before fuel load. There's
12 an ITAAC for performing -- for draining the vessel
13 through the GDCS -- or draining the GDCS pools through
14 lines into vessel, with an open vessel low pressure
15 test, and then from -- the data from that test you'd
16 back calculate the line losses for those GDCS lines
17 and demonstrate that they're within the values used in
18 the TRACG analysis.

19 MEMBER ABDEL-KHALIK: And that would be
20 done without the squib valves in place, or what?

21 MR. WACKOWIAK: Oh, let's see. The
22 startup test guys told me how they thought they were
23 going to do that. I think they -- I think they're
24 going to put in the line a different -- I think
25 they're going to put in something in the location

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 where the squib valve is that's equivalent to the open
2 squib valve for when they perform that test, because
3 I don't think they're going to actually actuate squib
4 valves here in the plant during that test.

5 MEMBER ABDEL-KHALIK: I mean, normally,
6 the isolation is done by the squib valves. Those --

7 MR. WACKOWIAK: Right.

8 MEMBER ABDEL-KHALIK: -- check valves
9 don't perform any function during normal operation.

10 MR. WACKOWIAK: Right. But they still --
11 we still have to test that the line is open before we
12 put fuel in the reactor vessel, and that -- we also
13 check that the check valve --

14 MEMBER ABDEL-KHALIK: But in order for
15 that to happen --

16 MR. WACKOWIAK: -- is installed properly.

17 MEMBER ABDEL-KHALIK: -- you can't do that
18 with the squib valve in place.

19 MR. WACKOWIAK: The squib valve would have
20 to be opened in order to perform that test. Removed
21 or some other surrogate valve would be put into place,
22 so that valve would be open, so that it would drain to
23 the vessel. So we would check the check valve during
24 that test.

25 Now, the squib valve itself -- can the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 squib valve be installed backward and not perform when
2 they reinstall -- when they put that one back in? I
3 don't see how the design concepts that we have been
4 using will be susceptible to that sort of failure
5 mode. But the check valve will be checked with flow
6 through the check valve.

7 MEMBER ABDEL-KHALIK: Thank you.

8 MEMBER MAYNARD: Current plants typically
9 have requirements for surveillance on leak check of
10 check valves for lines coming off the RCS. Would this
11 plant most likely have a similar surveillance
12 requirement on the leak tightness of the check valve?
13 I know that current plants do.

14 MR. WACKOWIAK: I don't know the answer to
15 that question.

16 MEMBER BLEY: The problem is, this check
17 valve is normally open.

18 MEMBER STETKAR: Right. It isn't -- it's
19 normally biased open.

20 MEMBER MAYNARD: I understand that. And
21 some other check valves are, too. But typically check
22 valves coming off the RCS are required periodically to
23 have a surveillance to make sure that they are --

24 MEMBER STETKAR: I thought I read
25 something in there that said that there was some type

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of test line to verify operability of that check
2 valve.

3 MR. WACKOWIAK: There may be. I just
4 don't know the answer to that.

5 MEMBER STETKAR: The reverse flow
6 direction.

7 MR. WACKOWIAK: So noted that we -- that
8 one particular failure mode of that valve is probably
9 not covered in the PRA.

10 Okay. I think we've talked about most of
11 these things here already. But the PRA, we did do
12 Level 1, 2, and 3, covered internal and major external
13 events, covered full power and shutdown. We do do a
14 seismic margins analysis rather than a seismic PRA.
15 I've covered just about everything there.

16 What's new since we talked last time is
17 the systematic search for modeling uncertainties. We
18 underwent a process where all of our engineers got
19 into an expert panel mode and went through the models
20 gate by gate, and wrote down everything they needed to
21 know to make that logic work the way it was. And
22 we've got documentation for that.

23 And then, from that -- did the flow chart
24 make it into the documentation?

25 MR. MILLER: In the NEDO.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: In the NEDO? So then we
2 took all of those -- all of those evaluations and took
3 all of the assumptions and went through a process to
4 determine if it was a key assumption with respect to
5 meeting the safety goals. And so that process is in
6 there.

7 MEMBER APOSTOLAKIS: Can we talk about it
8 later? Or is this it?

9 PARTICIPANT: This is it.

10 MR. WACKOWIAK: Yes. This is it for right
11 now, because it's in the new material.

12 MEMBER BLEY: Let me understand a little
13 better. You went through your models, your fault tree
14 models, to identify --

15 MR. WACKOWIAK: And event tree models,
16 yes.

17 MEMBER BLEY: And event tree models. Did
18 you ever do something similar but up at the higher
19 level of the actual -- I guess it works through here.
20 I'm okay. This is in the new stuff, so we'll see
21 that. And you were looking for anything that could
22 affect the performance.

23 MR. WACKOWIAK: Right. What we are --
24 what we recognized here, since we talked last -- how
25 many years ago that was now --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: Almost two.

2 MR. WACKOWIAK: -- that when -- in PRAs
3 when we talk about assumptions, people list their --
4 we say, "List your assumptions," and they'll list 10
5 things, or, you know, there is some list of
6 assumptions. And it's just like Dr. Apostolakis was
7 saying earlier today. This is not a plant that is
8 built. It is on paper. And everything is an
9 assumption.

10 So if we are going to be comprehensive at
11 looking at all of our assumptions, we really needed to
12 go back through and look at everything that we put
13 down. Everything in the model right now is an
14 assumption, and it would need to be verified.

15 MEMBER BLEY: When you did this process,
16 which is a process I was disappointed I didn't see
17 before, and I'm happy to hear that you've done it, did
18 you also ask, what are all of the things that could
19 defeat this system, including things operators could
20 do? You know, in your HRA analysis, there is a
21 statement that, gee, in any plant with good --
22 essentially good procedures, errors of commission are
23 negligible.

24 Well, in a plant that is highly passive,
25 there might be some things people could do for reasons

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you didn't quite think of that would be important.
2 Did you ask that question as you went through all of
3 these functional issues?

4 MR. MILLER: I think we asked that a
5 little bit in the adverse systems interaction that
6 Rick talked about earlier.

7 MEMBER BLEY: Is that documented in the
8 new PRA?

9 MR. MILLER: The discussion of a
10 consideration of operator actions is documented in
11 19(a).

12 MEMBER BLEY: Okay. I'm looking forward
13 to seeing it.

14 MR. WACKOWIAK: And the kind of things
15 that we went through in this was you'd have a gate in
16 the model, and it's okay to say, "What do I need to
17 know? You know, why are the different things in
18 here?" Work those things out.

19 We also asked everyone to go through and
20 say, "Describe the things that you've excluded from
21 that gate," so we have both -- we're including and
22 excluding --

23 MEMBER BLEY: And you've documented that?

24 MR. WACKOWIAK: That's documented.

25 MEMBER BLEY: Okay. Good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: So this -- it would be
2 interesting to go back and see that particular
3 question about the valve --

4 MEMBER BLEY: That valve, yes.

5 MR. WACKOWIAK: -- the stem separation.
6 I'm pretty sure that they use the criteria that I
7 mentioned, though, to say why --

8 MEMBER STETKAR: But if it's documented,
9 it would help an awful lot.

10 MR. WACKOWIAK: Yes.

11 MEMBER APOSTOLAKIS: So we are going to
12 see these when, Hossein? With the NUREG?

13 MS. CUBBAGE: The extra CD should arrive
14 today by FedEx, so I'll try to get those --

15 MEMBER APOSTOLAKIS: Oh, to you.

16 MS. CUBBAGE: To me, yes.

17 MEMBER APOSTOLAKIS: Okay.

18 MS. CUBBAGE: And I'll get --

19 CHAIRMAN CORRADINI: It first has to go to
20 her.

21 MS. CUBBAGE: I physically have it, but I
22 just got it yesterday.

23 MEMBER APOSTOLAKIS: Will the Committee
24 have an opportunity to express a view?

25 CHAIRMAN CORRADINI: Sure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: When?

2 CHAIRMAN CORRADINI: Well, first we have
3 to get it. But --

4 (Laughter.)

5 -- I would say it's going to be a while.

6 MEMBER BLEY: I think that's the stuff of
7 the whole meeting. I mean, that's crucial
8 information.

9 CHAIRMAN CORRADINI: I would say -- I
10 would -- can I reverse it? I don't think -- I don't
11 sense that the right-hand side of the table is going
12 to be feeling ready to write a letter until we review
13 it.

14 MEMBER APOSTOLAKIS: That was my next
15 question.

16 CHAIRMAN CORRADINI: Yes. That's what --

17 MEMBER APOSTOLAKIS: Are we --

18 CHAIRMAN CORRADINI: I'm just trying to
19 jump a couple steps.

20 MEMBER APOSTOLAKIS: Okay.

21 MR. WACKOWIAK: And then, just to go on
22 with this, there was a question that had come up about
23 the PRA quality. I think it's listed as one of the
24 open items that Hossein is going to present as being
25 resolved at this point. But we did an internal self-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 assessment against the ASME-2005, and provided
2 information to the staff on the results of our review.

3 We are also providing some feedback to the
4 ASME Committee for when they write their update to the
5 standards, so that it can be used for new plants or
6 plant designs rather than existing plants. There are
7 some things that they need to consider, so we'll be
8 folding that back in.

9 MEMBER BLEY: As you did that, did you
10 identify things that were not in the current standard
11 that ought to be for highly passive systems?

12 MR. MILLER: I think the problem we had
13 was there are a lot of things in the standard that are
14 for operating plants versus a design plant.
15 Obviously, things like walkdowns we can't do. As far
16 as passive versus active, since these were looked at
17 on a functional level, I can't recall any differences
18 that we had.

19 MR. WACKOWIAK: I do have one thing that
20 I'm not really sure how to present it to the
21 Committee, to the ASME Committee. When you're doing
22 a review of a passive equipment, the best estimate
23 valves or best estimate calculations may not always be
24 the right way to evaluate those things.

25 In many cases, bounding assessments are --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 give you more information than trying to come up with
2 a best estimate for something passive. I think the
3 uncertainties there are just probably too large. So
4 something that would fall into a capability
5 Category 1, or maybe barely make 2, because of -- we
6 didn't -- we used a bounding value rather than a best
7 estimate, I think that needs to be rethought for
8 passive plants. I think there are some cases, like in
9 the Level 2 area -- I believe the way that we address
10 Level 2 using the ROLL methodology, and doing bounding
11 assessments, is the right way to address the passive
12 containment rather than the multi-million node
13 containment event tree that would tend to dilute the
14 contribution of certain phenomena.

15 So that's my opinion. I'm not sure how to
16 write that up and send it yet, because it's a change
17 in philosophy from what they have. But that's
18 something that we also learned.

19 We've -- and I'm sorry you walked out,
20 because it was the first time I actually put the mean
21 on the slide instead of just a point estimate.

22 (Laughter.)

23 But the idea here to show -- and we've
24 talked about this before -- what we tried to do is to
25 make -- a low number was not necessarily the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 objective. We tried to address balanced risk profile,
2 and it just so happens that when you try to address
3 outliers on many things, the overall number continues
4 to go down for these particular events.

5 So what we were really trying to get at
6 was coverage for most types of upsets in the plant,
7 and I think we've achieved that. There is isn't any
8 one thing that really causes problems, and that's
9 basically going back to that same philosophy that if
10 you have a combination of passive and diverse active
11 systems, we can get pretty good coverage.

12 Now, the question comes back: can we use
13 this in a seismic assessment later? We've got a lot
14 of things covered here, and what we need to do is see
15 how we would use some of the protections built into
16 the different scenarios. By that I mean things -- in
17 a seismic PRA assessment, we wouldn't just use the
18 safety-related equipment. We would want to look at
19 the capabilities of some of the non-safety equipment.

20 So your assessment is right. If you just
21 do the numbers for the seismic -- for the safety-
22 related equipment for seismic, you are likely to get
23 a very big number. But I think some of these other
24 pieces of equipment that are non-safety related do
25 have some seismic capability, and we should be able to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mitigate that.

2 MEMBER STETKAR: For the record, I'm not
3 saying a very big number, in terms of the safety goal
4 or anything like that --

5 MR. WACKOWIAK: Right.

6 MEMBER STETKAR: -- it's a much larger
7 number than the numbers that we see on the screen
8 there.

9 MR. WACKOWIAK: Right.

10 MEMBER STETKAR: But not -- just for the
11 record, I'm not implying that the seismic risk is
12 large compared to the safety goal. But it could be
13 substantially larger than what we see there.

14 MR. WACKOWIAK: Larger than this. But,
15 once again, it's only considering the safety-related
16 equipment.

17 MEMBER STETKAR: That's true, although
18 most of the non-safety related equipment usually is
19 designed to equal to or less than lower seismic
20 capacities than safety-related equipment. So --

21 MR. WACKOWIAK: Some of it is. When we
22 talk about RTNSS, we'll talk about which set of
23 equipment is designed to the same --

24 MEMBER STETKAR: Regarding this slide,
25 Rick, just out of curiosity, an unusual situation is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that the mean, since you said you finally put it on a
2 slide, is slightly lower than the point estimate.
3 That almost never happens. Do you know why it
4 happened here?

5 MR. WACKOWIAK: I think that it's another
6 artifact of the number being small, and that the mean
7 and the point estimate are just right near each other
8 and small variations --

9 MEMBER STETKAR: Usually the things like
10 correlated uncertainties and -- the state of knowledge
11 uncertainty in your data will tend to, if nothing
12 else, push the mean value from the uncertainty
13 distribution higher than that point estimate value, if
14 nothing else.

15 MR. WACKOWIAK: And I would say that one
16 of our issues from the review against the standard is
17 that on common cause failures our state of knowledge
18 is somewhat limited by the code that we used. So it
19 probably -- when we're working on addressing that,
20 that may change somewhat, and the mean may come up
21 slightly over the point estimate when we address that
22 in the way that our uncertainty software addresses the
23 correlation of common cause failures. We understood
24 that.

25 MEMBER BLEY: Rick, a related question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If these results include that look you guys did
2 through all of the uncertainties and success criteria
3 and phenomena, I would have expected that to yield
4 some broader uncertainties that would have pushed the
5 mean higher than your point estimate. Did anything
6 come out in that direction? Are those uncertainties
7 factored into this result?

8 MR. WACKOWIAK: They are not factored into
9 this result. In Chapter 11, we have an extensive set
10 of uncertainty and -- of sensitivity analyses that we
11 looked at with respect to those specific items.

12 MEMBER BLEY: And that's where we'll see
13 it.

14 MR. WACKOWIAK: And that's where you'd see
15 that. There are --

16 MEMBER BLEY: So this is just the basic --

17 MR. WACKOWIAK: This is just the basic
18 model.

19 We have a chart in there that just gives
20 you a sense of what all of the different things are.
21 You know, once again, the pie chart is -- historically
22 represents just the Level 1 internal events. You can
23 get an idea of where we are with the different types
24 of events. All are around the same order of
25 magnitude. Once again, though, all of them include

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different -- varying levels of uncertainties.

2 For example, in the fire, even though in
3 the full-power CDF the fire looks like it's about the
4 same as the internal events, in the shutdown it is
5 higher than the internal events. We have to remember
6 that we didn't do any fire modeling to address the
7 spread of fires, and we didn't do any fire
8 suppression. So those numbers really are -- they're
9 not on the same level of modeling detail.

10 CHAIRMAN CORRADINI: So the shutdown
11 numbers are upper bounds, then.

12 MR. WACKOWIAK: The fire numbers we
13 believe are upper bounds.

14 CHAIRMAN CORRADINI: I'm sorry. Yes.

15 MR. WACKOWIAK: The internal events
16 shutdown, we think that with the exception of one open
17 item that's still in play, we think that that's
18 probably a pretty close number for the internal events
19 shutdown.

20 MEMBER POWERS: Do you think the fire is
21 an upper bound because you didn't model suppression,
22 but on the other hand you didn't model spread either?

23 MR. WACKOWIAK: We assume that every fire
24 spreads to its maximum capability.

25 MEMBER POWERS: In just the fire area?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WACKOWIAK: We considered failure of
2 fire barriers to -- for it to propagate into the
3 adjacent area, and then spread to completely fill the
4 adjacent area.

5 MEMBER POWERS: So the adjacent areas were
6 spread into?

7 MR. WACKOWIAK: Yes, following the failure
8 of a fire barrier. And one of our insights from the
9 shutdown PRA is that fire barriers need to be
10 controlled during outages.

11 MEMBER POWERS: That's a good insight.

12 MR. WACKOWIAK: Well, there's talk about
13 whether or not you -- you know, would that be a
14 requirement in --

15 MEMBER POWERS: Most of them are open.

16 MEMBER APOSTOLAKIS: Let me ask you, Rick,
17 some -- a sort of philosophical question.

18 MR. WACKOWIAK: Oh, good. I like those.

19 MEMBER APOSTOLAKIS: If you go back to the
20 '70s, and you look at various studies that were done
21 in the first PRA topical meeting in Newport Beach, the
22 numbers one sees for -- under vulnerability of safety
23 systems were typically 10^{-6} . And then, as we learned
24 more, collected experience, and so on, the numbers
25 have shifted up by about two orders of magnitude

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 roughly. Now, it depends on the event tree, but
2 roughly it's about 10^{-4} .

3 So we were very optimistic, and then the
4 numbers became more -- now, this 10^{-11} and 10^{-10} , do you
5 think that these numbers will shift up a little bit,
6 still meeting the goals of the Commission? I think
7 they will. I don't know how, but they will.

8 MR. WACKOWIAK: Some of these numbers may
9 shift some. Now, we are doing some things differently
10 than were done back then, because we are using the PRA
11 throughout the design process. So when we start
12 selecting components, and, you know, part of the --
13 not only part of the DRAP, but as part of the GE
14 design process, as we go and select components and
15 determine ways to install those components, we're
16 going to be looking at it with respect to this.

17 So it's not -- it's not just the numbers
18 are done here, they're good, and when you build this
19 plant everything is going to come out okay. We have
20 to take, you know, some looks at that along the way.
21 There have been examples through the last year, year
22 and a half, where something that looked like a
23 perfectly good configuration change from the
24 designer's point of view, when it got to the PRA
25 signoff we had to go back and say, "This is not the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 right way to look at this. We have to come up with a
2 different way of implementing what it is you are
3 looking for, because we may affect some of these
4 values."

5 Now, do we have to have a 10^{-8} CDF?

6 MEMBER APOSTOLAKIS: No.

7 MR. WACKOWIAK: That's not a requirement.
8 And -- but it -- the way that the modeling and the
9 numerics turn out, is that when we apply the good
10 defense-in-depth techniques, and when we apply
11 diversity techniques, the -- using today's modeling
12 practices it comes out this way. If we discover
13 something that changes that, it's okay.

14 MEMBER APOSTOLAKIS: No, I fully agree
15 with that. I mean, I'm not saying that --

16 MR. WACKOWIAK: I've seen some of those
17 old results. I think I even saw some control rod drop
18 analysis that somebody had that was a 10^{-20} frequency
19 for the --

20 MEMBER APOSTOLAKIS: The lowest I have
21 seen is 10^{-31} .

22 MR. WACKOWIAK: Right.

23 MEMBER APOSTOLAKIS: But that was not for
24 a system. That was --

25 MR. WACKOWIAK: Right. It was --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I think to put things
2 in perspective, I believe the age of the earth's crust
3 is three 10^9 years. So we are talking about a reactor
4 here that was built when the crust started forming.

5 (Laughter.)

6 And there has been no failure since.
7 Basically, that's what we're saying.

8 Now, I will be the first one to admit that
9 I don't know how to raise the number. I don't know,
10 maybe John here has some ideas. But even with those,
11 they are not -- even 10^{-9} --

12 MR. WACKOWIAK: He had the unavailability
13 of a system go up by a factor of --

14 MEMBER APOSTOLAKIS: No, no.

15 MEMBER STETKAR: No, no, no. Just a tank,
16 not a system. One tank, not a system.

17 MEMBER APOSTOLAKIS: In other words, with
18 the details you can raise it to an order of a
19 magnitude. Okay. Big deal. I mean, it's still low.
20 It's still low.

21 MR. WACKOWIAK: And, once again, what we
22 were trying to do with this was not to come up with an
23 absolute low number. The intent was to try to take
24 events that result in risk from operating a commercial
25 nuclear powerplant, things that have risk associated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with them, and lower that so that it's on the same par
2 of things that we have determined to be acceptable
3 risks.

4 The things that were excluded from the
5 design, like the 10^{-7} aircraft impact into the
6 buildings, and other design areas where if the
7 frequency is below some value you don't have to design
8 for it. We want to make normal events -- the risk
9 from normal events to be similar to things that we
10 have already decided are acceptable risks.

11 MR. KRESS: Let me ask you a question
12 about your LRF. When we used to use LERF, it was
13 defined in terms of timing with respect to ability to
14 evacuate.

15 MR. WACKOWIAK: Right.

16 MR. KRESS: Now, you know, with this plan,
17 you no longer have LERFs, so you have to redefine LRF
18 some way. Does it involve a magnitude of release or
19 what? How did you define that?

20 MR. WACKOWIAK: Not in these numbers. For
21 the baseline PRA, it was a bounding approach. If the
22 containment was open for any reason whatsoever,
23 anything other than leakage through the shell, we
24 considered it a large release.

25 MR. KRESS: Okay. So it didn't matter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that you really might not have had a large release.

2 MR. WACKOWIAK: Right. And in some of the
3 sensitivity analyses, we did look at the magnitude of
4 specific -- of specific things. And it -- I think we
5 can show that any release of the iodines -- I think
6 there's a couple of groups there. Iodines come to
7 mind, but some of the groups, if the release is less
8 than three and a half percent, or -- yes, less than
9 three and a half percent of the inventory, then it
10 would not be large. But the only place that we
11 applied that was in sensitivity analyses, not in this
12 base model.

13 CHAIRMAN CORRADINI: So just to make sure
14 I understand -- again, I'm interpreting -- it's what
15 I read. So in all of the shutdown estimates the LRF
16 is the CDF, which means that the containment is open,
17 or is assumed open.

18 MR. WACKOWIAK: Right.

19 CHAIRMAN CORRADINI: So that is point one.
20 Point two is the -- for the at-power internal events,
21 you are showing something like eight percent -- eight
22 percent? Less than 10 percent containment failure
23 probability.

24 MR. WACKOWIAK: Right.

25 CHAIRMAN CORRADINI: For internal events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I'm sorry, yes.

2 MEMBER APOSTOLAKIS: Now, the fire
3 probably will go up, because this is kind of a
4 bounding code analysis. A more detailed analysis
5 could go up. We don't know. It could go down.

6 MR. WACKOWIAK: Actually, I think the fire
7 analysis is probably going to go down, because there
8 is not much source of fire ignition in this plant.
9 The electrical systems are pretty much low voltage
10 systems.

11 MEMBER APOSTOLAKIS: But, you see, with
12 numbers like these now, it seems to me that other
13 things would start dominating, like transient fuels,
14 organizational screw-ups. In other words, the design
15 did its job and now we have all of this other stuff --

16 MR. WACKOWIAK: Right.

17 MEMBER APOSTOLAKIS: -- that you can't
18 predict. I mean, some of the --

19 MR. WACKOWIAK: Right. You would run into
20 things like that that are not fixed in place,
21 initiators maybe, maybe something else.

22 But remember with the fire, though, we did
23 a lot of things to the design to make the fire low.
24 We were worried about inadvertent actuation of the
25 squib valves during a fire, because if the BPS valves

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 open, then we lose our isolation condenser system.
2 That would not be a good thing. Or the isolation
3 condenser is the best thing to have in these fire
4 scenarios.

5 So we arrange the plant so that the cable
6 that had to get to the squib valve to provide the
7 power had to go through two load drivers in two
8 different fire areas. And that most of the
9 connections between the cabinets are with fiber, so
10 they are not subject to hot shorts. And we also
11 looked at where logic cabinets were located and made
12 sure that certain logic cabinets were not collocated
13 in a room with other ones, so that we maintain
14 diversity during fire.

15 MEMBER APOSTOLAKIS: That sounds very
16 good, but you also used FIRE, right?

17 MR. WACKOWIAK: Not this time.

18 MEMBER APOSTOLAKIS: Oh, not this time.
19 Oh.

20 MR. WACKOWIAK: Yes. Starting in the
21 last --

22 MEMBER BLEY: You changed the -- when you
23 get the new report, we'll have a new FIRE analysis.

24 MR. WACKOWIAK: Rev 2 that you already
25 have was our first attempt at applying NUREG-6850

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where we -- so that's in there.

2 MEMBER BLEY: Speaking of hot shorts, have
3 you been following the CAROLFIRE work at Sandia?

4 MR. WACKOWIAK: As much as we can. It's
5 -- now that the last DCD rev is in, I'll be able to
6 follow it more.

7 MEMBER BLEY: I think it's worth taking a
8 look at.

9 MR. WACKOWIAK: Yes.

10 Okay. So go through some of these. I
11 don't know when you guys are required to have a break
12 or anything, so you just tell me.

13 CHAIRMAN CORRADINI: We're not required.

14 MR. WACKOWIAK: Okay.

15 CHAIRMAN CORRADINI: Go for a few more
16 minutes, and then we'll --

17 MR. WACKOWIAK: So --

18 CHAIRMAN CORRADINI: Is this a logical
19 point to break for you, or do you have somewhere else
20 a few slides later?

21 MR. WACKOWIAK: We can break almost
22 anywhere in these, because now the way the rest of the
23 -- the rest of my slides are implemented is I'm going
24 to go through chapter by chapter, say what we have,
25 and if there's any open items, and, if we do, how we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have addressed them.

2 CHAIRMAN CORRADINI: After this, then. Go
3 ahead.

4 MR. WACKOWIAK: Okay. So we talk a lot
5 about initiating events being based on historical
6 data. For transients, we use NUREG-5750, categorize
7 our equipment into those categories, and look for
8 similar types of failure modes and how they would
9 match up.

10 Loss of offsite power -- once again, based
11 on the historical data. We have asked the customers
12 to provide their loss of offsite power data for us,
13 and we have looked at that in our PRA as well.

14 LOCAs -- we scaled the numbers that are in
15 5750 to match up with the ESBWR arrangement. Since we
16 don't have recirc pipes and things like that, we tried
17 to -- we kept the frequencies about the same, but we
18 distributed amongst different pipes and different --
19 we include inadvertent ADS and then spurious DPVs and
20 multiple spurious SRV openings in our LOCA data. So
21 some of the steam line LOCA frequencies may look very
22 large, but it's mainly because these other system-
23 based things are included in those LOCAs.

24 We did include vessel rupture with an
25 evaluation method in NUREG-1806 based on the forged

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 vessel construction and the forged nozzles.

2 Break outside containment -- once again,
3 5750, we looked at the lines that are connected to the
4 reactor vessel. Interfacing system LOCA -- we did
5 have two candidates for those, but it turns out that
6 those particular failure modes were covered in other
7 LOCA events, so we just added the frequency into those
8 other ones. And they were much lower because of the
9 isolation capability.

10 We looked at loss of service water and
11 loss of instrument air as special initiators. So the
12 list that we have here is a fairly standard list of
13 Level 1 initiating events. No open items in this
14 area.

15 The accident sequences -- we used a linked
16 fault tree methodology, and I think you've seen our
17 event trees in the report. The event trees that
18 you've seen already are pretty much -- other than some
19 tweaks in the new one, they are essentially the same
20 event trees. We include all of our front line
21 systems, both passive and active, in our event tree
22 headings, and the support system are then built in
23 under the fault tree.

24 Success criteria is based on thermal
25 hydraulic calculations, combination of MAAP and TRACG.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 What we did, though, was we found a bounding criteria
2 that we would apply to all of the event trees, and
3 that's most of the cases. There was some things on --
4 I'm trying to remember which one it is now.

5 I think there's one area where we used
6 different success criteria on one branch between two
7 different event trees, but we tried to determine --
8 and I'll get to that on the next page -- what the
9 limiting number of GDSCS valves would be for our worst-
10 case LOCA, and then we applied that to all LOCAs
11 rather -- you know, whether it was worst case or not.

12 MEMBER ABDEL-KHALIK: But if we look at
13 the opposite problem, what would be the success
14 criterion for non-condensable gas accumulation in the
15 GDSCS line? How much gas can you actually tolerate and
16 the system would still perform?

17 MR. WACKOWIAK: I know that question has
18 come up several times, and I believe the last
19 resolution of that -- of that was that the line is
20 required to be oriented such that non-condensable
21 gases won't accumulate in the line. The slope of the
22 line -- the low point is the squib valve, and it goes
23 up from both ends from there.

24 MEMBER ABDEL-KHALIK: So the problem is
25 essentially designed out?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WACKOWIAK: Right.

2 MEMBER ABDEL-KHALIK: But --

3 MR. WACKOWIAK: Well, for that -- for non-
4 condensable gas. There were other questions about
5 non-condensable gases in the ICS heat exchangers, and
6 the way we dealt with that is we -- we require venting
7 of the ICS heat exchanger to consider it for success.
8 So the system to purge the gas out of the ICS heat
9 exchanger is required for the success, so we don't ask
10 the question, how much non-condensable gas is going to
11 be in there.

12 MEMBER ABDEL-KHALIK: So in going through
13 this whole process, you are assuming that whoever is
14 going to put these lines together will actually do it
15 right.

16 MR. WACKOWIAK: Their ITAAC for those
17 slopes on those lines.

18 CHAIRMAN CORRADINI: I'm trying to
19 remember back two years ago when we last had you -- I
20 think it was August -- and we discussed this. I seem
21 to remember that there was a decision -- or maybe I'm
22 -- "decision" is the wrong word, but at least a
23 suggestion that more TRACG calculations be done to
24 benchmark --

25 MR. WACKOWIAK: I'll get to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN CORRADINI: You're going to get
2 there?

3 MR. WACKOWIAK: I'll get to the point
4 where we acknowledge that we have to do.

5 CHAIRMAN CORRADINI: Okay. Fine.

6 MR. WACKOWIAK: Okay?

7 CHAIRMAN CORRADINI: Thank you.

8 MEMBER ABDEL-KHALIK: Let me just follow
9 up. When we talk about squib valve failure, and, you
10 know, probability of failure, what is included in
11 that?

12 MR. WACKOWIAK: It's the probability --
13 the squib valve itself is -- it includes the
14 pyrotechnic material not igniting, the shear pin not
15 shearing, and the scored cap not coming off of the
16 pipe. So those are the failure modes that are
17 subsumed within the data that we have for the squib
18 valve.

19 MEMBER ABDEL-KHALIK: So when you look at
20 an event like the Cooper event in 1976, when the
21 standby liquid control system was deemed to have
22 failed, because of a fuse failure, that is not
23 included in any probabilities of squib valve failure
24 that you may have included.

25 MR. WACKOWIAK: That particular failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be included in the detailed model for the I&C
2 system, because the I&C system is what actually
3 provides the power out to the squib valve. And what
4 we've shown is is that those types of detailed
5 failures -- unless it's a common cause failure --
6 doesn't show up in the answer. So --

7 CHAIRMAN CORRADINI: You mean they are too
8 low to show up. Is that what your point --

9 MR. WACKOWIAK: Yes, they don't make the
10 truncation level, unless it's a common cause failure.
11 So in the particular case that you are talking about,
12 we may have a fuse failure that, because of the
13 information that is known about the I&C system right
14 now, we don't necessarily know if it's going -- if
15 there is going to be a fuse there. We can talk about
16 the details of that.

17 The I&C system itself makes the power for
18 sending it out to the squib valve. There is some sort
19 of protective device there, but I don't know if it's
20 a fuse or if it's something -- if it's something else.
21 But that sort of thing would affect one valve, and if
22 you remember the way that our squib valves are set up,
23 every squib valve has four electrical wires connected
24 into it. So we would have to fail four different
25 fuses in different divisions, and then one in a non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safety system, in order for a fuse failure to prevent
2 a squib valve from opening.

3 MEMBER ABDEL-KHALIK: But we don't know
4 the details yet.

5 MR. WACKOWIAK: But we do know it would
6 take four fuse failures in order for that phenomena to
7 happen to one squib valve. So I'm confident that,
8 unless it's a common mode failure, then it's not going
9 to affect the final result.

10 MEMBER BONACA: But where did you get the
11 frequencies for those three failure modes that you
12 subsumed in the squib valve?

13 MR. WACKOWIAK: That's from -- I'll have
14 to look back again, but I think -- I think that the
15 squib valve data was in the ALWR database. And those
16 were the types of failure modes that were considered
17 for those.

18 MEMBER STETKAR: Rick, I have to
19 apologize. I was looking at something else here, and
20 you were talking about something and I had a question.
21 The squib valve designs here do have four separate
22 igniter power supplies?

23 MR. WACKOWIAK: Yes.

24 MEMBER STETKAR: Yes. Okay, thanks. I've
25 seen other ones where they have four separate logics,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 but there is only a single -- there is only a single-
2 firing power supply circuit, so there's four
3 separate --

4 MR. WACKOWIAK: Four separate --

5 MEMBER STETKAR: -- igniter power
6 supplies.

7 MR. WACKOWIAK: -- igniter power supplies.

8 MEMBER STETKAR: Okay.

9 MR. WACKOWIAK: And on the three that are
10 the safety-related, the current configuration actually
11 has two power supplies in each of those. So it's
12 actually I think seven power supplies that can give
13 power to that valve and ignite it.

14 MEMBER STETKAR: Okay.

15 MEMBER ABDEL-KHALIK: So what is the
16 common mode failure probability of these fuses that
17 would affect all of the squib valves?

18 MR. WACKOWIAK: What we have in our model
19 right now is a common mode -- we have three common
20 mode failure designators in the I&C system. One would
21 be the loss of communication amongst all of the remote
22 computer boxes. And I don't remember what that number
23 is. There is another one that is associated with the
24 logic in the computers. I don't remember what that
25 one is right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But then, there is also the one that we
2 address the software failure that would say don't
3 ignite any of the squib valves across the platform,
4 and that value is set at 10^{-4} . We think that
5 particular value would cover anything like a common
6 mode failure of hundreds of fuses out in the plant,
7 things like that. So there is a 10^{-4} chance that any
8 of our platforms will fail to ignite all of the safety
9 system.

10 MR. MILLER: We don't have the detail, but
11 there's a lot of self-diagnostics in the digital
12 control system. So the latent failure is like a fuse
13 that is broken or open, would be detected prior to
14 actuation.

15 PARTICIPANT: That is a common mode
16 failure.

17 MR. WACKOWIAK: Yes, the fuse is a tough
18 one to detect, because it looks like it can handle the
19 trickle current, but it won't be able to handle the
20 surge for blowing the valve. So it's a funny failure
21 mode, or a strange failure mode, to have there. But
22 I'm confident that through the sensitivities that
23 we've done on the details of the I&C system, every
24 time we've tried to model the details of the I&C
25 system we end up with a 2,000-page fault tree, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the thing is very complex, and we end up getting three
2 basic events out as the answer every time.

3 MEMBER ABDEL-KHALIK: So you have actually
4 looked at this --

5 MR. WACKOWIAK: We haven't looked at --

6 MEMBER ABDEL-KHALIK: -- plant event and
7 designed your system so that this particular event is
8 excluded?

9 MR. WACKOWIAK: A single fuse failing a
10 system is excluded in our plant design. There are no
11 single-point fuse failures that will disable a system
12 in this plant design.

13 MEMBER ABDEL-KHALIK: But still, we don't
14 know what the common mode failure probability of the
15 fuse is.

16 MR. WACKOWIAK: And we don't know if it's
17 even going to be fuses yet is the hard part. It may
18 -- the protective device may not actually be a fuse,
19 because it's the system -- we're not coming from a
20 250-volt DC battery out to a field squib. The
21 computer cabinet itself has a power supply in it --
22 two power supplies actually -- but it's making a 12-
23 volt signal from that power supply to send out to the
24 device.

25 MEMBER ABDEL-KHALIK: So what do these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 numbers mean anyway, if we don't know how the system
2 will actually be designed?

3 MR. WACKOWIAK: Once again, in all -- when
4 we've looked at the details of the design of the I&C
5 system, because of the way that it is -- the
6 redundancy and the -- basically it's the redundancy in
7 the way it's connected, that we can put in almost any
8 numbers for these values, and the only things that
9 come out are the common cause failure of the software
10 to operate, common cause failure of the communications
11 protocol to be -- basically to be specified properly,
12 and the common cause failure that the logic processors
13 would fail. And that one comes from the
14 manufacturer's data.

15 But the specifics of it -- to understand
16 how these work, we have talked about 12 different ways
17 to get power to that squib valve. Or not 12 -- seven
18 different ways to get power to that squib valve, and
19 that's for one of the squib valves. And we see on
20 here for the GDCS valves, one of those others, the PRA
21 says that only two of the eight have to actuate.

22 We have shown by calculation that it's --
23 probably one would be okay, but, you know, right now
24 we're not taking credit for that. So if we have -- so
25 to get to a failure of seven of those valves, it would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 be a common cause of 49 isolation devices that would
2 have to fail, and these are isolation devices that are
3 tested in the plant, and our configuration includes a
4 test switch for these squib valves, where during the
5 outage they can put the full firing current into a
6 resistor and show that the rest of the circuit is
7 still functioning.

8 So I -- you know, I'm -- we could put
9 something in for these types of isolation devices, but
10 I'm sure that no matter what number we use it's not
11 going to be bigger than the 10^{-4} that we just said the
12 I&C system just won't work. And that's an assumed
13 number right now, because there is controversy on how
14 you would calculate such a number. But I'm certain
15 it's less than 10^{-4} .

16 MEMBER ABDEL-KHALIK: Thank you.

17 MR. WACKOWIAK: That's how we dealt with
18 those things. We do have a detailed model, and it's
19 just -- it's huge. And with all of the sensitivities
20 we've done, you still just come out with those three
21 basic events, three massive common cause failures, out
22 of the system.

23 MEMBER STETKAR: I'm assuming, by the way,
24 that that -- the model is fully linked together,
25 right? When you solve the model, that your model for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the I&C systems is actually linked to the front-line
2 systems, isn't it?

3 MR. WACKOWIAK: We have --

4 MEMBER STETKAR: Because in the individual
5 systems you show that with like a 10^{-3} or 10^{-4} or 10^{-5}
6 input, but I'm assuming that that's just for display
7 purposes. Is that correct?

8 MR. WACKOWIAK: That's for display
9 purposes in the system. Those are linked. But, once
10 again, when we do quantify the whole model, we don't
11 use -- we do a sensitivity with the 2,000-page I&C
12 model, but when we run most of our other cases we have
13 a simplified model that has those failure modes that
14 come out, those individual failure modes, and it has
15 the links to all of the support systems, the 125-volt
16 AC power, and the DC power system.

17 So all of the details of all of the
18 different failures that could happen are not linked in
19 the model when we solve the model, but we do do
20 sensitivities to show all of it.

21 MEMBER STETKAR: Where is that simplified
22 logic shown? That must be some simplified logic.

23 MR. WACKOWIAK: The previous version of
24 the PRA showed the detailed logic.

25 MEMBER STETKAR: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: And then, back at the back
2 page was the simplified logic. And I think we've --
3 we changed that this time, so that the chapter shows
4 the logic that was actually linked into the tree, and
5 then the detailed logic is contained in an appendix.

6 MEMBER STETKAR: When --

7 MR. WACKOWIAK: So it was in --

8 MEMBER STETKAR: We'll get to that in the
9 system.

10 MR. WACKOWIAK: We'll get to that. So,
11 once again, on the success criteria, we did look at
12 various things. What we -- where we went through is
13 we calculated for large LOCAs, we looked at all of our
14 large LOCAs, have a big matrix that says, "What is the
15 -- you know, in different sensitivities, what is the
16 minimum number of components that you can use?" We
17 have come up with like one, one, zero, and two, and so
18 we selected the next thing up higher, two, two, one,
19 and four. Once again, medium LOCA, we had to add DPVs
20 in there, and we did the same sort of process.

21 Now, so let me just get to this next part
22 here, and then I'll talk about the open item that we
23 have on that. On our mission times, one of the things
24 that we have -- that was pointed out here is that the
25 mission on these plants is very long. If we were to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cut off our sequences all at 24 hours, you know, we
2 don't have very much left, because some of these
3 failures actually occur out in the second day, third
4 day, and I think one of our sequences even has the
5 core damage occurring at 108 hours following the
6 initiating event.

7 So our event tree branches look for the
8 safe stable state. Safe and stable in this plant is
9 not necessarily cold shutdown. A hot state is okay,
10 and that's defined. So these sequences consider the
11 entire mission time. But when we put in data, the
12 data values for something that has to operate for the
13 mission time, we put in a 24-hour mission time.

14 MEMBER APOSTOLAKIS: In terms of timing,
15 if there is a problem, you have the active systems
16 going first, right?

17 MR. WACKOWIAK: Yes.

18 MEMBER APOSTOLAKIS: And when and why
19 would you switch to the passive system?

20 PARTICIPANT: Because they don't work.

21 MR. WACKOWIAK: The active systems no
22 longer work.

23 MEMBER APOSTOLAKIS: What does that mean?

24 MR. WACKOWIAK: Let's say we have a pump
25 injecting water into the vessel, and sometimes three

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or four hours into the mission the pump would fail.
2 Then, since we are considering recovery in our models,
3 that pump failing to continue to inject would result
4 in water level going down, and then the active system
5 -- or the passive systems could come in and still
6 recover in --

7 MEMBER APOSTOLAKIS: They would come in
8 automatically?

9 MR. WACKOWIAK: Yes.

10 CHAIRMAN CORRADINI: So can I just
11 interject one thing here? Because you said something
12 that I guess I hadn't thought of. But let's use that
13 example and push it a bit. So let's say one
14 particular part of the active system failed, but
15 another part of the active system was working. You
16 have procedures in place that say, "Ah ha, because of
17 sister interaction this passive system will be
18 defeated. Shut down this other active system to allow
19 the passive system to operate." You were using sprays
20 and pumping into the vessel. But I guess I want to
21 make sure I'm clear on this, because that sort of
22 interaction can get you in some sort of a pickle.

23 MR. WACKOWIAK: Yes.

24 CHAIRMAN CORRADINI: So have I got it
25 right that if I were to have this active system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 failure, there are going to have to be emergency
2 operating procedures in place that says that I'm going
3 to shut down other active systems to allow the full
4 complement of the passive systems to work?

5 MR. WACKOWIAK: There are some limited
6 cases where that would be in place. The spray is one
7 of them that --

8 CHAIRMAN CORRADINI: Well, that's --
9 brought that one up, and I hadn't thought of it.

10 MR. WACKOWIAK: Right.

11 CHAIRMAN CORRADINI: But I guess this is
12 something I was thinking of coming in.

13 MR. WACKOWIAK: Yes. The way that we
14 would want to deal with that is, like I said, before
15 you spray, you verify one of two things -- one, that
16 you do have active cooling going into the core, okay,
17 or the core is outside the vessel and you don't care
18 about that. But anyway, you do have active cooling.

19 When you've established that you do have
20 active cooling, that usually means that you have AC
21 power available, you have cooling water available, you
22 have the full complement of just about everything
23 onsite when you get to the point in the procedure
24 where it says to do that.

25 So then we'd be in a situation where we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 had the LOCA, we've been injecting and things for a
2 while, and then subsequently we started losing all of
3 our power and all of our diesel generators and things
4 after they worked successfully for some period of
5 time.

6 Those types of complex time-space
7 sequences are not included in this model, and that
8 might be one place where some of the CDF might go up.
9 We would have to know a lot more about the specific
10 equipment and about our procedures and operating
11 training and things in order to do that. It's not
12 something that can be done at the design phase.

13 CHAIRMAN CORRADINI: I'm not so much
14 worried about the CDF numbers. I want to understand
15 the logic about something actively failing and then
16 getting appropriate emergency procedures such that
17 they'd have to look for certain attributes or
18 characteristics to keep the rest of the active systems
19 going. Otherwise, you essentially get into this
20 situation where the passive systems can't function as
21 designed.

22 MR. WACKOWIAK: So in this particular
23 case, if you lost your cooling or lost your injection,
24 then the procedures would have to say don't spray
25 anymore to reestablish the steam path through. But,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 remember, the water tanks are still there, so it's not
2 like if the -- if the GDCS has not injected yet, there
3 is still 2,000 cubic meters roughly of water that's
4 there for the initial injection. Decay heat is lower,
5 because you've been removing heat from the vessel for
6 quite a long time. I think the accident scenario
7 progresses much differently at that point. So --

8 CHAIRMAN CORRADINI: Okay.

9 MR. WACKOWIAK: -- those are concerns, and
10 there are also concerns -- the things that concern me
11 more than those sorts of things that -- when the
12 operators have control of the plant, and then
13 something fails and they have to respond to that, I
14 think their -- those types of things can be handled to
15 through the procedures and training. Operators
16 usually are pretty good these days at dealing with
17 that.

18 What I'm more worried about in the design
19 phase is that the -- that the designers or the
20 reviewers get overzealous in trying to protect some of
21 these systems. So if you -- one step might be, if you
22 have the active systems going, maybe you would turn
23 them off before you put too much water inside the
24 containment to displace nitrogen.

25 Well, the designers would say, "Oh, yes,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I've got to protect that, so my containment pressure
2 doesn't go up too high." Where we would say, "No, you
3 want to be very careful of that," because the
4 containment doesn't actually fail at the design
5 pressure. The containment fails much higher than the
6 design pressure, and you need to be deliberate on how
7 you would give those kinds of instructions.

8 So where we are right now in the design
9 phase of this is we are interacting with the designers
10 to make sure that we have a proper balance of
11 functions to turn off active systems, if you will,
12 versus the operators having control of the plant so
13 that things will operate.

14 MEMBER APOSTOLAKIS: Is it possible to
15 have the passive systems actuated while the active
16 systems are working?

17 MR. WACKOWIAK: Yes.

18 MEMBER APOSTOLAKIS: And then, what will
19 happen?

20 MEMBER MAYNARD: They are going to
21 actuate.

22 MR. WACKOWIAK: It's a completely -- it's
23 a different set of signals that -- if water level gets
24 into Level 1, the passive systems --

25 MEMBER APOSTOLAKIS: And then what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 happens? I mean, is there a sequence that you have
2 analyzed or --

3 MR. WACKOWIAK: Yes.

4 MEMBER APOSTOLAKIS: Oh, it is analyzed?

5 MR. WACKOWIAK: So the question is, if
6 something like low pressure injection is working, but
7 just not keeping up, then what happens if the passive
8 systems come on?

9 CHAIRMAN CORRADINI: That's a good one.

10 MR. WACKOWIAK: In that particular case,
11 the SRVs would already have been open, because the low
12 pressure systems need the SRVs to perform their
13 function. So the first 150 seconds of the ADS
14 sequence would be meaningless. The ACS valves are
15 already open.

16 The DPV squib would blow, but since the
17 reactor vessel is already depressurized at that point,
18 we -- you know, and cooler water is coming in, maybe
19 we would lose a few more pounds of pressure there when
20 those actuate. And then, when the GDCS squibs open,
21 then the water would drain into the reactor and fill
22 up. And then, the low pressure system, since it is
23 always in a recirculation mode from the suppression
24 pool back into the vessel, would probably preclude the
25 need for using the PCCS at that point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Yes?

2 MEMBER SIEBER: Would it be fair to say
3 that if we don't address Dr. Corradini's question that
4 the PRA result that we now see is not fully reliable,
5 that the risk would be higher than what this analysis
6 says?

7 MR. WACKOWIAK: Well, I don't like the
8 term that a number isn't reliable, or the results
9 aren't reliable, because the purpose of the results is
10 to show that we meet the goals.

11 MEMBER SIEBER: Right.

12 MR. WACKOWIAK: Now, you might say that
13 the results might be low, but they are still adequate
14 for performing the application that -- the risk-
15 informed application that we are doing, which is a
16 design certification for the plant.

17 MEMBER SIEBER: That is specifically the
18 question now. It seems to me that Dr. Corradini's
19 question identifies an area that hasn't been fully
20 explored. The question is: to what extent can we
21 rely on the answer when there's a piece of the puzzle
22 that's still missing?

23 MR. WACKOWIAK: That's what needs to be
24 decided. Is there enough there that shows that we
25 meet all of the goals with margin such that the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 should be certified?

2 If there's no other questions about
3 that --

4 MEMBER ABDEL-KHALIK: You can't address
5 this issue until you have a complete set of
6 procedures.

7 MR. WACKOWIAK: It's even more than that.
8 I think you have to have the equipment in order to
9 develop those procedures. So it's a chicken and egg
10 sort of thing. You really can't -- you can't know
11 exactly what you have until you actually have it.
12 They are far enough along the line that, you know,
13 procurement specifications and things like that, much
14 farther than anywhere in the licensing process here.

15 MEMBER SIEBER: In the old days, the
16 process was that the vendor would provide procedural
17 guidelines to the applicant, the licensee, to write
18 the plant-specific procedures. Do you plan, as part
19 of the package of supplemental plans to customers to
20 provide procedural guidelines like that?

21 MR. WACKOWIAK: I think there's a -- in
22 the area of the emergency operating procedures and the
23 severe accident guidelines, there is a COL item now
24 that those procedures need to be developed. The lead
25 for that at this point is with GE, working with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DCWG, and it's kind of outside of the scope of the
2 certification. But that whole process is going on.
3 There will be a common set of guidelines and probably
4 procedures and training for all of the ESBWRs.

5 MEMBER SIEBER: It seems to me, though,
6 that for you to develop a reliable PRA, and also to
7 design a few parts of the plant, you have to know what
8 the operator is going to do or you have to decide what
9 he is going to do and write it down in terms of
10 guidelines, that all of the plant-specific features or
11 company-specific things that they would ordinarily put
12 in there would get into it when the detailed
13 procedures are written. I mean, you didn't say yet
14 that you are going to write the guidelines.

15 MR. WACKOWIAK: Well, absolutely, we would
16 -- we have some guidance in there. In Chapter 19,
17 there is a list of insights from the PRA, and some of
18 those insights have to be implemented in the procedure
19 development plan, and those are identified in the
20 latest one -- which ones are -- they were just called
21 operational programs before.

22 But as you look at those, most of those
23 are things that are implemented through procedures and
24 training. So we have already got some guidelines from
25 the PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But, remember, the PRA itself -- and
2 people talk about a reliable PRA and things that --
3 the PRA is built to answer the specific questions that
4 it was built for. And what we're trying to show with
5 this one is that we meet the goals and the other few
6 things there. You'll notice in our application we did
7 not try to do risk-informed tech specs.

8 Our PRA needs to include all of those
9 things that you are talking about in order to do risk-
10 informed tech specs, so we did not do that in this
11 application.

12 MEMBER SIEBER: Yes. But there's other
13 risk applications, and the development of other
14 software and hardware for the plant PRA has value.

15 MR. WACKOWIAK: Oh, it does. But we want
16 to make sure that we have the right PRA for the right
17 applications. And we think -- it is our contention
18 that this PRA is sufficient to ask the questions that
19 have been answered for design certification. It may
20 or may not be sufficient for doing other things. And
21 when we've got --

22 MEMBER MAYNARD: The question that's on
23 the table is: is that going to be a COL issue? That
24 once the procedures are developed and the equipment is
25 picked, then the COL applicant would have to show that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with that equipment and those procedures that it stays
2 within the bounds of the PRA established for the
3 design certification.

4 MEMBER SIEBER: But the COL applicant is
5 going to write the procedure. So I'm wondering what
6 the check on that is.

7 MEMBER BLEY: Well, let me ask it a
8 slightly different way. I don't fully understand the
9 ITAAC business, but it's inspection, test, analysis,
10 and acceptance. Could these criteria end up being
11 acceptance criteria in the form of an ITAAC, once your
12 work is all done, that would flag it for the COL,
13 then, that those have to be included? That's probably
14 more for staff than you guys. I don't know. Would
15 anyone address that?

16 MR. WACKOWIAK: I think that these things
17 that we're talking about here are all intertwined
18 through that. And the question is: is there a
19 specific point that you could point to me that does
20 that? Because you have to remember that the
21 procedures development is tied in with this I&C
22 development, and that's something that they called
23 DAAC.

24 And, you know, around here DAAC is a four-
25 letter word. But there's part of the design that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just based on -- right now on acceptance criteria, and
2 the I&C systems and much of the human factors things,
3 like the development of the EPGs, things like that,
4 are in this design acceptance criteria where we have
5 rule -- we have a process for how we're going to
6 develop those, but they have not been developed yet.

7 And when they are developed, then those
8 things are submitted as DAAC closures through one of
9 the -- probably the first COL applicant, most likely
10 North Anna, but probably the first -- the first COL
11 applicant for review. Does this particular aspect of
12 the human factors -- does it close out the design
13 acceptance criteria? If that is okay, then everyone
14 else references that closure of it. So there's
15 other --

16 MEMBER BLEY: Where I was headed is, is
17 there an accepted place for these assumptions that are
18 important to the PRA and that ought to end up in
19 procedures? Do they end up as DAACs then? How do we
20 make sure that when we get to the next step these
21 things don't just fall through the cracks and they
22 aren't there in the procedures?

23 MR. WACKOWIAK: They currently exist in a
24 table in Chapter 19 of the DCD, so that's where they
25 reside today.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: That's where they're
2 captured.

3 MR. WACKOWIAK: That's where they're
4 captured today.

5 MR. HAMZEHEE: I think -- Dennis, I think
6 one thing we're trying to ensure at this time is that
7 there is a clear documentation of all of these
8 assumptions -- and we call them operational programs
9 -- so that they may become COL action items. And
10 through the application, then they have to ensure that
11 these assumptions/procedures are somehow incorporated
12 into their operating procedures and checked and
13 balanced.

14 MEMBER BLEY: And I guess the point we're
15 raising is that "somehow" part is leaving us a little
16 queasy.

17 MR. HAMZEHEE: Yes.

18 MEMBER BLEY: "Somehow" needs to be
19 defined.

20 MR. HAMZEHEE: Yes. And I think --

21 MEMBER BLEY: And it ought to be defined
22 pretty soon.

23 MR. HAMZEHEE: I think we -- there may not
24 be ITAAC. We will get back to you on that. But these
25 are all COL action items that become --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Right. This is Amy Cubbage.
2 You know, by nature of these assumptions and insights
3 being in Chapter 19 of the DCD, they become
4 requirements for all future licensees for ESBWR
5 forever. And so if they -- if they don't meet those
6 requirements, they have to come in through a departure
7 through the Part 52 change process. They become
8 design requirements.

9 MEMBER APOSTOLAKIS: But something
10 confuses me a little bit. You said earlier, Rick,
11 that we have not included in this PRA -- the way I
12 understand it anyway -- this transition from active to
13 passive system cooling, and the operator actions
14 because the procedures and equipment are not known.
15 But for design certification purposes, a PRA is good
16 enough. How does that follow from missing something
17 that appears to be very important? Why is it good
18 enough for the design certification when an important
19 transition is not modeled?

20 MR. WACKOWIAK: We did do a look -- this
21 was the adverse system interactions look that we have
22 been talking about here. What can happen if an active
23 system is working, either during or prior to a passive
24 system active, and then we have a qualitative
25 assessment of -- is that a failure mode that has to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 addressed? Okay?

2 And so, for example, on one of these
3 things associated with adding water into the
4 containment, prior to the passive systems actuating,
5 one of the concerns would be that you have displaced
6 or possibly displaced more nitrogen in the
7 containment, so the containment pressure could be
8 higher.

9 But in the PRA assessment what we say is
10 that the containment failure occurs at three times --
11 at or above three times the design pressure, and you
12 can't get to those kinds of pressures just by adding
13 this extra bit of water into the containment. So
14 we've gone and qualitatively looked to see if there
15 are anything like that that affects the system in the
16 PRA.

17 But the specific modeling of that sequence
18 has not been done. We think it will come out okay.

19 MEMBER APOSTOLAKIS: So what you're saying
20 is that, yes, we did look into how things can become
21 complicated, but we assume -- we looked at the
22 consequences of if they become complicated.

23 MR. WACKOWIAK: Right.

24 MEMBER APOSTOLAKIS: Okay. That makes
25 sense.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: And then, in our PRA
2 model, then, we assume that if there's a failure, a
3 run-time failure of an active system, then that -- we
4 decided that that happens early at time zero, so that
5 would go on, and we didn't model the details of that
6 time phasing. But we think it's note -- that the
7 consequence is not going to be significantly different
8 from what we have in the PRA now.

9 MEMBER APOSTOLAKIS: Thank you.

10 MR. WACKOWIAK: Okay. On the accident --

11 MEMBER APOSTOLAKIS: There is no break, I
12 guess, huh?

13 MR. WACKOWIAK: Let me just get this one
14 here, the accident sequence analysis --

15 CHAIRMAN CORRADINI: Let's just get to
16 this, George, and then we'll have a break.

17 MEMBER APOSTOLAKIS: When?

18 CHAIRMAN CORRADINI: In a minute or two.

19 (Laughter.)

20 MR. WACKOWIAK: The accident -- we have a
21 couple of significant open items. The one we talked
22 about was the thermal hydraulic analysis.
23 Specifically, the cases that we showed for the MAAP
24 versus TRAC comparison didn't cover PRA scenarios.
25 They were design basis scenarios.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And then, there was another question about
2 TRACG models, and are they -- what is the
3 justification for calculating the clad temperatures in
4 these regimes, since it was qualified for other
5 regimes. Those specific responses are, unfortunately,
6 still being developed, and we don't have that right
7 now. The latest DCD took precedent over this RAI, so
8 those will now be picked back up.

9 MEMBER APOSTOLAKIS: Okay.

10 MR. WACKOWIAK: There was a question about
11 the rationale for selection of the limiting accident
12 scenarios. We provided the road map to where that
13 selection can be found throughout our document. And
14 the other one is the treatment of parameters affecting
15 the thermal hydraulic uncertainty was not provided
16 before, and we provided in an RAI response the
17 information needed to understand how we made those
18 selections. And I think that table is now included in
19 the PRA.

20 MEMBER APOSTOLAKIS: Rick, are you
21 familiar with the work that has been done primarily in
22 Europe on these things, the RMPS method for passive
23 systems? I mean, have you addressed where they
24 develop a number of steps. First, you look at this
25 and that and that, you know, that kind of stuff. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 mean, are you familiar with that?

2 MR. WACKOWIAK: By name, no. But it's
3 possible that I -- I'm not familiar with the name.

4 MEMBER APOSTOLAKIS: Also, EPRI issued a
5 report just a few months ago. You are familiar with
6 that? A review of activities of passive system
7 reliability. The EPRI report is probably the best,
8 because it -- do you have it?

9 MR. WACKOWIAK: If we don't, I'll get it.
10 I have to say.

11 MEMBER APOSTOLAKIS: Okay.

12 MR. WACKOWIAK: Yes. The thing that we --

13 MEMBER APOSTOLAKIS: He is not asking me
14 to give it to him, so --

15 CHAIRMAN CORRADINI: He has it. Can you
16 -- he's waiting for you to ask him.

17 (Laughter.)

18 MEMBER APOSTOLAKIS: I'll give it to you.

19 MR. WACKOWIAK: Well, the way that
20 those --

21 MEMBER APOSTOLAKIS: No, because that
22 report is not -- that report, not only does it review
23 what has been done in the literature, but also it goes
24 to past ACRS subcommittee meetings, what was done with
25 AP-1000, what issues did you raise. So in that sense,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it is kind of the latest.

2 MR. WACKOWIAK: Okay. Sounds like a good
3 source.

4 CHAIRMAN CORRADINI: So before -- I think
5 we're done with this slide. Before we go to your next
6 one, is this a good time for a break?

7 MR. WACKOWIAK: This is a good time for a
8 break.

9 CHAIRMAN CORRADINI: Okay. So we will
10 reconvene at 11:20.

11 (Whereupon, the proceedings in the
12 foregoing matter went off the record at
13 11:06 a.m. and went back on the record at
14 11:25 a.m.)

15 MR. WACKOWIAK: Okay. I am going to start
16 going through the rest of the chapters again and
17 trying to cover the open items. Once again, it is all
18 great discussion, and we want to have it, and
19 hopefully we can get through the program. But I don't
20 want to leave you with unanswered questions.

21 MEMBER BLEY: We might have a question
22 before the day is over.

23 MR. WACKOWIAK: Okay. The next chapter in
24 the PRA is a systems analysis. Just basically some
25 statistics -- we have 29 systems in the plant that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 model. That's roughly a third of the named systems,
2 39 functions that are there, that we have in the model
3 from these systems.

4 The kinds of things that we -- that aren't
5 in there tend to be things that don't affect getting
6 water to the core or provide support systems to the
7 systems that do get water to the core.

8 We based our model on the descriptions
9 that are in Tier 2. And, once again, since that is a
10 fairly high-level description, it may not be
11 sufficient in all cases. Augment that with topical
12 reports, which you should also have access to on some
13 of the issues. But then, we also use some internal
14 design specifications, which are -- I think the only
15 information available to you there is the summary that
16 we put in the PRA, and the rest would be auditable
17 material rather than submitted material.

18 We assume a typical maintenance schedule.
19 We didn't try to come up with anything complex. We
20 did a sensitivity, I believe, on the maintenance terms
21 that we put in the model.

22 MEMBER STETKAR: Rick, let me ask you
23 about that. If I understand -- let me make sure I
24 understand the tech specs correctly. The tech specs,
25 as I understand them, seem to allow one complete

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 division of safety-related -- let me call it DCIS,
2 because it's one division of the safety-related
3 actuation systems -- both batteries, power supply,
4 everything -- to be out of service indefinitely, is
5 that correct? There is no time limit if I have one --

6 MR. WACKOWIAK: Yes. The specs only
7 include three.

8 MEMBER STETKAR: They only require three.
9 So I can have one out indefinitely, and then -- I've
10 lost my notes here, but there are time limits that
11 kick in if I have two out -- three -- and I can have
12 up to three out of service simultaneously. I don't
13 know how you do that, but it will allow three to be
14 out of service for I think two hours, something like
15 that.

16 MR. WACKOWIAK: Oh, okay.

17 MEMBER STETKAR: Let's go back to the
18 first condition, however. Since I can -- and I
19 understand that this is in the technical
20 specifications, I'm assuming it, to allow the
21 licensees to perform online preventive maintenance and
22 the types of things that people like to do, because
23 the design supports that type of activity, why is
24 there nothing in the PRA that accounts for the fact
25 that one complete division of the actuation systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can be out of service? And, in fact, two divisions
2 can be out of service. In fact, maybe even three
3 divisions could be out of service, although that might
4 be a rare event.

5 It's allowed by the tech specs, and, if
6 it's allowed, people are not breaking the law by doing
7 it. It's not clear to me how somebody could actually
8 remove three divisions from service and be operating
9 at power, but I think they can do it with two.

10 And PRA does not have any contribution
11 from those -- let me call them maintenance alignments
12 rather than -- and it's not repair-type maintenance.
13 It's just normal preventive maintenance, inspection,
14 could be modification work even, anything that you
15 could do at power that removes it from service.

16 MR. WACKOWIAK: That's right. The
17 maintenance that we expect on this DCIS system is
18 really only associated with calibration of
19 instruments, the instruments themselves not the DCIS,
20 and for doing battery discharge tests. Everything
21 else that is going on in this system is self-
22 diagnosed, and so they would be going into the
23 cabinets based on repair work.

24 MEMBER STETKAR: That is repair of
25 failures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WACKOWIAK: Yes.

2 MEMBER STETKAR: However, in Europe, there
3 are many plants operating that have similar four-train
4 safety systems, and they have regular preventive at-
5 power preventive maintenance, inspection programs,
6 where indeed they do take the entire train out of
7 service, not for repair of failures but because they
8 don't want people inside those cabinets checking
9 things on an active system. They actually de-energize
10 the entire train.

11 The duration may be a couple of days to
12 even a week or 10 days depending on the plant's
13 maintenance programs, and so forth, and --

14 MR. WACKOWIAK: It is my understanding
15 from talking to our designers of the DCIS system that
16 that will not be going on in this plant.

17 MEMBER STETKAR: It's allowed by the
18 technical specifications.

19 MR. WACKOWIAK: I know that it's allowed
20 by the tech specs, but the tech specs were written
21 that way to allow things like battery testing.

22 MEMBER STETKAR: No, it has separate tech
23 specs for the batteries.

24 MR. WACKOWIAK: I understand that.

25 MEMBER STETKAR: Compared to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 divisions. It's very clear.

2 MR. WACKOWIAK: I understand that that's
3 that way. The way that they have explained this to me
4 for the -- the way that the plant will be operated, so
5 I know we're in-bounding here, but, you know, I'm
6 making the leap for the as-to-be-operated, that they
7 don't want anybody in those cabinets.

8 MEMBER STETKAR: Well, then, why aren't
9 the technical specifications written that way to
10 prevent people from doing that?

11 MR. WACKOWIAK: Okay.

12 MEMBER BLEY: Well, let me ask you an
13 easier question. Given what you said, I should be
14 able to go to Appendix 19(a) and find that this is an
15 assumption, that they won't be in those cabinets as
16 often as allowed by tech specs. Will I find it there?

17 MR. WACKOWIAK: No.

18 MEMBER BLEY: Okay.

19 MR. WACKOWIAK: No.

20 MEMBER BLEY: Should I find it there?

21 MR. WACKOWIAK: I wouldn't expect it to be
22 found there. The place where I would expect it to be
23 found, but I don't know that it's there, would be in
24 Section 4 of the DCD in the -- not 4 in the DCD, 4 in
25 the PRA, in the description of the assumptions of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DCIS system. But I don't think that that assumption
2 is there.

3 So that's an interesting question, and I
4 understand that the tech specs are written that way.
5 Did we ever -- do you remember if we ever effected the
6 fourth division in the availability controls manual?

7 MR. MILLER: The fourth division of?

8 MR. WACKOWIAK: Q-DCIS. We talked about
9 that at one point. I don't know that it made it into
10 this. But, once again, the PRA does assume that there
11 isn't any maintenance other than corrective
12 maintenance needed on these systems.

13 And as a matter of fact, the way that they
14 explained the system to me is that each of the tri-
15 conic -- I think the tri-conics cabinets have the
16 ability to have two redundant cards in every slot.
17 And so if the first one fails, the other one hots,
18 it's not really -- they are always hot-swapping, but
19 the other one is there and the system doesn't even
20 need to go offline for corrective maintenance.

21 So we could probably do -- look into our
22 set of sensitivity studies and look at what would
23 happen if we only had three of the four divisions, and
24 see if that made any difference to the results. Once
25 again, I'm guessing -- and it's right now a gut feel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- that the common cause failures would still be
2 dominant. Because, remember, the way that our system
3 is set up, the individual valves themselves, the
4 mechanical devices, aren't division-based. Each
5 mechanical valve still gets its feeder from multiple
6 divisions, so it's -- the tech spec is what it is, and
7 I believe that the PRA is correct in assuming the
8 things that we have assumed.

9 Now, we can do the sensitivity to see how
10 important that would be. Where I'm a little bit
11 worried about the sensitivity, though, is that we made
12 some assumptions about which divisions -- you know,
13 since there is three safety-related divisions
14 connected to each valve, and we actually have four
15 safety-related divisions, which ones go to which,
16 because I think that was going to be decided at the
17 time that they were doing the final electrical layout.
18 Probably won't make much difference, that --

19 MEMBER STETKAR: We ought to go -- keep on
20 schedule here, because that's fine structure, but
21 it's --

22 MR. WACKOWIAK: It's an interesting
23 question, and it's probably worth a look.

24 CHAIRMAN CORRADINI: Keep on going.

25 MR. WACKOWIAK: Then, the last thing is,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you'll see in the fault trees that there is multiple
2 plant configurations allowed -- this pump in standby,
3 this one running -- but we really only picked one when
4 we did the quantification.

5 MEMBER STETKAR: Oh, is that right? You
6 said some --

7 MR. WACKOWIAK: We have a set. We tried
8 to do it based on split fractions at one point, and it
9 wasn't solving. And then, when we quickly did a hand
10 calc to see what it was doing, we ended up -- we were
11 solving the PRA model more than four million times in
12 that case, and it turns out there is -- no wonder it
13 doesn't run.

14 MEMBER STETKAR: You need some pretty
15 interesting complementary logic to get it to work.

16 MR. WACKOWIAK: But we don't think it
17 makes that much difference to the --

18 MEMBER STETKAR: Which division did you
19 set -- is it obvious in the new version which division
20 is running?

21 CHAIRMAN CORRADINI: Careful. What was
22 passed out was the new DCD, not the new PRA.

23 MEMBER STETKAR: But it includes the new
24 Chapter 19.

25 MR. WACKOWIAK: It includes the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 19, but the rest --

2 PARTICIPANT: But it does not include the
3 new PRA.

4 MR. WACKOWIAK: We are going to get that.

5 MS. CUBBAGE: I have it on a stick.

6 MR. WACKOWIAK: We are going to get that.

7 (Laughter.)

8 MR. WACKOWIAK: I'll have to look to see
9 if, in the quantification file, they actually -- that
10 we actually did or did not list what the flag files
11 were. I don't remember if that is listed in the
12 table.

13 MEMBER STETKAR: That's important for
14 documentation, for people to understand how the plant
15 is lined up normally.

16 MR. WACKOWIAK: Yes, and it really would
17 -- most of the systems are pretty symmetrical in this
18 plant. We don't have a lot of asymmetry. We did some
19 looks at which ones would be the best to be the ones
20 operating, but I really don't remember if the flag
21 settings were listed in the PRA document.

22 MEMBER STETKAR: Well, I couldn't find
23 them anywhere, but in the Rev 2 PRA, I was led to
24 believe the rotating thing kind of worked, because all
25 I saw was the fault tree --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WACKOWIAK: No, it didn't work.

2 MEMBER STETKAR: Okay.

3 MR. WACKOWIAK: Not with the computers we
4 have today.

5 System analysis -- there were no
6 significant open items in the systems analysis. In
7 the data analysis -- we have talked about this before
8 -- we think we picked bounding data, and there could
9 be -- you know, there is always controversy on what's
10 bounding and what's not. But we made an attempt to do
11 that. We tried to use the data from the ALWR URD.

12 We do have a generic database that we use
13 for other GE projects that -- like the Lung Min
14 project, and things like that, that we rely on if
15 something is not in the ALWR URD, and then some things
16 are based on engineering judgment. I think the data
17 analysis says where we got all of the -- which of
18 those things gave us the data. I think it even goes
19 down to the sources in the GE database.

20 For the passive components, we did adjust
21 failure rates for long maintenance intervals, and we
22 have previously talked about that process, and that is
23 described in the PRA. We have uncertainty
24 distributions for all of the data, and, once again,
25 like we said earlier, the way that our software is set

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 up we may be missing some state of knowledge
2 correlation in the uncertainty on the common cause
3 failure.

4 MEMBER STETKAR: What software are you
5 using?

6 MR. WACKOWIAK: It's CAFTA 5.1(a), and
7 then whatever -- I don't remember the exact number,
8 but whatever version of uncert came with 5.1(a). It's
9 not the current --

10 MEMBER STETKAR: Okay. But it's CAFTA.

11 MR. WACKOWIAK: -- version. There are
12 some things that have been changed there that might
13 help this, and we are looking into that.

14 The squib valve failure rates we -- we did
15 increase the failure rates on the squib valves from
16 what the database had, mainly because of uncertainty
17 and the types are somewhat different than what has
18 been used in the past.

19 The sizes are pretty comparable to things
20 that have been used in the past. We don't have any
21 18-inch squib valves or anything like that in this
22 plant, but they are somewhat different in design.
23 So --

24 MEMBER ABDEL-KHALIK: What is the original
25 source of the data, and how large is that database?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WACKOWIAK: The original source, the
2 URD?

3 MEMBER ABDEL-KHALIK: For the squib valve
4 failure rates.

5 MR. WACKOWIAK: I'll have to get back to
6 you on that. I don't know that answer.

7 MEMBER ABDEL-KHALIK: Yes. I would be
8 very interested in knowing where that -- those numbers
9 come from.

10 MEMBER SIEBER: Aren't the squib valves
11 for this plant unique to this plant?

12 MR. WACKOWIAK: Some aspects of the squib
13 valves are unique.

14 MEMBER SIEBER: Like the size and the
15 display and --

16 MR. WACKOWIAK: Yes. Some of them, the
17 disk is not that much different from what others have
18 used. The GDCS and equalizing line valves are not
19 that -- are not that different in size than what has
20 been used in standby liquid control systems before.
21 The DPVs are a larger special design, and -- but that
22 has been prototype tested. We've got data from the
23 test.

24 So that's a good question, because the
25 data -- is the data just from nuclear powerplants? Or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is it -- does it come from other industries as well?

2 We can look into that.

3 MEMBER SIEBER: Well, your explosive
4 charge database is lot of industries.

5 MR. WACKOWIAK: A lot of industries.

6 MEMBER SIEBER: I think NASA has --

7 MR. WACKOWIAK: NASA has got a lot of
8 that.

9 What I say here, high end digital system
10 failures, where some of these things are still being
11 hashed out, as many of you well know, in the -- what
12 we use in -- what we should use for the digital
13 failure rates. We do have a point estimate for some
14 of these things that we're discussing now, or that the
15 industry is discussing, and we chose to use the high
16 end of the industry numbers in our PRA. The -- I
17 guess that's all I want to say there.

18 We have screening values for our limited
19 number of operator actions. I think we've talked
20 about this before. Many of them tend to be on the
21 order of .1 or higher, and the ones that are lower are
22 the things where the operators have days to perform
23 the action. You probably found one that is higher
24 than that, too, or --

25 MEMBER STETKAR: Lower with about 30

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minutes, yes.

2 MR. WACKOWIAK: Lower? I don't know if --

3 MEMBER STETKAR: They are actually taking
4 -- the cognitive responses are taken pretty much from
5 ACEP curves.

6 MR. WACKOWIAK: Yes.

7 MEMBER STETKAR: And they tend to be in
8 the middle to the upper end of the ACEP curves, but
9 not necessarily at the upper valve.

10 MR. WACKOWIAK: Right.

11 MEMBER STETKAR: So some type of
12 performance shaping factor analysis must have been
13 done for some of those actions.

14 MR. WACKOWIAK: And some of those --

15 MEMBER STETKAR: And some time windows
16 were assigned. I mean, there are 30-minute, one-hour
17 time windows.

18 MR. WACKOWIAK: And some of those time
19 windows there -- and we'd have to look at the specific
20 ones -- some of those values always occur in orgates
21 with other values, and so sometimes we put all of the
22 -- all of the particular action in under one of the
23 terms, and then the other one is just the thing that
24 wasn't covered in that common value. So some of those
25 lower ones for the 30-minute might be where it's split

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 out.

2 MEMBER STETKAR: It's manual GDCS
3 actuations.

4 MEMBER APOSTOLAKIS: Now, the digital
5 system failures, I mean, reduce probabilities, right?
6 Can't you just get out of it, you don't use
7 probabilities and give an argument why you think these
8 things are reliable? I mean, the probabilities are
9 really, when it comes to these systems, they do not
10 have any basis.

11 MEMBER SHACK: Expert judgment.

12 MEMBER APOSTOLAKIS: No, even if --

13 PARTICIPANT: There's no experts is the
14 problem, to say expert judgment.

15 MEMBER APOSTOLAKIS: Maybe if you can
16 argue in terms of diversity, redundancy, that kind of
17 stuff, it's acceptable. And leave it out of the PRA.
18 Because -- yes, leave it out. Don't put probability
19 -- don't put probabilities. Do whatever it is you
20 want to propose.

21 MR. WACKOWIAK: Well, and the one thing
22 where we looked at this in terms of using this
23 particular probability of 10^{-4} , which is the common
24 failure that the system just doesn't work, or there is
25 a complementary -- the common cause failure that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 system does things that you didn't want it to do.
2 That is also included as one of the failure modes.

3 We've looked at that somewhat, and because
4 of where the goals are, if we use 10^{-4} or 10^{-3} or 10^{-5} ,
5 you still end up making the same decisions on what
6 needs to be in the tech specs, what needs to be in the
7 ACM, what needs to be in RTNSS.

8 MEMBER APOSTOLAKIS: But the program --

9 MR. WACKOWIAK: That whole range, it -- so
10 for the purpose of this exercise, I'm not sure that --

11 MEMBER APOSTOLAKIS: No. The problem,
12 Rick, is that if we let this go, other people later
13 will say, "Well, gee, at look this. 10^{-4} , they used
14 it, you approved it. What are you complaining about?"
15 Let me ask you this --

16 MR. WACKOWIAK: That doesn't always work,
17 though, because we started with 10^{-5} , because that's
18 what Westinghouse did, and that's --

19 MEMBER APOSTOLAKIS: See, that's the
20 problem.

21 MR. WACKOWIAK: But we didn't use 10^{-5} ; we
22 used 10^{-4} .

23 MEMBER APOSTOLAKIS: You can't put numbers
24 that make no sense in it. You don't analyze
25 organizational failures, do you?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: No.

2 MEMBER APOSTOLAKIS: So why should you
3 analyze these. You have to give -- you can give
4 qualitative arguments.

5 MR. WACKOWIAK: That's right. And,
6 actually, it's a similar thing. Analysis of the
7 digital failures turned out to be -- specification or
8 organizational failure. So it's the same problem.

9 MEMBER APOSTOLAKIS: We have a -- I mean,
10 this Committee or Subcommittee has been trying now for
11 at least a year to convince everybody not to put
12 probabilities where they don't belong. And the stuff
13 is beginning to go along with us. Maybe we made a
14 mistake with Westinghouse, I don't know, but this
15 10^{-4} , 10^{-5} , there is no basis for it, absolutely no
16 basis.

17 MEMBER BLEY: You need something in there,
18 but maybe you don't need a number. You need to make
19 sure --

20 MEMBER STETKAR: You need a placeholder.
21 You need a placeholder of some sort.

22 MEMBER APOSTOLAKIS: That's fine, as long
23 as you don't use a number.

24 (Laughter.)

25 MR. WACKOWIAK: And what we tried to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with it was we looked at whether changing the number
2 would lead us to different decisions.

3 MEMBER APOSTOLAKIS: At some point, it
4 will.

5 MR. WACKOWIAK: So, at some point it will.
6 If we got to 10^{-2} , it would give us a different
7 decision. If it got down to 10^{-6} -- if it got down to
8 10^{-6} , we could eliminate the diverse protection
9 system. So --

10 MEMBER APOSTOLAKIS: I don't know about
11 that, but it's really a problem that we have right
12 now. But we can't go on that -- this way. You know,
13 the research is not done, we don't understand
14 something, ah, we'll use a number anyway, because then
15 these things acquire a life of their own. Now, that
16 may not be your problem, but it's an agency problem.
17 Okay? And I really don't want to see a number there,
18 huh?

19 MR. WACKOWIAK: Can we move on?

20 CHAIRMAN CORRADINI: Yes, let's keep on
21 going. Can we?

22 MEMBER APOSTOLAKIS: I don't want to see
23 a number there. Can you take that out?

24 (Laughter.)

25 MEMBER BLEY: Rick, one thing I want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ask you about -- I really want to ask the staff about
2 this when they're on, but I just wanted to get an
3 anchor point from you. We've had a long discussion a
4 couple of times about these vacuum breakers, the new
5 big valves.

6 MR. WACKOWIAK: Okay.

7 MEMBER BLEY: And you refer to the testing
8 program and to a Bayesian approach. Do you use a
9 Bayesian approach in a lot of areas, or was it
10 peculiar for this one?

11 MR. WACKOWIAK: That one was different,
12 because there were actually tests that were run. In
13 the rest of the DCD, we have generic data, and we have
14 nothing to update that generic data with. In this
15 particular case, they were doing the Bayesian update
16 for a specific purpose. They had a --

17 MEMBER BLEY: Okay.

18 MR. WACKOWIAK: -- vacuum breaker, they
19 tested -- did various tests on that vacuum breaker,
20 and then they updated the generic vacuum breaker data
21 with their test information.

22 MEMBER BLEY: Have you done a lot of other
23 Bayesian analysis, or is this kind of unique to the
24 PRA work you guys have done?

25 MR. WACKOWIAK: That's the -- in answering

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that RAI, it's the only place that we --

2 MEMBER BLEY: Okay. Fair enough.

3 MR. WACKOWIAK: -- use that.

4 MEMBER BLEY: One more question on this,
5 and then I'm going to talk to the staff about it. Are
6 you comfortable, or do you understand the effect of
7 the prior on the posterior results?

8 MR. WACKOWIAK: What?

9 MEMBER BLEY: Have you really played with
10 that analysis enough to understand that?

11 MR. WACKOWIAK: Yes.

12 MEMBER BLEY: Was there an RAI on this
13 issue?

14 MR. WACKOWIAK: There was an RAI on the
15 reliability used of the vacuum breaker, yes.

16 MEMBER BLEY: Okay. I guess I missed that
17 one. I was looking for it and couldn't find it. But,
18 very simply, let me say that --

19 MR. WACKOWIAK: The Bayesian update that
20 was used for that was actually to answer a different
21 question in the SBWR program.

22 MEMBER BLEY: Okay. The prior that is
23 given is anchored to data on valves that are
24 completely different, have nothing to do with this
25 valve. And the range of the prior, including the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uncertainty, essentially guarantees the answer that
2 came out.

3 MR. WACKOWIAK: That's correct.

4 MEMBER BLEY: And it's not a broad enough
5 prior. I want to ask the other folks about their
6 review of it.

7 MR. WACKOWIAK: Okay.

8 MEMBER BLEY: It lets you use a very small
9 sample of data to prove something that's really just
10 saying, "I picked a prior so low that whatever data I
11 put in is going to get me the answer I wanted coming
12 into the process."

13 MR. WACKOWIAK: The purpose of that
14 evaluation in the SBWR program was to demonstrate that
15 the vacuum breaker design was a passive component and
16 did not require any sort of active backup.

17 MEMBER BLEY: Okay.

18 MR. WACKOWIAK: We rejected that. Our
19 design includes an active backup to the vacuum
20 breaker. So --

21 CHAIRMAN CORRADINI: You mean the valve
22 closure, the isolation valve.

23 MR. WACKOWIAK: The isolation valve is on
24 there, because in our judgment, my group's judgment,
25 the Bayesian update that was performed for that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 purpose of deciding that that was a passive valve did
2 not conclude that that was a passive valve.

3 MEMBER BLEY: Okay. And I would go
4 further to say that your results are really
5 essentially wrong, and they are driven wholly by the
6 prior rather than the results of the test.

7 MR. WACKOWIAK: Okay. We can talk about
8 other things associated with that report offline.

9 MEMBER APOSTOLAKIS: This brings up --

10 MEMBER BLEY: That's fine. I mean,
11 it's --

12 MEMBER APOSTOLAKIS: This brings up
13 another issue. I don't think today's meeting is
14 detailed enough. And we've had two meetings before,
15 and they were I would say at the same level. Okay?
16 Will we ever have an opportunity to actually go into
17 details and have slides that present, "This is what we
18 did here," and somebody says, "Well, I agree, I
19 disagree."

20 MR. WACKOWIAK: So let me just --

21 MEMBER APOSTOLAKIS: In my view, this is
22 too high level.

23 MR. WACKOWIAK: So let me try --

24 MEMBER APOSTOLAKIS: We did just the
25 analysis, we did this other analysis, and if we happen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to have seen something relevant, then we raise it.

2 MR. WACKOWIAK: Right.

3 MEMBER APOSTOLAKIS: I don't know how to
4 handle this. I mean --

5 MR. WACKOWIAK: In the previous two
6 meetings since, I don't remember --

7 MEMBER APOSTOLAKIS: It was the same
8 thing.

9 MR. WACKOWIAK: Was it? Okay.

10 MEMBER APOSTOLAKIS: Well, not the same
11 presentation, but, I mean, you know, slides and data
12 analysis, we did this, we did that, without really
13 jumping into the details.

14 MEMBER BONACA: Maybe what they are
15 showing in the afternoon is more --

16 MEMBER APOSTOLAKIS: The staff? No, the
17 staff will tell us what they did.

18 MEMBER BONACA: George, I think the
19 purpose of --

20 MEMBER APOSTOLAKIS: No. I'm talking
21 about what I see here, which hasn't been presented
22 yet, seems to get into more details technically.

23 MR. WACKOWIAK: In some areas, but there
24 are --

25 CHAIRMAN CORRADINI: I don't think we are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 going to answer your question to your satisfaction at
2 this moment. But I think we've got to discuss it,
3 because we're going to have essentially a lapse in
4 time between -- we have a couple more chapters which
5 we have received, that we're going to look at, and
6 then we're going to have a lapse in time where we have
7 about six months that we can call special meetings to
8 get the details.

9 I think -- Sanjoy is not here, but I know
10 he sent me a number of e-mails, and Said has talked to
11 me about thermal hydraulics. And PRA may be another
12 area we're going to have to have a couple of days just
13 for that.

14 MR. HAMZEHEE: George, and I was just
15 going to suggest that the purpose of today's meeting
16 is not really to get into the details of some of these
17 technical areas. This is to give you the overall
18 status, the issues, the significant open items.
19 However, if there are specific areas that you'd like
20 to learn more about, then we have to have those
21 meetings that you mentioned and go over the details.
22 Today, we haven't even gotten to half of our
23 presentation, and half of the day is over.

24 MEMBER APOSTOLAKIS: Right. I understand
25 that, but I don't recall ever having these kinds of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 meetings that you guys are talking about where we have
2 a special meeting, Subcommittee meeting, to talk about
3 data analysis, frequency, or whatever. We never do
4 that. I don't recall it. I mean, it was always
5 thermal hydraulics, 15 Subcommittee meetings, PRA
6 today, and we're done.

7 (Laughter.)

8 PARTICIPANT: Half an hour.

9 CHAIRMAN CORRADINI: Let's go on. We can
10 talk about that this afternoon.

11 MS. CUBBAGE: We'll get you here for a
12 day. I mean --

13 (Laughter.)

14 PARTICIPANT: She's got you. She's got
15 you.

16 (Laughter.)

17 You were set up. You just walked into
18 that one.

19 (Laughter.)

20 MS. CUBBAGE: I mean, the bottom line is
21 we would -- we would come back, if there's topics you
22 want us to discuss. We just need to schedule it.

23 CHAIRMAN CORRADINI: We are going to have
24 to get back to that. Let's let him go on. But you're
25 right, I think we're going to have to.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: And to do the kinds of
2 things you're looking for sounds like, based on doing
3 Reg Guide 1.200 reviews at sites, you know, you'd
4 probably need to book two weeks of time to go over
5 everything that you want to go over.

6 MEMBER APOSTOLAKIS: These are extremes.
7 One extreme is what we are doing today; another
8 extreme is two weeks for data. I mean --

9 MR. HAMZEHEE: George, if you pick a few
10 areas that you are interested, or other members, then
11 we can have like half day one day, special meeting,
12 just on those areas. But you know how broad the PRA
13 is, and we can't really cover every single area in a
14 day, and that's not feasible.

15 MR. WACKOWIAK: And then, when we would
16 set it up, we would have to set it up so that we're
17 not going over all of the same upfront material every
18 time, too. So it's a balance. We'll figure that out,
19 or you guys can figure that out with your schedule.

20 CHAIRMAN CORRADINI: Keep on going.

21 MR. WACKOWIAK: So in data analysis there
22 were no significant open items remaining. Human
23 reliability analysis, we have talked a bit about this.
24 The pre-initiating event values, we have done that
25 evaluation, and we took the list of the important pre-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 initiating events and that's now in the hands of the
2 human factors.

3 MEMBER STETKAR: Back to data, because you
4 skipped it, this is probably a mechanics thing, but I
5 was just curious -- the code -- does CAFTA -- I'm not
6 familiar with CAFTA. Does CAFTA generate the MGL
7 parameter values internally, or do you do that
8 manually and input -- you have those terrible,
9 terrible fault trees with all of that stuff in it.

10 MR. WACKOWIAK: Yes.

11 MEMBER STETKAR: And each basic event has
12 a number.

13 MR. WACKOWIAK: Right.

14 MEMBER STETKAR: Does CAFTA --

15 MR. WACKOWIAK: CAFTA generates those
16 numbers. We put in the --

17 MEMBER STETKAR: You put in the basic --
18 you put in the failure rate, the beta gamma delta
19 values, and it generates -- I think the numbers are
20 wrong. You may want to go look at that.

21 MR. WACKOWIAK: Wow. Okay.

22 MEMBER STETKAR: Because I think if you
23 add up all of the MGL -- all of the failures, they add
24 up to something that is greater than what you started
25 with, which is not correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Okay.

2 MEMBER STETKAR: Check that. We'll get
3 together later. I'll show you the example that we
4 did, because if it's -- if it's something internal,
5 that's just something in the code.

6 MR. WACKOWIAK: We've got to figure that
7 out.

8 MR. HAMZEHEE: I think it happens
9 sometimes, John, when they don't do one minus. So
10 just --

11 MEMBER STETKAR: I don't care. If the
12 code is generating the numbers --

13 MR. WACKOWIAK: Because I know we've done
14 -- early on when we adopted that method we did some
15 backup calculations to show that we were getting the
16 right answers, but it is automatically generated.

17 MEMBER STETKAR: Fine. Go on. I was just
18 curious. That's the only thing on --

19 MR. WACKOWIAK: It's possible that
20 something might be -- the human action-induced
21 initiating events, we talked a little bit about this.
22 It's covered in our discussion of initiating events,
23 but maybe not to the level of detail that you were
24 looking for. We'll have to go into our internal files
25 and maybe get -- if we had a day on that, we could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bring more information.

2 MEMBER BLEY: And I guess what I was
3 getting at is with a passive -- you've used the PRA in
4 a very good way with a design to get rid of the things
5 that were contributors. Now you've got a machine
6 that's a little different.

7 MR. WACKOWIAK: Right.

8 MEMBER BLEY: And maybe the traditional
9 techniques don't do everything. Maybe they don't find
10 what is left, one of the things that might be left is
11 people interfering with some of these functions that
12 I hope to see in 19(a) that you've looked at, and
13 trying to identify some of those rather than saying,
14 "Errors of commission have to be small."

15 I think they might normally be, but it's
16 small compared to a really low number. Now, maybe
17 they're not that small anymore.

18 MR. WACKOWIAK: Right. And the only --
19 but, remember, the only way that that would be an
20 issue is if it's the same type of errors of commission
21 that result in the same types of things that would
22 happen to the plant as the existing plants. If it's
23 low enough in the existing plants it would still be
24 low enough here.

25 It's only when those errors of commission,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 even though they are low, they have some vastly
2 different result in the plant that could increase the
3 risk. So those are the kinds of things that we
4 qualitatively look for, and --

5 MEMBER BLEY: I think we've made that
6 assumption in existing plants, and it might not always
7 be true. But then, a plant with a 10^{-8} core damage
8 frequency at the current time, maybe they're not so
9 small compared to that. So I think it's worth a look.

10 MR. WACKOWIAK: Okay. Also, once again,
11 you know, I think we talked about the HFE. We did a
12 dependency analysis where we went through the
13 quantification and looked for the cut sets that had
14 multiple events and adjusted things accordingly.

15 No significant items in the HRA.
16 Presented the Level 1 results earlier on in the day,
17 so we won't dwell on this. We look a little bit at
18 how it is going to be passed into Level 2. Our
19 designators are slightly different than -- maybe than
20 what were used in the past. CD-1 is a low pressure
21 core damage event; 2 is the long-term; 3 are high
22 pressure core damage events; 4 are events where
23 reactivity had not been under control before the core
24 was damaged; and 5, the Vs, are containment bypass
25 sequences.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: One is low pressure;
2 3 is high pressure; 4 is?

3 MR. WACKOWIAK: Four is the ATWS-type
4 events.

5 CHAIRMAN CORRADINI: Okay.

6 MR. WACKOWIAK: Where reactivity remains
7 high and the containment is really at a higher energy
8 state when the core damage --

9 CHAIRMAN CORRADINI: There is some sort of
10 combination of operator action and lack of recognition
11 that gets you into a problem.

12 MR. WACKOWIAK: Operator actions and also
13 automatic actions.

14 CHAIRMAN CORRADINI: Well, I guess I want
15 to understand the majority of the source of the
16 yellow. Is that failure of squib valves? You said it
17 in your --

18 MR. WACKOWIAK: Yes.

19 CHAIRMAN CORRADINI: So that's the main
20 thing, because I read through it and there was some
21 talk about the PCCS and this and that, and the
22 isolation condenser. Excuse me. But as I understand
23 the way the system operates, when all is said and done
24 that is totally the unavailability -- or the
25 inoperability of enough squib valves to get to -- of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 enough depressurization valves to get you to low
2 pressure.

3 MR. WACKOWIAK: Yes. Almost every cut set
4 will involve the squib valves in some manner, because
5 if the squib valve worked you can't have core damage.
6 So --

7 CHAIRMAN CORRADINI: And according to
8 your --

9 MR. WACKOWIAK: -- about every -- just
10 about every cut set has something that affects those
11 squib valves.

12 CHAIRMAN CORRADINI: And according to your
13 previous -- somewhere in here -- matrix, you need two.

14 MR. WACKOWIAK: Yes, you need two GDCS,
15 and then there is also we say three of the DPVs.
16 Those kind of go together, so you're going to find
17 just about every cut set you will be able to trace it
18 back somehow to affecting squib valves.

19 MEMBER APOSTOLAKIS: But then you do a
20 sensitivity analysis, right?

21 MR. WACKOWIAK: That's right.

22 MEMBER APOSTOLAKIS: And you multiply the
23 failure rate, as I recall, by a factor of 10.

24 MR. WACKOWIAK: Yes. For the squib valve.

25 MEMBER APOSTOLAKIS: Yes. What do you do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about the common cause failure?

2 MR. WACKOWIAK: The common cause failure
3 was also multiplied by 10.

4 MEMBER APOSTOLAKIS: Because the failure
5 rate was multiplied by 10.

6 MR. WACKOWIAK: Right.

7 MEMBER APOSTOLAKIS: Didn't you say
8 earlier this morning, though, that we really don't
9 have any experience with squib valves? What was the
10 original value that was multiplied by 10? What was
11 the basis of the original value?

12 MR. WACKOWIAK: The basis of the original
13 value is probably nuclear powerplant squib valves that
14 we modified by some factor and it's probably close to
15 a factor of eight to account for long test intervals.
16 So it's an increased failure rate over the existing
17 nuclear database of squib valves.

18 MEMBER APOSTOLAKIS: How extensive is that
19 database?

20 MR. WACKOWIAK: It's not. That's the
21 question. It's not --

22 CHAIRMAN CORRADINI: That's the question
23 where we were --

24 MR. WACKOWIAK: The question is that: is
25 that an adequate --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: My ultimate question
2 is: how meaningful is multiplying by 10? Because we
3 are used to orders of magnitude and they say, "Oh, 10,
4 well, that's pretty good. It's an order of
5 magnitude."

6 Well, if the original number was -- had no
7 basis, I don't care that you multiply by 10. That's
8 my problem.

9 CHAIRMAN CORRADINI: Well, I think that's
10 a question that we have listed that Rick noted and
11 can't remember, and we've got to get more information
12 on.

13 MEMBER APOSTOLAKIS: Why does this have to
14 be handled as a sensitivity analysis and not part of
15 the uncertainty analysis?

16 MR. WACKOWIAK: The distribution also
17 covers them on the uncertainty analysis.

18 MEMBER APOSTOLAKIS: Oh, you are putting
19 it in there. I have to remember that. A lot of this
20 stuff is -- it's pretty narrow.

21 MR. WACKOWIAK: Okay.

22 MEMBER APOSTOLAKIS: The broader issue of
23 sensitivity, by the way, I think you have some pretty
24 convincing arguments there. Just that sensitivity
25 analyses always have an element of arbitrariness.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'll take this number, multiply by five. I'll take
2 this other number, multiply by 10, and see what
3 happens. Why don't you put -- multiply by 100? And
4 why don't you do it to all of them? Why do you do it
5 one by one?

6 See, that's the value of uncertainty
7 analysis, that it gets rid of all of this stuff. I
8 think you have --

9 CHAIRMAN CORRADINI: Isn't that just --

10 MEMBER APOSTOLAKIS: What?

11 CHAIRMAN CORRADINI: No, no. No, I wasn't
12 going to say anything.

13 (Laughter.)

14 MEMBER APOSTOLAKIS: Well, I mean, we have
15 point estimates here that show that the numbers are
16 extremely low. They don't reflect the sensitivity
17 analysis, I don't think.

18 MEMBER SHACK: When he does the parameter
19 uncertainty analysis, he gets different numbers, and
20 they are still pretty low.

21 MEMBER APOSTOLAKIS: Right. Because they
22 are limited to the parameters for which you have --

23 CHAIRMAN CORRADINI: But as I understand
24 Rick's -- if I understood his answer to you, then we
25 are eventually going to get, well, it's in Chapter 11,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 I don't remember the result off the top of my head.
2 But he would then have propagated this factor of 10
3 into Chapter 11 uncertainty analysis, and we should
4 see essentially a range of --

5 MR. WACKOWIAK: No, we didn't do an uncert
6 run based on the increased factor.

7 MEMBER APOSTOLAKIS: No, it's a
8 sensitivity.

9 MR. WACKOWIAK: Sensitivity.

10 CHAIRMAN CORRADINI: Oh. I misunderstood
11 you. I thought you said it was also rolled into the
12 uncertainty analysis. Excuse me.

13 MEMBER APOSTOLAKIS: What I conclude from
14 everything they have done is that these individual
15 numbers are not that meaningful. But the risk is low.
16 That's my overall conclusion by looking at everything
17 they have done. Would I have done it different? Some
18 parts of it probably I would have.

19 But all of this stuff that they have in
20 the chapter on sensitivity analysis adds confidence,
21 but I don't know how much. If you ask me, you know,
22 is it 10^{-7} , I don't know. But the stuff they've done
23 is pretty good, but, I mean, why can't we have a
24 complete uncertainty analysis, so that people can say,
25 "Well, gee, you use a 95th percentile for this failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rate for squib valves. Why?" Rather than saying, "I
2 multiply by 10."

3 CHAIRMAN CORRADINI: But you've answered
4 my question, which is --

5 MEMBER APOSTOLAKIS: Which is the most
6 important thing of the meeting, right?

7 CHAIRMAN CORRADINI: Well, because I
8 assume that the depressurization valves with the
9 squibs were causing all of -- most of the yellow, and
10 that is what I wanted to make sure I understood.

11 MEMBER APOSTOLAKIS: Didn't Rosen raise a
12 question about the squib valves? Do you remember,
13 Bill?

14 MEMBER BONACA: For the P-1000.

15 MEMBER SHACK: AP-1000 because they had
16 squib valves that were bigger.

17 MR. KRESS: Bigger. They're the ones
18 that --

19 MEMBER APOSTOLAKIS: These are not.

20 PARTICIPANT: These are 18-inch squib
21 valves.

22 CHAIRMAN CORRADINI: Their fourth stage
23 squibs are enormous, right, because they had stages in
24 one, two --

25 MEMBER APOSTOLAKIS: AP-1000.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Yes.

2 MR. WACKOWIAK: And I think that our --
3 the DPVs are still about a six-inch valve roughly.

4 CHAIRMAN CORRADINI: Okay. Sorry.

5 MR. WACKOWIAK: Okay. One of the things
6 you'll notice when you read the new results, the CD-3
7 is smaller and it moved into the CD-1. The thing
8 there is it's just a Level 1/Level 2 interface. Most
9 of the -- or a lot of the scenarios in CD-3 are
10 associated with stuck open relief valve cases. And
11 what happens is the core starts to melt while the
12 reactor is still at high pressure, but by the time the
13 reactor vessel fails it is already at low pressure
14 from the stuck open valve.

15 So they are probably -- in our current --
16 in the Level 2 results, as you have seen, we have
17 already made that adjustment on the Level 2 side. In
18 the upcoming PRA, we made that adjustment on the
19 upfront side. We used the vessel pressure --

20 MEMBER APOSTOLAKIS: As I recall --

21 MR. WACKOWIAK: -- at the time of
22 containment failure instead of at the time of core
23 damage to decide which --

24 MEMBER APOSTOLAKIS: You run a case where
25 all of the human reliability or human unreliability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 numbers were set equal to unity, right? And you still
2 found that the core damage frequency was 10^{-6} or
3 something.

4 MR. WACKOWIAK: Yes.

5 MEMBER APOSTOLAKIS: Maybe it's a question
6 for the staff. What if the next design does this and
7 they get a core damage frequency of 10^{-3} ? Then, what
8 do you guys do? I mean, as long as these sensitivity
9 analyses work, then everything is fine. But at some
10 point then we say, you know, don't set them equal to
11 one set and you go to .63. See, that's a problem with
12 this kind of approach, because if you do the same
13 thing to the --

14 CHAIRMAN CORRADINI: But the uncertainty
15 analysis --

16 MEMBER APOSTOLAKIS: -- digital I&C, it
17 doesn't work.

18 CHAIRMAN CORRADINI: But the uncertainty
19 analysis --

20 MEMBER APOSTOLAKIS: You built it.

21 CHAIRMAN CORRADINI: But the uncertainty
22 analysis would still have to have a justification of
23 the range that you propagate through the analysis.

24 MEMBER BLEY: You would have to do
25 sensitivity --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Laughter.)

2 CHAIRMAN CORRADINI: I mean, that was
3 going to be my nasty little comment before you said
4 it. All an uncertainty analysis is is a more
5 organized sensitivity analysis, in the sense that you
6 have to justify the range.

7 MEMBER APOSTOLAKIS: It's much better
8 organized.

9 MR. WACKOWIAK: There's a table in the
10 initiating events analysis I think that says what the
11 size of all of the different penetrations are. And
12 you can get an idea from that.

13 MEMBER APOSTOLAKIS: The biggest
14 difference is that you don't do it individually.

15 MR. WACKOWIAK: Yes.

16 MEMBER APOSTOLAKIS: It's not just that
17 you have distributions and you argue. You don't do it
18 individually. You do the whole thing, and you
19 propagate.

20 CHAIRMAN CORRADINI: That I got, kind of.
21 Sorry.

22 MR. WACKOWIAK: And as long as it's
23 associated with the reliabilities of components and
24 things, and that works just fine.

25 MEMBER APOSTOLAKIS: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: I have some slides here
2 that talk about the top five or describe the top five
3 sequences. I don't know, do you want to cover these
4 here? But you get the idea that there are things that
5 are associated -- inadvertent open relief valve is the
6 top cut set -- or top sequence, I'm sorry. Successful
7 scram, feedwater injection failed, high pressure
8 injection also fails. Our CRD pumps are our active
9 high pressure injection system.

10 Low pressure systems fail because of
11 manual depressurization failure, but the ADS is
12 successful. Vacuum breakers are successful to keep
13 the containment in an operable state. And low -- once
14 again, low pressure injection, asked after ADS, is
15 unsuccessful. Vessel fails is low pressure.

16 And then the last piece there, the lower
17 drywell water level is low. Our calculations show
18 that it's less than .7 meters in the lower drywell.
19 So that affects what's going on in the Level 2.

20 The next one is an ATWS sequence. That
21 starts from a general transient. Once again, in this
22 scenario, we didn't specifically ask what happens to
23 the depressurization. But when we looked at this
24 sequence in this past, we find that most of the -- we
25 did a split fraction for depressurization. Most of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the sequence would end up in the low pressure end of
2 it, and, once again, in the containment analysis it
3 turns out that it didn't matter which bin we put it
4 in. So we just assumed low.

5 Loss of feedwater event --

6 MEMBER SHACK: Just on these low drywell
7 water levels, there is some cryptic remark in there
8 that you rerouted the GDS spillover to keep the water
9 levels in the lower drywell below the magic 1.5
10 meters.

11 MR. WACKOWIAK: Yes.

12 MEMBER SHACK: But I can't find any
13 description of what in the hell was done.

14 MR. WACKOWIAK: Because it's magic.

15 (Laughter.)

16 CHAIRMAN CORRADINI: So it's not my
17 imagination that I couldn't figure that out either.
18 I sent him an e-mail saying I couldn't understand your
19 water management.

20 MR. WACKOWIAK: No. It's probably a
21 manifestation of the several iterations of the DCD and
22 the PRA. But what we did is we set the spillover line
23 high enough that the suppression pool won't spill back
24 into the lower drywell.

25 CHAIRMAN CORRADINI: And why is that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 why is that an important thing?

2 MR. WACKOWIAK: If we have a steam --

3 CHAIRMAN CORRADINI: Where does it spill,
4 then?

5 MR. WACKOWIAK: -- leak into -- if we have
6 a steam leak into the drywell, and GDCS doesn't work,
7 so we're not injecting into the vessel with GDCS, what
8 happens is the steam that goes into the drywell is
9 condensed in the PCC heat exchanger and puts into the
10 -- goes into the GDCS pools. Since they are not
11 draining, they overflow.

12 We have a design in the plant so that if
13 it just overflowed onto the floor it would go to the
14 lower drywell, and all sequences would have a high
15 lower drywell water level, right, because that's where
16 it ends up. So, instead, we put -- for lack of a
17 better term -- gutters on the GDCS pools, so the water
18 that spills over the GDCS pools goes into the
19 suppression pool area and is stored there.

20 We raised that spillover line high enough
21 such that you could boil all of the water out of the
22 vessel in these scenarios and you still don't end up
23 with a suppression pool level high enough to spill
24 water into the lower drywell.

25 In the latest version, in your new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Chapter 19, those gutters on the GDCS pools actually
2 list it as a design requirement coming out of the PRA.

3 CHAIRMAN CORRADINI: So can you just --
4 can I just say it back to you so I get it right? So
5 if there is some sort of overflow or GDCS, it has
6 essentially a rain gutter which sends it to a
7 suppression pool, and the suppression pool -- even
8 with all the water inventory in the RPV, it will not
9 overflow in the lower drywell.

10 MR. WACKOWIAK: Right.

11 CHAIRMAN CORRADINI: As I finally got --
12 we can hold this off until later. But as I finally
13 got to explain it -- as I finally got to some picture
14 in your PRA, you showed a combination of insulation in
15 the pedestal and flow areas, and I was trying to
16 figure out where the water accumulated. If it didn't
17 accumulate in the suppression pool, and it couldn't go
18 in the lower drywell, it seems to pile up along the
19 shield.

20 Am I misunderstanding, or can we just --
21 and if we can wait until later when we talk about the
22 Level 2, because this kind of has an interest to me
23 with Level 2. But I guess I still don't get it on how
24 you are keeping it out. Except for condensation --

25 MR. WACKOWIAK: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: -- how you keep it
2 out of lower drywell. I mean, I understand this one
3 part, but there is other things in getting --

4 MR. WACKOWIAK: For things that are LOCAs
5 that discharge the water into that area around the
6 vessel, we assume that that all does go to the lower
7 drywell.

8 CHAIRMAN CORRADINI: Oh.

9 MEMBER SHACK: But break -- is that a
10 break inside the shield wall? It goes to the lower --
11 and then, well, how about a break outside the shield
12 wall? Is there something that caps that part? No,
13 because the skirt is not --

14 MR. WACKOWIAK: No. But if the water can
15 get to the lower drywell, we're not counting on any
16 kind of insulation or anything holding it out of the
17 -- holding it out of the lower drywell.

18 CHAIRMAN CORRADINI: So it's just the
19 accident sequence that determines the --

20 MR. WACKOWIAK: How much water comes in.

21 CHAIRMAN CORRADINI: -- water level. I
22 thought it was -- there was a -- I misunderstood. In
23 reading a certain part of the PRA, I got the
24 impression there was a design effort to -- except for
25 condensation, to keep water out of the lower drywell.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MR. WACKOWIAK: No. It's this overflow --
2 overflow from the GDCS pools is what our effort was.

3 CHAIRMAN CORRADINI: Okay. Thank you.

4 MR. WACKOWIAK: And the instructions to
5 the operators not to spray until after the core is out
6 of the vessel.

7 The top five are all -- they are in your
8 slide packages there, and they are in the case. So
9 the --

10 CHAIRMAN CORRADINI: Before you go to
11 this, I'm going to look at the Committee. Is this the
12 time for a break for lunch? Because you are now going
13 to go through containment performance analysis, the
14 off-power events, and then to Level 2, is that
15 correct?

16 MR. WACKOWIAK: I'm going to go through --
17 I'm going to do the Level 2 right now, and then we're
18 going to go to the external events, and then we'll go
19 to shutdown events.

20 MEMBER APOSTOLAKIS: How much time do you
21 need, Rick?

22 MR. WACKOWIAK: Three more days probably.

23 (Laughter.)

24 I'm trying to wrap it up as fast as I can,
25 because we still have RTNSS to do this afternoon.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 RTNSS is a much shorter package, though.

2 MEMBER SIEBER: Well, you're almost
3 halfway done with --

4 MR. HAMZEHEE: And the staff presentation,
5 Rick. We haven't even talked yet.

6 MR. WACKOWIAK: I know you haven't talked
7 yet.

8 MEMBER APOSTOLAKIS: The staff may not get
9 a chance to present.

10 MR. WACKOWIAK: No. We need to --

11 CHAIRMAN CORRADINI: Move on.

12 MR. WACKOWIAK: The current schedule has
13 us, oh, going for another 12 minutes before I'm
14 supposed to be done.

15 CHAIRMAN CORRADINI: So why don't you try
16 to do the containment performance analysis, and then
17 we'll break for lunch.

18 MR. WACKOWIAK: Okay. And we've talked
19 now it has been probably two years, or more than two
20 years since we talked about this. We based our severe
21 accident evaluation on the ROAAM methodology to
22 determine which sorts of things in the containment
23 area now should be treated probabilistically, the
24 systems in which things -- which things should not be
25 treated in that way and treated in a bounding way, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that will be the different phenomenon.

2 Our containment system models -- it's --
3 we now have -- or this -- we have fault trees. Now we
4 have -- it has been that way since Rev 2. We have
5 fault trees for things like the vacuum breakers, and
6 the other systems that are in the containment model.
7 They are linked into the containment event tree. And
8 when I say a fully-linked model, we take it all the
9 way from the initiating event now through the Level 2,
10 all the way to the Level 2 end states, and without a
11 -- you know, calculating point estimates and
12 transferring them to a different model.

13 As a matter of fact, these days, when we
14 calculate the Level 1, we just run the whole Level 2
15 model and extract the Level 1 results from the Level 2
16 model.

17 MEMBER STETKAR: Does that mean all of the
18 systems, the support systems are fully linked in
19 Level 1 and Level 2?

20 MR. WACKOWIAK: Yes.

21 MEMBER STETKAR: I thought you were
22 binning --

23 MR. WACKOWIAK: We used to. Starting in
24 Rev 2, we made it fully linked.

25 MEMBER STETKAR: Well, it said fully

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 linked, but I don't understand the mechanics of -- you
2 actually link the event trees together.

3 MR. WACKOWIAK: Yes. It's --

4 MEMBER STETKAR: Okay.

5 MR. WACKOWIAK: Yes. It's one big model,
6 and the way it's set up we can take the results, we
7 put it into a spreadsheet and tell the spreadsheet,
8 okay, give me the Level 1 results, or give me the
9 Level 2 results. It's all the same thing.

10 And then, as we mentioned earlier, any
11 release larger than the allowed leakage, which is
12 leakage through the containment liner, is considered
13 large in our model.

14 We've talked about -- years ago -- but our
15 containment event trees. This particular one is the
16 low pressure Class 1 with lower drywell water level.
17 This would be attached into our event trees as one of
18 the end states. We asked the deluge line, which is a
19 model of the squib valves and the power supplies now,
20 and the next question, is debris successfully cooled?
21 That comes from ROAAM. Whether or not the BiMAC
22 performs like it's supposed to.

23 Containment isolation system is asked.
24 That's a system model again. Vapor suppression
25 function is the vacuum breaker function. Containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat removal short term is PCCS. Containment heat
2 removal long term is refill of the pools, and residual
3 heat removal systems.

4 And then, there is operation of the vent,
5 and, once again, that is for our purposes. But for
6 generating the radiological releases, but filtered
7 release and overpressurization both still end up in
8 LRF. So the LRF model both -- anything other than
9 sequence 1 is considered LRF.

10 MEMBER APOSTOLAKIS: LERF with an E?

11 MR. WACKOWIAK: L-R-F.

12 MEMBER APOSTOLAKIS: Oh.

13 MR. WACKOWIAK: Yes. I don't know that
14 there's any earlies in this plant.

15 Just to get an idea of what kind of
16 results we get from our Level 2, almost everything
17 falls into our category that we call TSL, which is the
18 allowed leakage. TSL just happened to creep in as our
19 -- one of our acronyms, but it's the intact
20 containment. Tech spec leakage is what it stands for,
21 but it's -- we don't really leak that much, but it's
22 what is allowed.

23 Filtered release is small. Containment
24 bypass is the next one. This is containment bypass
25 where the release is into the containment, and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the containment is open and it goes out, as opposed to
2 the one down at the bottom, which is a break outside
3 containment, where it's just -- there is no
4 containment involved at all in that in those
5 scenarios.

6 CHAIRMAN CORRADINI: And that would be
7 what? A break outside containment?

8 MR. WACKOWIAK: Reactor water cleanup line
9 break, main steam line break, where the isolation
10 valves fail.

11 CHAIRMAN CORRADINI: Oh, okay.

12 MR. WACKOWIAK: Those types of things.

13 CHAIRMAN CORRADINI: Okay. Thank you.

14 MR. WACKOWIAK: We have overpressurization
15 due to vacuum breaker failures, overpressurization due
16 to the other two containment heat removal sources, the
17 RHR systems, and then the PCCS long term.

18 CCIW, which is the -- we have core-
19 concrete interaction, but there is a water -- overline
20 water pool on top of the melt. And what this is --
21 this case is the one where the BiMAC doesn't function
22 for some reason, and in this particular case it would
23 be because some type of -- well, no, that would be a
24 different -- the BiMAC doesn't -- itself doesn't
25 function. These results are from the previous, before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we had the test done, so I think we assumed that it
2 had a 10^{-2} failure for the BiMAC. We'll talk a little
3 bit more later. I hope to get to that about --

4 CHAIRMAN CORRADINI: So do I.

5 MR. WACKOWIAK: -- what we have come up
6 with.

7 CCI dry, which means the water didn't get
8 down there to the BiMAC, and then the areas where
9 there is an ex-vessel explosion. That's where we have
10 a deep subcooled water in, and the material comes out
11 of the vessel, and we have a steam explosion that
12 fails either the BiMAC pipes or the drywell hatch,
13 leading to a release.

14 Direct containment heating turns out to be
15 a -- physically, the containment failure due to direct
16 containment heating we have determined to be
17 physically unreasonable. Everything is within the
18 loads of our design. We --

19 CHAIRMAN CORRADINI: So you can have --

20 MR. WACKOWIAK: -- for completeness, but
21 we have -- in the Chapter 21 we have determined that
22 it is not possible to get to the right set of
23 parameters needed, amount of melt, ablation rates,
24 discharge rates, to get to a point where the
25 containment would be failed by the DCH event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Are we going to talk
2 about this again in the severe accident -- or severe
3 accident --

4 MR. WACKOWIAK: I've got some slides on
5 it, and I hope --

6 CHAIRMAN CORRADINI: Well, I guess I -- I
7 tried to read through this, and I understood -- I
8 understood what was being said. I didn't understand
9 why you excruciatingly went to do an EVE, but said
10 this one can't happen, because if I --

11 MR. WACKOWIAK: We excruciatingly went and
12 did both of them, and this one turned out that we
13 couldn't fail containment, and EVE turned out to be --

14 CHAIRMAN CORRADINI: Because the loads
15 were just not hitting the --

16 MR. WACKOWIAK: Right.

17 CHAIRMAN CORRADINI: Okay.

18 MR. WACKOWIAK: And it turned out that we
19 could set up an EVE case where the loads would fail
20 the containment. So we went to excruciating detail in
21 both of them.

22 MEMBER APOSTOLAKIS: So physically,
23 unreasonable means that it's -- it's what, it's
24 impossible or it's --

25 MR. WACKOWIAK: You can't set up the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conditions for it to happen. We would either need a
2 core that was three times the size of the one that's
3 in the vessel, or we would need physical properties of
4 the vessel, so that it would ablate, so fast that the
5 -- much faster than seen in any previous experiments.
6 Just -- we just can't set up a case that would drive
7 the pressure up high enough to fail the containment.

8 MEMBER POWERS: So what experience do you
9 know of for ablating the vessel?

10 MR. WACKOWIAK: I would have to go back
11 and look at the report. I don't have -- I haven't
12 looked at that in a while. Don't remember.

13 CHAIRMAN CORRADINI: But I think where I'm
14 going with it -- I'm not sure if Dana is going the
15 same way -- but in the analysis that I remember -- and
16 I can find it somewhere in here -- there were
17 calculations done that showed large pressures that
18 went beyond the capability of the -- and they were
19 deemed unphysical why?

20 MR. WACKOWIAK: Well, what we --

21 CHAIRMAN CORRADINI: Because the release
22 rate was deemed unphysical? Because I --

23 MR. WACKOWIAK: What we did -- what we did
24 in that, we calculated our best estimate, and that's
25 not shown in these slides. I don't know. Sometimes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we -- we don't show the thing that we expect, but we
2 show the thing we don't. But anyway, we had the best
3 estimate, which didn't challenge the containment.
4 Then, we did an evaluation with the parameters set to
5 the upper bound from the various experiments that we
6 looked at, and we didn't fail the containment.

7 And then we said, okay, what is it going
8 to take to fail the containment? What kind of
9 parameters do we have to put in there to make it fail
10 the containment? And when we look at what those
11 parameters are, it turns out to be things that just --
12 that can't happen.

13 CHAIRMAN CORRADINI: But it was due -- I
14 guess I'm back to Dana's question, because I had the
15 same thing. It looked like release rate was the
16 dominant --

17 MR. WACKOWIAK: Right.

18 CHAIRMAN CORRADINI: Okay. Reason that
19 you weren't making it.

20 MR. WACKOWIAK: Right.

21 CHAIRMAN CORRADINI: Not inventory but
22 release rate.

23 MR. WACKOWIAK: The release rate was one
24 of the more dominant -- or was probably the dominant
25 one. But, once again, the upper bound case, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 case 2 where we used the bounding parameters observed
2 in -- and, once again, I'll have to look it up, which
3 -- in the experiments that gave us that case, the case
4 where the pressures went up high, we adjusted things
5 beyond that.

6 We do have a significant open item in the
7 Level 2. Further information was requested on the
8 vacuum breaker design, that we have the -- some of the
9 information about the vacuum breakers in ITAAC, and
10 also what happens with the emergency procedures
11 related to a failed vacuum breaker.

12 We have responded to these in RAI
13 responses, and so far the preliminary information we
14 have is that that response was satisfactory. There is
15 -- just to build on that, there is further vacuum
16 breaker design discussed in Chapter 6, and I know you
17 guys talked about that in detail here a couple of
18 months ago. And we do have a COL item that is
19 established to develop the emergency procedures as
20 part of the COL process.

21 MEMBER STETKAR: Is the new version of the
22 PRA updated to include the changed isolation valve
23 design?

24 MR. WACKOWIAK: Yes. Yes, the current
25 version of the PRA that we sent this week covers all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the design included in DCD Rev 5. There is no
2 delta anymore between the PRA and the DCD.

3 Now, we'll cover how we've covered that in
4 a minute, but -- okay. In the source terms, you know,
5 it -- you'll probably say I didn't do justice to these
6 topics here in this meeting, but, you know, we
7 evaluated 15 different release categories and decided
8 which ones were representative sequences. Pretty
9 standard stuff here.

10 Calculated the magnitude and timings of
11 the releases and presented that information. In
12 Chapter 9 of the PRA, there is an extensive set of
13 plots and other things that -- I know the staff has
14 done confirmatory analysis on those. No significant
15 open items came out of that, and if you want to get
16 into detail, it would probably be a different meeting.

17 Offsite consequences -- we used a -- what
18 we consider a bounding site, but, you know, once again
19 it came from the ALWR URD. It appears to remain
20 bounding, but 60 years from now who knows if it will
21 still be bounding. We do have quite a bit of margin
22 in the results.

23 What we find is that, from our dose
24 results, most of the dose risk is associated with the
25 containment intact sequences. The individual risk,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which is an early fatality within one mile of the site
2 boundary, that's dominated by ex-vessel explosion,
3 which was -- you know, it's clear that that just
4 breaks the containment and there's an unscrubbed
5 release from those scenarios, so that's reasonable.

6 The societal risk, which is latent deaths,
7 out to a 10-mile boundary, half of that comes from
8 EVE, about a quarter or a fifth from the bypass
9 events, and another 10 percent from the break outside
10 containment events. All scenarios that we would have
11 expected unscrubbed releases to the environment.

12 MEMBER ARMIJO: Now, in this analysis, no
13 one evacuates, no one --

14 MR. WACKOWIAK: No one evacuates.

15 MEMBER ARMIJO: -- takes any special
16 precautions, and you have this population just doing
17 what it was doing.

18 MR. WACKOWIAK: Just doing what they were
19 doing, and we did some sensitivities and looked at
20 different energy and plume and weather conditions, and
21 found that if certain weather conditions, especially
22 when it's more asymmetric like along the Southern
23 coast, they tend to give you a little different
24 result.

25 But we've included sensitivities from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other types of weather patterns, population
2 distributions, and I think what we found is the
3 population distribution has to go up by orders of
4 magnitude before we start bumping up against the -- up
5 against the stated limits for these.

6 So, yes, while we recognize that the
7 population might not be exactly right, so many years
8 from now it might not be bounding anymore, it would
9 have to change by a real lot before it would be an
10 issue.

11 MR. KRESS: The ex-vessel explosions
12 require water being in the bottom head floor.

13 MR. WACKOWIAK: In the lower --

14 MR. KRESS: Yes, so that frequency is
15 driven by the flood system --

16 MR. WACKOWIAK: No.

17 MR. KRESS: -- not getting water?

18 MR. WACKOWIAK: No. This is -- those are
19 driven by scenarios where the -- they are basically
20 LOCAs, where the LOCA is discharged into the lower
21 drywell.

22 CHAIRMAN CORRADINI: That gives you the
23 1.5 meters?

24 MR. WACKOWIAK: It depends on the size of
25 the break, but if the break is big enough then that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gives us the 1.5 meters in the lower drywell. And
2 it's -- we've shown that it's possible to have those
3 steam explosions.

4 Now, will it happen every time? Probably
5 not. But it is possible, and it is possible to get
6 enough force out of one of those explosions to fail
7 the containment. So for this -- for the purpose of
8 this analysis, we've assumed that it does every time
9 if there is water down there.

10 CHAIRMAN CORRADINI: So just one last --
11 I'm sorry, Tom.

12 MR. KRESS: Go ahead. That answered my
13 question.

14 CHAIRMAN CORRADINI: So when you say
15 "fail," what is -- I guess I'm back to the 29 percent,
16 72 percent, and 50 percent. What does "fail" mean
17 here, above surface release? Are you assuming
18 something relatively severe? Because this strikes me
19 as surprising I guess. I'm trying to understand what
20 the failure is. What are you taking as the failure?
21 Just an open containment at a high vent?

22 MR. WACKOWIAK: Everything is assumed to
23 be vented from the reactor building. So it's a kind
24 of sort of high vent. It's, you know, a few meters.
25 It's not --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay.

2 MEMBER SHACK: It's not an elevated
3 release by any --

4 CHAIRMAN CORRADINI: All right. That
5 answers my question. Thank you.

6 MEMBER SHACK: What does that bullet --
7 the containment intact sequence is 29 percent EVE?
8 But the containment is not intact if you get --

9 MR. WACKOWIAK: I said mostly from
10 containment. TSL is containment intact.

11 MEMBER SHACK: Okay. So this --

12 MR. WACKOWIAK: I was referring to the --

13 MEMBER SHACK: It's referring only to the
14 .58 percent.

15 MR. WACKOWIAK: Yes. I could have done
16 that better.

17 MEMBER POWERS: The containment intact
18 sequences are dominated by iodine?

19 MR. WACKOWIAK: I think so, but I'm going
20 to have to go back and look. I'm trying to remember
21 what the graphs look like, and I'm just not getting
22 there right now.

23 MR. KRESS: Are those the results that
24 come out of the MAAP code?

25 MR. WACKOWIAK: We generate the source

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 term from MAAP, and then we take the table of source
2 terms from MAAP with the magnitude and the timing and
3 input to MAACS-2. Now, MAACS has some limitations.
4 You know, there is only -- you can only consider 24
5 hours of time, and things like that, so we take -- so
6 some cases will take a 72-hour release and compress it
7 into 24 hours, just so the code will work.

8 MR. KRESS: Well, with MAAP, iodine would
9 be considered an aerosol data.

10 MEMBER POWERS: Why would that be correct?

11 MR. KRESS: Pardon?

12 MEMBER POWERS: Why would that be correct?

13 MR. KRESS: That's a question. But it --
14 the release rate treats it like an aerosol. Not the
15 release rate, the behavior in containment has a --
16 treats it as an aerosol.

17 MEMBER POWERS: The control rods are
18 boron-carbide blades?

19 MR. WACKOWIAK: Yes.

20 MEMBER POWERS: Went from stainless steel
21 to boron-carbide -- similar to what you have in
22 existing --

23 MR. WACKOWIAK: I'm guessing it is. I
24 don't know why it would be different.

25 MEMBER POWERS: What do you use for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 oxidation of the boron, steam oxidation of boron?

2 MR. WACKOWIAK: I am not prepared to
3 answer that. The question hadn't come up.

4 MEMBER POWERS: The problem is that, the
5 steam oxidation of boron produces boric acid. Boric
6 acid reacts with everything, so there is nothing to
7 form particular with iodine, so you get a strong
8 gaseous component. That gaseous component comes into
9 your containment. I assume you try to scrub it with
10 the PCCS, but, at the same time, you are
11 radiolytically attacking air, cabling, and what-not,
12 that's acidophil in the water. That comes back out of
13 the water.

14 So I would think that, especially for
15 containment intact, it would be gaseous iodine that
16 would dominate.

17 MR. KRESS: Well, we had this question
18 earlier, and we are awaiting an answer. It seems like
19 you are continually pumping iodine into the
20 containment, because of --

21 CHAIRMAN CORRADINI: But I think at the
22 time when you -- when we had this, the acidification
23 was due to the fact that -- was due to the fact of the
24 -- what you were saying was the process of the
25 radiolysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's the last time I remember we were
2 bringing this up, because they were MELCOR
3 calculations that the staff showed at some point. I'm
4 trying to think. It was maybe Chapter 6 discussion.

5 MEMBER POWERS: There are three ways to
6 facilely acidify water. There is a lot of ways to
7 acidify water that people speculate about, but three
8 ways that have been demonstrated to acidify water.

9 Air radiolysis forms nitric acid. It
10 tends to be slow. Radiolytic or pyrolytic
11 decomposition of cabling insulation. Tends to be kind
12 of intermediate. And radiolytic and dissolution
13 attack on paint, and solvents in paint especially.
14 There are keytones, and they are relatively readily
15 oxidized to carboxylic acids. And that tends to be a
16 short-time acidification.

17 MR. WACKOWIAK: And for those particular
18 failure -- or for those particular modes, I know there
19 are ITAAC to address some of those things. There is
20 a maximum mass of cable insulation that is in ITAAC,
21 and then there is also an ITAAC on coatings that could
22 potentially generate or acidify the pool. So I think
23 that's how that was addressed, but I don't -- this was
24 addressed outside of the PRA area.

25 MEMBER POWERS: Are you thinking of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 solvent-free coatings in this containment?

2 MR. WACKOWIAK: I'm not sure what the --
3 what they are considering there. I know that there is
4 an ITAAC that addresses coatings. Don't know the
5 details behind that. I just know that they have
6 addressed it.

7 MEMBER POWERS: You've done a lot of work
8 recently on solvent-free coatings. Not because of
9 severe accidents or anything like that. It's because
10 people just don't want to put up with the solvents and
11 all of the hassles of EPA and everything like that.
12 And they're very good. They're very interesting
13 coatings.

14 MS. CUBBAGE: I think in the context of
15 Chapters 6 and 15, we owe you -- GE and the staff owe
16 you another presentation on that. There are a number
17 of open issues in that area still. I think that will
18 get to those issues.

19 MR. WACKOWIAK: All you'd get from me is
20 what I remember rather than anything that might be
21 right.

22 MEMBER POWERS: Which is probably more
23 than I remember. The older I get, the less I
24 remember. What was your name again?

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Offsite consequences, we
2 had no open items, or no significant open items.

3 CHAIRMAN CORRADINI: So at this point, I
4 would like to take a break for lunch, if it's all
5 right with folks. And I'd like to ask that we're back
6 by 1:15, 35 minutes. I'm sorry.

7 (Whereupon, at 12:38 p.m., the
8 Subcommittee recessed for lunch.)

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

2 (1:31 p.m.)

3 MR. WACKOWIAK: Let's try to get back on
4 schedule. Where we left off was in the uncertainty
5 and sensitivity analyses. We've talked about various
6 things throughout the morning, so I think we -- I
7 understand what your issues are in the uncertainty
8 area and propagating more data.

9 MEMBER APOSTOLAKIS: So, Rick, for
10 example, you mentioned that your --

11 (Laughter.)

12 I interrupted you?

13 MR. WACKOWIAK: No. No, no. Go ahead.

14 MEMBER APOSTOLAKIS: We are grown men.

15 MR. WACKOWIAK: We are?

16 MEMBER APOSTOLAKIS: For design
17 certification purposes, even though I wouldn't do it
18 that way, I think you are succeeding. But if you want
19 later to use this for risk-informed applications,
20 regulatory applications, I don't think that a
21 sensitivity analysis will do it.

22 MR. WACKOWIAK: Okay.

23 MEMBER APOSTOLAKIS: Because I don't know.
24 Should I be using the results with a factor of 10
25 higher rates for the squib valves or not? I mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is the problem you are running into. But if you
2 want to say the design is robust, and this and that,
3 I think the totality of these calculations gives me
4 that confidence.

5 CHAIRMAN CORRADINI: But if I can just
6 make sure I understand, George. If you were to
7 encapsulate all of the variations within an
8 uncertainty analysis, you still have to justify the
9 ranges, and that is not going to be by just changing
10 how you do the analysis. That's going to have to be
11 by essentially discussing how the data was developed
12 and --

13 MEMBER APOSTOLAKIS: But I would submit
14 that it's easier to justify a distribution than a
15 single number. And other people think it is the other
16 way around, but it isn't. It's easier to justify a
17 range of numbers with probabilities and say, "I will
18 multiply by a factor of 10."

19 MR. KRESS: And your comment about the --
20 when you used the distributions, you fold in all of
21 the uncertainties, whereas you're doing one at a time
22 with the --

23 MEMBER APOSTOLAKIS: You schedule one at
24 a time. Now, would it make a big difference?
25 Frankly, I don't think so. I don't think so. But it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would be nice to --

2 CHAIRMAN CORRADINI: But the way you would
3 fold in all of the -- all of the -- fold in the
4 distribution was simply because you would have a
5 discussion about coming to some consensus of what it
6 ought to be bounded by.

7 MEMBER APOSTOLAKIS: No. I would like at
8 the end when we say, "Yes, the risk is, you know,
9 eight 10^{-8} ," or whatever, to have a feeling that that
10 really comes close.

11 CHAIRMAN CORRADINI: I just want us to
12 take the squib valve as an example, because Said asked
13 about data -- the database or the data source. And to
14 the extent that you've got the data source, and you
15 looked at it and kind of went, oh, there's only 30
16 experiments, and they are kind of scattered,
17 eventually you've got to get a few people together and
18 say, "Okay. Given what you know, this is the
19 approximate shape."

20 That -- your point is that -- that
21 exercise, in and of itself, is valuable.

22 MEMBER APOSTOLAKIS: Of course, yes. And
23 that it will be easier to defend this curve rather
24 than a single number, you know, multiplied by 10.

25 CHAIRMAN CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: And I think I agree that
2 that would be the case, that would be easier to
3 defend. But sometimes when you just have the number,
4 the -- you can't do as many things with just the
5 number when we look at, you know, putting things into
6 DRAP and maintenance rule, you have to do other
7 things. So important to do, and I think eventually
8 we'll get there.

9 MEMBER APOSTOLAKIS: I'm not saying it's
10 easy or straightforward, but look what we are doing
11 over here. We say, okay, here is the pie, the
12 distribution, the contributions. This is the dominant
13 sequence. All that is based on the point values,
14 isn't it?

15 MR. WACKOWIAK: Right.

16 MEMBER APOSTOLAKIS: And then, on the side
17 we say, well, we also did a sensitivity and jumped up
18 a little bit. But the fundamental approach is those
19 point values. The results are all -- again, I am not
20 -- for present purposes, I suspect this is --

21 MEMBER SHACK: Of course, while you were
22 out of the room, he did show a mean value, George.

23 (Laughter.)

24 MEMBER APOSTOLAKIS: Lower than the point
25 estimate. Last time it was higher. It was higher.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Two years ago it was higher.

2 PARTICIPANT: That was then; this is now.

3 MEMBER APOSTOLAKIS: Sorry?

4 PARTICIPANT: That was then; this is now.

5 MEMBER APOSTOLAKIS: That was then; this
6 is now. Yes. We have very powerful arguments today.

7 Anyway, why are we --

8 MEMBER SIEBER: So it really would be very
9 important for us to look at the sources of data and
10 the nature of the data of -- that was used to come up
11 with the failure rates for the squib valves,
12 because --

13 MEMBER APOSTOLAKIS: Now that they gave us
14 permission to have many Subcommittee meetings, we will
15 try to complete with the Thermal Hydraulics
16 Subcommittee.

17 MR. WACKOWIAK: Okay. Speaking of thermal
18 hydraulic, one of the significant open items in the
19 uncertainty and sensitivity was the thermal hydraulic
20 uncertainty. We talked about that in the accident
21 sequence slides from the thermal hydraulic side. We
22 covered this in two ways. I think there was a
23 presentation on this before where we also looked at it
24 from the probabilistic side.

25 Basically, what we did was we -- we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 adjusted the success criteria in our event -- in our
2 fault trees to find information about what type of --
3 how bad would our estimates need to be before it had
4 a large impact on the risk results. And so we looked
5 at the GDCS valves, DPVs, and the PCCS heat exchanger.

6 In the design basis, there is just -- it's
7 just evaluated as a single failure. It does no good
8 for us to look at those design basis calculations in
9 the PRA. But basically what we did was we started
10 from there, and then we added redundancy, so it's
11 success criteria. So one failure was a failure of the
12 system; then, two, a failure of the system; three,
13 failure of the system; to see where the numbers would
14 break.

15 MEMBER SIEBER: This is just sort of a
16 sensitivity essentially on the boundary conditions.

17 MR. WACKOWIAK: Right. We wanted to look
18 at the --

19 MEMBER SIEBER: Not on the physics for
20 what you're modeling.

21 MR. WACKOWIAK: It's not on the physics.
22 That's right. We looked at it two different ways.
23 With TRACG, we're trying to look at the sensitivity on
24 the physics. And here we are trying to get an idea of
25 what would it do to the PRA if we came up with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different number after looking at the physics.

2 And I think we have gone -- we went
3 through this in a previous meeting more in detail, but
4 in the end, as long as we have any redundancy left --
5 so we have six -- if the success criteria comes out to
6 be six of eight GDCS valves, that's about where it
7 changes. Whether it's two, three, or four, would
8 really make not much difference to the results, save
9 for --

10 MR. KRESS: Success was if the core stayed
11 covered?

12 MR. WACKOWIAK: Success in these cases was
13 that the -- that we did not get significant heatup in
14 the -- I'm sorry. Success was the core stayed covered
15 in our -- in this set of sensitivities. In the
16 thermal hydraulic sensitivity, or area where we were
17 looking with TRACG, we were looking at the rapid rise
18 in the core heatup.

19 MR. KRESS: So the reactor looked at the
20 temperature that --

21 MR. WACKOWIAK: Yes. We looked at that.
22 In the other analysis that isn't -- hasn't been
23 submitted yet, and we haven't brought that here.

24 CHAIRMAN CORRADINI: So just so I
25 understand this, the curve you showed previously, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 purple, as we're going to the right, we're just having
2 more and more of the GDCS pipes failing to operate.

3 MR. WACKOWIAK: Yes. There's different
4 cases on there -- GDCS, DPVs, and PCCS. It's -- what
5 it's saying is: do we need two, or do -- do we need
6 two, do we need three, four, five, six, seven,
7 eight --

8 PARTICIPANT: Failures.

9 MR. WACKOWIAK: -- failures. No, for
10 success. So in this case, one failure of anything
11 would be core damage. In this case, you need two
12 failures, this case you need three failures, four
13 failures, five, six, on down the line. And there's a
14 couple of things that aren't exactly one through six
15 in there, because there were different combinations.

16 The purple bar was something that we
17 looked at with the PCCS heat exchangers. Our base
18 model does assume some unavailability for maintenance
19 of those heat exchangers, but we are not convinced
20 that those heat exchangers are going to be maintained
21 later on down the line.

22 So basically the PCCS has -- without the
23 maintenance concern, it breaks much later with the
24 number of PCCS heat exchangers.

25 So what we concluded from this is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 while, yes, we still want to understand the success
2 criteria based on the thermal hydraulics codes and
3 what the codes are telling us, we are confident, after
4 looking at this, that even if we are off by a little
5 bit in those -- in the codes, one way or the other,
6 and the success criteria that we used is robust, and
7 the results won't change if we -- if some time later
8 in a different analysis we have to adjust success
9 criteria by one component or one heat exchanger. And
10 I said that -- that part of this has been given to the
11 staff already.

12 The fire risk assessment now, starting
13 with Rev 2, we are using NUREG-6850 methods. It is --
14 we talked about it a little bit today already. It's
15 -- we couldn't do everything that you would do -- no
16 fire modeling. So the assumption is all fires grow to
17 be fully developed and affect the whole area.

18 As it was asked before, what about
19 propagation in the other areas? Yes, we have a
20 probability of a failure of fire barriers, allowing it
21 to go into the next area. We also did a look there of
22 propagation of smoke between different areas with the
23 -- in the ventilation system, and that's described in
24 the report.

25 No credit for the suppression. And we did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make an assumption. Our I&C design is supposed to be
2 set up such that if -- if the cabinet that contains
3 the logic cards does start to fail, that it is not
4 possible for it to be spuriously issuing commands out
5 into the field. And there is -- we can get into more
6 detail about how that is structured.

7 We don't think it can happen. However,
8 for the cases where we have multiple fires, or fires
9 spreading between multiple rooms where these
10 processors are, we add a non-mechanistic SRV actuation
11 to the case. Basically, what that does is it causes
12 a failure of the ICS. So it's -- when the fires
13 spread between -- to multiple rooms, we reduce our
14 capability to respond with ICS, those scenarios.

15 MEMBER STETKAR: Spurious SRV actuation on
16 this plant is a good thing.

17 MR. WACKOWIAK: No. SRVs are small enough
18 that -- and require and have some back pressure, such
19 that an SRV is sufficient to depressurize the plant
20 enough where ICS won't work, but it can't depressurize
21 it enough so that GDCS can work. So it's that
22 intermediate stage there, and an ICS spurious SRV is
23 not really a good thing.

24 MEMBER STETKAR: Are you saying that the
25 only spurious signals that you modeled in the fires

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 were spurious SRV actuations?

2 MR. WACKOWIAK: The design of the I&C
3 system is that it can't -- you really can't get a fire
4 to cause it to spuriously issue commands. It is not
5 like an analog system where you change the voltage or
6 the current on some line, and a random noise can go
7 down and actuate the valve.

8 What you have -- what we have here is a
9 complex string of checked valves and using sequence
10 numbers -- command sequence numbers and all sorts of
11 things, such that if one of the processors starts to
12 fail it is, as far as we could tell, impossible for it
13 to be interpreted by the device at the other end as a
14 close to contact to -- close the contact in two
15 different rooms now, and actuate those valves.

16 MEMBER STETKAR: The device at the other
17 end has some actuator?

18 MR. WACKOWIAK: Yes. Yes. And it's not
19 set up -- and the way that the cables are routed, we
20 don't have hot cables in with these. These are all
21 dead, de-energized cables, and the only power source
22 is coming from the I&C system to tell it to open.

23 So we don't really see how we can do it,
24 but we included it in here just in case. And we
25 picked -- the system that gives us the most benefit in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a fire is ICS, and we picked the system that gives us
2 the most benefit as the one we are going to fail by
3 our spurious actuation.

4 And I think I just covered all of this.
5 But, once again, one of the things that we found in
6 our fire risk is that we really do need to adhere to
7 the -- to our separation criteria that we have in the
8 design. There is extensive separation criteria
9 covered by the design, and by the ITAAC, and we have
10 even found areas where for non-safety systems that are
11 in the RTNSS category that we have applied
12 requirements for fire separation of that equipment.

13 As I mentioned earlier, I think the fire
14 risk is probably going to be reduced when we get the
15 as-built information, and look at fire modeling. But,
16 once again, the point came up, what about other
17 transient combustibles and things like that that are
18 left out? You know, we will probably hit some floor
19 on the initiators that you just couldn't justify going
20 below.

21 Once again, once we get fire mitigation
22 procedures, too, we think that fire risk should go
23 down somewhat. Somewhat, not expected to be a lot.

24 And at this point, there is no open items
25 in the fire area.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In flood, we have made some bounding
2 assessments in the flood model. Kind of like the
3 fire, where the fire takes out the whole room, we have
4 assumed that if we have -- if we start a flood, then
5 we drain whatever reservoir that is going to be. So
6 if it's a break in the suction line for the CRD pump,
7 the entire CST gets transferred into the reactor
8 building. Or if it's a fire water line, the entire
9 million gallons of fire water gets pumped into the
10 building. So it -- that's the kind of things that we
11 looked at there.

12 Some past PRAs tried to look at capability
13 of doors that were not flood doors to provide some
14 kind of mitigation. We didn't do that. Unless it was
15 a designated door, you know, submarine-type door to
16 prevent flood propagation, we didn't take any credit
17 for that. No credit for operator actions. And even
18 after all of that, the flood still didn't come out --
19 internal flood now -- didn't come out to be a
20 significant contributor to risk.

21 One of the main things, though, that we
22 did have to do with that is make sure that the control
23 building doesn't have the fire water standpipes within
24 the building. They are outside the building, so that
25 that flood doesn't become a dominant contributor. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's low because we made it low.

2 And right now there is no open items here.

3 Now, let's get to some open items. In the
4 high winds assessment, we assumed that seismic Cat 1
5 buildings can withstand hurricane and tornado events.
6 Seismic Cat 2 buildings are designed to withstand
7 hurricane events. And the main difference there isn't
8 the wind loading, but it's the missile protection.

9 The seismic Cat 1 buildings, we add
10 additional material to preclude penetration from
11 tornado-generated missiles. In the seismic Cat 2
12 buildings, the missiles that we protect against are
13 hurricane Category 5 type missiles rather than tornado
14 missiles.

15 Non-seismic buildings that house our RTNSS
16 C equipment, which we'll talk about later -- it's more
17 the defense-in-depth, non-safety-related equipment --
18 we can -- it can withstand the hurricane events there,
19 and the seismic events are treated a little bit
20 differently. But the plan is for them to withstand
21 the hurricane events.

22 Now, our frequencies are based on the
23 historical data for the different -- for the tornadoes
24 and for the hurricanes. We tried to set up a process
25 of setting up a bounding wind frequency. The way we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 did that for tornadoes was that we -- we calculate or
2 we got the tornado frequency from -- and I had this in
3 my head a few hours ago, but I can't remember it now,
4 from National Weather Service sort of data source. I
5 don't remember which one we got it from now.

6 But anyway, and we increased that to cover
7 any local variations. I believe it was by an order of
8 magnitude, and said that that was what our tornado
9 frequencies were. And we look at different tornadoes,
10 the lower scale tornadoes and the higher scale
11 tornadoes, and failed different buildings, and the
12 equipment located in those buildings based on those
13 scales.

14 The hurricanes we did a similar thing, but
15 our data comes from the NOAA data on hurricanes over
16 the last hundred years or so, and --

17 MEMBER POWERS: What made you think that
18 the data over the last hundred years are applicable
19 for the next hundred years? You have not noticed that
20 in -- episodically things appear in the paper speaking
21 to global warming and increased hurricane frequencies?

22 MR. WACKOWIAK: So we looked at those. We
23 also looked at it for the past -- the information that
24 we used to generate the frequencies was actually based
25 on the years when nuclear powerplants have been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating. So we looked at the hundred years to get
2 the relative frequencies between Cat 1, 2, 3, 4, and
3 5 hurricanes. But the frequencies of the hurricanes
4 themselves were based on -- or the frequencies of,
5 yes, the hurricanes that we used in the model were
6 based on hurricane-initiated events at nuclear
7 powerplants. So that really only covers the last four
8 years worth of data.

9 MEMBER POWERS: But if we are -- the
10 weather prognosticators are correct, that was a period
11 of relatively low hurricane frequencies.

12 MR. WACKOWIAK: That's possible.

13 Now, when we go through and we looked at
14 what it is that we do with the hurricane events, and
15 one of the things that we recognized in our insights
16 is that we do -- that high wind events are important
17 to risk, and designing for them are as well. In
18 ESBWR, we have a reactor building that is meters-thick
19 of concrete above the -- the above-ground area. What
20 is that?

21 MR. RAJENDRA: It's 54 meters.

22 MR. WACKOWIAK: And the -- we have
23 capability inside the building for --

24 MS. CUBBAGE: Excuse me. You need to
25 identify yourself.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAJENDRA: This is Clement Rajendra.
2 The height of the reactor building is about 54 meters
3 above grade.

4 MR. WACKOWIAK: Right. And most of that
5 -- all of that is concrete wall.

6 We have enough water inside the building
7 to allow decay heat removal for three days without
8 anything coming from the outside. If the building
9 fails at the upper floors, which is the thinnest part
10 of the walls and the ceiling and the roof, that
11 doesn't affect this heat removal capability.

12 We have added a seismic Category 1
13 building, and a seismic Category 1 fire tank that has
14 a million gallons of what that we can use a self-
15 contained diesel-powered pump to pump it up into those
16 pools up on top. And now in this last rev of the DCD,
17 we have added a seismic Category 2 low building to the
18 ground that has two ancillary diesel generators in
19 them that can be used to power other electric pumps
20 that are in the seismic Category 1 building.

21 So I think, in the end, where we may not
22 have the high -- the frequency on the high wind
23 perfectly established for the future, what might
24 happen in the future, but for the purposes of design
25 certification I think we have added everything that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 prudent to add to the design of this plant to respond
2 to high wind events, especially that can knock out
3 power and access to the site for long periods of
4 time.

5 We can withstand a massive direct hit
6 hurricane on this site for seven days without even
7 having to worry about getting things from offsite.
8 So --

9 MEMBER STETKAR: How do you do that if
10 your batteries only have 72 hours' capacity?

11 MR. WACKOWIAK: The batteries have 72
12 hours of capacity. But, once again, I said we have
13 added this new seismic Cat 2 building, a low building
14 down nestled in amongst other things. And we have two
15 one-megawatt ancillary diesel generators there that
16 can be used to power the Q-DCIS system after the
17 batteries run out.

18 And the fuel storage that we have for that
19 is also in a protected -- hurricane wind-protected
20 building that can provide fuel for those to operate
21 for the seven days. So I would agree that we have not
22 gone to the extent to try to figure out what global
23 warming would do to the increased hurricane frequency,
24 but I do believe we have added equipment to the design
25 sufficient -- as much as can be reasonably asked to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 address these sorts of events.

2 MEMBER STETKAR: In your tornado analysis,
3 why did you use only the footprint of the plant site
4 for the tornado strike frequency? Large tornadoes,
5 especially F3 to F5, typically have a fairly large
6 damage path length. In some cases, miles. I mean,
7 the damage area of like an F5 tornado can be up to 10
8 square miles.

9 MR. WACKOWIAK: Yes.

10 MEMBER STETKAR: So a tornado -- an F5
11 tornado could actually hit five or six miles away from
12 the plant and still affect the plant. It's not just
13 the tornado that happens to touch down inside the
14 plant boundary. They can come from outside and get
15 you.

16 So, therefore, the effective exposure
17 area, if you will, is considerably larger than the
18 plant footprint.

19 MR. WACKOWIAK: So which kinds of failures
20 would we be looking at for the -- let's say the
21 tornado that is a half a mile or a mile away from the
22 site?

23 MEMBER STETKAR: No, no, no. It touches
24 down a half a mile, but it makes it to the site. It
25 actually is an F5 tornado as it roars through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant site and goes five miles down the road. It
2 didn't touch down within your .14 square miles. It
3 touched down at a point --

4 MR. WACKOWIAK: Okay.

5 MEMBER STETKAR: -- five miles away.

6 MR. WACKOWIAK: And then got --

7 MEMBER STETKAR: Came five miles, went
8 through the site, and kept going. It was still Cat 5.
9 So, therefore, the effective exposure area, if you
10 want to think about it that way, especially for the
11 larger hurricanes -- not hurricanes, tornadoes -- can
12 be substantially larger than the site.

13 MR. WACKOWIAK: I'm going to need to go
14 back and look at how we did that. I thought we took
15 that into account. But the way you're explaining it
16 now, you're making me --

17 MEMBER STETKAR: I was just reading it.
18 I wanted to make sure that I understood something, and
19 it just says that the site -- I can't read things and
20 talk at the same time, but the site is approximately
21 .14 square miles.

22 MR. WACKOWIAK: Right. And we did use
23 that. And my understanding of the way this was done
24 -- granted, you know, you have to get into the details
25 like you're doing, is that, yes, if it touches down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here, that's one thing. You've got it. But if it
2 touches down here, it's got to go that path to get it.
3 And if it goes any of the other 360 degrees, it --

4 MEMBER STETKAR: That's true.

5 MR. WACKOWIAK: And I thought we took that
6 into account, but I don't know that we did. So I'll
7 have to go back and look at that.

8 MEMBER STETKAR: If you do the integrals,
9 it's --

10 MR. WACKOWIAK: Right. It's --

11 MEMBER STETKAR: -- details, but --

12 MR. WACKOWIAK: You have to do the
13 integrals to find out the right way to do that. So,
14 once again, if you asked me cold, I would have said we
15 did that. But you're reading what's in there, so I'll
16 have to go back and look.

17 The significant open items for these areas
18 -- we -- the way our analysis is is that for certain
19 buildings, if it's designed for hurricane winds, we
20 said that it would not -- that the building would not
21 fail. And the open item on that is that while there
22 might be an increased failure probability of that
23 building, that's designed for the hurricane.

24 In the hurricane areas, what we have
25 looked at is that the loads on the seismic Cat 1 and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2 structures are really bounded by the seismic events
2 -- the loads on the building -- by about an order of
3 magnitude. So designing for the seismic events we
4 think gives us more margin than would just be present
5 if we only designed it for the hurricane category
6 winds, and we're responding to that RAI hasn't --
7 hasn't been sent out yet. That's a new one.

8 So we'll be responding by relating it to
9 the loads that we actually designed the building for
10 rather than specifically saying this is a hurricane
11 thing or a tornado thing.

12 The other -- the next open item is whether
13 credit was taken for equipment in seismic Cat 2
14 structures hit by tornado missiles. I think there is
15 a table that we have in the analysis that says for
16 Cat 2 structures it is designed for hurricane
17 missiles, and probably to be clear it should say and
18 it will be failed by tornado missiles. But the
19 implication in the analysis assumed that for tornadoes
20 those Cat 2 structures, tornado missiles, those would
21 be damaged, but for hurricanes they wouldn't.

22 Also, questioning our declarations,
23 whether the tornado and hurricane assessments are
24 bounding, that kind of probably gets back to some of
25 this issue about possibly increased frequency in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 future of hurricanes and the tornadoes. Once again,
2 our analysis shows that within a reasonable change in
3 tornado frequency, the analysis really isn't sensitive
4 to that.

5 But we did for the hurricanes indicate
6 that it is important, and we think that we provided
7 all reasonable protection from hurricanes. Now we're
8 talking about numbers after that point.

9 And then, once again, these responses --
10 these are RAIs that came out in the last month or so,
11 and we are working on our responses to those.

12 Now, in the seismic margins assessment,
13 what we have done is that we only took credit -- I've
14 got a one instead of an I here, but we only took
15 credit for equipment that is located in seismic Cat 1
16 structures in our seismic margins analysis. So we
17 have kind of discounted everything that is in the non-
18 safety-related category. We failed it. We failed
19 everything else, so that the margins analysis is only
20 based on a limited set of equipment. So we know that
21 that's -- that doesn't cover everything that we have
22 available to us.

23 Our structural capability -- we can infer
24 what that capability is based on the buildings being
25 designed to Cat 1 requirements. And since those are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- those rules are fairly proscriptive, we know, based
2 on experience, what the margins are going to be for
3 those types of buildings.

4 The capability that we use for the systems
5 housed in those buildings, on the other hand, is an
6 assumed value. We looked at similar types of systems
7 in similar applications at other plants, and said,
8 okay, they all look like they will meet those kinds of
9 margins. But instead of just doing the analysis based
10 on that, we added a COL item to confirm in the as-
11 built plant that the systems actually do meet that --
12 meet the margins capability. And, once again, that is
13 confirmed in 1.67 times the SSE capability for the
14 buildings and equipment.

15 That brings us to our significant open
16 issue in this. The spectrum shape that we used for
17 the certified design response spectrum is not what we
18 used in the margins analysis. We used a performance-
19 based spectrum in the margins analysis. We describe
20 that it bounds -- it bounds most potential, or all of
21 the potential, ESBWR sites, so it could be the CSCRS
22 for most sites, but it's not in the design.

23 We think that the ground motion response
24 spectrum is the right one to use when we're looking at
25 margins. When we're designing these buildings, yes,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we'll use the combined response spectrum that we have.
2 But then, when we're looking at, what is the
3 capability beyond the design, we believe that using
4 the site-specific GMRS is the right spectrum for
5 confirming that COL item. And there is a disagreement
6 on that right now. That is basically where we are.

7 Seismic margins SSE has not been defined
8 as the CSDRS. That's the same issue as the above.

9 And then, finally, the fault tree for fire
10 protection water system doesn't model all of the
11 components in the system that must survive the
12 earthquake. Yes, that was an omission in our previous
13 -- we took credit for everything that is needed to run
14 the fire protection water system, the seismic Cat 1
15 system that we have. We took credit for that, but
16 just didn't write it down in the assessment. Now we
17 explicitly show all of the support systems needed to
18 make that work as being required to be confirmed in
19 the HCLPF confirmation.

20 So we will still be working with the staff
21 on which is the right spectrum to use for confirming
22 margins. Our main issue with this is that in -- we
23 know that we want -- in the design of the plant, we
24 are using the more conservative CSDRS. It's a
25 combined spectrum that includes both high frequency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and low frequency events. And it's not real for any
2 site. It's a composite spectrum.

3 So we're designing to that. But we feel
4 that when we're looking for margins beyond the design,
5 we should really look at what the margins are beyond
6 the design at the specific site. You should -- we can
7 design for one thing, but confirm margin above what we
8 would actually see rather than margin above a
9 theoretical curve. So that's going to be -- that's
10 our position right now, and we are -- we are still
11 talking about it.

12 In the shutdown area --

13 MEMBER APOSTOLAKIS: Are you done with
14 seismic?

15 MR. WACKOWIAK: Yes.

16 MEMBER APOSTOLAKIS: Just a question or
17 clarification. You conclude that the HCLPF is .6g, as
18 I recall.

19 MR. WACKOWIAK: I think it was .6 in
20 Rev 1.

21 MEMBER APOSTOLAKIS: I'm sorry. And the
22 SSE is .3?

23 MR. WACKOWIAK: .5.

24 MEMBER APOSTOLAKIS: Okay.

25 MR. WACKOWIAK: That's why it went up to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 .84.

2 MEMBER APOSTOLAKIS: I was looking at the
3 wrong graph. .5g -- is that sufficient for east of
4 the Rockies?

5 MR. WACKOWIAK: Go ahead.

6 MR. RAJENDRA: Yes. The .5g at 100 Hertz
7 is for North Anna, and that is the highest that we get
8 -- see on the eastern seaboard.

9 MEMBER APOSTOLAKIS: Really?

10 MR. RAJENDRA: Yes. Yes, sir.

11 MR. HAMZEHEE: You need to introduce
12 yourself again for --

13 MR. RAJENDRA: My name is Clement
14 Rajendra.

15 MEMBER APOSTOLAKIS: Okay. The .3g
16 sounded too low to me. But if you say the .5 --

17 MR. RAJENDRA: .5g.

18 MEMBER APOSTOLAKIS: Okay.

19 MR. WACKOWIAK: Okay?

20 MEMBER APOSTOLAKIS: The high confidence
21 is 99 percent?

22 MEMBER STETKAR: It's 95 percent
23 confidence of less than -- of five percent or less
24 failures. So it's roughly one percent or less mean
25 failures if you do the math.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Okay. We'll come
2 back to this at some point.

3 MR. WACKOWIAK: Now, the next thing, we
4 had looked at the shutdown risk analysis. Everything
5 else that we presented in the Level 1 was for Mode 1,
6 full power operation. We took a look at 2, 3, and 4,
7 and looked at the tech specs that we have, the
8 differences between Modes 1, 2, 3, and 4, and
9 qualitatively determined that 2, 3, and 4 should be
10 bounded by the full power analysis.

11 At this point, we didn't look at any
12 transition risk between modes. We don't think that
13 that is really needed in the design cert. That is
14 more of an operational issue that will be addressed in
15 the later PRA that we talked so much about.

16 Five and 6, we needed to split that. Let
17 me be clear on this, because it's -- may be different
18 than what you are used to. Mode 5 in this plant is
19 cold shutdown, and Mode 6 is refuel. Four is hot
20 shutdown, or 4 is -- 3 is hot shutdown, 4 is safe
21 shutdown, stable shutdown, 5 is cold shutdown, 6 is
22 refuel. And 4 -- so anyway, in Mode 5 we had to split
23 that into two areas, one with the head on and one with
24 -- and the other with the head off.

25 The main difference with the head on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 versus head off is that if we do lose decay heat
2 removal with the head still on, then the plant can
3 repressurize and we can use the isolation condensers.
4 Also, if we had to use GDCS, we would be required to
5 use DPVs and depressurize with the heads on. With the
6 head off, GDCS will work without any further help.

7 Then, there is Mode 6 where it -- in
8 refuel now we look at unflooded where the water level
9 is down near the dryer and separators, and then
10 flooded where it is still up all the way to the
11 reactor cavity. Significant timing differences
12 between the scenarios and those -- in those different
13 modes. So those are the four different things that --
14 states that we looked at for shutdown.

15 We didn't take any credit for containment
16 in shutdown. So this really is based on a refueling
17 outage rather than going to cold shutdown for some
18 tech spec issue. We would have credit for the
19 containment possibly in those, but we didn't take
20 credit for it here.

21 The LOCA during shutdown turns out to be
22 more than 90 percent of the CDF for these scenarios.
23 And the main issue with that is that if we have a LOCA
24 in the lower drywell that begins to be filled up with
25 water, if the hatch is closed, the containment acts

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like a cup and can be filled and keep the core covered
2 just by pouring water into the containment.

3 If the hatch is open, then we can't do
4 that. The water comes out the hatch, and, as a matter
5 of fact, we can't even fill the reactor building if we
6 -- if so much water was available, mainly because
7 grade level is at the bottom of the core, and so it
8 would come out through the drains there rather than
9 the top of the core, to use that for a cup.

10 So our insight from this is that the lower
11 drywell hatch does need to be controlled during
12 outages, and we have gone back and forth on what the
13 specific procedural guidance would be for that. But
14 we do indicate that someone has to be available to
15 close that hatch if we were -- if we got to a point
16 where there was a LOCA in the lower drywell.

17 CHAIRMAN CORRADINI: Just to make sure I
18 understand, so it would be a mode --

19 MR. WACKOWIAK: Five or 6.

20 CHAIRMAN CORRADINI: Okay. We said --

21 MR. WACKOWIAK: Send people in to work in
22 the lower --

23 CHAIRMAN CORRADINI: No, that I
24 understand. I was just trying to understand that you
25 were strictly speaking about Mode 5. But it's Mode 5

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or 6.

2 MR. WACKOWIAK: Yes, 6 is the same
3 problem. Even though there's more water and we have
4 more time to respond to it in Mode 6, the end state
5 still comes out to be the same. You have to get water
6 in. But we didn't look at -- also, we didn't look at
7 other bizarre once-through modes where we would maybe
8 throw a hose in the top and pump in water faster than
9 it's pouring out the hole in the bottom, and then out
10 through the walls in the reactor building. Didn't
11 take credit for that at this point.

12 I think we need some procedures before we
13 can do -- get ready for that.

14 MEMBER MAYNARD: On the hatch, not only
15 can somebody close it, you also have to be able to --
16 you also control lines and stuff like that that might
17 be running through that?

18 MR. WACKOWIAK: Sorry, I left that part
19 out. We don't allow any service lines or power cables
20 or anything to go through the drywell hatch. We had
21 service penetrations in the lower drywell to handle
22 equipment during outages.

23 MEMBER STETKAR: Can you actually close
24 the hatch against the hydraulic head if water is
25 pouring out of the drywell through the opening?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: The calculations that we
2 did to determine the time to close the drywell hatch
3 were based on how long it took for the water to get to
4 the bottom of the door. So once the water got to the
5 bottom of the door, we assumed no recovery.

6 CHAIRMAN CORRADINI: The hatch opens, by
7 design, in or out?

8 MR. WACKOWIAK: Out.

9 CHAIRMAN CORRADINI: Is it --

10 MR. WACKOWIAK: And, once again, it
11 doesn't have to -- it doesn't have to be a pressure
12 boundary at that point. It just needs to be a water
13 seal boundary.

14 CHAIRMAN CORRADINI: I understand.

15 MR. WACKOWIAK: So it doesn't have to be
16 fully tensioned in to stop the water, and we are
17 designing the hatch so that it can be easily closed
18 and sealed for this water seal, so it wouldn't take
19 quite as much time as installing it -- the hatch in
20 some of the current plants.

21 MEMBER STETKAR: Is it a -- I didn't look
22 at any of this. Is it a hinged hatch, or is it a
23 removed hatch with a little local crane and a --

24 CHAIRMAN CORRADINI: Has it been designed
25 at all?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Well, I think the sketches
2 that are -- you know the sketches from the general
3 arrangement. I think they show a hinge.

4 PARTICIPANT: I don't recall.

5 MR. WACKOWIAK: And we're still looking at
6 what the detailed design is. You know, some of us
7 have come up with really cool things where it's
8 hinged, kind of like a bathroom store -- stall door
9 with a magnet, and you just take the magnet off and it
10 closes. Then, the life safety people don't like that,
11 because somebody might get stuck in there. All sorts
12 of things that we have to --

13 MEMBER STETKAR: How did you handle human-
14 induced LOCAs during shutdown?

15 MR. WACKOWIAK: We have a discussion of
16 the human-induced LOCAs in the PRA. You know,
17 changing out CRD mechanisms, there's interlocks built
18 into the machine that takes those apart, so that, you
19 know, you have to have the seal. We have removed --
20 we have added maintained valves into all of the
21 lines, so that any of the power-operated valves that
22 need to be maintained can be isolated before they are
23 maintained, so we don't have -- we don't have to use
24 any free seals in this plant.

25 And then, drain and sample lines we moved

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 outside of the containment isolation valve boundary,
2 so that opening up the wrong drain would not drain
3 everything because the containment isolation would
4 still isolate that path.

5 MEMBER STETKAR: Since I didn't have a
6 chance to read that section, from what I'm hearing, it
7 sounds like there are no human-induced LOCAs. Is that
8 correct?

9 MR. WACKOWIAK: In the model we did not
10 explicitly put in any human-induced LOCAs, and we have
11 had several RAIs back and forth on all of those
12 issues, and the discussion centered around the
13 interlocks on the machines, getting rid of free seals,
14 moving drain and sample valves outside of the -- so we
15 think we've got it bounded there, and now -- then what
16 we're left with is a -- you know, a frequency of a
17 pipe break.

18 And the kind of things that -- you know,
19 it's a low pressure, not a real lot of flow. The
20 kinds of things that are probably in the pipe break
21 frequency at that point are, you know, the -- somebody
22 runs a machine into the pipe and breaks it off, and
23 things like that.

24 MEMBER STETKAR: I'm just curious. Since
25 it's 90 percent of the total core damage frequency,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and it's only quantified by pipe breaks --

2 MR. WACKOWIAK: Right.

3 MEMBER STETKAR: -- assuring that the
4 human contribution to that is precisely zero could be
5 important, especially because creative people have
6 managed to drain reactor vessels, despite multiple
7 redundancies of normally closed valves.

8 MEMBER APOSTOLAKIS: That would change the
9 frequency, right, of occurrence -- to include the
10 human --

11 MEMBER STETKAR: That's correct.

12 MEMBER APOSTOLAKIS: I mean, it's not that
13 we have something entirely new. Unless it --

14 MEMBER STETKAR: Once some --

15 MEMBER APOSTOLAKIS: -- some intervention.

16 MR. WACKOWIAK: It changes the
17 frequencies. And for those specific types of things,
18 we tried to address the things where something is put
19 in place that we think the pipe is intact, and then
20 the human action occurs remotely and then nobody knows
21 about the floor. So these sorts of things associated
22 with, you know, the --

23 MEMBER STETKAR: That's recognized in
24 the --

25 MR. WACKOWIAK: -- break the pipe, they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are getting wet, and recognizing the pipe is broken,
2 and that should make it easier to close the door.

3 MEMBER STETKAR: No. These tend to be
4 things where people are doing maintenance and repairs
5 on systems. And Joe thinks that the isolation valve
6 is closed, but it really isn't. And they cut into the
7 pipe, and said system is now not available as a
8 mitigation system if it's one of them, or whatever.

9 MR. WACKOWIAK: Right.

10 MR. HAMZEHEE: Another point that, Rick,
11 you maybe forgot to make is that some of the human-
12 induced LOCA during shutdown is a little easier to
13 quantify when you do the plant-specific shutdown risk,
14 because you have more procedures, more configurations.
15 For you guys to get some more accurate estimation of
16 that would be difficult.

17 MEMBER STETKAR: That's correct. But in
18 that sense, this is an area where you might expect the
19 risk contribution to increase as you went to the COL
20 stage where you might know more about how you --

21 MR. WACKOWIAK: That's right.

22 MEMBER STETKAR: -- are going to manage
23 the outage.

24 MR. WACKOWIAK: And, once again, we think
25 we did the kinds of things that we need to do. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 moved the penetration, so we can get the -- or moved
2 things into penetration so we can get the door closed.
3 Requirement to have somebody to monitor and close the
4 door, moving -- putting in maintenance valves so we
5 don't need to do free seals, interlocks on the
6 machines for changing the CRDs.

7 MEMBER APOSTOLAKIS: But is it the
8 frequency only that changes, or the actual sequence of
9 events?

10 MR. WACKOWIAK: No, it's just the
11 frequency.

12 MEMBER APOSTOLAKIS: If you have a random
13 one, then are the operators going to do anything to
14 mitigate it? Or is it all of --

15 MEMBER STETKAR: The only thing that you
16 can do to mitigate it at that point is -- well, that
17 we had to take credit for is getting the door closed.
18 Once the door is closed, the automatic systems take
19 care of it.

20 MEMBER APOSTOLAKIS: And they will do that
21 even if it's human-induced?

22 MEMBER STETKAR: Yes.

23 MR. WACKOWIAK: The only thing would be is
24 if it's human-induced, for example -- I don't want to
25 think of scenarios. If it's a human-induced scenario

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that affects a mitigation system -- for example, if
2 the human inadvertently opens the GDCS deluge valve --

3 MEMBER STETKAR: I'd have to think about
4 that.

5 MR. WACKOWIAK: -- in that particular
6 case, if the human opens up one of the deluge valves,
7 we still have the other two tanks. And if they open
8 the deluge valve, there is no reason for that to be in
9 the vessel. The vessel is still filled with water, so
10 that really wouldn't even be an initiating event.

11 We've tried to go through some of those
12 scenarios and --

13 MEMBER APOSTOLAKIS: So there might be
14 others.

15 MR. WACKOWIAK: The significant open items
16 that we have left in the shutdown risk analysis is to
17 define the tech spec for DPVs during Mode 5 and 6 with
18 the head on. Previously, we were ambiguous on how
19 many DPVs needed to be operable during those modes of
20 shutdown. Rev 5 of the DCD specifies that six DPVs
21 are going to be required during shutdown. And that's
22 consistent with what we have in our model.

23 Staff requested that building the
24 isolation condenser to function effectively for some
25 operational conditions in Mode 5 -- this is one thing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that was identified late in the process, and we
2 haven't fully digested what we need to do here with
3 this one.

4 But the scenario is is that if the water
5 level during shutdown -- during the Mode 5 head-on
6 conditions, usually they flood up to the flange on the
7 vessel head before they take the head off. But if you
8 flood up that high, then the isolation condenser inlet
9 lines are flooded. And it's -- the conjecture here is
10 that they would not function as isolation condensers
11 if we repressurized there because we have a water seal
12 or something on that.

13 We agree that that's an issue that we need
14 to look into, and we are looking into it, and we'll
15 get back.

16 (Laughter.)

17 All right. The next one is to determine
18 the range of conditions, temperature, and level for
19 which reactor water cleanup shutdown cooling can
20 adequately remove decay heat in the various modes.
21 Once again, this is a question that came in fairly
22 recently. Or, I'm sorry, we have responded to this
23 one, and the staff is looking at our response to this
24 issue.

25 Our point is that we can maintain the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor in a subcooled condition as long as the
2 reactor water cleanup shutdown cooling suction, mid-
3 vessel suction nozzle, is covered. It might not be
4 120 degrees in the vessel like we want it to be in
5 cold shutdown if we have a reduced set of equipment.
6 But we can maintain it in a cold shutdown condition
7 with multiple different configurations of that system.

8 There is also concern about injection may
9 bypass the core. The shutdown cooling flow rate comes
10 back in through the feedwater nozzles, and the
11 feedwater nozzles are up on the top of the -- outside
12 the shroud area. And then, the suction for shutdown
13 cooling is at the mid-plane.

14 The question -- I guess the question came
15 out in -- to GE that -- how much water just -- cold
16 water just goes back and bypasses versus being fully
17 mixed in the -- outside the shroud area. We have sent
18 in a response to the staff. They are looking at it.

19 The one thing is this configuration,
20 similar to what was in the ABWR -- and the ABWRs have
21 successfully dealt with cold shutdown -- so we think
22 we got it, but it's still under review. Slight
23 different configuration, but it's similar.

24 CHAIRMAN CORRADINI: I have a question
25 here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Okay.

2 CHAIRMAN CORRADINI: So a number of us
3 would have a number of questions here. Do you have
4 the expertise in the room to answer detailed questions
5 about this? Otherwise, I have a suggestion to move us
6 along.

7 MR. WACKOWIAK: About this?

8 CHAIRMAN CORRADINI: Yes.

9 MR. WACKOWIAK: I can probably answer --

10 CHAIRMAN CORRADINI: So here is my
11 proposal.

12 MR. WACKOWIAK: -- 80 percent of your
13 questions.

14 CHAIRMAN CORRADINI: Okay. But I have a
15 proposal. We are falling behind and --

16 MR. WACKOWIAK: Way behind.

17 CHAIRMAN CORRADINI: Yes. And so what I
18 was going to suggest is for severe accident management
19 that a number of us submit questions through the staff
20 to you about this to clarify things or questions we
21 have and skip this for now, because this is a whole
22 300 pages that I went through. But I'm not sure if
23 we're going to have a chance to go through in any
24 detail here.

25 I'd rather hear the staff about the rest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the Chapter 19, and then allow us time for RTNSS.

2 MR. WACKOWIAK: Let's do that and --

3 CHAIRMAN CORRADINI: I'll look at the
4 Committee. I checked with a few of us to see if it's
5 okay with ones that I expected a lot of questions. Is
6 that okay?

7 (No response.)

8 Hearing silence, I think that's approval.
9 So --

10 MR. WACKOWIAK: And I think that the only
11 thing I want to say here is there are open items on
12 this that they will talk about. BiMAC testing was one
13 of the open items. Testing has been completed. We
14 have submitted the report to the staff.

15 CHAIRMAN CORRADINI: Do we have that,
16 though?

17 MR. WACKOWIAK: I -- yes. Somebody --

18 CHAIRMAN CORRADINI: We have the BiMAC
19 test?

20 MR. WACKOWIAK: The test report, do they
21 have it yet?

22 MS. CUBBAGE: We have it. I'll have to
23 verify if you --

24 CHAIRMAN CORRADINI: Okay. So, then, I
25 definitely positively want to hold off until I look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that.

2 MR. WACKOWIAK: And it's a proprietary
3 report. So just be aware that that is. When we want
4 to discuss that, we should probably have a closed
5 session.

6 CHAIRMAN CORRADINI: No, we don't have it.
7 No, I think that would be fine, then, because I think
8 we would rather -- at least I would rather see that
9 and look at that -- those results before we ask you a
10 few of the questions we've got.

11 MR. WACKOWIAK: And then, these other
12 additional open items are things I think I covered in
13 passing in the other topics, but they are also
14 underway.

15 I want to do one statement about what
16 you'll see in Rev 3. What we did to do Rev 3 of the
17 PRA is not updating the entire PRA. It's easy in a
18 PRA to change a couple of numbers and end up having
19 every page look like it was a change, just because of
20 the results and things are -- propagate on through.
21 So we didn't want to do that to facilitate the review.

22 So what we did was like a typical PRA
23 maintenance and update process. We reviewed all of
24 the differences between the plant from what we had in
25 the model before, and where we are now, and we added

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a Section 22, which goes 22.1, 2, 3, all the way
2 through 21, and we describe what the differences are
3 and what the results of those differences are, and any
4 sensitivity analyses that we needed to do to
5 demonstrate that we understood what those results were
6 and what the final numbers would be.

7 In Section 7, we did do a full Level 1
8 internal events requantification of the PRA, and
9 demonstrated that with the exception of two sequences
10 that swapped places the results remained essentially
11 unchanged. And when you look at 22, you will see it's
12 set up like a guide to how to review the PRA update
13 from what we did before, and the plan with the staff
14 is that now, after this -- they've had a chance to
15 review that, then we will update that into the main
16 report, they will come out and audit that we
17 implemented it properly, and by then we'll have
18 another Section 22 that has the newer things, added
19 detail, whatever, from the detailed design process.
20 So now we're in a PRA maintenance process, even though
21 we are still in the DCD right now. So we're --

22 MEMBER BLEY: If I understood you right,
23 except for Chapter 7, Chapters 1 through 21 are
24 identical, then, to Rev 2?

25 MR. WACKOWIAK: But we have clarifications

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and corrections from RAI responses in those sections.

2 MEMBER BLEY: That are in those sections.

3 MR. WACKOWIAK: Yes. So it is --

4 MEMBER BLEY: Some update.

5 MR. WACKOWIAK: If they said -- if we did
6 something that was adjusting the document but didn't
7 affect the quantification, we put it in that section
8 to clarify it. But anything associated with a new
9 model or a new quantification would go in 22.

10 In the end, we found the same results, the
11 same insights, and the same -- essentially everything
12 was the same as before. It was just using different
13 equipment. You had asked, "How is that possible?"
14 Well, the reason it's possible is because our -- the
15 way our design process is set up right now with the
16 PRA plugged in at every step of the design process,
17 and we make sure that when things are changing in the
18 plant they are being changed consistently with the
19 things that are modeled in the PRA, and we only change
20 things in the PRA or in the plant to change that if
21 there is a good reason for it.

22 And so far we have been able to take all
23 of the different design changes to address the rest of
24 the branch's questions about the design of the ESBWR
25 and make it fit right within the framework of the PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that you saw back last year in September when it was
2 submitted as Rev 2.

3 MEMBER STETKAR: Rick, let me just make
4 sure I understand, because we don't have it, but it
5 will help once we get it. As a specific example,
6 between DCD Rev 3 and Rev 4, the instrument air system
7 design changed completely.

8 MR. WACKOWIAK: Yes.

9 MEMBER STETKAR: Would I find the new
10 model for the instrument air system in Chapter 4 of
11 the Rev 3 PRA or in Chapter 22?

12 MR. WACKOWIAK: 22.4.

13 MEMBER STETKAR: 22.4.

14 MR. WACKOWIAK: And in that section, we
15 give the new model and we discuss the -- if there's
16 any difference in contributors at the system level,
17 and then we talk about how that affected the results
18 of the integrated models.

19 MEMBER STETKAR: But you did integrate the
20 new model into the full PRA.

21 MR. WACKOWIAK: Yes.

22 MEMBER STETKAR: Okay. Thanks.

23 MR. WACKOWIAK: I think the only things
24 where we didn't integrate everything is something in
25 the high winds area we still use the Rev 2 model. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 didn't use the underlying for the -- for that. And
2 maybe in the fire again, too, because there is a lot
3 of little connections that you have to make in fire
4 with all of the flag files, so --

5 MEMBER STETKAR: It just helped. There
6 are so many thousands of pages of fault trees that a
7 little bit of direction, which thousands of pages to
8 look at, helps. Thanks.

9 MR. HAMZEHEE: Rick, do you plan to
10 provide any additional guidance as to what is in Rev 5
11 for the PRA Subcommittee later on?

12 MR. WACKOWIAK: If they would like it,
13 we're going to be discussing it with you for half a
14 day tomorrow.

15 MR. HAMZEHEE: That's correct. I just --
16 all right.

17 CHAIRMAN CORRADINI: Thank you.

18 MR. WACKOWIAK: Okay.

19 CHAIRMAN CORRADINI: So we'll turn to the
20 staff now on the Chapter 19.

21 MR. HAMZEHEE: I will just start talking
22 while they're getting ready. There are just a couple
23 of --

24 CHAIRMAN CORRADINI: We want to catch up,
25 so --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. HAMZEHEE: Since we don't have a lot
3 of time, I wanted to make a verifying remark first
4 with the response I gave early this morning, and that
5 was with regard to the COL application and PRA and COL
6 holder application. And I think based on the changes
7 to the Reg Guide and Part 52 that were made last year,
8 right now we asked the design certification applicant
9 to submit their PRAs, mainly the results, and
10 description of the methodology.

11 And then, the results is very significant.
12 There are a lot of things they have to submit.
13 Similar things, we have requested the COL applicants
14 to submit. But for COL holder, there is a Rule
15 Part 52 that says they have to perform full scope, all
16 initiating events, all modes, for those that -- the
17 NRC-endorsed standards exist one year prior to the
18 fuel load. But they don't have to submit the results
19 to the NRC, and they have to have them available so
20 that if the NRC staff feels like they need to review
21 or audit something, they can go and audit the results.
22 I just wanted to clarify this.

23 And then, another point I want to make
24 before we go ahead and talk, if you don't mind, Rocky,
25 is the fact that I just wanted to let you know that in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the last several years we have had many interactions
2 with the GEH staff. And through the RAI process, we
3 have raised a lot of technical questions and a lot of
4 issues, most of which have already been addressed.

5 And as a result of those interactions and
6 RAI process, GE has made a lot of improvements to
7 their PRA studies. And as a result, you see that they
8 have Rev 0, Rev 1, Rev 2, and they just issued a Rev 3
9 PRA. And as Rick mentioned this morning, they have
10 also made a lot of design improvements as a result of
11 their PRA studies that have been updated and upgraded
12 in the last few years.

13 So I just wanted to make that comment for
14 the record. With that, Rocky can --

15 MR. FOSTER: I'm going to go ahead and
16 start, then. We are here to brief the Subcommittee on
17 results of the staff's review of the ESBWR DCD
18 application, Chapter 19. My name is Rocky Foster.
19 I'm the lead project manager on Chapter 19. Mark
20 Caruso, to my right, is the lead technical reviewer.
21 And then, we have numerous technical reviewers that
22 have worked on this project, and the vast majority of
23 them are in the audience right now.

24 Our presentation we are going to provide
25 you today will be the RAI status summary of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicable regulations. SER technical topics,
2 significant open items, and COL action items are
3 related for each section of Chapter 19.

4 RAI status -- we had 289 RAIs that we
5 issued; 272 of them have been resolved, and we have 17
6 open items as we speak.

7 MEMBER STETKAR: Those are impressive
8 numbers, but they are numbers.

9 (Laughter.)

10 MR. FOSTER: Yes, sir.

11 MEMBER STETKAR: If I were to ask you to
12 characterize your technical review of the PRA, would
13 you -- on a scale from a high level review through a
14 moderately detailed review to a detailed review, how
15 would you characterize the level of scrutiny in terms
16 of completeness, level of detail? That's not
17 necessarily reflected by numbers of questions,
18 although that might be a measure.

19 I'm trying to get a sense from a technical
20 level of detail and --

21 MR. HAMZEHEE: Mark is going to cover it
22 later. But if you want --

23 MEMBER STETKAR: Oh, okay. Fine.

24 MR. HAMZEHEE: -- it now --

25 MEMBER STETKAR: Keep going. Keep going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then.

2 MR. FOSTER: Okay.

3 MEMBER STETKAR: Keep going. Keep going.

4 MR. FOSTER: And now I will turn it over
5 to Mark for the --

6 (Laughter.)

7 MR. CARUSO: And my first comment -- my
8 first comment was going to be on the 289 RAIs, and
9 sort of give you some perspective on that, which I
10 think is exactly what you just asked.

11 I'd say, you know, we got PRA -- Rev 1 of
12 the PRA some time ago. I'm not sure -- 205 or 206.
13 And there was, I would say, a fairly detailed -- quite
14 detailed review of that done by the staff. Nick
15 Saltos was the reviewer at that point, and he
16 generated most of these -- a good share of these
17 questions.

18 MEMBER APOSTOLAKIS: Who did those?

19 MR. CARUSO: Nick Saltos.

20 MR. HAMZEHEE: He was the original
21 reviewer, and then there were some changes in the
22 staff.

23 MR. CARUSO: Detailed questions on the
24 modeling and all of the -- in Chapter 4, all of the
25 different system models, there were a number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 detailed questions on the modeling, all of the models,
2 questions on the data, a number of questions on
3 particular data values, and my -- were they
4 appropriate, a number of questions on common cause
5 failure, questions on providing additional information
6 on insights, addressing the thermal hydraulic
7 uncertainty.

8 So over the past year, I took over for
9 Nick about a year ago when Nick moved to the PWR
10 group. And over this past year, we have received a
11 lot of responses to those questions and looked at
12 those responses over I guess last summer. Most of the
13 responses to those questions are included in Rev 2 of
14 the PRA which we got some time around -- started
15 getting it some time around August. In some cases,
16 questions went away -- questions went away because the
17 design was changed, modeling methods were changed.

18 So I think there was -- I would say there
19 was a significant update between Rev 1 and PRA Rev 2.
20 Now, I would say the level of review of the responses
21 to those questions was probably not as detailed. It
22 was: are these reasonable responses? Do they address
23 the question? In some cases, we weren't satisfied
24 with the responses, and in most cases we were
25 satisfied with the responses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Mark, just to really
2 understand what you've told us so far, going back to
3 the Rev 1 review, your folks actually looked at the
4 event trees and fault trees to see that they modeled
5 the system as it is described?

6 MR. CARUSO: Yes.

7 MEMBER BLEY: And looked at the data
8 analysis or how the data was handled down at that
9 level.

10 MR. CARUSO: And we looked at that in
11 Rev 2, too.

12 MEMBER BLEY: Spot-checking or
13 actually trying to look at most of it?

14 MR. CARUSO: Well, I mean, if you look at
15 Rev 2, you look at the fault trees and the basic
16 event, they go on and on and on. So I -- from my own
17 perspective, I would say it was a sample check review.
18 In some cases it depended, if there was a question we
19 had asked that related to a certain part of modeling,
20 and they responded to it, we would go in and look at
21 that.

22 MEMBER BLEY: Just an aside -- if I took
23 one of those systems that is maybe 200 pages long and
24 took out the common cause cut sets, it's a much
25 smaller --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. CARUSO: That's true. Reviewable,
3 yes.

4 So we're left with basically 17 open
5 items, and they -- I also wanted to say I focused my
6 efforts on the Level 1 topics, and then sort of a
7 coordination for the group. We had a number of people
8 work on different parts of the PRA review -- fire,
9 high winds, work on the shutdown. Those people are
10 all here, and if there are questions in those areas we
11 will have them address those questions.

12 And I think from the -- at least from the
13 perspective of the Level 1 PRA, I think overall we
14 feel like we have some of the same concerns that you
15 have expressed about the sensitivity studies and about
16 some of the data, and do we know these numbers, the
17 squib valve failure rates and software common cause
18 failure.

19 But I think, overall, looking at, you
20 know, what they've done and the modeling, the data
21 they have used, the sources they have used, and then
22 the results they got, and a comparison of the results
23 they got with the design of a plant, that we feel
24 pretty good about their Level 1 core damage -- well,
25 their Level 1 results, in the sense of from the point

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of view of meeting tradition's goals.

2 So I think I would say overall we have
3 some open items to resolve, but we're -- I think we
4 see the light at the end of the tunnel.

5 MEMBER APOSTOLAKIS: Can we really claim
6 that we demonstrate that the Commission's goals are
7 met? I mean, that's a pretty strong statement, it
8 seems to me, given that we don't have a lot of detail
9 and we don't have a plant. We have to find better
10 words I think.

11 MR. CARUSO: Yes, I would agree. I would
12 say we need to make a judgment as to whether or not,
13 you know, we think --

14 MEMBER APOSTOLAKIS: As to whether the
15 design should be certified.

16 MR. CARUSO: Yes.

17 MEMBER APOSTOLAKIS: This is the decision.
18 We are not meeting the Commission's goals. In fact,
19 some of my colleagues here will claim that we have
20 never demonstrated that we met the Commission's goals,
21 right?

22 MEMBER POWERS: Never.

23 MEMBER APOSTOLAKIS: Never. See? He
24 spoke up. Even for LWRs. So let's not stretch it.

25 MR. CARUSO: Well, we can certainly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make --

2 MEMBER APOSTOLAKIS: Sorry. What?

3 MR. CARUSO: I mean, I think we can also
4 turn it around to say, "Do we think they don't meet
5 the goals?"

6 MEMBER APOSTOLAKIS: No, that's very
7 different. That's a very different conclusion.

8 MR. CARUSO: It's a very different
9 question.

10 MEMBER APOSTOLAKIS: Very different
11 conclusion. But given that a lot of things are
12 missing, if there are assumptions that have been --
13 have had to be made, and all of that, I can see how
14 one can conclude that the design should be certified,
15 but to claim that we meet the Commission's goals is a
16 little bit, well, too much.

17 MR. CARUSO: I have another slide here
18 later on that shows that there are a number of other
19 objectives that the Commission had. That was one
20 objection.

21 MEMBER APOSTOLAKIS: That's different, and
22 I think it was Commissioner Jaczko who made the
23 statement recently that we can't really demonstrate
24 that we meet the Commission's goals, even with LWRs.

25 MR. CARUSO: I agree. I find that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stickiest one to deal with as the staff making the
2 conclusion about it. The other objectives I think are
3 much easier to deal with.

4 MEMBER APOSTOLAKIS: Well, if you focus on
5 the decision in front of us, namely should we certify
6 it or not, I think that is -- it's clear what you're
7 doing or what they are doing and what you are doing.

8 MR. CARUSO: But I agree with you. Here
9 we have an objective that is based on numbers.
10 They've got numbers there -- I mean, goals -- CDF and
11 LRF numbers. We have a PRA that doesn't match a real
12 plant, doesn't match real procedures, and creates a
13 great deal of uncertainty in terms of a numerical
14 analysis. So, you know, that's hard to deal with.

15 MR. HAMZEHEE: And I think you may,
16 George, in general be right, but what Mark is eluding
17 to is the fact that if you look at some of the
18 Commission goals, there are a set of them that Mark is
19 going to glance through. And, for instance, one of
20 them is to make sure they use PRAs during the design
21 phase to improve this design of the plant, and they
22 have demonstrated -- they have definitely demonstrated
23 that.

24 MEMBER APOSTOLAKIS: I have no objection
25 to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMZEHEE: So that's one objective.

2 MEMBER APOSTOLAKIS: I just think that in
3 this area, the precision in language is really
4 important.

5 MR. FOSTER: Sure. We do have an upcoming
6 slide that goes to the objective.

7 MEMBER APOSTOLAKIS: Don't be defensive.
8 Don't be defensive.

9 MR. FOSTER: They help to outline things
10 for the --

11 MEMBER APOSTOLAKIS: You see to agree with
12 me.

13 MR. HAMZEHEE: I do.

14 MEMBER APOSTOLAKIS: Okay. No?

15 MR. HAMZEHEE: All right. Keep going.

16 MR. CARUSO: I would say from my
17 perspective that when I look at their design and their
18 modeling in the design, and the things that they have
19 addressed in terms of trying to reduce the
20 vulnerabilities that the other plants have, I would
21 say I feel confident that this -- if someone buys this
22 and builds it and, you know, puts in responsible
23 procedures and the other stuff that they put in, it
24 could very much, you know, exceed -- you know, meet
25 the goals and exceed the goals. But I agree we are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not there yet in terms of saying that's the case.

2 MR. KRESS: If you looked at the next
3 slide, I think you pretty much can agree that those
4 things have been --

5 MR. HAMZEHEE: And that's what I was
6 trying to say. There are a number of them that have
7 been demonstrated to be --

8 PARTICIPANT: That's the Commission
9 objectives.

10 MR. KRESS: It may include some --

11 PARTICIPANT: Oh, we'll bypass it.

12 MR. HAMZEHEE: These are the ones that
13 have been published, discussed, shared with the
14 industry, with the ACRS, with the NRC staff members,
15 and there is nothing that we are not aware of.

16 MR. CARUSO: This is our guidance. This
17 is our focus. These are our criteria in doing this
18 review. Not so much a PRA review as a review of their
19 use of the PRA and -- but you can't get around the --
20 is the PRA at a quality level that is good enough I
21 guess I think is one of the key issues that we have
22 had.

23 MEMBER APOSTOLAKIS: But see how carefully
24 they have phrased this. Determine how the risk
25 associated with the design compares against --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 compares against the Commission's goals. That's how
2 you interpret --

3 MR. KRESS: But for my information, where
4 will I find this well-known LRF? It's relatively new.

5 MR. HAMZEHEE: These are not new. These
6 are among different policy papers and documents. And
7 if you want, we can find you the reference documents
8 that have this information available. There isn't one
9 single place that you can find it, in other words. Am
10 I right, Mark?

11 MR. KRESS: I just wasn't familiar with
12 the LRF.

13 MEMBER APOSTOLAKIS: Yes, the LRF of 10⁻⁶,
14 I think that was a question we raised in the past,
15 too.

16 MR. KRESS: Yes, we've raised it.

17 MEMBER APOSTOLAKIS: Where did this come
18 from? You say the Commission --

19 MR. KRESS: I didn't realize it had
20 actually become a Commissioner's goal.

21 MEMBER SHACK: Yes. The trick is, though,
22 they never defined what an LRF is.

23 MR. KRESS: And that was one of the
24 questions that --

25 MEMBER SHACK: You have a frequency but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not a definition.

2 MR. HAMZEHEE: Well, we will get back on
3 that.

4 (Laughter.)

5 MEMBER SHACK: They never defined it.
6 That's -- we're getting distracted. Let's let them go
7 on with their show.

8 MR. HAMZEHEE: Let's get back to the --
9 I'll get you the document.

10 MR. KRESS: Appreciate it.

11 MR. HAMZEHEE: Sure.

12 MEMBER APOSTOLAKIS: So where are you
13 now? Slide what?

14 MR. CARUSO: We're Slide 8.

15 MR. HAMZEHEE: Do you have any more
16 questions about Commission's objections?

17 MR. KRESS: But, George, couldn't you
18 agree that since they all have been -- because you can
19 say a positive statement about all of these being met?

20 MEMBER APOSTOLAKIS: I'm sorry. What?

21 MR. KRESS: On this slide, I would have
22 thought that you could be positive that all of these
23 have been met.

24 MEMBER APOSTOLAKIS: Yes, it could be
25 positive. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, I have a minor question, though.
2 What if their CDF were six times 10^{-5} ? Would you
3 conclude that they compare favorably with the
4 Commission's goal of 10^{-4} ?

5 MR. HAMZEHEE: Probably not.

6 MEMBER APOSTOLAKIS: Ah, okay. Good.
7 It's close enough that, then, you need to include all
8 of the other things -- other risk contributors, make
9 sure the comments you made this morning are adequately
10 addressed. Is the common cause values correct, what
11 about this, what about that. But since there are four
12 -- three, four orders of magnitude, even if you add
13 some of those things, there is still a high confidence
14 that they are below the Commission's safety goal.

15 MEMBER APOSTOLAKIS: Good.

16 MR. CARUSO: I think for me -- in
17 wrestling with that question -- you know, it is 10^{-8} .
18 And, you know, whatever it is -- two orders of
19 magnitude smaller. Why am I -- what should I really
20 expect? Should I expect that to be, you know, a
21 number that is in the right range? Or should I expect
22 them to be substantially above the goals?

23 And I looked at -- the thing that I looked
24 at was: what have they done compared to plants that
25 we know -- we sort of have a benchmark in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating plants -- 10^{-5} , 10^{-6} . These guys are, what,
2 two, three orders of magnitude higher.

3 How are they different? So we looked at,
4 you know, the things that they've done, and they're
5 substantial in terms of, you know, station blackout
6 and improving ATWS protection.

7 All right. Let's move to Slide 8.
8 Basically, we are basically walking through the
9 sections of the SER. Section 19.1.2, quality of PRA,
10 the major topics in this area were -- that we looked
11 at were the success criteria for common cause
12 failures, the PRA technical adequacy, and the
13 maintenance program. We felt these were important
14 issues.

15 Since common cause failures, because the
16 PRA was showing that because the diversity and
17 redundancy, common cause was the major contributor.
18 So we looked at how they treated common cause
19 failures, and we felt that they had done an
20 appropriate job in terms of methodology and data.

21 PRA technical adequacy -- we felt that,
22 you know, we had given it --

23 MEMBER APOSTOLAKIS: Let's talk about
24 common cause failures. By common cause failures do
25 you mean the standard approach for redundant systems,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and so on? Are you satisfied they have done a good
2 job in the digital I&C?

3 MR. CARUSO: Is it a software issue?

4 MEMBER APOSTOLAKIS: Yes. I mean, are you
5 saying --

6 MR. CARUSO: Here I agree with you again.
7 10^{-4} -- I don't know what this number is. I don't
8 think anybody knows what this number is. And I'm not
9 sure when anybody will know what this number is.

10 MEMBER APOSTOLAKIS: Do you raise that
11 issue anywhere?

12 MR. CARUSO: What I thought was they put
13 a relatively -- the core number in there that made the
14 common cause software failure show up as a significant
15 contributor. So, you know, essentially if you are to
16 go lower in that -- higher in that number, you know --

17 MEMBER APOSTOLAKIS: It would still be
18 dominant.

19 MR. CARUSO: Right. It would still -- so,
20 I mean, they -- well, I think it tells us that as long
21 as we feel uncertain about what the common cause
22 failure rates are for software and for digital I&C
23 systems, that, you know, they should be treated as
24 significant contributors.

25 I don't think you can -- I think -- well,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the other thing is if you look at the modeling they
2 did, I mean, there is a whole lot of stuff in there
3 that's equipment and sensors and, you know, software
4 common mode failure in one little box down there.
5 And --

6 MEMBER APOSTOLAKIS: But we do have
7 regulations, at least guidance --

8 MR. CARUSO: Yes.

9 MEMBER APOSTOLAKIS: -- so for the
10 deterministic guidance that deals with the issue of
11 common cause failures for digital I&C. I mean, they
12 don't have to quantify everything, in other words.
13 The decision, as we have been told many times, is the
14 result of the whole process. And the process includes
15 deterministic evaluations, probabilistic evaluations,
16 and so on.

17 MR. HAMZEHEE: Let me just also expand on
18 what Mark is saying. We don't intend to resolve,
19 under ESBWR, all of the existing issues related to
20 digital I&C. It's outside the scope. But if we claim
21 that we resolved it, we are telling -- we are not
22 telling you the truth. There are issues that industry
23 is dealing with, and they are still working on them.
24 And it's not or has not been resolved as part of ESBWR
25 design certification PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, we have two options under these
2 conditions. Either don't put any numbers next to
3 digital I&C and just don't model it. That means you
4 are assuming the success of the digital I&C 1.0 or the
5 failure probability is zero, or go and use your best
6 of knowledge with what you have available and what you
7 know about your digital and do some quantification.

8 GE decided to go ahead and use what -- the
9 numbers that they could find or could to some degree
10 justify, and haven't included those numbers and
11 modeling into their PRAs. That's what they have
12 chosen, and Mark is right -- we are not able to
13 resolve some of the issues, and we don't know enough
14 about system yet to either agree or disagree.

15 MR. CARUSO: But we did sit down with Rick
16 and have him go through this design, and, you know, I
17 think it's safe to say that the types of redundancy
18 and diversity that they put in their design are, you
19 know, very strong. They end up using different
20 designers, different --

21 MEMBER APOSTOLAKIS: I don't doubt that.
22 It seems to me that you should flag that issue, say,
23 "Is anybody reviewing the digital I&C arrangement they
24 have from the deterministic perspective?"

25 MS. CUBBAGE: Absolutely.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: Oh, yes.

2 MEMBER APOSTOLAKIS: Okay. All right. So
3 why, then, don't you say that this is happening there,
4 and in the PRA use it -- find the right words to say
5 that you are not really that sure about the numbers.
6 I would expect to be flagged down.

7 MR. HAMZEHEE: All right. That's a good
8 comment. I think we will write it down and go back
9 and --

10 MEMBER APOSTOLAKIS: Don't feel
11 responsible --

12 MR. HAMZEHEE: No, no, no.

13 MEMBER APOSTOLAKIS: -- that everything
14 has to be quantified.

15 MR. WACKOWIAK: I have a comment on that.
16 Rick Wackowiak from GEH again.

17 MEMBER APOSTOLAKIS: Yes.

18 MR. WACKOWIAK: The difficulty with
19 leaving it up to the deterministic side is I think
20 they may come up with different insights than what we
21 would, than by looking at it this way. If you look at
22 it directly, the digital I&C issued only from the
23 deterministic side, assuming that the system can fail
24 and you need to do something about that, you end up
25 with a situation where you want to add more diverse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control systems and add and add and add, whereas when
2 we do it this way in the PRA, at least as dubious as
3 the number may be, when you add new control systems
4 you also bring with it the baggage of a control system
5 can spuriously operate or do something that you don't
6 want it to do. And we can catch those in the way we
7 did our PRA modeling.

8 And so it kind of puts a balance on the
9 deterministic side, which is good to do, because we
10 can say that maybe just adding new control systems as
11 a backup is not always the right answer, because it
12 can cause more problems sometimes than what it is
13 solving.

14 And we can do -- we can look now at our
15 digital I&C system. And with the failure rate of
16 10^{-4} , for the software, if you will, adding diversity
17 with another digital system is prudent in some
18 applications, but it's not prudent in others. And
19 backing up an isolation function at 10 -- if the
20 failure rate of that system really is 10^{-4} , then you
21 don't want to have another digital system that can
22 isolate systems that you want to have work in the
23 plant.

24 So I think there has to be a balance. We
25 have to do something. I don't know what the right

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thing ultimately will be, because that is still up in
2 the air. But I think we -- if we leave it to the
3 deterministic side only, we're going to get more
4 digital systems in places where we don't want them.

5 MEMBER APOSTOLAKIS: Well, it's not
6 entirely clear without that, because you can always
7 raise this issue of spurious actuation without
8 resorting to probability. Plus, there seems to be a
9 consensus that we don't really understand how I&C
10 systems fail. So if we start putting numbers there
11 just to make a point, it doesn't make much sense to
12 me. But as long as the staff identifies this as some
13 let's call it weakness of the analysis, then maybe
14 that's good enough.

15 See, we've had this problem over the years
16 that the lack of information never stopped the
17 regulatory guys.

18 (Laughter.)

19 They will make a decision no matter what,
20 which is fine. But it has to be based on knowledge,
21 on what we know. And if we don't know enough, maybe
22 be conservative and all of that. But the truth of the
23 matter is we don't understand how these digital I&Cs
24 fail. So to say, you know, I put in 10^{-4} and see what
25 happens.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the other problem that perhaps is not
2 your problem, but is our problem here, is that the
3 moment these things go on paper then they create a
4 precedent. Then, you know, the next guy says, you
5 know, why did you approve it then? Why don't you do
6 it to me, too? You know, it creates a problem. The
7 agency is spending a lot of resources right now trying
8 to understand how the I&C may fail. And when it comes
9 to real decisions, we say we don't care. That doesn't
10 make much sense.

11 MR. HAMZEHEE: We wrote it down. We'll go
12 back and see what's the best way to address this in
13 our SER. But I think the key thing, as Mark said, is
14 that we ensure that they have enough defense-in-depth
15 diversity into the design, so that if some of these
16 numbers are not correct or inadequate that defense-in-
17 depth would take care of it.

18 MEMBER APOSTOLAKIS: Right.

19 MR. HAMZEHEE: So at least that's what we
20 could do during the design certification review. I'm
21 sorry.

22 MEMBER BLEY: I guess I just want to get
23 something on the record, George. In the I&C
24 Subcommittee, I agree, we ought to be focusing on
25 failure modes and understanding them. I think having

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 worked on, as was done here, including the fault tree
2 analysis that includes some of the interactions with
3 people.

4 Some of the things that we do know how to
5 model, and some of the structure that they've done,
6 gets us moving in the way of getting there. But I
7 think the statement, as you suggested from the staff,
8 as you said, that we don't have a lot of confidence is
9 an appropriate one now. But if we don't have people
10 trying to move these models forward, it is going to be
11 a long time before we get there.

12 And I haven't looked in great detail at
13 what is here, but at a little and some of what is
14 there online -- what Rick said -- is showing things
15 that can affect the system, and I think that's how
16 we'll move ahead.

17 MR. CARUSO: Okay. Let's continue on.
18 Slide 8. PRA technical adequacy -- in the DCD Rev 4,
19 GEH had indicated that, to the extent possible, they
20 had met category -- capability category 2 attributes
21 of the PRA standard. And so we felt like, gee, we
22 need more than that, so we queried them on extent of
23 basically, you know, you need to tell us and explain
24 to us in more detail why you think this PRA is of good
25 enough quality for the design certification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 application.

2 And they responded to that. They
3 explained to us their review of the PRA against the
4 attributes, the capability category 2 attributes in
5 the standard, and identified those that they didn't
6 treat and identified why they didn't or what the
7 impact of not treating them was. And we felt that
8 their response was adequate.

9 MEMBER BLEY: Can I say something here?
10 Mr. Chairman, maybe this is something we ought to hold
11 for more detailed meetings. But I think the fidelity
12 of the fault trees to the systems descriptions is
13 something we want to get into in some detail with you.
14 And at least some of us in looking have had some
15 concerns in that area, and I don't -- it seems that's
16 an area where you folks have accepted what's been done
17 as being appropriate. I think we want to get into
18 that in some detail.

19 In the other one, it's just a single
20 thing, but it's the one I raised earlier this morning.
21 These vacuum breaker valves are very unique, and the
22 analysis that was done to come up with a number cites
23 a report, and you go to that report and they lay out
24 an approach through a Bayesian analysis. And they
25 define a prior that is kind of pinched on the ends,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and what they conclude is that you can run 3,000 tests
2 to ensure that your failure rate is less than one in
3 30,000. And I think you guys ought to go back and
4 look at that again.

5 MR. HAMZEHEE: Yes. We already took a
6 note this morning.

7 MEMBER BLEY: Okay.

8 MR. CARUSO: I think in regard to your
9 comment about fault trees and review of the fault
10 trees, when we were thinking about how are we going to
11 deal with these pages and pages and pages of fault
12 trees and it's a review -- I think what we thought was
13 this is too much. And we said, "Well, what about the
14 other PRAs that are done in the industry?"

15 And so we raised with GEH, you know, "Are
16 you going to peer review this PRA?" Because that's
17 how we -- that's what we rely on in other PRA reviews,
18 to make sure that that level of detail has been looked
19 at to an adequate level, and that's within our
20 standard.

21 Well, and then they said, "Well, we don't
22 have independent reviewers to do it," and so they did
23 something -- a compromise in a sense of organize their
24 own peer review team and sort of follow the peer
25 review thing of bouncing it off the standard. So I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think when you discuss these issues with the Committee
2 about how to, you know, broaden the standard for
3 design certification PRAs, these are the kinds of
4 issues that are important.

5 MEMBER BLEY: Let me make a suggestion.
6 Before we have a detailed meeting to look at them,
7 take a few systems -- I&C, GDCS -- and look at the top
8 levels of the fault tree. Go down one or two levels,
9 or three, and see how you see it matching up.

10 MR. HAMZEHEE: All right. Okay.

11 CHAIRMAN CORRADINI: We are moving on?

12 MR. CARUSO: Yes.

13 CHAIRMAN CORRADINI: Good.

14 MR. CARUSO: Slide 9 discusses the
15 significant open items here. We just talked about the
16 PRA quality. I think Rick went through the thermal
17 hydraulic analysis for the passive system, what
18 they're doing there. Unless there is any additional
19 questions, I don't think we need to go -- repeat that.

20 MEMBER ARMIJO: The TRACG model, that has
21 been around for a long time, what is the problem with
22 using the TRACG for calculating the clad temperature.
23 What is the issue there?

24 MR. CARUSO: The issue there is that the
25 staff never reviewed it for that application, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the ESBWR, in the design basis analysis, they never
2 uncovered the core. So the staff didn't review the
3 ability of the code to deal with core uncovering and
4 approaching 2,200 degrees.

5 We're asking GE to address this. We're
6 not saying, "You need to do a design basis" -- you
7 know, we're going to do a design basis review of this
8 part of the code. But you need to give us confidence
9 because the code has been around and it has been
10 tested. Give us some good confidence that it can
11 handle that. I think they -- we haven't seen their --
12 they have submitted their response. We haven't looked
13 at it, but I think there is probably a success path
14 there.

15 MEMBER ARMIJO: Has the staff used its own
16 codes for calculating that -- those situations for
17 comparison with what GE has done?

18 MR. CARUSO: George Thomas, are you here
19 anywhere? Can you --

20 MS. CUBBAGE: If you're referring to
21 design basis, the design basis space, we use the TRACE
22 code, and, you know, we don't look at uncovering in that
23 situation either.

24 MR. THOMAS: This is George Thomas,
25 Reactor Systems. TRACG, we are using for a LOCA and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where we are calculating the cladding temperature.
2 But for the PRA, and the Appendix K, they will not be
3 the same. But being able to review the TRACG for the
4 PRA application --

5 MR. CARUSO: His question was: have we
6 used our own codes to look at this stuff?

7 CHAIRMAN CORRADINI: And when you do an
8 audit calculation, what do you use? The core design
9 is essentially a current BWR core design. So what do
10 you use for your audit calculations?

11 MR. THOMAS: TRACE. You are using --

12 MEMBER SHACK: They are comparing a design
13 basis calculation where it's flooding, not 2,200. So
14 the -- have you done it with -- you know, have you
15 done any check calc -- for your PRA checks, have you
16 done it with another code, if not TRAC? I mean, if
17 not TRACE.

18 MEMBER APOSTOLAKIS: But you are using the
19 codes of the applicant, or you are not --

20 MR. THOMAS: We are using TRACE. We are
21 using the calculation to verify TRACG. This is being
22 done by our different --

23 MEMBER SHACK: But you are not using it
24 for success criteria of this type.

25 MEMBER APOSTOLAKIS: Right, right. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have used it in the past to certify the code.

2 MR. HAMZEHEE: But I think you may have
3 heard earlier that the issue we had here was we wanted
4 to address some of the uncertainties associated with
5 passive systems, success criteria, and GE used MAAP-4,
6 which is the acceptable code for industry. And we
7 told them that because MAAP-4 we have now reviewed it
8 and approved the code, and may not know enough about
9 it, why use -- why don't you use TRACG to make some
10 comparison and benchmarking. That was the overall
11 concern with this RAI.

12 MEMBER ARMIJO: Then, they did it.

13 MR. HAMZEHEE: Then, they did it. Now we
14 have concern for some cases using TRACG make sure you
15 can justify that TRACG can model it properly.

16 MEMBER ARMIJO: Okay. And they have
17 responded to your --

18 MR. HAMZEHEE: They are working on it.
19 They haven't done anything yet. He is going to tell
20 you about the status. We don't know the results yet.
21 So let's wait until we get something, and then we'll
22 get back to you.

23 MEMBER ABDEL-KHALIK: I'm sorry. Let me
24 just rephrase --

25 MR. HAMZEHEE: Sure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: -- what you said.
2 You asked him to do the comparison with TRACG, and
3 after they did that you came back and said, "Do you
4 have questions about TRACG?"

5 MR. CARUSO: No. All the questions were
6 at the same time. The one question was we -- they
7 were separate issues. The first issue was we wanted
8 to make sure they had -- they had done their --
9 basically, their benchmark of MAAP for cases where
10 there was no core uncovering, no steam, no approaching
11 2,200 degrees, although 2,200 degrees was what they
12 said -- that's our criteria for success.

13 But they had compared the code that they
14 used to do all the studies with cases that were, you
15 know, design basis cases. They weren't cases where
16 you only had, you know, two valves or two out of six
17 or whatever. They weren't the cases in the PRA.

18 We said, "Hey, we want to see -- we want
19 to see that MAAP can do the job when, you know, you
20 guys -- you are approaching a severe accident, you're
21 uncovering the core." You know, that's where the
22 benchmarks -- we want to make sure, because we -- we
23 are aware of issues with some of the thermal hydraulic
24 capabilities of MAAP. And we felt for those reasons
25 that they could at least do the benchmarking at those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 points and show us that the codes were good there, and
2 then we would have confidence that MAAP was okay.

3 The second issue was that they had said
4 that their success criteria in doing this was going to
5 be core uncovering of 2,200 degrees clad temperature,
6 and they were going to use TRACG. And our folks were
7 concerned that we had never reviewed TRACG for that --
8 for that type of heatup. And we wanted to have some
9 confidence there.

10 CHAIRMAN CORRADINI: So let me just ask
11 that question again, because I'm still not clear I got
12 the answer I was expecting. So in current BWRs, the
13 geometry is pretty much the same. So what other
14 calculations does the staff do for current BWRs under
15 the situation you have core uncovering? It's not trace,
16 is it?

17 MEMBER SHACK: It's Appendix K LOCA.

18 CHAIRMAN CORRADINI: It's Appendix K LOCA
19 with RELAP 5 I would assume, is what I was expecting
20 to hear, but I could be wrong.

21 MR. HAMZEHEE: I think for the design
22 basis calculations, George, if you can expand on it,
23 what do you use for design basis calculation during
24 the confirmatory or independent analysis by NRC staff?

25 MR. THOMAS: We are using RELAP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMZEHEE: RELAP?

2 MR. THOMAS: RELAP, yes.

3 MR. HAMZEHEE: Okay. Fine.

4 CHAIRMAN CORRADINI: Okay. Thank you.

5 MEMBER APOSTOLAKIS: Now, when it comes to
6 this treatment of parameters affecting thermal
7 hydraulic uncertainty, can you elaborate on that?
8 What do you mean by that? Do you mean things that may
9 affect the performance of the passive system like --

10 MR. CARUSO: Heat transfer coefficients in
11 the isolation condensers.

12 MEMBER APOSTOLAKIS: Yes. And how about
13 things that may affect the geometry?

14 MR. CARUSO: Tank size, valve area.

15 MEMBER APOSTOLAKIS: You don't get into
16 those things?

17 MR. CARUSO: Yes. The issue was they
18 didn't tell us what parameters they treated. And they
19 didn't tell us how they treated it. You said --

20 MEMBER APOSTOLAKIS: Oh, so it's a broader
21 question.

22 MR. CARUSO: Please tell us, you know,
23 which ones did you use? How did you treat them? Were
24 they bounding? Were they nominal? So it was -- we
25 just didn't have the information. We felt it was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 important to understand that.

2 MEMBER APOSTOLAKIS: And this is not in
3 Rev 3 of the PRA, right?

4 MR. WACKOWIAK: A partial response is in
5 Rev 3.

6 MEMBER APOSTOLAKIS: Rev 3.

7 MS. CUBBAGE: That was Rick Wackowiak.

8 MR. HAMZEHEE: Rick, will you speak up in
9 the microphone and introduce yourself, please?

10 MR. WACKOWIAK: This is Rick Wackowiak.
11 It's partially addressed. The pieces that we have
12 already answered in our responses are in Rev 3. The
13 pieces that have not been sent in as an answer are not
14 in Rev 3 at this point.

15 MEMBER ARMIJO: You are still working on
16 it.

17 MR. WACKOWIAK: Yes.

18 MEMBER APOSTOLAKIS: Okay.

19 MR. CARUSO: Okay. Slide 10 is design
20 features. I think we talked about that. Rick talked
21 about the various design features they have. I think
22 I -- in my opening remarks I mentioned I felt that
23 they had incorporated a wide diversity of design
24 features that addressed previous vulnerabilities and
25 that they included a table. There's a table in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SER that compares the design features in ESBWR with
2 those in previous BWRs, and tries to focus on places
3 where vulnerabilities have been addressed.

4 We don't have any open items in this area.
5 We felt like a number of the Commission's objectives
6 could be addressed with the discussion of design
7 features.

8 Slide 12 -- 19.1.4 deals with internal
9 events at power insights for Level 1 and Level 2 PRA.
10 I think Rick pretty much discussed those insights. We
11 didn't have any open items in that area.

12 MR. KRESS: Did you consider using MELCOR
13 to audit some of their Level 2 results?

14 MR. CARUSO: I believe that was done. Ed?

15 MR. FULLER: This is Ed Fuller from the
16 NRC staff. MELCOR was used to do some confirmatory
17 assessments for the -- to evaluating severe accident
18 behavior and ability of the severe accident mitigation
19 features to respond.

20 And a number of scenarios were evaluated,
21 and quite a bit of detail was gone into to evaluate
22 these scenarios, at least six or eight scenarios.
23 Some of those scenarios were actually compared with
24 equivalent sequences that GE analyzed in their PRA,
25 and the results of the comparison appear in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 document that was prepared and submitted to the NRC,
2 the latest revision of which was at the beginning of
3 2007.

4 MEMBER SHACK: But those reports from EPRI
5 don't seem to be in ADAMS. They're referenced in the
6 SER, but when I --

7 MR. FULLER: Can you get to the -- can you
8 get to the proprietary part of that?

9 MEMBER SHACK: Yes. When I come in
10 through CITRIX.

11 MS. CUBBAGE: We'll check on that.

12 MR. FULLER: Well, I think they're there.

13 MEMBER SHACK: I searched six ways from
14 sundown and couldn't come up with it. But --

15 MR. FULLER: Is Hossein Ismaili here?

16 MR. HAMZEHEE: We will get back to you,
17 and we will provide it to you if you can't get it.

18 MR. FULLER: Because Hossein and I went
19 through this a little while ago.

20 MR. ISMAILI: Yes. This is Hossein
21 Ismaili, staff. I just recently put the ESBWR severe
22 accident report into ADAMS. I can get you the ADAMS
23 number and give it to Ed.

24 MEMBER SHACK: Okay. Within the last
25 week?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ISMAILI: No. Maybe a few months
2 back. I don't remember.

3 MEMBER SHACK: Okay. I can't find it.
4 You'll have to tell me how to do it.

5 MR. CARUSO: Go to Slide 14, external
6 events at power PRA. Covered the seismic margins
7 analysis, the high winds analysis, fires, and floods.
8 We had open items in two areas -- a seismic margins
9 analysis and a high winds analysis.

10 Rick went through those and we concur with
11 his assessment of where things are and what the issues
12 are. And I can go through it again if you want, or --

13 CHAIRMAN CORRADINI: I have a question.

14 MEMBER APOSTOLAKIS: Go ahead.

15 CHAIRMAN CORRADINI: I guess at the end
16 you said you had 17 open items. So maybe you weren't
17 here last time we were together, and so the general
18 feeling of the Committee was -- and I'll just say it
19 now, maybe you can end with this in your conclusion.
20 I'm curious from the staff's standpoint -- of the 17,
21 what is the ones that were you? Are they all of equal
22 concern? Are some just rudimentary clarifications?
23 That sort of classification would help me.

24 But you can wait until the end to kind of
25 summarize that. That's I guess what I'm looking for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in all of this, because I -- a lot of these Rick has
2 gone over, but I'm curious, from the staff's
3 standpoint, which ones keep you up at night, if
4 anything keeps you up at night?

5 (Laughter.)

6 MR. CARUSO: Well, I know some of these
7 keep some people up at night.

8 (Laughter.)

9 You know, I think this one on the spectrum
10 shape is we're at a -- on that one, and I don't think
11 there's a success path in sight yet. So I would say
12 that --

13 MEMBER SHACK: Let me understand that. I
14 thought -- I was confused on that one. So the
15 certified design one is like the -- what is it, the
16 old Reg Guide 1.60, the standard spectrum, is that
17 what they use?

18 MS. CUBBAGE: Plus. Plus, it envelopes
19 the North Anna site.

20 MEMBER SHACK: Oh, it has that extra bump.
21 It's got -- so that's the certified seismic design.
22 Now, which one are they using for the -- to calculate
23 the HCLPF? Just the old one?

24 MS. CUBBAGE: From a design perspective --

25 MR. XU: Jim Xu from the staff. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design -- the certified design response factor is the
2 combination of the reg guide and the specific wind
3 spectrum from North Anna, okay, is envelope spectrum.
4 It kind of -- it looks like two humps. One hump for
5 low frequency; the other hump for high frequency.
6 Right, okay.

7 But there is two issues that concerns
8 staff with regard to seismic margin assessment GEH had
9 to perform. One is the shape. Okay. And that has to
10 do with the definition of seismic margin earthquake.
11 Okay.

12 We believe, as a standard design, you
13 should use the CSDRS as the seismic margin earthquake
14 in your seismic margin assessment. GEH chose to use
15 a performance-based spectrum, which is somewhat
16 different from the CSDRS in the low frequency range.

17 And that's one disagreement we have, and
18 we are going to continue to discuss on how to resolve
19 that issue.

20 CHAIRMAN CORRADINI: Okay. Okay. I
21 understand now.

22 MR. HAMZEHEE: Is it clear?

23 MEMBER SHACK: To me at any rate, yes.

24 MR. HAMZEHEE: All right.

25 MR. XU: The second issue has to do with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the COL holder's item. Okay. Since the majority of
2 SSCs in the cost sites has assumed a HCLPF value,
3 okay, they only assessed five structural components
4 for the HCLPF capacities. The rest of the structural
5 system component in the cost site has assumed a HCLPF
6 value of 1.67 times the design basis.

7 Therefore, they have a COL holder's item
8 to confirm by the holder prior to fuel loading that --

9 MEMBER SHACK: That seemed fair enough.
10 Until you have a structure, you can't go off and
11 compute the --

12 MR. XU: That's a very fair statement, and
13 we agree with that. But we believe if we -- if we
14 have to draw a conclusion that a certified design has
15 a seismic margin, had that margin 1.67 times the
16 CSDRS, okay, then the holder's item, should we use
17 that as a reference for HCLPF calculation? Okay.

18 The GEH had a different position on that.
19 They believe that the specific GMRS should be used for
20 that confirmation, and that is another issue we have
21 the difference with GEH. So those are the two major
22 issues that we have.

23 MR. HAMZEHEE: That is the safety margin
24 that we have built into this calculation.

25 MR. WACKOWIAK: This is Rick Wackowiak

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again from GEH. The situation there is is that the
2 CSDRS has a different shape than the GMRS in all
3 cases. You know, it's the one hump versus two hump.
4 And why would we want to have a plant confirm margin
5 above an event that can't happen at that site? That's
6 what our position is with this, that when we go to do
7 the confirmatory HCLPF, it should be based on what is
8 at the site, the best estimate for the site.

9 If it was simply a case that it was the
10 same shape but a different level, we could probably
11 talk about that, because then it's margin. But here
12 it's margin against an event that can't happen, and
13 that's what our main point is about using the GMRS
14 versus the CSDRS.

15 MR. HAMZEHEE: And for the sake of time,
16 we are not going to resolve it now.

17 (Laughter.)

18 Can we wait for a response?

19 MEMBER APOSTOLAKIS: Let me ask another
20 question, though. Since the seismic analysis is based
21 on margins, and the fire is really the same thing --
22 bounding -- we really don't know what the contribution
23 to core damage frequency from earthquakes is, right?

24 MR. HAMZEHEE: That's correct.

25 MEMBER APOSTOLAKIS: And, in fact, they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 could be dominating the other, the transients, for
2 example, that have been identified as dominant
3 contributors. And we don't know by how much. All we
4 know is that there is a high confidence -- 95 percent
5 probability that -- you know, the probability of
6 failure is less than .05.

7 How, then, can I compare with a safety
8 mode if I don't know?

9 MR. CARUSO: Well, that you can't compare.
10 All you can do is get a good feeling that if they --
11 you know, based on their analysis, that if they
12 satisfy the COL requirement to meet those HCLPFs, that
13 they will, you know, design --

14 MEMBER APOSTOLAKIS: But let me put it a
15 different way. We have said earlier -- I think
16 Hossein said it -- that they are giving us at 10^{-8} ,
17 maybe close to 10^{-7} , and there are three orders of
18 magnitude until I hit the Commission's goals. And
19 there is an assumption there that other things will
20 not really raise the CDF by three orders of magnitude.

21 So is it reasonable to say that these
22 other things include earthquakes and fires, that I
23 will not come close to 10^{-4} ?

24 MR. HAMZEHEE: Well, let me express my
25 opinion now. At the design state, that's the best you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 can do. However, again, once you get plant-specific
2 PRAs during the actual COL holder and actual
3 construction of the plant, then they are asked by
4 Part 52 to perform seismic PRA if the standard exists.
5 At that time, they will perform a risk assessment of
6 seismic.

7 And if there are some vulnerabilities, or
8 things that may have high risk contributions, they may
9 have to make some seismic improvements. They may have
10 to have some additional protection to ensure that the
11 risk profile is acceptable.

12 MEMBER APOSTOLAKIS: But when it comes to
13 the objectives of the Commission that you had earlier
14 on a slide --

15 MR. HAMZEHEE: Yes.

16 MEMBER APOSTOLAKIS: -- it seems to me you
17 have to use very careful language when you write your
18 SER.

19 MR. HAMZEHEE: Yes. That's right. But
20 again, remember, there is no site right now, so the
21 best they can do --

22 MEMBER APOSTOLAKIS: Oh, I know the
23 reasons. I'm just addressing the conclusions that,
24 you know, we meet the goals, we meet this, we meet
25 that. With a margins analysis, especially if I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 already down to 10^{-8} , I don't know. Okay? I would be
2 surprised if this thing was 10^{-4} , but the fairer
3 statement is that we really don't know and that at
4 this stage maybe this is good enough.

5 MR. KRESS: I recall, George -- I recall
6 an ACRS fellow at one time was chartered to make a
7 study to see if you could convert HCLPF -- how he
8 would pronounce it -- into an estimate of the CDF
9 value. I don't know what became of this study.

10 MEMBER APOSTOLAKIS: I don't know. That
11 was before my time. You can imagine how far it goes.

12 MR. KRESS: It wasn't before Bill Shack's
13 time.

14 MEMBER APOSTOLAKIS: Bill Shack is there
15 from the creation.

16 (Laughter.)

17 MEMBER SHACK: I have a different
18 question, though, for Rick, and that is, the
19 performance-based criterion sort of implies a CDF of
20 around 10^{-5} . Do you think that's an appropriate goal
21 for this plant?

22 MR. WACKOWIAK: My understanding -- this
23 is Rick Wackowiak. My understanding is that the
24 initiator is implied at around 10^{-5} performance base,
25 and then we show margin of one and two -- or two-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thirds beyond that. So it's less than 10^{-5} .

2 MEMBER SHACK: That's -- I think that's
3 the staff's approach. They take the 10^{-5} initiator,
4 and then add the 1.67. I think the performance-based
5 one backs off on that 10^{-5} initiator, because you've
6 got margin built into the plant and you're going to
7 really get 10^{-5} CDF, which is where everybody sort of
8 is at. And, therefore, it is good enough for current
9 plants. Is it good enough for this plant? Worth
10 looking into.

11 MR. CARUSO: Okay. We're going to move on
12 to Slide 17. But before I do, I wanted to mention a
13 couple of things in regards to Dr. Corradini's
14 comment. One is that the 17 open items all aren't
15 covered in the slides. There is a number of open
16 items that are very low, didn't even meet the
17 threshold for talking to you about, and those are no
18 problem.

19 And the other thing I'll say is the ones
20 that we have talked to up to the point of the seismic
21 design one are -- we see success paths. We're not
22 concerned about those.

23 MR. HAMZEHEE: In other words, there are
24 no show-stoppers.

25 MR. CARUSO: Right. On the high winds

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis, we had several open items, and Rick went
2 through those. And we're awaiting your responses, and
3 I think there are probably success paths there, too.

4 CHAIRMAN CORRADINI: Thank you.

5 MR. CARUSO: Slide 17, PRA for other
6 operational modes. I think these are the most
7 interesting of the open items, because they address
8 whether or not systems we credited in the PRA, you
9 know, are going to function as they were assumed. So
10 I think -- of all of the open items, I think these are
11 probably the ones of most interest to us, and we are
12 working with GE, and there are some -- we are walking
13 down paths.

14 MEMBER APOSTOLAKIS: Parallel paths.

15 MR. HAMZEHEE: I think you heard Rick this
16 morning.

17 MEMBER SHACK: Riemannian or Euclidean?

18 (Laughter.)

19 MR. HAMZEHEE: And then, you also heard
20 Rick this morning that mentioned when he was going
21 through the risk profile that the shutdown risk is
22 over 90 percent. And because of that, we spend more
23 time and pay more attention to these issues related to
24 shutdown mode risk assessment. So we didn't just
25 spend time on everything -- areas that were more risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significant.

2 MEMBER APOSTOLAKIS: So shutdown,
3 earthquake, and fire, all at the same time.

4 MR. HAMZEHEE: What's the probability of
5 that happening, George?

6 MEMBER APOSTOLAKIS: 10^{-3} . It's of the
7 same basis as a software.

8 MR. CARUSO: If there are no further
9 questions on the open items in the area of the PRA for
10 other operational modes, we'll move on.

11 Now, Slide 21 is severe accidents. Do you
12 want to go through that or hold off on that, since
13 you --

14 CHAIRMAN CORRADINI: Well, you can tell us
15 what you're thinking.

16 MR. CARUSO: All right.

17 CHAIRMAN CORRADINI: I'm curious.

18 MEMBER SHACK: I think if you are beating
19 them up, we won't have to now.

20 MR. CARUSO: In severe accident
21 mitigation, the only open item there was the BiMAC
22 test report. We have the report now, and we are
23 reviewing it. I don't anticipate that -- there being
24 issues there, but I don't want to put words in
25 anybody's mouth.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Has the staff
2 reviewed ROAAM?

3 MEMBER SHACK: Oh, don't go there.

4 (Laughter.)

5 MEMBER APOSTOLAKIS: Is there a safety
6 evaluation report of ROAAM?

7 MEMBER SHACK: Not that I'm aware of.

8 MR. KRESS: They accepted it for DCH
9 issues, as best I remember.

10 MEMBER SHACK: It was first developed for
11 steam explosions in '85.

12 MR. KRESS: Steam explosions.

13 MR. FULLER: This is Ed Fuller from the
14 staff. The ROAAM report is essentially Chapter 21 of
15 the PRA, and we reviewed it as part of reviewing the
16 PRA. And with the exception of what you see up there
17 right now, the BiMAC test report, which was an RAI or
18 two RAI open item, we pretty much have written what we
19 feel about it in our SER of open items.

20 We are reviewing the test -- you know,
21 just to answer the question you are all thinking
22 about, we are currently reviewing this topical report.
23 Last summer we actually went out and saw the rig and
24 got a make-believe or a repeat of a test that was
25 already done to see how it worked.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, of course, we wanted to see the test
2 results, and those RAIs are asking essentially for the
3 test program and test results. We now have them. We
4 find that these -- this is a very significant report.
5 We are having a contractor help us, and we expect to
6 see a draft report in the middle of July, and RAIs
7 produced --

8 MEMBER APOSTOLAKIS: Which report are you
9 referring to, Ed?

10 MR. FULLER: We are reviewing the test
11 report that was produced by GE, providing the test
12 results for the BiMAC.

13 CHAIRMAN CORRADINI: But I think, Ed, what
14 George was asking is, the process by which you do the
15 calculation -- let's say you had all of the
16 experiments you wanted. The ROAAM process, I think
17 George is asking, has it been reviewed? And I'm not
18 aware of it.

19 MR. FULLER: It has been reviewed as part
20 of reviewing the PRA, Chapter 21 of the PRA. And our
21 SER with open items discusses the recoverability, the
22 ex-vessel steam explosions, and the DCH components of
23 that report.

24 MEMBER APOSTOLAKIS: Okay. Thank you very
25 much.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMZEHEE: Thanks, Ed.

2 MR. CARUSO: Slide 23, we had an open
3 issue on.

4 CHAIRMAN CORRADINI: Let's just go back
5 one slide. So I'll give you a hint to some of the
6 things that some of us might be thinking about. So I
7 am not sure, but if I remember correctly, two years
8 ago we were told this was upcoming. And I'm guessing
9 this is a heat transfer test. What worries me most
10 about all of this is the transient deposition of the
11 melt.

12 I think Dr. Powers actually has mentioned
13 this a couple of times somewhere in the ESBWR, the
14 times we have gone through this. But the transient
15 deposition of the melt onto this device, and would it
16 survive that deposition, that's just one thing that I
17 worry about.

18 MR. HAMZEHEE: And I think it's a good
19 time, because we are currently starting to review it.
20 So if we hear your concerns, we can pay more attention
21 to and when we do review the report.

22 CHAIRMAN CORRADINI: So we owe you
23 something. We promised to get it to you also.

24 MR. HAMZEHEE: Great. All right.

25 MR. FULLER: This is Ed Fuller from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff again. What we are reviewing are heat transfer
2 tests, not any configurations of particular molten
3 material onto the pipes. However, the heat fluxes
4 that the experiments are simulating presumably are
5 somewhat characteristic of what one might expect.

6 So in our review, we are looking at not
7 only the adequacy of the test facility scale for
8 applicability to the ESBWR configuration, we are
9 looking at the range of test data as compared with
10 what we would expect in severe accident loading
11 conditions, and determining the adequacy of the
12 predictions as compared to data. Okay? And we have
13 some well-known experts in this, one of whom is in
14 this room.

15 MEMBER POWERS: I guess I don't
16 understand. If you are looking to see what is
17 prototypic about the wrong heat transfer regime, you
18 are going to be frustrated. The problem is that with
19 core debris interacting with any material, it is not
20 just a step change in heat flux. It's a step change
21 in the temperature and the heat flux.

22 We have known that for 25 years, that the
23 two are not the same. I mean, looking for something
24 that says, "Well, it's a prototypic step change in the
25 heat flux," without looking at a prototypic step

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 change in the temperature, you're looking in the wrong
2 regime. We will not see the phenomena that will
3 affect the stability of the structure.

4 CHAIRMAN CORRADINI: Yes. Just to make
5 sure everybody sees what I think Dana is saying, he
6 said this I thought it was a couple of years ago when
7 we were in the August PRA meeting. The concern is is
8 that if you get the initial deposition, you are going
9 to create a spallation effect, and you will just rip
10 away what you built before it even starts cooling.

11 I mean, you just essentially short-circuit
12 the device, because as it deposits you are going to
13 get this very large temperature, and a thermal
14 cracking spallation effect.

15 MEMBER SIEBER: A refractory.

16 CHAIRMAN CORRADINI: I seem to remember
17 that's what was said way back then.

18 MEMBER SIEBER: I mean, it's the same
19 problem you have in a steel mill. You don't pour
20 those things in cold. You preheat it, because it
21 can't tolerate the step change in the temperature. It
22 tolerates the heat flux. The heat flux is fine. But
23 the step change in temperature doesn't let -- the
24 material will not stand up to it, so they preheat it.
25 They preheat them with blow torches. I mean, they get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the sucker high, so it can stand -- when you just pour
2 a steel melt in it.

3 Steel melts typically never run over about
4 1,500 degrees Centigrade when they cast them, usually
5 a good deal less than that. And now you're talking
6 about something that if you come in -- it depends on
7 the phase and what not -- at substantially higher
8 temperatures.

9 MEMBER SIEBER: Well, the test reg they
10 have doesn't model that part of the operation.

11 MEMBER POWERS: Then, you are looking at
12 the wrong stuff.

13 MR. HAMZEHEE: Thanks for the inputs. We
14 will take them into account when we review the topical
15 report.

16 MR. CARUSO: Slide 23, the vacuum breaker
17 performance issue. That is not an open item anymore,
18 so -- we got the information we needed, and we're
19 happy with it.

20 Section 19.2.4 was containment capability,
21 containment performance capability. We identified
22 some problems in the finite element analysis. GEH has
23 given us a response in that area, and I think it's
24 safe to say we are on a success path there.

25 And Slide 25, accident management, we had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 asked them for a description of the process for
2 developing the severe accident guidelines, and they
3 have provided a response, and that is currently under
4 review.

5 So if there are other questions, I'll take
6 them now. No, I guess in --

7 CHAIRMAN CORRADINI: Are there other
8 questions by the Committee?

9 (No response.)

10 Okay. I think this might be a good time
11 for a break.

12 (Laughter.)

13 So we'll get back here at about 4:00 with
14 Chapter 22.

15 (Whereupon, the proceedings in the
16 foregoing matter went off the record at
17 3:39 p.m. and went back on the record at
18 4:02 p.m.)

19 MR. MILLER: Good afternoon. I am Gary
20 Miller. I was introduced before. Rick and I will be
21 talking about regulatory treatment of non-safety
22 systems and how we have addressed that for the ESBWR.

23 The SECY document has specified that there
24 are five criteria that should be addressed when
25 treating a regulatory treatment for non-safety-related

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 systems, and these are the five criteria. They go
2 through deterministic items such as items needed for
3 the ATWS rule and the station blackout rule, items
4 that are needed to resolve long-term safety issues
5 beyond 72 hours, and this is important because for
6 advanced passive reactors safety-related is defined
7 for 72 hours -- functions that are needed to maintain
8 72 hours. Beyond that, we are allowed to maintain
9 those safety functions with active or non-safety-
10 related systems, and this is what we will be
11 addressing in Criterion B.

12 Criterion C is the probabilistic
13 criterion, and it looks at whether or not we meet the
14 Commission's safety goal guidelines of CDF of less
15 than 10^{-4} per year, and a large release frequency of
16 less than 10^{-6} per year. And that is if we take
17 credit only for safety-related systems.

18 Criterion D has to do with containment
19 performance goals, and Criterion E is something we
20 have already talked about a little bit, and that is
21 the adverse system interactions.

22 Okay. The first criterion, what we want
23 to do is identify non-safety-related systems that are
24 required in order to meet the ATWS rule. And that
25 would be -- the ATWS rule requires that you have an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 alternate rod insertion, standby liquid control, and
2 recirc pump trip or basically some method of reducing
3 reactor power rapidly. Since we don't have a recirc
4 pump trip, we have feedwater runback for the ESBWR.

5 The non-safety-related portions for the
6 ESBWR that meet these are alternate rod insertion and
7 feedwater runback supplied by the diverse protection
8 system.

9 The SLC actuation is safety-related. And
10 as far as station blackout goes, all of the components
11 that are necessary to cope with the station blackout
12 are safety-related. So the bottom line for
13 Criterion A is that the DPS, or diverse protection
14 system, has these functions that would be in RTNSS, in
15 the scope of RTNSS.

16 Okay. Long-term safety and seismic, that
17 is the criterion that we are looking at in
18 Criterion B. To define safety, we looked at the key
19 safety functions of the plant, and that would be core
20 cooling, containment integrity, control room
21 habitability, and post-accident monitoring. So I'll
22 step through each one of those.

23 Core cooling -- after 72 hours, there is
24 a need to make -- to provide makeup water to the
25 IC/PCCS pools, so the isolation condenser and the PCCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat exchanges have sufficient capacity to perform
2 their function for 72 hours. But after that point, at
3 some point the water in the pools will boil off, and
4 that needs to be replenished.

5 That function of providing the makeup is
6 provided by fire protection water, and it is pumped up
7 by the diesel fire pump. And as a backup, there is an
8 electric fire pump, motor-driven fire pump that is
9 powered by ancillary diesel generators. These are
10 permanently installed diesel generators capable of
11 powering the electric fire pump and other loads that
12 are required for long-term issues.

13 MEMBER ABDEL-KHALIK: I'm sorry. Could
14 you go back one slide? At one time we were sort of --
15 information was presented to us on feedwater
16 temperature control as a means for power control. How
17 does the feedwater runback interact with the feedwater
18 temperature control?

19 MR. MILLER: Okay. With regard to RTNSS,
20 the requirement is solely: how do we meet the ATWS
21 rule? And the requirement is that --

22 MEMBER ABDEL-KHALIK: We look at it in
23 terms of effectiveness.

24 MR. WACKOWIAK: Right. What is going on
25 here is the feedwater signal essentially runs back to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 zero demand. So it rapidly reduces the water level
2 outside the shroud area. And when the water level is
3 reduced in a natural circulation system, it is the
4 head of water in the shroud that causes the natural
5 circulation flow to go. As we reduce water level down
6 farther and farther, there is less head to drive
7 natural circulation. So that's what the intent is
8 there.

9 We run water level back down to around
10 five feet above the top of fuel, and then at that
11 point the operators take manual control of the
12 injection systems and maintain the water level around
13 five feet above the core.

14 MEMBER ABDEL-KHALIK: But how does the
15 feedwater temperature controller respond during a
16 feedwater runback?

17 MR. WACKOWIAK: The feedwater temperature
18 control is not part of this scenario.

19 CHAIRMAN CORRADINI: I think he's asking
20 if you did this, does the controller do it --

21 MEMBER ABDEL-KHALIK: What happens to
22 inlet feedwater temperature?

23 MR. WACKOWIAK: It really depends on what
24 is going on with the BOP. If the transient that
25 initiated this involves closing the MSIVs, then there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is no more feedwater heating anyway. There is no more
2 steam to provide feedwater heating.

3 If the initiating event is something else,
4 I don't think -- the part of the logic that addresses
5 this is not doing anything to release -- there is
6 nothing in the current scheme for the feedwater
7 control system that says to do anything different with
8 the feedwater heating during this event. You wouldn't
9 heat it up. You wouldn't cool it down. I think it
10 would just still try to control independently.

11 But, you know, as soon as the water level
12 starts coming down and we get past a Level 2, we'll
13 isolate the MSIVs anyway, and there won't be any more
14 feedwater heating.

15 MEMBER SIEBER: The assumption is the
16 turbine trips as the root cause of the accident. On
17 the other hand, if the turbine trips, then everything
18 is bottled up. And so you -- if you topped off the
19 feedwater, it would stay the same as it is, except you
20 would generate more bulk boiling in the reactor, it
21 seems to me.

22 MR. WACKOWIAK: Okay. Yes, that's the
23 initial response -- not putting cold water.

24 MEMBER MAYNARD: Okay. So this
25 temperature control is not part of this design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certification.

2 MR. WACKOWIAK: No, it's not part of
3 RTNSS. That's part of the feedwater control system,
4 which is in a different digital control system all
5 together.

6 MS. CUBBAGE: But it is part of the design
7 certification. Right. It was added several years
8 into the certification, so you haven't seen it yet in
9 detail.

10 MEMBER SIEBER: All right. But the system
11 is isolated once you get the ATWS event, because you
12 are really regulating amount of extraction steam flow.

13 MR. WACKOWIAK: Right. When we have the
14 ATWS event, feedwater demand will be run back to zero.
15 So very quickly after that we will have a Level 2 in
16 the reactor, which will close the MSIVs and stop any
17 extraction steam to the feedwater heating system. So
18 it's -- they are really two separate subjects.

19 MEMBER SHACK: Do the IC and PCCS pools
20 communicate? Are they really one big pool?

21 MR. WACKOWIAK: I can show you. There are
22 separate compartments for the heat exchangers, but it
23 is one big connected pool. We can show you a
24 schematic of that.

25 MEMBER BLEY: It's like there are gates on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it that they can pull out or something?

2 MR. WACKOWIAK: No, it's pipes.

3 CHAIRMAN CORRADINI: Well, I think they
4 are interconnected. The external pool communicates.
5 So as you lose from one, you lose from the other.

6 MEMBER SHACK: Yes. When you feed one,
7 you feed the other.

8 MR. WACKOWIAK: For the first 24 hours or
9 so, the two halves of the building are separated. But
10 after 24 hours or so, the connection between the two
11 halves of the building open. And so it's all one big
12 interconnected mass.

13 MR. MILLER: Okay. We talked about core
14 cooling. The next one would be containment integrity
15 -- to maintain stable conditions in the containment.
16 That is provided by PCCS. And, again, after 72 hours
17 we need to provide makeup to the IC/PCCS pools and,
18 just as I described before, by the fire protection
19 water and the two pumps that I described.

20 MR. KRESS: Is there a limiting amount of
21 that water?

22 MR. MILLER: The fire water storage tank
23 is -- has been sized to account for that, and it's --
24 I'm not sure what the capacity is.

25 MR. WACKOWIAK: It's around a million

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gallons, but the size is based on removing decay heat
2 for seven days. So the water that is in the pools in
3 the reactor building initially, plus the fire tank, is
4 enough to remove decay heat for seven days.

5 MR. MILLER: Okay. Another long-term
6 phenomena called -- within the containment is the
7 accumulation of non-condensable gases. So you look at
8 the containment profile. Beyond 72 hours, it is not
9 stable. There is a slight increase due to hydrogen
10 and oxygen radiolytic decomposition.

11 In order to get rid of that and provide a
12 means to reduce containment pressure, we have -- for
13 the ESBWR we have PCCS vent fans. And their function
14 is to redistribute the non-condensable gases to
15 provide -- well, provide more efficient heat transfer
16 and to reduce pressure. Another item we have is
17 passive autocatalytic recombiners to recombine the
18 hydrogen to the non-condensable gases. Of course,
19 those are working at time zero, but, you know, they
20 would take credit for this long-term buildup of
21 hydrogen and oxygen.

22 MEMBER POWERS: These are palladium-based?

23 MR. MILLER: I can't say for sure. I have
24 heard that it's something. Do you know if it's
25 palladium?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: The specific units have
2 not been specified. And I think you guys had some
3 presentations on the -- on what the containment
4 designers are thinking along those areas in Chapter 6.
5 Beyond saying that there is a requirement in RTNSS for
6 this, that is the extent of what we do.

7 We found in the PRA itself because of the
8 ultimate failure pressure of the containment is so
9 much higher than the design pressure, even without the
10 combiners, the -- we don't challenge the ultimate
11 pressure in the containment due to radiolytic
12 decomposition of the water.

13 MEMBER ARMIJO: Are these PCCS vent fans
14 operating during the initial 72 hours, or just after?

15 MEMBER SHACK: In the PRA, not in the
16 design basis accident.

17 MEMBER ARMIJO: I'm just wondering how --

18 MEMBER BLEY: In the real world.

19 (Laughter.)

20 MEMBER ARMIJO: When do you operate them,
21 and how long are they operated with battery power
22 versus some other auxiliary power?

23 MR. MILLER: Okay. The PCCS vent fans are
24 powered from the ancillary diesel generators. So they
25 can be put on at any time. The idea would be it would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be for long-term. The PRA doesn't even credit them.

2 MR. WACKOWIAK: And because we are looking
3 at margin to design pressure with these fans, we need
4 to turn them on at 72 hours. If we were looking at
5 margin to containment ultimate pressure, it would be,
6 well, five months before we would need to turn them
7 on. Something like that. I don't know. I'm just --

8 MEMBER BLEY: But they are manually
9 started.

10 MEMBER SIEBER: If it's not -- if a
11 component is not required for mitigation of a severe
12 accident, that is what makes it a non-safety system?
13 And assuming that's the case, things like the diesel
14 generators, and so forth, must have quality
15 requirements. And I see a slide is where that is a
16 bullet, and it must have some tech specs about it.
17 But are you going to address exactly what the quality
18 requirements are and the tech spec requirements for
19 things like outage times and --

20 MR. MILLER: Yes.

21 MEMBER SIEBER: -- preventive maintenance
22 and all of that stuff, so that one can actually say,
23 "Yes, I think they are going to be there," as opposed
24 to it's non-safety and it's -- you know, if it sits
25 and rots away, that's okay, too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MILLER: We will address in the next
2 few slides how we -- the treatment we provide.

3 MEMBER SIEBER: I would like to hear
4 enough detail to have some comfort that the non-safety
5 systems would be available to help mitigate a severe
6 accident.

7 MR. MILLER: Okay.

8 MEMBER SIEBER: If they can do it.

9 MR. MILLER: Control room habitability is
10 -- the function there is to keep the dose down to an
11 acceptable limit, and to maintain the temperature to
12 an acceptable limit, so that the control room can be
13 habitable for the duration of the accident.

14 The long-term dose protection is provided
15 by emergency filtration units, and those are powered
16 by our safety-related DCIS or Q-DCIS. And that is
17 powered by batteries for 72 hours, and beyond that
18 also by the ancillary diesel generators.

19 MEMBER BLEY: Quick question. At some
20 sites, when you actually have a real plant, you might
21 need protection for the control room for hazardous
22 gases of one sort or another. Does that go in the
23 design to start with, or is that an add-on plant by
24 plant?

25 MR. MILLER: That would have to be plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 by plant. There is no -- it's certainly not within
2 the scope of RTNSS, but I'm am not familiar with any
3 other hazardous gases that we would have onsite at
4 that --

5 MR. WACKOWIAK: I think there is a COLA
6 item about that.

7 MEMBER SIEBER: A lot of utilities use
8 gaseous chlorine to treat their circulating --

9 PARTICIPANT: Or it can be going past on
10 a barge.

11 MEMBER SIEBER: It could be, or some
12 factory down the street. But the common one is
13 chlorine.

14 MEMBER POWERS: One of the issues that has
15 come up with control rooms in existing plants is the
16 allowable unfiltered in-leakage. I don't know what
17 the -- what you have as your allowable unfiltered in-
18 leakage to be, but I was wondering if you have taken
19 steps to ensure that whatever it is it's preserved
20 over the lifetime of the plant. Because certainly
21 what we have observed in the existing plants is that
22 they have a relatively low unfiltered in-leakage on
23 day one.

24 On day two, the first modification that
25 the control room has made, and that tends to lead to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 higher -- ever higher uncontrolled, unfiltered in-
2 leakage, and that it is not maintained.

3 MR. WACKOWIAK: The control room
4 habitability area, as they call it in this plant, is
5 serviced by these emergency filter units. And that
6 area and these units are all safety-related, and that
7 in-leakage is covered by the tech specs for the
8 control room habitability area.

9 MEMBER POWERS: All of which is true for
10 the existing plants. All of -- most of whom no longer
11 meet their tech specs. Have you taken steps to see
12 that that doesn't occur in new plants?

13 MR. WACKOWIAK: We have had many a
14 discussion with the potential customers over just that
15 issue.

16 MEMBER POWERS: I'm glad you've had the
17 discussions.

18 MS. CUBBAGE: I just wanted to confirm
19 that it is a COL item in Chapter 6 for the site-
20 specific analysis of toxic gas.

21 MEMBER BONACA: The question I had was:
22 this classification by function, and the corresponding
23 design requirements, where do they come from? Are
24 they part of some requirements from Part 50, or 52, or
25 is it simply --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: I mean, this whole slide
2 comes from a reg guide.

3 MR. WACKOWIAK: It's in the reg guide now,
4 but it wasn't in the reg guide when we started. When
5 we started all of this was in a combination of SECY
6 and SRM papers, and then a letter that the staff wrote
7 that took the various SECY papers and combined it into
8 something that was a readable unit.

9 Subsequent -- and that's what Westinghouse
10 had when they did the AP-1000, and, when you read the
11 reg guide, the reg guide actually tells you to go and
12 take a look at what AP-1000 did.

13 MS. CUBBAGE: Right. Well, I'll just
14 point out that this is strictly a passive plant issue
15 RTNSS, so the staff at this time had not, you know,
16 made a decision to write an SRP, to have guidance,
17 because we don't intend to be applying this in the
18 near term to any other designs.

19 MEMBER BONACA: When I go back to the --
20 later to the design, there is a lot of requirements
21 there. Makes you almost want to go back to the -- you
22 know, nuclear design and say, "On this end, the
23 requirements are" --

24 MR. WACKOWIAK: In the SRP for quality
25 assurance, SRP Section 17, there is a discussion of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the quality requirements for equipment that is in this
2 category, the RTNSS category. And while all of the
3 elements of quality assurance are in that section, we
4 allow the use of different standards.

5 So, for example, instead of Appendix B for
6 certain things, for a quality assurance program at a
7 vendor site, we would allow an ISO-9001 quality
8 assurance program. So while all of the elements are
9 there, and they rightly should be there, the
10 acceptance criteria is relaxed for these.

11 MEMBER BONACA: And now you are proposing
12 this, and the staff has not yet --

13 MR. HAMZEHEE: No. I think there has been
14 a lot of interactions.

15 MEMBER BONACA: Okay.

16 MR. HAMZEHEE: But the latest revision of
17 the RTNSS has not been reviewed yet. But they have
18 made a lot of changes/improvements as a result of the
19 RAIs that have been sent to them. So there is good
20 agreement as to what needs to be done.

21 MEMBER BONACA: Okay.

22 MS. CUBBAGE: And starting with DCD
23 Revision 0, there was very, very limited SSCs that
24 were included in RTNSS. And as you can see now, there
25 is quite a list of them now, and that's a result of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff review.

2 MR. WACKOWIAK: There was one in Rev 0.

3 MS. CUBBAGE: There was one, yes.

4 (Laughter.)

5 Refill of the PCCIC pool.

6 MR. WACKOWIAK: The fire pump.

7 MEMBER BONACA: And how many do you have
8 now?

9 MS. CUBBAGE: Too many to count.

10 (Laughter.)

11 MR. MILLER: Okay. We talked about
12 control room --

13 MEMBER SHACK: Where is 50.69 when you
14 need it?

15 MR. WACKOWIAK: Well, this I think would
16 be similar to 50.69.

17 MEMBER SHACK: Do you think you can come
18 up with a similar list?

19 MR. WACKOWIAK: Well, not really, because
20 Parts A and B are deterministic, and there is -- we
21 have to do these things irrespective of what --
22 because we are protecting the design basis limits here
23 rather than the risk limits. So it's different.

24 MR. MILLER: Okay. I'll move on to long-
25 term temperature control, and the air handling units

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the control building have heating and cooling units
2 in them that are powered by Q-DCIS. And, of course,
3 as I said before, that has 72-hour batteries, and
4 beyond that the ancillary diesels will supply that.
5 So all of these components that I have talked about
6 are within the scope of RTNSS.

7 And, finally, post-accident monitoring --
8 the functions -- the monitoring functions themselves
9 are provided by the Q-DCIS, and in addition to that
10 emergency lighting for the operators to perform these
11 monitoring activities. And that, again, is supplied
12 by the ancillary diesels for the long term.

13 So these are the long-term safety issues
14 for RTNSS Category P, and we'll talk about the seismic
15 issues coming up.

16 The design treatment, as we talked about
17 earlier, for all RTNSS Category B components, because
18 they are not safety-related, we want to provide
19 reasonable assurance that they will function when they
20 are needed. So the design treatment that we have for
21 those is -- they are required to have redundancy.
22 They are required to be fire- and flood-protected.
23 And this is all, of course, described in DCD
24 Chapter 19(a).

25 Hurricane Category 5 missile protection,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and they also need to be able to withstand the
2 accident environment that they are -- would be exposed
3 to.

4 The RTNSS components are required to be
5 within seismic Category 2 structures or better. And
6 in most cases, or if not all cases, I think they are
7 in seismic Category 1 structures, except the ancillary
8 diesels.

9 MEMBER SIEBER: Are the components
10 themselves, do they meet a seismic qualification?

11 MR. WACKOWIAK: The components -- that's
12 an interesting question that has come up several
13 times, initially I think by us, and then through
14 others. And we tend to have a -- to talk about
15 seismic qualification of components, whereas the
16 qualification of components, including the seismic
17 aspect of it, is really covered under equipment
18 qualification, which is the bullet above design for
19 the accident environment.

20 So what we've said with these Category B
21 pieces of equipment, their seismic condition is that
22 following a seismic event they need to be functional
23 following the event. They don't need to be functional
24 during the event, but they need to be functional
25 following the event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But that's -- you know, saying something
2 is seismic Category 2 I think is a -- for equipment is
3 a shortcut that a lot of us take when we really mean
4 that it's in a seismic qualification/equipment
5 qualification program.

6 MEMBER SIEBER: And this is a standard
7 qualification program like now applies to Cat 1
8 equipment, or something less than that? Something
9 less than that, right?

10 MR. WACKOWIAK: It's less than that. For
11 Cat 1 equipment, typically it has to --

12 MEMBER SIEBER: You don't have to run it
13 while you're shaking it.

14 MR. WACKOWIAK: Right. You --

15 MEMBER SIEBER: Okay.

16 MR. WACKOWIAK: -- run it after you've
17 shaken it.

18 MEMBER SIEBER: You're supposed to run it.

19 MR. WACKOWIAK: Yes.

20 MEMBER SIEBER: Okay.

21 MR. MILLER: As Rick mentioned a little
22 while ago, in DCD 17, with quality assurance, it
23 identifies RTNSS quality measures that are required,
24 and for RTNSS B we have quality suppliers. It's not
25 Appendix B, but it's something perhaps a little bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 less than that in some cases.

2 MR. WACKOWIAK: Or just different.

3 MEMBER SIEBER: ISO-9000.

4 MR. WACKOWIAK: That's one of the things
5 the SRP calls out, yes.

6 MEMBER SIEBER: Would that be considered
7 acceptable?

8 MR. MILLER: Yes. And the Availability
9 Controls Manual was developed in response to RTNSS to
10 identify RTNSS equipment and to impose additional
11 regulatory oversight. It's not quite technical
12 specifications. It's more like a technical
13 requirements manual where there are LCOs, and there
14 are surveillance requirements for these RTNSS
15 components.

16 But the consequences would not result in
17 a plant shutdown or anything like that. It was -- it
18 is strictly to provide increased attention to it, make
19 sure that these components are surveilled and operated
20 with a higher level of --

21 MEMBER SIEBER: So if you decide to do an
22 overhaul to one of these ancillary diesels, and it
23 says here you could finish it in a week or two weeks,
24 you get halfway through it and find, you know, that
25 something isn't right or a supplier isn't there or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some other job comes up, there is no regulatory impact
2 if you go beyond the two weeks?

3 MR. MILLER: Well, there is regulatory
4 impact in regard to maintenance rule and Criterion
5 A(4), which would require us to assess the risk when
6 we take equipment out of service.

7 MEMBER SIEBER: Yes. But when you assess
8 the risk before you take it out of service, you don't
9 presume that it will stay out of service.

10 MR. MILLER: But when it's out of
11 service --

12 MEMBER SIEBER: You can take it all apart,
13 and you can say, "Gee, I don't think this is going to
14 work out." We don't need that anyway. It's not in
15 our tech specs.

16 MR. WACKOWIAK: One of the things that we
17 have to remember with the maintenance rule for this,
18 on A(4), when you take this out of service, we assess
19 the risk of the plant. And let's say we find out it
20 is going to take longer, and now you have some other
21 new maintenance activity that has some synergy with
22 this one that is coming up, and now they overlap.

23 A(4) would direct you most likely to
24 postpone that second maintenance activity until after
25 you get the first one restored. And, still, we would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 get the -- if it's too much unavailability on these
2 pieces of equipment, everything in RTNSS is covered as
3 a high safety-significant in the maintenance rule, it
4 can still go into A(1). It still gets into the
5 corrective action program that way.

6 Because these pieces of equipment,
7 especially in RTNSS B, by their very nature, they are
8 not needed until more than 72 hours after the
9 initiating event. This is the appropriate treatment
10 for this type of equipment.

11 MR. HAMZEHEE: I think, Rick, also another
12 way is we have to define target reliability and
13 availability for these RTNSS systems, and consistent
14 with the PRA assumptions. So if you assume that
15 diesel is supposed to only be out for the whole 18
16 months 60 hours, so you have to maintain that 60
17 hours. You can't just take it out for longer than
18 that. If you do, then you have to do some engineering
19 evaluation and assessment as to why you did it, and
20 then comply with some of your procedures.

21 MR. WACKOWIAK: It goes into A(1).

22 MR. HAMZEHEE: Correct.

23 MR. MILLER: Okay. Criterion C is
24 probabilistic, and the idea is if you take away all of
25 the non-safety systems, what would your CDF be? And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would it be lower than the goals of 1E minus 4 per
2 year and LRF of 1E minus 6 per year.

3 So to do that, we -- you know, we
4 quantified the model with those parameters and
5 determined that the goals were not met. What we found
6 -- we looked at the dominating contributors to the
7 core damage frequency at that point, and it had to do
8 a lot with the common cause failures of Q-DCIS, that
9 type of thing that we were talking about earlier.

10 And so it felt like the natural thing to
11 do would be to add the diverse protection system into
12 the RTNSS scope to see if that would bring the CDF and
13 LRF above the goals, which it did. So it's the first
14 thing we did is to add the diverse protection system
15 within the scope of RTNSS.

16 But then, you have to determine within the
17 diverse protection system -- because it covers many
18 different functions, you have to determine which
19 functions are really contributing to the risk. So we
20 determined the significance of those by removing one
21 function at a time, or one train at a time, to
22 determine if the CDF or the LRF goals were exceeded.

23 And if you took a certain DPS function out
24 of service, and the goals were exceeded, then that was
25 significant. And we did identify the four on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bottom here as being significant. And because they
2 are significant, then they required tech specs. So
3 each one of those has been assigned a tech spec.
4 Those are GDCS actuation, ADS actuation, isolating the
5 RWCU shutdown cooling valves in the event of a break,
6 and opening of the cross-connect valves, the IC/PCCS
7 pools, after the long term so that the pools can
8 refill and re-establish the level.

9 MR. WACKOWIAK: And just to back up some
10 of this evaluation, we were meeting the CDF goals. In
11 most -- in all of the cases, I believe it was the LRF
12 goal that got these functions into the high category.

13 MR. HAMZEHEE: You mean LRF?

14 MR. WACKOWIAK: L-R-F, LRF.

15 MR. HAMZEHEE: You can say either.

16 MR. WACKOWIAK: L-R-F, LRF.

17 MR. HAMZEHEE: LERF is large early release
18 frequency.

19 MR. WACKOWIAK: That's LERF, not LRF.

20 (Laughter.)

21 MR. MILLER: Okay. In addition,
22 Criterion C asks to provide an assessment of
23 uncertainty, and --

24 MEMBER ABDEL-KHALIK: I'm sorry. Going
25 back to what you were saying before, what was that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 quantitative delta that -- on the basis of which the
2 function was deemed to be significant?

3 MR. WACKOWIAK: If the core damage
4 frequency, including -- if the core damage frequency
5 with the system that -- one of the functions we have
6 on the bottom failed, is greater than 10^{-4} , or if the
7 large release frequency is greater than 10^{-6} , then it
8 would be considered significant, and that particular
9 function would be required to be treated in tech
10 specs.

11 As it turns out, that the top -- I believe
12 it's the top function was slightly above 10^{-6} , and the
13 other three were right at, you know, 9 times 10^{-7} , 7
14 times 10^{-7} , so we put them in the -- into that
15 category to say that they required tech specs. Did
16 that answer your question?

17 MEMBER ABDEL-KHALIK: They were put in
18 that category, even though they didn't meet the
19 quantitative criteria that were used in --

20 MR. WACKOWIAK: They were close enough.

21 MEMBER ABDEL-KHALIK: And they were put in
22 this category because they were just on top of the
23 list?

24 MR. MILLER: They were close to the goal.

25 MEMBER BLEY: They included uncertainty.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Yes. If we included
2 uncertainty, maybe they would be above it. See, what
3 we have is we took the safety-related systems in the
4 plant -- they are in the model now -- and then we
5 added the diverse protection system functions, put
6 that into the model. When we quantify that,
7 everything is below CDF or 10^{-4} CDF, and below 10^{-6}
8 LRF.

9 Then, we went through each of these DPS
10 functions, and we failed each one one at a time. And
11 we looked at what the CDF was in each of those cases.
12 And for the first one, it was one point something
13 times 10^{-6} -- or the LRF was 1.7 or one point something
14 times 10^{-6} , and then the next ones were down just
15 below that. So we said that without those functions
16 then the core damage frequency and LRF goals are not
17 quite met. They are just barely met or not quite met.

18 So what we did is we added these functions
19 to technical specifications, so now there is a testing
20 and availability requirements through technical
21 specifications for these four functions that we
22 determined are important.

23 The other DPS functions that we included
24 in the model are now -- are included in the
25 availability controls manual, and they are controlled

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through this other process and maintenance rule. So
2 everything has some kind of control on it, but the
3 important ones are in tech specs.

4 MR. MILLER: Okay. Also, in Criterion C
5 is a requirement to assess uncertainties, and thermal
6 hydraulic uncertainties, things that we have talked
7 about earlier today. To do that, we didn't need to
8 add FAPCS, but we did because it's a very flexible,
9 active system.

10 So if you did have a lot of -- with
11 uncertainties in your passive systems, we have thrown
12 in FAPCS and RTNSS to provide additional regulatory
13 treatment for that and higher assurance that it would
14 be performing its functions as required. And the two
15 functions that we have added are low pressure
16 injection and suppression pool cooling.

17 And because we added FAPCS, that is fuel
18 and auxiliary pool cooling system, and that is fuel
19 pool cleanup and residual heat removal functions. To
20 support that, we need the standby diesel generators
21 and the plant investment protection, or the PIP buses.
22 So those are in the scope of RTNSS because they
23 support FAPCS.

24 And we need -- to control that, we need
25 the non-safety-related DCIS. We need HVAC for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 buildings, controlling the NDCIS and FAPCS, as well as
2 cooling for the components. So we have reactor
3 component cooling water, nuclear island chilled water,
4 to cool the HVAC, the pumps, the motors, the diesel
5 generators, and, finally, to cool the cooling we have
6 service water.

7 CHAIRMAN CORRADINI: So can you help me
8 here? So this is post 72 hours?

9 MR. MILLER: No. This is Criterion C
10 probabilistic. So --

11 CHAIRMAN CORRADINI: So you have now an
12 active system. I guess I'm -- I didn't read this
13 section ahead of time. I was reading something else.
14 I'll admit to that openly. You have an active system
15 which is backup to the passive systems that now you
16 are going to treat in a RTNSS, which means it must be
17 available or can be available? That's what I'm trying
18 to understand, because you have now added a whole
19 laundry list of subsidiary systems that have to be
20 treated. Is that correct?

21 MR. MILLER: That's right. We have
22 augmented the -- well, they were non-safety -- they
23 are non-safety-related, right, so there is no tech
24 spec requirement.

25 CHAIRMAN CORRADINI: But you can add them

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the list.

2 MR. MILLER: We are going to add them to
3 the list, and the Availability Controls Manual
4 augmented design standards that I'll get into the next
5 slide. So we are adding, you know, higher assurance
6 of their reliability.

7 MR. HAMZEHEE: If I just may add a couple
8 of things, hopefully that will clarify it. I think as
9 he mentioned, because of uncertainty associated with
10 passive system design, we want to make sure some of
11 the active systems that are used to mitigate severe
12 accident consequences are under some regulatory
13 treatment.

14 How do we define what those systems are?
15 We define five criteria, one of which is PRA-based
16 criteria. So, and what -- the way we do it is we
17 perform a focused PRA to define which those systems
18 are.

19 CHAIRMAN CORRADINI: No, that part I got.

20 MR. HAMZEHEE: Once you define those
21 systems, then you have to now decide on the treatment
22 of them. What do you do with these RTNSS systems?
23 They don't have to be safety-related, and you cannot
24 apply the safety-related requirements for RTNSS.
25 Then, we have some treatment that we say you need to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 follow for these RTNSS, one of which is put them in
2 tech specs because that is the best control you can
3 have.

4 The ones that are not as important, then
5 we have some targeted liability, availability. Some
6 that are less important, we put them in the
7 availability controls manual, and so forth and so on.

8 MEMBER BLEY: That's negotiated, I take
9 it.

10 MR. HAMZEHEE: Correct. Yes. But there
11 are some high-level requirements that are in the
12 Commission paper that say how you treat these RTNSS-
13 related systems.

14 MEMBER BONACA: The question I have is --

15 MR. HAMZEHEE: Yes.

16 MEMBER BONACA: -- and you explained it
17 before you went about the writing of this -- I would
18 expect that for AP-1000 it would have the same
19 criteria.

20 MR. HAMZEHEE: Correct. They do have --
21 follow similar criteria and approach.

22 MEMBER BONACA: So the requirements would
23 be the same. I mean --

24 MR. HAMZEHEE: Correct.

25 CHAIRMAN CORRADINI: If it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 negotiated, I don't think so.

2 MS. CUBBAGE: Negotiated I think is --

3 CHAIRMAN CORRADINI: Different.

4 MS. CUBBAGE: Well, I mean, things like
5 whether they're in tech specs or not, we have
6 regulations 50.36, and if it meets the criteria to be
7 in tech specs it's going to be in tech specs. That's
8 not negotiated.

9 CHAIRMAN CORRADINI: But I guess I just
10 want to make sure I understand the concept. The
11 concept is you started this whole thing off saying we
12 didn't have to add the system, but we did. And so
13 this is a pool cooling system for spent fuel pools?

14 MR. WACKOWIAK: What we had in the
15 original --

16 CHAIRMAN CORRADINI: Well, that I'm going
17 to get to, yes.

18 MR. WACKOWIAK: Yes. This system provides
19 coolant injection from -- suction from the suppression
20 pool, you put it in the vessel. It also can take
21 suction from the suppression pool, put it through a
22 heat exchanger, and go back to the suppression pool.

23 It also does -- provides spent fuel pool
24 cooling. So this is one of the reasons why we chose
25 this system to go in, because there are other systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that can provide backup to the passive systems. There
2 are other ones that are there. And since we went
3 through the numerical requirements for what we needed
4 to have in, and we were able to satisfy all of the
5 numerical requirements just using the diverse
6 protection system, that still didn't bring in active
7 systems.

8 So we said, "If we are going to bring in
9 an active system, let's bring in the system that ends
10 up giving us the most flexibility for its use." So
11 now if we are going to treat something, we will treat
12 a system that can do a lot of things rather than
13 trying to treat a bunch of other systems.

14 CHAIRMAN CORRADINI: But bring in --

15 MS. CUBBAGE: Mike, if I may, I mean, the
16 criteria are not negotiated. The functions that the
17 plant has to provide are not negotiated. It's that
18 they can choose to select what systems they want to to
19 satisfy the requirements and the functions. In fact,
20 they have added systems in some cases rather than
21 putting higher treatment on existing systems. That is
22 their financial decision.

23 CHAIRMAN CORRADINI: No, no. That I think
24 I get. But I just want to make sure I understand,
25 though, that by doing it this way -- I'm sorry, excuse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 me. That the policy that is being followed is that
2 there is going to be some sort of additional backup
3 system that is active.

4 MS. CUBBAGE: Well, the specific criteria
5 was to address uncertainty. And so you have to
6 establish what the uncertainty is you are trying to
7 fix.

8 CHAIRMAN CORRADINI: The uncertainty,
9 though, in this case I assume is -- I'm going back to
10 the definitions here -- meet the containment's
11 performance goal, which is, then, the -- right, this
12 is a -- oh, I'm sorry. Excuse me. I was looking at
13 the wrong one. This is a C. The safety goal
14 guideline.

15 So there's enough uncertainty in the
16 passive safety function -- I want to say it a
17 different way. There's enough uncertainty in the
18 passive safety systems function that this is a way to
19 give an assurance that you've met it. That's the way
20 I read the C. Do I have it right? I don't have it
21 right?

22 MR. WACKOWIAK: When we talked earlier, we
23 were talking about not knowing what the right value is
24 for the failure of the Q-DCIS system. There is some
25 uncertainty there in the number that we pick. Did we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pick 10⁻⁴? Is that too high? Is it too low?

2 FAPCS -- these functions don't rely on
3 Q-DCIS, so we're able to address the uncertainty in
4 that particular number that we picked for the safety-
5 related system by saying we have a different system
6 that can perform some of the functions that were taken
7 up by that --

8 CHAIRMAN CORRADINI: So let me just push
9 my point, that I'm --

10 MR. WACKOWIAK: Squib valves -- we have
11 uncertainty -- and we talked about this -- did we pick
12 the right numbers for the -- data numbers for the
13 squib valves? And this system can provide backup for
14 some of the functions that those squib valves provide.

15 MEMBER SHACK: "Backup" is the wrong word,
16 because this is the first low pressure system you are
17 going to use, right? I mean, the passive is sort of
18 the last.

19 MR. WACKOWIAK: I mean, it's manually
20 operated, so it probably would get to be a --

21 CHAIRMAN CORRADINI: But I see your -- I
22 see how you're explaining it, but I would interpret it
23 separately, which is two meetings ago you weren't
24 here, or some meeting ago you weren't here, and we
25 were torturing another part of GE a lot about gas and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the GDCS.

2 This essentially is a redundant system for
3 the GDCS for low pressure. Once I depressurized, this
4 provides the cooling I need.

5 MR. WACKOWIAK: Right.

6 CHAIRMAN CORRADINI: Okay.

7 MR. WACKOWIAK: So we would address that
8 uncertainty as well. What we tried to do is we tried
9 to pick the system that would give us the most
10 coverage of the various uncertainties that we have.

11 MR. CARUSO: Can I make a point? Mark
12 Caruso, staff. To your point, I think one of the
13 reasons, at least in our SER what we said, was we said
14 this was an especially appropriately -- appropriately
15 good choice of a system, because the whole genesis of
16 RTNSS was -- is really about uncertainty, it came
17 about because of uncertainty in the passive systems.

18 And they said, "Hey, you've got these
19 active systems, but we want to make sure that there is
20 some treatment because, you know, there is uncertainty
21 in the passive systems." There is no RTNSS for non-
22 passive plants. So here is a system that really
23 addresses, you know, as a backup for the passive
24 system. So we think it's a very -- it's a very
25 appropriate choice. I think your point is very well

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 taken.

2 Their official criteria that they used it
3 for was uncertainty in their focused PRA, I believe.
4 But I think --

5 MR. WACKOWIAK: But we will use your
6 criteria as well. That's how --

7 MR. CARUSO: Yes. We did in our SER.

8 CHAIRMAN CORRADINI: Well, so let me ask
9 the staff this question, then, and I'll stop because
10 this is good education for me. So for -- the AP-1000
11 was an example of what they chose to meet the
12 guideline, that was an active system. Can you give me
13 a reminder?

14 MS. CUBBAGE: I can tell you in two
15 minutes if you want to keep talking, and I'll come
16 back.

17 CHAIRMAN CORRADINI: No. I'll stop
18 talking. I'll just let them go on.

19 MS. CUBBAGE: I think it was --

20 CHAIRMAN CORRADINI: I'm trying to
21 understand --

22 MEMBER STETKAR: I'll buy your two minutes
23 for you.

24 MS. CUBBAGE: Diverse actuation I believe
25 was one of them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Gary, if you go back to
2 the previous slide, I just -- for clarification,
3 because I also will honestly admit that I did not read
4 this section either. I notice under the supporting
5 functions for FAPCS you have a -- what appears to be
6 a rather complete list, except for the fact that I
7 don't notice non-safety DC power in that list. Why?

8 MR. MILLER: Non-safety DC power.

9 MR. WACKOWIAK: In the case here, the
10 standby diesel generators have their own DC power
11 source to get them started.

12 MEMBER STETKAR: Sure.

13 MR. WACKOWIAK: And once they are started,
14 the way our uninterruptible power supplies are, which
15 is the way all of our DCIS is, including NDCIS, the
16 diesel generators can power directly through that
17 system, and the batteries aren't required to keep it
18 going.

19 MEMBER STETKAR: How do you close the
20 circuit breakers for the FAPCS points?

21 MR. WACKOWIAK: The power to close those
22 circuit breakers come through the AC power systems.
23 It is not directly out of the DC power system.

24 MEMBER STETKAR: That's not what I read in
25 the non-safety DC power system design. It said it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 supplied control power for operation of circuit
2 breakers on switch gear, which would be those circuit
3 breakers.

4 MR. WACKOWIAK: Okay. We'll have to go
5 back and take a look at how that exactly is. But my
6 understanding was that once we got the power back to
7 the bus, the bus actually provides the power for the
8 -- for those breakers.

9 MEMBER STETKAR: One could design
10 electricity to do that, but one doesn't normally do
11 that. And it didn't --

12 MR. WACKOWIAK: We talked at length about
13 whether or not we needed the DC batteries. The issue
14 with recharging the batteries in these scenarios is
15 that that brings in additional ventilation
16 requirements, because of the hydrogen. And so we
17 spent a lot of time discussing that this set of
18 systems would work without those batteries.

19 MEMBER STETKAR: Okay.

20 MR. WACKOWIAK: Now, it may be
21 procedurally controlled that they have to do some
22 manually closing of some of those breakers. I'll find
23 that out.

24 MEMBER STETKAR: And the fact that these
25 are -- if these are somehow specially treated --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Right.

2 MEMBER STETKAR: -- they might be
3 different, but it --

4 MR. WACKOWIAK: There are some breakers
5 that require DC-controlled power. I don't -- we
6 talked about this, the --

7 MEMBER STETKAR: But the problem with this
8 has got to be that it's not only the FAPCS, but the
9 chillers and the RC -- all of those things that -- all
10 of those things.

11 MR. WACKOWIAK: That's correct.

12 MEMBER STETKAR: All of those things.

13 MEMBER ABDEL-KHALIK: Let me just
14 conceptually understand what I heard in the past 10
15 minutes. If none of the squib valves were to open, if
16 none of the gravity-driven safety systems were to
17 work, if these systems were to function as you expect
18 them to, you will still meet the safety goals.

19 MR. WACKOWIAK: We will still not
20 prevent --

21 MR. MILLER: We will keep the core
22 covered. We will keep the core covered. We didn't
23 quantify taking -- we didn't quantify failing all of
24 the squib valves.

25 MS. CUBBAGE: I think they said the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 opposite. They said if you do the focus, Gary, with
2 only safety systems, you needed to add in some non-
3 safety systems to meet the goal. They didn't say the
4 opposite, which is what you said.

5 MEMBER ABDEL-KHALIK: Well, that's what
6 I'm trying to get to.

7 MS. CUBBAGE: Oh, okay.

8 MR. HAMZEHEE: And I think also remember
9 when -- just let's forget about RTNSS. When they did
10 their PRAs, they took credit for the operations of
11 safety systems as well as non-safety systems. That is
12 how they do their PRAs. They don't have to only take
13 credit for the operations of safety systems.

14 And they came up with their published CDF
15 of 1E minus 7 or 1E minus 8, whatever that number was.
16 Now, we want to know, since those active systems are
17 not safety-related, how high the CDF would have been
18 if they did not take credit for non-safety active
19 systems?

20 So there is a category for RTNSS selection
21 that says if you don't take credit for those non-
22 safety active systems, how high does your CDF get?
23 And if it does get really high, is it going to exceed
24 1E minus four? If so, then you've got to put them
25 under regulatory treatment, even though they are non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safety-related. That's really the essence of what
2 they have done under C, and they call it focused PRA.

3 MEMBER APOSTOLAKIS: Why didn't you make
4 it safety-related?

5 MR. HAMZEHEE: That's a different question
6 now.

7 (Laughter.)

8 CHAIRMAN CORRADINI: You were giving an
9 example of --

10 MS. CUBBAGE: Yes. For AP-1000, this was
11 the certified version. They had automatic diverse
12 actuation for ATWS and ESF features, injection with
13 the normal RHR and the associated power supplies, and
14 hydrogen igniters.

15 CHAIRMAN CORRADINI: So they had -- they
16 had RHR injection.

17 MS. CUBBAGE: Yes.

18 MR. WACKOWIAK: We followed a very similar
19 process and got a very similar answer.

20 CHAIRMAN CORRADINI: Thank you.

21 MEMBER APOSTOLAKIS: So you really have
22 this high confidence that there is a big difference in
23 reliability between safety-related and non-safety-
24 related.

25 MR. HAMZEHEE: That's not what we said.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We just want to make sure, just in --

2 MEMBER APOSTOLAKIS: I mean, why have the
3 agency go through all of this process of RTNSS and od
4 it only with a focused PRA? One would expect that the
5 non-safety-related systems are much worse than the
6 safety-related systems. Is there any evidence that
7 says that? The answer is no.

8 MR. HAMZEHEE: The answer is no, but
9 because NRC staff wants to have some regulatory
10 oversight for those systems that are important and
11 perform risk-significant functions, but are not
12 safety-related, because if they are not safety-related
13 there may not be enough regulatory oversight. And
14 this is one way of providing that regulatory
15 oversight.

16 MEMBER APOSTOLAKIS: I mean, gee --

17 MS. CUBBAGE: Well, also, the RTNSS
18 process actually was developed not with AP-1000 but
19 with AP-600. It's beginning to be a lot of years ago,
20 and did you have maintenance rule, did you have all of
21 the other programs to ensure reliability.

22 MEMBER APOSTOLAKIS: Safety-related --
23 declaring something safety-related increases its cost
24 for DOE by a factor of three or four, which is pretty
25 significant. So one would expect the benefits to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 commensurate with that? And evidently they are not.

2 I have been looking for years for evidence
3 that safety-related pumps are much better than non-
4 safety-related.

5 MR. HAMZEHEE: I am not going to answer
6 the question. I don't know yet to answer that, but
7 that's why we have 50.69 treatment.

8 MEMBER APOSTOLAKIS: That's a good
9 example. I mean, the South Texas firm that -- the
10 overwhelming majority of safety-related components
11 should be down to Category C, because from the risk
12 perspective they are not really contributing.

13 So, yes, Mike, what do you want to say?

14 MR. SNODDERLY: I wanted to just point out
15 for Dr. Bonaca's point about --

16 MEMBER APOSTOLAKIS: Identify yourself.

17 MR. SNODDERLY: I'm sorry. Mike Snodderly
18 from the staff. To get at Dr. Bonaca's point, just so
19 you understand, one of the key differences between the
20 AP-1000 certified design and this -- the present ESBWR
21 design is -- and you mentioned the normal RHR would
22 receive what they call the RTNSS B design treatment.

23 So, for example, it was seismic Category 2
24 an availability controls for those systems. So for
25 RTNSS C -- so right here we see Availability Controls

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Manual and seismic Category 2. So that treatment
2 applied to the RHR and its support system.

3 So for ESBWR, if we can go now to the
4 RTNSS C slide you're on, it would be availability
5 controls for the front-line systems, and the seismic
6 category treatment would be designed for accident
7 environment. So you asked about differences. That's
8 one difference.

9 And, of course, the reason for that --
10 there is a reason, and one showed up as being more
11 significant and this one didn't. So it's important I
12 think to understand that.

13 MR. HAMZEHEE: So there are -- there may
14 be differences, but the approach is the same, and the
15 requirements are the same.

16 MR. WACKOWIAK: The approach is similar,
17 and the requirements are the same.

18 MR. HAMZEHEE: Yes, thanks.

19 MEMBER BLEY: But back to what you were
20 saying, George --

21 MEMBER APOSTOLAKIS: Yes.

22 MEMBER BLEY: -- while you buy two pumps
23 or two valves -- one safety and one not -- they might
24 be the same valve or pump. If one of them, once
25 you've installed it, has no requirements for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 maintaining it and no need to have it there all the
2 time, it often turns into a spare part. And this is
3 not there at all.

4 So they are requiring some level of
5 reliability of this equipment day to day.

6 MEMBER APOSTOLAKIS: Is that really true?

7 MEMBER BLEY: It has been true.

8 MEMBER APOSTOLAKIS: If it's not safety-
9 related, they just let it go to hell?

10 MEMBER BLEY: If they don't need it for
11 anything.

12 MEMBER MAYNARD: That's the way it used to
13 be before the maintenance rule came out. I think the
14 maintenance rule is one of the best things that came
15 out. And that was really the difference between
16 safety-related and non-safety-related. Not so much
17 the quality of the equipment; it's more your assurance
18 that you've maintained it and it's reliable.

19 The maintenance rule kind of does away
20 with that line of safety-related/non-safety-related.
21 Talks about the importance of it, and the availability
22 and the maintenance of that to keep it available. But
23 there is not really that much difference between the
24 equipment itself. It's more how you maintain it, how
25 you treat it, how you keep it available.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: And that depends on the
2 quality of the licensee.

3 MEMBER BONACA: Essentially, the
4 distinction is when you use equipment that is put out
5 for a safety purpose, but it is never run unless you
6 test it, because it doesn't have an operational role.

7 MR. WACKOWIAK: And yet the system that we
8 chose here -- and this one happens to be one that is
9 normally operating and running all the time. That
10 went into the decision to pick that system.

11 MEMBER BONACA: That gives you confidence
12 regarding the operability.

13 MR. MILLER: Okay. I'd like to continue
14 with the design treatment for RTNSS Criterion C, which
15 we just talked about, is very similar, as you can see,
16 to what we had for the RTNSS B redundancy, fire,
17 flood. And as I mentioned, the diverse protection
18 system functions that were required are actually in
19 tech specs. The Availability Controls Manual captures
20 the other -- the front line systems that I have
21 mentioned.

22 Criterion D has to do with meeting
23 containment performance goals, and they are -- the
24 BiMAC and the GDCS deluge valves, because they are
25 non-safety-related were included in that category, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they will receive RTNSS treatment as well.

2 And then, the final criterion was a
3 request to look at adverse systems interactions. We
4 found two instances -- the bottom line, drywell
5 hatches, we've talked about before. So that if those
6 hatches were open during shutdown and we had a LOCA
7 condition, we would want to close those, so we
8 included those in RTNSS so that they could have
9 availability controls and enhanced quality.

10 The reactor building HVAC purge exhaust
11 charcoal filters -- these filters are not safety-
12 related. However, they play an important role in a
13 very long-term beyond design basis severe accident
14 situation where we might have fuel damage. We may
15 have to cool the coolant through the fuel building,
16 the FAPCS heat exchangers, which are in the fuel
17 building. No, wait a minute, in the -- we would
18 normally --

19 MR. WACKOWIAK: Yes. With this one, we --
20 we normally would want to cool the core long term
21 using FAPCS, because FAPCS is a much more flexible
22 system and it's lined up so that we can take a suction
23 from the suppression pool, put it through a heat
24 exchanger, and get back to the vessel, or back into
25 the suppression pool.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The problem is is if there does happen to
2 be a significant source term in the suppression pool,
3 whether it's from a severe accident, or where we first
4 looked at this was in design basis accidents where we
5 have to non-mechanistically impose a source term that
6 is there.

7 The pathway of the water out of the
8 reactor building, and then back in, led to some
9 interesting dose consequences. So we have another
10 system that -- the reactor water cleanup system. We
11 reconfigured that, so that it can perform the same
12 cooling function using some cross-tie valves with the
13 FAPCS system, all within the reactor building.

14 If you ask why that's not in RTNSS, when
15 we look at our core damage frequency, core damage
16 situations, the probability of meeting FAPCS is
17 somewhere -- for core cooling is somewhere on the
18 order of 10^{-4} . But the probability of needing this
19 cross-tie is only in core damage events, so that's on
20 the order of 10^{-8} . So in 99.99 percent of our cases,
21 FAPCS is the right system to use for this. So that's
22 the RTNSS system.

23 But the thing is, when we put this cross-
24 tie into operation and start pumping contaminated
25 water throughout the reactor building, the source that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is generated from that using the standard methods of
2 doing design basis source calculations requires us to
3 have some cleanup of the atmosphere in the reactor
4 building during that mode of operation.

5 So we had a system that would do that --
6 the purge exhaust charcoal filters. And what we said
7 is if those purge exhaust charcoal filters either fail
8 or are unqualified for performing that function, when
9 we turn on this cross-tie and the failure of these
10 charcoal filters would have an adverse interaction on
11 our dose calculations.

12 So we moved these purge filters into
13 RTNSS, and we actually require those filters to have
14 the same quality as a standby gas treatment filter to
15 meet the same performance requirements in Reg. Guide
16 1 point -- it escapes me now. There is a four in
17 there somewhere.

18 So it's to treat that scenario. So these
19 are one of the things that we're looking at. If
20 you're going to operate the plant under various
21 conditions like a radiological event inside the
22 containment, and you want to get into long-term
23 cooling, then there are systems that if they don't --
24 active systems, if they don't perform properly, there
25 could be adverse interactions. In this case, it's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dose consequence.

2 We put it into RTNSS. We put quality
3 requirements on this charcoal filter system. And
4 then, also it falls into the Availability Controls
5 Manual, so now it has to be tested periodically, and
6 we would monitor the availability of the equipment in
7 that system. So it's always available, should be
8 available within the mission that we have defined in
9 the maintenance rule.

10 MEMBER APOSTOLAKIS: So monitoring the
11 availability is one of the regulatory requirements for
12 RTNSS?

13 MR. WACKOWIAK: Yes. Everything --

14 MEMBER APOSTOLAKIS: Do you cover what the
15 requirements are, or is it somewhere -- I'm sorry. I
16 didn't read it. What additional regulatory
17 requirements are imposed on these?

18 MR. HAMZEHEE: Again, because these are
19 non-safety systems, and we want to have a --

20 MEMBER APOSTOLAKIS: I understand why.
21 What are the requirements? It says regulatory
22 treatment. What is that regulatory treatment?

23 MR. HAMZEHEE: That means they have to
24 define some target reliability and availability for
25 these risk-significant systems and their associated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 components, and then monitor it throughout the life of
2 the plant, through different existing programs such as
3 maintenance rule, such as reliability assurance
4 program, and some others.

5 MEMBER APOSTOLAKIS: So that's it.

6 MR. HAMZEHEE: Correct. Yes. Nothing
7 more.

8 MEMBER APOSTOLAKIS: Reliability.

9 MR. HAMZEHEE: Correct.
10 Reliability/availability, yes.

11 MR. WACKOWIAK: And there are some design
12 requirements, like redundancy, we -- I think we added
13 those criteria, but --

14 MEMBER APOSTOLAKIS: Redundancy?

15 MR. WACKOWIAK: Redundancy. We want to
16 make sure that the things that we take credit for in
17 the RTNSS are not always -- are not just a single
18 train. We have looked at how we have multiple trains
19 to perform the function, so that now when we do do
20 maintenance on that, we have a backup.

21 MEMBER APOSTOLAKIS: Yes.

22 MR. WACKOWIAK: And so we would use good
23 design practices in designing them. They would be
24 separated. We don't run the cables together in the
25 same trays. We try to separate fire areas as much as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 possible. That sort of thing.

2 MEMBER APOSTOLAKIS: Then, the question I
3 guess, which you will answer very quickly, why don't
4 we do the same with the safety-related?

5 MR. HAMZEHEE: Well, safety-related
6 systems, by definition, have enough control in place
7 already, such as tech specs --

8 MEMBER APOSTOLAKIS: The question is: why
9 don't you relax all of the other requirements you
10 impose on safety-related and just say
11 reliability/availability.

12 MR. HAMZEHEE: That's a different --

13 MR. WACKOWIAK: Where do we sign?

14 (Laughter.)

15 When can we sign? I'm ready.

16 MEMBER APOSTOLAKIS: No. I'm just asking,
17 because I hear that the most expensive part is this
18 paper trail that you have to keep. If we are to have
19 a performance-based regulatory system, why isn't
20 monitoring the reliability and availability good
21 enough?

22 CHAIRMAN CORRADINI: George, they want you
23 on their team. I had a question.

24 MEMBER APOSTOLAKIS: I'm curious.

25 MEMBER BLEY: You know, one answer would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be it probably would be for most things. For some
2 others, you would need some explained concurrently,
3 like guaranteed operability under adverse conditions.
4 But that --

5 MEMBER APOSTOLAKIS: Yes, sure. That --

6 MEMBER BLEY: The framework is hinting
7 that that's the way you ought to go.

8 MEMBER APOSTOLAKIS: Because it appears
9 there is a big difference between the treatment of
10 safety-related and the RTNSS.

11 CHAIRMAN CORRADINI: I had a question
12 about D. Are you satisfied with your answer?

13 MEMBER APOSTOLAKIS: No.

14 CHAIRMAN CORRADINI: Okay.

15 MEMBER APOSTOLAKIS: I think I want to get
16 a better answer, though, because this is something
17 that has come from the mountain. These guys aren't
18 just inventing it.

19 CHAIRMAN CORRADINI: So I want to
20 understand D. So BiMAC and GDCS, by RTNSS D, are in.
21 So that means you've done a calculation that says, "If
22 they weren't in, something is not going to be met."
23 What is not going to be met?

24 MR. WACKOWIAK: What is not -- what we
25 can't assure is met -- remember, we -- our containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis doesn't look at the best estimate. It looks
2 at what we can prove. So if we don't have the BiMAC
3 under our current analysis, we can't assure that in
4 all cases the basemat melt penetration won't cause the
5 corium to leave the containment in less than -- or in
6 -- keep it in the containment for more than 24 hours.

7 CHAIRMAN CORRADINI: So that leads me to
8 my other question, which is in Chapter 11,
9 Tables 11.3.19 and 20, which I did read, your
10 sensitivities don't turn on and off the BiMAC's
11 performance. In Level 2, you did a lot of one-offs,
12 but unless I miss it, I don't see it there.

13 MR. WACKOWIAK: The answer is, if we turn
14 it off, then by our calculation -- by our methodology,
15 not our calculation, by our methodology if we turn off
16 BiMAC, it's containment failure every time.

17 CHAIRMAN CORRADINI: Eight percent
18 becoming 100 percent?

19 MR. WACKOWIAK: Yes.

20 CHAIRMAN CORRADINI: Okay.

21 MR. WACKOWIAK: So we did have an RAI on
22 that, though, that asked us to look at basemat melt
23 penetration probabilistically like the ABWR did. And
24 we duplicated the evaluation that was done for the
25 ABWR more or less using MAAP-4.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They used MAAP-3 and MELCOR analyses, but
2 we tried -- we tried to set up the same conditions and
3 demonstrated that if we used the same assumptions,
4 same best estimate assumptions that the ABWR used,
5 then we would still need 10 percent or better for the
6 containment failure goal through basemat melt
7 penetration.

8 So it's a separate calculation. But it
9 doesn't -- it doesn't fit in our -- it doesn't fit
10 into our methodology. That methodology requires
11 making a judgment of the probability of things that
12 you don't know -- how much melt comes out of the
13 vessel, and ABWR, like a lot of other plants did, they
14 did various sensitivity calculations and said, "Okay.
15 It is 90 percent this much, 10 percent this much; or
16 50 percent this much, 50 percent that much."

17 And when you go through the containment
18 event tree that way, where you split everything up
19 that you don't know into probabilities that you think
20 they might be, you can get things that show up. It's
21 a 10 percent chance that the core is going to go out,
22 90 percent chance that it is going to stay in.

23 CHAIRMAN CORRADINI: Whereas, the approach
24 you guys are taking in Chapter 21 is a bounding
25 approach.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WACKOWIAK: Right. What we said is --

2 CHAIRMAN CORRADINI: I should say you
3 considered a bounding approach.

4 MR. WACKOWIAK: It's considered a bounding
5 approach. We can't prove at this point that simply
6 putting water on top of the melt will always arrest
7 the melt. Therefore, we assume that it would continue
8 to erode the concrete.

9 MEMBER SIEBER: ABWR doesn't do BiMAC.

10 MR. WACKOWIAK: That's what made us put in
11 the BiMAC. We rely on it for that.

12 MEMBER SIEBER: ABWR doesn't have BiMAC.
13 They just spread the core out.

14 MR. WACKOWIAK: No. And that's what was
15 certified.

16 MEMBER SIEBER: Pardon?

17 MR. WACKOWIAK: That's what was certified,
18 getting back to the question earlier. If it's
19 certified, then that's it.

20 MEMBER POWERS: When you put water on top
21 of the core debris, do you substantially attenuate to
22 radionuclide release?

23 MR. WACKOWIAK: Yes. Yes. As a matter of
24 fact, the end state from a scenario where we have
25 emptied the deluge into the vessel, or into the core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's in the lower drywell, we have somewhere between
2 12 and -- 12 or more meters of water above the top of
3 the melt. And I don't know that I've seen any curves
4 that show anything more than about, what, five or 10
5 feet of water above melt in terms of decontamination
6 factor.

7 MEMBER POWERS: Yes. The deepest
8 calculation that I'm familiar with had 32 feet of
9 water.

10 MR. WACKOWIAK: Thirty-two feet? Okay.

11 MEMBER POWERS: It actually attenuated
12 some of the krypton and xenon at that depth.

13 MR. WACKOWIAK: Well, that's similar to
14 what our end state will be --

15 MR. MILLER: Okay? Well, I'll continue
16 then. We have some open items. Some of the SSCs
17 needed for post 72-hour safety were housed in
18 structures below seismic Category 2, and that's a
19 legacy of DCD Rev 4 we have -- with the addition of
20 things like the ancillary diesel generator, all of the
21 Criterion B components are in structures that are
22 Category 1 or Category 2. So this should close the
23 item.

24 Additional information was also required
25 on the design to enable the staff to confirm that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are adequately protected from floods and natural
2 phenomena. And we have provided a response to that.

3 The availability controls -- there are a
4 few items here on some specifics within the
5 availability controls specifying the number of
6 functions required and the surveillance requirements.
7 A lot of these were received late into the game as we
8 were trying to get the revision out. We have
9 addressed some, and some we will be addressing in a
10 followup.

11 CHAIRMAN CORRADINI: That's it?

12 MR. MILLER: That's it.

13 CHAIRMAN CORRADINI: Thank you.
14 Questions? George?

15 MEMBER APOSTOLAKIS: Just a general
16 interest. Does anyone from the staff know where I
17 could go to learn more about why the requirements are
18 imposed on safety-related and --

19 MS. CUBBAGE: Background on?

20 MEMBER APOSTOLAKIS: Question that has
21 never been resolved. Where should I go to learn about
22 this? Is it 50.69?

23 MR. HAMZEHEE: No. There should be some
24 other reference documents or Commission papers that
25 may have some background information for you. 50.69

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is basically how to have a risk-informed approach to
2 get relaxations from some of those safety-related
3 requirements or classification.

4 MEMBER APOSTOLAKIS: But Risk C category
5 components are treated, again, somewhere in between.
6 Are the requirements on Risk C similar to these, or
7 different?

8 MR. HAMZEHEE: They should all be similar.
9 Now, one can choose to have additional requirements,
10 like for instance putting them in tech specs, so that
11 it's more stringent. That's it. But requirement
12 based on the Commission policy paper is that for those
13 systems that perform risk-significant functions, and
14 are identified as RTNSS, the designers and the
15 potential future licensees have to establish targeted
16 reliability and availability, and then monitor it
17 during the life of the plant.

18 Now, one can do that by putting it in the
19 tech specs, in the maintenance rule, in the RAP, in
20 different -- there are different mechanisms by which
21 you could assign and then monitor the reliability and
22 availability of these components.

23 MEMBER APOSTOLAKIS: I guess what I want
24 to understand is why there are additional
25 requirements, additional requirements, to be imposed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on safety-related systems.

2 MS. CUBBAGE: On safety-related systems?

3 MR. HAMZEHEE: On safety. That -- as I
4 said, that's a different question, but we'll go back
5 and see if we can provide you with some reference
6 documents. That may have some basis for why the
7 agency chose to have those safety-related type
8 requirements, and what the bases are. We have to go
9 back and search. I can't remember.

10 MEMBER APOSTOLAKIS: I mean, what confuses
11 me is that both the active systems that have declared
12 RTNSS, and the passive systems in this case, are
13 expected to perform under accidental --

14 MR. HAMZEHEE: Well, the only --

15 MEMBER APOSTOLAKIS: Why are we asking
16 only reliability/availability questions here, and the
17 other one we are asking for much more?

18 MR. HAMZEHEE: I know that one of the main
19 reasons is because those safety-related systems are
20 being taken credit in the Chapter 15 design basis
21 accidents. But now does it mean that they have to
22 have additional requirement? That's something that we
23 need to go back and look at some of the existing
24 documents and give you some of the bases. I don't
25 know the answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I remember there were
2 a lot of -- there was a lot of resistance on the part
3 of the staff when 50.69 was approved as to what
4 requirements should be relaxed for this Risk C
5 category. And until you -- I mean, is there a
6 document that says this is what the staff believes the
7 reasons are? And the NRC is --

8 MR. CARUSO: Let me take a crack. I think
9 the answer to the question is it's the regulations .
10 The regulations -- 50.36 and tech specs -- the systems
11 that are -- you know, satisfy the accident analysis
12 and are basically the safety systems, they have to
13 have tech spec controls. Non-safety systems that
14 don't fall in that category don't have to have tech
15 spec controls, except now in this RTNSS process it's
16 possible for them to have it based on these other
17 criteria that we have incorporated.

18 The other difference I think is -- I mean,
19 as far as the maintenance rule goes, all of the RTNSS
20 systems are in the maintenance rule, all of the safety
21 systems are in the maintenance rule, they are all
22 pretty much considered equal there.

23 The other difference I think is in QA.
24 The requirements -- the regulations require that
25 safety systems have to have Appendix B quality

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assurance requirements. These other systems don't.
2 They have something less.

3 So I think 50.69 is a move toward the
4 risk-informed regulation where you would treat
5 everything. But I think right now we have regulations
6 that require certain things of safety systems.
7 That's -- if you look at those regulations, you
8 will --

9 MEMBER APOSTOLAKIS: I agree that there
10 are regulations. I know them. My question is, why we
11 are demanding this here and not there.

12 MEMBER SHACK: Because it is what it is.

13 MEMBER APOSTOLAKIS: Is it because the
14 system has inertia, and, you know, it takes time to
15 get used to this performance-based risk-informed
16 approach? Because all the stuff you mentioned is from
17 the previous era.

18 MEMBER SHACK: Right.

19 MS. CUBBAGE: We are using the same --

20 MEMBER APOSTOLAKIS: All I remember is we
21 questioned this in the presence of the Commission, and
22 the then-Chairman got really upset.

23 MR. CARUSO: I mean, there may be some
24 information in the stuff that Mary Drouin is doing on
25 -- you know, Mary Drouin is working on this futuristic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approach to regulation, coherence and risk-informed
2 Part 50. There may be some discussion in there that
3 would be helpful.

4 MEMBER APOSTOLAKIS: If you can get me the
5 documents, that would be good. And if there is any
6 suspicion that they are not doing the right thing,
7 then maybe the Committee will take some action.

8 MR. CARUSO: Okay.

9 MEMBER APOSTOLAKIS: What did you say,
10 Rick? You seem to be very happy.

11 MR. WACKOWIAK: No. I think that if you
12 have a good set of design requirements for the
13 components, and you -- and you buy them from a
14 reputable vendor and you have a reliability program,
15 like the maintenance rule, then you get most of what
16 you need to make the plan safe.

17 MEMBER APOSTOLAKIS: But that would
18 require a change in the regulations, which means
19 something is --

20 CHAIRMAN CORRADINI: Can we move on?

21 MEMBER APOSTOLAKIS: We may, yes.

22 CHAIRMAN CORRADINI: Thank you.

23 MEMBER APOSTOLAKIS: Unless it is a
24 thermal hydraulic issue, he is willing to give me the
25 time of day --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: I think the discussion is
2 worth at least one comment. In the current plants,
3 the Category 1 components are geared toward design
4 basis accidents, and severe accidents beyond that have
5 no requirements. And in this case, there is -- there
6 is a difference in the design basis accident, and the
7 equipment required to mitigate that is also safety-
8 related. But you have assist equipment that is non-
9 safety-related.

10 So I think that we're consistent between
11 existing plants and these new designs as far as
12 categorizing things. And having a sort of
13 intermediate regulatory treatment of non-safety
14 systems is an improvement.

15 MR. FULLER: This is the Subcommittee on
16 the staff's review of ESBWR DCD Chapter 19(a), SER
17 Chapter 22.

18 Once again, I am the lead project manager
19 for Chapter 22. Mark Caruso is our lead technical
20 reviewer, and we have numerous technical reviewers.
21 Many of them are still in the audience.

22 I'll outline our presentation. RAI status
23 summary, applicable regulation, SER technical topics,
24 and significant open items.

25 For this chapter we had 24 RAIs, and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have been able to resolve 16 of them. We have eight
2 open items left to resolve.

3 MS. CUBBAGE: I will also add that a
4 number of the Chapter 19 RAIs were directly related to
5 RTNSS, so those numbers appear smaller than reality.

6 MR. CARUSO: Slide 6 --

7 MS. CUBBAGE: Well, there were a number of
8 Chapter 19 ones that have now been closed.

9 MR. CARUSO: Slide 6 talks about the
10 regulatory guidance and requirements that apply for
11 the RTNSS evaluations. I think we have talked about
12 this a great deal during the last presentation as to
13 these guidance documents here embody the genesis of
14 why you need to have RTNSS, why it applies to passive
15 systems, what are the issues.

16 A number of the staff's issues,
17 Commission's issues, became the framework for the
18 process. Then, the Commission told the staff and EPRI
19 to go off and develop this process. This is the
20 process that Rick talked about, the criteria and the
21 process that they used.

22 As far as regulatory requirements go, we
23 talked a lot about how some things -- some things --
24 in this process there is a risk piece that looks at
25 risk-significance of these non-safety components and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 identifies that risk-significance.

2 That, coupled with the fact that there's
3 a requirement in 10 CFR Part 36 that says -- has
4 criteria for what systems, structures, and components
5 should go in tech specs, and one of those criteria is
6 anything that is determined to be significant from a
7 risk assessment or operating experience.

8 So that requirement is a basis for -- can
9 be a basis for having systems identified through the
10 RTNSS process go in the tech specs. I should also
11 mention that maintenance rules aren't on there and
12 probably should be on there, because it plays a big
13 role.

14 MEMBER APOSTOLAKIS: Are there documents
15 the ones that I wanted?

16 MR. CARUSO: Well, they would be helpful.
17 I'm not sure that they -- they don't really talk about
18 the safety systems. They talk about the non-safety --

19 MEMBER APOSTOLAKIS: Oh, just the regular,
20 not safety. Oh. But they seem to be --

21 MR. HAMZEHEE: These are RTNSS-related
22 safety that may help your thought process to some
23 degree.

24 MEMBER APOSTOLAKIS: Okay.

25 MR. HAMZEHEE: But are not exactly what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you were asking for.

2 MR. CARUSO: Slide 7. I think these are
3 the criteria for selecting RTNSS systems, and I think
4 Gary went through these. I don't think we need to go
5 through these again.

6 This slide, Slide 8, is a summary of the
7 important topics in RTNSS. I think Gary went through
8 these, too. I don't think I need to say any more
9 about these.

10 I guess, yes, we want to get to the open
11 items. And I guess what I would say is our open items
12 are primarily based on the information that was
13 provided in DCD Rev 4. And what Gary talked about was
14 sort of their revised approach to RTNSS, a number of
15 modifications, and how they are treating RTNSS, and
16 DCD 5, which very much go to these issues.

17 And so I think we have heard about this
18 stuff in phone calls, in slides, and I think the
19 general feeling is that it's definitely going in the
20 right direction to address the concern to fundamental,
21 open items that we had. But it's complicated what
22 they have done, and where they have moved things
23 around in the categories and stuff.

24 And so, you know, we need to look at it,
25 make sure we understand it. There's a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 confusion about exactly what they did and how it
2 addresses the different criteria. So I think, you
3 know, this particular item here in the system
4 interaction area -- this one in fact they have given
5 us a response on, but they have added some stuff in
6 the system interaction area, so we need to look at
7 that.

8 Again, these open items apply to the
9 Category B, the long-term safety criterion. And this
10 is something that has been substantially revised in
11 Rev 5 -- the concerns we had that some of the B items
12 previously were being housed in instructions that were
13 not even seismic Category 2. And that was our
14 fundamental concern, and I believe they are addressing
15 that concern directly in Rev 5.

16 The same thing goes for the issue about
17 protecting these systems against floods and
18 hurricanes. So I think there is a success path there;
19 we just need to look at what they've done.

20 And the last set -- as Gary said, there
21 are a number -- we have identified a number of
22 concerns. You know, we have their Availabilities
23 Control Manual. It is attached to Chapter 19(a). And
24 it has been reviewed by a number of folks on the
25 staff, and we have identified a number of issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there, which are -- I wouldn't say they are -- I mean,
2 they are significant issues, but I think there's
3 resolution paths.

4 We just need to get them addressed by GE
5 in terms of making the -- I think making the
6 availability controls clear in terms of what they
7 require and what they don't require, and also to make
8 them consistent with assumptions they have made in the
9 PRA.

10 I would say overall -- I think overall
11 where we stand with RTNSS is we think they follow the
12 process. We think they are identifying the right
13 systems. I think our concerns have been in the area
14 of treatment. Overall, I think, you know, their
15 treatment is -- you know, my opinion is their overall
16 treatment is fine.

17 They have identified stuff that goes in
18 tech specs, that seems appropriate. They have
19 identified stuff -- they have identified availability
20 controls for the other things, and everything gets
21 covered under this design reliability assurance
22 program, which they have committed to implement
23 through the maintenance rule.

24 The design reliability assurance program
25 is reviewed by us, too. It's reviewed in Chapter 17.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We reviewed it, accepted it. It has been briefed in
2 front of your Committee. It talks about the treatment
3 of these systems in terms of design control,
4 organization, quality assurance, all those aspects.
5 But I think the real powerful piece is the fact that
6 it will be implemented through the maintenance rule,
7 which really is -- provides, you know, a strong
8 regulatory source for treating availability and
9 reliability.

10 So I think there is an overall good
11 argument as to why their approach is acceptable. We
12 just have some particular concerns in some areas about
13 the availability controls and some of the requirements
14 of the -- for the Criterion B systems.

15 So I think that's -- I think that's where
16 we stand.

17 CHAIRMAN CORRADINI: Questions?

18 (No response.)

19 Thank you very much. Should we go around
20 the table -- I'll start with Mario -- just to get
21 people's reactions. And I'll try to -- I'll try to
22 document what I hear from everybody.

23 MEMBER BONACA: As you know, I am not an
24 official member of this Subcommittee.

25 CHAIRMAN CORRADINI: But welcome at any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 moment.

2 MEMBER BONACA: I always attend it,
3 basically whenever I can. I think I'm qualified to
4 make a comment. I would like to see some more detail
5 in the PRA. I understand it has been promised, and we
6 will be seeing that.

7 I was intrigued by the issues of
8 interactions between active systems and passive
9 systems, and would like to understand better the
10 downsides of that. But, in general, I think I am
11 reasonably impressed by the progress.

12 I have no further comments.

13 CHAIRMAN CORRADINI: tom?

14 MR. KRESS: I am pretty much in agreement
15 with what Mario said. Clearly, to me the PRA appears
16 to be of acceptable quality, and they used it in such
17 a way as I think they pretty much met that list of
18 Commission objectives with it.

19 And I think it clearly shows, with the
20 absolute values, that ESBWR has a level of safety that
21 is much better than the existing plants. So, you
22 know, it's a good thing. I have to agree with George,
23 though, that we shouldn't be quoting values for
24 digital I&C failure probabilities. I don't think it's
25 a meaningful number yet. But you have to deal with it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in some way in the PRA.

2 I was glad to see -- I guess it was Ed
3 Fuller that mentioned the use of MELCOR to audit
4 several of the severe accident sequences. I was glad
5 to see that. I was going to suggest as a probability
6 -- I hadn't seen the results of that comparison. I
7 think we ought to look at them some time.

8 I was quite interested in the 10^{-6} goal
9 for LRF, because I consider an LRF to be a potential
10 surrogate for a societal risk goal, which we have
11 never had before. So I'm anxious to see if we can
12 relate the 10^{-6} to some sort of acceptable societal
13 risk.

14 MEMBER POWERS: I am stunned that you
15 would be interested in that at all.

16 MR. KRESS: You know, I am going after the
17 new --

18 (Laughter.)

19 No matter what, I have to say that. Is
20 that a surprise?

21 MEMBER POWERS: Yes. I'm -- it has taken
22 me aback. I am going to take some -- several days to
23 recover from the shock.

24 MR. KRESS: To really take that one in.
25 At one time, there was an attempt to model passive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 systems thermal hydraulically, and use the model in an
2 uncertainty way to look at the various parameters in
3 it, and vary them, and to the extent to see when you
4 might expect failure in the passive systems.

5 I don't know what ever happened to that
6 study. I wonder if we can find out whether it came to
7 any conclusion or is still going on.

8 CHAIRMAN CORRADINI: Actually, Bill
9 mentioned that in an e-mail a couple days ago about
10 that study. Do you remember?

11 MEMBER SHACK: No, no. It was Harold.

12 CHAIRMAN CORRADINI: Was it Harold? So
13 Harold is the one that mentioned it.

14 MR. VANDER MOLEN: Yes. We can try and
15 find the -- find the details of that, but it goes back
16 10, 15 years or so. I remember Art Bussick was the
17 project manager and he is retired now. So it will
18 take a little bit of research, but we can see if we
19 can find it.

20 MEMBER APOSTOLAKIS: Why do you have to go
21 so far back? I'm telling you --

22 CHAIRMAN CORRADINI: History is good.

23 MEMBER APOSTOLAKIS: But, you know, BNRPS
24 is only a few years old and does all of this stuff.
25 It's published in the literature, nuclear engineering

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design and nuclear technology.

2 MR. KRESS: I think we ought to look at
3 that.

4 MEMBER APOSTOLAKIS: Yes. A good starting
5 place is this EPRI summary.

6 MR. KRESS: I was intrigued by the
7 discussion we had that -- on the use of PRA to certify
8 a plant. And then, all at once we decided when we got
9 to COL stage we left something out that we might think
10 is -- should have been in at the time. What do we do
11 about that?

12 My view is that I like to think of
13 certification of design as separate from siting. And
14 once you certify a design, it's certified. You deal
15 with things you left out of the PRA or things that
16 were in the PRA but may not have been dealt with, it's
17 in the design but it may not have been dealt with.
18 You deal with those at the siting stage, the COL
19 stage.

20 I guess I still have two outstanding items
21 on my list that the staff has promised to give us
22 answers to. You know, that's the question -- iodine
23 pumping into containment continuously, and the other
24 one is one I brought up, and I don't know if we have
25 been promised anything on it or not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That was when you inject boric acid as a
2 backup system to prevent recriticality, and if you are
3 low pressure and you are sitting there boiling away
4 the water, it's my view that the boric acid goes with
5 the steam. And pretty soon you deplete it, and the
6 question is: do you have another recriticality issue
7 after you've gotten rid of all of the boric acid?

8 There is a race between it and the build-
9 in of the xenon from the decay. So it could very well
10 be that the xenon race wins, but I don't know. I have
11 never seen a study.

12 MS. CUBBAGE: The last -- the second of
13 your two issues, that would be generic, right, to all
14 of --

15 MR. KRESS: It's a generic. It has
16 nothing to do with -- I mean, it's not specific. It's
17 a generic issue. So those are -- I for one think I --
18 the PRA and its use in design was a good job. I like
19 what I heard.

20 CHAIRMAN CORRADINI: Thanks Tom.

21 Sam?

22 MEMBER ARMIJO: Yes. I think the most
23 important thing that I've gotten out of this is that
24 the -- really the value in using the PRA in the design
25 process rather than simply assessing a design plant,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I think that has been done very well.

2 I think there is enough margin in all of
3 these to the numerical goals of CDF and LRF that even
4 though the plant isn't completely designed and enough
5 detail isn't there to really state that you are
6 meeting those numerical goals, there is enough margin
7 that you have a pretty high assurance that when that
8 time comes you will be post-goal. So I am very
9 comfortable with that.

10 I think the staff and the -- and GE are
11 rapidly converging on the PRA, and I don't see a big
12 problem for the certification.

13 CHAIRMAN CORRADINI: Okay. Dana?

14 MEMBER POWERS: I've got some notes here
15 in front of me.

16 CHAIRMAN CORRADINI: Do you want to say
17 anything out loud?

18 MEMBER POWERS: No.

19 (Laughter.)

20 MR. KRESS: Can I do that?

21 MEMBER APOSTOLAKIS: Would you object to
22 Dr. Corradini's reading the notes?

23 MEMBER POWERS: Yes.

24 (Laughter.)

25 CHAIRMAN CORRADINI: I knew it. I knew

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it.

2 MEMBER APOSTOLAKIS: This is a public
3 meeting.

4 (Laughter.)

5 MEMBER POWERS: I simply commented that
6 I'm interested in some of the pictures of how they did
7 the core degradation and the potential
8 recriticalities. I am interested in how they are
9 handling the issues of poisoning and choking on the
10 passive catalytic hydrogen recombiners, and how we
11 will look closely at how they handled the DBA and DDBA
12 source terms.

13 CHAIRMAN CORRADINI: Thank you, Dana.

14 MEMBER SHACK: I have just -- you know, I
15 think it's very interesting, the redundancy and the
16 diversity of the systems that they have I think gives
17 the system a lot of robustness. Whatever questions
18 you may have about numbers of any particular item,
19 there is just enough ways to do different things here
20 that gives me high confidence that this is, in fact,
21 a pretty safe reactor.

22 My one concern is the one that Mario
23 brought up, and that is whether there isn't stacked
24 some adverse interaction between these active systems
25 and the passive systems, and just how this will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 treated actually in a -- I'd like to see a set of
2 procedures for how somebody would actually proceed in
3 an accident. You know, he has got all of this choice
4 of systems. You know, what is he actually going to
5 do, and is there a potential that you are going to
6 create problems as you are going through this? But --

7 MEMBER BONACA: That seems tricky.

8 MEMBER SHACK: It certainly gives you a
9 lot of choices and a lot of ways to get success, or
10 not.

11 CHAIRMAN CORRADINI: Said?

12 MEMBER ABDEL-KHALIK: Yes. I am also
13 concerned about the interactions between active and
14 passive systems, particularly since one wouldn't
15 really know what is the best thing to do until you
16 specify what equipment you have and what procedures
17 you will have in place.

18 There is another concern that I would like
19 to add to the comments raised by my colleagues, which
20 is I would like to see the original source of failure
21 rate data for squib valves. I think the database may
22 be very small to justify that the numbers have been
23 used were common cause failure.

24 MEMBER POWERS: Let me ask you what you
25 mean by "database," and that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: I think the source
2 of the data is based on data for squib valves used in
3 nuclear plants, and the only place that they are used
4 is in the standby liquid control system. And I think
5 that database is very small.

6 MEMBER POWERS: Well, again, I am
7 interested in what you mean by "database," because if
8 I am a manufacturer of squib valves, and I go out and
9 test them a lot, I test the ones that go to the
10 nuclear plant, is that a database that you accept, or
11 is it only those that are actually in use and you can
12 episodically go --

13 MEMBER ABDEL-KHALIK: Well, I'm sure any
14 surveillance tests that have been done, any
15 qualification tests that have been done, for the
16 specific valve designs that are we are interested in
17 would be applicable to that database.

18 MEMBER POWERS: Well, I bring it up
19 because we certainly had a manufacturer come in here
20 and discuss his quality assurance and his testing that
21 he did, and he has tested hundreds of these things.
22 But I don't know whether you count that as qualifying.
23 I can certainly imagine an argument that --

24 MEMBER SIEBER: The biggest user is NASA,
25 and that's where the database is coming from.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Well, I mean, this guy had
2 built these things for NASA. He came in here and
3 talked to us, and, I mean, they are basically cheap.
4 So he goes off and he tests hundreds of them.

5 MEMBER ABDEL-KHALIK: But the claim that
6 has been made here is that these numbers are based on
7 nuclear-related data.

8 MEMBER POWERS: These are nuclear devices.
9 I mean, he sells them to the nuclear industry. He
10 tests them. I just don't know whether they -- that
11 qualifies as an acceptable database for you.

12 MEMBER ABDEL-KHALIK: Sure. I mean, any
13 -- as I said, any surveillance data, any equipment
14 qualification data, etcetera, that would go into
15 establishing these failure rates would fall within
16 that database, provided of course that, you know, one
17 can establish that the data would be applicable to any
18 unique valve designs that may be used in this
19 particular plant.

20 MEMBER ABDEL-KHALIK: I was also struck by
21 the fact that sometimes, you know, issues are brought
22 up, and then they say, "Well, there is an ITAAC that
23 will check that." An example of that would be, you
24 know, things like a check valve installed backwards.

25 MS. CUBBAGE: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Okay. There is an
2 ITAAC. Is that something that is really doable? Can
3 you actually establish with the configuration that we
4 have that these check valves will operate and will be
5 installed in the manner that they are supposed to?

6 MS. CUBBAGE: If you are questioning
7 whether it would be feasible to verify that
8 particular --

9 MEMBER ABDEL-KHALIK: Right. I mean --

10 MS. CUBBAGE: -- aspect by an ITAAC? I
11 mean, I think in the case of the GDCS they are going
12 to have to verify that they are going to get the flow
13 rate through the line. So if the check valve is in
14 backwards, they are not going to get it.

15 MEMBER ABDEL-KHALIK: And things like
16 whether or not the lines are implied in the correct
17 configuration, so that any -- to preclude the
18 possibility of, you know, non-condensable gas
19 accumulation.

20 Well, can you -- how can you say that you
21 will always do this correctly, so that the probability
22 that you will have enough gas accumulated that would
23 cause the gravity-driven system to not function
24 correctly is zero?

25 MS. CUBBAGE: Well, if there is a specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ITAAC for an item, and I'm not aware of one on the
2 slope of the lines, but we can look into that, but if
3 there's an ITAAC, that would say that they have to
4 send us a letter that says that they verified that
5 every line meets that criteria. And until we get
6 that, and we can inspect, then they are not allowed to
7 load fuel.

8 MEMBER ABDEL-KHALIK: Yes. Those are my
9 comments.

10 CHAIRMAN CORRADINI: Thanks.

11 MR. WACKOWIAK: And that was one of the
12 issues with Tier 1 that we continue to struggle with
13 is that just because we put something in there, like
14 you said, doesn't mean you can do the test. Just
15 because you write the test down doesn't -- or write
16 the acceptance down doesn't mean you can do the test.

17 So one of my objectives in Tier 1 area is
18 to make sure that every test that we write down in
19 that -- in that column actually can be performed under
20 the conditions that we're going to have prior to fuel
21 load. So that's a big part of making Tier 1 actually
22 work.

23 CHAIRMAN CORRADINI: Jack?

24 MEMBER SIEBER: Okay. Basically, from my
25 examination of the DCD application and the draft

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 document -- and the staff's SER -- I did not reveal
2 any -- or identify any PRA concerns that the staff has
3 not already picked up. And so that issue, as that
4 review finishes and as the request for additional
5 information responses come in and are accepted, I
6 think that's okay.

7 I note during this morning's presentation
8 that we really didn't cover Slides 55 to 70, which is
9 severe accident management. And I think some time in
10 the future we ought to run through that.

11 One of the issues that strikes me in that
12 realm is the BiMAC. Now, about two years ago it seems
13 to me that we had a presentation on the design of the
14 BiMAC as it existed at the time. And I seem to
15 remember some pretty old studies, and perhaps Dr.
16 Powers can help us remember that.

17 But it seems to me that when you get
18 4,000-degree molten core that goes down onto a
19 refractory surface, then the refractory loses the
20 battle so to speak, and then you have all of these
21 pipes of water underneath. And, you know, are you
22 going to get a steam explosion out of that, or just
23 exactly, you know, what is the issue there?

24 But a molten core is very hot, and you may
25 be better off, you know -- molten core in a BWR is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably oxygen-starved also. So you are going to
2 oxidize a lot of things once you get out into a more
3 oxygenated atmosphere.

4 The question is: are you better off with
5 BiMAC, knowing what we know? Or without it? It
6 seemed to me the ABWR just had a bigger spreading
7 area, and that was an attempt at reducing the amount
8 of heat capacity that the molten core presented itself
9 to whatever surface it rests on.

10 But I think that's something I'd like to
11 know more about. I have a concern about it. I guess
12 I don't have a concern if somebody can tell me that
13 containment integrity will be preserved whether it
14 works or not, and then whatever you want to put in
15 there is okay to say.

16 But it seems to me the reason why you're
17 putting it in is because you have some concern that
18 the containment may be vulnerable should an accident
19 progress to the point of melting through the vessel.
20 And I think that at least for me I would either like
21 to have a reference, that I could study it more, or
22 perhaps add it to one of our future presentations, so
23 that we can learn about it.

24 When you first -- on another subject, when
25 you first look at the way design certifications and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 construction and operating licenses are issued
2 compared to the old days, and you look at what safety
3 systems and what are not safety systems, I think there
4 is a pretty good consistency between what we're doing
5 now and what we used to do.

6 The difference is that the number of
7 components that comprise the safety system in a
8 passive core protection scheme are pretty small. When
9 you -- several people have talked about the
10 interaction between active systems and passive
11 systems. And I think this is important, because if
12 the operator sits back and folds his arms and says, "I
13 don't have to do anything for three days, so I'm just
14 going to wait for shift turnover" --

15 (Laughter.)

16 -- which is -- that's an approach. On the
17 other hand he said that "I'm going to be unemployed in
18 three days, because we are going to ruin the plant."
19 And so he is going to do his best to use the active
20 systems in order to keep from screwing up the plant
21 any more than he would have to.

22 And then, that makes the importance of
23 answering whatever interactions there are between the
24 operation of the passive systems, upon which we rely
25 for solving design basis accidents, and an operator in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there trying to pump water and open valves, and things
2 like that, I think that that -- I think that's a
3 legitimate concern and perhaps deserves more
4 attention.

5 Other than that, I think there were a lot
6 of slides. I think everybody made good presentations.
7 I think I learned some things. I think the
8 documentation that we got in advance was good enough
9 to -- for us to prepare for this meeting.

10 So that would be my comments.

11 CHAIRMAN CORRADINI: Thank you, Jack.

12 Otto?

13 MEMBER MAYNARD: Well, I continue to be
14 impressed with the use of the PRA throughout the
15 design process. I think it has been obvious to me
16 that design changes have been made, and because it has
17 been an integral process through the design.

18 I think the challenge -- and it needs to
19 be that this continues through the development of the
20 procedures and stuff. I think the COL stage, it's
21 going to be very important that this continue and get
22 into the procedures and other things down the road,
23 too.

24 But anyway, I think that's like --
25 overall, I think the PRA has done -- it's very good

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for meeting the purpose of the PRA for the design
2 certification. And that is to address primarily the
3 Commission objectives for the PRA.

4 And I think it has done that. I think
5 that there are some improvements to be made. I think
6 you need to be careful before you start just believing
7 all of the numbers and everything, but I think that
8 even with the -- including some things that I am not
9 sure why they are not in there, like locked-open
10 valves, you know, a failure of some of those valves
11 and stuff in the GDCS system, and, you know, treating
12 those somehow, even if you include them, I don't think
13 that it would get to the point where we're starting to
14 come close to eating away all of the margin that is
15 needed for the Commission policy there.

16 I think that before we start trying to use
17 the PRA to do other things, I think we would need to
18 refine those things. So I think it's going to be an
19 important aspect of -- I mean, what is it being used
20 for? And I think for the purpose of addressing the
21 Commission objectives, I am satisfied with that.

22 I've got mixed emotions on including the
23 numbers in the design -- in the digital control
24 systems. You know, first of all, I think we have to
25 be careful we don't believe the numbers. You know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is all a new area and everything. But at some
2 point you've got to put some numbers in, and then
3 start, as lessons get learned, to make adjustments and
4 stuff there.

5 And I'm not sure how you show compliance
6 with Commission objectives without putting some type
7 of number in here. And I know there are some other
8 things we don't have numbers for. So I've got some
9 mixed emotions about it.

10 I think that it's a problem probably that
11 we have within the NRC. If we are not happy with what
12 is being done by the applicants, I think we need to
13 provide some additional guidance, or what do we really
14 expect in this area, rather than just have them just
15 keep throwing things at us, and we'll kind of tell
16 them what we like when we see it. But at some point,
17 you do have to put some numbers in there, and then
18 start making some adjustments there.

19 I think it's going to be important to
20 clarify at the COL stage what some of the requirements
21 are in complying with this, and I really get -- this
22 is where I get into the operation of the systems, the
23 safety systems, and any interactions they may have
24 with the passive systems and things.

25 You know, what things kind of come out of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this that carry over to that that we need to make sure
2 that we -- somehow we capture and we take care of that
3 at some point before a license is actually issued for
4 -- to allow people to operate the plant?

5 Those are my comments, overall, I think
6 were the objectives of the meeting.

7 CHAIRMAN CORRADINI: Good. Thank you.

8 And now to murderer's row.

9 (Laughter.)

10 Starting with Dennis.

11 MEMBER BLEY: Very good presentations
12 today, and I am very impressed and pleased with the
13 way the PRA has been used in the design process, and
14 the way -- using a traditional PRA approach and
15 generic data to see what were dominant contributors
16 and design your way past them. And I think that's a
17 great approach and one we need to do. And it no doubt
18 has led to a safer design, and probably much safer.

19 On the other hand, when I get to the PRA,
20 I have got a couple of significant concerns. The
21 first one is, as you move the design to more and more
22 a passive system, and something less like what we've
23 been operating, maybe the way we've been doing PRA
24 isn't the whole answer. We have got a lot of
25 experience with current kinds of LWRs, and we had a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lot more than we have on this when we did WASH-1400.

2 And back when we did that one, there was
3 a lot of questioning and a lot of things kind of like
4 HazOps saying, "What could go wrong? How could things
5 go wrong?" What I see in the PRA is looking at
6 existing PRAs and gathering up the initiating events,
7 doing a review of systems and somehow mentally
8 defining things that in those systems could lead to
9 initiators.

10 What has been missing I think is a real
11 thorough look at the passive systems, what they need
12 to do, and a real hard questioning, like a HazOp, what
13 kind of things could make this not work the way we
14 think it is? Anything from things of aging to
15 contaminants getting in to something a maintenance
16 person could do, the whole variety, and laying out
17 that deep questioning process to see if there is
18 something we're missing, because it's a new design and
19 I haven't seen that kind of digging.

20 I'm hoping, from what you guys told us
21 today, that what you did on going through success
22 criteria with respect to the gates and the fault trees
23 may really be addressing that or beginning to address
24 it. I really hope so, and I'm looking forward to
25 seeing that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I have some concerns about the fidelity of
2 the fault trees to the system design descriptions, and
3 we are going to get into that later in some detailed
4 meetings I hope.

5 I certainly agree with everything people
6 have said about the interactions of passive and active
7 systems, and even active and active systems, which we
8 haven't talked about, and operators with both kind of
9 systems. And the thing we haven't talked about is
10 including their control systems and how they might
11 assist or preclude operations of some, and that is an
12 area you probably won't get into in its full depth at
13 this stage. But eventually, as those systems get
14 better defined, that has got to be looked at real
15 hard.

16 Overall, it looks like it -- my gut
17 feeling is things are really good, but I have these
18 things that haven't looked at it systematically enough
19 for me at the new areas that I'm a little concerned
20 about.

21 CHAIRMAN CORRADINI: Mr. Stetkar?

22 MEMBER STETKAR: Well, first of all, I
23 echo a lot of the things that Dennis said. I guess I
24 spent more time probably than some of the others
25 looking -- doing some spot checks of details, and I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think that what troubles me -- and I do think we need
2 a couple of additional sessions on this -- is that in
3 most places that I looked it was quite easy to find
4 things that were not there.

5 I tend to look -- I don't tend to look at
6 what's there. I look at what's not there. And most
7 of everything that I looked at I could find things
8 quite easily that were not there, and I mentioned a
9 few of them this morning. I did not mention a large
10 number of other things. And that was not from a
11 comprehensive review of the whole PRA; it was looking
12 at one system in particular who was doing a sort of
13 one-day look through of initiating events.

14 And what makes me a bit uneasy about the
15 whole process is that this PRA has extremely small
16 numbers. And by virtue of the fact that the numbers
17 are very small, this PRA, contrary to any other PRA
18 that has probably been done, has raised the bar in
19 terms of level of detail and completeness to support
20 the risk estimate.

21 Now, do I believe that things have been
22 left out that will cause the core damage frequency to
23 increase by three orders of magnitude? No, I don't.
24 And in this forum, I am not going to estimate how much
25 I think it might increase. But I know that this is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lower bound estimate of the actual core damage
2 frequency. Just because of the things that have been
3 left out that I know about that are small things.

4 I'm a bit concerned about the staff's
5 review of the PRA in the context of looking for things
6 systematically that have not been included in the PRA.
7 And this is not esoteric things about digital I&C,
8 it's not different ways of developing new initiating
9 events, this is kind of PRA 101.

10 It's the question of: is the level of
11 detail and completeness of the PRA models, given the
12 design information that we already have, adequate to
13 model the plant design? According to criteria and
14 standards that we have in place already -- modeling
15 maintenance unavailabilities, modeling normally open
16 valves that might spuriously close, and several other
17 things.

18 So I think that for me personally to feel
19 more confident about the robustness of this PRA to
20 actually characterize the risk and its contributors --
21 and I'm not talking about now an overall number, I'm
22 talking about the relative contributions to risk, the
23 relative importance of systems, perhaps maintenance
24 testing, those types of things.

25 I think we need to delve into some more of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the details, and I don't know how to do that. I think
2 that's something that we need to look at, because I am
3 concerned that once the design is certified, and once
4 the PRA is accepted, that PRA will take on a life of
5 its own. It will become the PRA. People will look at
6 changes to the PRA, if there are small changes to the
7 design when the plant is constructed, they will never
8 go back and look at things that are not there. That's
9 one of my bigger concerns.

10 CHAIRMAN CORRADINI: George?

11 MEMBER APOSTOLAKIS: Well, I agree with
12 almost everything I have heard. I think we should not
13 talk too much about meeting the Commission's goals,
14 because we cannot demonstrate that. But the
15 objectives that were on one of their slides, I think
16 we can make a very good case that we are actually
17 meeting those, if we have not already met them. There
18 may be some things to resolve, but I think we are very
19 -- we are well on our way.

20 Now, the digital I&C issue, I don't think
21 it is unique -- especially Otto said, you know, that
22 his trouble -- he can't see how, unless you put a
23 number there, you can show that you meet the goals.
24 And my point is that I don't need numbers to show that
25 I meet the goals.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The seismic analysis they do doesn't help
2 me in trying to demonstrate I meet the goals. All
3 they are telling me is that there is a very high
4 probability of a very low failure probability at a
5 certain earthquake. Okay? Double the SSC, or
6 whatever the number is now. They are not telling me
7 what the risk is.

8 Why, then, should I demand that the
9 digital I&C part should tell me what the contribution
10 to risk is? I can equally well there say, using a
11 bounding deterministic analysis, that this is good
12 enough, without putting a number on it.

13 I am troubled by the very low numbers, but
14 I don't see any way to raise it.

15 (Laughter.)

16 I agree with Tom. I would like to
17 understand better -- I know that Powers -- well, I can
18 repeat it now that he is not here. That 10^{-6} and what
19 LRF means -- I also agree with everybody's concern
20 regarding the active-passive interactions and how you
21 go from one to the other.

22 I believe that the way we are handling the
23 passive cooling systems is deficient in the sense that
24 we are not using the extensive work that has been
25 published in the literature. We are not operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 independently of the literature.

2 Dennis mentioned HazOps and asking
3 questions, you know, what can go wrong? There are
4 papers from 2003 that propose HazOp analysis. Okay?
5 They have not identified any, but they are giving you
6 things.

7 Well, GE, though, being the real expert on
8 this design, can use this kind of approach and make a
9 good case that, well, the reliability of the
10 convective heat transfer from the core is one, is it
11 not? Forget about valves opening, but the reliability
12 of the physical phenomenon of removing heat through
13 convection is taken to be equal to unity. And we are
14 not questioning that.

15 And I think there are papers in the
16 literature -- and I repeat, a good review is this EPRI
17 document from last December. So I really think we
18 should come up to speed.

19 Now, do I expect that we are going to find
20 something earth-shaking? No. But I really think we
21 ought to do a good job there in questioning and have
22 the thermal hydraulic colleagues raise questions, and
23 so on. But you need that framework, and I think the
24 European Union has put it together.

25 I do support the idea of having focused

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 subcommittees, more detailed things, and we will have
2 to talk about them. And I think I'm done.

3 So take out the numbers, please. Oh. I
4 am really troubled by the way we are using sensitivity
5 analysis. I mean, as long as it works everything is
6 fine. I mean, we set the human reliability numbers
7 equal to zero, and it's 10^{-6} I think the number you
8 get. That's great. The next guy who tries that may
9 get into trouble.

10 MEMBER SHACK: That's his problem.

11 MEMBER APOSTOLAKIS: And then, we start
12 playing games with failure rates, you know, multiply
13 it by five, multiply by 10. You guys could have done
14 a better job there and include a lot of that stuff in
15 the uncertainty evaluations.

16 You see, the problem is that we still
17 carry the interpretation of the word "sensitivity
18 analysis." In the old days, before PRA, "sensitivity"
19 then meant, well, you have taken the number here to be
20 three. What happens if it's five? Now it's a
21 different world. Now you are dealing with a
22 probabilistic world where presumably you have curves,
23 distribution functions. So what does sensitivity mean
24 now?

25 Well, one of the things it means, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 example, is there are assumptions you can make
2 somewhere. Okay? But does it -- it doesn't mean
3 anymore to take one number and multiply it by five or
4 10 or whatever. And I remember there was a case with
5 50.69 where they multiplied -- I think it was an NEI
6 document. In an early version, we saw they multiplied
7 by 10.

8 MEMBER SHACK: Texas could multiply by 10.
9 Other people couldn't.

10 MEMBER APOSTOLAKIS: Yes, right. Other
11 people couldn't.

12 (Laughter.)

13 I'm glad you reminded me. A factor of 10
14 worked very well.

15 (Laughter.)

16 Then, the NEI document says it's fine.
17 Why? We thought about it.

18 (Laughter.)

19 You know, this is not a serious way of
20 doing business. I mean, there ought to be a better
21 way.

22 Now, overall though, I really think that
23 changing the style of the presentation, both from GE
24 and you guys, the staff, you know, instead of focusing
25 on we are meeting the goals of the Commission, no, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you show that you are meeting those six or seven or
2 eight goals, objectives, I think you can do that, and
3 doing that involves both PRA and the deterministic
4 requirements that the agency has.

5 So you don't feel that burden that, my
6 God, the goal says 10^{-6} for early fatalities. I
7 really have to show I meet it. No, you don't, because
8 if you claim you do, then some of us will claim that
9 you haven't. So that's my input, Monsieur la
10 Presidente.

11 CHAIRMAN CORRADINI: Thank you, Professor
12 Apostolakis.

13 MEMBER APOSTOLAKIS: Mister.

14 PARTICIPANT: You're a Professor Doctor.
15 (Laughter.)

16 CHAIRMAN CORRADINI: Thank you, George.
17 (Laughter.)

18 Let me thank GEH and the staff --

19 MEMBER APOSTOLAKIS: Well, what do you
20 think?

21 CHAIRMAN CORRADINI: I'm not there yet.

22 MEMBER APOSTOLAKIS: Oh.

23 CHAIRMAN CORRADINI: Let me thank GEH and
24 the staff for their presentations today. I guess I
25 heard a number of things, which I tried to capture on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one page with some notes. I think what the Committee
2 owes the staff and GEH, though, is we have a time
3 period somewhere in the range of a few months where we
4 can take our time and schedule detailed -- more
5 detailed Subcommittee meetings on certain topics.

6 So I'd like to ask those of you -- I made
7 notes, and I thought I captured some things, such as
8 a Subcommittee meeting strictly on severe accident
9 management. That is, we skipped -- purposely skipped
10 it here. The Committee said they were going to get us
11 -- give me some questions from what they had read, so
12 I can transmit them to Amy and to Rick about severe
13 accident management. So that's a potential meeting.

14 Another one I heard I think from the
15 gentleman over here on the right, some sort of meeting
16 on system design analysis for the Level 1. At lunch,
17 I think one of you made the comment that I think was
18 important, that perhaps we can pick -- I think Rick
19 actually gave us a handful, maybe five or six of the
20 dominant sequences, and take three -- two, three of
21 those and walk through them, and then maybe
22 investigate the data analysis that went into them, the
23 analysis -- the fault tree analysis that went into
24 them, and then essentially use those as surrogates to
25 try to probe and understand it at some detailed level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I guess I don't know what the right word
2 for that is, but I would call it some sort of
3 selective accident sequence analysis review.

4 MEMBER APOSTOLAKIS: If we do two or
5 three, I don't think all of them should be dominant
6 sequences.

7 MEMBER STETKAR: That is my whole point.
8 You want to pick -- you don't want to pick the ones
9 that everybody has looked at. Everybody has looked at
10 the dominant sequences.

11 CHAIRMAN CORRADINI: So then I'm
12 looking --

13 MEMBER STETKAR: You want to randomly pick
14 a few high-pressure transients, for example.

15 CHAIRMAN CORRADINI: I think at dinner
16 tonight you will put your heads together and you will
17 give me a couple.

18 MEMBER APOSTOLAKIS: Or a few.

19 CHAIRMAN CORRADINI: All right. Beyond
20 that, I guess the one thing that I was writing down
21 somewhere in my list here was that I guess I want to
22 understand a bit -- I guess I want to thank the staff
23 and GEH. Last time we were together we kind of beat
24 up them a bit about just quoting numbers, and I think
25 to their credit they identified things that there were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 open items that were tough versus those that were
2 doable, a path forward.

3 And the one that I wrote down which I want
4 to understand a bit more is this seismic spectrum and
5 how that is going to be resolved. I think that is an
6 important one. I think the issue about the iodine
7 pumping that Tom has brought up is one that has kind
8 of come back up.

9 And I do want to understand a bit about
10 some of the physical processes for the -- for Level 2.
11 Since that is my interest area, I guess I am going to
12 particularly look at that relative to a Subcommittee
13 meeting. I think in terms of data analysis, Said's
14 point about squib failure rate, but basically failure
15 rates in particular but using the squib valves as an
16 example case is good.

17 I guess I'd kind of turn to GEH about
18 that. You guys are going to have to tell us a bit
19 more about what your database is. Is it nuclear? Is
20 it the vendors testing data? Is it actual operational
21 data upon demand, what it is? Because I think that
22 will essentially potentially give us more confidence.

23 Other than that, I just want to thank
24 everybody. We were a bit late, but I think it all
25 went pretty well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Just to clarify before you
2 end. I assume you mean we are not going to come back
3 to full Committee before you have these additional
4 Subcommittee meetings?

5 CHAIRMAN CORRADINI: I think I sense we
6 will not. That's my sense of it, by talking to my
7 colleagues at lunch, and at breaks. Is that a fair
8 statement, gentlemen?

9 MEMBER APOSTOLAKIS: Yes. When does GE
10 plan -- or GEH plan to submit this response to the
11 passive systems? You said there is partly --

12 CHAIRMAN CORRADINI: It's partly in Level
13 -- in the Rev 3.

14 MEMBER APOSTOLAKIS: That would be a more
15 complete response.

16 MS. CUBBAGE: The thermal hydraulic?

17 MR. WACKOWIAK: The thermal hydraulic
18 uncertainty? Yes. Well, now that the DCD has been
19 submitted, I believe I know have access to some TRACG
20 resources again that were not available to us over the
21 last couple of months. So we'll be getting that
22 picked back up.

23 Just to let you know where we are, the
24 calculations have been run. And when we had to move
25 on to other things, we were in the middle of writing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 up our response on why we thought that TRACG and MAAP
2 were giving us the same results with respect to the
3 PRA.

4 Where we kind of got stuck is that we --
5 my group didn't understand some of the things that was
6 -- that were going on in the TRACG runs. And we are
7 getting -- in the middle of getting clarification on
8 those things, and we will have a writeup on why things
9 look the way they do, and we will discuss that.

10 In the end, I think it comes down to
11 something that you may have talked about in previous
12 meetings with GEH, in that the selection of models in
13 TRACG are not -- they are bounding rather than best
14 estimate. And that led to a little bit of our
15 confusion about what TRACG was doing versus what MAAP
16 was doing. And it was deliberately doing it that way
17 for a reason based on design basis calculation. More
18 bounding model.

19 So we are fairly close. I think it is
20 just a couple weeks away from getting that response
21 out to Hossein, so that they can start taking a look
22 at that, and then we should be able to come in and
23 talk about it.

24 CHAIRMAN CORRADINI: So to get back --
25 thank you very much, Rick. To get back to you, Amy,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about timing, I guess I am just reflecting that we had
2 expected to consider a letter in July. I think,
3 unless you want a letter that is going to have an
4 awful lot of provisos in it, I don't see there is a
5 necessary rush on this one, particularly because --

6 MS. CUBBAGE: It's not a necessary rush to
7 get a letter in July, but I would say that these
8 Subcommittees need to be done pretty quickly, because
9 the staff and GE, as you heard here today, are quickly
10 converging. And we're going to be going to a final
11 SER at the -- you know, in a draft form very soon.
12 And then, we'll be finishing it up.

13 CHAIRMAN CORRADINI: So, then, let me ask
14 you -- so, then, I guess I have no problem with having
15 a Subcommittee meeting in July and August, but I've
16 got to check with my colleagues to have it populated.

17 (Laughter.)

18 Besides just me --

19 MS. CUBBAGE: I'm not seeing it happen.

20 MEMBER APOSTOLAKIS: That is not the only
21 problem. If we come back here and say again the EPRI
22 report, and I draw blanks, they are not ready. I
23 mean, we have to give them some time to think about
24 these things. So it's not only us.

25 CHAIRMAN CORRADINI: No, I understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that. But I guess I want to just at least lay it out
2 that, over the next couple months is a relatively
3 slower time, but I think other things are going to
4 take priority for other things on the Committee.

5 MS. CUBBAGE: Right. I just don't want it
6 to hit the back burner.

7 CHAIRMAN CORRADINI: No, I understand
8 that.

9 MS. CUBBAGE: It's not a year from now.

10 CHAIRMAN CORRADINI: No, no, no.

11 MS. CUBBAGE: It's not nine months from
12 now. It's --

13 CHAIRMAN CORRADINI: No, no, I understand
14 that. But I guess what I'm saying -- let me just say
15 it more just bluntly. It seems to me on the GE side
16 is a response relative to the TRAC versus MAAP
17 calculations. We have to look at the BiMAC result,
18 which just arrived, and we have got to digest it.
19 You've got to digest it.

20 They have got to think about things
21 relative to passive safety systems, that George has
22 suggested and has volunteered to give it to them.
23 Whether or not he can is a different question.

24 The EPRI report -- that sort of back and
25 forth, that is at least a month, if not six, seven

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 weeks.

2 MS. CUBBAGE: We could go to
3 September/October. I'm just --

4 CHAIRMAN CORRADINI: But just to -- the
5 last thing I guess I want to leave to you, and we have
6 talked about it privately, is I do think, though, we'd
7 like to know from you what -- how it looks after the
8 summertime in September, October, November, December,
9 because it seems to me we still have opportunity in
10 those few months to have two or three Subcommittee
11 meetings strictly on things related to this and some
12 outstanding thermal hydraulic -- I'm pointing to him
13 because there are a couple of his issues, and Sanjoy
14 is nobody to point to around here -- but thermal
15 hydraulic issues. But between those two, two or three
16 meetings are going to probably be necessary.

17 MEMBER APOSTOLAKIS: Well, let me ask you
18 this, though. Wouldn't it be wise to have a two- or
19 three-day meeting so the guys from GEH don't have to
20 fly here just --

21 CHAIRMAN CORRADINI: I agree.

22 MEMBER APOSTOLAKIS: And then, you know,
23 have maybe half a day on this, half a day on that,
24 three hours on this.

25 CHAIRMAN CORRADINI: But I just have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 feeling --

2 MEMBER APOSTOLAKIS: They can go over
3 everything.

4 CHAIRMAN CORRADINI: But I don't want to
5 be overly -- just this is me, I don't want to be
6 overly zealous, because I have tried these with the
7 thermal hydraulics, and we say, "Oh, we can do a
8 couple accident sequences." Well, six hours later we
9 were through one accident sequence. Okay?

10 (Laughter.)

11 So my thought is if we are going to have
12 something on PRA, it might be a different group of --
13 the different part of the team, and you might want to
14 have a day on severe accident management, a day on
15 system design, these sequences, and maybe take a
16 couple of days and take within those two days two or
17 three sequences and just clean out all of the issues
18 -- at least we think we will -- for over a two- or
19 three-day time span there. And then, another one on
20 thermal hydraulics, which we still have yet to do.

21 MEMBER APOSTOLAKIS: Good work. Good
22 work.

23 MR. HAMZEHEE: How many PRA Subcommittee
24 meetings do you envision we would need before we are
25 ready to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: I can see three days
2 would be a good start.

3 MR. HAMZEHEE: Three days.

4 MEMBER APOSTOLAKIS: I think we need to
5 get together in the next two or three days.

6 CHAIRMAN CORRADINI: And get you an
7 answer.

8 MEMBER APOSTOLAKIS: Identify the areas.

9 CHAIRMAN CORRADINI: And Amy is already
10 checking out the future and is going to tell me a bit.

11 MS. CUBBAGE: And this is only one design
12 center. That's --

13 MEMBER APOSTOLAKIS: I don't see how we
14 can --

15 MS. CUBBAGE: You all are going to be
16 busy.

17 MEMBER APOSTOLAKIS: -- method over PRA
18 before December.

19 CHAIRMAN CORRADINI: Excuse me? We can't
20 do it in July. That's what I told --

21 MEMBER APOSTOLAKIS: That's for sure.

22 CHAIRMAN CORRADINI: Well, and it's very
23 difficult to do it before December -- September, if
24 you don't do it in July.

25 MEMBER SHACK: He said December.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Oh, he said December.

2 MEMBER SHACK: Yes. That's why I didn't
3 want to accept that as --

4 MEMBER SIEBER: Not August, please.

5 CHAIRMAN CORRADINI: We can't -- I don't
6 think we will be able to do it in July. I think
7 that's a fair statement.

8 MEMBER APOSTOLAKIS: If you have any hopes
9 for September, you'd better come down to earth.
10 Because July/August is very hard to set up
11 Subcommittee meetings.

12 MS. CUBBAGE: Keep in mind we have to do
13 Chapters 7 and 14 in September.

14 MEMBER SIEBER: Pick a date and see who
15 shows up.

16 (Laughter.)

17 CHAIRMAN CORRADINI: So we will -- we owe
18 you some discussions, and we'll get back to you, and
19 then we'll see each other later this week, no doubt.

20 MS. CUBBAGE: Yes.

21 CHAIRMAN CORRADINI: So thank you all.
22 Thank you, Rick. Thank your team. Amy, thank you
23 very much. Hossein, thank you very much.

24 MR. HAMZEHEE: You're welcome.

25 CHAIRMAN CORRADINI: All right. We're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done.

2 (Whereupon, at 6:21 p.m., the proceedings
3 in the foregoing matter were adjourned.)

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

ESBWR Regulatory Treatment of Non-Safety Systems


Rick Wachowiak

Technical Lead ESBWR PRA

Gary Miller

Principal Engineer ESBWR PRA

June 3, 2008



HITACHI

NRC RTNSS Criteria

- A SSC functions relied upon to meet beyond design basis deterministic NRC performance requirements such as 10CFR50.62 for anticipated transient without scram (ATWS) mitigation and 10CFR50.63 for station blackout
- B SSC functions relied upon to resolve long-term safety (beyond 72 hours) and to address seismic events
- C SSC functions relied upon under power-operating and shutdown conditions to meet the Commission's safety goal guidelines of a core damage frequency of less than 1.0E-4 each reactor year and large release frequency of less than 1.0E-6 each reactor year
- D SSC functions needed to meet the containment performance goal (SECY-93-087, Issue I.J), including containment bypass (SECY-93-087, Issue II.G), during severe accidents
- E SSC functions relied upon to prevent significant adverse systems interactions



HITACHI

RTNSS A: Deterministic

ATWS

- Diverse Protection System Functions
 - Alternate Rod Insertion
 - Feedwater Runback
- Safety Related SLCS Actuation

Station Blackout

- Safety-related components



HITACHI

RTNSS B: Long Term Safety and Seismic

Core Cooling

- Need makeup water to IC/PCCS Pools after 72 hours
- Fire Protection Water supplied by
 - Diesel fire pump
 - Electric fire pump
 - Powered by Ancillary Diesel Generators



HITACHI

RTNSS B: Long Term Safety and Seismic

Containment Integrity

- Also need makeup to IC/PCCS Pools after 72 hours
- Long Term Containment Pressure Reduction
 - PCCS vent fans
 - Passive autocatalytic recombiners



HITACHI

RTNSS B: Long Term Safety and Seismic

Control Room Habitability

- Long term Dose Protection
 - Emergency filter units
 - Powered by Q-DCIS
 - Supplied by Ancillary Diesel Generators Long Term
- Long Term Temperature Control
 - Heating/Cooling Units in Air Handling Units
 - Powered by Q-DCIS
 - Supplied by Ancillary Diesel Generators Long Term



HITACHI

RTNSS B: Long Term Safety and Seismic

Post Accident Monitoring

- Provided by Q-DCIS
- Emergency Lighting
 - Supplied by Ancillary Diesel Generators Long Term



HITACHI

RTNSS B Design Treatment

Redundant Functions

Fire and flood protected

Hurricane category 5 missile protection

Designed for accident environment

Seismic Category II

Quality suppliers (not Appendix B)

Availability Controls Manual



HITACHI

RTNSS C: Probabilistic

Focused PRA

- ESBWR that considers only safety-related and RTNSS equipment
- Determine significance by removing one function-train at a time
 - If CDF or LRF goals are exceeded, the function is considered significant
 - Significant functions are included in Technical Specifications
- All equipment in the focused model requires treatment
- DPS functions needed to meet CDF and LRF goals
 - GDCS Actuation
 - ADS Actuation
 - Isolation of RWCU/SDC Valves
 - Opening of IC/PCCS Pool Cross-Connect Valves



HITACHI

RTNSS C: Probabilistic

- Assessment of Uncertainty
 - FAPCS Low Pressure Injection
 - FAPCS Suppression Pool Cooling
- Supporting Functions for FAPCS
 - Standby Diesel Generators and PIP buses
 - Nonsafety-related DCIS (N-DCIS) to operate FAPCS
 - HVAC for buildings containing identified N-DCIS and FAPCS
 - RCCWS and Nuclear Island Chilled Water to cool FAPCS, HVAC, and SDGs
 - Service Water to cool RCCWS



HITACHI

RTNSS C Design Treatment

Redundant active components

Fire and flood protected

Hurricane category 5 missile protection

Designed for accident environment

Quality suppliers (not Appendix B)

Technical Specifications for SSCs Needed to Meet CDF
and LRF Goals

Availability Controls Manual for Frontline Systems



HITACHI

RTNSS D: Containment

- BiMAC and GDCS Deluge Valves

RTNSS E: Adverse Systems Interactions

- RBHVAC Purge Exhaust Charcoal Filters
- Drywell Hatches



HITACHI

RTNSS Open Items

- Some SSCs needed for post-72 hour safety housed in structures designed to a standard that may not guarantee functionality post-earthquake
 - In DCD rev 5, all post-72 hour safety function equipment located in Cat II or better structures. This should close the item
- Additional information on structure design needed to enable the staff confirm RTNSS systems have been adequately protected from flood-related effects associated with both natural phenomena and system and component failures
 - Response provided in DCD rev 5. Post-72 hour safety functions are protected



HITACHI

RTNSS Open Items

- ACs did not state the associated instrumentation functions and the number of required divisions in the AC LCOs for some functions
- AC bases do not explicitly state the minimum level of system degradation that corresponds to a function being unavailable, or the number of divisions used to determine the test interval for each required division (or component) for AC surveillance requirements
- No AC Surveillance Requirements provided for FAPCS pumps
- AC LCOs for FAPCS and EDGs inconsistent with PRA assumptions

These questions were provided after DCD rev 5 was well into production. Answers will be provided in a followup letter.



HITACHI

ESBWR PRA and Severe Accident Management


Rick Wachowiak

Technical Lead ESBWR PRA

Gary Miller

Principal Engineer ESBWR PRA

June 3, 2008



HITACHI

PRA For A New Reactor Design

Determine risk management strategy

Consider all aspects in the design

- Core damage and releases
- Severe accident phenomena
- Internal and external events
- All modes

Design PRA provides a bounding assessment

- Provides the safety case for the plant license



Make risk assessment an integral part of the overall design process

Updated As-Built PRA prior to fuel load is required



HITACHI

Three Chief Methods to Affect Calculated Risk



Procedures include the entire man-machine interface
Data includes methods as well as reliability programs



HITACHI

Using a PRA early provides maximum benefit

PRA as a Design Tool

Eliminate Severe Accident Vulnerabilities

- PRA provides a systematic means for finding vulnerabilities
- GE utilizes the PRA as an integral element of the design process
- Make corrections in design phase
- Quantitative and Qualitative PRA tools are used



HITACHI

Key Features of ESBWR Design Risk Management

Passive safety systems

Active asset protection systems

Support system diversity


Minimize reliance on human actions

Use historical data


Target configuration for
core damage prevention
functions




HITACHI



Key Features of ESBWR



NOTE 1: THE COMPONENTS ATTACHED TO THE PCC CONDENSER ARE AN INTEGRAL PART OF THE CONTAINMENT BOUNDARY ABOVE THE DRYWELL



Passive features shown



HITACHI

Features of ESBWR PRA

Detailed Fault Tree / Event Tree Models

Level 1, 2, and 3

Internal & External Events

All Modes

Seismic Margins

Generic Data

Historical Initiating Event Frequencies

Parametric Uncertainty


Systematic Search for Key Modeling Uncertainties

Internal review for compliance with ASME-RA-Sb-2005



HITACHI

ESBWR Core Damage Risk Profile



$$CDF_{pe} = 1.2 \times 10^{-8} / \text{yr}$$

$$CDF_{\text{mean}} = 1.1 \times 10^{-8} / \text{yr}$$

At power internal events



HITACHI

Overall Results

	Internal Events	Fire	Flood	High Winds
At-Power CDF	1.22×10^{-8}	8.06×10^{-9}	1.62×10^{-9}	1.34×10^{-9}
Shutdown CDF	9.37×10^{-9}	2.71×10^{-8}	5.24×10^{-9}	1.19×10^{-9}
At-Power LRF	9.6×10^{-10}	5×10^{-10}	2×10^{-10}	3×10^{-11}
Shutdown LRF	9.37×10^{-9}	2.71×10^{-8}	5.24×10^{-9}	1.19×10^{-9}

Point Estimate Values
Units are (1/yr)



HITACHI

Initiating Events Analysis

Transients based on historical BWR data

- NUREG-5750
- General, Loss of PCS, Loss of Feedwater, IORV

Loss of offsite power based historical data

- NUREG/CR-6890
- Plant, Switchyard, Grid, Weather related events

Loss of coolant accidents

- NUREG-5750 scaled for ESBWR piping arrangement
- Includes inadvertent ADS, spurious DPV & multiple spurious SRV
- Includes vessel rupture (NUREG-1806)



HITACHI

Initiating Events Analysis

Breaks outside containment

- NUREG-5750
- Main steam, Feedwater, RWCU, ICS

Interfacing systems LOCA

- Two candidates are subsumed into other scenarios

Special initiators

- NUREG-5750
- Loss of service water, Loss of instrument air



HITACHI

Initiating Events Analysis

Significant open items

- none



HITACHI

Accident Sequence Analysis

Linked fault tree methodology

Front line systems (passive and active) included as headings

Success criteria based on thermal-hydraulic calculations

- MAAP 4.06, TRACG
- In general, single bounding criterion applied all event trees
- Sensitivity analyses confirm success criteria
- MAAP case performed for each success end state

Six end states to support containment analyses



HITACHI

Success Criteria - LLOCA

	PRA	Minimum
GDCS Valves	2	<1
GDCS Pools	2	1
Equ Valves	1	0
PCCS	4	<2



HITACHI

Success Criteria - MLOCA

	PRA	Minimum
GDCS Valves	2	< 1
GDCS Pools	2	1
Equ Valves	1	0
PCCS	4	< 2
DPV	4	< 3



HITACHI

Accident Sequence Analysis

Mission time

- Passive design requires very long mission time analysis
 - Evaluation consider safe, stable state as success
 - Not necessarily cold shutdown
- Event sequences consider entire mission time
- Data for components uses maximum 24 hour mission time



HITACHI

Accident Sequence Analysis

Significant open items

- Thermal-Hydraulic analysis for passive system success criteria
 - Cases used for TRACG/MAAP4 comparisons did not cover scenarios where the water level dropped below TAF
 - TRACG models for calculating clad temperature need to be described
 - Responses are being developed for these issues
- Rationale for selection of limiting accident scenarios not provided
 - Roadmap to this information provided in an RAI response
- Treatment of parameters affecting T-H uncertainty not provided
 - Information provided in an RAI response and in rev 3



HITACHI

Systems Analysis

Fault trees used to model system functions

- 29 Systems
 - 12 Front line systems
 - 17 Support systems
- 39 Functions

Based on descriptions in DCD Tier 2, Topical Reports, and internal design specifications

Typical maintenance schedule assumed

Multiple plant configurations included in the model

- Single configuration included in the results



HITACHI

Systems Analysis

Significant open items

- none



HITACHI

Data Analysis

Bounding analysis

- Generic data representative of operating BWRs
 - ALWR URD, GE generic database, engineering judgment
 - Passive component failure rates adjusted for long maintenance intervals
- Uncertainty distributions included for all data
- Increased squib valve failure rates
- High end digital system failures
- Screening values for limited operator actions



HITACHI

Data Analysis

Common Cause Failures

Multiple Greek Letter methodology

Generic sources

- ALWR URD
- NUREG/CR-5497
- EPRI TR-100382
- NUREG/CR-5801



HITACHI

Data Analysis

Significant open items

- none



HITACHI

Human Reliability Analysis

ESBWR design PRA minimizes reliance on operator actions

- Type A – Pre-initiating event actions
 - Significant parameters addressed in HFE
- Type B – Human action induced initiating events
 - Included in historical data
- Type C – Post-initiating event actions
 - Limited set – also addressed in detailed HFE
 - Screening values used based on time required to perform the action
- Dependency analysis included



HITACHI

Human Reliability Analysis


Significant open items

- none



HITACHI

Level 1 Results




PRA rev 2



HITACHI

Level 1 Results



HITACHI

Level 1 Results

Sequence	T-IORV063	Sequence No. 1
CDF	2.06E-09	
% of Class I CDF	36.61%	
% of total CDF	16.90%	
Initiating event	Inadvertent Open Relief Valve	

Scram is successful

Feedwater Injection Fails

Both CRD Pumps fail to restore level

Failure to Manually Depressurize with SRVs

ADS Depressurization with DPVs is successful

DW/WW vacuum breakers suppress containment pressure

Low Pressure Injection with GDCS, FAPCS, and Firewater fail

Vessel fails at low pressure

Lower drywell water level is LOW



HITACHI

Level 1 Results

Sequence	AT-T-GEN023	Sequence No. 2
CDF	1.3E-09	
% of Class IV CDF	69.66%	
% of total CDF	10.70%	
Initiating event	General Transient (e.g. turbine trip)	

Scram fails

Feedwater Runback is successful

SRVs lift and overpressure protection is successful

ADS Inhibit is successful

One of two trains of SLC fails

Vessel fails at low pressure*

Lower drywell water level is LOW

*It is assumed that operators depressurize once core damage is imminent.



HITACHI

Level 1 Results

Sequence T-FDW050 Sequence No. 3
CDF 1.14E-09
% of Class I CDF 20.26%
% of total CDF 9.35%
Initiating event Loss of Feedwater

Scram is successful

Isolation Condensers fail to provide overpressure protection

SRVs lift - overpressure protection is successful

All SRVs reclose

ADS is successful using DPVs

DW/WW vacuum breakers are successful - pressure suppression is successful

GDCS fails

Low pressure injection using FAPCS, Firewater and CRD fail

Vessel fails at low pressure

Lower drywell water level is LOW



HITACHI

Level 1 Results

Sequence T-IORV018 Sequence No. 4

CDF 9.02E-10

% of Class III CDF 19.98%

% of total CDF 7.39%

Initiating event Inadvertent Open Relief Valve

Scram success

Feedwater injection fails

Both CRD fail to restore level

Manual Depressurization using SRVs is successful

Low pressure injection with FAPCS and Firewater fail

ADS fails to depressurize using DPVs Vessel fails at low pressure*

Lower drywell water level is LOW

*Pressure is low prior to RPV failure due to IORV



HITACHI

Level 1 Results

Sequence AT-T-GEN021 Sequence No. 5
CDF 8.78E-10
% of Class III CDF 19.46%
% of total CDF 7.20%
Initiating event General Transient (e.g. turbine trip)

Scram fails

Feedwater runback success

SRVs lift – overpressure protection is successful, but one or more SRVs sticks open

ADS Inhibit is successful

SLC is successful

Feedwater and CRD fail to maintain reduced level Vessel fails at low pressure *

Lower drywell water level is LOW

*It is assumed that operators depressurize once core damage is imminent or pressure is low prior to RPV failure due to IORV.



HITACHI

Containment Performance Analysis

Level 2 based on the severe accident phenomena evaluation which uses ROAAM

- Phenomena discussed in Severe Accident section

Containment system models incorporated


Fully linked model

Any release larger than “allowed leakage” is considered Large



HITACHI

Level 2 – Class I With Low DW Water Level



HITACHI

Level 2 Results

Release category	Frequency (per year)
TSL	1.12E-8
FR	< 1E-12
BYP	5.6E-11
OPVB	1.6E-11
OPW1	3.2E-11
OPW2	< 1E-12
CCIW	9.9E-11
CCID	1E-12
EVE	6.10E-10
DCH	Physically Unreasonable
BOC	1.47E-10



HITACHI

Level 2

Significant open item

- Further information was requested on vacuum breaker design, coverage in DCD and ITAAC, and on emergency procedures related to failed vacuum breakers
 - Responses to RAIs 19.2-6, 19.2-10, and 19.2-11 address these issues
 - VB design discussed in Chapter 6 review
 - COL item established to develop emergency procedures



HITACHI

Source Terms

15 Release categories evaluated

Representative sequences cover all core damage end states

Magnitude and timing of releases described

Significant open items

- none



HITACHI

Offsite Consequences

Calculated using MAACS2

Population and climate derived from ALWR URD

Dose results mostly from containment intact sequences

- 58% TSL
- 29% EVE

Individual risk is $8.2e-11$ /yr

- 72% from EVE
- 6% from BYP

Societal risk is $1.1e-11$ /yr

- 50% from EVE
- 22% from BYP
- 12% from BOC



HITACHI

Offsite Consequences

Significant open items

- none



HITACHI

Uncertainty And Sensitivity Analyses

Systematic process for determining sensitivities

Two categories

- Data estimates
- Modeling

Reviewed all assumptions and insights

Results presented in Section 11

- Level 1 – 16 cases
- Level 2 – 3 cases
- RTNSS – 9 cases
- Fire – 8 cases
- Other external events – 5 cases



HITACHI

Uncertainty and Sensitivity Analyses

Significant open items

- Thermal-hydraulic uncertainty
 - Discussed in accident sequence slides
 - Resolution has both probabilistic and deterministic attributes
 - Probabilistic justification presented on next 3 slides



HITACHI

Thermal-Hydraulic Sensitivities

Adjusted success criteria in event trees

- GDCS valves
- DPV valves
- PCCS heat exchangers


Design basis criteria (single failure allowed)

Added redundancy until CDF reached baseline



HITACHI

CDF Sensitivity on Passive System Success Criteria



HITACHI

Thermal-Hydraulic Sensitivity Results

GDCS success not significant until 6 of 8

PCCS success not significant until 6 of 6

- Test and maintenance assumption is key

DPV success not significant until 7 of 8

Any redundancy allows for acceptable CDF



HITACHI

Fire Risk Assessment

Analysis is based on NUREG/CR-6850 methods

Simplifying assumptions

- All fires grow to be “fully developed” and affect whole area
- No credit for suppression
- I&C design precludes spurious actuations, however fires in the reactor building that spread to multiple barriers include a non-mechanistic spurious SRV actuation



HITACHI

Fire Risk Assessment

Spurious actuations

- ESBWR design precludes hot shorts
 - Fiber optic connections
 - Actuation devices in multiple separated areas
 - Requirements on digital components to be qualified to prevent spurious operations in presence of fire and smoke

Strict adherence to separation is key to low fire risk

Calculated fire risk is expected to be reduced when as-built information is available to enable fire modeling

Calculated fire risk is expected to be reduced when fire mitigation procedures are developed



HITACHI

Fire Risk Assessment

Significant open items

- none



HITACHI

Flood Risk Assessment

Floods are assumed to drain entire reservoir

Fire doors do not provide flood protection

No credit for operator actions to mitigate floods

Flood is not a significant contributor to risk

Significant open items

- none



HITACHI

High Winds Risk Assessment

Seismic Cat I buildings are assumed to withstand hurricane and tornado events

Seismic Cat II buildings are assumed to withstand hurricane events

Non-seismic buildings that house RTNSS C equipment can withstand hurricane events

Event frequencies are based on historical data

- Hurricanes include only coastal plant data

Given the above assumptions, ESBWR risk is low with respect to high winds



HITACHI

High Winds Risk Assessment

Significant open items

- Justification for assumed conditional probability of zero that Category 4 or 5 hurricanes can damage structures
 - Loads on Cat I and II structures is bounded by seismic events by an order of magnitude
- Not clear whether credit was taken for equipment in Seismic Category II structures hit by tornado missiles
 - GEH failed equipment in Cat II structures for F5 Tornadoes
- Staff questions declarations that tornado and hurricane assessments are bounding
 - Analyses show that risk is not sensitive to tornado frequency
 - Insights from ESBWR analysis indicates that designing for hurricanes is important. All reasonable protection is provided in the design
- Responses are being developed for these items



HITACHI

Seismic Margins Analysis

Framework for margins has been established

Only credits seismic Cat I structures and equipment located in Cat 1 structures

Capability of structures can be inferred based on Cat I design requirements

Capability of systems is assumed

As-built information is needed to confirm capability

COL item commits to confirm $1.67 \times$ SSE capability for buildings and equipment



HITACHI

Seismic Margins Analysis

Significant open issues

- GEH used a spectrum shape different from the Certified Seismic Design Response Spectra (CSDRS) for HCLPF estimates
 - Performance based response spectrum used
 - Bounds all potential ESBWR sites
 - GEH believes GMRS is the correct spectrum to use for as-built seismic margins capability assessment
- Seismic margins SSE has not been defined as CSDRS
 - See above
- Fault-tree for Fire Protection Water System does not model all of the components in the system that must survive the earthquake
 - Revision 3 identifies all of these components



HITACHI

Shutdown Risk Analysis

Modes 2, 3, and 4 assumed to be bounded by full power analysis

Modes 5 and 6 needed to be split to account for unique behavior

- Mode 5 head on
- Mode 5 head off
- Mode 6 unflooded
- Mode 6 flooded

No credit for containment in shutdown PRA

LOCA during shutdown is more than 90% of CDF

- Lower Drywell hatch needs to be controlled during outages



HITACHI

Shutdown Risk Analysis

Significant open items

- GEH needs to define Technical Specification for DPVs during Modes 5 and 6 w/vessel head on
 - Revision 5 TS specifies 6 DPVs are required
- Staff questions ability of Isolation Condenser to function effectively for some operational conditions in Mode 5
 - Water level above the ICS steam nozzle is the issue
 - This analysis will be provided in an RAI response



HITACHI

Shutdown Risk Analysis

- GEH must determine range of conditions (temperature and level) for which the RWCU/SDC can adequately remove decay heat in Modes 4, 5, and 6 (with the RPV head installed)
 - Response is under review
 - RWCU/SDC can maintained subcooled conditions as long as the suction nozzle is covered
- Staff concerned that RWCU/SDC injection may bypass the core due to inadequate mixing in downcomer
 - Response is under review
 - Configuration is similar to ABWR



HITACHI


Severe Accident Management

Threat Failure Mode Mitigative System



HITACHI

Containment Fragility – Composite Curve



HITACHI

Cumulative F. P. $P_{med}=1.632\text{MPa}, \text{COV}=.16$

Containment Fragility


Significant open item

- Calculated upper drywell liner strain appears to exceed Level-C limit under conditions of 100% metal/water reaction
 - The documentation is not clear that service level C is presented in gauge while the metal/water results are presented in absolute
- Temperature boundary condition for drywell head in finite element model set at 110 °F versus drywell air space temp of 500 °F
 - Analysis using 500 °F is presented in rev 5 of the DCD




HITACHI

The Basemat internal Melt Arrest and Coolability (BiMAC) device



HITACHI

BiMAC Configuration




All Numerical Values are Preliminary




HITACHI

BiMAC Flow Path




HITACHI

Natural Convection in BiMAC




HITACHI

Wetting of BiMAC Horizontal Channels



HITACHI

Thermal Loads against Coolability Limits in BiMAC Channels



HITACHI

BiMAC Thermal-Hydraulic Testing


Results provided in NEDE-33392P

- Demonstrates that the analytical results presented on the previous slides are bounding
- Even a few degrees of subcooling greatly enhances the performance of the BiMAC
- Staff is reviewing this document to close a significant open item




HITACHI

Test Overview



Systems Effects (SE)
[1/2 scale, 1/4 symmetry]

Single Channel (SC)
[Full scale tests]





HITACHI

Quantification of DCH Loads

Identified Three Dynamic Regimes


Used Complete Space (up to all fuel, Zr, and SS) to Bound Independently each Failure Mode



HITACHI

Regime III Expected (not shown)


Minimum (bounding) Margins to Energetic DCH Failure



HITACHI


Pedestal Failure Margins to EVE

1 to 2 m Subcooled Pools



|

BiMAC Failure Margins Due to EVE 1-2 m subcooled pools



Additional Open Items

- The staff requested additional information on the process that will be used by GEH to develop the Severe Accident Guidelines (SAGs)
 - A description of how this is being addressed within the HFE process was provided as a response
- Applicant's basis for ensuring PRA quality is adequate for design certification not provided in DCD
 - The results of the self assessment of the PRA with respect to ASME-RA-Sb-2005 was presented to the staff. This is now considered closed



HITACHI

ESBWR Design PRA Revision 3

Submitted June 1, 2008

Reviewed differences between PRA rev 2 model and DCD rev 5 configuration

No significant change in the risk assessment results and insights

Added Section 22 to describe the differences and any sensitivity analyses needed to support our conclusions



HITACHI



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 19

Presented by
NRO/DNRL/NGE1 and NRO/SPLB

June 3, 2008

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

Purpose:

Brief the Subcommittee on the results of the staff's review of the ESBWR DCD application, Chapter 19

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19**

Review Team for Chapter 19:

Lead Project Manager

- Rocky D. Foster, Project Manager

Lead Technical Reviewer

- Mark Caruso, Sr. Risk & Reliability Engineer

Technical Reviewers

- Edward Fuller, Sr. Risk & Reliability Engineer
- Marie Pohida, Sr. Risk & Reliability Engineer
- Glenn Kelly, Sr. Risk & Reliability Engineer
- John Lai, Risk & Reliability Engineer
- Jim Xu, Sr. Structural Engineer

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

Outline of Presentation:

RAI Status Summary
Applicable Regulations
SER Technical Topics
Significant Open Items
COL Action Items

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

RAI Status Summary:

289 RAIs

272 RAIs resolved

17 Open Items

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

Regulatory Requirements:

- 10 CFR 52.47(a)(8) – comply with TMI requirements
- 10 CFR 52.47(a)(21) - resolve USI/GSI
- 10 CFR 52.47(a)(23) – provide description and analysis of design features for prevention and mitigation of severe accidents
- 10 CFR 52.47(a)(27) – provide description of PRA and results

Regulatory Guidance:

Policy Statements on Severe Accidents and Use of PRA
SECY-93-087, SECY-96-128, and SECY-97-044 - guidance for implementing features in new designs to prevent or mitigate severe accidents
Regulatory Guide 1.206 and SRP Chapters 19.0 and 19.1

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19

Commission's Objectives:

- Use the PRA to identify and address potential design features and plant operational vulnerabilities.
- Use the PRA to reduce or eliminate the significant risk contributors
- Use the PRA to select among alternative features and design options.
- Identify risk-informed safety insights
- Determine how the risk associated with the design compares against the Commission's goals of less than 1×10^{-4} /yr for CDF and less than 1×10^{-6} /yr for LRF and containment performance goals
- Assess the balance between severe accident prevention and mitigation.
- Determine whether the plant design represents a reduction in risk compared to existing operating plants
- Demonstrate compliance with 10 CFR 50.34(f)(1)(i) (i.e., perform a PRA)
- Use PRA in support of programs and processes (e.g., RTNSS, RAP)

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.2 Quality of PRA

Technical Topics:

Success Criteria and Passive System Uncertainty
Treatment of Common-Cause Failures
Probabilistic Risk Assessment Technical Adequacy
PRA Maintenance Program

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.2 Quality of PRA

Significant Open Items:

Thermal-Hydraulic analysis for passive system success criteria

- cases used for TRACG/MAAP4 comparisons not appropriate
- rationale for selection of limiting accident scenarios not provided
- treatment of parameters affecting T-H uncertainty not provided
- TRACG models for calculating clad temperature need justification
- GEH provided partial response to RAI 19.1-1, Supplement 1, staff is evaluating

Applicant's basis for ensuring PRA quality is adequate for design certification not provided in DCD

- GEH response to RAI 19.1-155 acceptable, issue now closed

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.3 Design Features

Technical Topics:

Features for Preventing Core Damage
Features for Mitigating the Consequences of Core
Damage and Preventing Releases from Containment
Features for Mitigating Releases from Containment
Uses of the PRA in the Design Process

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.3 Design Features

Significant Open Items:

None

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.4 Internal Events At-Power PRA

Technical Topics:

Level 1 PRA Insights
Level 2 PRA Insights

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.4 Insights from Internal Events At-Power PRA

Significant Open Items:

None

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.5 External Events At-Power PRA

Technical Topics:

Seismic Margins Analysis
High Winds Analysis
Internal Fires Analysis
Internal Floods Analysis

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 19

19.1.5.1 Seismic Margins Analysis

Significant Open Items:

GEH used a spectrum shape different from the Certified Seismic Design Response Spectra (CSDRS) for HCLPF* estimates.

Majority of SSCs treated in SMA assume a HCLPF equal to the limit of $1.67 \times \text{SSE}$; however, the SSE has not been defined as CSDRS in the DCD.

- Awaiting response to RAI 19.2-92 from GEH

Fault-tree for Fire Protection Water System does not model all of the components in the system that must survive the earthquake

- Awaiting response to RAI 19.2-91 from GEH

*High Confidence of Low Probability of Failure defined as: Earthquake level at which, with high confidence (95 percent), it is unlikely (probability less than 5×10^{-2}) that failure of the SSC will occur.

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.5.1 Seismic Margins Analysis

COL Action Item:

COL Holder shall compare the as-built SSC HCLPFs* to those assumed in the ESBWR seismic margin analysis. Deviations from the HCLPF values or other assumptions in the seismic margins evaluation shall be analyzed to determine if any new vulnerabilities have been introduced.

*High Confidence of Low Probability of Failure defined as: Earthquake level at which, with high confidence (95 percent), it is unlikely (probability less than 5×10^{-2}) that failure of the SSC will occur.

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19**

19.1.5.4 High Winds Analysis

Significant Open Items:

Assumed conditional probability of zero that Category 4 or 5 hurricanes can damage structures not justified

Not clear whether credit was taken for equipment in Seismic Category II structures hit by tornado missiles

Staff questions declarations that tornado and hurricane assessments are bounding

Status: Awaiting responses to RAls 19.1-165, 19.1-166, 19.1-167 and 19.1-169 Supplement 1 from GEH

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.1.6 PRA for Other Operational Modes

Technical Topics:

RCS vent capability in Modes 5 and 6
Capability of decay heat removal systems in Modes 4, 5 and 6

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19**

19.1.6 PRA for Other Operational Modes

Significant Open Items:

GEH needs to define Technical Specification for DPVs during Modes 5 and 6 w/vessel head on

- Awaiting response from GEH for RAI 19.1-143

Staff questions ability of Isolation Condenser to function effectively for some operational conditions in Mode 5

- Awaiting response from GEH for RAI 19.1-94 Supp. 1

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19**

19.1.6 PRA for Other Operational Modes

Significant Open Items (continued):

GEH must determine range of conditions (temperature and level) for which the RWCU/SDC can adequately remove decay heat in Modes 4, 5, and 6 (with the RPV head installed)

- response from GEH for RAI 19.1-96 Supplement 1 under staff review

Staff concerned that RWCU/SDC injection may by-pass the core due to inadequate mixing in downcomer

- response from GEH RAI 19.1-144 Supplement 1 under staff review

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19**

19.2 Severe Accidents

Technical Topics:

- 19.2.2 Severe Accident Prevention**
- 19.2.3 Severe Accident Mitigation**
- 19.2.4 Containment Performance Capability**
- 19.2.5 Accident Management**
- 19.2.6 Severe Accident Mitigation Design Alternatives**

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.2.3 Severe Accident Mitigation

Significant Open Items:

BiMAC performance test report

- Response to RAls 19.2-23 S02 and 19.2-25 S02 included a topical report documenting the results of the BiMAC tests.
- Topical report NEDE-33392 is currently under staff review

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.2.3 Severe Accident Mitigation

Significant Open Items:

Vacuum breaker performance

- Further information was requested on vacuum breaker design, coverage in DCD and ITAAC, and on emergency procedures related to failed vacuum breakers.
- Responses to RAls 19.2-6, 19.2-10, and 19.2-11 have recently been received and are acceptable.

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.2.4 Containment Performance Capability

Significant Open Items:

- Calculated upper drywell liner strain exceeds Level-C limit under conditions of 100% metal/water reaction
- Awaiting response from GEH for RAI 19.2-86
- Temperature boundary condition for drywell head in finite element model set incorrectly at 110 °F versus drywell air space temp of 500 °F
- Awaiting response from GEH for RAI 19.2-41 Supplement 2

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

19.2.5 Accident Management

Significant Open Items:

Description of the process for developing Severe Accident Guidelines

- The staff requested additional information on the process that will be used by GEH to develop the Severe Accident Guidelines (SAGs) in RAI 19.2.4-1 and its supplements.
- Response from GEH is under staff review

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19

Discussion / Questions



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 19A (SER Chapter 22)

Presented by
NRO/DNRL/NGE1 and NRO/DSRA/SPLB

June 3, 2008

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)

Purpose:

Brief the Subcommittee on the results of the staff's review of the ESBWR DCD application, Chapter 19A (SER Chapter 22)

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

Review Team for Chapter 19A (SER Chap. 22):

Lead Project Manager

- Rocky D. Foster, Project Manager

Lead Technical Reviewer

- Mark Caruso, Sr. Risk & Reliability Engineer

Technical Reviewers

- Eugene Eagle, Instrumentation and Controls Engineer
- Craig Harbuck, Sr. Operations Engineer
- Thomas Scarbrough, Sr. Mechanical Engineer
- Mohamed Shams, Structural Engineer
- David Shum, Sr. Reactor Systems Engineer
- George Thomas, Sr. Reactor Systems Engineer
- Harry Wagage, Sr. Reactor Engineer

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

Outline of Presentation:

**RAI Status Summary
Applicable Regulations
SER Technical Topics
Significant Open Items**

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

RAI Status Summary:

24 RAIs

16 RAIs Resolved

8 Open Items

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 19A (SER Chap. 22)

Regulatory Guidance:

SECY-94-084, "Policy and Technical Issues Associated with the Regulatory Treatment of Non-Safety Systems in Passive Plant Designs," dated March 28, 1994.

SECY-95-132, "Policy and Technical Issues Associated with the Regulatory Treatment of Non-Safety Systems in Passive Plant Designs," dated May 22, 1995.

SECY-96-128, "Policy and Key Technical Issues Pertaining to the Westinghouse AP600 Standardized Passive Reactor Design," dated February 18, 1997.

Regulatory Requirements:

10 CFR 50.36(c)(2)(ii) – Technical Specifications

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

**Regulatory Treatment of Non-Safety Systems
(RTNSS)**

CRITERIA FOR SELECTING RTNSS SSCs:

Non-safety SSC relied on to meet ATWS and SBO rules.

Non-safety SSC needed for core cooling, containment heat removal or control room habitability beyond 72 hours post accident.

Non-safety SSC that provides diagnostic info beyond 72 hours post accident.

Non-safety SSC relied on to meet Commission's safety goals

Non-safety SSC relied on to meet containment performance goals.

Non-safety SSC relied upon to prevent significant adverse interaction with passive safety system.

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

**Regulatory Treatment of Non-Safety
Systems**

Technical Topics of Interest:

- 22.5.1 Focused PRA
- 22.5.2 Containment Performance Assessment
- 22.5.3 Seismic Consideration
- 22.5.4 Beyond Design Basis Evaluation -ATWS/SBO
- 22.5.5 Adverse Systems Interaction
- 22.5.6 Post-72 Hours Actions and Equipment
- 22.5.7 Regulatory Treatment
- 22.5.8 Technical Specifications
- 22.5.9 Availability Controls

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

22.5.5 Adverse Systems Interaction

Significant Open Items:

Staff requested additional details to explain and clarify the systematic approach to evaluate adverse system interactions between passive and active systems.

- GEH response to RAI 22.5-17 Supplement 1 acceptable, issue is closed

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

**22.5.6 Post-72 Hours Actions and Equipment
Augmented Design Standards**

Significant Open Items:

Some SSCs needed for post-72 hour safety, housed in structures designed to a standard that may not guarantee functionality post-earthquake

- GEH response to RAI 22.5- 6 Supplement 1 under review

Additional information on structure design needed to enable the staff confirm RTNSS systems have been adequately protected from flood-related effects associated with both natural phenomena and system and component failures.

- Awaiting response to RAI 22.5-5 Supplement 1 from GEH

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)**

22.5.9 Availability Controls (AC)

Significant Open Items:

ACs did not state the associated instrumentation functions and the number of required divisions in the AC LCOs for some functions

- Awaiting GEH response to RAI 22.5-22

AC bases do not explicitly state the minimum level of system degradation that corresponds to a function being unavailable, or the number of divisions used to determine the test interval for each required division (or component) for AC surveillance requirements

- Awaiting GEH response to RAI 22.5-22

No AC Surveillance Requirements provided for FAPCS pumps

- Awaiting GEH response to RAI 22.5-23

AC LCOs for FAPCS and EDGs inconsistent with PRA assumptions

- Awaiting GEH response to RAI 22.5-24

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (SER Chap. 22)

Discussion / Questions