

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Subcommittee on Power Uprates

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, July 8, 2008

Work Order No.: NRC-2291

Pages 1-299

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

July 8, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on July 8, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)  
SUBCOMMITTEE ON POWER UPRATES

+ + + + +

TUESDAY, JULY 8, 2008

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

OPEN SESSION

The Subcommittee met in Open Session at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 9:00 a.m., John D. Sieber, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

- JOHN D. SIEBER, Chairman
- SAID ABDEL-KHALIK
- J. SAM ARMIJO
- SANJOY BANERJEE
- MARIO V. BONACA
- CHARLES BROWN
- OTTO L. MAYNARD
- WILLIAM SHACK
- JOHN STETKAR

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CONSULTANTS TO THE SUBCOMMITTEE PRESENT:

GRAHAM WALLIS

TOM KRESS

NRC STAFF PRESENT:

DAVID BESSETTE, Designated Federal Official

JOSEPH G. GIITTER, Director, NRR

JOHN G. LAMB, Senior Project Manager, NRR

BENJAMIN PARKS, NRR

SAMUEL MIRANDA, NRR

LEONARD WARD, Ph.D., NRR

AHSAN SALLMAN, NRR

SHEILA RAY, NRR

MATTHEW YODER, NRR



T-A-B-L-E O-F C-O-N-T-E-N-T-S

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Page

Introduction	4
Opening Remarks	6
Introduction	8
MPS3 SPU Overview	12
Fuel and Core	33
Safety Analysis . . . . .	74
Fuel and Safety Analysis, B. Parks . . . . .	198
Containment Analysis . . . . .	239
Containment Analysis, A. Sallman . . . . .	276
Public Comment . . . . .	282
Adjourn	

## P-R-O-C-E-E-D-I-N-G-S

8:58 a.m.

## 1. OPENING REMARKS

CHAIRMAN SIEBER: The meeting will now to come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, Power Upgrades Subcommittee. I'm Jack Sieber, Chairman of the Subcommittee. Subcommittee members in attendance are Said Abdel-Khalik, Sam Armijo, Mario Bonaca, Otto Maynard, John Stetkar and Charles Brown. We have several other members who are in another meeting that will be with us shortly and I'd also like to welcome our consultants, Dr. Tom Kress and Dr. Graham Wallis.

Our Designated Federal Official for this meeting is David Bessette. The purpose of today's meeting is to consider the license amendment application to increase power of Millstone Unit 3 by seven percent including the safety analysis performed by Dominion Power and its contractor and a safety evaluation by the NRR staff.

The Subcommittee will gather information, analyze relevant issues and facts and formulate proposed positions and actions as appropriate for deliberation by the full committee in September. Participation in today's meeting has been announced as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 part of the notice of this meeting previously  
2 published in the Federal Register. Portions of  
3 today's meeting may be closed for the discussion of  
4 proprietary information.

5 We have received no written comments.  
6 However, we do have a request for time to make an oral  
7 statement from a representative of the public group  
8 regarding today's meeting which we will accommodate at  
9 the end of today's proceedings.

10 A transcript of the meeting is being kept  
11 and will be made available as stated in the Federal  
12 Register notice. We request that participants in this  
13 meeting use one of the available microphones when  
14 addressing the Subcommittee. The speakers should  
15 first identify themselves and speak with sufficient  
16 clarity and volume so that they may be readily heard.

17 The matter under consideration today is  
18 the stretch power uprate of Millstone Power Station  
19 Unit No. 3. The Applicant submitted its request as a  
20 request for an amendment to the plant's technical  
21 specifications and the staff reviewed this application  
22 under Review Standard-001, Power Uprates. This  
23 process is not a new license nor is it a renewal of a  
24 license and therefore issues discussed under  
25 consideration at the operating license stage or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 renewal operating license stage are not germane here.  
2 However, matters that are to be discussed under Review  
3 Standard-001 are germane here.

4 I would like to introduce at this time  
5 Joseph Giitter, Director of the Division of Operating  
6 Reactor Licensing in the Office of Nuclear Reactor  
7 Regulation. Joe.

8 MR. GIITTER: Thank you, Dr. Sieber.

9 MEMBER MAYNARD: I'm sorry. Mr. Chairman,  
10 a clarification. I believe we're meeting in July, the  
11 July meeting.

12 CHAIRMAN SIEBER: Right.

13 MEMBER MAYNARD: I think tomorrow we --

14 CHAIRMAN SIEBER: Yes. Right.

15 2. INTRODUCTION

16 MR. GIITTER: Thank you, Dr. Sieber. I  
17 worked with many of you before when I was in the  
18 Office of Nuclear Material Safety and Safeguards on  
19 the mixed oxide fuel fabrication facility and I look  
20 forward to working with you in my new capacity.

21 As Dr. Sieber indicated, we are in the  
22 process of -- Excuse me. Dominion Nuclear Connecticut  
23 Incorporated or DNC submitted a license amendment  
24 request for approximately seven percent stretch power  
25 uprate or SPU as we call it on June 13, 2007 for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Millstone Power Station Unit No. 3. The proposed SPU  
2 would increase the maximum authorized power level of  
3 Millstone 3 from 3411 megawatts thermal to 3650  
4 megawatts thermal.

5 By memorandum from Frank Gillespie,  
6 Executive Director of ACRS, to Luis Reyes, then the  
7 Executive Director of Operations, dated April 23,  
8 2008, the ACRS decided to review the proposed SPU for  
9 Millstone 3.

10 As the next slide shows we have conducted  
11 a very thorough review. Over the next several hours,  
12 I believe you will hear how we conducted that review.  
13 We had frequent communications with the Licensee. We  
14 had conference calls, letters and meetings and I  
15 believe that the frequent and effective communications  
16 between the NRC and the Licensee substantially  
17 facilitated our review.

18 Finally, there were several rounds of  
19 requests for additional information or RAIs issued to  
20 the Licensee. The RAIs were submitted as they were  
21 developed allowing the Licensee as much time to review  
22 and respond to the RAIs in different technical areas  
23 and that's a little different than we sometimes do it.  
24 Some of the more challenging review areas that you'll  
25 hear about in the next few hours include the fuel and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 core design analysis and environmental qualification.

2 As presented in the safety evaluation  
3 which was provided to the ACRS on June 11, 2008, there  
4 are currently no open technical issues in the NRC  
5 staff review of DNC's proposed SPU. I'm pleased with  
6 the thoroughness of the review conducted by the NRC.  
7 The staff had extensive interactions with DNC on these  
8 technical issues and was very cooperative in answering  
9 our questions which I think has led to our success in  
10 completing our review on the time frame that we did.

11 At this point, I would like to turn over  
12 our discussion to our NRC Project Manager to my left,  
13 John Lamb who will introduce the discussions.

14 MR. LAMB: Good morning. My name is John  
15 Lamb. I'm the Senior Project Manager in NRR assigned  
16 to Millstone 3 SPU. As you know, we only gave you 26  
17 days to review the information. The staff realizes  
18 the significant burden this places on the ACRS  
19 members. On behalf of the staff, I would like to take  
20 this public opportunity to thank the ACRS for  
21 accommodating our schedule and reviewing the proposed  
22 SPU on a short turnaround. The staff greatly  
23 appreciates the ACRS members' efforts in this regard.

24 To quote the then ACRS member, Dr. Graham  
25 Wallis, at the NRC Commission meeting held on December

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 21, 2001, "one of our major activities right now and  
2 in the near future concerns applications for core  
3 power uprates and it's a very current topic. The  
4 impetus comes from the industry that sees considerable  
5 advantages to uprating the power and believes that  
6 they can do it safely. Many licensees are planning or  
7 have initiated these power uprates programs."

8 This statement by Dr. Wallis is as  
9 appropriate today as it was seven years ago. The  
10 staff's primary concern is safety. Our purpose is to  
11 convince you over the course of today that the staff's  
12 safety evaluation or SE for the Millstone Power  
13 Station Unit 3 SPU provides reasonable assurance that  
14 the health and safety of the public will not be  
15 endangered by operation of the proposed SPU. At the  
16 end of the day after hearing presentations from the  
17 staff and DNC, we hope that you agree with this and  
18 will recommend to the ACRS full committee on July 9,  
19 2008 that the proposed Millstone Power Station Unit 3  
20 SPU amendment be issued and reflect this in your  
21 letter report.

22 Before I go over the agenda, I would like  
23 to present some background information related to the  
24 staff's review of the proposed Millstone Power Station  
25 Unit 3 SPU. Millstone 3 is a Westinghouse 4-loop

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       pressurized water reactor or PWR. The proposed SPU  
2       would increase the maximum authorized thermal power  
3       from the current license thermal power level of 3,411  
4       megawatts thermal to 3,650 megawatts thermal. This  
5       represents an approximate seven percent increase from  
6       the current license thermal power.

7               On January 31, 1986, the NRC licensed  
8       Millstone 3 for full power operation at 3,411  
9       megawatts thermal. Millstone 3 has a renewed license.  
10       The ACRS reviewed the Millstone license renewal at its  
11       525<sup>th</sup> meeting and wrote a letter report dated  
12       September 22, 2005, recommending that the license  
13       renewal be approved. Millstone 3 license renewal was  
14       approved in October 2005 under NUREG 1838 titled  
15       "Safety Evaluation Report Related to the License  
16       Renewal of the Millstone Power Station Units 2 and 3."  
17       Millstone 3's renewed operating license now expires on  
18       November 25, 2045.

19               As far as the method of staff review,  
20       there is no specific guidance for SPUs since the staff  
21       has previously reviewed 61 SPUs and since there are no  
22       projected SPUs expected to be submitted to the NRC in  
23       the next five years, for the Millstone 3 SPU, the  
24       staff therefore used Review Standard-001, Review  
25       Standard for Extended Power Uprates as guidance along

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 with internal document, Power Uprate Guidance,  
2 provided by memorandum from Christopher P. Jackson of  
3 the NRC to the Special Projects Branch, NRC, dated  
4 February 6, 2006 as well as experience gained from  
5 previously approved Westinghouse SPUs such as Indian  
6 Point 2 and 3 and Seabrook. The review standard  
7 includes a safety evaluation template as well as  
8 matrices that correspond to maintenance areas that are  
9 to be reviewed by the staff as well as specific  
10 guidance and the acceptance criteria that apply to  
11 those review areas.

12 Provided ACRS writes a letter report that  
13 states the Millstone 3 SPU should be issued, DNC has  
14 requested that the staff issue the proposed SPU  
15 amendment by August 15, 2008. DNC plans to implement  
16 the proposed approximately seven percent Millstone 3  
17 SPU after completing the Fall 2008 refueling outage.

18 Basically, DNC's application followed the  
19 guidelines of Review Standard-001, Review Standard for  
20 Extended Power Uprates. DNC applied for an SPU by  
21 letter dated July 13, 2007. There were 33  
22 supplements. A majority of these dealt with responses  
23 to the 107 requests for additional information of the  
24 staff questions. The staff spent a great deal of time  
25 reviewing the fuel and safety analysis as well as the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 environmental qualification.

2 After I conclude my remarks, DNC will  
3 provide an overview of their licensing approach as  
4 well as their modifications required and their  
5 implementation schedule. This will be followed by  
6 presentations from the Licensee and the staff on the  
7 following topics: fuel and safety analysis,  
8 containment analyses, electrical and grid reliability  
9 and lastly, flow accelerated corrosion or FAC. The  
10 bulk of the agenda is devoted to fuel and safety  
11 analysis.

12 So this concludes my presentation as far  
13 as the introduction. I would like to turn it over to  
14 Mr. J. Alan Price, DNC Site Vice President for  
15 Millstone Power Station. This is a position Mr. Price  
16 has held since January 2002. Mr. Price has  
17 approximately 29 years of experience in commercial  
18 nuclear power operations. Here is Mr. Price.

19 CHAIRMAN SIEBER: While we are changing  
20 speakers, I'd like to say that Dr. Sanjoy Banerjee and  
21 Dr. Bill Shack has joined us as members of this  
22 Subcommittee.

23 3. MPS3 SPU OVERVIEW

24 MR. PRICE: Good morning. My name is Alan  
25 Price, Site Vice President for Millstone Power Station

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and accompanying me this morning is Mr. Ron Thomas.  
2 Ron is the Project Manager for the Stretch Power  
3 Uprate Project at Millstone Unit No. 3.

4 Thank you all for the opportunity to come  
5 in and make our presentation this morning and to  
6 answer any of the questions that the Subcommittee may  
7 have for us regarding our request.

8 As previously stated, Millstone Unit 3 is  
9 a 4-loop Westinghouse PWR. A few of the more  
10 significant historical milestones include a license  
11 for commercial operation in January 1986, the NRC  
12 approved a transfer of the operating license for  
13 Millstone 3 to Dominion in 2001, March 2001, and then  
14 in 2005 we received a license renewal approval. With  
15 the license renewal approval and examples of other  
16 utilities before us completing the power uprates, it  
17 was natural for us to consider the power uprate for  
18 Unit 3.

19 I would like to mention that increasing  
20 the power for Unit No. 3 by about 80 megawatts  
21 electric it provide much needed electrical capacity to  
22 ISO New England which is the transmission authority  
23 that serves our area of the United States.

24 As the Millstone Site Vice President, I'm  
25 ultimately responsible for the safe and reliable

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operation of the units. At the very beginning of this  
2 project, we established an oversight committee, much  
3 in the similar fashion that others have done before  
4 us. We meet monthly and I generally chair the  
5 meeting.

6 The members of our executive oversight  
7 committee for the power uprate project include the  
8 most senior managers of our station as well as the  
9 most senior managers of our corporate organization.  
10 Typically, we review the progress of the major  
11 milestones associated with the project and any areas  
12 that may require additional focus. We review how  
13 effectively we're using operating experience from  
14 others who have completed their power uprates and we  
15 have provided special focus and attention on how  
16 effectively we have managed the margins of our power  
17 station as we've considered uprating the unit.

18 We set an expectation early in the project  
19 to preserve and enhance margins whenever possible.  
20 Several of the topics that we'll explore in more  
21 detail with you all today will demonstrate how we have  
22 effectively achieved this goal.

23 What I'd like to do now is turn it over to  
24 Ron Thomas who will go through the details of the  
25 project and then Ron will turn it back over to me at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the end.

2 CHAIRMAN SIEBER: Thank you.

3 MR. PRICE: Yes sir.

4 MR. THOMAS: Thank you, Alan. My name is  
5 Ron Thomas. I'm been the Millstone Stretch Power  
6 Uprate Project Manager since the project kicked off in  
7 December of 2005. On the project team, when Dominion  
8 put together a project team, we took the approach that  
9 we did not want to do a turnkey operation that was  
10 solely performed by an outside company. Instead,  
11 Dominion assured that we have a significant project  
12 involvement and ownership so that we would end up with  
13 a robust margin management program and detailed in-  
14 house knowledge of all aspects of the project.

15 Of course, no utility has the resources or  
16 specialized subject matter experts to complete the  
17 effort by themselves. So we hired Shaw, Stone and  
18 Webster and Westinghouse to help lead us through the  
19 effort. These two companies have helped others at  
20 Seabrook, Comanche Peak, Ganay and Beaver Valley  
21 successfully complete their power uprate. They  
22 brought the operating experience of these power  
23 uprates and applied the OE to the Millstone Stretch  
24 Power Uprate.

25 CHAIRMAN SIEBER: Now the plants that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mentioned, some of those were at the same increase in  
2 power as Millstone. For example, Beaver Valley I  
3 think is seven percent also.

4 MR. THOMAS: In terms of percentage, yes.  
5 In terms of megawatts-thermal, the closest example  
6 would be Seabrook.

7 CHAIRMAN SIEBER: Yes. Okay.

8 MR. THOMAS: Let's see. A project team  
9 strength that we would like to point out is that we  
10 had a licensed senior reactor operator, SRO, as a  
11 full-time team member since the beginning of the  
12 project. The SRO was involved with the early analysis  
13 phase of the project, the licensing phase of the  
14 project and now the station modification and  
15 implementation phase of the project.

16 The licensed SRO was the focal point of  
17 the analysis portion to ensure that the Design  
18 Engineers did not unintentionally believe that there  
19 was sufficient margin on a system that Operations  
20 believed would cause a challenge for them to operate.  
21 In other words, the SRO made sure that the Design  
22 Engineers did not leave the Operations with components  
23 and systems that would be too difficult to operate at  
24 the new power level.

25 MEMBER SHACK: Now you have enough

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 capacity in your steam generator, right, because I  
2 know you haven't gotten a replacement? So you lose a  
3 tube you're --

4 MR. THOMAS: Correct. We do have excess  
5 capacity and excess margin in the steam generator.

6 MEMBER SIEBER: You have that now.

7 MR. THOMAS: And we looked at it for the  
8 full tube plugging that were analyzed for the remainder  
9 of the life of the power station.

10 CHAIRMAN SIEBER: Yes, that has some  
11 implication to Bill's question which is that your t  
12 hot temperature is something like 619 or 617 as I  
13 recall which is pretty hot for a t hot temperature.  
14 Have you consider that in the Alloy 600 issues in your  
15 plant and if you have, what have you done?

16 MR. PRICE: We have considered that as  
17 part of our application and when we get into some of  
18 the more detailed part of the discussion today, I  
19 think we'll be able to answer all of your questions.

20 CHAIRMAN SIEBER: Okay. But I still note  
21 that that's pretty hot for a reactor outlet  
22 temperature.

23 MEMBER MAYNARD: Are those thermally  
24 treated, the TT Alloy 600 or is that the conventional,  
25 the early version?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: They model that.

2 MEMBER MAYNARD: I'm interested in overall  
3 what the temperatures are going to end up. The 619 is  
4 consistent with the later model, Westinghouse PWR,  
5 large PWR.

6 CHAIRMAN SIEBER: Right.

7 MEMBER MAYNARD: That's 618, 619 is what  
8 most of them are operating at now. So I do think it's  
9 a good question for later as to exactly where we are  
10 getting the power and what the temperatures end up  
11 being there.

12 MR. THOMAS: We'll make sure that that  
13 topic is adequately covered in the technical brief  
14 later.

15 MEMBER MAYNARD: Okay.

16 MEMBER BROWN: Jack, one observation in  
17 their general overview of their license request or  
18 their uprate request, the analysis. It was they have  
19 a table in there that talks about core outlet and  
20 vessel outlet and the core outlets are like two 628 in  
21 a couple of cases and the vessel outlet is about 622,  
22 623. So just pointing out it's a little higher than  
23 the 618 to make the point.

24 CHAIRMAN SIEBER: Right. Pretty hot  
25 though.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER BROWN: Yes. Fairly toasty.

2 CHAIRMAN SIEBER: I guess the only reason  
3 why I bring that up is the nickel alloys are  
4 temperature sensitive and therefore the cracking and  
5 so forth that may go on accelerates this temperature  
6 acceleration. So that's a concern for me.

7 MR. PRICE: As part of our reviews for  
8 this project what we did pretty random analyses  
9 assuming a spectrum of t aves, and a spectrum of t  
10 colds and t hots. So what we've done is all of our  
11 analyses would be based on the worst case conditions.  
12 That does not necessarily mean that they would be the  
13 protocols that we would expect to operate.

14 MR. THOMAS: So we'll make sure that that  
15 question is specifically answered.

16 Another project team strength that I would  
17 like to point out is that we had a full-time engineer  
18 dedicated to margin management and operating  
19 experience. This engineer, Mr. Larry Salyards, helped  
20 guide the project team members as they prepared to  
21 review a system or a component by providing them with  
22 applicable operating experience from other power  
23 uprates. Then when the analysis was completed for any  
24 component or system, Larry would then ensure that the  
25 engineering documents contained a discussion of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 margin. In the examples we were just using with steam  
2 generator, he would look at that steam generator  
3 evaluation report, make sure that it clearly  
4 identifies what is the current margin with the full  
5 temperature swing that we're talking about that we  
6 could potentially operate within that t ave window and  
7 he would make sure it describes what is the current  
8 margin for that equipment, then what is the change in  
9 margin for that equipment at the new proposed power  
10 level of seven percent more power.

11 CHAIRMAN SIEBER: Do you have a margin  
12 manager all the time or just for the power uprate?

13 MR. THOMAS: We do have a -- Millstone  
14 does have a margin management program. It's a program  
15 that existed prior to us starting the project. What  
16 we did, that program was what I'll characterize as a  
17 small program with certain focus topics in which there  
18 was adequate industry information and adequate  
19 information at the power station.

20 What we've done is with a full-time margin  
21 management individual, he worked with the program  
22 owners and the individuals with that team and he met  
23 with them and brought to them every margin  
24 identifications we did and every changes in margin  
25 that we performed. So he and our team and our project

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is leaving behind a better, well-defined margin  
2 management program and leaves us with more knowledge  
3 of how the power station operates today in addition to  
4 how it's going to operate with the power level. So  
5 we've enhanced the knowledge of the power station.

6 CHAIRMAN SIEBER: I think that's important  
7 and I wish all plants, and I don't know that they  
8 don't, but I wish all plants had a margin manager  
9 because middle managers and engineers have a tendency  
10 to what to use the margin and if too different bodies  
11 are using the same margin, you have potentially some  
12 safety issues. I'm pleased that you have that.

13 MEMBER MAYNARD: One of the things I'll be  
14 interested in when we get into talking about some of  
15 the margins is how much of it is through the more  
16 detailed analysis versus how much of it is either  
17 through plant modifications or operating parameters  
18 that maintain the margin.

19 MR. THOMAS: And we will be covering some  
20 of these topics during the presentations that we have  
21 and certainly ask the individual doing the  
22 presentation related to margin specifically and we  
23 have slides that will describe what is the current  
24 value, what's the limit and then what is it going to  
25 be with the new proposed power level.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So that was one of our legacies that we  
2 did want to leave behind. If nothing else, we wanted  
3 to leave behind the best margin management program in  
4 the industry and I believe we've achieved that  
5 objective.

6           License core power level, today Millstone  
7 3 is operating at its original 1986 license core power  
8 level of 3411 megawatts thermal. In the past 22 years  
9 of safe operation at Millstone 3, we have observed  
10 that the NRC has approved over 120 power uprates in  
11 the industry and 23 power uprates for our peer 4-loop  
12 Westinghouse units.

13           Half of those peer uprates were at  
14 measurement uncertainty recapture, MUR power uprates,  
15 and half were stretch power uprates, SPUs. Some of  
16 these units were approved for both MURs and SPUs.

17           More than five years ago we began to  
18 explore the concept of a power uprate. At that time,  
19 we installed an ultrasonic flow meter to more  
20 accurately measure reactor power level. We installed  
21 a system which allows up to a 1.7 measurement  
22 uncertainty recapture, MUR, power uprate.

23           As we studied the margins available on the  
24 primary and secondary sides of the power station, we  
25 realized that we had much more margin available than

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 we expected. We determined that almost all components  
2 and systems had so much margin that we could easily  
3 and safely implement a seven percent power uprate  
4 while maintaining adequate operating margin without  
5 replacing any major components. The limiting  
6 component was the electrical generator and we'll hear  
7 more about that later today. It needs to be replaced  
8 or modified if we were to desire to increase the  
9 reactor power level beyond seven percent.

10 CHAIRMAN SIEBER: Why did you decide to  
11 replace the main feed pump turbine? The capacity or -

12 -  
13 MR. PRICE: I'll be happy to talk about  
14 that right now if you would like. When we looked at  
15 the increased flow required for the power uprate and  
16 we started looking at the weak links in the system the  
17 steam turbine for the main feed pumps became the weak  
18 link. We had an option of doing additional welding on  
19 the first stage steam turbine blades. That would have  
20 given us the margin we were looking for.

21 CHAIRMAN SIEBER: I thought you --

22 MR. PRICE: But we decided to not pursue  
23 that option. Instead we went with the OEM and we  
24 decided to purchase new steam turbines to give us the  
25 operating margin that we were looking for.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN SIEBER: So these are complete  
2 turbines and not new internals.

3 MR. PRICE: These are the new turbines for  
4 the main feed pumps. That's correct.

5 CHAIRMAN SIEBER: They were run at a  
6 higher speed.

7 MR. PRICE: That is correct.

8 CHAIRMAN SIEBER: By -- The old ones are  
9 4700 or 4800 rpm.

10 MR. PRICE: Yes.

11 CHAIRMAN SIEBER: And the new ones are  
12 5100.

13 MR. PRICE: That is correct and they are  
14 already on site and ready for installation this fall.

15 CHAIRMAN SIEBER: Right, and you're going  
16 to do all the standard things like checking alignment  
17 and measuring vibration and all that stuff when you  
18 start up.

19 MR. PRICE: Yes sir. That's correct.

20 CHAIRMAN SIEBER: Okay.

21 MR. THOMAS: And that's an example of  
22 where we saw a reduced margin that we could have  
23 worked around but we wanted to improve the margin as  
24 much as possible and went with new equipment.

25 So we began a 15-month analysis effort to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 confirm the seven percent potential assumption. The  
2 results of that detailed analysis concluded that seven  
3 percent was the correct selection for the new power  
4 level for Millstone 3.

5 . CHAIRMAN SIEBER: I have another question  
6 that relates to the feedwater system. Since you're  
7 using steam turbines, the signal that tells how much  
8 feedwater demand there should be goes to the turbine  
9 throttle valves and your feedwater regulating valves  
10 essentially maintain constant differential pressure.

11 MR. PRICE: Yes sir.

12 CHAIRMAN SIEBER: Is that the case?

13 MR. PRICE: Yes sir.

14 CHAIRMAN SIEBER: Okay.

15 MR. PRICE: And as part of the  
16 modifications that we'll be making to the plant will  
17 be the rescaling of those components on the secondary  
18 side, the main feed as well as the main steam and the  
19 steam dump systems.

20 CHAIRMAN SIEBER: Do you plan to change  
21 the trim in the feedwater regulating valves or is what  
22 you have good enough?

23 MR. PRICE: What we have is sufficient.

24 CHAIRMAN SIEBER: Usually with electric  
25 pumps, you end up with problems with the feed reg

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 valves. Steam driven pumps usually don't have that  
2 problem.

3 MR. PRICE: Yes sir.

4 MR. THOMAS: Once we understood the  
5 potential power level for Millstone 3, it became a  
6 matter of determining the licensing strategy, to  
7 reapply apply for an MUR followed by an SPU like  
8 Comanche Peak or should we apply for an SPU followed  
9 by an MUR like Seabrook? We decided on a single step  
10 approach applying for a new power level in a single  
11 stretch power uprate license amendment request.

12 We did retain the two percent uncertainty  
13 margin in determining reactor power level. So we are  
14 not asking for a combined approval of an MUR and an  
15 SPU. This is just an SPU. We do not intend to ask  
16 for an MUR in the near future and that is because we  
17 have a limiting component at the electrical generator  
18 that we'll hear more details about later and because  
19 of that limiting component, even for an MUR, we would  
20 have to replace that component or modify.

21 (Simultaneous conversations.)

22 CHAIRMAN SIEBER: What about the rest of  
23 your electrical system and grid system as far as  
24 stability is concerned? Is that all sized probably  
25 for --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. PRICE: Yes sir.

2 MR. THOMAS: Yes sir and --

3 CHAIRMAN SIEBER: I noticed that in your  
4 discussion in the SER it said that you improved your  
5 process for the uprate that really made your  
6 improvement at the voltage at that end of the system.  
7 Correct?

8 MR. THOMAS: We do have a topic  
9 specifically for electrical power and the electrical  
10 generator that is coming up.

11 CHAIRMAN SIEBER: I might save my  
12 questions for that.

13 MR. THOMAS: The best person to ask that  
14 are the two subject matter experts that I'm bringing  
15 up here later.

16 CHAIRMAN SIEBER: -- ask people who --

17 (Laughter.)

18 MR. THOMAS: Selecting the new power level  
19 was based on Operations' input. An engineering  
20 analysis showed no major modifications were necessary  
21 up to 100 percent above the current power level at  
22 3650 megawatts thermal. Most of the station  
23 modifications that are necessary to achieve the new  
24 power level are changes to the licensing design basis  
25 document, the document design calculations, design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 drawings and operating procedures.

2 DR. WALLIS: Can I ask if you have any  
3 idea how much of an increase in power you could get by  
4 changing the generator with the existing system? Do  
5 you have any idea what that would be?

6 MR. PRICE: Is your question what would  
7 our next most limiting component be?

8 DR. WALLIS: Yes and how much power would  
9 that get you?

10 MR. PRICE: I don't know the answer to  
11 that question.

12 MR. THOMAS: I can answer that question  
13 later during the day.

14 DR. WALLIS: It must be tempting to go  
15 after this measurement uncertainty.

16 CHAIRMAN SIEBER: It's a lot of money.

17 MR. PRICE: It would be if we were  
18 prepared to replace the new generator at this time  
19 which we're not.

20 DR. WALLIS: Right. I just wonder how  
21 much that the nuclear end of it could stand in terms  
22 of an uprate.

23 MEMBER ARMIJO: Is the limitation to the  
24 main generator, the turbine or condenser or the  
25 generator itself.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PRICE: Right now, the limiting  
2 component is the main generator.

3 CHAIRMAN SIEBER: So you will actually be  
4 controlling power on the basis of current flow and  
5 temperatures in the generator. That will be your  
6 summer limit.

7 MR. PRICE: Basically, that's one way to  
8 look at it.

9 CHAIRMAN SIEBER: As opposed to condenser  
10 vacuum or --

11 MR. PRICE: Yes sir. That's one way to  
12 look at it.

13 MEMBER BANERJEE: With regards to this  
14 plant, is it critical heat flux limited or LOCA  
15 limited? All levels.

16 MR. THOMAS: We'll leave that for our  
17 subject matter experts that are coming up later.

18 CHAIRMAN SIEBER: Which is after the  
19 break.

20 MR. THOMAS: With that, Alan, do you have  
21 any final comments?

22 MR. PRICE: I do. I know that the  
23 Committee will be interested in some of the changes  
24 that we'll be making for the power uprate, the  
25 proposed power uprate. We've already talked about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 most significant hardware change which is the main  
2 feed pump steam turbines. In addition, we're making  
3 a number of changes in some of our safety systems. An  
4 excellent example is the logic change that we have  
5 proposed in our emergency core cooling system. We  
6 plan to implement a new permissive, P19, that will  
7 provide additional protection for the inadvertent  
8 pressurizer overfill on a spurious safety injection  
9 and we'll get to that in more detail as the technical  
10 part of the presentations continue.

11 Also we're making a modification to our  
12 control building emergency filtration unit. This  
13 takes out of the question operator reaction post fuel  
14 handling accident and puts an automatic system in our  
15 control building fuel ventilation system. We're  
16 making a variety of set point and scaling changes for  
17 the feed pumps' feed control, pressurizer level  
18 program, turbine generator controls, steam dump and  
19 load reject controls and the like. But as we've  
20 indicated before, right now the most major physical  
21 plant change is the main feed pump turbines.

22 CHAIRMAN SIEBER: So other than rescaling  
23 some instruments on your control panel and changing  
24 some set points here and there and some of the logic,  
25 you aren't making any changes to the layout of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 control room instrumentation and controls.

2 MR. PRICE: Yes sir. That's correct. Now  
3 we are replacing our main transformers onsite. That  
4 was not part of the power uprate project. It was  
5 because the main transformers are greater than 20  
6 years old. We're watching the OE from the industry.  
7 We wanted to stay ahead of the transformer failures  
8 that others are seeing. So we are replacing our  
9 transformers. We're going to three single phase with  
10 an installed spare and they are all sized to handle  
11 this power uprate and beyond.

12 CHAIRMAN SIEBER: What's your current  
13 transformer? All three phases and one can?

14 MR. PRICE: What we have is we have two  
15 transformers, main step-up transformers, for Unit 3.  
16 Each are about 60 percent and each of those two  
17 transformers or both of those two transformers are  
18 three phase units.

19 CHAIRMAN SIEBER: Elevated gas levels in  
20 the oil of either one of them?

21 MR. PRICE: Yes sir. That's part of the  
22 impetus for us to replace the transformers. So we  
23 will be taking ownership of the new transformers in  
24 September of this year.

25 CHAIRMAN SIEBER: How much of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 switchyard do you own, those transformers and the  
2 circuit breakers and your station service buses?

3 MR. PRICE: We own from the house side of  
4 our transformers to the switchyard.

5 CHAIRMAN SIEBER: Okay.

6 MEMBER ARMIJO: Another modification and  
7 I'm sure you'll get into this later is the rod control  
8 system logic. You're taking out the automatic rod  
9 withdrawal.

10 MR. THOMAS: That is correct.

11 CHAIRMAN SIEBER: I'm sure you'll discuss  
12 that later, too.

13 MR. PRICE: Yes, sir. We will.

14 CHAIRMAN SIEBER: Everybody has done that.

15 MR. PRICE: So I trust some of the  
16 examples that we've talked about provide an adequate  
17 overview of the type of modifications that we'll be  
18 proposing for our power station.

19 Mr. Chairman, that does conclude our  
20 overview presentation and we do recognize that since  
21 we are not going for the extended power uprate, it's  
22 not part of the normal business for you all to take a  
23 look at our power ascension testing. We do have a  
24 presentation prepared to address those questions if  
25 you would like for us to do those and throughout the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 day we'll be happy to accommodate that. You can  
2 request it anytime.

3 CHAIRMAN SIEBER: Thank you very much.

4 MR. PRICE: Yes, sir.

5 CHAIRMAN SIEBER: According to the  
6 schedule, we would take a break now. But I think it's  
7 too early to do that. On the other hand, the next  
8 topic is Fuel and Core which is a 45 minute  
9 presentation. I think we can get it in.

10 MEMBER SHACK: I think we'll catch up with  
11 the schedule.

12 CHAIRMAN SIEBER: Sooner or later. Thank  
13 you very much and let's have the other -- We'll take  
14 a break later.

15 4. FUEL AND CORE

16 MR. KAI: Good morning. My name is Mike  
17 Kai. I'm a Principal Engineer at Dominion. I've  
18 worked in Safety Analysis since 1970, a long time.  
19 I'm going to go over the fuel and safety analysis.  
20 First, I would like to introduce my partners here.  
21 Albert Gharakhanian is the Engineer who worked on the  
22 containment analysis, did most of the containment  
23 analysis and coordinated the containment analysis  
24 effort and Sandy Andre who is our contractor from  
25 Westinghouse who was responsible for the transient

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 analysis. So hopefully between the two of us, we will  
2 be able to answer any questions.

3 I did try to take some notes of things  
4 that you wanted to bring up. I believe they're all  
5 covered in my presentation, but please don't hesitate  
6 to ask.

7 CHAIRMAN SIEBER: You can count on us.

8 MR. KAI: Okay. The other thing I'd like  
9 to say is how I set up my presentation. There's a lot  
10 of information in it, a lot of numbers, a lot of  
11 results. I did not intend to go over each item. I  
12 will try to highlight what I think is significant.  
13 But please feel free to ask about anything that's on  
14 the slide. Okay. Any questions?

15 (No verbal response.)

16 This slide just shows what I'm going to  
17 cover. So there's an outline of my presentation and  
18 I think I'll just skip directly to the fuel design.

19 The thing about the fuel I think to  
20 understand is that we have not changed the fuel  
21 design. We're actually going to go with what's our  
22 current fuel system that we're using and actually add  
23 our SPU power level, we have a full core of RFA-2  
24 fuel. So we have no mixed core issues. That clearly  
25 simplified our analysis and we have experience with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the fuel assemblies. So in general, I foresee no fuel  
2 issues.

3 DR. WALLIS: Did you change the burn-up or  
4 anything? What did you change?

5 MR. KAI: We are increasing the feed and  
6 that's how we're getting extra energy and we have a  
7 little slide that shows what we're doing. But burn-up  
8 is unchanged. We're achieving the extra energy by  
9 adding --

10 CHAIRMAN SIEBER: More assemblage.

11 MR. KAI: More assemblies. We're not  
12 really going to have what you would call transition  
13 questions. This is going to be like our normal cycle  
14 of fuel replacement.

15 CHAIRMAN SIEBER: This is Westinghouse 17  
16 X 17 fuel.

17 MR. KAI: Right. This one is 17 X 17.

18 CHAIRMAN SIEBER: That's what's in the  
19 core now.

20 MR. KAI: That's correct.

21 CHAIRMAN SIEBER: That's what your  
22 transition core will be.

23 MR. KAI: Yes. Correct.

24 CHAIRMAN SIEBER: Okay. Beyond that  
25 you're not -- Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER BANERJEE: And you have the zero  
2 cladding.

3                   MR. KAI: That's correct. Zero cladding.

4                   CHAIRMAN SIEBER: One thing I would point  
5 out while we're discussing the fuel and core design is  
6 that every reactor at every refueling has to prepare  
7 a reload safety analysis which is sent into the NRC  
8 that's specific to the core that will be started up  
9 after that refueling outage. So when we discuss  
10 transition and equilibrium cores here, we're not  
11 exactly talking about the same core as the reload  
12 safety analysis core because that analysis will be  
13 done separately and probably in more detail.

14                   What we're doing here is putting in a  
15 typical core design to determine what kind of margins  
16 there will be and where the close spots are.

17                   MEMBER ARMIJO: Well, this core has been -  
18 - you're going to put in -- You must have ordered the  
19 fuel for the reload coming up in September.

20                   CHAIRMAN SIEBER: Correct.

21                   MEMBER ARMIJO: So it may be even  
22 delivered. I don't know. But now is it -- The point  
23 I want to ask is is it really identical to the fuel in  
24 there?

25                   MR. KAI: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: You know, because  
2 cladding, wall thickness, gap.

3 MR. KAI: Everything.

4 MEMBER ARMIJO: -- volume, pellet density,  
5 all of those things. You're not changing that at all.

6 MR. KAI: Correct. No fuel design change  
7 at all. No physical changes to fuel at all.

8 MEMBER ARMIJO: And you're increasing the  
9 number of burnable rods, the number of burnable  
10 assemblies.

11 MR. KAI: Yes, we are going to increase --  
12 We're going to replace more assemblies. We'll get to  
13 that. I'll show you that.

14 MEMBER ARMIJO: Okay. When we get to  
15 that, I'll just hold off on that.

16 MR. KAI: We will also be adding more the  
17 integral fuel burnable poisons to control reactor  
18 activity. So really what we have is really a core  
19 that is essentially the same as what we have now.

20 MEMBER ARMIJO: You know, I'm getting that  
21 you're not going outside of your experience base --

22 MR. KAI: Correct.

23 MEMBER ARMIJO: -- for the existing fuel.

24 MEMBER BONACA: How many assemblies are  
25 you going to replace?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: That's on slide six but it's  
2 between 80 and 84. Right now, we do 72 to 76. So  
3 we're going to go about eight more assemblies.

4 MEMBER BANERJEE: So this is going to give  
5 you a flatter power distribution.

6 MR. KAI: Yes and that is actually the  
7 next bullet which talks about reducing the real  
8 peaking factor. So it will help a little bit.

9 DR. KRESS: You are increasing the linear  
10 heating rate in the fuel. How does that change the  
11 thermal gradient between midpoint and the top of the  
12 core?

13 MR. KAI: You mean actually? Because the  
14 rating part, yes. You would still be bounded. The  
15 average power will go up obviously because it's  
16 average. But the actual power distributions are  
17 essentially the same. They're not expected to change.

18 MEMBER BANERJEE: It will be simply more  
19 fuel --

20 MR. KAI: It will simply be more fuel.  
21 Correct.

22 MEMBER ARMIJO: But you do have to  
23 increase the peak in your heat generation rate and I  
24 couldn't find that number in the materials.

25 MR. KAI: That's in slide six.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: The application says  
2 you're going to flatten it, too.

3 (Simultaneous conversations.)

4 MEMBER ARMIJO: The average linear will go  
5 up, that means the peak has to go up and that's what  
6 I would like to know. What does the --

7 MR. KAI: The shape will be the same. But  
8 you're right. The actual magnitude of the peak would  
9 be higher.

10 PARTICIPANT: How do you calculate the  
11 effect of borate consumption on the clad? How do you  
12 calculate the effect of the changed temperature  
13 distribution on the boric acid absorption in the top  
14 part of the core?

15 MR. KAI: I don't think there's going to  
16 be any change.

17 PARTICIPANT: There must be a reason for  
18 you to think that.

19 MR. KAI: I don't -- I mean I know this is  
20 not my area. So I guess we'll take that note and I'll  
21 get back to you. But we have -- I was going to have  
22 our internal fuel experts go through and do a pretty  
23 comprehensive design of the fuel itself to make sure  
24 that such things as boric interactions with the fuel  
25 would be bounded.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: If you increase power,  
2 you obviously have to -- The initial boron  
3 concentration has to change and go up because you're  
4 suppressing more.

5 MR. KAI: Absolutely. That's not correct.

6 (Simultaneous conversations.)

7 Boron is actually going to go down.

8 PARTICIPANT: It seems to me that the  
9 temperature is necessarily higher here and it seems to  
10 me that the absorption of borate on the zirconium  
11 dioxide is a function of temperature and so you're  
12 going to have more absorption of borate on the top  
13 half of the core. I want to know how they calculated  
14 that and he tells me that they did a comprehensive  
15 analysis and a bounding. I would like to see the  
16 details on that analysis.

17 MR. KAI: Okay.

18 PARTICIPANT: Because I had no --

19 MR. KAI: Now I understand where you're  
20 going.

21 CHAIRMAN SIEBER: At the risk of going out  
22 of bounds from your schedule here, I'd like to ask  
23 this question. You've made some statements about this  
24 core and you've made some statements about the neutron  
25 fluence to the vessel walls.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Some of the statements you've made about  
2           the core is that you're going to flatten the core.  
3           That's statement one. Secondly, you're going to  
4           maintain a low leakage core and I'm not sure how you  
5           flatten it and do that. Then you're going to do the  
6           calculations for neutron fluence to the vessel walls.  
7           You have taken account of the seven percent increase  
8           in power but you have not taken account of any change  
9           in the flux shape. For example, if you flatten the  
10          core, the edges will produce more neutrons and  
11          therefore you will irradiate the wall more than you  
12          would if you just grazed everything by seven percent  
13          and my question is by really flattening the core, are  
14          you really going to maintain a low leakage core and if  
15          so, can you tell me that the neutron fluence to the  
16          vessel wall is only affected by the power level and  
17          not affected by the power --

18                   MR.: The distribution.

19                   CHAIRMAN SIEBER: -- the flux shape in the  
20          core. Do you understand my question?

21                   MR. KAI: Yes. I understand.

22                   CHAIRMAN SIEBER: Okay.

23                   MR. KAI: And actually the next bullet on  
24          -- If we go back talking about fluence basically what  
25          you said is correct. With an uprate, you would get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 increased fluence. But one of the advantages that we  
2 have was that we had removed a surveillance capsule.  
3 Our previous prediction --

4 CHAIRMAN SIEBER: I forgot that. You have  
5 three left.

6 MR. KAI: Right, and we benchmarked our  
7 fluence counts and actually the net result is the  
8 calculated fluence action goes down when we get to  
9 what we projected.

10 CHAIRMAN SIEBER: You got some margin out  
11 of the third capsule.

12 MR. KAI: Correct.

13 CHAIRMAN SIEBER: But that's not my  
14 question. Okay.

15 MR. KAI: Yes.

16 CHAIRMAN SIEBER: My question is how did  
17 you account for the change in flux shape in the  
18 fluence calculation for, what, the next 30 years of  
19 operation.

20 MR. KAI: We assumed that we would operate  
21 at this equilibrium power distribution that we use as  
22 our basis for fluence --

23 CHAIRMAN SIEBER: You're assuming the  
24 power distribution is the same as it is today.

25 MR. KAI: Well, no.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN SIEBER: I hope not.

2 MR. KAI: We use the core --

3 CHAIRMAN SIEBER: It's not the fluence  
4 level. The fluence level is up by seven percent.

5 MR. KAI: Right.

6 MEMBER BANERJEE: I guess the answer is  
7 have you taken into account in the fluence  
8 calculations that the core is going to be flatter.

9 MEMBER SHACK: You have I presume.

10 MR. KAI: Yes. Correct. We have. And  
11 the fluence calculation is going to be redone.

12 DR. KRESS: I think Jack's question boils  
13 down to is the fluence in the SPU's condition going  
14 to, at the vessel wall, going to increase by seven  
15 percent or more and I think it should increase by  
16 more. It may be small.

17 CHAIRMAN SIEBER: That's what I thought  
18 too. But it's not in the applications. It mentions  
19 all these facts, but it doesn't reach a conclusion.

20 MR. KAI: And that's because on top of the  
21 FAC, yes. We didn't do a way to do apples and apples  
22 is what you're saying because we also got in the  
23 fluence calc the impact of the surveillance calc. So  
24 when you put it all together at the end, what you end  
25 up is a lower fluence which though if you had done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that before would have shown -- I mean, I understand  
2 what you're saying, but we didn't do the --

3 CHAIRMAN SIEBER: Yes, I know you didn't.

4 DR. WALLIS: But you could say the real  
5 fluence is going up, but the calculated fluence isn't  
6 because of the way you calculated it.

7 MR. KAI: Exactly.

8 DR. WALLIS: The extra information you  
9 have.

10 CHAIRMAN SIEBER: Then they came out and  
11 said that we're okay because you got margin out of the  
12 third capsule and I don't know how much of that margin  
13 you're using up.

14 MR. KAI: Right. That's correct. I don't  
15 have that information.

16 CHAIRMAN SIEBER: Do you have graphs of  
17 the old flux shape versus the new flux shape  
18 somewhere?

19 MR. KAI: Yes, we do.

20 CHAIRMAN SIEBER: Okay. It would be a  
21 good thing for us to look at tomorrow.

22 MR. KAI: Yes.

23 CHAIRMAN SIEBER: If you can come up with  
24 that. If they are superimposed and we can see what  
25 happens to the tail ends and by how much.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. KAI: Okay. Well, I don't have it  
2 physically now. I will get back to you on that.

3 CHAIRMAN SIEBER: Okay. I consider that  
4 one of the important issues.

5 MR. KAI: Okay.

6 CHAIRMAN SIEBER: Okay.

7 MEMBER BANERJEE: And clearly, you know,  
8 it impacts your fourth bullet that reduction in  
9 peaking pressure leads to design limit.

10 MR. KAI: It's a design limit. Keep in  
11 mind that this is a design change which means that the  
12 actual core obviously is well below the design limit.  
13 We just reduced the margin on the design limit in  
14 order to gain the other margins. So what our core  
15 design is --

16 MEMBER BANERJEE: I understand the design.  
17 It's just that it would be nice to have a really small  
18 quantificative idea first.

19 CHAIRMAN SIEBER: That was one of the  
20 problems I had with the application and the SER is  
21 that there weren't a lot of numbers. So there wasn't  
22 too much for me to work on as far as seeing exactly  
23 what it is you're doing.

24 MEMBER BANERJEE: There's a lot of  
25 different --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN SIEBER:     I'm sure there's  
2     proprietary information there.

3                   MR. KAI:     Yes.

4                   CHAIRMAN SIEBER:     Sooner or later we're  
5     going to get to at least the answers that we need to  
6     have.   Okay.

7                   MR. KAI:     Okay.   The next slide really  
8     tries to show what I said before is that we've not  
9     changed the fuel design at all.   We're saying the same  
10    enrichment.     The LOCA design parameters are  
11    essentially unchanged other than like I said when we  
12    decreased the allowable rate of peaking factor.

13                   MEMBER ABDEL-KHALIK:   What is your peak P-  
14    bar?

15                   I mean, the average bundle power.

16                   MEMBER BANERJEE:   It goes up.   It has to.

17                   CHAIRMAN SIEBER:     Usually you look for the  
18    hot rod.

19                   MR. KAI:     I mean, I can round up the  
20    average kilowatts per foot.

21                   CHAIRMAN SIEBER:     No.

22                   MEMBER ABDEL-KHALIK:   What is the peak  
23    bundle power divided by the average bundle power?

24                   MR. KAI:     I don't have that number off the  
25    top of my head.   I'll have to get that to you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. GUERCI: I'm John Guerci, Manager of  
2 Fuel. Our peak P-bars are approximately 1.3.

3 CHAIRMAN SIEBER: Okay.

4 MEMBER ABDEL-KHALIK: 1.30.

5 MR. GUERCI: .1.30, that's correct.

6 MEMBER ABDEL-KHALIK: But what is your  
7 core duty index at the higher power? Core duty. They  
8 are increasing t ave. They're increasing power. Your  
9 core flow remains unchanged? So could you give us  
10 sort of a feel for how this plant at the higher power  
11 level would compare to other 4-loop Westinghouse  
12 plants in terms of core duty index?

13 MR. KAI: Okay. With that, I will discuss  
14 about temperature later.

15 MEMBER ABDEL-KHALIK: But it's more than  
16 temperature.

17 MR. KAI: Yes.

18 MEMBER ABDEL-KHALIK: But do you know what  
19 the core duty index is?

20 MR. GUERCI: Excuse me. Are we referring  
21 to the EPRI core duty index?

22 MEMBER ABDEL-KHALIK: Right.

23 MR. GUERCI: Yes, I don't have the number  
24 right with me. I understand the question. The core  
25 duty index could be similar to the Seabrook Power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Station with our power levels and our temperatures.

2 MEMBER ABDEL-KHALIK: Would your plant be  
3 considered a high duty index, a medium or low at the  
4 higher power level?

5 MR. GUERCI: We took it to be a high duty  
6 index plant.

7 MEMBER ABDEL-KHALIK: It would be a good  
8 idea to have quantitative answers to these questions.

9 MR. GUERCI: I understand.

10 MR. KAI: Understand.

11 MEMBER ABDEL-KHALIK: Thank you.

12 MEMBER BANERJEE: Said, why don't you  
13 define the core duty index?

14 MEMBER ABDEL-KHALIK: It's a function of  
15 bundle power, flow rate. It's also dependent on t  
16 ave, in other words, subcooling. It would give an  
17 indication of how much subcooled boiling you have in  
18 the upper half of the core and therefore it's an  
19 indication of how much boron precipitation you would  
20 have in the upper half of the core.

21 MR. GUERCI: Okay. Right. So yes, it  
22 would be a high duty plant. Okay. I understand what  
23 you're asking. I don't have the quantitative number.

24 MEMBER ABDEL-KHALIK: Would you be able to  
25 provide that sometime later today?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. GUERCI: Yes. We'll get that for you  
2 later today.

3 MEMBER ABDEL-KHALIK: Thank you.

4 MEMBER BONACA: Do we have an  
5 understanding? Does the Licensee have an  
6 understanding of the algorithm you're talking about?

7 MEMBER ABDEL-KHALIK: They should be able  
8 to. It's a fairly straightforward definition.

9 DR. WALLIS: Is this a moderated  
10 temperature coefficient?

11 CHAIRMAN SIEBER: Yes.

12 DR. WALLIS: Moderated temperature?

13 CHAIRMAN SIEBER: Yes.

14 MR. KAI: Okay. The next slide gives a  
15 comparison of the nuclear design parameters, the  
16 average kilowatts per foot. You can see it  
17 decreasing. It also shows that you will be replacing  
18 --

19 MEMBER ABDEL-KHALIK: Can we go back to  
20 the previous slide?

21 MR. KAI: Sure.

22 MEMBER ABDEL-KHALIK: Your most positive  
23 MPC greater than 70 percent power is zero. What is  
24 your peak pressure for loss of feedwater ATWS at  
25 beginning of cycle?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: I don't know off the top of my  
2 head, but we had -- We've done ATWS, loss of feed.  
3 She'll look it up for me and we are below the  
4 acceptance criteria for -- We're below the generic  
5 analysis that had been done for ATWS.

6 MEMBER ABDEL-KHALIK: Again, it would be  
7 nice to have quantitative answers.

8 MS. ANDRE: I'll find it here.

9 MR. KAI: Okay. Anything else? I'll  
10 continue.

11 Okay. Any other questions about the fuel?

12 MEMBER ARMIJO: Yes, I still want to get  
13 a number for the increase in peak power, peak linear,  
14 heat generation rate. You're increasing your average.  
15 But do you increase the peak power on these rods? And  
16 what's that number? Is it half a kilowatt a foot or  
17 what?

18 CHAIRMAN SIEBER: How do you want that in  
19 percent?

20 MEMBER ABDEL-KHALIK: Kilowatts per foot  
21 increase Delta.

22 CHAIRMAN SIEBER: Okay.

23 MR. KAI: So you want the --

24 CHAIRMAN SIEBER: For the peak assignment.

25 MR. KAI: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER BROWN: Can I ask one question back  
2 to the previous slide? You talked about the MP3. I'm  
3 not familiar. I'm new from that standpoint. Is that  
4 a moderator temperature coefficient?

5 MR. KAI: Yes, that's correct.

6 MEMBER BROWN: And it's positive as  
7 opposed to negative.

8 CHAIRMAN SIEBER: Yes.

9 MR. KAI: Correct.

10 MEMBER BROWN: Let's talk a little bit  
11 about that.

12 CHAIRMAN SIEBER: This is not a Navy  
13 point.

14 MEMBER BROWN: That's fine. I haven't  
15 seen this plant in about 35 years. So if they have a  
16 positive temperature coefficient of any kind, it was  
17 like a death knell. So that's why I was asking the  
18 question.

19 (Simultaneous conversations.)

20 CHAIRMAN SIEBER: They plan to launch  
21 airplanes.

22 MEMBER BROWN: I understand that, John.  
23 I just wanted to make sure I understood what the thing  
24 looked like based on what my reading of their request  
25 was.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: Yes. Well, you're  
2 correct.

3 DR. WALLIS: You have the whole operation  
4 of the plant involved is dictated by --

5 CHAIRMAN SIEBER: Generally, there's an  
6 attempt not to have a positive moderator.

7 MEMBER BROWN: That's kind of a nice idea.

8 CHAIRMAN SIEBER: Coefficient on the other  
9 hand is not --

10 MEMBER SHACK: It's not what?

11 CHAIRMAN SIEBER: Forbidden.

12 MEMBER BROWN: Forbidden. Is that  
13 supposed to be because of the boron with the borated  
14 coolant that allows you to do that? Like you say I'm  
15 not familiar with that enabler.

16 CHAIRMAN SIEBER: That's sort of what  
17 causes it I think. I have no idea what causes  
18 expansion to the amount of boron in the core reduced  
19 and as you go through life the coefficient changes.

20 MEMBER BROWN: Okay. I didn't mean to  
21 take a tour. I'll ask questions later. Let's go  
22 ahead and get this done.

23 MR. GUERCI: Mr. Chairman, excuse me.  
24 John Geirse. I can clarify. The full power  
25 moderated coefficient is a plus or minus six, minus

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 seven, at full power conditions. We have a design  
2 limit of zero, but the actual nominals are negative --

3 MEMBER BROWN: Okay.

4 MR. GUERCI: At full power.

5 MEMBER BROWN: That's at full power.

6 MR. GUERCI: That's correct.

7 MEMBER BROWN: How does that translate?  
8 You said six or seven?

9 MR. GUERCI: Minus six or minus seven,  
10 that's correct.

11 MEMBER BROWN: Minus six or seven. How  
12 does that translate down as opposed to the design  
13 basis? Where you say it's plus five, does that mean  
14 it's closer to negative as you go below 70 percent?

15 MR. GUERCI: To sort of clarify, at full  
16 power, the limit is zero and we're approximately at  
17 minus seven. At zero power, the limit is plus five  
18 and we're approximately at zero.

19 MEMBER BROWN: Okay. Thank you very much.  
20 Thank you. Okay.

21 MR. KAI: Sandy has an answer on the ATWS  
22 question.

23 MS. ANDRE: For the loss of feedwater,  
24 it's 2979 psia and the loss of load was 3105 psia.

25 MEMBER ABDEL-KHALIK: What was the latter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 number please?

2 MS. ANDRE: That was for loss of load 3105  
3 psia.

4 MR. KAI: Okay. We're going to talk about  
5 initial conditions. Currently, they are analyzed for  
6 a single nominal temperature at 100 percent power with  
7 no margin for temperature coastdown and one of the  
8 things that we wanted to do when we went to uprate was  
9 to allow us to operate over a band of temperature as  
10 well as provide margin for a temperature coastdown.  
11 So from a design standpoint, we have analyzed a much  
12 larger range of initial temperatures from the high end  
13 of our temperature band all the way down through a  
14 coastdown temperature. So it gives us additional  
15 operational flexibility in where we operate and also  
16 gives us flexibility at the end of the cycle during  
17 coastdown.

18 We have chosen to operate at the same  $t$   
19 ave that we currently operate and that is specifically  
20 to limit issues that you brought up in terms of Alloy  
21 600 corrosions.

22 CHAIRMAN SIEBER:  $\Delta t$  increases.

23 MR. KAI: Correct.  $\Delta t$ .

24 CHAIRMAN SIEBER: The average stays the  
25 same.

1 MR. KAI: So we have a Delta t increase  
2 obviously. So we would be operating at a slightly  
3 higher t hot than we currently do.

4 CHAIRMAN SIEBER: What's that? Four  
5 degrees or five degrees, something like that?

6 MR. KAI: It should be about two degrees  
7 higher hot rate temperature. A Delta t is about four  
8 degree increase, something in that order. So while we  
9 are analyzing, design-wise, of alloys for a full range  
10 of temperature, you know, obviously where we actually  
11 operate would be lower and we'll go over that on the  
12 next slide. We'll talk about the actual temperatures.  
13 So if you look at where we are actually going to  
14 operate, we would expect a modest impact in terms of  
15 Alloy 600 corrosion and really if you look at the cold  
16 leg side if you're operating at the same t ave the  
17 cold leg temperature actually goes down a little bit.

18 And the other thing I'd like to mention is  
19 that we are changing our pressurizer level initial  
20 pressure level, increasing that to take into account -  
21 -

22 DR. WALLIS: These numbers are small. You  
23 mean, it's something like one percent or something.

24 MR. KAI: Yes. I have the numbers there.  
25 Okay. This slide is a little busy and I

1 understand that. One thing I want to point out is  
2 other than the second column the other columns are all  
3 design numbers. They were calculated -- Temperatures  
4 are calculated based on a thermal design flow of  
5 363,000 gpm which is almost ten percent lower than our  
6 actual flow rate.

7 MEMBER ABDEL-KHALIK: So can you tell me  
8 the difference between the 372,000 gpm in the first  
9 column and the 398,912 in the second column?

10 MR. KAI: Okay. That 372,000 is called  
11 minimum measured flow and it's used as the limit in  
12 our DNBR analysis. So this limit is an actual limit  
13 that we cannot operate below in terms of RCS flow. So  
14 it goes -- This is used in our DNBR analysis as the  
15 minimal flow for DNBR. So if you were to measure flow  
16 below that we would have to take it out.

17 MEMBER ABDEL-KHALIK: So are we comparing  
18 apples and apples here when we talk about these two  
19 numbers?

20 MR. KAI: Between design flow and --

21 MEMBER ABDEL-KHALIK: No, between the  
22 372,000 at current design conditions and the 398,912?

23 MR. KAI: No. The line is what our  
24 expected flow is, what we got measured today. That's  
25 our best estimate. For DNB purposes, that measurement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cannot be below 372,000. So we do a surveillance to  
2 assure that we meet that.

3 CHAIRMAN SIEBER: Yes, that's the current  
4 design and that limit changes to 379,200.

5 MR. KAI: But yes, we are --

6 CHAIRMAN SIEBER: The flow you think  
7 you're going to have is 398.

8 MEMBER ABDEL-KHALIK: Okay. What actions  
9 do you currently take if the measured flow drops below  
10 372,000 gpm?

11 MR. KAI: That's going to be by our  
12 technical specifications. We would be forced to  
13 reduce power for shutdown. We cannot operate below  
14 that minimum measured flow.

15 MEMBER ABDEL-KHALIK: So would these  
16 actions also be taken if your flow drops below 398,912  
17 at SPU conditions?

18 MR. KAI: No.

19 MEMBER ABDEL-KHALIK: So what is the  
20 meaning of the 398,000 number?

21 CHAIRMAN SIEBER: That's the classic flow.

22 MR. KAI: That's what we currently expect  
23 for our flow at uprate conditions as currently  
24 measured.

25 MEMBER SHACK: The feel good number.

1 (Simultaneous conversations.)

2 MEMBER ARMIJO: It shows you how much  
3 margin there is between the actual flow and what their  
4 design minimum flow rate is.

5 CHAIRMAN SIEBER: Yes.

6 MEMBER ARMIJO: And it goes up to -- The  
7 required goes up to 379,200 under the SPU conditions.

8 (Simultaneous conversations.)

9 MEMBER ABDEL-KHALIK: So does this reflect  
10 your current minimum measured flow?

11 MR. KAI: The number on the left.

12 MEMBER ABDEL-KHALIK: The 398,912, does  
13 that reflect your current flow rate measurement?

14 MR. KAI: Yes.

15 DR. KRESS: But it really isn't a minimum  
16 flow rate. This is your current flow rate.

17 MR. KAI: Not minimum. That's why it says  
18 best estimate. I didn't know how to put it in the  
19 table.

20 MEMBER ARMIJO: Okay. For the SPU,  
21 you're going to change 372,000 to 379,200 for the  
22 minimum allowable flow rate to continue normal  
23 operations.

24 MR. KAI: Right.

25 MEMBER ARMIJO: Let's try to understand



1 this table fully. And 398,000, just as an expression  
2 of that's where you are today.

3 MR. KAI: Right.

4 MEMBER ARMIJO: And it's enough to say,  
5 "Look, we have a lot of margin in there and then we  
6 can do this" and I would reiterate this as kind of a  
7 feel good number and have yourself -- From what I  
8 understand what you said earlier, the second column  
9 SPU, that's basically what you would expect your  
10 normal operating parameters to be. The others are all  
11 design limit, design minimums.

12 CHAIRMAN SIEBER: Yes.

13 MEMBER ARMIJO: Your second column is  
14 basically at SPU where you expect the normal operation  
15 to be.

16 MR. KAI: Exactly. Correct.

17 MEMBER BANERJEE: What is your normal  
18 operation now?

19 MR. KAI: Our current t ave is 571, the  
20 t hot is about two degrees lower and the t cold is --

21 MEMBER BANERJEE: But what's your flow  
22 rate, gpm?

23 MR. KAI: It's the same.

24 MEMBER BANERJEE: That's going to stay the  
25 same.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: Correct.

2 MEMBER ABDEL-KHALIK: If you're operating  
3 at tech spec limit flow of 379,200 at the stretch  
4 power uprate, what would your t hot be?

5 MR. KAI: It would be about two degrees  
6 higher than what's shown here. I think that's about -  
7 -

8 MEMBER BROWN: Say that again.

9 MR. KAI: It's about a five percent.

10 MEMBER ABDEL-KHALIK: I mean, by tech spec  
11 you're allowed to operate with a flow down to 379,200.  
12 Right? So the question is is there a column here that  
13 reflects that condition and I can't see it.

14 MEMBER BROWN: Wouldn't it be 622.6?

15 MEMBER ABDEL-KHALIK: No.

16 MR. KAI: No, that 622.6 is based on --

17 MEMBER ABDEL-KHALIK: Height, yes.

18 MR. KAI: -- the 363,000. So you would  
19 have to --

20 MEMBER: Based on what?

21 MR. KAI: 363,000. It's design flow.  
22 These three columns are all design flow.

23 DR. WALLIS: But that's based on that.

24 MEMBER BANERJEE: I'm a little confused  
25 here. So let's look at the design column and the SPU

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 column.

2 (Simultaneous conversations.)

3 MEMBER ARMIJO: That's at design level  
4 also. That's not a normal condition.

5 MEMBER BANERJEE: Yes, I'm sort of  
6 confused because what should I look at as the cold leg  
7 temperature and the hot leg temperature and compare  
8 the current design with the new design? Which column  
9 should I look at?

10 MR. KAI: Okay.

11 MEMBER BANERJEE: So the first column is  
12 your current design. That's right?

13 MR. KAI: Yes.

14 MEMBER BANERJEE: So your cold leg  
15 temperature is 555.6 and your hot leg temperature is  
16 618.3. Now which column is comparable to that column  
17 with the new design?

18 MR. KAI: Okay. Now we have --

19 MEMBER BANERJEE: So apples and apples.

20 MR. KAI: An apples and apples comparison  
21 would be that the last three columns which gives you  
22 the SPU max, the Max t ave, the Min t ave and  
23 coastdown. Those were all calculated with the same  
24 flow rate. That's the 363,200 gpm.

25 CHAIRMAN SIEBER: Hopefully you did the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 average of columns three and four. If you're looking  
2 at the extreme boundaries of normal operations --

3 MEMBER ARMIJO: Fine. I don't think that  
4 there is an apples to apples comparison here because  
5 to do that you would have to have three columns for  
6 the current design to line up with the --

7 CHAIRMAN SIEBER: Right.

8 MEMBER ARMIJO: -- Last three columns.  
9 There's really not an apples to apples comparison.

10 MEMBER BANERJEE: Yes, there is none.  
11 Exactly. But at least it gives you a feel for it.

12 MR. KAI: And that's what I was trying to  
13 do here without making three or four tables. On this  
14 table, the column in the middle is where we expect to  
15 be and I think what we want and what I use that for is  
16 in terms of things like our aging management which is  
17 what Alloy 600 is. I want to see what do we really  
18 expect in terms of increases, in terms of Alloy 600.

19 MEMBER ABDEL-KHALIK: What I was really  
20 looking for is a column that would say what the flow  
21 rate is, 379,200 and t ave is 587.1. It gives you a  
22 nominal t ave and if that is the case, then I suspect  
23 your peak temperature would be 620.2. That would be  
24 your t hot.

25 MR. KAI: Yes, I think that's right. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 was just doing the math in my head, but correct.

2 CHAIRMAN SIEBER: Usually when you make  
3 these comparisons, you make them --

4 (Simultaneous conversations.)

5 MEMBER BANERJEE: If you had two tables  
6 you would have had much less discussion.

7 MR. KAI: Right.

8 MEMBER ABDEL-KHALIK: I guess my concern  
9 is that why show this second column rather than a  
10 column where the flow rate is at the tech spec limit  
11 of 379,200 and the t ave value is at a nominal value  
12 of 587.1, which would tell you that that nominal hot  
13 leg temperature at tech spec flow limit would be 620.1  
14 rather than 617.1.

15 MR. KAI: Okay. I didn't choose to do it  
16 that way, but I see your point. Like I said, I was  
17 really trying to compare where we expect to operate  
18 compared to the design condition. So it wasn't meant  
19 to look at --

20 MEMBER BANERJEE: But let's make it  
21 simple. Why don't we get a table with apples and  
22 apples comparison in the process? That would be  
23 easier rather than trying to do these sums ourselves.  
24 At some point, I'd like --

25 MEMBER BROWN: I appreciate your attempt.

1 But it does make it easier. There's nothing on here  
2 that you can really compare current to the SPU  
3 conditions.

4 MEMBER ARMIJO: Under the same set of  
5 assumptions.

6 MEMBER BROWN: Under the same set of  
7 assumptions.

8 MEMBER POWERS: But on the other hand,  
9 there's nothing here that looks very dramatic either.

10 MEMBER BROWN: I agree.

11 MEMBER POWERS: And I can interpolate  
12 fairly quickly here the fluid that there's not of a  
13 change.

14 MEMBER BROWN: I don't disagree with that  
15 at all.

16 CHAIRMAN SIEBER: You can do it in your  
17 head.

18 MR. KAI: These numbers are all there like  
19 I said. I think I'll ask for Goshing Wong who is our  
20 Westinghouse thermal hydraulic engineer. He can  
21 provide additional information about the temperature.

22 CHAIRMAN SIEBER: Probably if you just did  
23 one. If we need to answer this at all, you just need  
24 one column which is SPU design.

25 MR. WONG: Okay. I would like to add real

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 quickly some information. This table --

2 MEMBER ARMIJO: Identify yourself.

3 MR. WONG: Yes. My name is Goshing Wong.  
4 I'm a thermal hydraulic designer from Westinghouse.  
5 Good morning, everyone. This table, the last line,  
6 the last row, is additional information. Everything  
7 else are consistent with each other. Basically, the  
8 t ave, t hot and the thermal design flow are  
9 consistent. So the last row is just additional  
10 information. That's it.

11 MR. KAI: But what you want is this one at  
12 587.1 with a flow rate of 379.

13 CHAIRMAN SIEBER: Yes.

14 DR. WALLIS: I just have one comment. If  
15 you can quote the normal operation flow rate to one  
16 part in 400,000 you ought to be able to capture 1.7  
17 percent uncertainty.

18 (Laughter.)

19 MEMBER BANERJEE: How do you measure the  
20 flow rate?

21 MR. KAI: Pardon?

22 MEMBER BANERJEE: How do you measure the  
23 flow rate?

24 CHAIRMAN SIEBER: Thermal calorimetric.

25 MR. KAI: Thermal calorimetric.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: That's calorimetric?

2 MR. KAI: Right.

3 CHAIRMAN SIEBER: Yes, flow meters --

4 MEMBER ARMIJO: Obviously you do have flow  
5 meters but then you allow them a calorimetric --

6 MR. KAI: Correct.

7 DR. WALLIS: But your accuracy is one  
8 percent or something. So this is imaginary. The last  
9 three figures are completely imaginary.

10 MR. KAI: We mention the errors, and we  
11 put the number up to places, but you're right.  
12 Correct.

13 CHAIRMAN SIEBER: Why don't we move on?

14 MR. HUEGEL: This is Dave Huegel from  
15 Westinghouse and I guess one question that everybody  
16 seems to be wanting an answer to is the fact that you  
17 have two different  $t$  averages yet you have two different  
18 flow rates and the question is how does that affect  
19 the  $t$  hot. If you just merely take the difference in  
20  $t$  average and reduce that amount from  $t$  hot and  $t$  cold,  
21 believe me, that to the nearest tenth of degree will  
22 give you what the temperature is for  $t$  hot and  $t$  cold.  
23 It's as simple as that.

24 DR. WALLIS: So it is as simple as that.

25 MR. HUEGEL: If you want to know what the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 t hot and t cold for the flow rate or what it would be  
2 at the 587, just take the difference in t ave which is  
3 roughly 2.5 degrees, subtract that from the 622.6  
4 which gives you 620.1 for t hot and that's --

5 MEMBER ARMIJO: I understand it and the  
6 information is here.

7 MR. HUEGEL: Does that answer your  
8 question?

9 MEMBER ARMIJO: It would just make it a  
10 little easier if it just showed up that you can -- We  
11 look for things to compare when we see a table.

12 MR. HUEGEL: What we're trying to present  
13 here is here's what the current operating conditions  
14 are, here are the conditions that we're going to.  
15 Does that answer the question?

16 MEMBER ARMIJO: Yes sir.

17 CHAIRMAN SIEBER: Good enough.

18 MR. HUEGEL: Okay.

19 CHAIRMAN SIEBER: Why don't we move to  
20 Slide 9?

21 MR. KAI: Okay.

22 MEMBER BANERJEE: The main effect is that  
23 you now have a higher minimum flow for your DNB limit.

24 CHAIRMAN SIEBER: Right.

25 MEMBER BANERJEE: That's the main effect,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I guess.

2 MR. KAI: Yes. Correct.

3 CHAIRMAN SIEBER: But they have margin.

4 MEMBER BANERJEE: And a little bit hotter  
5 outlet --

6 MR. KAI: Correct. And like I said, in  
7 terms of that, the analysis goes back to why I put  
8 this number, the best estimate number in this, as  
9 opposed to something to compare apples to apples which  
10 I understand now.

11 MEMBER BANERJEE: Referring to us that you  
12 have enough margins.

13 MR. KAI: Yes, that's what I'm trying to  
14 do. Correct.

15 CHAIRMAN SIEBER: No matter what they have  
16 margin. Okay. Slide 9.

17 MR. KAI: Pressurizer level, we are  
18 increasing from the 100 percent pressurizer level from  
19 61.5 percent to 64. This represents a compromise,  
20 obviously, for accidental system. Pressurizer  
21 overfill is an issue. The higher you make it, the  
22 less margin you have to overfill and we have to weigh  
23 that versus looking at a routine reactor trip and  
24 assuring that the level collapse from the reactor trip  
25 doesn't result in things like uncovering the heaters

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or isolating letdown.

2 CHAIRMAN SIEBER: So what level would you  
3 expect to drop to during a trip from 100 percent  
4 power, reactor trip, assuming everything is tight and  
5 it actually trips instead of just drops off?

6 MR. KAI: Approximately the 27<sup>th</sup> or the  
7 28<sup>th</sup> percent. We have about five percent margin.

8 CHAIRMAN SIEBER: Okay.

9 MR. KAI: That's what we try to maintain.

10 CHAIRMAN SIEBER: That's where the 550 is  
11 here.

12 MR. KAI: About.

13 CHAIRMAN SIEBER: And where is the range  
14 of the heaters? Where are they on this level?

15 MR. KAI: The set point is 22. So that's  
16 --

17 CHAIRMAN SIEBER: Where physically are the  
18 heaters?

19 MR. KAI: Physically they are below 22 and  
20 --

21 MS. ANDRE: Seventeen maybe.

22 MR. KAI: I think it's 17 or 18 percent,  
23 it's about.

24 CHAIRMAN SIEBER: Okay.

25 MR. KAI: So we are trying to maintain

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 under the five percent margin to the level cutoff and  
2 the heater cutoff and the letdown isolation and that  
3 currently provides --

4 CHAIRMAN SIEBER: But you have to run the  
5 heaters. They would deenergize.

6 MR. KAI: Correct.

7 CHAIRMAN SIEBER: On the other hand, an  
8 operator, one of the sickening feelings is to have  
9 pressurizer level disappear.

10 (Laughter.)

11 MR. KAI: Right.

12 CHAIRMAN SIEBER: Okay.

13 MR. KAI: Okay. That's all I was going to  
14 say about initial conditions. If you have any other  
15 questions?

16 CHAIRMAN SIEBER: Is this a good time to  
17 take a break or do you want to do Slide 10?

18 MR. KAI: Probably yes because I'm going  
19 to go and talk about the safety analysis next.

20 CHAIRMAN SIEBER: Why don't we do that and  
21 since we're ahead of schedule we can come back at 20  
22 to 11:00. So we'll take our recess of 20 minutes now.

23 (Whereupon, at 10:20 a.m., the above-  
24 entitled matter recessed and reconvened at 10:38 a.m.)

25 CHAIRMAN SIEBER: I'd like to resume the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 meeting after our short recess and what I'd like to do  
2 is call on -- One of the questions we asked had to do  
3 with the calculation of fluence to the vessel walls,  
4 how that is affected by the power increase and how  
5 it's affected by the power increase and how it's  
6 affected by the change in power shape and Ambrose  
7 Wallace of NRR can answer that question, I think.

8 MR. WALLACE: Yes. Thank you. My name is  
9 Ambrose Wallace. I'm with the Reactor Systems at NRR  
10 and responsible for the fluence calculations. The  
11 methodology we use and all of the licensees that have  
12 adapted so far which we have codes approved in that  
13 direction is the so-called synthesis method and what  
14 it takes into account are the following things.

15 One is the loadings of the outer  
16 assemblies. The second is the azimuthal radial  
17 distribution and the third is axial radial  
18 distribution. So all of these things are synthesized  
19 in a manner that accounts for the azimuthal, the  
20 radial and the axial distributions in addition to  
21 which it accounts for the average cycle loading our  
22 power condition, of each one of the assemblies in the  
23 outer two assembly rows.

24 So the question is as I understood it to  
25 be is the flattening of the flux taken into account.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Absolutely.

2 CHAIRMAN SIEBER: Okay. I guess that sort  
3 of satisfies my question. Does anybody else have any  
4 questions they would like to ask about that?

5 DR. KRESS: I'm still a little confused.  
6 The reason that the most -- I'm guessing, but the  
7 reason the most recent capsule fluence was lower than  
8 the previous, let's say, extrapolation was partly  
9 because of this low leakage core design. Imagine that  
10 to create that. Now with a higher power being  
11 generated by the peripheral bundles the benefits of  
12 that low leakage core are reduced.

13 MR. WALLACE: Yes.

14 DR. KRESS: So the expectation of the  
15 fluence is going to be, should be, higher and I'm just  
16 wondering if it actually was taken into account in the  
17 final calculation.

18 MR. WALLACE: Let me address that  
19 question. The capsules, the surveillance capsules,  
20 have really very little to do with the calculated  
21 value. The surveillance capsules are there to connect  
22 the embrittlement of the archival material that bleeds  
23 into the capsule to its exposure. That may or may not  
24 have anything to do with the maximum location of the  
25 exposure of the vessel. That is a calculated value

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 which we ascertained, verified, if you wish, or  
2 benchmarked to the particular value of where the  
3 capsule is. But the capsule may or may not have  
4 anything to do with the calculated maximum value on  
5 which the material properties of the vessel are based.

6 DR. KRESS: So it's not even a comparison  
7 between the calculated and the actual measured.

8 MR. WALLACE: Yes, it is for this  
9 particular location where the capsule is.

10 DR. KRESS: I understand that.

11 MR. WALLACE: Yes, it is to verify the  
12 reliability of the calculation rather than to directly  
13 measure the value of the vessel. There is no way to  
14 directly measure the value of the vessel.

15 DR. KRESS: Okay. That explains it.

16 MR. WALLACE: Thank you.

17 CHAIRMAN SIEBER: Now Millstone has six  
18 capsules. If I read the report correctly, you may  
19 have removed three. Typically, the schedule for  
20 removal of capsules and their examination is one every  
21 ten years. So this subject gets revisited two more  
22 times in the life of the plant and each time these  
23 same calculations are made to predict what changes in  
24 vessel properties have occurred over that period of  
25 time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BROWN: We've talked around this a  
2 lot and I think I heard the answer. I just want to  
3 make sure that the fluence calculations for the future  
4 under SPU conditions has taken into account the  
5 flatter core --

6                   CHAIRMAN SIEBER: Yes.

7                   (Simultaneous conversations.)

8                   Okay. I think we're on Slide 10 if you  
9 want to continue.

10                  MR. KAI: Okay. We'll talk about the  
11 safety analysis now.

12                  MR. GUERCI: I want to make a statement to  
13 the previous question. This is John Guerci. In  
14 response to the EPRI duty index, our best estimate  
15 numbers went from approximately from the mid to low  
16 160s, 163, up to a little over 200, maybe 206. The  
17 worst case numbers are a little higher if you use  
18 minimum flow instead of nominal flow. I think we used  
19 that as a scoping tool then to get back to, I believe,  
20 the question previously with -- In fact, there's a  
21 clarification on the boron precipitation.

22                  I assume you're referring to the corrosion  
23 of boron at the top of the core. And so we used the  
24 EPRI duty index as a scoping tool and we had looked at  
25 this a number of years ago prior to even the uprates

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 starting and then we go through a bow analysis to look  
2 at boron deposition in the core at the new uprated  
3 conditions. So that work has all been done in support  
4 of --

5 MEMBER ABDEL-KHALIK: Where does the 206  
6 place you?

7 MR. GUERCI: My recollection is high. I  
8 think it's above 200, approximately whatever we call  
9 the high range. Again, it's a scoping tool because we  
10 need to go back and look at the actual thermal  
11 hydraulic conditions. It's a pretty general kind of  
12 tool in terms of it doesn't have the detailed thermal  
13 hydraulics in it.

14 MEMBER ABDEL-KHALIK: Thank you.

15 MR. GUERCI: And the peak linear heat rate  
16 went from 14.2 at a 15.1 from the previous cycle to  
17 the projected uprate cycle.

18 MEMBER BROWN: Fourteen?

19 MR. GUERCI: 14.2 kilowatts per foot up to  
20 15.1 kilowatts per foot.

21 MEMBER BROWN: Okay. Thank you.

22 CHAIRMAN SIEBER: Any others before we  
23 begin?

24 Go ahead.

25 5. SAFETY ANALYSIS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: Okay. I'll make some general  
2 remarks about the safety analysis first and then like  
3 I said, the slides have lots of results. I'm not  
4 going to go over them all.

5 The first thing I would like to state is  
6 what we did in the safety analysis is essentially redo  
7 every one of the accident analyses. Not only that,  
8 but we went back and validated every input that went  
9 into the safety analysis, not just the ones that are  
10 affected by uprate but every single parameter, flows,  
11 ECCS, performance, all of the parameters, were  
12 revalidated for uprate.

13 And in general, we did not need  
14 methodology changes to show acceptable results. We  
15 did, however, we have used the latest technology and  
16 methodology that Westinghouse employs primarily to go  
17 for going forward that we would be postured for the  
18 next ten years or so in terms of analysis methods.

19 So the scoping studies were done with the  
20 current tools and so that we accepted the margin to  
21 the uprate. In general, we have not used analysis  
22 methods to gain margins to show acceptable results.  
23 Now it does provide us some benefit of how it runs  
24 well. We have gained some benefit in terms of a new  
25 methodology. But in general, we have not used

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 analysis as a method to gain margin.

2 What we wanted to do is restore margin or  
3 where we could back to our current. So we've made a  
4 number of modifications to restore DNBR margin as  
5 opposed to just using the available margin that we  
6 have.

7 CHAIRMAN SIEBER: Now does this discount  
8 the fact that you've used a realistic code for your  
9 Appendix K analysis.

10 MR. KAI: Right.

11 CHAIRMAN SIEBER: Rather than the  
12 deterministic one because that gives you oodles of  
13 margin that you don't get out of the deterministic  
14 method.

15 MR. KAI: Right, and we currently have  
16 fairly significant margins in LOCA here. We're not  
17 LOCA limited.

18 CHAIRMAN SIEBER: From the FAC's  
19 temperature limit.

20 MR. KAI: Correct. From the -- Correct.

21 CHAIRMAN SIEBER: And oxidation. Right?

22 MR. KAI: Yes. So using the current  
23 methodology, BART/BASH, we have, we already have  
24 significant margin. We didn't use ASTRUM there. We  
25 just used it as going forward and you'll see that when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we compare. There are comparisons and results.

2 CHAIRMAN SIEBER: Let me ask you this  
3 question. Are the names that you used proprietary in  
4 any sense?

5 MR. KAI: No.

6 CHAIRMAN SIEBER: Okay.

7 MEMBER BANERJEE: Are these -- You'll come  
8 to it later, but I assume that ASTRUM must be a  
9 approved code of some sort.

10 MR. KAI: Yes, it's COBRA/TRAC.

11 MEMBER BANERJEE: Oh, it's COBRA/TRAC.  
12 All right.

13 CHAIRMAN SIEBER: There is a topic on  
14 that, I think.

15 MEMBER BROWN: Clarification. I think I  
16 understood you to say that you didn't need the new  
17 analysis to show acceptability of the power uprate.

18 MR. KAI: New codes.

19 MEMBER BROWN: Okay. You also tossed  
20 margins into there and I believe that if you're using  
21 your original codes and methods -- Are you saying you  
22 would have, with the modifications made you, would  
23 maintain the same margin.

24 MR. KAI: I believe so. Again, we did  
25 this early in the project to look at one of the ways

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that we could gain back margin and we did a number of  
2 sensitivity studies to show that we won't end up with  
3 zero margin coming out of this and that we have  
4 comparable margins.

5 MEMBER BROWN: And I understand there are  
6 a number of things that you're doing that do help you  
7 on your margins and stuff but it wasn't clear to me  
8 that under your original codes that you would have  
9 maintained exactly the same margins there.

10 MR. KAI: Right, and again you're right.  
11 That's not really -- I don't think you could have  
12 drawn that from our documentation. I think you're  
13 right.

14 MEMBER BANERJEE: You didn't do any  
15 calculations with BART/BASH or whatever it's called.

16 MR. KAI: At the uprate, no. We did not.

17 MEMBER BANERJEE: So what was the margin  
18 with -- What was the PCT margin with BART/BASH for the  
19 current design?

20 MR. KAI: Well, I will get to that. If  
21 you want to look at the numbers, it's on Slide 24 and  
22 you'll see that the current numbers are really low,  
23 with the current methodology.

24 MEMBER BANERJEE: With the current  
25 methodology, it was fairly close to 1974. With a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 seven percent uprate, I don't know what it would have  
2 done but it would reduce that quite a bit I would  
3 think.

4 CHAIRMAN SIEBER: And that's the result of  
5 using a realistic code. Right?

6 MEMBER BANERJEE: You're using a realistic  
7 code, but you're not using the sort of best estimate  
8 plus uncertainties, are you?

9 MR. KAI: This is just sort of a --

10 MEMBER BANERJEE: Explain to me what this  
11 code ASTRUM does. Does it have Appendix K assumptions  
12 in there or the best estimate only and if so, do we  
13 have uncertainty bands on it?

14 MR. KAI: Could I delay that until I get  
15 there. I will discuss that.

16 MEMBER BANERJEE: Okay.

17 MR. KAI: Okay.

18 MEMBER BANERJEE: And can you also explain  
19 all these other numbers in more detail?

20 MR. KAI: Well, I wasn't going to go over  
21 them all, but I will talk about LOCA.

22 MEMBER ARMIJO: Since you're talking about  
23 the codes, the new codes, that you did use, you made  
24 a comment in your documentation that you benchmarked  
25 the new codes against something. But you didn't --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 You just said you benchmarked them. But was I  
2 supposed to walk away with something from that? I  
3 mean, do you validate them against some other data?  
4 Do you go back and take them or am I misinterpreting  
5 what you said in the written license request? Do you  
6 understand my question?

7 MR. KAI: Yes. In general, the new codes  
8 are based on a sense of proved methodology which  
9 contains a series of benchmark analyses which can  
10 demonstrate that they will produce conservative  
11 results. We followed the modeling guidelines. We  
12 have -- We did look at, for example, a full coastdown  
13 to make sure that it compares with the current  
14 analysis of record. So in general, we will rely on  
15 the current benchmarking that's done by Westinghouse  
16 for the approved methodology.

17 MEMBER BROWN: So you didn't literally  
18 take this code and say, "Here we did this analysis on  
19 this particular transient with our old method." You  
20 used the new method and see that you got either the  
21 same or a more conservative or less conservative  
22 result. You didn't do that as part of this. Is that  
23 correct?

24 MR. KAI: That's correct.

25 MEMBER BROWN: So benchmarking was done by

1 Westinghouse and whatever other process they went  
2 through to get that code to get the Betty Crocker/Good  
3 Housekeeping seal of approval or whatever.

4 MR. KAI: Right.

5 MEMBER BROWN: Okay.

6 MR. KAI: And then, of course, obviously  
7 we did -- If we saw something that was significantly  
8 different -- But no we did not do any plant specific  
9 benchmarking.

10 CHAIRMAN SIEBER: I'd like to get back to  
11 Slide 10 please. You use an alternate source term for  
12 your radiological analysis. Right?

13 MR. KAI: Correct.

14 CHAIRMAN SIEBER: That was applied for and  
15 approved prior to your application for stretch power  
16 uprate.

17 MR. KAI: Right. Now when I get there, I  
18 will talk more. Go ahead. Sorry.

19 CHAIRMAN SIEBER: And the last bullet  
20 says, "PRA results show SPU has minimal impact on  
21 risk." Could you give me the numbers for the old risk  
22 and the new risk?

23 MR. KAI: They are on Slide 33. I will  
24 get to that. This is kind of a summary. Slide 33, it  
25 has the new and old.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1                   CHAIRMAN SIEBER:   Okay.   When you get  
2                   there, my follow-up question is usually in PWRs as  
3                   dominated by human factors issues which was operator  
4                   response times and the only one I was able to pick out  
5                   was the switch from injection to recirculation which  
6                   is hours out in the sequence.   So if you go through  
7                   the human factors issues, that will help me.

8                   MR. KAI:   Yes.

9                   CHAIRMAN SIEBER:   You'll follow up.

10                  MR. KAI:   Yes.   Don't worry.

11                  CHAIRMAN SIEBER:   Okay.

12                  DR. KRESS:   Are there any plans to do a  
13                  stretch power uprate for the Millstone 2?

14                  MR. KAI:   Yes.

15                  DR. KRESS:   After this one?

16                  MR. KAI:   Yes.   Of course, that's a  
17                  totally different animal altogether.

18                                To follow up on your -- One point I would  
19                                like to make about the PRA model is that what we did  
20                                is that we did validate using -- We did analyses to  
21                                confirm that the success criteria and the operating  
22                                response times that were assumed in the current  
23                                analysis, for the PRA, we showed that at SPU  
24                                conditions those still remained valid.   In other  
25                                words, we really updated all the thermal hydraulic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 analysis including the determination about response  
2 times and validated that what they had assumed is  
3 still valid.

4 CHAIRMAN SIEBER: When we get there, you  
5 can give me the times and the operator actions.

6 MR. KAI: Okay.

7 MEMBER ARMIJO: And you're going to tell  
8 us what these margins you talked about, those four  
9 items, you're going to say what they were for the  
10 current. We'll be able to get the Delta.

11 MR. KAI: Yes. Correct.

12 DR. WALLIS: We'll get to all this stuff.

13 MR. KAI: Any other questions before going  
14 on?

15 CHAIRMAN SIEBER: Go on.

16 MR. KAI: Number 11, what I'm doing is  
17 summarizing the methods change and as you can see that  
18 for the non-LOCA we have switched from LOFTRAN I think  
19 to RETRAN VIPRE and we have you used ASTRUM for large  
20 break LOCA.

21 CHAIRMAN SIEBER: And ASTRUM is --

22 MEMBER BANERJEE: What is the status of  
23 RETRAN? I thought we had some concerns at the ACRS  
24 about RETRAN that were raised before.

25 CHAIRMAN SIEBER: I think it's an improved

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 code.

2 DR. WALLIS: Yes, we had some concerns and  
3 then I discovered recently that the NRC approved it  
4 anyway.

5 (Laughter.)

6 CHAIRMAN SIEBER: It's an approved code.  
7 I did check that. And ASTRUM is just an update of  
8 BART/BASH. Right?

9 MR. KAI: No. Okay.

10 CHAIRMAN SIEBER: No?

11 MEMBER BANERJEE: Completely different.

12 MR. KAI: It's completely different.  
13 Correct. It actually uses COBRA/TRAC and it is a best  
14 estimate methodology and it's approved.

15 MEMBER BANERJEE: And you'll explain to us  
16 how you've used it because it's approved with  
17 uncertainties calculations. Right? The code is  
18 approved, but it's typically used as a best estimate  
19 plus uncertainties.

20 MR. KAI: Correct. And we applied the  
21 approved ASTRUM methodology that was developed. That  
22 was approved by the NRC.

23 DR. WALLIS: The number you quote is a  
24 9595 number, isn't it?

25 MR. KAI: It's an upper bound estimate of

1 9595. Correct.

2 MR. HARTZ: This is Josh Hartz. I work  
3 for Westinghouse Electric in a LOCA group. That is a  
4 95<sup>th</sup> percentile PCT.

5 DR. WALLIS: Ninety-fifth percent.

6 MR. HARTZ: Ninety-five ninety-five, yes,  
7 exactly. And it's advanced statistical treatment of  
8 uncertainty method. That's what ASTRUM stands for.

9 CHAIRMAN SIEBER: Right.

10 MEMBER BANERJEE: You used 59 sample drums  
11 or something. What is it?

12 CHAIRMAN SIEBER: That's the magic number.

13 MR. HARTZ: It has been increased and I  
14 believe it's gone to 124 sample cases. Don't quote me  
15 on that.

16 MEMBER BANERJEE: We may see them go to  
17 500 though.

18 MR. HARTZ: Yes, and you may see that.

19 CHAIRMAN SIEBER: You ought to reduce it  
20 up to a certain limit. Okay. Go ahead.

21 MR. KAI: Okay. There is 124.

22 CHAIRMAN SIEBER: Okay.

23 MR. KAI: One hundred twenty-four cases.

24 Okay. I'm going to go over DNBR margin.  
25 The way that this is organized is based on safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 limits. Start with DNBR and I'll talk about pressure  
2 and then overfill.

3 Obviously, we were concerned with DNBR at  
4 the uprate. Raising power is clearly a negative  
5 impact on the margin.

6 MEMBER SHACK: Just one. You changed your  
7 containment code, too. Right?

8 MR. KAI: Correct. We will talk about  
9 that in the afternoon, but yes. And there's a  
10 separate set of slides addressing containment.

11 One thing to understand about where we  
12 currently operate is that in this cycle and in the  
13 past we have been subject to what's called upper  
14 plenum anomaly and that results in spiking in the hot  
15 leg temperature. We've had spurious OTDT, OPDT  
16 alarms, pre trip alarms, and so that's been an issue  
17 with Millstone for a number of years. What we did in  
18 the last cycle really in order to try and reduce the  
19 likelihood of getting these alarms is that we have  
20 essentially taken all of our DNBR margin and used it  
21 to address this problem. So you'll see that in the  
22 next slide.

23 So obviously going forward, we could not  
24 live with that situation and one of the mods we have  
25 done to address that is to put in the modification

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that will reduce the severity of the --

2 MEMBER ABDEL-KHALIK: Are the spikes in  
3 hot leg temperatures consistently in a specific loop?

4 MR. KAI: No, they go from loop to loop.

5 MEMBER ABDEL-KHALIK: Then it's random.

6 MR. KAI: What happens is if you look at  
7 the core, the fluid coming out of the core from the  
8 different assemblies doesn't completely mix and  
9 depending on a somewhat random process as to whether  
10 it goes into which hot leg and also can rotate and  
11 whether the RTDCs, the temperature or not, you can get  
12 spikes in the temperature.

13 CHAIRMAN SIEBER: I think they call that  
14 chugging.

15 MR. KAI: Okay. We did do -- That was  
16 clearly something that we had to address and we needed  
17 to reestablish DNBR margin.

18 MEMBER POWERS: Is the spiking frequently  
19 enough that we have peak problem and there is damaged  
20 peak?

21 MR. KAI: Well, it's definitely a -- The  
22 big thing especially if you get a pre trip alarm.

23 MEMBER ABDEL-KHALIK: What is particularly  
24 the order of magnitude of these spikes?

25 CHAIRMAN SIEBER: They can digress.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: Darn. I have this in separate  
2 and not in temperature. Do you know what the order of  
3 --

4 MS. ANDRE: I don't.

5 CHAIRMAN SIEBER: Five degrees or 50  
6 degrees?

7 MR. KAI: It's more five. Fifty degrees  
8 you would --

9 MEMBER ABDEL-KHALIK: Could you please  
10 find out and let us know later?

11 MR. KAI: Okay.

12 MEMBER BANERJEE: Do you understand why  
13 they occur?

14 MR. KAI: Yes. Like I said, it's because  
15 the fluid coming out of the core, of the different  
16 assemblies, does not completely mix when it goes into  
17 the hot leg. Now like I said, there's some randomness  
18 as to which outlet fuel assembly goes into which loop  
19 and whether the RTD actually sees the hot temperature  
20 and mixed temperature.

21 MEMBER BANERJEE: So these spikes would be  
22 what you'd expect to come out of the hotter channels.  
23 Is that it or is it larger?

24 MR. KAI: The hotter channel has the  
25 higher temperature. Right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Right. But are these --

2 MR. KAI: The RTD is sitting in a well on  
3 the pipe. So depending on whether the fluid entering  
4 the pipe sees the water from the --

5 MEMBER BANERJEE: Let's say it's not  
6 mixed. Let's take an extreme case and it goes  
7 through. Now are these temperature spikes consistent  
8 with the maximum temperature you would expect of the  
9 hottest channels?

10 MR. KAI: Yes.

11 MEMBER BANERJEE: It's bounded by that.

12 MR. KAI: Yes.

13 MEMBER BANERJEE: The size of the spike is  
14 maybe five degrees or something like that.

15 MR. KAI: Right.

16 CHAIRMAN SIEBER: And you have t hot  
17 trips.

18 MEMBER BANERJEE: Can you reassure us that  
19 it's not something else?

20 MR. KAI: Correct.

21 MEMBER BANERJEE: It's just a lack of  
22 mixing.

23 MR. KAI: Yes, and like I said, a certain  
24 amount of randomness. For instance, if it actually  
25 was the same, the RTD would see the same temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 all the time. But it doesn't. It rotates a little  
2 bit.

3 MEMBER BANERJEE: We understand.

4 MEMBER BROWN: Does it always rotate in  
5 the same direction and always occurs at the same time  
6 or it just bounces around?

7 MR. KAI: It's bouncing around. Correct.

8 DR. WALLIS: So this affects the hot leg  
9 temperature.

10 MR. KAI: It measures hot leg temperature.

11 DR. WALLIS: Yes, and you have limits on  
12 that. But what does it -- It doesn't change DNBR,  
13 does it?

14 MR. KAI: No, physically it doesn't. But  
15 it's there.

16 DR. WALLIS: Why do you couple them  
17 together?

18 MR. KAI: In order to not get the pre trip  
19 alarms, what I did is I raised the set point.

20 DR. WALLIS: Oh, you raised the set point.  
21 It doesn't really change the DNBR, does it?

22 MR. KAI: No, but using the set point  
23 does.

24 MEMBER BROWN: The alarm set point or the  
25 trip set point?

1 MR. KAI: The trip set point.

2 MEMBER BROWN: When you say alarm, that's  
3 synonymous with trip.

4 MR. KAI: Yes.

5 CHAIRMAN SIEBER: Well, you get the alarm  
6 before the trip.

7 (Simultaneous conversations.)

8 We have a t hot trip. So any kind of a  
9 cycling --

10 MEMBER BONACA: I was asking a question,  
11 this is not unique to Millstone 3.

12 MR. KAI: No.

13 MEMBER BONACA: I'm sure you have looked  
14 at sister plants.

15 MR. KAI: Correct. And the more that  
16 we're implementing these, what's implemented at the  
17 sister plants to reduce the severity of the spiking.

18 MEMBER BONACA: Does the phenomenon exist  
19 if everybody uprates?

20 MR. KAI: It's somewhat random. When we  
21 did our initial studies, we just assumed it would and  
22 looked and obviously now we're predicting when we did  
23 the initial DNBR sensitivity studies, it showed that  
24 we would more frequently get pre trip alarms and  
25 actually we just arbitrarily increased it so that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 could possibly get a channel to be in trip mode and  
2 for the channels to go into trip. So that would be as  
3 you said, but it would be even worse for the operator.

4 MEMBER BANERJEE: The spikes are -- Their  
5 magnitude is such that they're still indicative that  
6 the flow distribution to the channels is what you  
7 expect it to be.

8 MR. KAI: Correct.

9 MEMBER BANERJEE: So it's not larger. It  
10 doesn't show that some channels might periodically be  
11 getting lower flows or anything like that.

12 MR. KAI: No. Correct.

13 MEMBER BANERJEE: That's something the  
14 magnitude -- It would be interesting to know what the  
15 magnitude is and to compare them with the hottest  
16 channel of the temperatures assuming a flow  
17 distribution.

18 MR. KAI: Okay.

19 MEMBER BANERJEE: That would be a concern.

20 CHAIRMAN SIEBER: Is that a question you  
21 folks will find out for us?

22 MR. KAI: Yes.

23 CHAIRMAN SIEBER: Okay.

24 MR. KAI: Okay. Any questions?

25 CHAIRMAN SIEBER: Let's go to 13.

1 MEMBER ABDEL-KHALIK: What's the  
2 difference between WRB2M and WRB2?

3 MR. KAI: A slightly different correlation  
4 based on additional tests that were done to develop  
5 the correlation. So it's a slightly improved  
6 correlation that's for the RFA fuel product line.

7 MEMBER BANERJEE: It's been approved.

8 MR. KAI: It's been approved. Correct.

9 CHAIRMAN SIEBER: Yes.

10 MEMBER BANERJEE: Where were these tests  
11 done? Were these full scale bundle tests?

12 MR. KAI: I believe so. Let me get  
13 Westinghouse to actually talk about the tests.

14 MR. WONG: This is Mr. Goshing Wong again  
15 from Westinghouse. Yes, we did the DNB test in  
16 Columbia University. So the WRB2M correlation is  
17 based on those test data.

18 MEMBER BANERJEE: This is very old data  
19 then. Right?

20 MR. WONG: Yes.

21 MEMBER BANERJEE: So when were these tests  
22 done?

23 MR. WONG: Nineteen something. I forget  
24 the exact year, but I can check it out.

25 DR. KRESS: It's been around a long time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: So this is pretty old  
2 data. This is not new data.

3 MR. WONG: Yes. It's not really new data.

4 CHAIRMAN SIEBER: Right. Okay.

5 MR. WONG: Another question?

6 MEMBER BROWN: I presume this is you're  
7 passing the electronic filter on the hot leg. That's  
8 part of the changes you made.

9 MR. KAI: Yes.

10 MEMBER BROWN: Obviously that introduces  
11 a time response into the t h?

12 MR. KAI: Yes.

13 MEMBER BROWN: For your Delta-t function.  
14 I presume that was cranked into you other analysis.

15 MR. KAI: Yes.

16 MEMBER BROWN: You said four seconds which  
17 is fairly hefty for the most part. Do you know that  
18 this eliminates the spikes?

19 MR. KAI: Yes. We've done a study looking  
20 at that.

21 MEMBER BROWN: So you include it in as a  
22 trial to see if it --

23 MR. WONG: Yes.

24 DR. WALLIS: So the spikes have a  
25 frequency or a time of duration of four seconds or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 something?

2 MR. KAI: No, the actual time --

3 MEMBER BROWN: It's supposed to be slowed  
4 down for four seconds.

5 MR. KAI: The time constant slows down the  
6 response. I mean, if you're in the frequency of the  
7 spikes, the time constant, that's what you're asking.  
8 Right? The frequency, not the duration.

9 DR. WALLIS: And you're going to get a  
10 spike and its length is something like four seconds.  
11 Is that what you're doing?

12 MEMBER ARMIJO: No, it's less than that.

13 MR. KAI: It's less than that.

14 DR. WALLIS: Less than that?

15 CHAIRMAN SIEBER: Yes.

16 MR. KAI: And so that the filter will  
17 assure that you don't really --

18 DR. WALLIS: How often does this spike  
19 happen? Is it something that's very regular? I mean,  
20 it happens -- If it's very regular, I think you would  
21 have fatigue concerns.

22 CHAIRMAN SIEBER: Somewhere. Well, if the  
23 temperature is very small.

24 DR. WALLIS: Very small.

25 (Simultaneous conversations.)

1 MEMBER BROWN: It temps together. You get  
2 a little higher.

3 DR. WALLIS: How big is very small?

4 DR. KRESS: Well, they will find out.

5 (Simultaneous conversations.)

6 MEMBER BROWN: That's why I asked whether  
7 it's five or 50 and he said roughly or whatever. We  
8 would like to see that that's confirmed.

9 MR. KAI: Okay. And like I said, I have  
10 this in set point and not in degrees unfortunately.  
11 When we benchmarked this, typically the spikes are of  
12 very short duration, a couple of seconds, and the  
13 frequency is on the order of about -- And it varies.  
14 It could be as much as 30 seconds apart or --

15 MEMBER BROWN: So you have to come in like  
16 that.

17 DR. WALLIS: What's the amplitude?

18 MR. KAI: Unfortunately, what I have is in  
19 terms of the set point, not in terms of degrees and  
20 that's --

21 DR. WALLIS: So what do you call a t hot  
22 if it's oscillating like this? I mean, when you say  
23 t hot max in your table do you mean the maximum of the  
24 spike or the maximum of the average?

25 MR. KAI: The maximum of the average.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: So what's a fair measure of  
2 t hot if you have these spikes in there in terms of  
3 its effect on materials and so on?

4 MR. KAI: Well, I can tell you that we  
5 used the average temperature for the impact on  
6 materials. I mean, it does again --

7 DR. WALLIS: Doesn't the effect on  
8 materials go up rather rapidly with temperature?

9 MEMBER BANERJEE: It should be  
10 exponential.

11 CHAIRMAN SIEBER: Or you just average.

12 DR. WALLIS: You think that's okay?

13 MR. KAI: Not bad.

14 DR. WALLIS: Just fine. It will get  
15 washed out in the transit of the --

16 CHAIRMAN SIEBER: It's random in the  
17 thermal dynamics.

18 MEMBER BANERJEE: But why does it affect  
19 the --

20 (Simultaneous conversations.)

21 MEMBER SHACK: What you need to do is  
22 establish that to the degrees.

23 DR. WALLIS: That's right.

24 (Simultaneous conversations.)

25 MEMBER ABDEL-KHALIK: Based on your P-bar

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 limit of 1.3, the potential maximum value of this  
2 spike is about 19 degrees. So what we need to find  
3 out is what is the actual magnitude of these spikes.

4 MR. KAI: Yes, and maybe we can have Bob  
5 Branum, our INC expert.

6 MR. BRANUM: We're gathering data for the  
7 spikes from studies we did that preceded the  
8 modification we're proposing for the plant. We'll  
9 have that available for you when we get it. Okay.

10 MR. KAI: Like I said, I have the studies  
11 in set points rather than temperature.

12 MR. RUSSELL: Can I add something to the  
13 discussion with regards to these spikes?

14 MR. KAI: This is Paul Russell, our  
15 Operations representative on our --

16 MR. RUSSELL: My name is Paul Russell.  
17 I'm a licensed operator at the Unit 3. From the  
18 operational standpoint and you did mention that they  
19 are just an annoyance to the operators, this is  
20 actually a very infrequent annoyance to us. We very  
21 rarely get the alarms that come in. It's not  
22 something that we'll see a drastic jump-up in our  
23 temperature indications. So it is a spike, not  
24 necessarily electronic-wise. It's a true indication  
25 of the temperature, but it is a very infrequent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 occurrence. It's not something that we see on a very  
2 regular basis.

3 DR. KRESS: But it's infrequent at the  
4 location you're measuring. Other parts of the system  
5 where you're not measuring, it could be happening all  
6 the time. I think that's really if you get into a  
7 materials concern that's where it would happen. But  
8 this sounds like a generic kind of issue for PWRs --

9 MR. KAI: Yes, it is.

10 DR. KRESS: It's not unique to the SPU.

11 MEMBER BANERJEE: But going back to what  
12 you are showing on the slide, you are saying you're  
13 installing an electronic filter and the purpose of  
14 this is to smooth out these spikes I take it.

15 MR. KAI: Yes.

16 MEMBER BANERJEE: But how does it affect  
17 the DNBR margin? On the top of the slide, you say  
18 DNBR margin and that's what I don't understand.

19 MR. KAI: Okay. Let me explain what we  
20 did because like I said, what we did in this cycle was  
21 we raised the set point. The alarm follows with the  
22 set point. It's like a couple of degrees different  
23 from the set point. So in this analysis because of a  
24 potential when we started up from the last cycle to  
25 get the spikes and cause pre trip alarms, they usually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 occur at the beginning of the cycle, we raised the set  
2 point, the OPDT/OTDT set points. So therefore they  
3 will trip later for those events, DNBR events, where  
4 it's credited and as a result you lose DNBR margin.

5 It's not the effect. It's the solution  
6 that we implement to try to overcome these --

7 DR. WALLIS: So you lose some margin  
8 because of this.

9 MR. KAI: What we did for this cycle is we  
10 actually physically raised the set point so it's  
11 closer to break point in order to.--

12 DR. WALLIS: How much do you raise it by?  
13 Three degrees? Four degrees?

14 MR. KAI: It's a complicated thing because  
15 OPDT/OTDT is an equation with coefficients with model  
16  $t$  ave and  $\Delta t$  but what we ended up doing is  
17 raising the set point to as high as we could possibly  
18 make it and still show acceptable results for this  
19 current cycle.

20 MEMBER BROWN: Typically what you do is  
21 move your margin around. You don't just reduce it in  
22 one place. You're usually taking it from someplace  
23 else. So your overall margin may not be changing but  
24 you're using it from someplace else.

25 MR. KAI: Right. We're getting an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operational margin and reducing safety analysis  
2 margin.

3 CHAIRMAN SIEBER: That's why you need a  
4 margin manager.

5 MEMBER BANERJEE: But now with more  
6 channels and these hot conditions and things, you  
7 would expect these events to become more frequent --  
8 Right?

9 MR. KAI: No, I mean, not the frequency.  
10 We did assume that the peaks would get bigger, in  
11 other words, because of the fluid.

12 MEMBER BANERJEE: Why would the peaks get  
13 bigger? Your powers are not higher.

14 DR. WALLIS: It's a flatter --

15 MR. KAI: When we did the initial studies  
16 we assumed that --

17 MEMBER BANERJEE: I'm trying to understand  
18 what's happening. So let me sort of give it back to  
19 you the way I see it. What's happening is that there  
20 are some channels where the outlet temperature is  
21 hotter than other channels. Because we have  
22 incomplete mixing before it gets to the hot leg, some  
23 of this hot fluid is going directly into the hot leg  
24 without having mixed with the colder fluid. Right?

25 MR. KAI: Correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BANERJEE: So that gives you a  
2 temperature dispersion because of the lack of mixing.  
3 That has to be bounded obviously by your 19 degrees  
4 which is what Said calculated. It has to be less than  
5 that. If it is more than that, there's some other  
6 effect happening.

7                   MR. KAI: Right.

8                   MEMBER BANERJEE: But let's say it's five  
9 degrees or ten degrees or something due to this. Now  
10 as you are going to have more channels now which are  
11 going to produce hot fluid, you are going to have  
12 higher frequency of these spikes. The amount may not  
13 change because your power per channel is not  
14 increasing very much. Is that the correct idea?

15                  MR. KAI: Yes.

16                  MEMBER BANERJEE: The magnitude should not  
17 increase, but the frequency should.

18                  MR. KAI: It's possible. Correct. But  
19 again, I would expect --

20                  MEMBER BANERJEE: Or is there something  
21 else happening? I don't understand.

22                  MR. KAI: No, I mean, how often it happens  
23 is more of a function of how the flow rotates or it  
24 goes from loop to loop. Okay. If it stays constant,  
25 the fact that you have higher temperatures of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 assemblies it doesn't make any difference. You're  
2 still going to see the same. You'll see a constant  
3 temperature.

4 MEMBER BANERJEE: And then either you're  
5 going to have a higher frequency or a longer duration,  
6 one or the other, because what you're saying is that  
7 there's incomplete mixing plus some sort of overall  
8 rotational behavior to the flow. I'm not clear why it  
9 happens, but let's say that's what happens. So you  
10 visit different hot legs with some frequency more or  
11 less. Without looking at the data, I have no idea  
12 what's going on. But assuming that this is some sort  
13 of flow pattern --

14 DR. WALLIS: It might be less evident.  
15 They have a flatter power distribution --

16 MEMBER BANERJEE: I know.

17 DR. KRESS: That may be the other way to  
18 go.

19 (Simultaneous conversations.)

20 MR. KAI: And that's exactly -- I mean,  
21 that's why the model -- We have to put in a solution  
22 for uprate and that's why we've done this, putting in  
23 a hot leg filter much like our sister plants.

24 DR. WALLIS: If you take the filter, then  
25 you're going to miss diagnosing what's really

1 happening. So you ought to have at least a  
2 measurement of the real signal. You use the filter  
3 for your set points and stuff.

4 MR. KAI: Yes.

5 DR. WALLIS: But you ought to have a real  
6 indication because as you increase the power you want  
7 to know how does this anomaly change with power level.  
8 So you really have to keep recording the real signal.

9 MEMBER BANERJEE: Yes. It's an electronic  
10 filter for the purposes of a set point or whatever.

11 MR. KAI: Yes, but that's only for the set  
12 point.

13 MEMBER BANERJEE: For the set point.  
14 Right. You should be actually logging the data and  
15 trying to understand this thing. I mean, in some way,  
16 is it changing as you're raising power or what's  
17 happening to it?

18 MEMBER MAYNARD: I'm assuming that you  
19 also have thermal couples in the core. But we're  
20 talking about the RTDs used for plant trips and  
21 alarms.

22 CHAIRMAN SIEBER: In the loops.

23 MEMBER MAYNARD: But typically that's a  
24 measuring issue. You really have to use thermal  
25 couples in the head to see or in that area --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: In that area.

2 MEMBER MAYNARD: -- To see what the  
3 temperatures and variations are really doing.

4 (Simultaneous conversations.)

5 CHAIRMAN SIEBER: Those thermal couples  
6 don't alarm.

7 MEMBER MAYNARD: Right.

8 CHAIRMAN SIEBER: So the operator is  
9 actually going to look at that in order to be able to  
10 see what's going on.

11 MEMBER BANERJEE: They are usually very  
12 slow anyway, they are filtering out temperature spikes  
13 to --

14 DR. WALLIS: What will concern me is what  
15 you would measure would depend on where you put the  
16 thermal couple. I don't know. This hot fluid, does  
17 it go to the top of the hot leg? Does it go to the  
18 bottom? They presumably tend to go to the top of the  
19 hot leg. So if you put your thermal couple lower  
20 down, you won't see it.

21 MR. KAI: And actually what you see,  
22 normally you would have -- These are RTDs. They're  
23 not thermal couple -- We will have them at various  
24 locations around the pipe and so you see them on one  
25 of them and not the other. It varies and it changes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MEMBER BANERJEE: So you are putting the  
2 filter only so that you don't have to do things to  
3 your set point. It's to remove an operational --

4 MEMBER ARMIJO: That's not what their  
5 license is. The question is they put their filter at  
6 the input to the t hot signals. The t hot input is  
7 where the filter comes. In other words, you take --  
8 That's the way I'm reading the document and I may be  
9 wrong. So the data, the output of the RTDs is fed  
10 through a filter before it gets to the measurement  
11 stuff where you do all the gains and zeros and all  
12 that kind of stuff and then before it goes and does t  
13 ave and the delta-T. That's the way I read Page 2.4-  
14 10.

15 MR. KAI: Correct.

16 MEMBER BROWN: So it's not just a filter  
17 on the alarm. It's a filter on the whole t hot and  
18 the whole --

19 (Simultaneous conversations.)

20 DR. WALLIS: You don't want to do that.  
21 You really want to know what the oscillation is, don't  
22 you? The real thing? You have to record an  
23 unfiltered signal somewhere.

24 MR. BRANUM: Excuse me. My name is Robert  
25 Branum and I'm the INC Engineer on Project. The t hot

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 signals will be available in our plant process  
2 computer unfiltered so we can monitor those.

3 DR. WALLIS: Okay.

4 MR. BRANUM: Where we are installing the  
5 filter is downstream of where the three t hots per  
6 loop are combined and that's the point at which they  
7 will be filtered. The filter signal will be used as  
8 an input to the t hot or the t ave and the delta-t  
9 circuits which are computing the set points of the  
10 trips for the OP and OT Delta-t safety functions.

11 MEMBER BROWN: So you take the raw data  
12 and you feed it off to another acquisition system.

13 MR. BRANUM: That's correct.

14 MEMBER BROWN: To go along with the normal  
15 operational instrumentation. Is that the way?

16 MR. BRANUM: That's correct. Now a couple  
17 of points that have been talked about here. Michael  
18 mentioned that in this present cycle I want to clarify  
19 the present operating cycle, now that's not post SPU  
20 but the present operating cycle, we implemented an  
21 optimization program where we actually raised the set  
22 points of our OP/OT Delta-t functions to get them  
23 above these spikes that we've been seeing. Okay. And  
24 as a result, it ate into some of our DNBR margin.

25 Now implementing the SPU, that will not be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 an acceptable result. So by installing the t hot  
2 filter, we'll be able to reduce the set points back  
3 down and it actually gained the margin back because  
4 the t hot filters will be filtering out the momentary  
5 spikes that we're seeing in the individual combined t.  
6 hot channels.

7 MEMBER BROWN: Another thing. Does a time  
8 response increase, if that reduction in set point is  
9 a far greater effect than the time response, the four  
10 second time response, which you refer to these as four  
11 second time response filters or seconds filters?  
12 Excuse me.

13 MR. BRANUM: Yes, the filters are four  
14 seconds. The duration of the spikes are much shorter  
15 than the four seconds that we've seen to date.

16 MEMBER BROWN: Like what? A half a  
17 second? A quarter of a second?

18 MR. BRANUM: A second or so.

19 MEMBER BROWN: Okay.

20 MR. BRANUM: The result of the four second  
21 filter time delay has been considered in the dynamic  
22 safety analyses and in response to the plant to the OP  
23 and OT Delta-t trips.

24 MEMBER BROWN: So the tradeoff is positive  
25 relative to the reduction in set points does more than

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 delay, the additional delay, in the time response of  
2 the incident.

3 MR. BRANUM: That's correct.

4 MEMBER BROWN: To help you recover that  
5 margin.

6 MR. BRANUM: That's correct.

7 MEMBER BONACA: Now you made a statement  
8 before that this has been implemented before in other  
9 plants.

10 MR. BRANUM: Yes. Correct.

11 MR. KAI: There are a number of  
12 Westinghouse plants that have implemented it. I don't  
13 --

14 MEMBER BROWN: Do you want to make that  
15 statement before you know?

16 MR. KAI: I don't know the names of --

17 MR. HUEGEL: This is Dave Huegel with  
18 Westinghouse and if you look at any of the  
19 Westinghouse plants out there you are going to see  
20 fluctuations in the t hot signal and depending upon if  
21 you have fast response or slow response RTDs installed  
22 in the thermal wells and they are at 120 degree angles  
23 about the hot leg and we take the average of those  
24 signals, you want to make sure that the spiking that  
25 you're seeing and we see this in all plants that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you're filtering that so that it doesn't cause an  
2 unwanted trip signal.

3           And as part of the evaluation for EPU or  
4 for any plant for that matter, we do take into  
5 consideration the set point, how high we set it and  
6 all the associated dynamic compensation. It's a very  
7 complicated process that we go through to ensure that  
8 the plant has sufficient operating margin. But again,  
9 you'll see this fluctuation in the hot signal on any  
10 plant that's out there operating and we get an average  
11 signal again from each of the four loops and we've  
12 installed this optimized set point as we've called  
13 probably on, I'd say, close to eight to ten plants  
14 where we looked at the entire package of the set  
15 point, the OTDT and OPDT where they are set and also  
16 the filters we have in the RTDs and then also the  
17 dynamic compensation and the lead lag functions on the  
18 average and also on Delta-t to ensure that you have (1)  
19 met your DNB criterion and (2) ensure that you have  
20 sufficient operational margins so that the plant can  
21 safely operate without getting spurious trips. Does  
22 that answer your question?

23           MEMBER BANERJEE: This whole methodology  
24 has come before the Committee before and sort of  
25 exposed in detail and been approved in some ways.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HUEGEL: The methodology for  
2 calculating the set points is contained in 8745 which  
3 was approved in 1986.

4 CHAIRMAN SIEBER: W-cap.

5 MR. HUEGEL: Right. I'm sorry. It's a  
6 Westinghouse W-cap.

7 CHAIRMAN SIEBER: We don't approve W-caps.  
8 But the staff does.

9 MR. HUEGEL: But it's a methodology that  
10 we've been using in Westinghouse plants for years.  
11 Does that help?

12 MEMBER BANERJEE: Yes. It helps. I'm not  
13 -- I still don't understand what --

14 DR. KRESS: Why this is happening?

15 MEMBER BANERJEE: Yes, why this happens.  
16 But more than that, it seems by doing a little  
17 filtering you're getting some DNB margin. DNB is a  
18 real thing. How does it change the margin? That's  
19 what I don't understand.

20 MR. HUEGEL: As it was explained, as Mike  
21 had stated, what you're doing is you're changing not  
22 the initial condition but you're changing where you're  
23 tripping and that is how it's affecting your DNBR. If  
24 you delay because you've added a filter, when you trip  
25 on the OPDT/OTDT trip function you are affecting the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DNBR and that's how it plays out, not as an initial  
2 condition per se, but you're changing where you trip  
3 the plant and that's how it affects the DNBR. You run  
4 these different transients. The protection function  
5 kicks in and trips you so that you meet the applicable  
6 acceptance criterion. Typically for OPDT/OTDT we're  
7 trying to demonstrate the DNB design basis is  
8 satisfied.

9 MEMBER BONACA: Have you noticed a  
10 dependency between the frequency of the spiking and  
11 the amount of new fuel that you put in the reactor?

12 MR. HUEGEL: No, I don't think that  
13 they're related. I'm sorry. The question again.

14 MEMBER BONACA: I was wondering was there  
15 a dependency in the frequency to the spiking occurs in  
16 the number of new fresh fuel assemblies you put in  
17 there.

18 MR. HUEGEL: No, there's not any relation.

19 MEMBER BONACA: It seems to be a signature  
20 of the plant.

21 MR. HUEGEL: I think you would see --  
22 You're going to see that fluctuation in the t hot  
23 signal no matter what plant you look at and actually  
24 it's a problem because in the safety analysis we don't  
25 predict spiking in the safety analysis. If you would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 look at the t hot signal for any of the safety  
2 analysis that we do (1) it's a nice signal. Yet (2)  
3 at the plant they are incurring these spikes which  
4 when you amplify it with lead lag function gives you  
5 trips much sooner than we would predict in a safety  
6 analysis.

7 I wish I could take credit in the safety  
8 analysis for the spiking that occurs at the plant. I  
9 could give you a much better safety analysis answer.  
10 But again, you do have to make sure that you have  
11 filtered the t hot signal so that you aren't getting  
12 spurious trips and that's what we were trying to do.  
13 As Mike had explained earlier is when we evaluated the  
14 EPU we wanted to make sure that based upon  
15 historically what we've seen for a t hot signal that  
16 the filter that we'd be installing in addition to the  
17 exact set point was such that (1) you met your DNB  
18 design basis and as I stated earlier (2) also you  
19 would have sufficient operational margin. It's a  
20 fairly rigorous and detailed process that we go  
21 through to ensure that that all fits together.

22 MEMBER MAYNARD: I have a general question  
23 on this. I don't know that much about this system,  
24 but does Westinghouse or does the staff understand the  
25 mechanisms that are causing these temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 fluctuations and have they dispositioned those? The  
2 temperature changes are small. At least, that's what  
3 we're told. So maybe there is no problem. But it just  
4 seems like nature is trying to tell you something and  
5 you're filtering it out. And that's a little bit of  
6 a worry.

7 MR. HUEGEL: Again, what we're seeing in  
8 this t hot spiking is applicable to any plant. You're  
9 going to see noise in the RTD signal for any plant  
10 that you're looking at when you're measuring the t hot  
11 signal. We do try to account for it in a number of  
12 ways. Again, we have three RTDs in the hot leg to  
13 make sure that we have an average signal.

14 We also have in the uncertainty  
15 calculations a PMA term to make sure that we've  
16 accounted for any streaming that you would see in the  
17 hot leg so that that is accounted for not only in your  
18 t ave uncertainty that we've accounted for in the  
19 safety analysis but it also factors in the uncertainty  
20 calcs that go into the OTDT and OPDT. So we've  
21 accounted for them in two different places in addition  
22 to filtering the signal. But this is something you  
23 would see at any plant.

24 DR. KRESS: It's generic. It's not  
25 unique.

1 MR. HUEGEL: Yes. And again, the spiking  
2 is relatively small in terms of magnitude. But it can  
3 be depending upon if your plant has a fast response  
4 RTD or a slow response RTD as we call them. Your  
5 spiking can vary. But it can be tough to deal with.  
6 Again, I wish in the safety analysis space, we could  
7 take credit for it because they give a much earlier  
8 trip than the safety analysis would predict. Do you  
9 want to --

10 MR. KAI: Anything else that I can answer  
11 about that?

12 MEMBER BROWN: I had just a real quick  
13 question. One of your mods is the elimination of this  
14 automatic rod withdrawal feature.

15 MR. KAI: I'll get to that next.

16 MEMBER BROWN: Okay, Mike. What do you  
17 lose when you eliminate that feature from a safety  
18 side?

19 MR. HUEGEL: A nasty accident.

20 DR. WALLIS: What do these spikes look  
21 like? You have a hot spike. Do you have a cold spike  
22 as well?

23 MR. KAI: No.

24 DR. WALLIS: Just an average and then a  
25 hot spike? Is it like that?

1 MEMBER BROWN: You wouldn't expect a cold  
2 spike.

3 DR. WALLIS: No, a cold spike in the hot  
4 leg. And if you get hot spikes, you might have cold  
5 spikes, too, because cold eddies can come in as well  
6 as hot eddies.

7 MR. KAI: But the cold -- Remember you  
8 have the RCP and the --

9 DR. WALLIS: In the hot leg. You get cold  
10 spikes, the temperature goes down.

11 MEMBER MAYNARD: But you only get trip or  
12 alarm based on --

13 DR. WALLIS: I'm interested in what it  
14 looks like and if the cold spikes are bigger, then I  
15 might be more worried about fatigue. It would be nice  
16 if you could show the spikes. Give us a picture.

17 Can you sometime later in the day give us  
18 a trace of these spikes? That would help a great  
19 deal.

20 MEMBER BANERJEE: It would be very nice to  
21 see what really turns up.

22 MR. HUEGEL: They are looking into getting  
23 that information.

24 DR. WALLIS: Thank you. That would help.

25 CHAIRMAN SIEBER: What I would like to do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is we have some outside things that some folks have to  
2 do and I'd like to end with Slide 15 and then break  
3 for lunch at that time.

4 MR. KAI: Okay. Now we're going to talk  
5 about the outer rod withdrawal.

6 CHAIRMAN SIEBER: We're on 14.

7 MR. KAI: We're still on 13. Okay. What  
8 we're going over is the modification section. On  
9 Slide 13 what we show is what we've done to assure  
10 that coming out of SPU we will have DNBR margin for  
11 our plant. We've talked about the other three items  
12 already, WRB2, WRB2M, the measured flow rate and the  
13 radial peaking factor and we've talked about the  
14 second bullet in terms of -- We talked about the first  
15 bullet which is the outer rod withdrawal.

16 The limiting DNBR event from Millstone 3  
17 is the steam line break with coincident rod withdrawal  
18 and we have to assume that because DNRs are not  
19 qualified for a steam line break inside containment we  
20 postulate that the rod control system will be -- We  
21 will be able to withdraw the control rods in response  
22 to the steam line break and exacerbate the power  
23 excursion. So what we're doing like a number of other  
24 plants that have had this problem, we are essentially  
25 eliminating the capability for the rod control system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to automatically withdraw the control rods. So in a  
2 steam line break, we would not have the control rods  
3 withdraw.

4 Now obviously the rod control system is  
5 for the operators. I mean that helps them manage the  
6 plant. Typically, for start ups where we're going to  
7 be withdrawing control rods, that's all done manually.  
8 We do not generally -- We never really have the  
9 operators increase power using an automatic rod  
10 withdrawal system. The operators must maintain  
11 positive control of reactivity. So it is very rarely  
12 used in terms of the operators.

13 DR. KRESS: So that was designed in as a  
14 nice feature to have, but it turns out it's not a very  
15 good thing to have.

16 MR. KAI: Yes, and you could probably go  
17 back and look --

18 CHAIRMAN SIEBER: They are between the one  
19 that's where an operator could look at it and smooth  
20 it out.

21 MR. KAI: Most of these systems, I'm  
22 talking about my old history here, they were designed  
23 in the early days for load foul where the plant would  
24 automatically increase power. We don't do that. So  
25 this feature, we'll obviously check with our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operations staff to make sure that this will have no  
2 impact on the capability to increase power and start-  
3 ups, etc.

4 MEMBER ARMIJO: How do you normally  
5 operate when you're 100 percent power? The rods on  
6 auto or rods in manual?

7 MR. KAI: Rods on auto.

8 MEMBER ARMIJO: There are some advantages.  
9 I think the overall advantage of deleting the  
10 automatic rod withdrawal outweighs the other benefit.  
11 The other is that there is a change. The operators  
12 hear the rods clicking immediately and alerts them  
13 that there is a change.

14 (Simultaneous conversations.)

15 MR. KAI: Now, remember, normally you want  
16 100 percent power.

17 MEMBER ARMIJO: Right.

18 MEMBER BROWN: But occasionally you'll get  
19 one clicking out of sync.

20 MR. KAI: Okay. And so that's another  
21 thing that we have done to restore DNBR margin. It  
22 essentially eliminates that as a DNBR limiting event.

23 We've also decreased the power range high  
24 flux neutron set point from 118 percent to 116.5  
25 percent to assure that for rod withdrawals of power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that we will maintain DNBR margin. So we made part of  
2 our modifications primarily to try and restore DNBR  
3 margin and if you look at the next page you can see  
4 how this is done and I tried to make this  
5 nonproprietary. So that's why there's no numbers in  
6 some of these columns.

7 But if you look, I explain how DNBR margin  
8 is calculated. We start with a correlation limit and  
9 that is based upon how well the correlation matches  
10 the experiment and the 9595 limit for the WRB2M is  
11 1.14.

12 The next step that we do is we define a  
13 design limit. Again, this is proprietary, but we  
14 statistically combine the uncertainties and the  
15 initial condition parameters. Let's say temperature,  
16 pressure, peaking, etc. to statistically combine the  
17 uncertainties and get a design limit so that when we  
18 do the DNBR analysis, it's done at nominal conditions.  
19 The statistical uncertainties for the parameters have  
20 been statistically combined.

21 DR. WALLIS: What sort of number do you  
22 come up with typically?

23 MR. KAI: It's usually only 1.2.

24 DR. WALLIS: One point two. Okay.

25 MR. KAI: Proprietary numbers is my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 problem.

2 Now if you look at our current cycle, we  
3 have a safety analysis. That's a DNBR configuration  
4 management tool that we use with Westinghouse's  
5 methodology. We establish a conservative limit which  
6 we call the safety analysis limit. I want to make  
7 sure it's not safety limit. It's called safety  
8 analysis limit. We do all the Chapter 15 analyses to  
9 show that we meet the more conservative safety  
10 analysis limit.

11 DR. WALLIS: The number that you simply  
12 arbitrarily define, isn't it?

13 MR. KAI: That's correct. It's a number  
14 that we arbitrarily defined to ensure that --

15 DR. WALLIS: When you changed it from 1.39  
16 to 1.6, does that mean that you're now getting more  
17 safety margin?

18 MR. KAI: Correct.

19 DR. WALLIS: Okay.

20 MR. KAI: And the benefit there like I  
21 said before is the filter because previously we had  
22 moved the safety analysis limit all the way up to get  
23 as much margin as we could so that the set point would  
24 be these little spikes that we get --

25 DR. WALLIS: That's interesting because I



1 would have thought with the power uprate that you  
2 could actually reduce this. But you increased it.

3 MR. KAI: Yes. Obviously, that's a big  
4 concern.

5 MEMBER BANERJEE: They can use the filter.

6 MR. KAI: Right. That was exactly --  
7 You're exactly right, Graham. That's what we're  
8 concerned about initially when I did this because I  
9 knew we had no -- We do not have margin coming out of  
10 this if we continued our same practice in terms of  
11 operational margin for this effect.

12 MEMBER BROWN: What's a relationship  
13 between DNBR design limit and your safety analysis.  
14 I haven't seen that differentiation before.

15 MR. KAI: Okay. That --

16 MEMBER BROWN: Should I be educated in  
17 some other point?

18 MR. KAI: Remember the 1.0 obviously, is  
19 the DNBR, a DNB at 1.0, 1.14 is the 95th/95th  
20 percentile that bounds the data used for the  
21 calculation of the uncertainty. Design limit  
22 statistically combines this 9595 limit with  
23 uncertainties --

24 MEMBER BROWN: You use the probability as  
25 opposed to the deterministic approach.

1 MR. KAI: Yes.

2 MEMBER BROWN: That's what that is, isn't  
3 it?

4 MR. KAI: Okay. Now we're talking about -  
5 -

6 MEMBER BROWN: Forget that statement.  
7 Just go on.

8 MR. KAI: Okay. Not only obviously are  
9 there uncertainty in the correlation but there's  
10 uncertainty in the your instrumentation and initial  
11 conditions. For example, for t ave and pressure -- .

12 MEMBER BROWN: Got it.

13 MR. KAI: So those uncertainties in  
14 instrumentation are then calculated and then  
15 statistically combined with the DNBR uncertainty.  
16 Then the DNBR analysis at nominal conditions because  
17 the uncertainty has been factored into design limit.

18 MEMBER BROWN: Okay.

19 DR. KRESS: How does that relate to the  
20 safety analysis one?

21 MR. KAI: Okay. So in theory, you can go  
22 right up to the design limit and assure yourself you  
23 would not be in DNB. But in practice that's not a  
24 good idea. I mean obviously issues will come up over  
25 the other times you're operating. So what we do is we

1 as a utility establish --

2 (Simultaneous conversations.)

3 MEMBER BROWN: The size of a design basis  
4 -- One is a design basis consider where you do your  
5 design design and the other part is how you do the  
6 safety analysis relative to that. You just made it  
7 higher.

8 MR. KAI: Right.

9 DR. KRESS: This also allows the margin  
10 for fuel design if you had any issues with that.

11 MR. KAI: Right.

12 DR. KRESS: This allows --

13 MR. KAI: And that is shown below in fuel  
14 issues and instrument biases which cannot be readily  
15 combined because some of them have biases.

16 MEMBER BANERJEE: I guess it really --  
17 What you call the generic margin, it would be an  
18 interesting number to know how's that affected for --

19 CHAIRMAN SIEBER: Proprietary.

20 MR. KAI: It's proprietary.

21 MEMBER BANERJEE: Well, you can -- I guess  
22 after the meeting. Right?

23 CHAIRMAN SIEBER: Well, okay. We'll do it  
24 after lunch. Do you want to --

25 MR. KAI: Yes. I think this is probably

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a good stopping point unless you want me to go on.  
2 Would you like me to go onto 15?

3 CHAIRMAN SIEBER: Is this a good stopping  
4 point?

5 MR. KAI: This is the generic --

6 CHAIRMAN SIEBER: Or is the end of this  
7 slide a good stopping point?

8 MR. KAI: The end of slide 14.

9 CHAIRMAN SIEBER: Okay.

10 MR. KAI: So like we pointed out, we do  
11 have a penalty for -- When we did the initial -- When  
12 we initially set the safety analysis limit, we  
13 underestimated what we needed for -- from power so  
14 instead of redoing all the calcs that we'd done we  
15 assessed that as an additional penalty against the  
16 generic margin.

17 MEMBER BROWN: So this is -- I was kind of  
18 trying to figure that out. This is a bank account  
19 you're keeping.

20 MR. KAI: Yes. Correct. It's a bank  
21 account.

22 MEMBER BROWN: You can only go in and you  
23 can only withdraw so much as you go through and find -  
24 - So you allow yourself to not meet your requirement.

25 CHAIRMAN SIEBER: Right.

1 MR. KAI: Yes, and typically like I said,  
2 that was not the ideal solution.

3 CHAIRMAN SIEBER: You want the margin to  
4 keep --

5 MEMBER BROWN: I'm seeing that. That's  
6 why I had to ask.

7 MR. KAI: So the net result is if you  
8 subtract these penalties from the generic margin you  
9 get really truly what's available margin for issues  
10 that may come up or future problems.

11 DR. WALLIS: So what are all these blanks  
12 in the table? Why didn't you just put numbers there?

13 MR. KAI: Proprietary.

14 DR. WALLIS: Proprietary?

15 CHAIRMAN SIEBER: Trying to keep it such  
16 that --

17 DR. WALLIS: You mean, I have to read  
18 those.

19 MEMBER BROWN: No, there's another table.

20 DR. WALLIS: There's another table.

21 MEMBER BROWN: It has some of them for  
22 those who are able to see it, I guess.

23 CHAIRMAN SIEBER: But we have to close the  
24 session.

25 MEMBER BROWN: And we don't want to do

1 that.

2 CHAIRMAN SIEBER: Right.

3 MEMBER ABDEL-KHALIK: Are you going to  
4 continue with Slide no. 15?

5 MR. KAI: Yes. Okay. Now let me just go  
6 on and go past 14. What this shows are the DNBR  
7 results for all the different transients that --

8 MEMBER ABDEL-KHALIK: What do you use W3  
9 for?

10 MR. KAI: W3 is used where the WRB2M does  
11 not apply. That's used for low pressure transients,  
12 for example, steam line break where the pressure and  
13 which you're calculating DNBR is outside the range of  
14 the correlation. It's also used for rod withdrawal  
15 subcritical where DNBR is occurring below the first  
16 grid because the correlation takes into account the  
17 mixing grids. So for those two transients, we would  
18 use either WRB2 or W3 depending on what is appropriate  
19 for that transient.

20 DR. WALLIS: The only place here you seem  
21 to be close to some limit is this rod withdrawal from  
22 subcritical.

23 MS. YOUNG: Yes, and that's a little  
24 misleading. Okay. And the big thing there is to look  
25 at the pumps.

1 DR. WALLIS: Yes, why the two instead of  
2 three?

3 MR. KAI: This has been a limiting  
4 transient for Millstone 3. I don't know. Maybe it's  
5 Cycle 4. So what we did, the standard methodology for  
6 Westinghouse is two RCPs are running when you're  
7 subcritical. We changed our specification to require  
8 three RCPs whenever we are capable of withdrawing  
9 control rods when they are coupled. So therefore our  
10 current analysis is based on withdrawal of the three  
11 RCPs.

12 When we went to SPU, we actually showed it  
13 was okay at two RCPs. We had no intention to run  
14 three.

15 DR. WALLIS: If you would run three, it  
16 would look much better.

17 MR. KAI: Exactly right. We had no  
18 intention of changing the spec.

19 DR. WALLIS: So apples to apples, you'd  
20 actually come out better.

21 MR. KAI: Yes. Correct.

22 DR. WALLIS: Why don't you show us that as  
23 well?

24 MR. KAI: We did not calculate with three  
25 RCPs because we made it with two RCPs. But like I

1 said, we had no intention of changing the  
2 specification. So yes, I --

3 CHAIRMAN SIEBER: You don't withdraw rods  
4 until you're at temperature with four pumps running.

5 MR. KAI: Correct.

6 DR. WALLIS: Right.

7 MEMBER BROWN: This assumes you do.  
8 Right?

9 CHAIRMAN SIEBER: Pardon?

10 MEMBER BROWN: This assumes you do.

11 CHAIRMAN SIEBER: Well, this is --

12 (Simultaneous conversations.)

13 MR. KAI: This is a failure. Okay. We're  
14 looking at some kind of either a failure in the  
15 control system -- But now that we've eliminated the --

16 CHAIRMAN SIEBER: You eliminated the  
17 automatic rod withdrawal. So it has to be a failure  
18 by the operator.

19 MR. KAI: The operator. Correct.

20 DR. WALLIS: Yes.

21 MR. KAI: So yes.

22 MEMBER BROWN: But your tech spec still  
23 requires three.

24 MR. KAI: It will require three and we did  
25 not change that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 DR. WALLIS: This is from subcritical  
2 though. This is with a steam line break maybe.

3 MR. KAI: No.

4 CHAIRMAN SIEBER: Okay. Go ahead.

5 MR. KAI: Anyway, what this shows is  
6 current and SPU and as you can see in some cases we're  
7 getting margin and that is really what the net result  
8 of all the changes that we made. Even at the higher  
9 power we're maintaining DNBR margin and that was our  
10 goal and not to use --

11 CHAIRMAN SIEBER: Some of that is changes  
12 in set points. Some of it is changes in analysis  
13 methods. Right?

14 MR. KAI: Yes. Correct. And to me the  
15 big part is the change in the hardware changes that we  
16 made.

17 MEMBER ABDEL-KHALIK: Can you explain to  
18 me physically how you would gain that much margin for  
19 the inadvertent opening of a PORV?

20 (Simultaneous conversations.)

21 MR. KAI: No, this is a short transient.  
22 Remember DNBR is going to be a problem primarily for  
23 power increases and temperature increases. In this  
24 case, the pressure decreased. So this is primarily a  
25 function of the DNBR correlation and those types of

1 changes.

2 MEMBER ABDEL-KHALIK: There is that much  
3 difference between the two DNBR correlations, the  
4 WRB2M and WRB2. Is that what you're saying?

5 MR. KAI: No. I can look at this, but  
6 this is -- We'll get back to it.

7 MEMBER ABDEL-KHALIK: Okay.

8 CHAIRMAN SIEBER: Anything else in this  
9 arena? Any questions from anyone?

10 MEMBER BROWN: We're coming back to the  
11 other parts after lunch.

12 CHAIRMAN SIEBER: Yes. We just want to  
13 continue on.

14 DR. WALLIS: So the next slide would wrap  
15 this one.

16 CHAIRMAN SIEBER: This is a natural time  
17 for us to break. Why don't we return at 1:00 p.m.

18 DR. WALLIS: Can't start until 1:30 p.m.  
19 (Simultaneous conversations.)

20 CHAIRMAN SIEBER: Okay, 1:30 p.m.

21 (Whereupon, at 11:54 a.m., the above-  
22 entitled matter recessed and reconvene at 1:30 p.m.)

23 CHAIRMAN SIEBER: Let's take our places so  
24 we can resume the Subcommittee on Power Upgrades. Are  
25 we ready?

1 MR. KAI: Yes. One thing, Mr. Chairman,  
2 I'd like to know is, what do I still owe you in terms  
3 of answers? What do I still owe you in terms of  
4 answers?

5 MEMBER ABDEL-KHALIK: I have two items on  
6 my list.

7 MR. KAI: Okay.

8 MEMBER ABDEL-KHALIK: Delta-t for the hot  
9 leg temperature spikes, both positive and negative,  
10 and why is the DNBR for PORV opening significantly  
11 different? Is that a result of the difference in the  
12 DNBR correlation?

13 MR. KAI: Okay.

14 DR. WALLIS: You were going to give us a  
15 trace of these spikes, you were going to give us  
16 actual trace of temperature in the hot leg so we could  
17 look at it. I think your Westinghouse friend was  
18 going to go after that.

19 MR. KAI: Yes. Understand.

20 CHAIRMAN SIEBER: I have nothing. Does  
21 anybody else have anything, any questions that are  
22 still open?

23 PARTICIPANT: Excuse me, Mike. I can give  
24 an answer in regards to the question about the traces.  
25 We'll get to data from the plant that will show the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 traces for the t h indications, and we'll use that.  
2 We'll provide that to you tomorrow.

3 MR. KAI: I actually have the traces in  
4 terms of the set points. And really, the Delta-t is  
5 just a scaling from the set point, so I could show you  
6 that.

7 To go back to your question on DNBR, the  
8 question was based on the stuck open --

9 MEMBER BROWN: I'm sorry, 15 in your  
10 slides.

11 MR. KAI: Fifteen, right. Okay. There  
12 are two reasons why this has increased, one of which  
13 I explained, which is the DNBR correlation. The 100  
14 percent power, which is what the DNBR correlation  
15 starts, it's significantly higher at the start under  
16 the normal conditions.

17 This DNBR is actually calculated with the  
18 correlation that's in RETRAN, rather than a VIPRE. So  
19 what we have is a crude correlation, I shouldn't say  
20 crude, but we have a correlation of DNBR in RETRAN,  
21 and we use that for events like this where there's  
22 expected to be very large margins to DNBR. And the  
23 way that RETRAN works is that it looks at the delta  
24 between where you start and where your safety limit  
25 is, and so since in both cases you're starting higher

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and the safety limit is higher, when it calculates the  
2 delta in DNBR for the current condition, it's  
3 calculating a much higher value. So it's a simplified  
4 method for estimating DNBR for those events where DNBR  
5 is really not a concern.

6 MEMBER MAYNARD: Was it calculated the  
7 same way for the current and for the --

8 MR. KAI: Yes. Right. But remember it's  
9 a delta. Okay? Because --

10 MEMBER MAYNARD: Well, I understand that,  
11 but it's --

12 MR. KAI: It's the same way. But the  
13 current one reflects both the fact that the initial  
14 DNBR starts off lower because of the WRB2 correlation,  
15 and also that our safety limit is lower. So what it's  
16 doing is calculating the percentage change, and so it  
17 results in the current one being a lot lower.

18 MEMBER ABDEL-KHALIK: I'm sorry.

19 DR. WALLIS: I'm thoroughly confused.

20 MR. KAI: Well --

21 DR. WALLIS: The safety limit has changed.  
22 Why does that change this?

23 MR. KAI: Well, I guess, maybe we'll ask  
24 Dave Huegel to try and take a second shot at  
25 explaining this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HUEGEL: Yes. This is Dave Huegel  
2 with Westinghouse, and as Mike had explained, what  
3 we're doing with RETRAN is really a simplified  
4 calculation for those transients where we don't expect  
5 to see any peaking occurring in the core, like you  
6 would see for a dropped rod event. And what we do, as  
7 Mike had explained, is we take the nominal conditions,  
8 and with the case of your current analysis, calculate  
9 a nominal DNBR based upon the nominal conditions, your  
10 current conditions. And say that gives you a value  
11 for DNBR of 2.2, then you look at the SPU conditions.  
12 You have a higher power level, you have a lower f-  
13 Delta-h, you have a higher flow rate, plus you're  
14 using WRB2M correlation, which gives you some amount  
15 of margin. And you end up with a higher initial DNBR.

16 And what RETRAN is then doing is it takes  
17 the core thermal limits, which are based upon the  
18 VIPRE calculations, which are doing a detailed  
19 calculation of what your limits are in terms of  
20 changes in temperature, pressure and power, and then  
21 you're seeing, during the transient, as my power,  
22 temperature and pressure are changing, how quickly do  
23 I approach the DNBR limit?

24 Now, remember with the current condition  
25 you have a DNBR of 1.39, so you can come down and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you're going to be at a minimum DNBR of 1.584, so  
2 you're significantly above your DNB limit, which for  
3 your current plant condition is 1.39. Now, you go to  
4 the SPU condition, and as Mike had noted, you have a  
5 higher initial DNBR condition. You then go through  
6 the transient looking at your temperature, pressure,  
7 power changes, but instead of being compared to a DNBR  
8 limit of 1.39, you are now doing the calculation  
9 compared to a 1.60 limit. So again, you are having  
10 margin to the limit. You can't compare the two,  
11 because you have a different safety analysis limit.  
12 You have a different nominal initial DNBR limit and  
13 you're using a different correlation. So you can't  
14 compare these one-for-one.

15 But what this is showing you is that you  
16 do have, in both cases, significant margin to limit,  
17 whether it's for the current design, which is a limit  
18 of 1.39 for the safety analysis limit, or whether it's  
19 for the SPU condition, which has a limit of 1.60. But  
20 in both cases --

21 DR. WALLIS: Both are rod withdrawal at  
22 power, which is less than 1.60.

23 MR. HUEGEL: Well, that gets into what  
24 Mike had talked about earlier, with the concerns with  
25 the addition of the filter because of the hot leg

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 spiking, we took some of that margin, and when we ran  
2 all the different cases for the rod withdrawal at  
3 power what we found is we went below the limit of  
4 1.60, so we had to assign some generic DNB margin,  
5 because again, your true limit is the design limit,  
6 which is down around 1.22.

7 DR. WALLIS: So what's the function of  
8 1.6, if the real limit is 1.2? I don't understand  
9 this at all.

10 MR. HUEGEL: The 1.60 is to provide you  
11 with a DNBR limit that again, as Mike had explained,  
12 provides you with margin to assess unknown things that  
13 come up on the plant that you may need to address.

14 DR. WALLIS: But then when you get below  
15 it, you do something else then?

16 MR. HUEGEL: Typically, the process that  
17 we would follow is we would try and demonstrate that  
18 you meet the safety analysis limit across the board.  
19 However, knowing that we have the question about the  
20 spiking in the hot leg temperature, we added a filter,  
21 knowing that yes, you might drop a little bit below  
22 the safety analysis limit, but that's an okay  
23 condition because again, the true limit is the design  
24 limit. And we allocated some amount of generic DNB  
25 margin for that penalty. So in the end, we are still

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 meeting the design-basis limit of the plant.

2 DR. WALLIS: So what does the NRC do then?  
3 They check that you're above the design basis, or  
4 above something else?

5 MR. HUEGEL: The true licensing limit is  
6 the design limit.

7 DR. WALLIS: Well, the safety analysis  
8 limit is a somewhat ephemeral thing that you can vary  
9 around to suit yourselves?

10 MR. HUEGEL: That's probably one term you  
11 could use, yes.

12 MEMBER SHACK: It's the utility's  
13 decision.

14 MR. HUEGEL: Yes. It's really up to the  
15 utility to decide what that limit needs to be.

16 MEMBER BROWN: Under the current design,  
17 isn't the rod withdrawal less than your safety  
18 analysis limit? It's 1.39, it's 1.38. Am I reading  
19 your chart wrong?

20 MR. KAI: No, you're correct.

21 MEMBER BROWN: Before, they had the same  
22 exact generic margin. They had to go borrow. They  
23 were still below the limit.

24 MR. KAI: Okay. Now, let me explain this  
25 slide, which is different.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: He's really digging this  
2 hole.

3 MR. KAI: Okay. We have a different limit  
4 depending on whatever the assembly has, a thimble  
5 plug, or it does not have a thimble plug. And  
6 unfortunately, I put in on Slide 14 the result with  
7 the thimble plug, and I put on Slide 15 without the  
8 thimble plug. So there actually are two limits here,  
9 which I took out to simplify it, but obviously, caused  
10 more confusion.

11 If you look at Slide 14, the 1.29, there  
12 are really two limits, there's a 1.39 and a 1.37,  
13 depending on whether you have the thimble plugs in or  
14 not. So I apologize for that, I really should have  
15 put the two numbers on Slide 14.

16 MEMBER SHACK: So you don't meet it.

17 MR. KAI: No, we do meet the 1.37.

18 MEMBER BROWN: Okay. So the 1.38 goes  
19 with the thimble plugs.

20 MR. KAI: Correct.

21 DR. WALLIS: So what you're trying to  
22 convince us about is that the margins are unchanged.

23 MR. KAI: We've actually got --

24 DR. WALLIS: All your arguments lead to  
25 this conclusion, that the margins are essentially

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 unchanged.

2 MR. KAI: Yes. Right.

3 DR. WALLIS: And it's a little bit fuzzy  
4 what that really means in terms of these numbers.

5 MEMBER SHACK: It's probably safer to say  
6 that he has margin. Whether he's got more margin  
7 because he changed his analysis method and everything,  
8 physically --

9 CHAIRMAN SIEBER: The margins are the  
10 same. The numbers are different.

11 MEMBER MAYNARD: Yes, I'm with you. I  
12 think the important thing is whether or not there's  
13 adequate margin. I think you have to be real careful  
14 when you go to try to compare margins, when you change  
15 analyses, and you change other things.

16 CHAIRMAN SIEBER: Right.

17 MEMBER MAYNARD: And there is a lot of  
18 this, you use it to do set points, and you can move it  
19 around. At the end of the day, though, the bottom  
20 line is do you meet your regulatory requirements, and  
21 do you have margins?

22 DR. WALLIS: And how much margin is  
23 adequate? I don't know. I mean, that seems to be a  
24 very iffy thing.

25 MEMBER SHACK: Regulatory limits.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: Yes. I think one of the  
2 confusing things is that currently SPU analysis in  
3 some cases used different assumptions.

4 MR. KAI: Right. And that --

5 CHAIRMAN SIEBER: So you get different  
6 answers, which are sometimes more difficult to  
7 understand than meets the eye.

8 MEMBER BROWN: Well, they don't scale  
9 directly either. They don't scale directly.

10 CHAIRMAN SIEBER: Right.

11 MR. KAI: Right. You're exactly right.

12 DR. WALLIS: You're trying to explain it  
13 to us, but I think if you tried to explain it to a  
14 judge and a jury, you'd have a tough time, because  
15 they'd want you to show that A is bigger than B, and  
16 which A are you talking about, and which B? It's not  
17 clear.

18 MR. HUEGEL: I mean, at the end of the  
19 day, what we're trying to demonstrate is that the  
20 design limit is satisfied, and that's what we've done.

21 DR. WALLIS: The design limit is  
22 satisfied.

23 MR. HUEGEL: Yes. And that's the true  
24 regulatory limit.

25 DR. WALLIS: Is that really what you're

1 trying to show? That should be what your conclusion  
2 is then. That should be the conclusion then,  
3 shouldn't it?

4 MR. HUEGEL: Yes. That's correct.

5 MR. KAI: Okay. Go on to where we left  
6 off, 16. I'll skip that and go to 17. There's  
7 nothing much on 16, you can look at the results. But  
8 in terms of RCS overpressure and some general  
9 pressure, the results are essentially identical, it's  
10 really unchanged.

11 CHAIRMAN SIEBER: Okay.

12 DR. WALLIS: So let's see now. Let me see  
13 this. Turbine trip is exactly at the limit currently,  
14 or is that a misprint?

15 MR. KAI: No, it's about 20 --

16 DR. WALLIS: Thirty and 20, 30 and 20, the  
17 same.

18 MR. KAI: Right.

19 MEMBER BROWN: All right.

20 MR. KAI: I'm sorry. That's a typo.

21 DR. WALLIS: That's a typo?

22 MR. KAI: Correct.

23 DR. WALLIS: What should it be, should it  
24 be 1340?

25 MR. KAI: I apologize for that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: What should it be? You'll  
2 find it.

3 Well, the message is it's less than 1320.  
4 Is that it?

5 MR. KAI: Yes.

6 DR. WALLIS: And 1302 isn't somehow a  
7 reversal of the two and the zero?

8 (Laughter.)

9 MR. KAI: No.

10 DR. WALLIS: So this is psia assuming an  
11 atmospheric pressure which is average?

12 MR. KAI: Correct.

13 DR. WALLIS: No hurricane, or high  
14 pressure region or something which would change it by  
15 one psi?

16 MR. KAI: Correct. This is assuming  
17 atmospheric.

18 MEMBER ABDEL-KHALIK: So how can -- I know  
19 the difference is relatively small, but how can the  
20 value for SPU for the turbine trip on the primary side  
21 be less than the current value?

22 MR. KAI: Well, the steam --

23 MEMBER ABDEL-KHALIK: No, no. I'm not  
24 talking about the secondary side. I'm talking about  
25 the primary side.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: Right. And you've got to keep  
2 in mind we've also gone from LOFTRAN to RETRAN, and  
3 these small differences, I believe, are due to the  
4 fact that we're using RETRAN versus LOFTRAN. The  
5 current one is LOFTRAN, and the SPU one is done with  
6 RETRAN.

7 In terms of overpressure limit, remember  
8 that we've got pressurizer safety valve that will  
9 assure that the pressure remains at the pressurizer  
10 safety set point, so these small differences are due  
11 to the switch in methodology from --

12 MEMBER ABDEL-KHALIK: But if you had not  
13 changed methodology, shouldn't this number be higher?

14 MR. KAI: No. Again, the pressure is  
15 controlled primarily by safety valve set point, which  
16 is unchanged.

17 MEMBER ABDEL-KHALIK: What is the safety  
18 valve set point? What's the pressurizer safety valve  
19 set point?

20 MR. KAI: Well, we assume 2,500 psi plus  
21 3 percent uncertainty.

22 MEMBER BROWN: To answer your question on  
23 1320, your license says it is 1320, 1319.6.

24 (Simultaneous conversations.)

25 MEMBER BROWN: A .4 psi margin.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Point four psi margin unless  
2 there's a very low pressure region going by.

3 MEMBER BROWN: I'm not going to argue  
4 about what the current might be, it's just that's what  
5 --

6 DR. WALLIS: I'm always bothered by these  
7 psias, because it's presumably psig that bursts  
8 things.

9 PARTICIPANT: I'm surprised that for the  
10 current the turbine trip was still so high, 2731.  
11 You're very close to the limit.

12 MR. KAI: Correct. That's -

13 MEMBER ABDEL-KHALIK: Now, you don't get  
14 an automatic reactor trip on a turbine trip?

15 MR. KAI: We don't credit it.

16 MEMBER ABDEL-KHALIK: You don't credit it.

17 MR. KAI: Correct.

18 (Simultaneous conversations.)

19 DR. WALLIS: Now, let's go back to that.  
20 This is inside containment, isn't it? So the actual  
21 pressure bursting this thing is this pressure minus  
22 the containment pressure? Why is the criterion an  
23 absolute pressure? Isn't there a difference in  
24 pressure between what's inside and what's outside that  
25 bursts these things?



1 CHAIRMAN SIEBER: The containment is sub-  
2 atmospheric.

3 DR. WALLIS: Sub-atmospheric.

4 CHAIRMAN SIEBER: Yes.

5 DR. WALLIS: So I have to take away from  
6 this whatever, 10 psi or something to get the bursting  
7 pressure? Presumably, the ASME gives you the pressure  
8 difference, doesn't it?

9 MR. KAI: Right.

10 DR. WALLIS: So are you quoting an ASME  
11 number or an ASME number plus the containment pressure  
12 here? What are you doing?

13 MR. KAI: First of all, the peak pressure  
14 is at the reactor vessel plant, RCS discharge. And  
15 it's calculated, so the containment impact is not on  
16 this pressure, but on the safety valve. Correct? The  
17 safety --

18 PARTICIPANT: Isn't this measured in the  
19 pressurizer?

20 MR. KAI: Pardon?

21 PARTICIPANT: Is this in the pressurizer?

22 MR. KAI: No. This is at the highest  
23 pressure point in the system.

24 PARTICIPANT: In the RCS.

25 MR. KAI: It's in the RCS. So it would be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 at the pump discharge, with the largest hydrostatic  
2 head at --

3 MEMBER MAYNARD: We have to be careful.  
4 We're talking sometimes RCS, sometimes about secondary  
5 side. You were talking primary side.

6 (Simultaneous conversations.)

7 DR. WALLIS: The secondary side is  
8 somewhat different.

9 MR. HUEGEL: Well, I think if you looked  
10 at the ASME requirements, I think it's 110 percent of  
11 the design pressure, which is given in psig.

12 CHAIRMAN SIEBER: Right.

13 MR. HUEGEL: So you take that times 110  
14 percent, and then if you want to present the result in  
15 psia, you can add the 14.7.

16 DR. WALLIS: Is 2750 an ASME number, or is  
17 it ASME and --

18 MR. HUEGEL: I've seen in the ASME  
19 requirements, the psig. However, I've seen in the  
20 licensing documentation from the NRC, psia. I've seen  
21 results presented typically in a licensing document in  
22 psia.

23 DR. WALLIS: The reason to worry is that  
24 you're so close to the limit that it makes a  
25 difference.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HUEGEL: Understood. But we are  
2 meeting 110 percent of the design pressure, as  
3 required by the ASME requirements.

4 CHAIRMAN SIEBER: That's 2500.

5 DR. WALLIS: That's 2500?

6 MR. HUEGEL: Twenty-two thirty-five is  
7 your design pressure, psig, plus 110 percent.

8 DR. WALLIS: Is how much?

9 CHAIRMAN SIEBER: Twenty-seven fifty.

10 DR. WALLIS: Twenty-seven fifty psig?

11 MR. HUEGEL: I'm sorry, 2500. Right.

12 CHAIRMAN SIEBER: The g.

13 MR. HUEGEL: Right.

14 CHAIRMAN SIEBER: ASME.

15 MR. HUEGEL: Right.

16 DR. WALLIS: So sump pressure in  
17 containment, you're okay.

18 MR. HUEGEL: Right.

19 MR. KAI: Okay. We'll now talk about the  
20 pressurizer overflow. As we just discussed before,  
21 one of the key factors here was the setting of the  
22 initial pressurizer level, so we took into account the  
23 results of these two events that we've analyzed here,  
24 the results of which are shown on Slide 20. We looked  
25 at loss of feed, and we looked at the inadvertent ECCS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 actuation.

2 One of the things that we found was that,  
3 number one, is that we did need a design change to  
4 provide us marginal inadvertent ECCS operation. In  
5 terms of operator action, this is one of the more  
6 challenging events that we analyzed. Currently, the  
7 way the current analysis shows is that, as you can  
8 see, with the PORVs available that we will reach a  
9 water solid condition in about 18.7 minutes. With the  
10 PORVs not available, it's 10-1/2 minutes, so we have,  
11 in terms of operator action, about 10 minutes.

12 DR. WALLIS: Oh, these are minutes here?

13 MR. KAI: These are minutes, correct.

14 MEMBER BANERJEE: So what was the hardware  
15 modification?

16 MR. KAI: Okay. That's what I'm going to  
17 go over. What we've done is -

18 MEMBER BROWN: Can you explain one -- I  
19 didn't understand a number. The maximum pressurized  
20 volume was 1,800 cubic feet.

21 MR. KAI: Correct.

22 MEMBER BROWN: In the loss of feedwater  
23 case, before you reach some value of what, 1,061 cubic  
24 feet of water volume in the pressurizer?

25 MR. KAI: Correct.

1 MEMBER BROWN: Now when you run that  
2 transient, you're at 1731.

3 MR. KAI: Correct.

4 MEMBER BROWN: So you've got 69 cubic feet  
5 left to go solid. And I don't know how many cubic  
6 feet there are per inch. Normally, you should be able  
7 to spit that out. It seems like you're almost solid  
8 for this transient. There's no times associated, or  
9 whatever it is, for the water relief associated with  
10 the loss of feedwater. And you can talk about the --

11 MR. KAI: Right.

12 PARTICIPANT: It just goes to the 1731  
13 minute drop, so that's the peak it's going to reach.

14 MEMBER BROWN: It used to go to 1,061.  
15 And this is just a swell due to the temperature, the  
16 expansion of everything.

17 MR. KAI: Correct.

18 MEMBER BROWN: And the swell in the  
19 pressurizer.

20 PARTICIPANT: We're starting at a higher  
21 level, too.

22 MEMBER BROWN: But that's not a whole lot.

23 MR. KAI: No. You're exactly right. This  
24 is probably the biggest impact of the uprate --

25 MEMBER BROWN: Yes, that's a big number,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and you're not far from being solid. There's nothing  
2 talking about why that little bitty -- recognizing you  
3 meet the limit, but from the other part of the license  
4 review, that is the volume.

5 MR. KAI: Correct.

6 MEMBER BROWN: That is solid volume. Am  
7 I correct?

8 MR. HUEGEL: This is Dave Huegel. Just a  
9 point I wanted to make, is that keep in mind for the  
10 loss of normal feedwater, what we're truly trying to  
11 demonstrate is that you have adequate cooling post-  
12 reactor trip condition. This is not a true limit that  
13 we're meeting. We're just trying to avoid a condition  
14 where we go water solid during the time period that  
15 we've analyzed this event, because it's a situation  
16 that we don't want to start sending water out of the  
17 pores, but it's not a true limit.

18 The true limit is trying to demonstrate  
19 that you have adequate heat removal capability via  
20 your aux feed pumps for post-trip reactor trip  
21 condition. So I just want to point that out.

22 MEMBER BROWN: But isn't the concern, you  
23 don't want that power operated relief valve.

24 MR. HUEGEL: Sure.

25 MEMBER BROWN: You don't want it to open,

1 because you don't want it to not --

2 MR. HUEGEL: You don't want it to pass  
3 water. We don't want it to pass water, it clearly  
4 passes steam.

5 DR. WALLIS: If the level goes all the way  
6 up there, it will open, will it not?

7 MR. HUEGEL: Yes. Another very good point  
8 is they are qualified for water relief.

9 DR. WALLIS: It does open, though, in this  
10 transient.

11 MR. HUEGEL: Yes, it does. Yes.

12 MEMBER BROWN: The water relief opens in  
13 this circumstance, or the steam?

14 MR. HUEGEL: No, the steam relief.

15 MEMBER BROWN: Oh, okay.

16 MR. HUEGEL: And the Millstone valves are  
17 qualified for water relief.

18 MEMBER BROWN: The steam relief valves are  
19 qualified for water relief.

20 MR. HUEGEL: Yes.

21 MR. KAI: What this transient is, if you  
22 can remember, number one, it's very conservatively  
23 analyzed. The RCS will continue to expand until your  
24 aux feed can match decay heat. And what you have in  
25 this situation is the power increase has pushed that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 time out when you match decay heat much further. If  
2 you look at decay heat in this time period, it's  
3 pretty flat, so the time that it takes for decay to  
4 drop such that you match decay heat, and then  
5 consequently start to pre-shrink the RCS is  
6 significantly extended. Like I said, this is probably  
7 the biggest impact on uprate.

8 Another thing to keep in mind here is that  
9 what we've done, the limiting case is actual off-site  
10 power available, and we're modeling an extremely  
11 conservative RC pump key on top of decay heat. So  
12 yes, I think you're right that this is a significant  
13 impact, and is a subject that we ought to monitor in  
14 our --

15 (Simultaneous conversations.)

16 MR. KAI: So I agree with that. The other  
17 thing is that we look at initially, and felt that we  
18 would show acceptable results with some loss of margin  
19 to overfill. And you're right, I think this is an  
20 area that we need to recognize going forward. It is  
21 very conservatively modeled. Like I said, it's very  
22 conservative that we add in, but we were able to show  
23 acceptable results.

24 MEMBER BANERJEE: What's the hardware  
25 change?



1 MR. KAI: Okay. The issue that we  
2 struggled with is the fact that we have high charging  
3 pumps. So what will happen is you'll get both trains  
4 to start up, and you'll inject ECCS, charging for 2-D  
5 ECCS valves at a significant rate. Remember, the  
6 charging pumps really can pump against 2750, so it can  
7 provide a significant flow.

8 MEMBER BROWN: SI and ECCS are synonymous?

9 MR. KAI: Right.

10 MEMBER BANERJEE: High pressure.

11 MEMBER BROWN: Safety injection or  
12 emergency core cooling, whatever. I just want to make  
13 sure they were --

14 MR. KAI: Right. No, they are normal  
15 charging pumps --

16 PARTICIPANT: They have five pumps at all  
17 high head. Right?

18 MR. KAI: Yes, we have two charging pumps  
19 running, two SI pumps, and two pumps that would start  
20 up in VNSI. And we actually have an event like this,  
21 so one of the things that we wanted to come out of  
22 this is to find a solution for this. I'll get to the  
23 mod that we did.

24 What we are adding is a permissive, a new  
25 permissive. The permissive uses an independent signal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 from the low RCS pressure RPS, so what it does is,  
2 that permissive has to sense low RCS pressure before  
3 it will allow the charging injection valves to open.  
4 Okay? So if you have an ECCS where RCS pressure is  
5 2200 or 2500 or higher, the charging injection valves  
6 will not open. The rest of the ECCS will actuate.  
7 But obviously, because your pressure is high, they  
8 won't be injecting. So that permissive we've added.  
9 In this event of an inadvertent SI, what would happen  
10 is the charge injection valves won't open. The only  
11 injection will come through the RCP seals.

12 MEMBER STETKAR: Let me stop you right  
13 there. I noticed in your analysis that you  
14 consistently said those exact words, that the only  
15 injection will occur through the RCP seals. What  
16 about the normal charging line? How do you model the  
17 normal charging flow?

18 MR. KAI: Okay. If you have an  
19 inadvertent SI signal, the normal charging flow is  
20 isolated by redundant valves. The path is switched to  
21 the ECCS.

22 MEMBER STETKAR: Is that actually true for  
23 Millstone, because it's not typically true for most  
24 Westinghouse plants that I'm familiar with.

25 MR. KAI: Yes. It's definitely true for

1 Millstone.

2 MEMBER STETKAR: You isolate all charging.

3 MR. KAI: We isolate the normal charging

4 --

5 MEMBER STETKAR: The normal charging line.

6 MR. KAI: Other than the seals, other than

7 RCP seals. Josh can --

8 MR. HARTZ: My name is Josh Hartz. I work  
9 for Westinghouse Electric. Millstone Unit 3 has what  
10 we refer to as a high pressure emergency core cooling  
11 system.

12 MEMBER STETKAR: Right. So did Zion,  
13 where I worked.

14 MR. HARTZ: Okay. Many Westinghouse  
15 plants have that same design feature, to answer your  
16 question.

17 MEMBER STETKAR: Zion's charging line was  
18 not isolated on a safety injection.

19 MR. HARTZ: Ours definitely are.

20 MEMBER STETKAR: So hence my question.

21 MR. HARTZ: Well, the charging pumps bail  
22 out of the chemical and volume control system, and  
23 they take suction from --

24 MEMBER STETKAR: Zion's charging line was  
25 not isolated on a safety injection. Hence my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 question. I wanted to confirm that your charging line  
2 was isolated.

3 MEMBER BROWN: What's the initiating  
4 signal for your ECCS?

5 MR. KAI: It's an inadvertent signal. It  
6 is some kind of short on the --

7 (Simultaneous conversations.)

8 MEMBER BROWN: Now what about non-  
9 inadvertent, what triggers it?

10 MR. KAI: Well, there are a number of  
11 signals, including low pressurizer pressure is the one  
12 that normally is credited, and that's obviously for  
13 LOCAs. And in that situation --

14 MEMBER BROWN: But it's independent of a  
15 low pressure reactor trip.

16 MR. KAI: Correct. It's a totally  
17 different, totally independent.

18 MEMBER BROWN: And you're using the low  
19 pressure reactor trip to isolate --

20 MR. KAI: Correct.

21 MEMBER BROWN: To provide the --

22 MR. KAI: The permissive.

23 MEMBER BROWN: Drive the permissive.

24 MR. KAI: Correct.

25 MEMBER BROWN: How many plants use a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 permissive to block a safety injection system?

2 MR. KAI: I don't know of anyone that does

3 --

4 MEMBER BROWN: Are you the first?

5 MR. KAI: Yes.

6 MEMBER BROWN: Okay. That was what I got  
7 out of reading this stuff. That's an interesting  
8 point. I mean, how many places do we put a permissive  
9 in, as opposed to the actual plant sensed signal  
10 evidence of a LOCA, and then we put something else in,  
11 that says well, we don't really need it if we haven't  
12 got a low pressurizer reactor trip.

13 MR. KAI: And part of our advantage is  
14 like Josh said, we are a high pressure ECCS plant,  
15 which is an advantage because we have what we call  
16 HPSI, or in one sense we'll call it an intermediate  
17 HPSI plant, pumps, and we have low pressure --

18 MEMBER BANERJEE: With high pressure do  
19 the HPSI pumps inject -

20 MR. KAI: Mike O'Connor can explain more  
21 of the background. This has been an industry issue  
22 that we've been trying to resolve for a number of  
23 years.

24 The inadvertent SI causing a water solid  
25 situation. It's not, by any means, a desirable

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 situation for our operators, or for our equipment.

2 MEMBER BROWN: So if you didn't do this  
3 fuel change, you'd be back in eight and a half --

4 PARTICIPANT: It would be shorter.

5 (Simultaneous conversations.)

6 MEMBER BROWN: So the only thing you're  
7 trying to do with this permissive to keep a longer  
8 dead time, not dead, wrong word, excuse me. Longer  
9 response time for the operator of the plant --

10 MR. KAI: Correct.

11 MEMBER BROWN: -- to take action in this  
12 circumstance. So as opposed to 10 minutes, you're  
13 trying to get to 30.

14 MR. KAI: And actually, there's a high  
15 likelihood that the operator will prevent the overflow  
16 altogether. I'll turn it over to Mike O'Connor.

17 MR. O'CONNOR: My name is Mike O'Connor.  
18 I'm the Manager of Systems and Component Engineering.  
19 When the project started, I was an on-shift Shift  
20 Manager working for Millstone Unit 3, and had a Senior  
21 Reactor Operator's license.

22 The design change, we have not categorized  
23 it as a block. Rather, we've let the actuation logic  
24 circuitry make a decision for operations and the plant  
25 on what's needed. Much like we don't get a automatic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 containment spray actuation for every safety  
2 injection, or every plant trip, we let containment  
3 pressure make that decision for us. That's what we're  
4 really doing with this modification to the plant at  
5 this time.

6 And as Mike was trying to describe, it  
7 takes that pressurizer fill time, or as we've been  
8 referring to it, the operation action time, that moves  
9 it from the -- currently we have it at 10 minutes,  
10 where an operator is required to make sure that there  
11 is a pressurizer relief valve path available at 10  
12 minutes. That's the current action. Really extends  
13 that time frame out to near 70 minutes, because the  
14 only water going into the plant for that event would  
15 be the seal injection that we were discussing earlier.

16 MR. BUCHEIT: Mr. Chairman, if I might say  
17 a word. I'm Dave Bucheit, the Manager of Safety  
18 Engineering for Dominion. And we did look at this  
19 from a risk assessment perspective before we made the  
20 change, and we have some slides to address this later  
21 on. But essentially, from a risk tradeoff point of  
22 view, you're trading off the increased risk of plant  
23 transients from an inadvertent SI against the slight  
24 increase in risk of this permissive which now has to  
25 actuate. It was a risk --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Simultaneous conversations.)

2 MEMBER STETKAR: Since you brought up the  
3 risk assessment, I was going to save it until then,  
4 but I didn't notice anything in your discussion of  
5 changes to the risk assessment, except the only  
6 discussion in the risk assessment regarding this  
7 modification is the assertion that the unreliability  
8 of the new logic is small compared to the  
9 unreliability of the injection valves. Okay. That's  
10 an assertion. Nobody did an analysis that I could  
11 see.

12 Are there any scenarios, either initiating  
13 events or developing scenarios in the risk assessment  
14 that either explicitly or implicitly include credit  
15 for safety injection where you would not have a low  
16 pressurizer pressure signal? Are there any scenarios  
17 where you include credit for safety injection under  
18 any conditions, and I don't know what your models are,  
19 and I don't know what scenarios you've looked at, but  
20 where you take credit in the PRA for a successful  
21 safety injection actuation where you would not have a  
22 low pressurizer pressure signal? I saw no discussion  
23 of that in your evaluation of plant design change  
24 impacts on the PRA. I would hope that the answer to  
25 that question is there are none, but I saw no

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 discussion of that. So it's not clear to me that that  
2 question was even considered.

3 MR. BUCHEIT: The primary risk tradeoff  
4 was the risk of --

5 MEMBER STETKAR: That's a small system-  
6 level, not a functional level of a plant response  
7 evaluation. It'll come up in the main Committee  
8 meeting tomorrow, so I hope someone has an answer.

9 There are -- I've been in some studies  
10 where you don't get the low pressurizer pressure SI.  
11 You have to take credit for some other SI signal to  
12 get it started.

13 (Simultaneous conversations.)

14 MEMBER ABDEL-KHALIK: -- scenarios.  
15 Wouldn't this permissive make them a lot worse?

16 MR. KAI: No, it would not. You would not  
17 even get -- you wouldn't get an ATWS, a ECCS signal.

18 MEMBER ABDEL-KHALIK: Well, but the fact  
19 that you had PD pumps injecting borated water at  
20 fairly high pressure.

21 MR. KAI: We don't have PD pumps.

22 MEMBER ABDEL-KHALIK: They're centrifugal  
23 pumps with a very high shutoff head.

24 MR. KAI: Correct. But these scenarios do  
25 not generate low pressurizer pressure signal to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 generate an injection.

2 MEMBER ABDEL-KHALIK: That is not my  
3 question. So during those scenarios, you don't take  
4 credit of the fact that you can actually inject boron  
5 at high pressure?

6 MR. KAI: Yes, we do. But this  
7 permissive, what it affects is not the normal charging  
8 pathway, not the ECCS pathway. The normal charging  
9 pathway is still available.

10 CHAIRMAN SIEBER: Do you have the boron --

11 MR. KAI: No. We did. That's been  
12 removed.

13 CHAIRMAN SIEBER: You took it out. Okay.

14 MEMBER MAYNARD: Now, if I understand, I  
15 think the only open question is your question.

16 MEMBER STETKAR: Yes. Take a look at it,  
17 because I'm curious.

18 MEMBER BROWN: We've answered the one  
19 about nobody else does it. So that one is -- I think  
20 we know the answer to this. The other part that I  
21 didn't get to was there was a rough diagram showing  
22 the reactor trip signal, two out of four that you  
23 wanted to use going to something which then triggered  
24 this stuff, initiated, or uninitiated the permissive,  
25 or withdrew the permission. It appeared to be that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 was a single channel path, as opposed to a dual  
2 channel path where both paths would have to fail in  
3 order to initiate this unpermissive that you didn't  
4 want to occur. That's from the diagram. It's very  
5 simple -

6 MR. O'CONNOR: Perhaps I could clarify the  
7 simplified diagram. You have four completely  
8 different pressure sensing signals.

9 MEMBER BROWN: I got that part.

10 MR. O'CONNOR: Providing the two out of  
11 four.

12 MEMBER BROWN: Yes.

13 MR. O'CONNOR: That goes to two trains of  
14 components. The safety injection path that we're  
15 talking about is two completely fully qualified paths  
16 in parallel with each other, controlled by two  
17 separate valves that are powered from two separate  
18 electrical buses, so those signals, and the safety  
19 injection signal all go to the valve, two different  
20 trains.

21 We only need one of the two trains to  
22 function, to provide full safety injection from  
23 charging. I think that might be the piece that wasn't  
24 shown clearly for the diagram you're looking at.

25 MEMBER BROWN: So you're saying there's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 two different -- one channel feeds one valve, and  
2 another -- you call that a train?

3 MR. KAI: Yes.

4 MEMBER BROWN: Okay. The other channel  
5 feeds the other valve?

6 MR. KAI: All four -

7 MEMBER BROWN: I know all four pressure is  
8 coming in, but something's got to say two out of four.

9 MR. KAI: Right.

10 MEMBER BROWN: And it's got to tell one  
11 valve two out of four you can do it, or be isolated,  
12 and the other's got another two out of four, or be  
13 isolated. Is it one or the other?

14 MR. KAI: Bob Burnham will clear up the  
15 logic circuitry for you.

16 MEMBER BROWN: Well, a diagram would be  
17 real nice, as opposed to words.

18 MR. BURNHAM: My name is Robert Burnham.  
19 I'm the I&C Design Engineer on the project. As Mike  
20 stated, we take four discrete pressurizer pressure  
21 signals. They have their own bi-stables. Those bi-  
22 stables feed into two parallel trains of solid-state  
23 protection. Inside the parallel trains of solid-state  
24 protection, two out of four voting is where it occurs,  
25 so this occurs completely separate -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Two sets of two out of four  
2 voting?

3 MR. BURNHAM: That's correct.

4 MEMBER BROWN: That's what I was asking.

5 MR. BURNHAM: Two sets of two out of four  
6 voting in each train of solid-state protection. That  
7 is where the signal is generated for the P-19  
8 permissive. From each of those trains of solid-state  
9 protection, the P-19 signal hits independent auxiliary  
10 relays at the output of the solid-state protection  
11 cabinet. Those relays that are P-19 are placed in  
12 series for the existing safety injection signals, so  
13 that you need both an SI, and a P-19 permissive to  
14 open up the ECCS injection valve. And as Mike stated  
15 --

16 MEMBER BROWN: So there are two sets, one  
17 works on one valve, and one works on the other valve.

18 MR. BURNHAM: That's right.

19 MEMBER BROWN: A failure on one won't  
20 prevent the other one from opening, so you would at  
21 least get partial ECCS operation.

22 MR. BURNHAM: But it isn't partial. It's  
23 two 100 percent -

24 MEMBER BROWN: I understand that. By  
25 partial I mean part of both loads.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. KAI: Capability.

2 MR. BURNHAM: There is no single failure  
3 that can -

4 MEMBER BROWN: It's fully redundant all  
5 the way down.

6 MR. BURNHAM: That's correct.

7 MEMBER BROWN: That was not stated in the  
8 write-up. Okay. Thank you. A thousand words always  
9 substitutes for a nice simplified one-page picture.

10 MEMBER BANERJEE: I just want to follow-up  
11 on Charles' question regarding the -- is this the only  
12 plant that has these conditions?

13 MR. KAI: Has this mod? Yes.

14 MEMBER BANERJEE: You said the mod, but  
15 you get the pressurizer almost going solid. Are there  
16 other plants that do this?

17 MR. KAI: Yes. And, actually, like I  
18 said, this is being -- I'll let Mike O'Connor  
19 elaborate, but this has really been an issue that we  
20 have been trying to champion to find some way to  
21 provide some relief to the operator action time  
22 frames, but I'll let -

23 MEMBER BANERJEE: But other plants have  
24 the same conditions that arise. Right?

25 MR. KAI: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BANERJEE: They have to live with  
2 short operator action, so why do you have to do all  
3 this stuff?

4                   MR. BURNHAM: If I might answer that  
5 question for you, we were looking to improve the  
6 operation of the plant, and limit the need for an  
7 operator to take short credited operator action times  
8 to prevent the condition from happening in the plant  
9 when the logic circuitry was able to determine that it  
10 was not needed. So you're correct in that similarly  
11 constructed plants do have this, and they've resolved  
12 these issues in different manners over the years.  
13 And, previously, we've ended up with that short 10-  
14 minute operator action time at our facility, as a  
15 result of making sure that the PORVs on the  
16 pressurizer were qualified for water relief, as well  
17 as the downstream piping. And so that was -- and, in  
18 addition to that, we made some modifications about 10  
19 years ago to ensure that there was a safety-grade  
20 actuation system of the PORVs.

21                   PARTICIPANT: Just to follow-up on that if  
22 I could real quick. Part of the culture that we're  
23 trying to develop at Dominion is a culture of risk  
24 management. When we update our PRA models now, as a  
25 matter of course, we look for opportunities to reduce

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 risk, and there are several examples of where we've  
2 done it.

3 This is a proactive example, proactive  
4 instance on our part where we've tried to reduce risk.  
5 The one question withstanding that we need to answer,  
6 we believe that this was a net risk-benefit to do  
7 this.

8 MEMBER BROWN: And I understand the 30  
9 minutes. In our stuff that I used to work on for the  
10 Navy for the operator actions, we hated -- we fought  
11 to try to allow the operators to have about 30 minutes  
12 to respond to things. When we got down in the 5-10  
13 minute range, we would take fairly heroic actions  
14 trying to work our way -- convince ourselves that they  
15 had to analyze-wise or put a hardware change in. I  
16 understand the desire to go away from it, depending on  
17 the operator who's in a 5-10 minute, what can be a  
18 chaotic time, is not as desirable as you would like,  
19 so I understand the need. I just was concerned about  
20 the redundancy of the whole setup, not excluding the  
21 other question relative, which is a very good  
22 question, also.

23 MR. KAI: Okay. Any other questions about  
24 that? We can move on.

25 MEMBER STETKAR: There's still pretty

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 short times for your limiting charging system  
2 malfunction.

3 MR. KAI: Yes. And that's always been  
4 there.

5 MEMBER STETKAR: Yes. I mean, that hasn't  
6 changed.

7 MR. KAI: Correct. Get to the design-  
8 basis results. And I've got a lot of the results  
9 here. I'm not going to go over them all in any  
10 detail. I will discuss a little bit about LOCA, to  
11 answer the questions about -

12 MEMBER ABDEL-KHALIK: Can we go back to  
13 the previous slide, please? Are the entries for the  
14 two rows when the PORVs are or are not available  
15 reversed?

16 MR. KAI: No.

17 MEMBER ABDEL-KHALIK: So if the PORVs are  
18 not available, it would take longer for the safeties  
19 to lift?

20 MR. KAI: What this -- okay. Yes, because  
21 you'll be at a higher pressure. What this is meant to  
22 show is really how much time the operators have.  
23 Okay? The first case where the PORVs are available,  
24 the PORVs are controlling pressure at about 2300 psi.  
25 Okay? So you will -- so to get water solid, you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 going to be using more water out of the pressurizer  
2 faster, so you will get to a water solid condition,  
3 which you were designed for. Okay? So we are  
4 designed for that scenario. If the PORV is available  
5 and they're working controlling pressure at 2300, the  
6 pressurizer will go water solid -

7 MEMBER ABDEL-KHALIK: But the table is  
8 giving time for pressurizer safeties to open.

9 MR. KAI: Okay. Yes. Okay. Now, go to  
10 the next row. Okay? Do you understand what we did  
11 there? What we have there is, with the PORVs in  
12 operation controlling pressure, the time to currently  
13 fill the pressurizer solid is 8.7 minutes, and that's  
14 because the pressurizer is at 2300 psi. Okay? Get  
15 higher charging flows, going to discharge more water  
16 faster, and you will hit a water solid condition.  
17 Okay? If the PORV is inoperable, or not available, it  
18 will take longer to reach that water solid condition  
19 to open the safeties, and that's because you're going  
20 to be at a higher pressure. The safety valves will be  
21 cycling. The charging flow will be less, so you would  
22 get water discharge off the safeties at 10.5 minutes.

23 What we have the operators do is, in this  
24 time period of 10 minutes, they are to make sure that  
25 the PORVs are available. Their job is to make sure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that the block valve, if it's closed, is open so that  
2 the PORVs will function. So the difference here is  
3 that the first number is done at RCS pressure of 2300  
4 where the PORVs are controlling pressure. And the  
5 second line is with the RCS pressure at 2500 psi,  
6 where it's higher and -

7 MEMBER ABDEL-KHALIK: I still don't  
8 believe it.

9 PARTICIPANT: The key is on the first one  
10 where the PORVs are available, the safeties don't  
11 open. I guess water solid, but it's going out the  
12 PORV, not the safety.

13 MEMBER ABDEL-KHALIK: What do these  
14 numbers give? This is time for pressurizer safety  
15 valves to open.

16 PARTICIPANT: But that's not really where  
17 this one line -- the time is to become water solid,  
18 but the safeties don't open on that.

19 CHAIRMAN SIEBER: With water available,  
20 the safety valves won't work.

21 MR. KAI: Right.

22 MR. WALLIS: It's really time for the  
23 water to get up to the PORV.

24 MR. KAI: Well, it's hard to -

25 (Simultaneous speaking)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: Mr. Chairman, it's 2:30.  
2 We haven't even heard anything from the staff. We  
3 have a number of subjects to go.

4 CHAIRMAN SIEBER: Why don't we try to go  
5 through this a lot quicker.

6 MR. KAI: I've given you all the design-  
7 basis results. One thing that I would use, we are  
8 using ASTRUM for large-break LOCA. We do have the  
9 results that compare the current, on page 24, they did  
10 the small break results, which actually will give you  
11 a much better idea of the LOCA impact, because in  
12 small break, we're using the same -

13 MEMBER POWERS: Let's go back to the rod  
14 ejection results.

15 MIKE: Okay.

16 MEMBER POWERS: You don't indicate what  
17 fraction of the core has suffered damaged rods with  
18 these kinds of energies.

19 MR. KAI: I'll ask -- I'll make sure our  
20 radiological guy -

21 MR. BARTON: Right here. Could you repeat  
22 the question, please?

23 MEMBER POWERS: Well, the kinds of maximum  
24 strut energies did you have in the rods here are  
25 sufficient to break them, and they're going to go rod

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ejection, so I assume there would be a lot of fission  
2 gas release?

3 MR. BARTON: I'm sorry. I'm having a hard  
4 time hearing.

5 (Off mic comments.)

6 MR. AIKEN: This is Bill Aiken. We  
7 assumed 7 percent of the fission gases.

8 MEMBER POWERS: And that assumption was  
9 tutored by what experimental data?

10 MR. AIKEN: It's our design-basis, the  
11 previous was at 6 percent, and we increased it up to  
12 7 percent.

13 MEMBER POWERS: Why didn't you increase it  
14 to 20 percent like observed in the experiments?

15 MR. KAI: I assume that you're referring  
16 to the Cabri test.

17 MEMBER POWERS: I was thinking more about  
18 NSRR, but okay.

19 MR. KAI: Right. Okay. Now, what we've  
20 done here, we have not -- as I said before, there are  
21 some industry issues out there that we have to decide,  
22 is that significant for SPU or not. They're not  
23 resolved yet in terms of industry setting limits,  
24 especially for high burn-up fuel where those types of  
25 failures can occur at really low calories-per-gram

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 limit. So at the high rate of this, and determined  
2 that we believe that this is not -- that SPU really  
3 has no impact on resolution of that issue, and so we  
4 are using the current methodology for fuel failure,  
5 with the recognition that industry -

6 MEMBER POWERS: I mean it's just flat  
7 wrong. Right?

8 MR. KAI: Well -

9 MEMBER POWERS: That's inconsistent with  
10 reality.

11 MR. KAI: Well, if we're going to talk  
12 about reality, I think one thing you've got to keep in  
13 mind is that when we operate our plant at full power,  
14 the rods are essentially 100 percent withdrawn. There  
15 is no -- there's practically no rod -

16 MEMBER POWERS: That's not when the hazard  
17 comes about.

18 MR. KAI: Correct. The hazards are at low  
19 power, which, in terms of SPU is not really -- I mean,  
20 SPU itself then doesn't make any impact on the low  
21 power head. So that is how we evaluated whether we  
22 were to do something in terms of logic, and we have  
23 thought about it, but the real question is, is what  
24 kind of analyses do we do, what limits do we apply?  
25 None of which have been set, so when we convince

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ourselves that this was not an issue at the uprate  
2 power level versus the current power level, we decided  
3 to continue with the current methodology. And we  
4 would, obviously -

5 MEMBER POWERS: Couldn't you increase your  
6 inventory, your release fraction from 6 to 7 percent?

7 MEMBER ARMIJO: You mean, percent failed  
8 fuel.

9 MEMBER POWERS: No.

10 MR. KAI: Percent failed fuel, and that  
11 was stated -

12 MEMBER POWERS: Gas release fractions went  
13 from 6 to 7 percent. I mean, you're neither fish nor  
14 fowl here.

15 MR. AIKEN: Yes, sir. The bottom line is  
16 this is a mystery issue. There's rule making coming,  
17 we're following the issue, and we'll implement work  
18 with our fuel vendor, and implement the regulatory  
19 rule making as it evolves.

20 CHAIRMAN SIEBER: Is this a generic safety  
21 issue?

22 MR. AIKEN: Yes.

23 CHAIRMAN SIEBER: Anyone on the Staff, is  
24 this a generic safety issue? The research issue  
25 that's been identified for high burn-up fuel, and -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: There are minimum guidelines  
2 that are in place, but they're only interim, and  
3 that's in part why we didn't do anything at this time,  
4 because we were uncertain what the final rule is going  
5 to be.

6 MEMBER MAYNARD: It's a generic issue. I  
7 do not know if it's an official generic safety issue.

8 CHAIRMAN SIEBER: I don't know either.

9 MR. KAI: I don't believe it's a GSI, but  
10 it is a generic issue that is being addressed by the  
11 industry groups and the owner's group.

12 MEMBER POWERS: But, in fact, we know what  
13 the answer is, and have known now for several years.

14 Okay. I know what they've done.

15 MEMBER ARMIJO: Just back at page 22, and  
16 that's just a question, clarification. On this locked  
17 rotor event, you have a failed fuel limit 7 percent.  
18 I presume that's a different 7 percent than what Dana  
19 was just discussing. I don't know, but in the SPU and  
20 you've made it less than 7 percent, and your current  
21 is less than 6 percent as your design basis. And what  
22 is the mechanism of fuel failure that we're talking  
23 about here?

24 MR. KAI: Okay. This is a locked rotor in  
25 which we assume an instantaneous stop of flow of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 RCPs, so, essentially, for the short time period  
2 before reactor trip occurs, you essentially have  
3 three-quarters flow with 100 percent power generation.  
4 And that is going to cause you to go into DNB.

5 MEMBER ARMIJO: So this is a DNB -

6 MR. KAI: Yes. Correct. And, again, in  
7 order to calculate things like peak clad temperature,  
8 we make a very conservative assumption. We do not,  
9 obviously, credit heat transfer in the DNB mode, so  
10 that's been the result is us calculating these types  
11 of parameters. And it applies only for the few second  
12 duration prior to reactor trip, because once reactor  
13 trip is over, the event is over.

14 MEMBER ARMIJO: So you calculate if they  
15 reach DNB conditions, you define them as failed.

16 MR. KAI: Right.

17 MEMBER ABDEL-KHALIK: Okay. And one  
18 should not compare the current and SPU conditions,  
19 because they are just different methods? Otherwise,  
20 the results don't make sense.

21 MR. KAI: Okay.

22 PARTICIPANT: Yes, for the peak clad  
23 temperature, I think we changed to the PAD data. I  
24 think that was the main -

25 MR. KAI: The fuel performance there that

1 we used, one of the - which is called PAD - we used  
2 Version 4, and that results in some improvement in  
3 these types of parameters. And so that's why you see  
4 that the current result is slightly better than the  
5 SPU results.

6 MEMBER BROWN: 250 degrees is just  
7 slightly?

8 MEMBER BANERJEE: That's puzzling. Why is  
9 that -- 1969 to 1718.

10 MEMBER ARMIJO: Yes.

11 MEMBER BANERJEE: I can't follow the  
12 logic. Can you repeat what happened there?

13 MR. KAI: This uses a code called PAD to  
14 calculate fuel performance. And it's gas pressure  
15 resumed, fuel temperatures is a function of kilowatts  
16 per foot, and they're going to a new version which  
17 results, in some transients, significant improvement,  
18 and others it doesn't make any difference.

19 MEMBER BANERJEE: Well, what changes the -  
20 - what is the physical reason? Is it gap conductance,  
21 or what is it? If you can get 250 degrees by just  
22 changing something -

23 MEMBER SHACK: It gives you the code.

24 MR. WANG: This is Guogiang Wang from  
25 Westinghouse, just a quick additional information. As

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Mike and Sandy explained, we changed PAD from 3.4 to  
2 4.0, which was issued -- Westinghouse was issued in  
3 2000, July 2000. It is a new PAD model. Basically,  
4 the fuel temperature was improved. At the normal  
5 operating condition, the fuel -- both the average fuel  
6 temperature and the fuel surface temperature was about  
7 -- close to 100 degree Fahrenheit lower at the normal  
8 operating conditions. So in the VIPRE model, when we  
9 calculated the PCT, peak cladding temperature, we  
10 assumed from the beginning the ultra surface of the  
11 cladding gone to DNB, so it's film boiling. So given  
12 the fuel surface temperature from PAD 4.0 is about  
13 almost 100 degree Fahrenheit higher, and we specify a  
14 fuel to clad heat transfer coefficient of about 10,000  
15 btu power per square feet.

16 MEMBER BANERJEE: What led to this  
17 reduction in fuel temperature between the two versions  
18 of PAD? The gap conductance? What changed it?

19 MR. WANG: That's the different model for  
20 calculating the fuel temperature. That's a different  
21 -- I'm not familiar with the PAD WCAP, so we need to  
22 get back to you. I don't know.

23 MEMBER BANERJEE: It wasn't the gap  
24 conductance. It was something in the fuel  
25 conductivity or something like that?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WANG: Yes. I guess, but yes.

2 MEMBER BANERJEE: Integral lambda dictator  
3 or something?

4 MR. WANG: I'm not too sure. It would be  
5 in the WCAP.

6 MEMBER BANERJEE: All right. I think it's  
7 fine.

8 MEMBER ARMIJO: It's a model change.

9 MEMBER BANERJEE: Yes, it's a model  
10 change. And, presumably, it was justified with data.

11 CHAIRMAN SIEBER: If we could, I'd like to  
12 move on. We're very far behind, gentlemen.

13 MR. KAI: Okay. I don't know if you're  
14 thinking there is more that we need from ASTRUM.

15 MEMBER BANERJEE: I have a question on SB  
16 LOCA. Was there any -- first of all, these SB LOCAs,  
17 the temperatures are very low, so you looked at all  
18 the spectrum of break sizes and things like that.  
19 Right? What sort of break size is that happening on  
20 the current, is that the same 4-inch? Is it  
21 different?

22 MR. KAI: I'll ask Josh.

23 MR. AIKEN: While Josh is coming to the  
24 microphone, I do want to point out that we -- all of  
25 the methods we're discussing here are methods that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have been reviewed and approved by NRC in various  
2 topical reports.

3 MEMBER BANERJEE: You're using -- yes, so  
4 it was a 4-inch cold leg break, the current one, as  
5 well?

6 MR. MILLER: I believe so, but I'm not 100  
7 percent sure on that. There's a 3-4 inch range. It's  
8 very typical of a standard 412 plant, the results  
9 we're seeing here.

10 MEMBER BANERJEE: Let me ask you then, do  
11 you get into a refluxing mode at all with such a small  
12 break?

13 MR. MILLER: You do, but it's a very short  
14 limited time for this particular break size. And  
15 there could be some countercurrent flow limitations  
16 preventing that liquid from getting back into the  
17 core. It's very short-lived, I can tell you that.

18 MEMBER BANERJEE: Well, the question I'm  
19 really asking here is, if you check the -- you,  
20 obviously, have higher steam velocities because of  
21 this 7 percent uprate condition. Are you close to the  
22 flooding limit at all, due to the increased steam  
23 velocity at the steam generator tube inlet? Have you  
24 checked that?

25 MR. MILLER: The inlet plane or at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 tube themselves?

2 MEMBER BANERJEE: Tubes.

3 MR. MILLER: The flooding limit? The model  
4 shows some liquid hold up in the steam generators  
5 under these circumstances, and we have seen that. And  
6 I have not looked at the details of this analysis, but  
7 I'd be willing to bet if you went in there, you would  
8 see that for a relatively short period of time until  
9 the flooding mechanism breaks down, and the steam  
10 generators drain out. Typically, in the loop seal  
11 vents, and you get a strong velocity through the  
12 faulted cold leg steam generator. That kind of clears  
13 the situation up.

14 MEMBER BANERJEE: So NOTRUMP has an  
15 explicit flooding criteria?

16 MR. MILLER: Yes, it does.

17 MEMBER BANERJEE: Like Graham Wallis -

18 MR. MILLER: Well, the flux flow links  
19 representing the steam generator are based on a TRAC  
20 flow regime map. TRAC-M I believe it is.

21 MEMBER BANERJEE: I was hoping you'd just  
22 say the Wallis correlation.

23 (Laughter.)

24 MEMBER WALLIS: Then you could really  
25 criticize it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. KAI: I'd like to move on.

3 MEMBER BANERJEE: Okay.

4 CHAIRMAN SIEBER: Please.

5 PARTICIPANT: Mr. Chairman, did you want  
6 us to conclude on our fuel in the safety analysis  
7 presentation at this time? Is there any additional  
8 topics you'd like us to address?

9 CHAIRMAN SIEBER: Well, I think we ought  
10 to get into the radiological results. But it seems to  
11 me, having to review all this, there's only a couple  
12 of important points. One of them is you use your  
13 ultimate source term that you applied for four years  
14 ago, and got. And when you applied for it, you  
15 applied for it at 6-1/2 percent SPU, so it almost  
16 covers the situation we're in right now. Most of the  
17 doses are far below the limits, except for small line  
18 break outside containment, which is on Slide 30. You  
19 may want to explain that to me. And, also, the  
20 thyroid dose, which you say is not applicable now.

21 MR. KAI: Okay.

22 CHAIRMAN SIEBER: And five whole body,  
23 which is not applicable. You can -- I think that  
24 covers the striking results.

25 MEMBER POWERS: The critical issue that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 determines all those is what they use for a gap  
2 inventory. And I don't quite understand how they  
3 calculated their gap inventory.

4 CHAIRMAN SIEBER: Well, that's a good  
5 question to ask.

6 MEMBER ARMIJO: It probably was reduced  
7 when they made this code change to PAD, because it's  
8 a drop in the fuel temperature.

9 MR. KAI: Okay. Why don't we go over  
10 this? I think we can answer your questions. Let's  
11 start with the small break outside containment. This  
12 is one of the only accidents that was not converted to  
13 alternate source term when we did the alternate source  
14 term submittal. And this is why we have this dual  
15 column. The 30 thyroid and the five whole body  
16 corresponds to the standard method for calculating  
17 doses. At SPU we converted it to the alternate source  
18 term methodology.

19 As you can see, what the standard --  
20 alternate source term is actually, gets an equivalent  
21 dose combining the thyroid and the whole body into a  
22 single dose. And the thyroid limit, as you can see  
23 we're pretty close to the thyroid limit. And that  
24 results in us being essentially at the 30 limit.

25 CHAIRMAN SIEBER: Well, the total

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 effective dose, the limit is 2.5, and you're at 2.5.

2 MR. KAI: Right.

3 CHAIRMAN SIEBER: So there's no margin  
4 there.

5 MR. KAI: Well, what we've done there is -  
6 -this analysis is terminated by the operator  
7 initiating -- isolating the break, so what we tried to  
8 do is get the maximum time for the operator, so we've  
9 gone all the way out to -- exactly as to what we  
10 expect. What this is, is a line that does not  
11 automatically isolate, and there's small lines, like  
12 instrument lines, and so we just calculate what we can  
13 -- the maximum operator response time that we can live  
14 with, and still meet the limit. So that's the reason  
15 why it's right up in there. If you were to assume a  
16 primary time, and like I said, this is 100 percent  
17 driven by what you're going to -- how much you're  
18 going to give for the operator in terms of isolating  
19 the small line like the instrument line.

20 CHAIRMAN SIEBER: When you look at fuel  
21 handling actions, there's not much difference between  
22 your current situation and the SPU situation, and  
23 that's due to fuel exposure, I take it. Higher burn-  
24 up.

25 MR. AIKEN: This is Bill Aiken. Well,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with the new uprate, we were beyond the limits of the  
2 regulatory guidance for .183, the alternate source  
3 term. We went over the combined 54,000 and then the  
4 6.3 kilowatts per foot guidance in the footnote, which  
5 says that the standard gap fractions that you're  
6 supposed to assume, you have to propose new gap  
7 fractions, and justify the new fractions.

8 We proposed to use the old Reg Guide 1.25  
9 gap fractions, the 12 percent for the iodine, and to  
10 offset that, we had to incorporate this control room  
11 design modification to have the control room initiate  
12 into the filtered recirculation mode within 30 minutes  
13 to counteract the additional dose that was -

14 CHAIRMAN SIEBER: Do you have a  
15 pressurized control room -

16 MR. AIKEN: Yes.

17 CHAIRMAN SIEBER: Bottled.

18 MR. AIKEN: Bottled air. We do not credit  
19 that in our analyses, though. We do not credit the  
20 bottled air, so we almost take a penalty, if you will.  
21 Even though the bottled air system still exists, and  
22 it is pressurizing the control room one minute after  
23 the accident, we don't credit that pressurization.

24 CHAIRMAN SIEBER: Still used?

25 MR. AIKEN: Yes, it is.

1 CHAIRMAN SIEBER: So you just haven't  
2 abandoned it and replaced it.

3 MR. AIKEN: No. No, it is still being  
4 maintained and surveilled.

5 CHAIRMAN SIEBER: On radiological  
6 controls, why don't we take a couple of minutes for  
7 the PRA overview.

8 MEMBER POWERS: Oh, one question, on the  
9 iodine spiking, you use a factor of 500.

10 MR. AIKEN: For which accident?

11 MEMBER POWERS: Steam generator tube  
12 rupture.

13 MR. AIKEN: Correct.

14 MEMBER POWERS: Any qualms about that?  
15 That's what the Reg Guide tells you to do that, and  
16 that's how you did it. You didn't look at it.

17 MR. AIKEN: That's exactly right.

18 MEMBER POWERS: You didn't look at it.  
19 You don't have any experience with your plant on  
20 spiking.

21 MR. AIKEN: No. Just following the  
22 guidance.

23 MEMBER POWERS: Now there's a controversy  
24 around that, but I guess you're not responsible for  
25 that controversy.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. AIKEN: That's a good thing.

2 MR. KAI: Should I keep the PRA -

3 CHAIRMAN SIEBER: Well, let me tell you  
4 what I think I need to know. One of them is the  
5 comparison of CDF and LERF currently in the stretch  
6 power uprate, and the increase which is a table on  
7 Slide 33. And I would like a listing in human factor  
8 space, or human reliability space as to how the times  
9 have changed for required operation operator responses  
10 during the abnormal operating occurrences and the  
11 accident conditions. Can you give me those?

12 MR. AIKEN: Yes, sir. The short answer,  
13 I'll start with the short answer, is that none of them  
14 have changed. We did use a different analysis tool.  
15 We used the RELAP code instead of the MAAP code to  
16 reconfirm all of the operator action times.

17 MEMBER STETKAR: In the real world, the  
18 times are shorter, so in the real world the times did  
19 change.

20 CHAIRMAN SIEBER: Well, they have to,  
21 because -

22 MEMBER STETKAR: They are shorter.  
23 However you evaluated them before or today, in the  
24 real world, there's less time available.

25 CHAIRMAN SIEBER: What he's telling me is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 he isn't going to answer my question.

2 MEMBER STETKAR: That's right.

3 CHAIRMAN SIEBER: Clarify something, the  
4 human errors didn't change as a result of the  
5 potentially shorter times.

6 MR. AIKEN: No.

7 MEMBER STETKAR: Let me see if I can  
8 shortcut something, because I looked at what they did.  
9 You changed five numbers in the PRA. You increased  
10 arbitrarily the PORV challenge probability by 10  
11 percent. That was a guess. You increased the plant-  
12 centered loss of off-site power frequency by 10  
13 percent. That was a guess. You increased the general  
14 transient frequency by 10 percent. That was a guess.  
15 Those three numbers were increased by some thermal  
16 hydraulic plant stability justification.

17 CHAIRMAN SIEBER: Yes, I don't understand  
18 what justifies it. I think -

19 MR. AIKEN: The 10 percent number was just  
20 based on what DeNay had done. We were just following  
21 previous industry -

22 MEMBER STETKAR: The only operator action  
23 you changed was the operator error rate for bleed and  
24 feed cooling, which actually didn't change. You  
25 assumed it was 10 percent lower in the current PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 You just assumed it was 10 -- if it was 10 percent  
2 lower in the current PRA, the current PRA core damage  
3 frequency would be somewhat lowered. You didn't  
4 increase it for SPU, you decreased it for the current  
5 PRA. Is that correct?

6 MR. AIKEN: Yes. All of that is based on  
7 thermal hydraulic analyses.

8 MEMBER STETKAR: I didn't see any time  
9 window, so because you're using HCRORE, the time  
10 window is very critical for the operator error rate.  
11 So back to Jack's question, there is no time  
12 documented.

13 CHAIRMAN SIEBER: The only one I could  
14 find was the inject recirc.

15 MEMBER STETKAR: Hot leg recirc, that  
16 changed from 9 hours to 5 hours, but they didn't  
17 change that in the PRA.

18 CHAIRMAN SIEBER: Yes, because it changes  
19 -- before you could wait for shift changes.

20 MEMBER STETKAR: Now you can't.

21 CHAIRMAN SIEBER: Now you have to do it  
22 yourself.

23 MEMBER STETKAR: Right. The other numbers  
24 that were changed, and these are critical. I want to  
25 get this on the record, because we're short time. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 can discuss it more if we have time, was that you  
2 decreased the off-site power recovery probability for  
3 a large number -- for all time windows in the current  
4 PRA. You decreased it by 10 percent. You did not  
5 change it for the SPU conditions. Again, there's no  
6 information about the time. You just said if the  
7 current time -- if the current recovery probability  
8 was less, your current core damage frequency would, in  
9 fact, be less than what you calculate now. And then  
10 you calculate a delta. This is kind of a backwards  
11 type of change in risk, because you've artificially  
12 reduced the current core damage frequency,  
13 artificially reduced the current large early release  
14 frequency, and then said well, now, here's the  
15 difference. Well, I could artificially reduce it to  
16 10 to the minus 8, and it would show that it's a 6  
17 times 10 to the minus 6 difference.

18 MR. AIKEN: Well, we have RELAP results.

19 MEMBER STETKAR: Well, what are the --  
20 back to Jack's time. If you have all of those  
21 analyses, what are the differences in time? We'd like  
22 to see those tomorrow.

23 MR. WALLIS: Do the 10 percents have any  
24 justification whatsoever?

25 MR. AIKEN: No, other than that's what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DeNay used in their -

2 MR. WALLIS: So you might as well have  
3 guessed the change in the core damage frequency.

4 MEMBER STETKAR: Well, the 10 percent  
5 changes that they made results in a 6.5 percent  
6 percent, which is sort of the only thing you can argue  
7 about. A 6.5 percent change -

8 MEMBER BONACA: In core damage frequency.

9 MEMBER STETKAR: But from an artificially  
10 reduced current core damage frequency. It's kind of  
11 a -

12 MR. WALLIS: But it's all very  
13 artificial; you could have guessed 20 percent, and you  
14 got a 12 percent change in core damage frequency. It  
15 really is not an analysis at all, is it?

16 MEMBER STETKAR: It's kind of a  
17 sensitivity study, but to state that the core damage  
18 frequency increase is 4.0, E to the minus -- not 4.1,  
19 not 4.2, but 4.0 E to the minus 7 is specious.

20 MR. AIKEN: But you understand that we did  
21 do a relatively formal update of the model before we  
22 did the sensitivity study.

23 MEMBER STETKAR: I understand that you  
24 updated the model. It's just that in whatever I think  
25 we could read, there is no information to tell us what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the differences might be, the real differences.

2 MEMBER POWERS: We have to get people to  
3 quit putting these bottom line numbers up, instead of  
4 putting up importance measures for us so we know what  
5 the critical components, and -

6 MEMBER STETKAR: Well, the only reason I  
7 wanted to bring this is they did make the point of  
8 saying that the most important parameters, at least  
9 that they looked at, were the operator action for  
10 bleed and feed cooling. That has a relatively high  
11 importance measure. In the details there is stuff in  
12 there.

13 PARTICIPANT: There was some justification  
14 for what we picked, not the 10 percent, but which  
15 things we picked to do the sensitivity -

16 MEMBER STETKAR: Yes. And the off-site  
17 power recovery time, the off-site power recovery  
18 probabilities is a function of time -- those are two  
19 that have relatively high -

20 MEMBER POWERS: Give them a gold star for  
21 pointing those things out, because lots of people give  
22 us these damned numbers that are meaningless.

23 MEMBER STETKAR: But, I mean, we've seen  
24 submittals where people actually do show you here's my  
25 time beforehand, here's my time after, and that's what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the delta is, run through the model.

2 MR. KAI: We can get you that information  
3 pretty easily, I think.

4 MEMBER BONACA: But this code, RELAP-5, I  
5 mean, what did you do, you calculate success criteria,  
6 your -

7 MR. AIKEN: Yes, we did all the success  
8 criteria as part of the model.

9 MEMBER BONACA: Before the EPU.

10 MR. AIKEN: Pardon? No, that's what -- we  
11 only did that for the stretch uprate. That's why -

12 MEMBER BONACA: I don't understand the  
13 logic. I mean, they seem to have some kind of logic,  
14 so you did that for the power uprate.

15 MR. AIKEN: Yes.

16 MEMBER BONACA: And then?

17 MEMBER STETKAR: I'll give you a good  
18 example, Mario. As I understand it, they said the  
19 steam generator dry-out time currently is 37 minutes.  
20 Is that correct? I don't know what -- SPU conditions  
21 is 37 minutes. I found that in there. I don't know  
22 what the current steam generator dry-out time is under  
23 current conditions. Does anybody know what it is?

24 Now, apparently, in the PRA they used a  
25 30-minute time window for operator actions to start

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 auxiliary feedwater or something like that, so as long  
2 as 30 minutes is less than 37 minutes, they said well,  
3 their 30-minute assumption is justified. That's fine,  
4 but I'm not sure why -- how that translates into a  
5 change in the human error rate, because that 37  
6 minutes is certainly less than what it is today.

7 MEMBER SHACK: Your PRA numbers are about  
8 a factor of 4 lower than when you submitted your  
9 license renewal application. Is that -

10 MR. KAI: Well, we've done a couple of  
11 major updates since then.

12 MEMBER SHACK: They just keep going down,  
13 huh?

14 MR. AIKEN: Well, a couple of things are  
15 happening. We're going through the process of  
16 incorporating the industry standard. We're updating  
17 the data on a more regular basis, incorporating better  
18 methods and models as we go. There's a lot more work  
19 being done in the PRA area now than there has been in  
20 the past, so that's been the net result, is that the  
21 initial risks have been shown to be conservative.

22 CHAIRMAN SIEBER: Any more questions? If  
23 not, I think that we'll take a short break for 5  
24 minutes, but I would like after we return from the  
25 break to have NRR present their remarks on safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 analysis for fuel, and safety analysis. We'll return  
2 at 5 minutes after 3.

3 (Whereupon, the proceedings went off the  
4 record at 2:57 p.m., and resumed at 3:03 p.m.)

5 CHAIRMAN SIEBER: Okay. We'll resume our  
6 meeting, and I'd like to call on NRR to do the fuel  
7 and safety analysis.

8 MR. PARKS: Good afternoon. My name is  
9 Benjamin Parks. I'm in the Reactor Systems Branch in  
10 NRR. I'm joined up here with John Lamb, our Project  
11 Manager, and Sam Miranda, also in Reactor Systems  
12 Branch. We worked together to review this power  
13 uprate.

14 As you can see from our review scope, we  
15 followed the guidance that was in RS-001, and our  
16 review focused on the topical areas covered by RS-001.  
17 I don't think that I need to run through the list.  
18 The last item on that list was Westinghouse methods.  
19 We reviewed an implementation of RETRAN and VIPRE, and  
20 we'll discuss a little bit about that, and answer some  
21 questions, if you may have some remaining.

22 Our review looked at, it says EPU  
23 evaluations, this is a stretch power uprate, we  
24 reviewed it to the EPU standard. We think RS-001 is  
25 a pretty powerful guidance document, and the licensee

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 formatted the licensing report, so it was a natural  
2 fit, pretty thorough evaluation.

3 I guess for the fuel system design itself,  
4 about the only place in the licensing report, and I  
5 feel like this is worthy of pointing out, the  
6 licensee's contractor made the point that it's okay  
7 to, from a mechanical perspective, reinsert previously  
8 irradiated fuel assemblies of a different type other  
9 than RFA or RFA2. The Staff's evaluation, however,  
10 focused on what the nuclear and thermal hydraulic  
11 analyses were for, which was RFA and RFA 2 fuel. And  
12 as you notice from the licensee, the uprated core will  
13 be RFA2 fuel entirely, so that was the focus of our  
14 review. Okay?

15 What we observed in terms of the fuel and  
16 system design was a slight increase to the linear heat  
17 rate, and a slightly less peaked core design. Our  
18 safety evaluation tabulates an overview of the nuclear  
19 effects of the uprate and you see some of the  
20 reactivity coefficients change a little bit. I think  
21 we've already talked about that.

22 Basically, as is typical of a power  
23 uprate, licensing report and our review, we looked at  
24 a sort of reference core design that isn't necessarily  
25 what will be used at the power uprate, but it is an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 updated core, and the cycle-specific, NRC-approved  
2 reload process, which is an NRC-approved Westinghouse  
3 process will confirm that they can live with the  
4 analyses that they set forth here, or will redo those  
5 analyses.

6 CHAIRMAN SIEBER: They may have to change  
7 that if they, during the process of refueling, find a  
8 damaged fuel assembly or something like that.

9 MR. PARKS: Correct.

10 CHAIRMAN SIEBER: And so that's why you do  
11 a separate reload safety analysis.

12 MR. PARKS: Right. You also want to make  
13 sure that if you changed any of your design  
14 parameters, or anything like that, or if something is  
15 implemented on a fit forward basis, you want to make  
16 sure that your safety analysis footprint, I guess your  
17 core design is going to fall within that.

18 So for the thermal hydraulic design, we're  
19 reviewing against GDC-10 and 12. We want to make sure  
20 that specified acceptable fuel design limits are not  
21 going to be exceeded as a result of anticipated  
22 operational occurrences, and we want to make sure that  
23 we have a stable core design.

24 For a Westinghouse reactor, a stable core  
25 design generally refers to a xenon transient. There

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are design features discussed in the licensing report  
2 reflected in our safety evaluation that explain trip  
3 features that sort of act to mitigate a xenon  
4 oscillation, should one occur. But, generally, a  
5 Westinghouse core is designed so that these types of  
6 oscillations where you're burning in and you're  
7 burning out xenon in various places is heavily dammed.  
8 Right.

9 And I'll just mention, I've heard some  
10 members before ask about Condition 1, 2, 3, 4. In  
11 this space, we are looking at Condition 1-4 ANSI scale  
12 events. In other words, Conditions 1 and 2 events are  
13 typically AOOs, anticipated operational occurrences,  
14 so we're looking for those. Typically, we're looking  
15 at violation to the departure from nuclear boiling  
16 ratio, or an acceptable pressurization result. And  
17 then 3 and 4 are more in accident space, either a  
18 limited amount of fuel damage, or an acceptable -

19 MR. WALLIS: So what is your acceptable  
20 DNBR?

21 MR. PARKS: The acceptable DNBR is going  
22 to be in the terms of this analysis, the design limit.

23 MR. WALLIS: So it's 1.2 then?

24 MR. PARKS: Yes, ish. The ish, right?  
25 Basically, I guess, my view on the acceptable DNBR

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 here is, there is -- when we step into DNBR space in  
2 terms of fuel design limit, we're looking at the  
3 safety analysis limit, that upper 1.6, and then below  
4 that to the, I guess, the design limit. It's  
5 basically a basket safety margin. And as you've seen  
6 in some of the accident analyses where they encroach  
7 upon that 1.6 limit, they take a piece out of the  
8 basket, but it's a quantified amount of margin, so  
9 you're not just saying there's margin there so we can  
10 live with it. It's actually quantifiable, and we  
11 notice that it was quantified.

12 MR. WALLIS: Quantifiable in terms of say  
13 1.5 being bigger than 1.2? Is that how you -

14 MR. PARKS: 1.5 being bigger than 1.2, and  
15 then accepting that we've, for a specific accident  
16 that has the .1 penalty, allocated that much margin.  
17 So I guess we used a bank account analogy, so that's  
18 in the balance sheet now. Okay? We're not just going  
19 to swipe the card and forget that we -

20 MR. WALLIS: This always puzzles me,  
21 because a 1.6 is a sort of arbitrary number picked by  
22 the licensee. They could have picked 1.5, and some  
23 other licensees pick other numbers.

24 MR. PARKS: It would leave them with less  
25 operational flexibility, and that's an agreement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 that's (a) sort of out of the scope of our review. I  
2 mean, we definitely consider it. We're more concerned  
3 about the safety limit DNBR, which is an enforceable  
4 quantity. But the point is, they are maintaining  
5 margin to it.

6 Obviously, for thermal hydraulic design,  
7 we're concerned about anticipated operational  
8 occurrences, and that begs the question of transient  
9 analyses and accident analyses. We went through this  
10 morning in a significant amount of detail the  
11 accidents and transients. I'll discuss, or Sam and I  
12 will discuss three specific points that were of  
13 interest to the Staff, and we had some interactions  
14 back and forth with the licensee about.

15 The first I'll tell you about is  
16 overpressure protection. I'll step through those  
17 slides. Sam will tell you about the inadvertent ECCS  
18 actuation, P-19 permissive. I apologize, our pictures  
19 aren't of the best quality, because we took them from  
20 the licensing report, but we do have pictures of the  
21 logic, if we need to talk about that more. And we'll  
22 talk about an interesting transient, rod withdrawal at  
23 power. If we need to move on in the interest of time,  
24 we'll be happy to do so. Overpressure protection.

25 CHAIRMAN SIEBER: Yes, make it as quickly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 as you can.

2 MR. PARKS: We're looking at Condition 2  
3 Acceptance Criteria here, limiting the peak pressure.  
4 And we look at two trips, high pressurizer pressure,  
5 and OT-delta T overtemperature delta T. Typically, we  
6 look for accident analyses to credit the second trip,  
7 and this licensing report credits it first, but we  
8 confirmed through the RAI process that crediting  
9 either trip would be acceptable. And the result was  
10 that the peak pressure didn't exceed 2750.

11 MR. WALLIS: Is this psig or psia?

12 MR. MIRANDA: It's psia.

13 MR. WALLIS: psia?

14 MR. MIRANDA: psia.

15 MR. WALLIS: Strange thing to take  
16 absolute pressure.

17 CHAIRMAN SIEBER: The ASME code gives you  
18 psig, which gives you the steam time margin.

19 (Simultaneous speaking)

20 MR. MIRANDA: 2735 psig.

21 MR. WALLIS: That would be the ASME code.

22 MR. MIRANDA: Yes.

23 MR. WALLIS: Okay. Thank you.

24 MR. PARKS: Okay. So now I'll turn it  
25 over to Sam for the P-19 permissive.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: This is the vessel, which is  
2 in a containment which is not at atmospheric pressure.  
3 It seems a bit peculiar.

4 MR. MIRANDA: It's absolute pressure, and  
5 it's the -- what you get is the output of our analysis  
6 codes.

7 MR. WALLIS: That's right.

8 MR. MIRANDA: psia.

9 MR. WALLIS: But the ASME code has to be  
10 the difference between that and whatever surrounding  
11 pressure.

12 CHAIRMAN SIEBER: Four pounds and 2500.

13 MR. WALLIS: Well, I assume you know what  
14 you're doing. It would be nice if it were clearer.

15 MR. MIRANDA: Well, one of the unique  
16 features of this application is the licensee's  
17 implementation of a new permissive. What they're  
18 doing is adding a P-19 permissive that interlocks low  
19 pressurizer pressure with the cold load safety  
20 injection charging valves. And this relates to their  
21 desire to comply with the acceptance criterion for  
22 Condition 2 events, which stipulates that a Condition  
23 2 event must not develop into a more serious incident.

24 And, typically, for an inadvertent ECCS  
25 actuation, this progression scenario consists of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 filling the pressurizer, opening the PORVs, which  
2 typically are not safety grade. And once the PORVs  
3 open with a ready solid pressurizer and they discharge  
4 water, then they're assumed not to reseal completely.  
5 So what we have then is a Condition 2 event, the  
6 inadvertent ECCS actuation developing into a more  
7 serious small break LOCA event at the top of the  
8 pressurizer.

9 Millstone's case is different in a couple  
10 of respects. First of all, they have this P-19  
11 permissive, and they also have water-qualified PORVs.  
12 There is some history behind this acceptance  
13 criterion, too. In 2005, the NRC issued a regulatory  
14 issued summary, 2005-29, which reminded licensees that  
15 this criterion, this acceptance criterion that a  
16 Condition 2 event must not become a more serious  
17 event, is going to be something that the NRC examines  
18 in all license applications, license amendment  
19 applications. And knowing this, Millstone has acted  
20 proactively to put in this P-19 permissive, which it  
21 changes significantly their ECCS actuation scenario.

22 One more comment, since we talked about it  
23 this morning at length. There is a criterion, that's  
24 an informal criterion, not filling the pressurizer.  
25 Not filling the pressurizer for Condition 2 events is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 related to this. For example, in the loss of  
2 feedwater accident, where the reactor coolant swell  
3 that results from the loss of heat sink gradually  
4 fills the pressurizer, and continues to fill it until  
5 eventually the heat removal through the auxiliary  
6 feedwater system exceeds the decay heat generation  
7 rate. At that point, you reach your maximum  
8 pressurizer level, and, hopefully, that doesn't fill  
9 the pressurizer.

10 The objective in not filling the  
11 pressurizer is to eliminate the possibility of passing  
12 water through open PORVs. So not filling the  
13 pressurizer is a way to demonstrate that their  
14 Condition 2 event will not become a more serious  
15 event.

16 MR. WALLIS: Does the PORV now close?

17 MR. MIRANDA: The PORV if it release steam  
18 will close, if it relieves water we assume will not  
19 close.

20 MEMBER ABDEL-KHALIK: Even if it is  
21 qualified?

22 MR. MIRANDA: If it is qualified, we  
23 assume it will close. And Millstone takes credit for  
24 using the PORVs.

25 MEMBER ARMIJO: Well, that's some sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 unique design, or test. There's something that  
2 qualifies these particular valves?

3 CHAIRMAN SIEBER: Test.

4 MEMBER ARMIJO: Test.

5 MEMBER SIEBER: For valve. You have to  
6 look at the downstream piping, too, because that water  
7 slug's like a board.

8 MR. MIRANDA: Yes, that's half of it. The  
9 other half is qualifying the actuation circuitry to  
10 the safety grade standards. And Millstone is one of  
11 six plants that have water-qualified PORVs.

12 Millstone also has in its history an  
13 inadvertent actuation event occurring in 2005, and  
14 that event resulted in a water leak through the PORVs.

15 MEMBER MAYNARD: Did they close?

16 MR. MIRANDA: They closed. But afterwards  
17 they showed some leakage.

18 CHAIRMAN SIEBER: Usually, the stem bends  
19 a little bit.

20 MEMBER MAYNARD: Some leakage?

21 MR. MIRANDA: Some leakage. Yes.

22 MEMBER BROWN: Some or a lot, talking  
23 about GPE power, GPH, or -

24 MR. MIRANDA: I don't have the exact  
25 amount. I know they repaired one valve and replaced

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the other.

2 MR. WALLIS: I don't quite understand. A  
3 permissive is something where you let them take credit  
4 for something. Is that what a permissive is?

5 MR. MIRANDA: A permissive is -

6 CHAIRMAN SIEBER: It's an actuation signal  
7 that allows the trip signal to pass through.

8 MR. MIRANDA: Yes, it's an interlock.

9 MR. WALLIS: Physical change of some sort.  
10 What's it got to do with permission?

11 MR. MIRANDA: Well, you can -- it depends  
12 on what sign you take. You can either prevent  
13 something or permit it. You can say an interlock,  
14 which would be the negative, and the permissive would  
15 be the positive.

16 MEMBER MAYNARD: These conditions have to  
17 exist before that would come into effect, or -

18 MR. MIRANDA: It imposes a condition for  
19 something else to happen. In this case, you have to  
20 have low pressurizer pressure in order to -

21 MR. WALLIS: In some sort of logic it says  
22 if A, then B.

23 MR. MIRANDA: Yes. In this case, the  
24 permissive comes from the low pressurizer pressure  
25 reactor trip logic, in that you have two out of four

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 low pressure bi-stables, which make up the low reactor  
2 coolant system pressure trip. It also generates the  
3 P-19 permissive. And that permissive is routed to the  
4 cold leg valves, which permit charging flow into the  
5 RCS.

6 MEMBER STETKAR: Sam, I forgot to ask this  
7 morning. Does Millstone have four cold leg injection  
8 valves or two?

9 MR. O'CONNOR: We have injections of four  
10 loops through two safety grade cold leg and actuation  
11 valves.

12 MEMBER STETKAR: Okay. A Train A valve,  
13 and a Train B valve?

14 MR. O'CONNOR: That's correct.

15 MEMBER STETKAR: Thanks.

16 MR. WALLIS: Well, they eject into two,  
17 each valves ejects into two loops?

18 MR. O'CONNOR: No, both valves provide  
19 flow to the four cold leg -

20 MR. WALLIS: Four.

21 MR. O'CONNOR: They're completely 100  
22 percent.

23 MR. MIRANDA: Okay. So with this  
24 arrangement, where you have the permissive or  
25 interlock, however you want to call it, you don't have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 a situation now where a single fault will cause  
2 charging flow to enter the -

3 MR. WALLIS: It's a way to prevent  
4 inadvertent actuation of ECCS.

5 MEMBER SHACK: Well, inadvertent water  
6 going into the -- you can still get ECCS actuation.

7 MR. WALLIS: But the valves aren't open,  
8 so it doesn't happen.

9 MEMBER SHACK: All other ECCS functions  
10 would work.

11 MR. WALLIS: But ECCS doesn't get into the  
12 RCS.

13 MR. MIRANDA: That's true, but you do get  
14 charging flow to the reactor coolant pump seals.

15 MR. WALLIS: Yes. That's what we were  
16 talking about before.

17 MR. MIRANDA: Right. So what it amounts  
18 to is a very slow motion -

19 MR. WALLIS: Pressurizes very slowly.

20 MR. MIRANDA: Yes. It provides the  
21 operator a lot more time to act. And unlike a lot of  
22 other plants, what the operator needs to do in  
23 Millstone is to assure that the block valves to the  
24 PORVs are open so that the PORVs are available for  
25 function. In other plants that don't have this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 permissive, and don't have qualified PORVs, they need  
2 to end the ECCS flow.

3 MR. WALLIS: So this is something else  
4 that has to open in order for this to actuate?

5 MR. MIRANDA: So this diagram which was  
6 taken from the licensee's application shows, marked in  
7 the little balloon there, the new permissive. And you  
8 can see, it comes off the pressurizer low pressure bi-  
9 stables, and they make up the two out of four voting  
10 logic, which continue then to the reactor trip.

11 MR. WALLIS: So a permissive is a physical  
12 thing. Now, I thought a permissive was something that  
13 the NRC allowed, gave permission for, but it's nothing  
14 like that, at all. It's a functional, logical thing,  
15 which opens or closes things.

16 MR. MIRANDA: Yes.

17 MR. WALLIS: That makes it a lot clearer  
18 what it is.

19 MR. MIRANDA: Yes.

20 MR. WALLIS: It's a funny name to give it.

21 MR. MIRANDA: Yes. The Westinghouse RPS  
22 logic is full of permissives.

23 CHAIRMAN SIEBER: Yes, but they've been  
24 doing that for 50 years.

25 MR. MIRANDA: And this is where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 permissive goes. It goes into this ANT gate. You  
2 need that ANT condition to open the valves and permit  
3 the ECCS flow into the RCS.

4 MEMBER ARMIJO: Has any other plant used  
5 or have this permissive, or is this one-of-a-kind,  
6 first-of-a-kind?

7 MR. MIRANDA: Not that I know of. I think  
8 this is a first-of-a-kind.

9 MEMBER ARMIJO: Okay.

10 MR. WALLIS: And it doesn't induce some  
11 new event?

12 MR. MIRANDA: No.

13 MEMBER ARMIJO: No downsides, no -

14 CHAIRMAN SIEBER: Unless it fails, that's  
15 a new event.

16 MEMBER BONACA: Did they perform an  
17 evaluation of risk for the PRA, the configurations?

18 CHAIRMAN SIEBER: Okay.

19 MR. WALLIS: Well, there's a new mode of  
20 failure now, whether for the permissive doesn't  
21 permit, then the ECCS doesn't work.

22 (Simultaneous speaking)

23 MR. WALLIS: There is a new mode of  
24 failure at the ECC.

25 MR. MIRANDA: Well, it's kind of hard to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 imagine a failure of a permissive when it comes from  
2 the two out of four voting logic.

3 MR. WALLIS: But it could still happen.  
4 It could still happen.

5 CHAIRMAN SIEBER: Yes, a card could burn  
6 out, but you've got two -- it meets the regulatory  
7 requirements, and defense-in-depth, and redundancy.

8 MR. MIRANDA: Failure to generate this  
9 permissive means also failure to have a reactor trip  
10 on low pressure.

11 MR. WALLIS: Which would not be very good.

12 MR. MIRANDA: Which should not be  
13 possible. It would not meet GDC, I think, 20.

14 MEMBER ARMIJO: I'm trying to understand  
15 this thing a little bit better. If there was no  
16 stretch power uprate, would the staff still look  
17 kindly on approving this permissive, or would you even  
18 get involved? Is this a good thing to do, even  
19 without SPU for this particular plant?

20 MR. MIRANDA: I believe it's a good thing  
21 to do for this plant, and other plants that have high  
22 pressure ECCS systems.

23 MEMBER ARMIJO: Improvement, independent  
24 of stretch power uprate.

25 MR. MIRANDA: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARKS: At this point, we're going to  
2 start talking about reactivity and power distribution  
3 anomalies, and I'd like to start before the rod  
4 withdrawal at power to follow-up on some discussion  
5 that you had about the Staff's acceptance of 200  
6 calories per gram for the reactivity insertion  
7 accident.

8 I don't believe we have a generic safety  
9 issue that we pursued with this, but we are following  
10 it up. And I'd like to introduce Paul Clifford to  
11 discuss -

12 MR. WALLIS: How many calories per gram  
13 did you say?

14 MR. PARKS: 200. That's the Westinghouse  
15 acceptance criterion for the enthalpy addition.

16 MR. WALLIS: It just seems high, isn't it?

17 (Simultaneous speaking)

18 MEMBER POWERS: It just depends on whether  
19 your fuel has any burn-up or not. If it doesn't have  
20 any burn-up, it's not -- if it's new, it's okay. But  
21 if it has a little burn-up, then you've got a problem.

22 CHAIRMAN SIEBER: Let's move along.

23 MR. PARKS: Could you please summarize for  
24 us what we're looking forward to in terms of that  
25 accident and the acceptance criteria?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. CLIFFORD: As many of you are aware,  
2 Reg. Guide 177 has some deficiencies in it, and the  
3 staff has been -

4 MEMBER POWERS: Has for 25 years.

5 MR. CLIFFORD: Exactly. And the Staff has  
6 -- excuse me. Paul Clifford, NRR DSS. The Staff has  
7 been reluctant to -- I shouldn't say reluctant -- has  
8 been slow in revising Reg Guide 177.

9 I think it's important to realize that  
10 Westinghouse identified this deficiency really with  
11 the 280 calories per gram, which is the coolability  
12 limit. And they imposed an internal guidance of 200  
13 calories per gram to preserve coolable geometry. And  
14 that, even now, we're looking at revising Reg Guide  
15 177, and to date, the criteria would be 230 calories  
16 per gram, so the 200 calories per gram for coolability  
17 would remain conservative. Nowhere in the  
18 Westinghouse internal -

19 MEMBER POWERS: Be precise. It would  
20 remain conservative relative to 200, relative to  
21 reality it's wildly non-conservative.

22 MR. CLIFFORD: Well, we can't mix up PCMI  
23 failure with coolable geometry. The 200 calories per  
24 gram limit, the Westinghouse-determined limit, is not  
25 a PC -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER POWERS: It's not conservative for  
2 fission product release.

3 MR. CLIFFORD: Right. But the  
4 Westinghouse internal criteria of 200 calories per  
5 gram is not to prevent PCMI failure. It's not  
6 replacing the 100 calories per gram, or the 150  
7 calories per gram, numbers thrown around like that.  
8 It's a maximum limit on coolable geometry, which is  
9 intended to prevent molten fuel from being dispersed  
10 into the coolant.

11 Now, the Staff has always relied upon the  
12 available margin in 2D methods to make up for the fact  
13 that we haven't introduced a PCMI-specific fuel  
14 failure criteria. And that's still our position  
15 today, but you need to note that Westinghouse still  
16 uses a very conservative method of using DNB as the  
17 point of failure for the cladding, and determining how  
18 many pins or how much RCS activity is available for  
19 release and for off-site doses. So the real question  
20 is, is DNB more or less conservative than what recent  
21 tests of Cabri or NSRR would tell us that PCMI failure  
22 would occur. And I believe that, up to reasonable  
23 burn-ups, mid- to high burn-ups, DNB would remain  
24 limiting relative to PCMI, and only high burn-up fuel  
25 that's heavily corroded and absorbed a lot of hydrogen

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 would PCMI become more limiting. And you would have  
2 to ask yourself would that fuel be -- have the ummpf,  
3 the reactivity left in it to actually experience PCMI.  
4 And it may, depending on fuel management. But there  
5 is ample margin, as Westinghouse has stated, the 3D  
6 methods could clearly show less than 100 calories per  
7 gram delta.

8 MEMBER BONACA: That's an issue to figure  
9 out, I mean, if they used 3D neutronics with proper  
10 simulation with Doppler feedback and so and so forth,  
11 you would get much lower calories per gram deposition.  
12 And by leaving the criterion so high, then you're  
13 allowing methodologies which are obsolete. I mean,  
14 they used to use it 20 years ago, combination of point  
15 kinetics with the 3D axial shape, which is not 3D. I  
16 mean, so --

17 MR. CLIFFORD: That's correct. And by  
18 maintaining the DNB failure criteria, the dose calcs  
19 will maintain sufficient conservatism.

20 MEMBER POWERS: How do we know this? This  
21 is based on your gut feeling?

22 MR. CLIFFORD: The Staff currently relies  
23 upon Rule 0401 which is an operability assessment  
24 performed in 2003 to state based upon three-  
25 dimensional physics calculations that show the current

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 fleet remains conservative relative to an  
2 investigation of the recent PCMI failures noted at NSR  
3 and Cabris.

4 MEMBER BONACA: It seems to me also that,  
5 I mean, physically DNB is a cladding issue, and the  
6 rod ejection, it's calorie deposition, and possible  
7 fuel damage, and burst, and so, I mean, I hear you,  
8 but -

9 MR. CLIFFORD: That is correct. We have  
10 issued interim guidance which we are currently  
11 imposing on new reactors, and we will be imposing that  
12 interim guidance once it's finalized over the next six  
13 to twelve months, and are going through the proper  
14 channels of backfit on current operating fleets.

15 MR. WALLIS: I'm trying to understand your  
16 argument. You're saying a lot of heat goes into this  
17 fuel, but because you don't have DNB, a lot of heat  
18 also comes out? Is that the argument?

19 MR. CLIFFORD: No.

20 MR. WALLIS: Therefore, it's okay?

21 MR. CLIFFORD: That's not what I'm saying.

22 MR. WALLIS: Well, what's the DNB argument  
23 got to do with so many calories per gram, and how are  
24 they linked together?

25 MR. CLIFFORD: They're using conservative

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 test methods, and assuming that if the clad goes into  
2 DNB for even a split second, that that cladding fails,  
3 and you release all of the gap activity for your dose  
4 calculation. That's a conservative assumption.

5 Now, if you were to look at PCMI failure

6 -  
7 MR. WALLIS: Do you know how to calculate  
8 DNB in a transient like this?

9 MR. CLIFFORD: It's very conservative to  
10 assume that the steady-state DNBR methods are valid  
11 for the speed of this transient.

12 MR. WALLIS: All the correlations are  
13 based on a steady-state.

14 MR. CLIFFORD: That is correct.

15 MR. WALLIS: And you're saying it's  
16 conservative with regard to a transient, because those  
17 things don't have time to get up to steady-state or  
18 something, or what? Is this a gut feeling, or is it  
19 justifiable analytically?

20 MR. CLIFFORD: There's several -

21 MEMBER BONACA: What they've been using  
22 forever, all the vendors, is to be a point kinetics  
23 calculation, and then a static calculation of axial  
24 values, and then they combine the two of them, and  
25 they call it a 3D calculation. Actually, it's not.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 It's a point kinetics calculation of some kind, and  
2 you do a DNB calculation to look at the thermal  
3 hydraulics of that. But you don't get the benefit of  
4 Doppler feedback, LOCA that you would have if you had  
5 a 3D simulation, too. And also, analytical methods.  
6 All the vendors have had it for a number of years, but  
7 it's expensive to use, and also you would have to  
8 change the regulation, I guess, because -- and so what  
9 happened is that nobody is using advanced methods.  
10 They're still using this hybrid static calculation  
11 where you don't get sufficient feedback to lower your  
12 peaking factor, so, therefore you have 200 calories  
13 per gram deposition. In reality, with the 3D  
14 calculation they show value at the order of 60-70  
15 calories per gram peak. Until you tighten up the  
16 criteria, that is the indication that you have, nobody  
17 is going to use more advanced methods.

18 MR. CLIFFORD: That's true, but to get  
19 back to the question that Graham Wallis had. The  
20 experimental results show -- well, confirm that the  
21 170 calories per gram radial average enthalpy is a  
22 point at which DNB failure occurs. And when you use  
23 our methods to calculate DNBR, I'm confident that it  
24 would be below 170 calories per gram.

25 MR. PARKS: Okay. So having heard on that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 issue, I want to share with you the rod withdrawal at  
2 power accident, or the transient analysis. At power  
3 is evaluated in the licening report. It considers, I  
4 believe, 1060 and 100 percent power, various rates of  
5 reactivity insertion. The results were acceptable,  
6 but there is a reference in the licensing report to a  
7 generic disposition of the potential for  
8 overpressurization associated with this transient.  
9 Basically, the high pressurizer pressure trip may not,  
10 if this accident is initiated at a low-power level,  
11 terminate the accident before there's  
12 overpressurization, so there's a generic evaluation  
13 that shows that this is not the case. We questioned  
14 that in the next slide.

15 The generic study was docketed for another  
16 licensee in concert with a different license amendment  
17 request, and it was performed as described here.  
18 Basically, it's for a four-loop Westinghouse plant to  
19 demonstrate that the positive flux rate trip will help  
20 terminate this transient before there's a  
21 pressurization problem. And the four-loop study, I  
22 was concerned, didn't cover Westinghouse's power  
23 level, so I asked about it.

24 I worked with Project Management and the  
25 licensee to conduct an audit, and we had some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 sensitivity studies that we reviewed of this accident.  
2 And, basically, what the licensee contended initially,  
3 and demonstrated with some sensitivity studies on this  
4 generic study, was that the potential for energy  
5 addition associated with the core uprate is mitigated  
6 by water-filled loop seals which are assumed in the  
7 accident and do not exist at the plant, water-filled  
8 loop seals on the pressurizer safety valve discharge  
9 piping. So because Millstone doesn't have those,  
10 there's no purge delay on its pressure relief, and so  
11 the safety valves relieve the pressure, and acceptably  
12 mitigate the consequences of the event.

13 MR. WALLIS: These are loop seals on the  
14 pressurizer discharge piping?

15 MR. PARKS: The safety valve discharge  
16 piping.

17 MR. WALLIS: You're just looking at the  
18 hydrostatic head in the loop seal?

19 MR. PARKS: Right. And there's -

20 MR. WALLIS: It's a rather small -

21 MR. PARKS: About a second and a half  
22 purge delay. And what you can see from the  
23 sensitivity studies -

24 MR. WALLIS: It's very small compared with  
25 the -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARKS: It is, but it's approaching  
2 2700 psia, and so, in that case -

3 MR. WALLIS: Loop seal is worth what, 10  
4 psi or something? What is it worth?

5 MR. PARKS: They contributed something  
6 like 20 pounds, and so eliminating -- basically, the  
7 energy addition and the pressurization associated with  
8 the increase in power level I think added about 20 to  
9 the peak pressure, and then eliminating the loop seals  
10 took down 20. The reason I was concerned about is  
11 because we're so close to 2750. Okay.

12 All in all, the results came out okay. We  
13 demonstrated and got the necessary information about  
14 Millstone 3 to show that we're reasonably assured that  
15 the positive flux rate trip will terminate this event,  
16 and the pressurizer safety valves will adequately  
17 mitigate the transient. In actuality, obviously, the  
18 PORVs will take care of this, so we covered that.

19 Okay. The next thing we'll talk about is  
20 LOCA. The licensee evaluated large breaks using  
21 ASTRUM. ASTRUM is the second, I guess, generation of  
22 a Westinghouse best-estimate LOCA analysis method. We  
23 previously, before this Automated Statistic Treatment  
24 of Uncertainties Method, before we approved that, we  
25 had approved what's called the Code Qualification

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Document Methodology. So, basically, what we're  
2 talking about is a statistical process, and that's  
3 based on WCOVERT TRAC, both methods were based on  
4 WCOVERT TRAC. ASTRUM is 124 cases convoluted with  
5 uncertainties associated with the plant parameters.  
6 There is no change to the small break evaluations.

7 MEMBER POWERS: One hundred and twenty-  
8 four samples in a minor correlating analysis, and  
9 build the distribution, depends, of course, on what my  
10 uncertain parameters are. I have relatively broad  
11 uncertainty bounds on each of the quantiles. How do  
12 they pick within that quantile range what number to  
13 use?

14 MR. PARKS: Now we're stepping from the  
15 plant-specific application of ASTRUM to its original  
16 basis for approval, so I researched it, Dr. Powers.  
17 I'm not as familiar with that as I am with Millstone.  
18 What I understand is the documentation that we have,  
19 and that we reviewed, considered -- now I looked at  
20 the introduction document. I mean, this is volumes  
21 and volumes of information. It's a huge amount of  
22 paper. But the introduction, in my opinion, concisely  
23 summarizes the various parameters against which  
24 uncertainty is considered, and are convoluted. And my  
25 opinion was, and you're just confirming that a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 statistical method is okay. I wasn't re-reviewing the  
2 method. There was adequate information contained in  
3 the submittal for the Staff to review, and its  
4 contractors to review all of the statistics and  
5 conclude that 124 cases agree that that was  
6 acceptable.

7 MEMBER POWERS: It's not a bad number to  
8 run, but in the end, you want a number to compare  
9 against some criterion. And usually you pick -- what  
10 you select, a mean value, a 95 percentile, or  
11 something like that, is kind of up between you and  
12 God, whatever gets decided. I know of no analytic way  
13 to make that choice. But when you go to 124, it's not  
14 a huge number of analyses, not a bad number, not a  
15 huge number. And, typically, if I go to a quantile,  
16 say I decide I want to use the 95 percentile, I will  
17 find that I have a fairly substantial range that  
18 corresponds -- that I know the 95<sup>th</sup> percentile lies  
19 within that range. I just wondered, how do you pick  
20 a number out of that range?

21 MEMBER STETKAR: What you're saying is in  
22 the standard Monte Carlo analysis, you look at  
23 convergence of the mean. You run enough samples, and  
24 then you have some confidence that -

25 MEMBER POWERS: The distribution, and you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 can only determine that distribution to a confidence  
2 level, because it's not an infinite number of samples.  
3 And so you set up the distribution, and you say well,  
4 okay, I'm going to take the 90<sup>th</sup> percentile on my  
5 quantiles, and there's a range there. So what number  
6 do I pick? I mean, I'm just curious.

7 MR. PARKS: Well, when I approved, or  
8 recommended the approval of the implementation, I'm  
9 working from the fact that the ASTRUM method has  
10 already been reviewed and approved, so I didn't  
11 revisit the adequacy of the selection of 124.

12 MEMBER POWERS: I don't argue with that.  
13 I mean -

14 MR. PARKS: So I guess where I'm headed  
15 with the question is, I think it may be a question  
16 that's better answered by the folks at Westinghouse,  
17 because it's their method, and it's under their  
18 control.

19 MEMBER POWERS: I'm desperately hoping  
20 they charge forward here.

21 MR. WALLIS: I don't think there's any  
22 range there. I think you just assert that 1781, you  
23 have 95 percent confidence that that 1781 lies within  
24 the 95<sup>th</sup> percentile. That's all you can say. With  
25 this value you get, that's what you say. Some other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 day you may run the codes 124 times and get 1722 or  
2 something. You have the same argument you can say  
3 then. I don't see any range of anything, though.

4 MEMBER POWERS: You can say that 1781 lies  
5 within the 95<sup>th</sup> percentile. I will believe that. But  
6 so might 1855 lie within the 95<sup>th</sup> percentile. I mean,  
7 the 95<sup>th</sup> percentiles do get pretty broad.

8 MR. WALLIS: Don't say anything about  
9 that.

10 MEMBER POWERS: Well, then I'm not very  
11 well informed here.

12 MR. WALLIS: No, you could be better  
13 informed. Sure.

14 (Laughter.)

15 MR. WALLIS: There's more information -

16 MEMBER POWERS: That's true almost  
17 throughout my life, Graham, that I could have been  
18 better informed.

19 MR. WALLIS: For information, but if you  
20 ask a specific statistical question, you get a  
21 specific answer. If you ask another question, you can  
22 get different answers, depending on what question you  
23 ask.

24 MEMBER POWERS: The question I'm really  
25 asking, Graham, is what is the temperature that I'm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 going to get in the event of one of these deleterious  
2 accidents.

3 MR. WALLIS: Well, you could ask what the  
4 mean is.

5 MEMBER POWERS: And if I want to be  
6 relatively conservative, I really want to know what  
7 the upper bound on that 95<sup>th</sup> range quantile is.

8 MR. WALLIS: You won't get enough of that,  
9 unless you run an infinite number of runs.

10 MEMBER POWERS: Well, I'm willing to say  
11 okay, give me the 95<sup>th</sup> percentile at 95 -

12 MR. WALLIS: You can say give me the 99<sup>th</sup>.  
13 You can ask for more and more.

14 MR. PARKS: I believe the point of the  
15 method is through 124 cases, there's a reasonable  
16 degree of confidence acceptable to the staff that  
17 we've identified a number under which -

18 MEMBER POWERS: I will accept that.

19 MR. PARKS: Okay.

20 MEMBER POWERS: What I'm asking is now,  
21 you, the staff, have looked at this methodology, so  
22 with 124 samples. I sampled, I know I have to a  
23 confidence level of about 95 percentile, I have  
24 sampled about 99 percent of the parameter space.  
25 Okay. And that's what the number corresponds to.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Okay. You have a distribution. Now you need a  
2 number. You need a number to compare against 2200  
3 degrees Fahrenheit. Okay? And you say, I take the  
4 95<sup>th</sup> percentile number, but there's a range up here,  
5 and I'm asking how big is that range?

6 MR. WALLIS: Well, I don't think  
7 Westinghouse reports all of the data of the 124. If  
8 they did, you could start to do that. They just  
9 report the biggest number. Isn't that what they do?

10 MR. PARKS: Right.

11 MR. WALLIS: They don't say that the  
12 lowest number was 1200 or something, do they? They  
13 don't give you any other information. They just  
14 follow the rule.

15 MR. PARKS: That's how the method is  
16 employed. That's how we approved it.

17 MR. WALLIS: That's how it works. That's  
18 right.

19 CHAIRMAN SIEBER: It seems to me like  
20 we're not really getting anywhere with this  
21 discussion. I'd like to move on.

22 MR. PARKS: Okay. So the results of the  
23 analysis, you've already seen. This small break came  
24 in at 1193, and that was a four-inch break, I  
25 confirmed, pretty significant margin-ing on cladding

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 oxidation and on core life.

2 MEMBER ABDEL-KHALIK: Does the 3-1/2  
3 percent clad oxidation number include pre-accident  
4 oxidation?

5 MR. PARKS: Does it include pre -- I  
6 believe that it does, or that the limiting scenario is  
7 chosen at a point -- okay.

8 MS. ANTOINE: My name is Stephanie  
9 Antoine. I'm from Westinghouse, on the best-estimate  
10 large break LOCA. The 3-1/2 percent does not include  
11 the pre-transient oxidation. The ASTRUM methodology  
12 was approved without the pre-oxidation.

13 MEMBER ABDEL-KHALIK: Now, the 17 percent  
14 acceptance criterion does include pre-transient  
15 oxidation.

16 MS. ANTOINE: That is not in the statement  
17 that we, I believe, have in our analysis. The way  
18 that it was approved by the NRC was that to meet the  
19 17 percent, we did not need to include pre-transient  
20 oxidation.

21 MEMBER SHACK: It does, but let's go on.

22 MR. PARKS: All right. Next slide,  
23 please. Westinghouse is implementing VIPRE and RETRAN  
24 to replace THINC-IV and LOFTRAN for the transient  
25 analysis methodology. In some cases, the LOFTRAN code

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is maintained, particularly for the steam generator  
2 tube rupture, a modified version is used to credit  
3 operator actions. I say here transients for the use  
4 of WRB2 is restricted, but I believe that that's a  
5 coincidence, not a reason to -

6 MR. WALLIS: What am I supposed to  
7 conclude from this? Is the VIPRE-RETRAN supposedly  
8 better or something? What do I conclude from this  
9 information?

10 MR. PARKS: RETRAN is a method that's, I  
11 know, based on LOFTRAN. It's the more current  
12 Westinghouse accident analysis method.

13 MR. WALLIS: Is the RETRAN 3D? Is that  
14 what this is?

15 MR. PARKS: No.

16 MR. WALLIS: The old RETRAN.

17 MEMBER POWERS: Yes, it's not nearly as  
18 good as the one that you have used.

19 MR. HEUGLE: Yes. This is Dave Heugle,  
20 Westinghouse. It's the old RETRAN-02.

21 MR. WALLIS: It's an old RETRAN.

22 MR. HEUGLE: Yes. It's not the RETRAN 3D.

23 MR. WALLIS: But what should someone  
24 reading this conclude? They've changed the code. Did  
25 they change it in order to get some advantage for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 themselves? Why did they do? What am I supposed to  
2 conclude from this?

3 MR. HEUGLE: The standard practice that we  
4 see when there's an uprate, Westinghouse typically  
5 implements their new -

6 MR. WALLIS: Because they get better  
7 numbers, or is it because it's a more reliable code,  
8 or what?

9 MR. MIRANDA: I believe that when we  
10 reviewed RETRAN, we compared the results to those  
11 obtained with LOFTRAN, observed that they were largely  
12 consistent, so it wouldn't be expected that you'd see  
13 significantly different results using one or the  
14 other.

15 MR. WALLIS: But you haven't run anything  
16 yourself, so you have no idea how good these codes are  
17 compared with something else?

18 MR. HEUGLE: This is Dave Heugle from  
19 Westinghouse. The reason we went with RETRAN was to  
20 align ourselves more closely with the utilities, and  
21 to also try and set ourselves up to allow us to take  
22 advantage of some improved methodologies down the  
23 road. But as a first step, what we did in the RETRAN  
24 submittal was to use the same methodology as we  
25 applied for LOFTRAN. And, as was stated, we compared

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 those results to our LOFTRAN results, and for all the  
2 transients we showed that you get very similar  
3 results.

4 In addition, at the Ganay Beaver Valley  
5 extended power uprating, we also provided results that  
6 showed for actual plant transients, that the RETRAN  
7 model very closely matched for a number of different  
8 primary and secondary site conditions what we actually  
9 got from plant data.

10 CHAIRMAN SIEBER: Thank you. Why don't we  
11 do the summary now?

12 MR. PARKS: So we reviewed the transients  
13 and accident analyses that demonstrated acceptable  
14 results at the uprated conditions, confirmed that the  
15 fuel design remains acceptable to support the uprate,  
16 and the methods have been implemented acceptably. We  
17 reviewed conditions, limitations on the methods, and  
18 the technical basis underlying those conditions and  
19 limitations to make sure that the licensee was in  
20 compliance with those, and the technical basis.

21 CHAIRMAN SIEBER: Any questions?

22 MR. WALLIS: When you listened to the  
23 questions ACRS had this morning, did the same  
24 questions occur to you, or are we more critical than  
25 you are of this? You have given a pretty sure review

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 here. Right? Did the same sort of questions get  
2 asked by you as they're being asked by, say, my  
3 colleagues here?

4 MR. PARKS: We spent some time -- we. I  
5 just promoted myself to an ACRS member, I apologize.  
6 The Committee seemed to discuss, heavily, comparison  
7 between RETRAN and LOFTRAN. Okay? And I asked a lot  
8 of those questions as draft RAIs, and ultimately  
9 removed them, having accepted the fact that as I dug  
10 into the methods themselves and noticing that the  
11 results from the various methods are largely  
12 consistent, that the implementation of the new  
13 analysis method, also given the fact that it's NRC-  
14 approved.

15 MR. WALLIS: But we asked questions, such  
16 as why is this number so much bigger than that number?  
17 Why is 1875 so much bigger than 1543, or something?  
18 Did you do that sort of thing, too? Did you get  
19 satisfactory answers?

20 MR. MIRANDA: I know I did. I asked  
21 questions like that, too. That's the first question  
22 you might ask when seeing the results. And you've got  
23 to know how it breaks down. And I have asked a couple  
24 of questions like that, and I've received plausible  
25 responses.

1 MR. WALLIS: I would think, you've got a  
2 long time to do this. You have a year to do it. We  
3 have -

4 MR. PARKS: No, we didn't have a year to  
5 do this.

6 MR. WALLIS: But, presumably, you asked  
7 many more questions than we do. I just want to make  
8 sure that you cover at least the kind of range that we  
9 cover, and probably many more. That's it.

10 MR. PARKS: We tried, I guess, to give you  
11 a sampling of things that we interacted with the  
12 licensee. I mean, I saw the rod withdrawal at power  
13 accident, for instance, and I didn't think there was  
14 quite enough information there, so I wanted to see  
15 more about that. So the answer to your question is  
16 yes, we asked the same types of questions. When we  
17 saw stuff that changed significantly, we asked about  
18 that. I asked about reactivity insertion rates.

19 MR. WALLIS: You don't feel that it's not  
20 an embarrassment that you had not asked the question  
21 when we asked it.

22 MR. PARKS: I'm sorry. I didn't hear the  
23 first part.

24 MR. WALLIS: You didn't feel any kind of  
25 embarrassment that you had not asked the question when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we asked it. You heard our questions, you didn't say  
2 gee whiz, I wish I'd asked that. You didn't have any  
3 kind of that reaction.

4 MEMBER POWERS: Did you ever feel God, I'm  
5 glad I didn't ask such a stupid question? .

6 (Laughter.)

7 MR. PARKS: Dr. Powers, I can't answer  
8 that question.

9 (Laughter.)

10 MEMBER MAYNARD: It's probably best to  
11 move on.

12 CHAIRMAN SIEBER: With that remark, I  
13 think that I appreciate your presentation. And I have  
14 a suggestion for the rest of the day. I've read  
15 through basically all the elements in the SER, and the  
16 application. And in my opinion, the electrical  
17 section is pretty simple, and I don't think that we  
18 need to review that. On the other hand, if any member  
19 objects, I'd like to know about that. And the flow-  
20 accelerated corrosion is also another area that is  
21 pretty standard in the industry. They're using  
22 standard methods and achieving the same results, so I  
23 suggest we accept -

24 MR. POWERS: When you say you get the  
25 standard results, that includes thinks like Surry?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: No, Surry didn't use  
2 CHEKWORKS. On the other hand, containment analysis  
3 has some interesting features to it, particularly  
4 because of the sub-atmospheric containment. They are  
5 not asking for credit for containment pressure, which  
6 is a good thing. On the other hand, I think it would  
7 be good if Dominion would present their containment  
8 analysis, and the staff can follow-up with their  
9 analysis of Dominion's application. So if there are  
10 no objections, I'd like to change the agenda to do  
11 that.

12 MEMBER STETKAR: A minor monkey wrench. I  
13 had a couple of questions about their EQ of electrical  
14 stuff, in the main steam safety valve building.

15 CHAIRMAN SIEBER: Okay.

16 MEMBER STETKAR: That's the only -

17 CHAIRMAN SIEBER: You're talking about -

18 MEMBER STETKAR: The high temperature  
19 stuff. And I think I can get it resolved, I hope I  
20 can get it resolved real quickly. I don't want to  
21 make a big deal about -

22 CHAIRMAN SIEBER: Why don't you ask the  
23 question now and we'll see.

24 MEMBER STETKAR: I'll do that. Are the --  
25 and I've seen them called -- are the main steam

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 atmospheric relief valves, or I've seen them called  
2 atmospheric dump valves, called both things, at  
3 Millstone, are they safety-related equipment, or not?

4 MR. RUSSELL: Paul Russell, Operations.  
5 The atmospheric steam relief valves?

6 MEMBER STETKAR: Yes.

7 MR. RUSSELL: Our steam generator PORVs,  
8 if you will, they are air-operated, and because  
9 they're air-operated, we don't take credit for them.

10 MEMBER STETKAR: Okay. So they're not  
11 safety-related.

12 MR. RUSSELL: That's correct.

13 MEMBER STETKAR: So, therefore, their  
14 operators are not qualified for the steam environment.  
15 Is that correct?

16 MR. RUSSELL: They do get -- if we have a  
17 main steam line isolation, they do get isolated.

18 MEMBER STETKAR: No, no, no, no. I'm  
19 asking, if you had a steam line break in -- I'm  
20 assuming the operators for the steam line -- main  
21 steam PORVs are located in the main steam valve  
22 building. Is that correct?

23 MR. RUSSELL: Yes.

24 MEMBER STETKAR: Yes. Okay. So if you  
25 have a steam line break in that building, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operators for those valves are not qualified to  
2 operate in that environment. Is that correct? I'm  
3 not talking about the isolation valves, the motor-  
4 operated. I'm talking about the atmospheric reliefs,  
5 themselves.

6 CHAIRMAN SIEBER: If the line is broken,  
7 why do you need atmospheric relief? I mean, it's all  
8 coming out anyway.

9 MEMBER STETKAR: If you have a break in  
10 that building, these are upstream from the MSIVs. Is  
11 that correct?

12 CHAIRMAN SIEBER: They're between the  
13 MSIVs.

14 MEMBER STETKAR: They're between the steam  
15 generator and the MSIVs. Right?

16 CHAIRMAN SIEBER: Yes.

17 MEMBER STETKAR: So if I have a steam line  
18 break in the main steam valve building, and the MSIVs  
19 go closed, I can still use the atmospheric relief  
20 valve on that steam generator. Right?

21 MR. RUSSELL: That is correct. Yes.

22 MEMBER STETKAR: Okay. But the operators  
23 are not qualified for that steam environment. Is that  
24 right?

25 MR. RUSSELL: That's a question I have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 defer to design.

2 MEMBER STETKAR: This is kind of -- I want  
3 to find out, this is sort of PRA-related issue,  
4 because since the steam temperatures are so much  
5 higher in that building right now, I want to find out  
6 if the PRA takes credit for using the atmospheric  
7 relief valve on the line with -- on a line that's now  
8 isolated for secondary heat relief, because I didn't  
9 notice that the -- it's a convoluted environment, it's  
10 a convoluted scenario. You get a steam line break,  
11 MSIVs close successfully; however, you -- because the  
12 break was in that -- is the main steam valve building  
13 -- I don't know anything about the plant. Do you have  
14 four separate enclosures, or do all the steam lines  
15 come through a single -

16 MR. RUSSELL: They basically come through  
17 one single -

18 MEMBER STETKAR: Single.

19 MR. RUSSELL: So there's not separate  
20 enclosures for each -

21 MEMBER STETKAR: So it's a single. You're  
22 talking about a single volume.

23 MR. RUSSELL: Yes.

24 MEMBER STETKAR: Okay. So what would  
25 happen is, you'd have a steam line break. You'd

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 relieve a bunch of steam into there for some period of  
2 time. The MSIVs would go closed. Temperature would  
3 be up. The question is, does the PRA then take credit  
4 for use of the atmospheric relief valves to remove  
5 secondary heat for active cool-down during one of  
6 those events?

7 MR. O'CONNOR: Mike O'Connor. I think I  
8 can help you with that. The atmospheric relief valves  
9 are air-operated. We don't credit those components,  
10 because the air system is not safety-grade.

11 MEMBER STETKAR: In the safety analysis,  
12 I asked does the PRA take credit for it.

13 MR. O'CONNOR: So there's no operator  
14 action to use those for a cool down. There are other  
15 valves that are used.

16 MEMBER STETKAR: Okay.

17 MR. O'CONNOR: Did that answer your  
18 question?

19 MEMBER STETKAR: Yes. I mean, as long as  
20 the PRA doesn't take credit for the atmospheric  
21 reliefs.

22 MR. RUSSELL: I'm pretty sure it doesn't,  
23 but I'll confirm that when I --

24 MEMBER STETKAR: After a steam line break,  
25 I only care about the steam line, or a feed line break

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 in the same area.

2 MR. KAI: Millstone 2 has two dump valves  
3 per generator, so there's actually eight valves, one  
4 is air-operated, and one is motor-operated. There are  
5 two totally separate valves on each generator.

6 MEMBER STETKAR: But all the operators are  
7 in this -

8 MR. KAI: Right. One is air-operated, one  
9 is motor-operated.

10 MEMBER STETKAR: Well, if you're going to  
11 back up and get to the motor-operated ones, then I'll  
12 ask you are the motor operators qualified to operate  
13 in 562 degrees -- I don't know. The atmospheric  
14 relief isolation valves and the bypass isolation  
15 valves were discussed to some extent. In fact, those  
16 are the ones that you're specifically insulating  
17 because you couldn't get them qualified to operate in  
18 that environment, so that they would close to isolate  
19 a break in the relief valve line. Recognizing that's  
20 limited to a three-inch break.

21 I'm worried about the operability of the  
22 relief function after a steam line break, or a feed  
23 line break, with successful -- subsequent successful  
24 main steam isolation, because that type of function  
25 was not discussed in any of the EQ discussion for that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 building. Jack, thanks. That's enough.

2 CHAIRMAN SIEBER: Okay.

3 MR. WALLIS: You didn't get an answer.

4 MEMBER STETKAR: That's -

5 CHAIRMAN SIEBER: Let's see if we can  
6 finish up on the containment analysis.

7 MR. COLLIER: Mike Collier back again to  
8 talk about containment analysis. To expedite our  
9 discussions, since I think you want to go directly to  
10 the results. I think that what I would recommend is  
11 that we start with Slide 8, unless you want to go and  
12 discuss the ones before. We'll start with 8, that  
13 gives the actual results. And I can talk in terms of  
14 what the initial conditions are, and what our results  
15 are, or would you -

16 MR. WALLIS: And they're all using  
17 different codes than you had before.

18 MR. COLLIER: Okay. We could start with  
19 6. Six is the changes in methodology. Now, again -

20 MR. WALLIS: I have no idea what that  
21 means.

22 MR. COLLIER: Okay.

23 MR. WALLIS: That doesn't -- I don't think  
24 it matters, but I just -- you've changed the code. I  
25 need some assurance that it hasn't -- the numbers

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 haven't changed because you've changed the code,  
2 they've changed, giving a fair representation of  
3 what's the effect of the uprate. That's all. How do  
4 I get that assurance?

5 MR. COLLIER: Well, in this case we  
6 benchmarked -- the work course code is GOTHIC.

7 MR. WALLIS: You benchmarked the new code  
8 against the old conditions?

9 MR. COLLIER: Yes, exactly. Here is the  
10 results. With the current analysis, assumptions we  
11 reproduced with GOTHIC to make sure that we got  
12 exactly the same answers.

13 MR. WALLIS: Okay. Thank you.

14 MEMBER BROWN: That's one of the  
15 circumstances where you benchmarked your new one  
16 against your results from the old code in the old  
17 plant.

18 MR. COLLIER: Yes. Correct.

19 MEMBER BROWN: The current plant.

20 MR. COLLIER: The current plant, correct.

21 MEMBER BROWN: With assumptions, et  
22 cetera. Which you didn't do with the reactor design-  
23 type codes.

24 MR. COLLIER: Correct.

25 MEMBER BROWN: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. COLLIER: And we are using the  
2 internal -- it was approved by the NRC, so we have  
3 done that benchmarking to make sure that GOTHIC will  
4 produce the same results as the current containment  
5 tool.

6 Slide 8 is the initial conditions. What  
7 we tried to do here is expand the range of initial  
8 conditions that we're going to assume for some  
9 additional operational flexibility, so we will look  
10 at, as you can see, a wider range of parameters. We  
11 used both ends, whichever is conservative, either the  
12 low end or high end, and that's the point of Slide 8.

13 Slide 9 gives the actual results, compares  
14 current to SPU for LOCA and steam line break.

15 MR. WALLIS: This containment liner  
16 temperature is an average temperature.

17 MR. COLLIER: Correct.

18 MR. WALLIS: But in reality, a big LOCA  
19 produces a jet, which could impinge on the liner, so  
20 there could be local places where the temperature of  
21 the liner is 500 degrees. Pressure is pretty uniform,  
22 but the temperature is certainly not. I mean, there's  
23 a jet which impinges on the liner. Is this considered  
24 at all there?

25 MR. COLLIER: No, we do not -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Because there have been  
2 incidents where jets have impinged on liners, and the  
3 whole liner has buckled. This happens with a water  
4 hammer accident. It has happened. I just wonder why  
5 average temperature is an acceptable criterion. Maybe  
6 the staff has some comment on that. Why is average  
7 temperature an acceptable criterion for containment  
8 liner, when some spots could be much hotter?

9 MR. CARICONE: Hi, my name is Albert  
10 Caricone, working in -- actually, nuclear safety  
11 analysis. I was heavily involved in doing containment  
12 analysis. We pretty much followed the same  
13 methodology that was used before. It's a pretty  
14 standard limit, that you encapsulate in the liner  
15 temperature -

16 MR. WALLIS: So maybe the question is why  
17 is the average acceptable to the Staff?

18 CHAIRMAN SIEBER: Anyone here from the  
19 Staff to answer that?

20 MR. LOBEL: This is Richard Lobel from the  
21 Containment Systems Branch in NRR. The number isn't  
22 meant to be a maximum in the sense of the jet  
23 impinging on the liner. It's meant to compare with  
24 the criterion for a structural number for the liner  
25 maximum allowed temperature. And it's calculated in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a conservative way for heat transfer from the  
2 atmosphere to the liner. The heat transfer  
3 coefficients are increased, and you make other  
4 assumptions that maximize the temperature on the  
5 surface of the liner.

6 MR. WALLIS: On the average.

7 MR. LOBEL: Yes.

8 MR. WALLIS: But if a local region gets  
9 much hotter, you'll get some -- you could get buckling  
10 of the liner.

11 MR. LOBEL: But it's really a one-  
12 dimensional type calculation.

13 MR. WALLIS: Yes, it is. I know.

14 CHAIRMAN SIEBER: Well, you end up blowing  
15 the liner -

16 MR. WALLIS: Why is that good enough?

17 MR. CARICONE: The other thing I was going  
18 to point out, that all the loop valves are in the  
19 steam generator valve cubic, our steam generator  
20 cubicles, so really they're not exposed to the  
21 containment liner, per se. You can always postulate  
22 the break that would, I guess, a jet that it would  
23 impinge on a liner, but the majority of the piping,  
24 RCS loop piping is pretty much enclosed.

25 MR. WALLIS: A large break LOCA could go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a long way.

2 MR. CARICONE: Correct. What I'm saying,  
3 that the lower levels of the containment are very much  
4 compartmentalized, I guess. I'm having a hard time  
5 pronouncing it.

6 MR. WALLIS: So there's something in the  
7 way?

8 MR. CARICONE: Correct. There are  
9 actually --

10 MR. WALLIS: Is there always something in  
11 the way?

12 MR. CARICONE: No, you can always  
13 postulate -- well, let's see. You have the reactor  
14 vessel, the hot legs come out. They're all inside the  
15 shield wall area, and then you -

16 MR. WALLIS: The shield wall helps you a  
17 lot.

18 MR. CARICONE: Right. And then you have  
19 the steam generator.

20 MR. WALLIS: That helps you, except you  
21 blow the insulation off it, and --

22 MR. LOBEL: Correct. And the steam  
23 generator compartment is a concrete structure.

24 MR. WALLIS: It's always been curious to  
25 me why the average temperature was acceptable as a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 criterion. I'm not sure I'm going to get an answer.

2 MEMBER MAYNARD: Well, typically, for the  
3 late model Westinghouse plants, which you guys are,  
4 all of the RCS piping is contained down below, into  
5 the bioshield area. And there really isn't any direct  
6 path of something to go to the containment. You could  
7 have steam in your secondary side -

8 MR. WALLIS: But that's different.

9 MEMBER MAYNARD: On the RCS side, that's  
10 typically all down within the bioshield where there's  
11 extra brick concrete wall between that -

12 MR. WALLIS: So from a LOCA you would  
13 never get a direct impingement on the containment  
14 wall.

15 MR. CARICONE: That is a true statement.

16 MR. WALLIS: That's a true statement?

17 MR. CARICONE: Right.

18 MR. WALLIS: But you might for a steam  
19 line break, or something?

20 MR. CARICONE: Steam line break,  
21 obviously, the upper portion of the steam generators  
22 are exposed to containment. There is a possibility  
23 that you might have impingements.

24 MR. WALLIS: What's the purpose of this  
25 temperature limit?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. LOBEL: There's a structural  
2 criterion, a temperature limit on the temperature of  
3 the liner. And this is just to show that for the  
4 LOCA, the steam line break, that you stay below that  
5 temperature.

6 MR. WALLIS: If you exceed it, what  
7 happens?

8 MR. LOBEL: If I were doing the review and  
9 I saw that the temperature -- well, first of all -

10 MR. WALLIS: What happens, if you get over  
11 280 degrees what happens?

12 MR. LOBEL: Well, I imagine there's -

13 MR. WALLIS: Blows up or something?

14 MR. LOBEL: I imagine there's a lot of  
15 margin, but if I were the reviewer and I saw that  
16 situation --

17 MR. WALLIS: I think if it heats up  
18 uniformly, it just pushes against the concrete, so  
19 that's not a bad thing.

20 MR. LOBEL: Yes.

21 MR. WALLIS: What's the mode of failure  
22 you're worried about?

23 MR. LOBEL: I, as the containment  
24 reviewer, would go to the structural people, and I  
25 would say that I'm very close or over this limit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Well, I as an IE person would  
2 say, if it's uniformly heated, I wouldn't worry very  
3 much. If I got a really hot region of 20 feet  
4 diameter, and if the rest is cold, and that's 500  
5 degrees, I might worry about what will happen.

6 MR. CARICONE: I believe -- you might want  
7 to correct me if I'm wrong, but I believe the issue is  
8 liner separation.

9 MR. WALLIS: Yes. That's what happens  
10 when it -- it does separate.

11 MR. CARICONE: Correct. I think, as you  
12 know, the liner is obviously attached -- when they're  
13 pouring the concrete -

14 MR. WALLIS: It's fitted to the concrete.

15 MR. CARICONE: Correct.

16 MR. WALLIS: AS long as they've been  
17 installed, it's all right.

18 MR. CARICONE: But if you separate the  
19 liner from the containment, my guess is that liner  
20 would start heating up more quickly.

21 MR. WALLIS: Really heat an area -

22 MR. CARICONE: Because you don't have,  
23 obviously -

24 MR. WALLIS: Cool off.

25 MR. CARICONE: I believe that that's the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 criteria, but that was never defined as a local  
2 temperature criterion.

3 MR. WALLIS: But you're meeting the  
4 regulations. I understand that. I'm just sort of  
5 wondering -

6 MR. CARICONE: Right. I understand.

7 MR. WALLIS: And I don't know where this  
8 goes, why this is a regulation. What makes sense, but  
9 it seems to me that buckling of the liner because of  
10 overheating some region might make a more sensible  
11 criterion. I don't know if the staff is going to do  
12 anything with that or not, but it just seems to me -

13 MEMBER ARMIJO: I want to ask a quick  
14 question. Is the fact that the temperature of the  
15 liner is lower than -- at SPU than current, is that  
16 strictly the result of these model changes?

17 MR. CARICONE: Right. There was  
18 definitely a methodology change, and -- do you want me  
19 -- I suppose I could elaborate on it a bit more.

20 MEMBER ARMIJO: Oh, no. I just -

21 MR. CARICONE: I understand.

22 MR. KAI: One thing I did want to point  
23 out, which you mentioned, is that as to whether we're  
24 a sub-atmosphere containment. We are a lot like  
25 Beaver Valley, in that we were originally designed to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 be sub-atmospheric. In the early 1990s, we removed the  
2 requirement to return sub-atmospheric, so we no longer  
3 have a requirement, post-LOCA, to return sub-  
4 atmospheric.

5 We operate, our plant normally operates  
6 slightly sub-atmospheric, but we do not -- we're like  
7 Beaver Valley in that we've eliminated, and actually  
8 we did almost a full 10 years ago, the requirement to  
9 return sub-atmospheric. So I just want to make sure  
10 that we understand that we're not thinking that we're  
11 like the original design, where we were required to  
12 the same -

13 CHAIRMAN SIEBER: The original design said  
14 you went back sub-atmospheric within an hour.

15 MR. KAI: Right.

16 CHAIRMAN SIEBER: And you don't do that  
17 now.

18 MEMBER ABDEL-KHALIK: Which of these two  
19 accidents do the numbers that you give in the table  
20 correspond to, in terms of containment liner  
21 temperature?

22 MR. CARICONE: Containment liner  
23 temperature comes from the steam line break analysis.  
24 Is that what the question is, whether it's a steam  
25 line break or a LOCA?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Yes, that's the -

2 MR. CARICONE: That is determined by the  
3 steam line break analysis. Matter of fact, it's a  
4 double-ended rupture of 1.4 square foot pipe, which is  
5 the maximum size break that you can have because of  
6 the venturis that we have at the steam generators for  
7 zero power. And that includes super heat, so it's  
8 governed by a steam line break, double-ended rupture  
9 of a steam line break at zero power. Does that answer  
10 your question?

11 MEMBER ABDEL-KHALIK: Yes.

12 MR. KAI: Okay. Any questions? You also  
13 have to look at a long term alarm pressure and  
14 temperature in containment, primarily driven -- we've  
15 had some discussions about EQ. What this graph shows  
16 is where, in fact, the EQ profile had to be changed to  
17 accommodate the SPU results. You can see there's a  
18 little red triangle. That was the sole change that we  
19 made. The current EQ profile, which assumed a 60 psi  
20 peak pressure lasting for, I don't know, a couple of  
21 hundred seconds, that is still bounding. So the part  
22 that needed to be changed to accommodated SPU is that  
23 little triangle that shows in the red. And this is  
24 shown in the following page.

25 Now, you were not meant to read all the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 different cases. But the point here is that we run  
2 dozens of cases to make sure that this EQ profile that  
3 we are using is still bounded at SPU condition. So  
4 each one of these traces represents a different case  
5 with different initial conditions, and different  
6 assumptions to try and maximize pressure. So we run  
7 dozens of cases for LOCA.

8 Same thing on -

9 CHAIRMAN SIEBER: The design pressure  
10 containment is how much?

11 MR. KAI: Forty-five psi gauge.

12 CHAIRMAN SIEBER: Forty-five pounds?

13 MR. KAI: Correct, 45 psi gauge.

14 CHAIRMAN SIEBER: Okay. And the pressure  
15 profiles that you show in Slide 11, go up to 55?

16 MR. KAI: Absolutely.

17 CHAIRMAN SIEBER: Absolutely. Okay.

18 MR. WALLIS: Isn't temperature more a  
19 problem than pressure?

20 MR. KAI: Yes, and we've got that. Right.  
21 The next slide -

22 MR. WALLIS: Well, I was hoping you were  
23 going to get to one that's important here.

24 MR. KAI: Okay. Slide 12 gives the  
25 temperature, exact same situation. The blue lines

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 shows the current EQ profile. The red part is the  
2 part that needs to be changed to accommodate SPU. And  
3 you could see that the change is from about 2000 to  
4 about 20,000 seconds, that the cool-down is slightly  
5 slower in that part. And if you look at the next  
6 slide, the same thing. We run dozens of cases to make  
7 sure that we have captured a bounding EQ profile for  
8 the containment.

9 MR. WALLIS: It looks rather like a  
10 complicated boundary.

11 MEMBER ARMIJO: Yes, it sure does.

12 MR. KAI: It is.

13 MR. WALLIS: Why didn't you take something  
14 simpler? Bigger.

15 MR. KAI: Well, again, remember how this  
16 is used. Right? Because it's used to match up with  
17 how the points are tested.

18 MR. WALLIS: You're going to test them  
19 with a profile like that, or something much simpler?

20 MR. KAI: We want this profile that we use  
21 bounded by what the equipment was tested for. And,  
22 like I said, they vary all over the place in how the  
23 equipment is tested.

24 MR. WALLIS: The test profile would be  
25 something much more simple.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: Yes, but they won't -- again,  
2 they typically run the test, some of them reduce the  
3 temperature earlier, some reduce it later, so the net  
4 result is we really need to get a profile that we are  
5 sure would be bounded by all of our tests.

6 MEMBER ARMIJO: If you make this change,  
7 do you have to retest some equipment?

8 MR. KAI: No.

9 MEMBER ARMIJO: Everything that you have  
10 is current, meet this new profile?

11 MR. KAI: Correct. Other than the issue  
12 that you discussed about the steam valve closing.  
13 This is all inside containment, but that issue we did  
14 need to take some mods for qualification. Any other  
15 questions?

16 NPSH, and I think this is another one that  
17 I'm going to have to explain kind of carefully. You  
18 have to understand how our ECCS and our containment  
19 system work. We're a lot like Beaver Valley.  
20 Initially, when we were designed, the recirc spray  
21 pumps, which are pumps that are used for recirc, that  
22 take suction from the sump, originally started on a  
23 timer from the CDA signal. Eleven minutes after the  
24 receipt of the signal, the pumps would start to take  
25 suction from the sump. In eleven minutes, most -- a



1 significant fraction of that water -- number one,  
2 there's not much water on the floor in the  
3 containment, and most of it, or a significant fraction  
4 is coming from the RCS, which is hot, much hotter than  
5 what you're going to spray. So the current -

6 CHAIRMAN SIEBER: Do you have a punch  
7 spray system?

8 MR. KAI: Yes.

9 CHAIRMAN SIEBER: That injects first, so  
10 that water is in there.

11 MR. KAI: Right, but only 11 minutes of  
12 it.

13 MR. WALLIS: Why isn't the sump  
14 temperature about the same at SPU?

15 MR. KAI: Okay.

16 MR. CARICONE: He's getting to it.

17 MR. KAI: Yes. You're ahead of me, again.  
18 Okay. So that's our current system. Okay? And the  
19 analysis was based on 11 minutes. And you can see  
20 that the sump temperature is like 260 degrees. A CDA  
21 will occur within seconds of a large break LOCA, so  
22 it's on the order of 11 minutes after CDA. Your sump  
23 temperature is 260 degrees, and that's because it's  
24 mostly made up of RCS water.

25 We made a mod last cycle, and it's also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cited to in GSI-191, to delay the start of the recirc  
2 spray pumps until we reach a low-low water level in  
3 the RWST. Now the pumps are going to start  
4 approximately 30 to 40 minutes, much longer, they'll  
5 start much later. Now you have 30 to 40 minutes of  
6 point spray, spraying in, filling the sump with cold  
7 water, and that results in this reduction of  
8 temperature.

9 MR. WALLIS: You're required to resume  
10 this containment pressure of one atmosphere. Is that  
11 right?

12 MR. KAI: Correct.

13 MR. WALLIS: Even though the temperature  
14 is 260 degrees Fahrenheit.

15 MR. KAI: Right. We assume -- we take no  
16 credit for the back pressure followed by the event.

17 MR. WALLIS: I understand that. It's  
18 somewhat unphysical.

19 MR. KAI: Well, it's margin. Again, think  
20 of that as margin there. Okay? So that's why this  
21 temperature is lower. It's not that -

22 MR. WALLIS: I understand that.

23 MR. KAI: Because physically now we are  
24 starting RSS pumps much later.

25 MR. WALLIS: But if it's 260, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 containment pressure better be more than one  
2 atmosphere.

3 MR. KAI: Right. That's definitely true.  
4 And you could see on the pressure -- so the net result  
5 here is that -- and, again, therefore the SPU really  
6 has not affected the current design-basis calc for  
7 NPSH at all, because the temperature is well below.  
8 And not so much SPU, but it's reflected in the  
9 modification we made.

10 I know that this issue is associated with  
11 GSI-191. That's still in progress. We're still  
12 working on that. We want -

13 CHAIRMAN SIEBER: According to the SER,  
14 you said you were done with your modifications for  
15 GSI-191.

16 MR. KAI: We've made the modifications.  
17 That's correct. We have installed a strainer, but the  
18 analysis pieces are still not -

19 CHAIRMAN SIEBER: Are you done?

20 MR. KAI: No, we are not done with the  
21 analysis pieces. There are still open issues on some  
22 of the WCAPs that we are following, so it's not  
23 completely resolved. But, again, like I said, at the  
24 very early thing in the morning is that -- what we  
25 tried to do here in this view is make sure that this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 doesn't make it worse, or it doesn't affect what we're  
2 planning to do in terms of what's listed in GSI-191.

3 MR. WALLIS: So, presumably your pump  
4 intake is significantly below 24 foot 6?

5 MR. KAI: Correct.

6 MR. WALLIS: It has to be. Otherwise you'd  
7 be boiling in the pump inlet.

8 MR. KAI: Yes, it is. You're right.

9 (Simultaneous speaking)

10 MEMBER WALLIS: About 24

11 MR. KAI: The bottom of the containment I  
12 believe is minus 24.6. That's the level of the floor.

13 MR. WALLIS: The pump is -

14 MR. KAI: Lower than that.

15 MR. WALLIS: -- 20 feet below that or  
16 something?

17 MR. KAI: Much lower.

18 MR. WALLIS: Significantly below that  
19 level.

20 MR. KAI: Correct. The same thing with  
21 the pipe stress. We have to make sure that the  
22 temperatures that we are predicting will be handled by  
23 the piping and associated attachments, et cetera. We  
24 are making a couple of modifications to two of the  
25 hangers inside containment to make sure that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 maintain, meet our ASME requirements. But we have  
2 looked at -- we have done a very comprehensive look at  
3 pipe stress, looking at all different combinations of  
4 temperatures that we can anticipate from the LOCA.

5 We still do a minimum containment  
6 analysis. That is an inadvertent actuation point  
7 spray, so it actually has absolutely no -- SPU has no  
8 real impact at all on that. That is not power-driven.  
9 It's a function of what the initial bounds are in the  
10 containment temperature, and you start the sprays, and  
11 that drives you to the minimum containment pressure.  
12 So that was not an SPU-impacted analysis at all.

13 CHAIRMAN SIEBER: Now your containment  
14 spray is actuated by a pressure sensor inside  
15 containment?

16 MR. KAI: Correct.

17 CHAIRMAN SIEBER: What is it set at, one  
18 pound?

19 MR. KAI: The point spray system is -

20 CHAIRMAN SIEBER: The one that comes on  
21 first.

22 MR. KAI: Five psi gauge. Correct.

23 CHAIRMAN SIEBER: Half?

24 MR. KAI: Five.

25 CHAIRMAN SIEBER: Five. Okay. They used

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to be set at one pound, which gave you inadvertent  
2 actuation everytime somebody sneezed.

3 MR. KAI: I'm pretty sure that the --  
4 well, the transfers are outside containment. We have  
5 -- they're not actually located inside containment.  
6 Again, maybe, Mike O'Connor, you can tell me where  
7 they're located, but I'm pretty sure that the  
8 containment, the pressure transmitters are actually  
9 located outside containment.

10 MR. O'CONNOR: Right. I'm sorry. I  
11 misunderstood your question, but the actual location  
12 of the transmitter itself?

13 CHAIRMAN SIEBER: Yes.

14 MEMBER SHACK: Actuation set point.

15 MR. WALLIS: What does the spray draw  
16 from? Where does the water come from?

17 MR. KAI: Out of UST.

18 MR. WALLIS: Out of UST? How cold can  
19 that be?

20 CHAIRMAN SIEBER: How cold? Thirty-three.

21 MR. WALLIS: That will be 33 degrees?

22 MR. KAI: No, we have a spec that involves  
23 -- that requires the --

24 CHAIRMAN SIEBER: There's a minimum and  
25 maximum.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KAI: Correct. It's 40-50 degrees is  
2 the range allowed on the -

3 MR. WALLIS: You have detainment coolers,  
4 do you? Fan coolers.

5 MR. KAI: We have a cistern that --

6 MEMBER WALLIS: The service water minimum  
7 temperature is 33 degrees. So you turned on the fan  
8 coolers, you could cool the containment to 33  
9 degrees?

10 (Simultaneous speech.)

11 PARTICIPANT: The thing that's cooled by  
12 service water is our recirc spray pumps that take a  
13 suction on the containment sump and provide for long-  
14 term cooling to the core. Also take over for the  
15 spray system in containment. Those coolers are cooled  
16 directly by service water.

17 MR. WALLIS: But there are fan coolers in  
18 there?

19 PARTICIPANT: At this point in an  
20 accident, there would be no fans running. We wouldn't  
21 be using those.

22 MR. WALLIS: In terms of an inadvertent  
23 use or something.

24 PARTICIPANT: Now, the measurement of 33  
25 degrees is with respect to the amount of cooling you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 can get to the recirculated water that's going back to  
2 the core.

3 MR. WALLIS: Well, the inadvertent use of  
4 the fan coolers couldn't bring the -- be a bounding  
5 event. That's all I'm trying to -

6 PARTICIPANT: No, it could not.

7 PARTICIPANT: Millstone does not have  
8 safety-related containment fan coolers?

9 PARTICIPANT: No.

10 PARTICIPANT: That is correct.

11 PARTICIPANT: We do have car fans that are  
12 cooled by CCP or CDS.

13 MEMBER ABDEL-KHALIK: What is the  
14 calculated value for the minimum containment pressure?

15 MR. KAI: We'd run at this 8 psi gauge, but  
16 remember what the actual calculated number is. That's  
17 in the FSAR. I can pull that out and pass it on to  
18 you.

19 Also, going back to your question, the car  
20 fans would normally be running so that would be  
21 something that we'd be wanting. I'm talking about for  
22 this particular depressurization scenario,  
23 depressurization, actuation of the point spray system.

24 MR. KAI: The last thing I was going to  
25 cover is sub-compartment, have looked at the impact of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the releases, calculated for sub-compartment, and that  
2 does -- and those are the short-term pressurization  
3 effects.

4 One of the things that did in our original  
5 analysis is our original analysis can arbitrarily  
6 apply 10 percent margin on to the mass area, so in  
7 general, that margin was acceptable for most of the  
8 cases. There are a couple that we were not bounded,  
9 that we've re-analyzed, and so that the structural  
10 limits for -- and this problem with the pressurizer  
11 cubicle for the spray lines and the service line in  
12 the pressurizer cubicle.

13 In addition, we did credit leak before  
14 break to eliminate the large break, meaning to  
15 postulate large break for sub-component analysis.  
16 Millstone 3 was approved for large break, for leak  
17 before break, excuse me, but we haven't applied it to  
18 this analysis, even though we had gotten approval for  
19 leak before break. So we have submitted that credit  
20 as part of the SPU, and that has a big significant  
21 impact, and reduced the model analysis we do since,  
22 for example, the steam generator compartment where you  
23 have hot leg and cold leg piping, and you apply heat  
24 before break. They were recently analyzed to be shown  
25 acceptable, and now when you exclude that it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 represents significant margin.

2 PARTICIPANT: Mr. Chairman, that concludes  
3 our presentation on containment. We do have, as we're  
4 transitioning as our NRC Staff is coming up, their  
5 containment presentation, we do have a couple of  
6 answers to some of the questions. I'll just briefly  
7 address those, if I may.

8 One of the questions that was asked early  
9 on was what is our next most limiting component  
10 outside of the electrical generator. And the next for  
11 Millstone 3 at the current time is the HP turbine, and  
12 then after that there's several components that are  
13 limiting, so we're at the point now that we don't  
14 intend to do any other power uprates, because we have  
15 major components after this.

16 Another clarification that we'd like to  
17 make is, a question was asked about Millstone Unit 2.  
18 To be clear, Millstone Unit 2 was not the subject  
19 today. Millstone Unit 2 is a -- and it was asked  
20 whether we're doing a power uprate on Millstone Unit  
21 2. Millstone Unit 2 is not a sister plant to  
22 Millstone 3. Millstone 3 is a four-loop Westinghouse  
23 unit. Millstone 2 is a two-loop CE-type design unit.  
24 Millstone 2 did a stretch power uprate, and I believe  
25 it was in the '70s time period, that was approved and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 implemented. It was approximately a 5.5 percent power  
2 uprate, so that was done in the past. And we do not  
3 intend to do a stretch power uprate on Millstone Unit  
4 2.

5 Let's see we had another question. Dave  
6 Bucheit, you address the next one while I get your  
7 slide up.

8 MR. BUCHEIT: Yes, a couple of PRA  
9 questions I'd like to address. While Ron is putting  
10 the -- Bob, could you do me a favor and hand the  
11 Chairman that, please. Printed out a table from the  
12 license amendment request, and it includes all of the  
13 operator timing information. And explain to you how  
14 we use that information.

15 I alluded to the fact that we used RELAP  
16 to justify the times that were used in the analysis.  
17 Earlier we had used MAAP-4. What we did in every case  
18 was to run RELAP at the un-uprated, and at the uprated  
19 conditions assuming the operator action took place at  
20 that time, and determined whether or not there was  
21 core damage. And in each case there was not core  
22 damage, or the success criteria, steam generator dry-  
23 out, whatever it was, did not occur, so all we did was  
24 confirm that there was still margin in those numbers.  
25 We didn't confirm what the decrease in the margin was,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 which, I'm sorry, was really the question you asked.  
2 I can't answer that question. I can tell you what we  
3 did do.

4 MEMBER STETKAR: I looked at this. The  
5 one thing I think Jack mentioned also, is that the  
6 only clear time that I could find is there's an  
7 operator action called OAPHLR for hot leg recirc  
8 switch over, and in this table it says 538 minutes,  
9 which is approximately 9 hours. And in an other  
10 section of the LAR, it clearly states that that time  
11 is now reduced to five hours.

12 MR. BUCHEIT: Right.

13 MEMBER STETKAR: So recognizing that the  
14 difference in PRA space between nine hours and five  
15 hours is insignificant for human reliability, but  
16 there is one instance where there was a substantial  
17 change in the time that's not reflected in this table.  
18 This table simply -- it's in the LAR we had. It's  
19 Table 213.2213-1 in the LAR.

20 CHAIRMAN SIEBER: But the only one that  
21 really changes is OAPFPW. All the rest of them stay  
22 the same.

23 MEMBER STETKAR: Some of them would  
24 change, Jack, because they take credit for -- they've  
25 taken credit for restoration of main feedwater.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Anything to do with steam generator dry-out times, or  
2 probably off-site power recovery times, which are  
3 generally related to secondary heat removal would  
4 change. How much they change, I don't know.

5 CHAIRMAN SIEBER: The RWST runs out of  
6 water quickly.

7 MEMBER STETKAR: Oh, yes. Sure. There  
8 are small changes in longer ones, but the more  
9 interesting ones from the PRA are typically in the 30  
10 -- there are some very precise numbers in here, like  
11 27 minutes, or 25 minutes. And those could change  
12 quite a bit. Not quite a bit, but they could change.

13 MR. BUCHEIT: But, again, we did do RELAP  
14 analysis at both un-uprated and uprated to confirm  
15 that when we assume the operator action meets the  
16 success criteria took place, that core damage did not  
17 result -- so we didn't get at the margin issue, but  
18 did confirm that the HEPs are still valid.

19 MEMBER STETKAR: Yes, but in terms of a  
20 delta, you don't really know what the delta is.

21 MR. BUCHEIT: Correct. Don't know what  
22 the delta is.

23 MEMBER STETKAR: And because -- the nice  
24 thing about the HCRORE methodology is that it is one -  
25 - because it's time reliability correlation, you could

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 show directly what that change in the estimated human  
2 error rate would be.

3 MR. BUCHEIT: Yes. And, in fact, we'll  
4 probably -- we'll almost certainly have to do that  
5 when we bring the model up to the Reg Guide status.  
6 You had another question, sir, about whether or not we  
7 took credit for safety injection in any other  
8 scenarios. I looked into that, and the answer,  
9 indeed, is no.

10 There is manual override capability of  
11 this permissive, for feed and bleed, or something like  
12 that. They would still be able to actuate -

13 MEMBER STETKAR: Yes. I was just curious  
14 whether there was -- it would have to be pretty  
15 strange, but I just wanted to make sure that you  
16 looked into that.

17 MR. BUCHEIT: Yes, sir. That's all I  
18 have.

19 MR. BURNHAM: This is Robert Burnham.  
20 This morning we discussed at length the T hot spikes,  
21 and we were going to get some data for you. We've  
22 been in contact with the plant, and unfortunately,  
23 unless we have a spike in the recent plant process  
24 computer history, we can't get the trace, and we  
25 haven't seen one for a while.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           What I can do is report what we had seen  
2           in the past through the engineering design changes and  
3           the valuations that were done. Initially, early in  
4           the cycle, we would see spikes of somewhat longer  
5           duration of 10 to 15 seconds, and they would be on the  
6           order of magnitude of a degree and a half to 3-1/2  
7           degrees.

8           MR. WALLIS: That's in a positive  
9           direction. You had negative spikes, as well?

10          MR. BURNHAM: What we observed was that  
11          while the temperature was going up in one loop, it was  
12          actually going down in another loop.

13          MR. WALLIS: Down in another, so they're  
14          sort of symmetrical spikes?

15          MR. BURNHAM: Yes. We actually saw, for  
16          example, loop one in the hot leg, the temperature  
17          would go up, loop four the temperature would go down,  
18          and saw a similar reaction in loops two and three  
19          where they offset each other.

20          MR. WALLIS: We're talking about one or  
21          two degrees, maybe?

22          MR. BURNHAM: A degree and a half to 3-1/2  
23          degrees. And that would be early in the cycle.  
24          Again, we haven't seen those for some time now.

25          Now, typically, what we have been seeing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 recently is a similar size spike of magnitude, again,  
2 a degree and a half to 3-1/2 degrees of a duration of  
3 approximately two to three seconds at the most. And  
4 that is what the T hot filter that we're putting in is  
5 specifically designed to filter out. And as we  
6 discussed this morning, that allows us to change the  
7 OPO to delta-T set points to gain margin back, because  
8 we're filtering out the spikes that were causing pre-  
9 trips and pre-alarms.

10 MR. WALLIS: If there was some kind of  
11 random turbulence, you would expect the spike size to  
12 vary a great deal. This seems to be a more regular  
13 thing, where the spikes usually are about the same?

14 MR. BURNHAM: Well, we see them -- the  
15 randomness we see is the degree and a half to 3-1/2  
16 degrees. Usually, the signal is pretty stable, no  
17 more than that.

18 MR. WALLIS: It's a regular thing. It's  
19 not just a random turbulent thing which would be all  
20 over the place.

21 MR. BURNHAM: I'm not sure we have enough  
22 data to confirm either way. But, again, the magnitude  
23 is probably the more significant, and it's rarely  
24 seen, if at all, above 3-1/2 degrees.

25 PARTICIPANT: A follow-up to Dr. Wallis'

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 question on elevations. Again, containment floor  
2 elevation is at minus 26 four inches, first space  
3 center line elevation is minus 47 seven inches.

4 MEMBER WALLIS: Way down there.

5 PARTICIPANT: Way down.

6 MEMBER WALLIS: Do you have these long  
7 vertical pumps with the -

8 PARTICIPANT: I have the artist's  
9 representation over here if you want to take a look at  
10 it.

11 CHAIRMAN SIEBER: The pumps are typically  
12 hard to balance.

13 PARTICIPANT: I think we had answered it.  
14 So, Mr. Chairman, we have completed our presentations  
15 for the day. Thank you very much for the opportunity,  
16 and we believe we have closed out all open items that  
17 were introduced during the day.

18 CHAIRMAN SIEBER: Anyone have any final  
19 questions for the applicant? If not, I'd like to ask  
20 the Staff to do their companion presentation.

21 (Off the record comments.)

22 MR. SALLMAN: Good afternoon. My name is  
23 Ahsan Sallman. I'm a Reactor Systems Engineer in the  
24 Containment and Ventilation Branch, Division of Safety  
25 Systems. I was the reviewer of the SPU power uprate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 for the containment for Millstone 3. And, basically,  
2 we covered all of the RS-001 standard for the  
3 containment.

4 This slide presents a summary of what we  
5 reviewed, or what particular aspects of the  
6 containment we reviewed. We went through the RS-001,  
7 and we checked whether all the NRC-approved analytical  
8 methods were covered, and we had a lot of RAIs, and  
9 they were satisfactorily answered. We reviewed all  
10 the GDCs, and found that they were satisfied. SRP  
11 acceptance criteria was satisfied, and the Staff found  
12 that 10 CFR 50 requirements were okay.

13 The first aspect of containment review was  
14 the primary containment functional design, and we  
15 found that the licensee used Gothic methodology, which  
16 NRC has approved previously. There was an SE issue on  
17 that, and we accepted their methodology. The licensee  
18 used conservative initial condition for LOCA, and  
19 analyzed a spectrum of breaks for LOCA and MSLB.

20 The conclusions, short-term LOCA, MSLB,  
21 peak pressures and temperatures were bounded by the  
22 containment design conditions, and the long-term LOCA  
23 and MSLB pressure and temperature responses were okay,  
24 acceptable.

25 For the sub-compartment analysis, we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 approved previously the leak before break criteria,  
2 and Millstone has used that in their analysis. And  
3 according to the NUREG-1838, and they used this  
4 criteria for the selection of five breaks. And there  
5 was sufficient margin in the differential pressure  
6 across the sub-compartment walls under SPU conditions.

7 We reviewed the mass and energy release  
8 analysis for LOCA and secondary pipe ruptures, and we  
9 found that there was a spectrum of break sizes that  
10 was analyzed by NRC-approved methods. And these are  
11 listed in this WCAP document that we have here. And  
12 so, also, secondary pipe breaks, energy release were  
13 used by NRC, the WCAP documents that are listed here.

14 For this same mass and energy release,  
15 LOCA and secondary pipe ruptures, the licensee used  
16 conservative assumptions and inputs to maximize the  
17 M&E release, and the Staff reviewed and agreed with  
18 the licensee's evaluation of LOCA M&E release.

19 MEMBER ABDEL-KHALIK: Did you do any  
20 independent confirmatory analyses of any of these  
21 calculations?

22 MR. SALLMAN: No, I did not, because there  
23 was nothing that I could see that would require such  
24 a review, because they were using acceptable codes and  
25 standards acceptable, the accepted codes that NRC has

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 approved already. And the assumptions they were using  
2 were acceptable, inputs were acceptable, so that's the  
3 reason we did not go to independent review.

4 MEMBER ABDEL-KHALIK: So the fact that the  
5 methodology was changed in a lot of these analyses,  
6 which resulted in somewhat counterintuitive results,  
7 just simply because the methods were different, did  
8 not give you pause, or you didn't ask whether or not  
9 these changes are actually reasonable.

10 MR. SALLMAN: Well, one thing to mention  
11 is the Gothic containment analysis that we already  
12 have heard from the licensee that they used this new  
13 methodology which we have approved, plus one of the  
14 results that they talked about is the sump temperature  
15 was less than the previous sump temperature. That is  
16 also responded by the licensee that because of the  
17 change in the logic in a previous SE that was  
18 submitted, I mean, licensing document that was  
19 submitted, so those are the kind of things that, I  
20 guess, it was not necessary to review, do an  
21 independent calculation.

22 MR. LAMB: This is John Lamb. Just for  
23 your information, we asked 107 RAI questions, and  
24 approximately 16 of them came from Containment System,  
25 so it's about 15 percent. And when you were asking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 before about reactor systems, they asked about 38  
2 questions, so about 40 percent or so. So you can see  
3 a bulk of our RAI questions came from Containment and  
4 Reactor Systems.

5 MR. SALLMAN: Next aspect of containment  
6 review was combustible gas control and containment,  
7 and was already approved, the hydrogen recombiners and  
8 monitoring system have been moved from the tech specs,  
9 so there was no impact of this aspect of the  
10 containment.

11 Heat removal system, the licensee did not  
12 take into account the containment accident pressure  
13 for calculation of the net positive suction head.  
14 They used the input parameters that were conservative  
15 or same as in the current analysis. And they used  
16 Gothic methodology to calculate a maximum sump  
17 temperature. So the heat -- the net positive suction  
18 head available requirement was met.

19 The next aspect of containment review was  
20 to see the minimum pressure analysis for ECCS  
21 performance capability. We found that the licensee  
22 used conservative initial conditions for calculating  
23 the minimum requirement containment back pressure, and  
24 the pressure transient bounds the transient used in  
25 the ECCS performance analysis, so it's unaffected.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 We requested the licensee to see if they  
2 had reconsidered the Generic Letter 96-06, in which we  
3 wanted to find out that the licensee has reviewed  
4 overpressurization of the isolated water fill piping  
5 section and containment. And the licensee responded  
6 that they have reviewed, and there was no issue in  
7 that area. So that's the summary here.

8 I want to respond to one of the questions  
9 that was coming on the containment liner temperature  
10 of 280 degrees, I have seen in most plants, this is  
11 the temperature that they use. And the plant  
12 arrangement design is such that you don't find any  
13 direct jet impingement on the containment liner.

14 MR. WALLIS: Even from a steam break?

15 MR. SALLMAN: Yes. Because this is a very  
16 important design. The liner design is a very  
17 important part of the containment, and they don't want  
18 to have a liner exposed to 500 or something. So most  
19 of the plants I've seen, this is order of magnitude is  
20 280 degrees, or close-by, I guess. That's the liner  
21 temperature. So the plant arrangement takes care of  
22 that.

23 MR. WALLIS: I'm trying to relate it to  
24 the zone of influence we have for the debris creation.  
25 And the zone of influence for some of these accidents

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 actually goes way out to the containment liner, so,  
2 clearly, there is some kind of a jet that impinges on  
3 the liner, or at least it's assumed for that purpose.  
4 You're just saying it doesn't happen?

5 MR. SALLMAN: This has been the practice.  
6 You can see all FSARs, this is a liner temperature  
7 that is -- if it will have been an issue, it would  
8 have been considered very seriously.

9 CHAIRMAN SIEBER: Except for the very top  
10 of the steam generators, the crane wall, which is a  
11 circular cylinder of quite sturdy design, shields the  
12 liner from the working parts of the plant. So jet  
13 impingement, in my view, would be the rare occurrence,  
14 and possibly only from a rupture to the steam line.  
15 I think leak before break applies there.

16 MR. WALLIS: Have these folks installed  
17 the GSI-191 suction strainers?

18 MR. SALLMAN: I have seen the suction  
19 strainers have been installed, and -

20 MR. WALLIS: All been installed?

21 MR. SALLMAN: I think there were some  
22 issues in that, as they responded. The suction  
23 strainers has been considered, the pressure loss  
24 across the suction strainer has been considered in  
25 this analysis. I think it was already mentioned.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. COLLIER: This is Mike Collier. We  
2 have installed the advanced strainer last cycle.

3 MEMBER BANERJEE: What is -- do you have  
4 a buffer?

5 MR. COLLIER: We use TSP.

6 CHAIRMAN SIEBER: Any other questions?  
7 Okay. If there are no other questions, we are next at  
8 the point where we will receive public comments. Ms.  
9 Nancy Burton with the Connecticut Coalition Against  
10 Millstone would like 15 minutes to give us her  
11 viewpoint, so why don't we do that now. You want to  
12 put her placard up there. Okay. Go ahead.

13 MS. BURTON: Good afternoon. I'm Nancy  
14 Burton, and I direct the Connecticut Coalition Against  
15 Millstone. I thank you very, very much for the  
16 opportunity to be here. Thank you very much. It's  
17 been a very, very informative day. I have with me  
18 Arnold Gundersen, a nuclear safety engineer based now  
19 in Vermont. Mr. Gundersen worked at Millstone Unit 3  
20 as Lead Licensing Engineer during the 1970s.

21 We have some handouts, which I'll  
22 distribute after I make a few comments. My comments  
23 are going to principally related to health, and Mr.  
24 Gundersen will be directing his comments for technical  
25 issues. And I hope that will be acceptable. Thank

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 you. And we'll try to be very, very brief.

2 I just wanted to start by talking about  
3 Millstone Unit 2 for just one moment. We're here on  
4 Millstone Unit 3, but we've heard conflicting stories  
5 about whether we'll be here next on Unit 2. Just as  
6 a point of interest, Unit 2 suffered three unplanned  
7 shutdowns within a month recently, and has one of the  
8 most unreliable safety records in the industry. And  
9 we can only hope that the last gentleman who spoke  
10 from Dominion is correct, that there are no plans for  
11 an uprate for Unit 2.

12 I'm here principally to tell you that the  
13 organization I'm with, which consists of numerous  
14 statewide environmental organizations and safe energy  
15 organizations in Connecticut, as well as Millstone  
16 whistle blowers, and members of the community, we are  
17 absolutely opposed to this application.

18 With Mr. Gundersen's help, we have a  
19 calculation that if this uprate is approved, it will  
20 bring an additional \$330,000 in profit to Dominion per  
21 year. That's what this is all about really, because  
22 there's no public need for this electricity. And my  
23 comments are directed to the complete failure of both  
24 the application and the NRC Staff review to address in  
25 any way the health effects on the population that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 lives in Southeastern Connecticut from this  
2 application.

3 The application does concede that there  
4 will be increases estimated at no less than 7 percent,  
5 and maybe much higher in the levels of radioactive  
6 materials released to the air and the water. This is,  
7 to a community which already suffers the highest  
8 levels of 12 categories of cancer in the State of  
9 Connecticut. And if we look at that figure of  
10 \$330,000, and try to put a value on the little girl  
11 who died at seven months last year, had fourth stage  
12 liver disease in the immediate area, the numerous  
13 children who died of congestive heart failure moments  
14 after they were born in the immediate area of  
15 Millstone, the 16 workers we know of, or we've heard  
16 of at Millstone now suffering from cancer, the values  
17 are way, way, way off. They're askew, and this is not  
18 acceptable. The community does not accept seven, or  
19 eight, or nine, or ten, or twelve, or whatever percent  
20 more radiation dose to itself from this nuclear power  
21 plant.

22 I just want to mention that I will be  
23 circulating a declaration from Cynthia M. Besade, who  
24 grew up two miles from Millstone. Her father was a  
25 nuclear pipefitter at Millstone, and a whistle blower.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 She has provided a statement in which she assesses the  
2 numbers of friends, neighbors, and associates in  
3 Niantic, in the area immediately around Millstone, who  
4 have suffered and died from cancer since Millstone  
5 began operations.

6 We keep a running count of people who are  
7 dying in this area, and we know there are clusters of  
8 brain cancer, breast cancer, childhood Leukemia, and  
9 bone cancer in an area that is celebrated for being a  
10 tourist attraction in our state. And this is entirely  
11 unacceptable. No rationale was given for this  
12 application other than to seek profit, and this body,  
13 we urge this body to ask what is the rush? There are  
14 so many unanswered questions here.

15 In Connecticut, we have a Department of  
16 Environmental Protection which presented the NRC and  
17 the NRC Staff with a series of questions. Those  
18 questions are still not answered, so I fail to see how  
19 the matter is at all closed. So we urge upon you a  
20 recommendation to the Full Committee denying this  
21 application. Mr. Gundersen will go into some of the  
22 technical and legal aspects of why that is necessary.  
23 And, at this time, I will turn the matter over to Mr.  
24 Gundersen.

25 MR. GUNDERSEN: It's Gundersen, S-E-N.

1 Get it right at the beginning, and I find I chase it  
2 a lot less. So thank you.

3 The NRC has a resume, but I used to be the  
4 Licensing Engineer at Millstone 3 back in the '70s  
5 when it originally was under construction. Of course,  
6 it was licensed in '86. I was long gone then, and was  
7 a Senior Vice President of Nuclear Energy Services at  
8 the time, and I was provided structural engineers at  
9 Millstone 3 at the time it was licensed.

10 Anyway, what we heard today was that the  
11 61 other stretch power uprates, that was the number I  
12 heard, there was another quote that said that the  
13 Staff's review is based on experience gained on the  
14 other stretch power uprates. I heard an apology for  
15 burdening you with 26-day review cycle. And, again,  
16 I reiterate what Nancy just said, is what's the rush?

17 It's important to note -- I also heard  
18 several times we are a lot like Beaver Valley, and  
19 that there were peer uprates of 24 other Westinghouse  
20 four-loop plants. Just for the record, according to  
21 the NRC's web page, Beaver Valley was an extended  
22 power uprate review, not a stretch.

23 I need to talk about Millstone 3, and it  
24 really is not typical of the other reactors that have  
25 been considered by you in the past. I have my expert

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 report that the NRC has already seen. Millstone 3 has  
2 an incredibly small containment. Initially, the  
3 number I used when I was analyzing this was 2.3  
4 million cubic feet of free volume. Today, there was  
5 a number that was 1 percent smaller than that, 2.26  
6 million cubic feet of free volume.

7 What I did was I used the NRC's web pages  
8 so there's nothing proprietary, and Dominion can stay  
9 in the room, and compared the reactors that have been  
10 - the Westinghouse reactors. And I didn't include as  
11 containment, and I didn't include the tiny ones. But  
12 anything over 2,000 megawatt thermal I looked at. And  
13 Millstone is the fifth smallest containment in the  
14 reactors, in the 25 reactors that fit that category at  
15 2.3 million cubic feet.

16 Now why is that? It was originally sub-  
17 atmospheric, and if you go to the NRC's web page,  
18 you'll find that the only four-loop sub-atmospheric  
19 plant in the nation is Millstone 3. So its  
20 containment is incredibly unique. The volume is very  
21 small, sub-compartments are very tight. And when I  
22 was working there we recognized this. In '75, we all  
23 realized that the sub-atmospheric containment was not  
24 a great idea, but we didn't want to change it at that  
25 point, because it meant going back to square one with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the licensing.

2 And, of course, when the reactor got  
3 built, it was within five years, the sub-atmospheric  
4 containment was essentially gone. We went from 10 psi  
5 to 14 psi in '91, if I remember right. But the  
6 containment, you're stuck with a 2.3 million cubic  
7 foot containment which is unlike any other four-loop  
8 Westinghouse plant out there.

9 In this, I urge you to take a look at the  
10 three tables, and they're all right out of the NRC's  
11 web page. Table Two in this report shows that  
12 Millstone is the fifth smallest reactor containment in  
13 the country. Then what I did was I -- in Table Three  
14 what I did was I compared the reactor power to the  
15 containment volume. And based on that criteria,  
16 Millstone 3 has the smallest containment in the  
17 country, dramatically smaller. That's the initial  
18 license reactor power. So even without the stretches  
19 of any of the reactors that ever have been licensed,  
20 the power output divided by the free volume is much  
21 lower than any other reactor in the country.

22 So then I went to the NRC's web page  
23 again, and Table Four of the handout takes all of  
24 these reactors and uprates their power, and again  
25 divides by the containment volume. And once again,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Millstone is at the bottom of the list. So this is an  
2 incredibly small reactor, and of any reactor bigger  
3 than 2,700 megawatts thermal, Millstone is the  
4 smallest. So when you get down to the Indian Point 2s  
5 and Robinson's, smaller in that -- a couple that are  
6 smaller just cubic feet-wise, but when you then take  
7 the available energy that's going into that  
8 containment, Millstone winds up the smallest of that  
9 batch.

10 The other thing I need to note is that the  
11 -two other things and I'll be done - is that the NRC  
12 requirements say that a stretch power uprate is up to  
13 7 percent. Millstone is actually above 7 percent.  
14 They round it up a thermal megawatt instead of down a  
15 thermal megawatt, and they're over by about 7.03 or  
16 something like that, so it actually exceeds the NRC's  
17 requirement for a stretch, and should be considered  
18 -as a legal basis that it should be considered as an  
19 extended power uprate, as was Beaver Valley at 8  
20 percent.

21 So given it's not typical, and given it's,  
22 in fact, slightly above the 7 percent criteria, which  
23 is the threshold to be considered an extended power  
24 uprate, I'd like to suggest, especially in the area of  
25 the containment, that the NRC stand back and take a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 harder look. We just heard that there was "no  
2 independent confirmatory analysis by the NRC", on any  
3 of the information provided by Dominion. Given -- I  
4 know my sensors went up when I realized that this is  
5 the smallest containment in the world - why didn't the  
6 NRC do anything other than just review what Dominion  
7 provided?

8 I'm not saying Dominion provided was  
9 wrong. I don't know that, but what I am saying is  
10 that the NRC owed it to you, and to us, to civilians  
11 that they should have taken a harder look at this  
12 containment, because it was the only four-loop  
13 Westinghouse plant in the world that was a sub-  
14 atmospheric containment, and had the smallest free  
15 volume.

16 Okay. The Staff -- again, there seems to  
17 be a pressure on both you and the Staff. I heard the  
18 Staff say up here about an hour ago that they had less  
19 than a year to review the entire document. If it had  
20 been an EPU instead of an SPU, they would have had  
21 essentially another eight or nine months. What's the  
22 rush?

23 And last, but not least, I was involved in  
24 the uprate at Vermont Yankee, and it doesn't take much  
25 to rewind a generator. It can be done on-site with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 the existing copper, and some additional copper would  
2 be added. I would suspect that you'll see that this -  
3 - if the generator is the limiting factor in the next  
4 bit of power that can be gotten out of the reactor,  
5 given the cost of power on the grid right now, that  
6 Dominion will come back and try to squeeze another 2  
7 percent out of a generator rewind without affecting  
8 the HP turbine. And I ask you, how are you going to  
9 treat that? Is that going to then make it an EPU? Is  
10 it 7 percent and 2 percent to get you to 9 percent, or  
11 is it 2 percent and it falls under the instrument  
12 error kind of a calculation.

13 In fact, we've got -- the containment was  
14 stretched in '91 when we went from sub-atmospheric 10  
15 to sub-atmospheric 14. Now the reactor is stretched  
16 by another 7 percent, and we're looking at yet another  
17 couple of percent when you go for a generator rewind.

18 I guess that summarizes my - I have one  
19 other comment. The \$300,000 was - the number I got  
20 in discovery on Vermont Yankee was \$1 million in  
21 electric megawatt per year is the going rate for an  
22 uprate. The round-up to be over 7 percent is one  
23 thermal megawatt or a third of a electric megawatt,  
24 which is the \$330,000. That's just the incremental,  
25 the actual outage, the actual uprate is probably

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 generating on the order of \$80 million a year for  
2 Dominion, not 330.

3 MS. BURTON: Thank you.

4 MR. GUNDERSEN: Thank you.

5 CHAIRMAN SIEBER: Any questions by any of  
6 the ACRS members?

7 MEMBER POWERS: Just one question. You  
8 spoke to the issue of confirmatory analysis. Staff  
9 did look at the computational method that was being  
10 used, and the inputs. Isn't that equivalent to doing  
11 a confirmatory analysis?

12 MR. GUNDERSEN: I guess given the short  
13 time that the Staff had to do it, and given that it  
14 wasn't typical, my answer would be no. Dominion had  
15 a handout here, it was Slide 17 of their containment  
16 analysis. And, again, I worked in that containment,  
17 and its space was incredibly tight. And it doesn't  
18 surprise me that a lot of the sub-compartment pressure  
19 issues became -- are becoming awfully significant.

20 Bullet One on Slide 17 of the Dominion  
21 presentation about half an hour ago shows that SPU  
22 mass and energy releases are bounded by the 10 percent  
23 margin provided in the current analysis, which tells  
24 me that until this uprate is approved, they had a 10  
25 percent margin. Now they're throwing roughly 7

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 percent more energy into the containment, so what was  
2 adequate 10 percent margin before is now down to maybe  
3 a 2.9 percent margin, and that put the warning lights  
4 on when I was looking at this analysis. That was  
5 Slide 17 of the Containment section of the Dominion  
6 presentation. Thank you.

7 CHAIRMAN SIEBER: Any other questions?

8 MS. BURTON: Thank you.

9 CHAIRMAN SIEBER: Okay. Thank you very  
10 much.

11 MR. GUNDERSEN: Thank you.

12 CHAIRMAN SIEBER: Appreciate it. I want  
13 to discuss for a minute tomorrow's agenda. We are the  
14 first Subcommittee report tomorrow, and it's supposed  
15 to go from 8:35, following Bill Shack's remarks, to  
16 10:45, which is two hours and 10 minutes. I think it  
17 would be very difficult to compress today's  
18 deliberations into two hours. On the other hand, we  
19 have all but three of our members, I think three, here  
20 today, and what we're doing is bringing everyone up to  
21 the same speed.

22 The agenda for tomorrow talks about the  
23 SPU overview by Dominion, and that's going to last 45  
24 minutes. The fuel and safety analysis by Dominion,  
25 which would last a half an hour, fuel and safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 analysis by the NRR, which last a half an hour, and  
2 closing remarks, which is 15 minutes, and that really  
3 covers the time allowed.

4 Now, the only thing that we covered beyond  
5 that was the containment analysis, and a few issues on  
6 electrical, and a few issues on the PRA. I'd like to  
7 ask any of the members would they object to just  
8 looking at the fuel and safety analysis at the Full  
9 Committee meeting, or do you want additional topics  
10 and information covered? Anybody have a comment?

11 MEMBER POWERS: Well, I think the fuel  
12 analysis section can be tightened up in its  
13 presentation a lot. I think they need to get to the  
14 point there, and get to bottom lines much more quickly  
15 than they did here. Here it was fine to go through  
16 it.

17 CHAIRMAN SIEBER: Yes. Well, it took them  
18 about four hours today, and that's a fair amount of  
19 time. On the other hand, we've all heard it. If we  
20 do that, my suggestion would be that we devote some  
21 time, like perhaps a half an hour, to our guest  
22 comments, which is the containment analysis. And if  
23 you can make those changes to tomorrow's agenda, we'd  
24 spend an hour and a half on fuel and safety analysis,  
25 and a half an hour on the containment analysis. Any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 other comments?

2 MEMBER MAYNARD: I would also suggest  
3 that, to me it's more important to talk about what are  
4 you doing for the SPU? Are you meeting the  
5 requirements and what your margins are. Either  
6 compare it to where you are currently, or if you're  
7 going to have a comparison, at least have some things  
8 that are more apples-to-apples. We spent a lot of  
9 time trying to talk about comparing an apple to an  
10 orange, and getting into an awful lot of non-  
11 productive dialogue.

12 CHAIRMAN SIEBER: Yes. I think I agree  
13 with you. When you look at the current ratings, and  
14 the current analysis, and compare it to the stretch  
15 ratings and stretch analysis, and in the process  
16 change assumptions and methods, the comparison is no  
17 longer valid. And that was the confusing issue today  
18 from 9:00 in the morning until now. And on the other  
19 hand, I don't think that the licensee or the Staff,  
20 either one of them, can change their presentations  
21 overnight, and I'm not going to ask them to do that,  
22 but I think your point is well taken.

23 Any other comments or remarks?

24 MEMBER MAYNARD: I would also just like to  
25 have part of the Staff's -- I would definitely like to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 know whether what we're doing is legal as far as the  
2 7 percent of whatever.

3 CHAIRMAN SIEBER: Really, I'm not a master  
4 of the regulations, but whether it's a stretch power  
5 uprating or an extended power uprate determines what  
6 review standard the Staff uses. And at Beaver Valley,  
7 they used RS-001, at Millstone they used RS-001, so  
8 it's really -- it's irrelevant whether you call it a  
9 stretch or extended.

10 MEMBER MAYNARD: Not necessarily. You do  
11 have different review standards you may use. I do  
12 think it's important that there is -- what we're doing  
13 is consistent with the regulatory requirements.  
14 That's all I wanted to make sure of.

15 CHAIRMAN SIEBER: Well, we'll ask John  
16 Lamb to find that out overnight.

17 MR. LAMB: There was a legal, a request  
18 for a hearing. The ASLB denied that request. The  
19 Coalition Against Millstone filed an appeal, that  
20 appeal was responded to by Dominion and the Staff, and  
21 now it is with the Commission for their decision. And  
22 if you wish to see their legal opinion of the 7  
23 percent argument, I can give you the ASLB's -

24 MEMBER MAYNARD: You've answered my  
25 question. I wanted to make sure that it had really

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 been addressed. It may still be under contention or  
2 whatever, and that's fine.

3 MR. LAMB: I can give you the ASLB order  
4 that discusses the 7 percent, and you can see the  
5 legal opinion from them. And, obviously, they've  
6 appealed that.

7 MEMBER MAYNARD: And I just wanted to make  
8 sure -- I also agree with Dr. Powers that it is really  
9 irrelevant for what we do ourselves.

10 MR. LAMB: It's about 50 pages, but the  
11 section on that is about three or four pages on the 7  
12 percent, the order.

13 MEMBER STETKAR: Jack, let me just ask  
14 you. Speaking for two of the members who are not here  
15 today who will be here tomorrow, both of whom are  
16 interested in PRA, and human reliability.

17 CHAIRMAN SIEBER: Glad they weren't here  
18 today.

19 MEMBER STETKAR: Yes, there's that, too.  
20 I don't know -- I'll ask everybody else in here for  
21 their opinion over whether we need -- there's nothing  
22 in the SER that discusses a word about the PRA. And  
23 this is certainly not a risk-informed application; so,  
24 therefore, the quality or any statements about the PRA  
25 in the application are relatively a moot point.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SIEBER: This is really a tech  
2 spec change.

3 MEMBER STETKAR: Yes. So, in that sense,  
4 in terms of governing time, I just wanted to bring it  
5 up in deference to -

6 MEMBER BANERJEE: Well, I would like to  
7 hear the answer to your question. The permissive,  
8 whatever it was. The injection system for the change  
9 in the logic.

10 MEMBER STETKAR: P-19 permissive?

11 MEMBER BANERJEE: Yes. Did you get an  
12 answer on that?

13 MEMBER STETKAR: Yes. They did. They  
14 answered it. And their answer is reasonable. They  
15 said there are no scenarios in the PRA that take  
16 credit for that. There are no scenarios in the PRA  
17 that take credit for high pressure injection during  
18 any condition that would not also have a low pressure  
19 in the pressurizer. In other words, that P-19 does  
20 not functionally disable injection for anything in  
21 PRA, and that seems pretty reasonable based on what -

22 MEMBER MAYNARD: I would recommend not  
23 putting it on the agenda tomorrow. It's not a risk-  
24 informed submittal. It's not affecting any decisions  
25 that would be made. And I think that the majority of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the members heard the discussion today. You could  
2 fill -

3 MEMBER STETKAR: No, I just -- we've been  
4 characterized as a gang of three in the past. I want  
5 to speak up for the other two of the gang. That's  
6 all.

7 CHAIRMAN SIEBER: Well, you have.

8 MEMBER POWERS: A description of -- a term  
9 of endearment when you called -

10 MEMBER STETKAR: No, no, no. We recognize  
11 that.

12 CHAIRMAN SIEBER: Any other comments?

13 MR. WALLIS: In view of our reaction to  
14 the PRA, I'm not sure that the licensee would want to  
15 present it.

16 (Laughter.)

17 CHAIRMAN SIEBER: Any other comments? If  
18 not, it's 5:30, and we're early, believe it or not,  
19 and so we will adjourn.

20 (Whereupon, the proceedings went off the  
21 record at 5:22:08 p.m.)

22

23

24

25

CERTIFICATE


This is to certify that the attached proceedings  
before the United States Nuclear Regulatory Commission  
in the matter of: Subcommittee on Power Upgrades

Name of Proceeding: Advisory Committee on  
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the  
original transcript thereof for the file of the United  
States Nuclear Regulatory Commission taken by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the  
foregoing proceedings.

  
Toby Walter  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



**Dominion**

# ***Millstone 3 Stretch Power Uprate***

**ACRS Meeting  
Overview**

**July 2008**



**Dominion**

# ***Introduction***

**J. Alan Price**  
**Millstone Site Vice President**

**Ron Thomas**  
**Project Manager**



**Dominion**

# ***Project Team***

- ❑ **Significant Millstone Station And Dominion Corporate Engineering Staff Involvement. Not Turn-Key To An Outside Company.**
- ❑ **Full Time Dominion Team Members Included Representatives From Operations, Project Engineering, Nuclear Analysis & Fuel, Mechanical Engineering, Electrical Engineering, and Licensing.**
- ❑ **Operations Provided A Full Time Licensed Senior Reactor Operator During The Entire Project. Additional Operations Full Time And Part Time Personnel Were Added During The Past 15 Months As We Prepared For The Implementation Outage.**
- ❑ **Full Time Engineering Team Member Dedicated To Operating Experience And Margin Management.**
- ❑ **22 Companies Supported The SPU Effort.**
  - Shaw: Stone & Webster focused on the BOP and engineering program evaluation effort.
  - Westinghouse focused on the NSSS and accident analysis effort.
  - OEM Vendors included GE, Areva, TEI, Yuba, ALTRAN, ProtoPower.



**Dominion**

# ***Licensed Core Power Level***

- The Current and Original Licensed Core Power Level For Millstone 3 Is 3411 MWt.**
  
- Requesting Approximately A 7% Increase To 3650 MWt.**
  
- This SPU Maintains The 2% Measurement Uncertainty Margin For Determining Core Power Level.**
  
- Selection Of The New Power Level Was Based On Operations and Engineering Analysis That Showed No Major Modifications Necessary Up To 107% Power.**
  - Most Station Modifications Were Changes To Documentation, Calculations, Procedures And Drawings.
  - Hardware Changes: Replaced Feedwater Pump Turbine Rotor. Insulated 4 MOV motors in MSVB.
  - Control Function Changes.
  - Instrumentation Setpoint and Scaling Changes.



**Dominion**

# ***Other Topics For Today***

- Fuel and Safety Analysis.**
  
- Containment.**
  
- Electrical Power & Equipment Qualification.**
  
- Flow Accelerated Corrosion.**



# ***Millstone 3 Stretch Power Uprate***

**ACRS Meeting  
Containment**

**July 2008**





**Dominion**

# ***Containment Topics***

- Analysis Summary.**
- Analysis Methodology.**
- Initial Conditions.**
- Results.**
  - EEQ Pressure Profile.
  - EEQ Temperature Profile.
  - Impact on RSS NPSH.
  - Piping Stress Analysis.
  - Minimum Containment Pressure.
- Sub-Compartment Analysis.**



Dominion

# *Analysis Summary*

- **Containment Analysis Methodology Updated To Current Standards.**
  
- **Significant Margin Remains Following SPU.**
  - 3.6 psi containment pressure margin.
  - EEQ profiles essentially unchanged.
  - No impact on current NPSH analysis.
  - Minimum pressure unaffected by SPU.
  - Subcompartment analysis remains bounding
  
- **Modifications Made To RSS Pipe Supports To Restore Stress Margins.**



**Dominion**

# ***Containment Analysis Overview***

- Current Long Term Mass and Energy release calculations have not been updated since original licensing.**
- SPU long term mass and energy releases incorporates NRC approved methodology updates.**
- Containment analysis changed to in-house NRC approved methodology.**
- Because of changes in both mass and energy releases and containment methodologies, comprehensive sensitivity studies performed to assure limiting conditions identified.**
- Original sensitivity studies repeated as well as new sensitivity studies performed consistent with current approved updated methodologies.**



**Dominion**

# ***Containment Analysis Overview***

- Ranges of initial conditions expanded for operational flexibility.**
  
- Containment results used for a number of different component evaluations.**
  - Containment minimum and maximum design pressure.
  - Maximum containment liner temperature.
  - Maximum pressure and temperature profiles for equipment qualification.
  - Maximum sump temperature at time of recirculation for pump NPSH.
  - Minimum and maximum temperature combinations for pipe stress evaluations.
  
- Bounding assumptions are dependent upon the component being evaluated.**
  
- Reduction in cold leg temperature for SPU evaluated for impact on subcompartment analysis.**



Dominion

# Analysis Methodology

<u>Methodology</u>	<u>Current</u>	<u>SPU</u>
<b>LOCA Mass &amp; Energy Releases</b>		
<b>Blowdown</b>	SATAN-VI	Unchanged
<b>Reflood</b>	WREFLOOD	Unchanged
<b>Post-Reflood</b>	FROTH	GOTHIC
<b>Models</b>	WCAP-9220 WCAP-6174 NS-TMA-2075 WCAP-8170	WCAP-10325 WCAP-8264 DOM-NAF-3



Dominion

# *Analysis Methodology*

<u>Methodology</u>	<u>Current</u>	<u>SPU</u>
<b>Steam Line Break Mass and Energy Releases</b>	MARVEL	LOFTRAN
<b>Containment Analysis</b>	LOCTIC	GOTHIC
<b>Subcompartment Analysis</b>	THREED	Unchanged



Dominion

# *Analysis Initial Conditions*


<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
Volume, cu. ft.	2.26E+6	Unchanged
Pressure, psia	10.4 to 14.2	Unchanged
Temperature, °F	80 to 120	75 to 125
Humidity, %	50 to 100	0 to 100
SW Temperature, °F	33 to 78	33 to 80



# Dominion *Results*


<u>Parameter</u>		<u>Limit</u>	<u>Current</u>	<u>SPU</u>
<b>Peak Containment Pressure, psig</b>	LOCA	45	38.3	41.4
	SLB	45	34.14	38.15
<b>Maximum Containment Liner Temperature, °F</b>		280	255.9	241





# EEQ Pressure Profile

SPU Accident Pressure Profile






Dominion

# EEQ Pressure Profile

Figure 1 - LOCA Composite Pressure Profile






Dominion


# EEQ Temperature Profile

Containment Accident Temperature Profile



# EEQ Temperature Profile

Figure 2 - LOCA Composite Temperature Profile





Dominion

# Impact On RSS NPSH

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>	<u>Impact</u>
Minimum Sump Elevation Above Elev -24'6", feet	4.33	4.33	Unchanged
Maximum RSS Flow, gpm	8220	8220	Unchanged
Maximum Sump Temperature, °F	260	225	Bounded By Current Calculation
Credit For Containment Back Pressure	No	No	Unchanged



# **Dominion** *Pipe Stress Analysis*

- Limiting Conditions For QSS / RSS Piping.**
  - Heatup prior to spray.
  - Cooldown due to spray initiation.
  - Asymmetric temperature conditions due to postulated single failures.
  
- Large Number Of Sensitivity Cases Analyzed,**
  
- Stress Level A / B Criteria Applied.**
  
- Modification To A Limited Number Of Pipe Supports Needed To Assure Stress Criteria Met For Asymmetric Temperature Conditions.**



**Dominion**

# ***Minimum Containment Pressure***

- Current Bounding Event Is An Inadvertent Containment Spray Actuation.**
  
- Analysis is Independent of Core Power Level.**



**Dominion**

# ***Subcompartment Analysis***

- For Most Scenarios, The SPU Mass And Energy Releases Are Bounded By The 10% Margin Provided In Current Analysis.**
  
- SPU Analysis Credits Leak-Before-Break For Exclusion of RCS Piping Break In The Steam Generator Cubicle.**
  
- New Analyses Performed For The Pressurizer Surge Line Break.**





# *Impact on Subcompartment Analysis*

	<u>Break</u>	<u>Basis For Acceptability</u>
<b>Pressurizer Cubicle</b>	Spray Line	Mass and Energy Releases Bounded By 10% Margin
	Surge Line	Structural Analysis Performed To Demonstrate Acceptability
<b>Steam Generator Compartment</b>	Primary Side Breaks	Leak-Before Break Exclusion
	Feedwater Line Break	Conservatism In Critical Flow Correlation

# ACRS Subcommittee on Power Upgrades

---

NRC Staff Review of Proposed Stretch Power Upgrade

For

Millstone Power Station, Unit 3



July 8, 2008

# Opening Remarks

---

Joseph G. Giitter

Director

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

# Opening Remarks

---

- NRC staff effort
  - Requests for additional information
  - Supplements to application
- Challenging review areas included:
  - Fuel and core design analysis
  - Environmental Qualification
- Safety evaluation - no open technical issues

# Introduction

---

John G. Lamb

Senior Project Manager

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

---

# Introduction

---

- Dominion Nuclear Connecticut, Inc. (DNC) is the licensee for Millstone Power Station, Unit 3 (MPS3)
- MPS3 Proposed Stretch Power Uprate (SPU)
  - 3,411 to 3,650 Megawatts Thermal (MWt)
  - Approximately 7% increase (239 MWt)
- Background
  - Licensed January 31, 1986
  - Approved License Renewal – October 2005
  - Operating License expires November 25, 2045
- Method of NRC staff review – RS-001 as guidance
- Schedule and Implementation

# Topics for July 8, 2008

---

- Introduction and Overview of the SPU application
- Fuel & Safety Analysis
- Containment Analyses
- Electrical and Grid Reliability
- Flow-Accelerated Corrosion

**Fuel and Reactor Systems  
Evaluation  
MPS3 SPU**

Benjamin Parks and Samuel Miranda  
Reactor Systems Branch  
Leonard Ward, Ph.D.  
Nuclear Performance and Code Review Branch  
Division of Safety Systems  
Office of Nuclear Reactor Regulation



# Review Scope

- Staff reviewed the impact of SPU on
  - Fuel system and nuclear design
  - Thermal-hydraulic design
  - Overpressure Protection
  - Accident & Transient analyses
  - LOCA
  - ATWS
  - Westinghouse methods

# Review Method

- Scope of EPU evaluations generally followed NRC-accepted, generic SPU guidelines and evaluations
- Analyses and evaluations are based on NRC-approved methodologies, analytical methods, and codes
- Followed the EPU review standard (RS-001)

# Fuel System and Nuclear Design

- Evaluations:
  - Mechanical based on multiple fuel types
  - Nuclear/Thermal-hydraulic on RFA/RFA2
- Uprate effects:
  - Slight increase to linear heat rate
  - Slightly less peaked core design
- Licensee's evaluations demonstrate that acceptable core design may be achieved at uprated power level
- Cycle-specific analyses and evaluations will demonstrate compliance in accordance with NRC-approved reload licensing process

# Thermal-Hydraulic Design

- Matrix 8 of RS-001 references General Design Criteria 10 and 12.
- Compliance with GDC 10 was shown by evaluations of DNB using ANSI acceptance criteria, Conditions I-IV.
- Compliance with GDC 12 is achieved by inherently stable core design, with trip features to shut down reactor in the event of xenon oscillations.

# Accident & Transient Analyses

- Review included those transients covered in Matrix 8 of RS-001; results were acceptable as noted in staff's SER.
- Several accidents/transients warranted additional staff review:
  - Overpressure Protection
  - Inadvertent ECCS Actuation/P-19 Permissive
  - Rod Withdrawal at Power – Low Power

# Overpressure Protection

- Limiting Overpressure event is Loss of Load/Turbine Trip
- Applicable ANSI Condition II Acceptance Criterion:
  - Limit peak pressure to 110% of reactor coolant system design pressure
- Two trips terminate event:
  - High Pressurizer Pressure
  - Overtemperature- $\Delta T$

# Overpressure Protection Continued

- Pursuant to staff request for additional information, licensee analyzed event crediting only the second (OTΔT) trip.
- Results of sequence crediting either trip were acceptable
- Peak pressure did not exceed 2750 psi (110% RCS Design Pressure)

# Inadvertent ECCS Actuation

- Licensee will implement new permissive, P-19 Cold Leg Injection Permissive



# AOO Acceptance Criterion

- “By itself, a Condition II incident cannot generate a more serious incident of the Condition III or IV type without other incidents occurring independently.”
- NRC reminded licensees that this criterion is in the plant licensing bases, and therefore must be met (RIS 2005-29).

# AOOs That Add Mass to RCS

- Inadvertent Actuation of ECCS can develop into a small break LOCA at the top of the pressurizer, if a PORV sticks open.
- In analyses, PORVs that are not qualified for water relief are assumed to stick open after they relieve water.

# Millstone Unit 3 Operating Experience

- Inadvertent actuation of ECCS incident occurred on April 17, 2005.
- Resulted in water relief through the PORVs

# Millstone Unit 3


- PORVs are qualified for water relief
- P-19 Permissive interlocks the charging cold leg injection valves with a low pressurizer pressure signal coincident with an SI signal.


# P-19 Permissive

- Charging cold leg injection valves do not open unless RCS pressure  $<$  low pressurizer pressure reactor trip setpoint and an SI signal is present.
- A single fault does not cause the cold leg injection valves to open. (P-19 would have prevented the incident of 2005.)

NO. 2101

PRESSURE LOW PROTECTION  
(LEAD/LAG COMPENSATED)





# Rod Withdrawal At Power

- Rod withdrawal at power evaluated in Licensing Report with acceptable results
- LR referenced a generic disposition of the potential for RCS overpressurization, given a RWAP initiated at a low power level
- Staff questioned the generic evaluation



# Low Power RWAP – Generic Study

- Westinghouse evaluated the potential for overpressure conditions following a RWAP initiated at a power level where the high neutron flux-low setting can be blocked.
- Evaluation pertained to plants with water-filled loop seals on pressurizer safety valve discharge piping.
- Millstone 3 does not have water-filled loop seals; pressure relief would occur earlier.

# Details of Generic RWAP Evaluation

- Performed for 4-loop Westinghouse plant
- Total power less than Millstone 3 SPU
- Pressurizer level lower than Millstone 3
- Remaining input parameters conservative relative to Millstone 3 SPU

# Westinghouse Study of RWAP at Millstone 3

- Remove seal purge delay on pressurizer safety valve
- Increase core power level
- Increase pressurizer initial water level

# Westinghouse Study of RWAP at Millstone 3 Continued

- Results confirmed that eliminating seal purge delay compensated for increased liquid volume in pressurizer and increased nuclear power addition capability
- Conclusion: Positive Flux Rate Trip terminates transient and Pressurizer Safety Valves mitigate pressurization effects.

# LOCA

- Large Breaks evaluated with ASTRUM Best Estimate Method (Change from BART/BASH Appendix K Method)
- Small breaks evaluated using NOTRUMP (no change)
  - SBLOCA results show significant margin to regulatory limit

# LOCA Results

	Small Break	Large Break	Acceptance Criterion
Peak Clad Temp, °F	1193	1781	2200
Local Cladding Oxidation, %	0.05	3.5	17
Core Wide Oxidation, %	0.01	0.12	1.0

# Westinghouse Methods

- Licensee implements VIPRE/RETRAN to replace THINC-IV/LOFTRAN
- Use of LOFTRAN is maintained in some cases
  - Steam Generator Tube Rupture
    - Modified version of LOFTRAN to credit operator action
  - Transients where use of WRB-2M is restricted

# Summary

- Transient and accident analyses demonstrate acceptable results at uprated conditions
- Fuel design remains acceptable to support the uprate
- Methods implemented acceptably



# Containment Review

Ahsan Sallman  
Containment & Ventilation Branch  
Division of Safety Systems  
Office of Nuclear Reactor Regulation

# Containment Review

- Primary Containment Functional Design
- Subcompartment Analyses
- Mass and Energy Release
- Combustible Gas Control in Containment
- Containment Heat Removal
- Pressure Analysis for ECCS Performance Capability
- Reconsideration of Generic Letter 96-06

# Summary of Staff Review

- RS-001, “Review Standard for Power Uprates,” was followed as guidance
- Applied NRC-approved analytical methods
- RAIs were satisfactorily answered
- Applicable GDCs were satisfied
- SRP acceptance criteria were satisfied
- Met 10 CFR 50 requirements

# Primary Containment Functional Design

- Application of GOTHIC 7.2a methodology to MPS3 approved by SE, dated August 30, 2006
- Conservative initial conditions for LOCA and MSLB
- Analyzed a spectrum of breaks for LOCA and MSLB

# Primary Containment Functional Design Continued

- Conclusions

- Limiting short-term LOCA & MSLB peak pressure & temperature are bounded by the containment design conditions
- Limiting long-term LOCA & MSLB pressure & temperature responses are evaluated to be acceptable from the standpoint of EQ

# Subcompartment Analyses

- NRC has approved leak-before-break (LBB) methodology for MPS3 contained in the license renewal SE – NUREG-1838
- Used LBB criteria for selection of pipe breaks
- Conclusion
  - Sufficient margin in the differential pressures across the subcompartment walls under SPU conditions

# Mass and Energy Release Analyses for LOCA & Secondary Pipe Ruptures

- Analyzed a spectrum of breaks for LOCA based on NRC-approved methods: LOCA blowdown & reflood (WCAP-10325-P-A & WCAP-8264-P-A) and post-reflood (DOM-NAF-3-0-0-P-A)
- Analyzed a spectrum of secondary breaks based on NRC approved methods in WCAP-8822, WCAP-8822-01-P-A, WCAP-8822-02-P-A, and WCAP-7907-P-A

# Mass and Energy Release Analyses for LOCA & Secondary Pipe Ruptures Continued

- Used conservative assumptions and inputs to maximize M&E release
- Conclusion
  - Staff reviewed and agreed with the licensee's evaluation of LOCA M&E release



# Combustible Gas Control in Containment

- SER, dated June 29, 2005, removed hydrogen recombiners & monitoring system from Tech Specs as per 10 CFR 50.44 and RG 1.97
- Conclusion
  - SPU does not impact combustible gas control in containment

# Containment Heat Removal

- Containment accident pressure was not used for calculation of NPSHA for RSS pumps
- Input parameters are conservative or the same as the current analysis
- Used GOTHIC methodology to calculate the maximum sump temperature

# Containment Heat Removal Continued

- Conclusion
  - RSS pumps NPSHA requirement is met

# Pressure Analysis for ECCS Performance Capability

- Used conservative initial conditions for calculating the minimum containment backpressure transient
- Calculated containment pressure transient bounds the transient used in the ECCS performance analysis
- Conclusion
  - ECCS performance capability is unaffected by SPU

# Reconsideration of Generic Letter 96-06

- GL 96-06 states, “Thermally induced overpressurization of isolated water-filled piping sections in containment could jeopardize the ability of accident-mitigating systems to perform their safety functions and could also lead to a breach of containment integrity via bypass leakage. Corrective actions may be needed to satisfy system operability requirements.”

# Reconsideration of Generic Letter 96-06 Continued

- Licensee reviewed GL 96-06 for piping system penetrating containment along with its relief valves as a part of SPU system design pressure & temperature evaluation
- Conclusion
  - No hardware changes are necessary for SPU conditions

# Summary

- Applicable GDCs were satisfied
- SRP acceptance criteria were satisfied
- Met 10 CFR 50 requirements

# Electrical Systems

Sheila Ray

Electrical Engineering Branch

Division of Engineering

Office of Nuclear Reactor Regulation



# Electrical Systems Regulations

- 10 CFR 50.49
  - Environmental Qualification
- 10 CFR 50.63
  - Station Blackout
- 10 CFR Part 50, Appendix A, GDC-17
  - Electrical Power Systems

# Electrical Systems Evaluation

- Loading on safety equipment remains bounding
- Current analyses remain bounding
  - AC Distribution System
  - EDGs
  - Switchyard
  - DC System
  - Station Blackout
  - Power Block Equipment

# Environmental Qualification

- Existing environmental qualification remain valid for all areas except Main Steam Valve Bldg
- Additional analysis was performed due to the environmental changes in the MSVB. All equipment remains qualified in accordance with 10 CFR 50.49.

# Grid Stability

- Safe operation under increased electrical output and increased plant load
  - Voltage studies indicated no adverse impacts.
  - The grid remained stable for all analyzed contingencies.

# Summary

- The Electrical Engineering Branch staff found the following areas acceptable for operation at uprated conditions:
  - Environmental Qualification
  - Offsite Power Systems
  - Onsite Power Systems
  - Station Blackout

# Flow-Accelerated Corrosion

Matthew Yoder

SG Tube Integrity & Chemical  
Engineering Branch

Division of Component Integrity  
Office of Nuclear Reactor Regulation

# Flow-Accelerated Corrosion

## Regulatory Evaluation

- Generic Letter 89-08, “Erosion/Corrosion Induced Pipe Wall Thinning”
- EPRI NSAC-202L, “Recommendations for an Effective Flow-Accelerated Corrosion Program”
- Design code minimum wall thickness

# Flow-Accelerated Corrosion

- Some changes in variables that affect FAC.
  - Primarily velocity and temperature
- Components inspections will increase as a result of the increased FAC rate at SPU conditions.
- CHECWORKS computer models are being updated prior to implementing the SPU.
- At SPU conditions, the FAC program remains consistent with industry guidelines.



# Summary

- Staff concludes the licensee has addressed changes in the plant operating conditions on the FAC analysis.
- Staff concludes the licensee has demonstrated that the updated analyses will predict the loss of material by FAC and will ensure timely repair or replacement of degraded components following implementation of the proposed SPU.

# Staff Conclusion

- The staff concludes that there is reasonable assurance that the health and safety of the public will not be endangered by the proposed SPU.

UNITED STATES  
NUCLEAR REGULATORY COMMISSION

*In the matter of*

DOMINION NUCLEAR CONNECTICUT INC. )  
MILLSTONE POWER STATION UNIT 3 )  
LICENSE AMENDMENT REQUEST )  
STRETCH POWER UPRATE )

Docket No. 50-423

DECLARATION OF ARNOLD GUNDERSEN SUPPORTING  
CONNECTICUT COALITION AGAINST MILLSTONE IN ITS PETITION FOR  
LEAVE TO INTERVENE, REQUEST FOR HEARING, AND CONTENTIONS

I, Arnold Gundersen, declare as follows:

1. My name is Arnold Gundersen. I am sui juris. I am over the age of 18-years-old.  
I have personal knowledge of the facts contained in this Declaration.
2. I reside at 376 Appletree Point Road, Burlington, Vermont.
3. The Connecticut Coalition Against Millstone has retained me as an expert witness in the above captioned matter.
4. I have a Bachelor's and a Master's Degree in Nuclear Engineering from Rensselaer Polytechnic Institute (RPI) cum laude.
5. I began my career as a reactor operator and instructor at RPI in 1971 and progressed to the position of Senior Vice President for a nuclear licensee. I am a vetted expert witness on nuclear safety and engineering issues. My more than 37-years of professional nuclear experience include and are not limited to: nuclear

safety expert witness testimony; nuclear engineering management and nuclear engineering management assessment; prudency assessment; nuclear power plant licensing, licensing and permitting assessment, and review; nuclear safety assessments, public communications, contract administration, assessment and review; systems engineering, structural engineering assessments, cooling tower operation, cooling tower plumes, nuclear fuel rack design and manufacturing, nuclear equipment design and manufacturing, in-service inspection, criticality analysis, thermohydraulics, radioactive waste processes and storage issue assessment, decommissioning, waste disposal, source term reconstructions, thermal discharge assessment, reliability engineering and aging plant management assessments, archival storage and document control technical patents, federal and congressional hearing testimony, and employee awareness programs.

6. My Curriculum Vitae delineating my qualifications is attached.
7. My Declaration is intended to support Connecticut Coalition Against Millstone's Petition For Leave To Intervene, Request For Hearing, and Contentions.
8. The Five Contentions my Declaration supports are:
  - A. The proposed power level for which Dominion Nuclear has applied to uprate Millstone Power Station Unit 3 exceeds the NRC Stretch Power Uprate (SPU) regulatory criteria.

- B. The design margins for the Millstone Unit 3 Containment, which help to protect public health and safety, have been significantly reduced by license amendments granted in 1991, and Dominion's proposed power increase, if granted, will further reduce Containment margins designed for safety.
- C. When compared to all other Westinghouse Reactors, Millstone Unit 3 is an outlier or anomaly. Dominion's proposed uprate is the largest percent power increase for a Westinghouse reactor. Additionally, Millstone Unit 3 also has the smallest Containment for any Westinghouse reactor of roughly comparable output.
- D. Construction problems due to the unique Sub-Atmospheric Containment Design, coupled with the impact upon the Containment concrete by the operation of the Containment Building at very low pressure, very high pressure and very low specific humidity, place the calculations used to predict the stress on that concrete Containment in uncharted analytical areas.
- E. The impact of flow-accelerated corrosion at Dominion Nuclear's proposed higher power level for Millstone Unit 3 have not been adequately analyzed and addressed.

9. As an expert witness, who happens to hold both a Bachelor's and Master's degree in Nuclear Engineering, have more than 35-years of nuclear industry engineering experience, and as a former Northeast Utilities employee worked on Millstone Nuclear Power Station Unit 3, in my professional opinion the Dominion Nuclear application fails to satisfy *any of the NRC criteria* to be accepted as a Stretched Power Uprate. A thorough review of the evidence presented by Dominion Nuclear and compared and contrasted with NRC Stretched Power Uprate requirements clearly shows that the Dominion Nuclear Stretched Power Uprate application should in fact be treated as an Extended Power Uprate (EPU) application.
10. According to the NRC, there are two criteria<sup>1</sup> that must be met for a licensee to be considered for a Stretch Power Uprate (SPU):
- A. An increase in the reactor power that is **"up to 7 percent"**  
and
  - B. **"... are within the design capacity of the plant"**
  - C. Furthermore, the NRC states that achieving a Stretch Power Uprate **"depends on the operating margins included in the design of a particular plant"**. [Emphasis added]
11. In my opinion, the magnitude of Dominion Nuclear's proposed power increase, the uniqueness of the initial Millstone 3 Power Plant Containment design, the Containment's unusually small size, and the fact that the design margins of the Containment have already been dramatically reduced by changes made to

---

<sup>1</sup> [www.nrc.gov/reactors/operating/licensing/power-uprates](http://www.nrc.gov/reactors/operating/licensing/power-uprates)

Millstone 3 in 1990 by Northeast Utilities, makes it necessary for the NRC to conduct the more thorough and intensive Extended Power Uprate review.

12. Dominion Nuclear has characterized this proposed increase in power at Millstone Unit 3 (Millstone Power Station Unit 3) as a Stretch Power Uprate (SPU), and Dominion Nuclear claims that Millstone 3 meets all the criteria for a Stretched Power Uprate. According to Dominion's letter filing for the power increase:

"DNC developed this LAR utilizing the guidelines in NRC Review Standard, RS- 001, "Review Standard for Extended Power Uprates." In addition, requests for additional information (RAIs) regarding SPU and Extended Power Uprate (EPU) applications for other nuclear units were reviewed for applicability. Information that addresses many of those RAIs is included in this MPS3 SPU LAR. RS-001 states that a SPU is **characterized by power level increases up to 7 percent and does not generally involve major modifications**. Plant modifications are addressed in Section 1.0 of the License Report (LR) (Attachment 5) and are not considered to be major. Since the requested uprate is 7 percent and does not involve major plant modifications, it is considered to be a Stretched Power Uprate."<sup>2</sup>  
[emphasis added]

13. Contention 1: To begin with, the Dominion Nuclear application fails to satisfy the first NRC criteria<sup>3</sup> that the NRC has set the power limit for SPU's at "... up to 7% ...". Yet Dominion Nuclear notifies its acceptance of the NRC's specific criteria in stating "...a SPU is **characterized by power level increases up to 7 percent** ...". Most importantly, Dominion's proposed power increase at Millstone Unit 3 in fact exceeds the seven percent limit established by the NRC and accepted by Dominion Nuclear.

<sup>2</sup> Letter, Dominion Nuclear to NRC, SPU Filing, February 2007

<sup>3</sup> [www.nrc.gov/reactors/operating/licensing/power-uprates](http://www.nrc.gov/reactors/operating/licensing/power-uprates)

14. Millstone Power Station Unit 3 is currently licensed to operate at 3411 thermal megawatts (MWt). This number signifies how much heat the reactor is generating and is accurate to four significant figures (numbers).

- The proposed power level of 3650, for which Dominion Nuclear has applied, exceeds the NRC 7% limit that would qualify the power uprate for the less rigorous review of a Stretched Power Uprate.
- Dominion Nuclear has applied for a power increase to 3650 MWt, which is a full 300 KW above what is allowable by the NRC regulations for a Stretch Power Uprate.
- Let's look at the math. Multiply the current licensed power by the NRC's maximum allowable 7% SPU increase. The calculation total equals 3649.7 MWt, which is below the reactor power level of 3650 MWt for which Dominion Nuclear has applied.  $3411 \times 1.07 < 3650$
- The 7% NRC limit is accurate to two significant figures. When multiplying a two significant figure number by a four significant figure number *mathematical methodology demands the calculation be rounded down not up* as Dominion Nuclear has done in its application.
- By rounding its proposed reactor power level to a higher power level the requested Dominion Nuclear reactor power increase exceeds the regulatory limit for a Stretched Power Uprate (SPU). Thus, this unscientific rounding up of the thermal megawatt power to a higher power



level causes the reactor power to exceed the legal Stretched Power Uprate limit of "up to 7 %" by a full 300 KW.

15. The mathematical evidence shows that Dominion Nuclear proposed power level increase for its Millstone Power Station Unit 3 exceeds the 7% regulatory limit clearly established by the NRC. Therefore, it is my opinion that the Dominion Nuclear's Millstone Unit 3 *is disqualified* for a Stretched Power Uprate.
16. Moreover, while on the face, this mathematical discrepancy may not appear to be a huge number, the 300 KW discrepancy between the NRC 7% limit and Dominion Nuclear's application for a 3650 megawatt thermal increase at Millstone 3 is a significant number that will yield approximately an additional \$1 Million in profit for each additional electric megawatt produced per year.
  - In other words, industry data<sup>4</sup> shows that the profit from each megawatt of electricity generated from uprated power increases the profit yield to each electric generating corporation by approximately \$1,000,000 per year.
  - Therefore the data show us that by rounding up the power level increase at Millstone 3 in excess of 7%, Dominion Nuclear's Millstone Power Station Unit 3 will earn additional profits of approximately \$330,000 each year until 2045.
  - Stated in total dollars, the round up to a power increase in excess of 7% will yield Dominion Nuclear an extra \$10,000,000 during the

---

<sup>4</sup> *Condenser Long Term Plan, Enrico Betti, Vermont Yankee, Memo FILE UND2002-042 07; MSD 2002/002.*

updated license extension to 2045.

17. In the first place, according to the NRC document *Approved Applications for Power Uprates*<sup>5</sup>, the NRC has never allowed a Westinghouse reactor to be licensed for a Stretched Power Uprate with a power level increase as great as that proposed for Millstone Unit 3 by Dominion Nuclear. In the second place, no other Dry Containment<sup>6</sup> Westinghouse reactor with a reactor power level greater than 2000 MWt has been granted a Stretched Power Uprate beyond 6.9 percent.
18. Table 1, inserted below, which is entitled Westinghouse Uprates Ranked in Ascending Order, is a list of all Westinghouse Dry Containment reactors whose thermal power exceeds 2000 MWt.
19. Table 1 ranks the Stretched Power Uprate from smallest to largest, and the NRC data provided in Table 1 shows that no other reactor of this type has ever been granted a Stretched Power Uprate in excess of seven percent like Dominion Nuclear has proposed for Millstone Power Station Unit 3.

---

<sup>5</sup> NRC *Approved Applications for Power Uprates* <http://www.nrc.gov/reactors/operating/licensing/power-uprates/approved-applications.html>

<sup>6</sup> A Dry Containment is a cylindrical structure with a hemispherical dome that relies solely on its large volume to contain the initial release of radioactive steam after an accident, and to reduce the peak accident pressure. It is a robust passive structure without any additional active mechanical means by which to mitigate immediate post accident pressure. Dry Containment does not rely upon ice or water suppression, nor is it maintained at a large sub-atmospheric pressure in order to reduce the peak accident pressure.

Westinghouse Uprates Ranked in Ascending Order

Name	Initial power	Power Uprate %	Current Power
Indian Point 2	2758	1.4	2797
Commanche Peak 1	3425	1.4	3473
Commanche Peak 2	3425	1.4	3473
STP 1	3800	1.4	3853
STP 2	3800	1.4	3853
Diablo Canyon 1	3338	2	3405
Diablo Canyon 2	3338	2	3405
Salem 1	3411	3.4	3527
Salem 2	3411	3.4	3527
Robinson 2	2300	4.5	2403
Shearon Harris	2775	4.5	2900
Vogtle 1	3411	4.5	3564
Vogtle 2	3411	4.5	3564
Wolf Creek	3411	4.5	3564
Turkey Point 3	2200	4.5	2300
Turkey Point 4	2200	4.5	2300
Callaway	3565	4.5	3725
Braidwood 1	3411	5	3581
Braidwood 2	3411	5	3581
Byron 1	3411	5	3581
Byron 2	3411	5	3581
Farley 1	2652	5	2785
Farley 2	2652	5	2785
Indian Point 3	3025	6.2	3213
Seabrook	3411	6.9	3646
Millstone 3	3411	7.01	3650

Table 1

20. Contention 2: The current application by Dominion Nuclear fails to meet the NRC's second criteria for a Stretched Power Uprate application, because the Millstone Power Station Unit 3 already had its design margins dramatically reduced.
21. According to the NRC, achieving a Stretch Power Uprate "...depends on the **operating margins included in the design of a particular plant.**"<sup>7</sup> [emphasis added] Dominion has stated that since the Millstone Power Station Unit 3 application "...does not involve major plant modifications, it is considered to be a SPU". Dominion has erroneously neglected to consider the significant reduction in structural **operating margins** already in place at Millstone Unit 3 prior to its application for a power uprate.
22. The Millstone Power Station Unit 3 Containment structure and its requisite systems have already been "stretched" by previous changes to its design basis when the Containment was converted from Sub-Atmospheric Containment to Dry Containment more than a decade ago. I believe that the proposed changes to Containment systems and structures that have already been reanalyzed and fine tuned once over a decade ago constitutes a dramatic decrease in "...the **operating margins** included in the design of a particular plant."
23. The Containment is the safety related building, which houses the nuclear reactor. As such, it "contains", or in other words collects, the steam and

---

<sup>7</sup> NRC *Approved Applications for Power Uprates* <http://www.nrc.gov/reactors/operating/licensing/power-uprates/approved-applications.htm>

radioactive material that may be released from the reactor after an accident.


Please see the photo below of the inside of the Millstone Power Station Unit 3 Containment during initial fuel load in 1986.

24. As the Northeast Utilities lead licensing engineer on Millstone Power Station Unit 3 during the 1970s, I was responsible for coordinating all of the analysis for the PSAR (Preliminary Safety Analysis Report), which formed the original design basis of the Millstone Power Station Unit 3 including its Containment. This interface was among Millstone's structural mechanical, electrical, construction, and operations personnel as well as the architect Stone & Webster and the NSSS vendor Westinghouse. Millstone Power Station Unit 3 was originally designed to be "Sub-Atmospheric Containment." [In this instance my testimony is that of a fact witness<sup>8</sup> in addition to my overall testimony as an expert witness in this Declaration.]
25. The unique design approach of the Sub-Atmospheric Containment maintained the pressure inside the Containment at a "negative pressure" with respect to the atmosphere. Thus the difference between the pressure outside the Containment and inside the Containment (pressure differential) was approximately four pounds. Speaking as an expert witness nuclear engineer, this pressure

---

<sup>8</sup> According to the Department of Justice United States Attorneys' Manual Title 3, Chapter 3-19.111 An expert witness qualifies as an expert by knowledge, skill, experience, training or education, and may testify in the form of an opinion or otherwise. (See Federal Rules of Evidence, Rules 702 and 703). The testimony must cover more than a mere recitation of facts. It should involve opinions on hypothetical situations, diagnoses, analyses of facts, drawing of conclusions, etc., all which involve technical thought or effort independent of mere facts. And according to Chapter 3-19.112 Fact Witness A fact witness is a person whose testimony consists of the recitation of facts and/or events, as opposed to an expert witness, whose testimony consists of the presentation of an opinion, a diagnosis, etc  
[http://www.usdoj.gov/usao/eousa/foia\\_reading\\_room/usam/title3/19musa.htm#3-19.111](http://www.usdoj.gov/usao/eousa/foia_reading_room/usam/title3/19musa.htm#3-19.111)

differential is quite dramatic for a structure of this size. According to the NRC Sourcebook<sup>9</sup>, page 4-26, paragraph B, Sub-atmospheric Containment, Millstone Unit 3 was the only Westinghouse four-loop plant in the nation to have Sub-Atmospheric Containment.



26. Due to critical engineering and operations concerns during my employment as

---

<sup>9</sup> NRC Sourcebook, page 4-26, paragraph B

the lead licensing engineer for Northeast Utilities on Millstone Power Station Unit 3, both the engineering and operations staff at Northeast Utilities (NU) expressed sincere regret as early as 1975 regarding NU's decision to design and build this unique Sub-Atmospheric Containment.

27. Critical issues of concern to both the engineering and operations staff regarding the Sub-Atmospheric Containment were:
- A. The operations staff working within the Containment was repeatedly subjected to the adverse effects of the high temperature and low oxygen.
  - B. The small size of the Containment Building severely limited space for equipment and also complicated accident analysis.
  - C. Significant construction problems relating to the placement of concrete and rebar were caused by the Containment's small size.
  - D. Minimal analytical data regarding the long-term strength of the building's concrete and its continual exposure to the combination of high temperatures, low pressure, and low specific humidity within the sub-atmospheric Containment as it aged lead to doubts and questions regarding the strength of this critical safety-related structure in the event of a nuclear accident.
28. Despite these major concerns, NU decided in 1976 to continue with the licensing process for Millstone Unit 3 as a Sub-atmospheric Containment rather than risk delaying the license by changing the design. At the same time, the company made the strategic decision to modify Millstone Unit 3's license to

operate, by converting the Containment to a standard "Dry" Containment, but only after the nuclear power plant became operational because it is easier to amend a power plant license after a plant is operational.

29. Millstone Power Station Unit 3 began generating power in 1986, and at that time had Sub-Atmospheric Containment. However, Millstone Unit 3's original design basis with its one-of-a-kind four loop Sub-Atmospheric Containment was modified after it became operational in 1986.
30. The purpose of this one-of-a-kind four loop Sub-Atmospheric Containment was to lower peak design pressure<sup>10</sup> in case of a nuclear accident and to rapidly reduce out-leakage<sup>11</sup> after an accident.
  - A. More specifically, the Containment Building is designed to capture steam, energy, and radiation after an accident. In order to capture this post-accident energy, the Containment pressure increases. Thus, Containment Buildings are designed to specific pressure levels that must be considered during all power level design changes.
  - B. At Millstone Unit 3 the 1975 initial peak Containment design pressure was 39.4 psig<sup>12</sup>.
  - C. However, prior to Millstone Unit 3's start-up<sup>13</sup>, NU reanalyzed the peak pressure and dropped it to 36.1 psig.
  - D. Then on February 26, 1990, NU applied to modify the Millstone Power

---

<sup>10</sup> Maximum pressure inside the Containment after a design basis accident

<sup>11</sup> Leakage out of the Containment

<sup>12</sup> psig - pounds per square inch, gauge

<sup>13</sup> Amendment 17 to FSAR



Station Unit 3 license by changing the design basis pressure of the Containment from 9.8 psia to 14.0 psia<sup>14</sup>.

31. When NU applied for the 1990 license change, it claimed that the sole basis for the change was to reduce the risk of injury to operations personnel who struggled to work at the reduced pressures inside this unique Containment. Such an environment is roughly equivalent to working at the top of the Grand Teton Mountains in temperatures in excess of 100 degrees.
  - A. On page 2 of the initial application, NU stated, "... very little is known about the health effects of people working in high-temperature, low pressure environments."
  - B. While it is true that this was indeed a staff concern dating back to 1975, it was only ONE of other equally important concerns.
  - C. Another major staff concern was the fact that the Containment concrete is being exposed to these very same conditions and there is no data to review regarding the ability of concrete to withstand such a unique high-temperature low-pressure environment. Disturbingly, NU was silent on this major concern throughout its application to modify its license and convert the Sub-Atmospheric Containment to Dry Containment.
32. These changes to the design of Millstone Unit 3's one-of-a-kind Containment actually changed the design basis for the plant.
  - A. From the time the initial PSAR was filed with the NRC, the peak accident pressure of Millstone Unit 3 was repeatedly *fine tuned* by NU.

---

<sup>14</sup> psia - pounds per square inch, absolute

B. From a nuclear engineering standpoint, the critical concern in my mind is that each time a new Containment pressure analysis was derived, NU applied less conservative assumptions in order to achieve more operational flexibility and decidedly increasing public exposure to radiation if there were an accident.

C. In order to accomplish the 1990 modification of Millstone Unit 3, NU changed numerous design criteria and further reduced design margins by taking further credits for systems that were in the original accident scenario design basis.

33. On page 5 of the application to increase Millstone Unit 3's Containment pressure, Northeast Utilities acknowledged that these modifications to the original design "...constitute an Unreviewed Safety Question."<sup>15</sup>

A. In this February 26, 1990 application to the NRC, NU requested to increase the design basis for the normal pressure inside the Containment from 9.8 psia to 14.0 psia, which resulted in the increase of the post-accident peak Containment pressure from 36.0 to 38.57 psig.

B. Since Millstone Unit 3 was originally designed with this unique Sub-Atmospheric Containment Design, in the event of an accident the Containment was designed to leak radiation to the environment for only an hour until it was able to drop the pressure back down and once again

---

<sup>15</sup> An unreviewed safety question means a change which involves any of the following: (1) The probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the safety analysis report may be increased; (2) A possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report may be created; or (3) The margin of safety as defined in the basis for any technical safety requirement is reduced. <http://www.nuclearglossary.com>

contain any radiation releases inside the Containment Building.

- C. The 1990 modifications changed the ability of the Containment Building to release radiation for only an hour and instead allowed the Containment to leak at 0.65 weight percent per day after an accident.
- D. Bypass leakage was also increased from 0.01 to 0.042 weight percent per day as a result of the change, and the modification to the Containment pressure increased the calculated exposure to a person at the Exclusion Area Boundary from 16.8 rem to 19.5 rem.

34. Contention 3: Earlier in this Declaration, I also mentioned that the Millstone Power Station Unit 3 Containment has what is considered a *small* Containment. To illustrate the fact that Millstone Unit 3's Containment is small in comparison to other Westinghouse designed nuclear reactors, I evaluated data from the publicly available "NRC Sourcebook" and compiled information regarding 25 Westinghouse Reactors, which all have "Dry" Atmospheric Containment<sup>16</sup>.
35. Table 2, inserted below, shows, in ascending order by size, the free Containment volume (in millions of cubic feet) of these 25 Westinghouse Reactors.
- A. The Containment for Millstone Unit 3 clearly stands out as one of the smallest such Containment Buildings in the country.

---

<sup>16</sup> Since they are not comparable with Dominion Nuclear's Millstone Power Station Unit 3, I have not included the Westinghouse Reactors with Ice Containments, or several three-loop Reactors with Sub-Atmospheric Containment in the compilation. Also, not included for the same reason are decommissioned reactors and reactors whose thermal power is less than 2000 MWt.

- B. For that matter, the only nuclear power plants with a Reactor Containment that is smaller than Millstone Power Station Unit 3 have power outputs that are 800 to 1200 MWt less than the power output of Millstone Unit 3 *prior to the Dominion's proposed uprate.*
  - C. Moreover, of the 11 identical 3411 MWt Westinghouse four-loop Reactors, Millstone is smaller by as much as half a million cubic feet.
36. The ratio of the initial licensed power level to the Containment Volume at each of the same 25 nuclear reactors is clearly shown in Table 3. This ratio comparison is the real indicator of Millstone Unit 3's small Containment. By applying these ratio criteria in comparison with all 25 reactors, Table 3 clearly shows that Millstone Power Station Unit 3 has the smallest Power to Volume ratio of any Dry Containment Westinghouse reactor in the nation.
37. Dominion Nuclear's proposed 7+% power increase to Millstone Power Station Unit 3 widens even further the size gap between Millstone Unit 3 and the other reactors, thus making Millstone Power Station Unit 3's Containment even "smaller" in comparison to every other Dry Containment Westinghouse reactor in the country.
38. Table 4 shows how the initial licensed power levels of all 25 reactors adjusted as a result of NRC approved "stretch" increases.
- A. Accordingly, I have adjusted the power level number for Millstone Unit 3 in order to reflect the amount proposed by Dominion Nuclear's application to uprate Millstone 3's power.

## Ascending Comparison of Containment Volumes

<b>Name</b>	<b>Volume xE6</b>	<b>Initial power</b>
Turkey Point 3	1.65	2200
Turkey Point 4	1.65	2200
Farley 1	2.03	2652
Farley 2	2.03	2652
Robinson 2	2.1	2300
Millstone 3	2.35	3411
Shearon Harris	2.5	2775
Wolf Creek	2.5	3411
Callaway	2.5	3565
Indian Point 2	2.6	2758
Indian Point 3	2.6	3025
Salem 1	2.6	3411
Salem 2	2.6	3411
Vogtle 1	2.7	3411
Vogtle 2	2.7	3411
Seabrook	2.7	3411
Diablo Canyon 1	2.83	3338
Diablo Canyon 2	2.83	3338
Braidwood 1	2.9	3411
Braidwood 2	2.9	3411
Byron 1	2.9	3411
Byron 2	2.9	3411
Commanche Peak 1	2.98	3425
Commanche Peak 2	2.98	3425
STP 1	3.3	3800
STP 2	3.3	3800

Table 2

### Containment Volume Compared to Initial Power

Name	Volume xE6	Initial power	Initial Power/Volume
Indian Point 2	2.6	2758	1,060.8
Robinson 2	2.1	2300	1,095.2
Shearon Harris	2.5	2775	1,110
Commanche Peak 1	2.98	3425	1,149.3
Commanche Peak 2	2.98	3425	1,149.3
STP 1	3.3	3800	1,151.5
STP 2	3.3	3800	1,151.5
Indian Point 3	2.6	3025	1,163.5
Braidwood 1	2.9	3411	1,176.2
Braidwood 2	2.9	3411	1,176.2
Byron 1	2.9	3411	1,176.2
Byron 2	2.9	3411	1,176.2
Diablo Canyon 1	2.83	3338	1,179.5
Diablo Canyon 2	2.83	3338	1,179.5
Vogtle 1	2.7	3411	1,263.3
Vogtle 2	2.7	3411	1,263.3
Seabrook	2.7	3411	1,263.3
Farley 1	2.03	2652	1,306.4
Farley 2	2.03	2652	1,306.4
Salem 1	2.6	3411	1,311.9
Salem 2	2.6	3411	1,311.9
Wolf Creek	2.5	3411	1,364.4
Turkey Point 3	1.65	2200	1,419.4
Turkey Point 4	1.65	2200	1,419.4
Callaway	2.5	3665	1426
Millstone 3	2.38	3411	1,433.2

**Table 3**

**Containment Volume Compared to Uprate License Power**

<b>Name</b>	<b>Volume xES</b>	<b>Initial power</b>	<b>Power Uprate %</b>	<b>Current Power</b>	<b>Current Power/V</b>
Indian Point 2	2.6	2758	1.4	2797	1,075.76923
Robinson 2	2.1	2300	4.6	2403	1,144.28571
Shearon Harris	2.5	2775	4.6	2900	1,160
Commanche Peak 1	2.98	3425	1.4	3473	1,165.43624
Commanche Peak 2	2.98	3425	1.4	3473	1,165.43624
STP 1	3.3	3800	1.4	3853	1,167.57576
STP 2	3.3	3800	1.4	3853	1,167.57576
Diablo Canyon 1	2.83	3338	2	3405	1,203.18021
Diablo Canyon 2	2.83	3338	2	3405	1,203.18021
Braidwood 1	2.9	3411	6	3581	1,234.82759
Braidwood 2	2.9	3411	6	3581	1,234.82759
Byron 1	2.9	3411	6	3581	1,234.82759
Byron 2	2.9	3411	6	3581	1,234.82759
Indian Point 3	2.6	3025	6.2	3213	1,235.76923
Vogtle 1	2.7	3411	6.2	3564	1,320
Vogtle 2	2.7	3411	6.2	3564	1,320
Seabrook	2.7	3411	6.9	3646	1,350.37037
Salem 1	2.6	3411	3.4	3527	1,356.53846
Salem 2	2.6	3411	3.4	3527	1,356.53846
Farley 1	2.03	2652	6	2785	1,371.92118
Farley 2	2.03	2652	6	2785	1,371.92118
Wolf Creek	2.5	3411	4.6	3564	1,425.6
Turkey Point 3	1.55	2200	4.6	2300	1,483.87097
Turkey Point 4	1.55	2200	4.6	2300	1,483.87097
Callaway	2.5	3565	4.6	3725	1,490
Millstone 3	2.35	3411	7.01	3650	1,553.19149

Table 4

39. An examination of Table 4, inserted above, shows that the new Power to Volume ratio created by the proposed uprate indicates that Millstone Unit 3's Containment would be even "smaller" if Dominion's proposed power increase is approved.
40. A smaller Containment does not mean that the physical Containment has shrunk in size, but rather that more reactor power, and, in the case of an accident, more radioactive releases are being squeezed by volume into the same small Containment Building as a result of this proposed power increase.
41. If approved, Dominion's power increase to Millstone Unit 3 would be the largest ever power uprate approved to Millstone 3's unique Containment with the "smallest" volume ever licensed as discussed above.
42. What is the net effect of increasing the reactor power in this unique very small Sub-Atmospheric designed Containment? I believe that the proposed power increase at Millstone Power Station Unit 3 means that in the event of a nuclear accident at Unit 3, more than 7% additional energy must be absorbed into this one-of-a-kind Containment.
43. I believe that Core samples from within the Containment should be analyzed to assure that the Containment's integrity has not been jeopardized by operating Millstone Unit 3 under these conditions during the first four years of its operational life during the time period while concrete curing shrinkage is



known to occur.

44. In addition to my concerns regarding Millstone Unit 3's operation beyond its design basis due to the analytical tweaking of its one-of-a-kind Sub-Atmospheric Containment, I am also concerned about the reactor power level Dominion has applied in its new analysis in order to support the proposed increase application.

A. Specifically, Dominion Nuclear used a 7.01 percent increase as the basis for energy added to the Containment during an accident. As I have already shown in this Declaration, that 7.01 percent exceeds the NRC limits for consideration for a Stretched Power Uprate.

B. More importantly, Millstone Power Station Unit 3 already has a history of exceeding its licensed reactor power. According to the NRC Integrated Inspection Report on Millstone<sup>17</sup>, Dominion Nuclear was cited for:

"failure to maintain reactor core thermal power less than or equal to 3411 megawatts thermal (MGTH). Specifically, during performance of turbine overspeed protection system testing, the Unit 3 reactor's four minute power average exceeded 3479 MWTH." [Unit 3's license limit is 3411 MGTH also written MWt]

C. This higher power level, for which Dominion Nuclear was cited, is a full 2% higher than level of power Millstone Unit 3 is licensed to produce.

---

<sup>17</sup> Inspection Report on Millstone, ML 080380599, February 7, 2008 for the period 10/012007 to 12/31/2007, Pages 4, 5, 21, and 22

- D. Such a power level increase would also increase the energy available in an accident scenario by the same additional two percent.
- E. Given Dominion's history of exceeding its licensed power level, it is my opinion that any analysis of Millstone Unit 3's Containment should use a 9% additional power level in order to most accurately reflect the condition of this one-of-a-kind Containment to withstand any additional pressures during an accident.
45. Contention 4: In its 1990 licensing application to change its Containment pressure, NU never mentioned its staffs' previous concerns about possible stress to the Containment's concrete due to the impact of its operation at high temperatures, low pressures, and low specific humidity. While it is a well known fact throughout the industry that concrete continues to shrink for up to 30-years as it matures after being poured, I was unable to uncover any NU or Dominion studies the long term impact Millstone Unit 3's concrete Containment due to its unique high temperature, low pressure, and low specific humidity environment.
46. Since nothing about this proposed change is either simple or standard, it is therefore my professional opinion that an Extended Power Uprate (EPU) review is more appropriate than a Stretched Power Uprate (SPU) review.

47. Furthermore, the Containment analysis for Millstone Unit 3 is further complicated by the fact that for the first four years of its operation, Millstone Power Station Unit 3 operated at the high, temperature, low pressure, low specific humidity unique to its Sub-Atmospheric Containment and therefore which may have compromised the structural integrity of the concrete.
48. In addition to being the lead licensing engineer at for NU at its Millstone Unit 3 nuclear plant during the 1970s, I have also been both a vice president and the senior vice president of a company that provided goods and services to Millstone 3 during the 1980s.
- A. In my capacity as an officer of the firm contracted to conduct structural analytical support to Millstone Unit 3 during its construction phase, I oversaw a group of sixty structural engineers at the Millstone Unit 3 site in 1984.
- B. Engineers reported to me during the construction phase informed me of other structural problems involving Millstone Unit 3's unique Containment.
- C. Due to the design of this Containment, the size and amount of rebar near major Containment penetrations created strategic geometry problems in the ability of the construction contractors to pour adequate amounts of concrete around the rebar in this tight configuration.
- D. This unique Containment design placed an enormous amount of rebar in

several different directions around the Containment penetrations<sup>18</sup>, making it extraordinarily difficult for concrete to slip by the rebar.

Concrete voids between the rebar were a major concern. To "solve" this problem, NU qualified a procedure for the construction workers to apply long vibrating shafts into the rebar to get the concrete to slide around the rebar and create a heterogeneous block without voids.

- E. This vibration method caused the sand to separate from the concrete if applied too long, and would create voids if applied for too short of a time.
- F. While the procedure was qualified and construction workers were trained in how to operate the vibrating rods, my structural engineers were concerned that there was no way to test the Containment penetrations after the concrete had hardened to assure there were no voids.
- G. The complex geometry at penetrations and the presence of concrete and steel intertwined made any ultrasonic exam impossible.
- H. Core drilling was, of course, impossible, as it would weaken the Containment.
- I. Given the structural limitations of the original design, and given that licensing changes in 1990 modified the Containment, it is imperative that this license modification be given a more thorough investigation than what is normally provided during a *Stretch* Power Uprate approval

---

<sup>18</sup> Containment penetrations - Locations through the Containment wall where pipes like steam lines and feedwater lines enter and exit the Containment.

process.

49. Contention 5: Flow Accelerated Corrosion is another critical issue that should be considered the review of Dominion's proposed power increase application.

- A. Dominion's proposed power uprate will change Millstone Power Station Unit 3's reactor coolant flow by approximately 7%.
- B. It will impact the flow in and out of the reactor and the steam and condensate/feedwater flow on the secondary side of the plant will also be increased by 7%.
- C. These flow increases in turn increase "Flow Accelerated Corrosion" thus causing pipes to wear out much faster.
- D. This Flow Accelerated Corrosion is a non-linear phenomenon, and in my opinion is a significant risk due to the application of a 7% power increase on a plant that is already in the second-half of its engineered design life.
- E. Disturbingly, in its application, Dominion did not propose hiring any new personnel at Millstone Power Station Unit 3 to deal with *flow accelerated corrosion* following the unit's proposed power uprate. This despite the fact that components will require more inspections because an uprate will cause those components to wear out much faster.
- F. In general, Flow Accelerated Corrosion increases the likelihood of pipe failure.

G. Equally important, given Millstone Power Station Unit 3 exceeded licensed power less than a year ago, is the concern that pipe already worn thin by the seven percent power increase might break when power is increased further.

H. I saw no evidence that the Containment has been analyzed to withstand this increased energy.

50. I believe that Millstone Unit 3's program for assessing Flow Accelerated Corrosion in Dominion's proposed uprate of the plant fails to comply with 10 CFR50 Appendix B, XVI which states:

10 CFR Appendix B to Part 50 – Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants, XVI. Corrective Action that reads:

“Measures shall be established to assure that conditions adverse to quality, such as failures, malfunctions, deficiencies, deviations, defective material and equipment, and nonconformances are promptly identified and corrected. In the case of significant conditions adverse to quality, the measures shall assure that the cause of the condition is determined and corrective action taken to preclude repetition. The identification of the significant condition adverse to quality, the cause of the condition, and the corrective action taken shall be documented and reported to appropriate levels of management.”

51. The power increase at Millstone Power Station Unit 3 will be accomplished by increasing the flow of water through both the primary and secondary sides of

the power plant. This increased flow through the pipes causes pipes to wear out faster by a phenomenon called Flow Accelerated Corrosion (FAC).

52. The basic two causes of FAC are erosion-corrosion of the pipe walls and cavitation- corrosion of the pipe wall. Electrolytic attack may also occur. Wall thinning from FAC is non-linear and is a local issue, caused by local geometry like Elbows and flow restrictions, local turbulence, and local metallurgical conditions (welds and impurities) in the pipe. Once local corrosion has started, changes in turbulence in the local area can intensify the corrosive attack. This localized nature of the corrosion is evident in a FAC pipe failure at the Surry plant in 1986. There a feed-water elbow had holes in one area, yet the nearby pipe wall was much less worn. Similar FAC piping failures have occurred at San Onofre in 1991 and 1993, Fort Calhoun in 1997, and Mihama in Japan in 2004. While this is an *old issue*, it has not been resolved, and instead has continued to plague the nuclear industry for more than three decades.
53. Due to the localized nature of the FAC, it is difficult to predict where and when a piping component might fail. The difficulty in developing accurate predictive models for FAC is the reason why, as recently as 2004, several workers were killed at Japan's Mihama I nuclear power plant. While prediction of what might fail is difficult, it is certain, however, to say that the rate at which piping components will wear out as a result of the proposed increase in power at Millstone 3 will exceed the 7 percent power increase due to the non-linear nature of FAC.

54. In my opinion, Dominion's application does not adequately address the guidance of NRC NUREG-1800, which requires that a FAC program address the scope, analytical tools, benchmarking of the computer model, preventative activities, what is monitored, what is inspected, trend analysis, acceptance criteria, operating experience, inspection techniques as well as data collection.
55. Furthermore, I believe Dominion's proposed License amendment for Millstone Power Station Unit provides inadequate information to determine if Millstone Nuclear Power Station Unit 3 has the management systems and staff in place to properly evaluate FAC if NRC approves Dominion's proposed power increase to the plant.
- A. The application did not discuss the increases in staff necessitated in order to maintain the plant in a safe condition if the proposed power increase is approved.
  - B. Clearly the increase in the increased corrosion rates caused by the proposed 7% power level increase will require extra analysis, extra inspection, and extra maintenance, yet the application is silent on the need to increase Millstone Unit 3's inspection and maintenance staff.
56. Without such programmatic and staffing information, I am unable to further assess the adequacy of any actions Dominion Nuclear might have to mitigate



the consequences of Flow Accelerated Corrosion caused by the proposed power uprate at Millstone Nuclear Power Station Unit 3.

57. In conclusion: following a complete review of the evidence presented and by relying upon my nuclear safety and nuclear engineering experience in my review of the documents referenced herein above, it is my professional opinion that the issues discussed above are serious safety considerations germane to the subject of the license application in this case. Similarly after reviewing all the evidence presented, it is my professional opinion that Dominion Nuclear is ill prepared to increase the power at Millstone Nuclear Power Station Unit 3. Finally, since Dominion's proposed power increase is above NRC regulatory criteria and given the new stresses upon the one-of-a-kind formerly Sub-Atmospheric Containment, I believe that the evidence clearly shows the entire application should be given the more rigorous review of the Extended Power Uprate License Evaluation.

I declare under penalty of perjury that the foregoing is true and correct.

Executed this day, March 15, 2008 at Burlington, Vermont.

 3/15/08

Arnold Gundersen, MSNE



# ***Millstone 3 Stretch Power Uprate***

**ACRS Meetings  
Fuel & Safety Analysis**

**July 2008**



**Dominion**

# ***Fuel and Safety Analysis Topics***

- Fuel Design.**
  
- Nuclear Design.**
  
- Initial RCS Conditions.**
  - Pressurizer Level.
  
- Safety Analysis Summary.**
  - Methodologies.
  - DNBR Margin & Results.
  - RCS / SG Overpressure Results.
  - Pressurizer Overfill.
  - Design Basis Results.
  
- Radiological Consequences.**
  
- PRA.**



**Dominion**

# ***Fuel and Nuclear Analysis Overview***

- No change in fuel design.**
- Core will be 100% RFA-2. There are no mixed core issues.**
- SPU achieved through an increase in feed batch size.**
- Reduction in peaking factor design limits to increase DNBR margin.**
- Predicted end-of-life fluence has decreased because the incorporation of more recent surveillance capsule data offsets power increase.**



**Dominion**

# *Fuel Design*

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
<b>Fuel Type</b>	Robust Fuel Assembly (17x17 RFA-2)	Unchanged
<b>Burnable Poison</b>	Integral fuel burnable absorber (IFBA)	Unchanged
<b>Blankets</b>	Annular pellets in axial blankets	Unchanged
<b>Maximum Enrichment</b>	5 weight percent	Unchanged



Dominion

# Nuclear Design

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
Core Power, MWT (7% increase)	3411	3650
Radial Peaking Factor (3% decrease)	1.70	1.65
Local Peaking Factor	2.60	Unchanged
Most Positive MTC, pcm/degree F < 70% power > 70 % power	+5.0 0.0	Unchanged
Shutdown Margin, %	1.30	Unchanged



Dominion

# Nuclear Design

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
<b>Average Linear Power Density, kW/ft</b>	5.445	5.827
<b>Feed Fuel Batch Size</b>	72-76 out of 193	80-84 out of 193
<b>Burnable Absorber (IFBA) Rods</b>	7400	8200
<b>18 Month Cycle Effective Full Power Days</b>	510	510
<b>18 Month Cycle Burnup, MWD/MTU</b>	19800	21200



**Dominion**

# ***Initial Conditions Overview***

- Currently analyzed for a single nominal temperature at 100% power with no margin for coastdown.**
- SPU analyses performed for a 8°F nominal temperature band at 100% power and 10°F coastdown for added operational flexibility.**
- SPU operation selected at the same nominal temperature as current operation.**
- Modest increase in hot leg temperature will have a small impact on the life of SG tubes and other hot leg Alloy 600 components.**
- Modest decrease in cold leg temperature will have a modest improvement in the life of Reactor Vessel Head penetrations and other cold leg Alloy 600 components.**
- Pressurizer level chosen to balance margins for operation and for design basis transients.**






Dominion

# Initial RCS Conditions

<u>Parameter</u>	<u>Current Design</u>	<u>SPU</u>	<u>SPU Max Tave</u>	<u>SPU Min Tave</u>	<u>SPU Coastdown</u>
<b>NSSS Power, MWt</b>	3425	3666	3666	3666	3666
<b>Reactor power MWt</b>	3411	3650	3650	3650	3650
<b>Pressure, psia</b>	2250	2250	2250	2250	2250
<b>Hot Leg Temp, °F</b>	618.3	617.4	622.6	615.1	605.6
<b>Tave, °F</b>	587.1	587.1	589.5	581.5	571.5
<b>Cold Leg Temp, °F</b>	555.6	556.8	556.0	547.6	537.0
<b>Thermal Design RCS flow, gpm</b>	363,200	NA	363,200	363,200	363,200
<b>Min Meas. Flow, gpm</b>	372,000	398,912 (Best Estimate)	379,200	379,200	379,200



# Pressurizer Level





# ***Safety Analysis Summary***

- All plant specific safety analyses re-analyzed at SPU conditions.**
  
- Significant Safety Analysis Margins Remain After SPU.**
  - 11.7% DNBR margin.
  - 419 °F LB LOCA PCT margin.
  - 1007 °F SB LOCA PCT margin.
  - 3.6 psi containment pressure margin.
  
- Margins Achieved Through Plant Modifications.**
  
- Methodologies Updated To Current Approved Standards.**
  
- SPU has small impact on currently approved AST radiological analyses.**
  
- PRA Results Show SPU Has Minimal Impact On Risk.**



# Safety Analysis Methodologies

<u>Methodology/Codes</u>	<u>Current</u>	<u>SPU</u>
Transient Analysis	LOFTRAN	RETRAN
Thermal & Hydraulic	THINC	VIPRE-W
Rod Ejection Rod withdrawal from Subcritical	TWINKLE FACTRAN	Unchanged
SGTR	LOFTR2	Unchanged
SBLOCA	NOTRUMP	Unchanged
LBLOCA	BART/BASH	ASTRUM



**Dominion**

# ***DNBR Margin Overview***

- Identified as a Margin Management Issue.**
  
- Current DNBR margin used to address Upper Plenum Anomaly.**
  
- Modifications will address Upper Plenum Anomaly and re-establish DNBR margin**
  
- Preliminary analyses used to establish target SPU DNBR margin.**
  
- Final analyses resulted in small change to target SPU DNBR margin.**



Dominion

# DNBR Margin

<u>Parameters</u>	<u>Current</u>	<u>SPU</u>
DNBR Correlation	WRB-2	WRB-2M
Min. Meas. Flow, gpm	372,000	379,200
Radial Peaking Factor	1.70	1.65
Modifications	N/A	<input type="checkbox"/> Elimination of auto rod withdrawal <input type="checkbox"/> Installation of electronic filter on hot leg temperature measurement <input type="checkbox"/> Decrease in power range high neutron flux setpoint from 118% to 116.5%



# DNBR Margin

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
<b>DNBR Correlation</b>	WRB-2	WRB-2M
<b>DNBR Correlation Limit</b>	1.17	1.14
<b>DNBR Design Limit</b>	Determined by statistically combining instrument and correlation uncertainties.	
<b>Safety Analysis Limit</b>	1.39	1.60
<b>Generic Margin, %</b>	Ratio of Design Limit to Safety Analysis Limit	
<b><u>Penalties</u></b>		
<b>Instrumentation Bias and Rod Bow Penalties, %</b>	Penalties for factors not addressed in VIPRE modeling.	
<b>Rod Withdrawal from Power penalty, %</b>	NA	3.2
<b>Total, %</b>	Sum of all penalties, generic and plant specific.	
<b>Available DNBR Margin</b>	Difference between generic margin and penalties	



**Dominion**

# ***DNBR Results***

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
Increase in FW Flow	2.31	1.88
Steam Line Break – Hot Zero Power (W-3 – Limit 1.45)	1.64	1.72
Steam Line Break – Hot Full Power	1.919	2.099
Turbine Trip	2.51	2.10
Loss of Flow	1.757	1.737
Rod Withdrawal from Subcritical Below 1 <sup>st</sup> grid (W-3 - limit 1.3)	1.417 (3 RCPs)	1.306 (2 RCPs)
Rod Withdrawal at Power	1.381	1.55
Inadvertent Opening of PORV	1.584	1.874





**Dominion**

# ***RCS/SG Overpressure Overview***

- SPU has no significant impact on RCS/SG Overpressure events.**
  
- Margins are essentially unchanged.**



# RCS/SG Overpressure Results

	Pressure, psia			
Transient	Current		SPU	
	<u>RCS</u>	<u>SG</u>	<u>RCS</u>	<u>SG</u>
Limit	2750	1320	2750	1320
Turbine Trip	2731	1320	2729	1302
Bank Withdrawal at Power	Bounded by Generic Analysis	1310	Bounded by Generic Analysis	1295



**Dominion**

# ***Pressurizer Overfill Overview***

- Identified as a Margin Management Issue.**
  
- Initial Pressurizer level selected to balance the margin to letdown isolation for routine reactor trips and margin to Pressurizer overfill for design basis transients.**
  
- Current limiting event is the Inadvertent ECCS Actuation at power.**
  
- Hardware modification proposed to significantly reduce the severity of the Pressurizer overfill rate for this event.**
  
- Modification eliminates the Inadvertent ECCS Actuation as the limiting event. The new Pressurizer overfill limiting event changed to the CVCS malfunction event, currently considered bounded and not explicitly analyzed for Millstone Unit 3.**



**Dominion**

# *Pressurizer Overfill*

<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
<b>Pressurizer volume, cu. ft.</b>	1800	Unchanged
<b>Initial Pressurizer Level, %</b>	61.5	64.0
<b>Modifications</b>	NA	ECCS Cold Leg Injection Valve Permissive



**Dominion**

# *Pressurizer Overfill Results*

	<u>Parameter</u>	<u>Current</u>	<u>SPU</u>
<b>Max Pressurizer Volume (cu. ft.)</b>	<b>Limit</b>	1800	1800
	<b>Loss of Feedwater</b>	1061	1731
<b>Time for Pressurizer Safety Valves to Open With Water Relief (minutes)</b>	<b>Inadvertent ECCS When PORVs Are Available</b>	8.7 (water solid)	30.4 (water solid)
	<b>Inadvertent ECCS When No PORVs Are Available</b>	10.5	70.4
	<b>CVCS Malfunction 1 Charging Pump</b>	Not Analyzed	19.6
	<b>CVCS Malfunction 2 Charging Pump</b>		10.4



**Dominion**

# ***Design Basis Overview***

- All design requirements are met at SPU conditions.**
- In general, SPU has a small impact on the results.**
- In general, safety analysis margins are essentially the same with significant margin remaining after SPU.**
- The only significant change is the margin to hot leg saturation for the limiting feedwater line break.**
- Reduction in margin to hot leg saturation due to the increase in decay heat associated with the SPU power level.**
- Due to generic issues unrelated to SPU, initiation of two-path post-LOCA recirculation is reduced from 8-9 hours to 3-5 hours.**



# Design Basis Results

	<u>Event</u>	<u>Limit</u>	<u>Current</u>	<u>SPU</u>
Steam Line Break	Pins in DNB, %	0	0	0
Feedwater Line Break	Min. Margin to Hot Leg Saturation, °F	0	22	2.4
Locked Rotor	Peak Clad Temperature, °F	2700	1969	1718
	Zr-H <sub>2</sub> O reaction, %	16	0.5	0.22
	RCS Pressure, psia	3214.7	2652	2616.6
	Failed Fuel, %	7	< 6	< 7



Dominion

# Rod Ejection Results

<u>Event</u>	<u>Limit</u>	<u>Part of Cycle</u>	<u>HFP Current</u>	<u>HFP SPU</u>	<u>HZP Current</u>	<u>HZP SPU</u>
Max Fuel Stored Energy, cal/g	200	Beginning	181.5	175.8	150.9	152.4
		End	170.6	173.7	148.9	158.3
Fuel Melt at the Hot Spot, %	10	Beginning	8.92	4.66	0.0	0.0
		End	5.71	6.86	0.0	0.0
Max Clad Average Temperature, °F	3000	Beginning	2258	2251	2624	2684
		End	2161	2224	2682	2899
Reacted Zirc, %	16	Beginning	0.90	0.91	2.65	3.01
		End	0.73	0.88	2.82	4.39





# Design Basis Results

	<u>Event</u>	<u>Limit</u>	<u>Current</u>	<u>SPU</u>
<b>SGTR</b>	<b>Margin to Overfill, cu. ft.</b>	0	306	698
<b>SBLOCA</b>	<b>Peak Clad Temperature, °F</b>	2200	1009	1193 (4 inch CLB)
<b>LBLOCA</b>	<b>Peak Clad Temperature, °F</b>	2200	1974	1781 (DEGCLB)
	<b>Local Oxidation, %</b>	17	4.55	3.5
	<b>Core Wide Oxidation, %</b>	1	< 1	0.12



**Dominion**

# ***Radiological Overview***

- Alternate Source Term methodology submitted in 2004 and approved by the NRC in 2006.**
- 2004 submittal included 6.5% power increase in anticipation of SPU.**
- Alternate Source Term methodology resulted in significant increase in available radiological dose margins.**
- For SPU, all events have been re-analyzed to take into account the additional 0.5% power increase.**
- SPU impact on radiological analysis is small.**
- For some events, changes were made to the radiological analysis assumptions to streamline the analyses and eliminate unnecessary restrictions.**



**Dominion**

# ***Radiological Consequences***

<u><b>Parameter</b></u>	<u><b>Current</b></u>	<u><b>SPU</b></u>
<b>Methodology</b>	Alternate Source Term	Unchanged
<b>Modifications</b>	N/A	Automatic initiation of control building pressurized filtration mode upon receipt of CBI signal



# Radiological Results

<u>Event</u>		<u>Limit</u>	<u>Current</u>	<u>SPU</u>
<b>Steam Line Break / Pre-Accident Spike</b>	<b>EAB</b>	25	0.091	0.096
	<b>LPZ</b>	25	0.036	0.044
	<b>Control Room</b>	5.0	1.2	1.6
<b>Steam Line Break / Concurrent Accident Spike</b>	<b>EAB</b>	2.5	0.36	0.40
	<b>LPZ</b>	2.5	0.18	0.22
	<b>Control Room</b>	5.0	3.0	3.6
<b>Locked Rotor</b>	<b>EAB</b>	2.5	2.3	2.4
	<b>LPZ</b>	2.5	0.37	0.44
	<b>Control Room</b>	5.0	3.2	3.9



# *Radiological Results*

<u>Event</u>		<u>Limit</u>	<u>Current</u>	<u>SPU</u>
<b>Rod Ejection / Containment Releases</b>	<b>EAB</b>	6.3	0.87	0.51
	<b>LPZ</b>	6.3	0.48	0.26
	<b>Control Room</b>	5.0	0.83	1.5
<b>Rod Ejection / Secondary Side Releases</b>	<b>EAB</b>	6.3	0.12	0.12
	<b>LPZ</b>	6.3	0.015	0.016
	<b>Control Room</b>	5.0	0.053	0.051



# *Radiological Results*

<u>Event</u>		<u>Limit</u>	<u>Current</u>	<u>SPU</u>
<b>SGTR / Pre-Accident Spike</b>	<b>EAB</b>	25	2.1	2.2
	<b>LPZ</b>	25	0.18	0.20
	<b>Control Room</b>	5	3.0	3.3
<b>SGTR / Concurrent Spike</b>	<b>EAB</b>	2.5	0.9	1.0
	<b>LPZ</b>	2.5	0.09	0.2
	<b>Control Room</b>	5.0	1.3	1.7



# Radiological Results

<u>Event</u>		<u>Limit</u>	<u>Current</u>	<u>SPU</u>
Small Line Break Outside of Containment	EAB	2.5 TEDE	N/A	2.5
		30 Thyroid	21	N/A
		5 WB	1.5	N/A
LOCA	EAB	25	7.5	5.4
	LPZ	25	1.8	1.1
	Control Room	5.0	1.9	3.4



Dominion

# *Radiological Results*

<u>Event</u>		<u>Limit</u>	<u>Current</u>	<u>SPU</u>
<b>Fuel Handling Accident</b>	<b>EAB</b>	6.3	2.4	2.7
	<b>LPZ</b>	6.3	0.13	0.15
	<b>Control Room</b>	5.0	4.9	4.8
<b>Fuel Handling Accident Drop of Non-Fuel Object</b>	<b>Control Room</b>	5.0	Not Analyzed	4.3





**Dominion**

# ***PRA Overview***

- Self assessments and Owners Group Peer Review evaluations have been performed for the Millstone 3 PRA model.**
  
- As part of the SPU project, changes were made to address a number of the findings of these assessments.**
  
- PRA model enhancements are continuing with the goal of full compliance with industry standards.**
  
- No specific impacts were identified as result of SPU. Postulated impacts were assumed to determine SPU sensitivity.**
  
- Results show SPU will have no significant impact on risk.**



**Dominion**

# ***PRA Results Summary***

<u><b>PRA Results</b></u>	<u><b>Current</b></u>	<u><b>SPU</b></u>	<u><b>Increase</b></u>
<b>CDF (/yr)</b>	6.2E-6	6.6E-6	4.0E-7
<b>LERF (/yr)</b>	5.2E-7	5.4E-7	2.0E-8



**Dominion**

# ***PRA Evaluation***

**Initiators.**

- 10% increase in PORV challenges postulated.
- 10% increase in Loss of Offsite postulated due to unforeseen switchyard reliability issues.
- 10% increase in plant transients due to operating experience.

**Success Criteria Validated at SPU Conditions.**

**Human Reliability Analysis.**

- 10% increase in failure postulated for feed-and-bleed.

**SPU Modifications Have No Significant Impact.**



# Summary of PRA Changes

<u>PRA Sensitivity</u>	<u>Change</u>	<u>Current</u>	<u>SPU</u>
<b>Consequential Small LOCA Due To Stuck Open PORV</b>	Increased PORV Challenge Probability by 10%	7.7E-2	8.5E-2
<b>Loss of Offsite Power (LOOP)</b>	Increased Frequency by 10%	8.3E-3/yr	9.1E-3/yr
<b>General Plant Transients</b>	Increased Frequency by 10%	9.6E-1/yr	1.1E+0/yr
<b>Operator Action To Establish Bleed and Feed</b>	Increased Probability by 10%	4.9E-2	5.5E-2

