

Appendix 5.0-3

EVALUATION OF THE EFFECT OF MICRONIZED COAL  
INJECTION ON UNIT 1 ELECTROSTATIC  
PRECIPITATOR PERFORMANCE

**MILLIKEN CLEAN COAL TECHNOLOGY  
DEMONSTRATION PROJECT**

**EVALUATION OF THE EFFECT  
OF MICRONIZED COAL INJECTION  
ON UNIT 1 ELECTROSTATIC PRECIPITATOR  
PERFORMANCE**

**INTERIM REPORT**

Prepared by:

CONSOL Inc.  
Research & Development  
4000 Brownsville Road  
Library, Pennsylvania  
15129-9566

New York State Electric & Gas  
Corporation  
Corporate Drive  
Kirkwood Industrial Park  
P.O. Box 5224  
Binghamton, New York 13902-5224

Principal Investigator  
J. T. Maskew  
M. S. DeVito

Principal Investigator  
B. Marker

Prepared for:

U. S. Department of Energy  
Milliken Clean Coal Technology  
Demonstration Project  
DE-FC22-93PC92642

New York State Electric & Gas  
Corporation  
Corporate Drive  
Kirkwood Industrial Park  
P.O. Box 5224  
Binghamton, New York 13902-5224

Electric Power Research Institute  
3412 Hillview Avenue  
P. O. Box 10412  
Palo Alto, California 94303

Empire State Electric Energy  
Research Corporation  
1515 Broadway, 43<sup>rd</sup> Floor  
New York, New York 10036-5701

New York State Energy Research  
and Development Authority  
Two Rockefeller Plaza  
Albany, New York 12223

June 1999

## TABLE OF CONTENTS

EXECUTIVE SUMMARY .....	1
INTRODUCTION .....	2
DISCUSSION OF THE RESULTS .....	3
CONCLUSIONS .....	5
REFERENCE .....	5

## LIST OF ABBREVIATIONS

°F	Degrees Fahrenheit
°R	Degrees Rankine, Absolute Temperature
“ Hg	Inches of Mercury
0% O <sub>2</sub>	Value Calculated on Oxygen Free Basis
% ISO	Percent Isokinetic Sampling Rate
μm	Micrometers
A	Ampere(s)
ABS	Absolute
acfm	Actual Cubic Feet per Minute
ASTM	American Society for Testing and Materials
Amps	Amperes
An	Area of Sampling Nozzle, ft <sup>2</sup>
Avg	Average
BaCl <sub>2</sub>	Barium Chloride
C-Factor	Pitot Tube Calibration Factor
CO	Carbon Monoxide
CO <sub>2</sub>	Carbon Dioxide
CONSOL R&D	CONSOL Inc., Research & Development
Delta H	Dry Test Meter Orifice Calibration
dscf	Dry Standard Cubic Feet
dscfm	Dry Standard Cubic Feet per Minute
EPA	U. S. Environmental Protection Agency
ESP	Electrostatic Precipitator
F-Factor	Fuel Factor Relating Flue Gas Volume to Coal Composition
fpm	Feet per Minute
fps	Feet per Second
ft	Foot
ft <sup>2</sup>	Square Foot
ft <sup>3</sup>	Cubic Foot
gr	Grains
gr/dscf	Grains per Dry Standard Cubic Foot
H <sub>2</sub> O	Water
H <sub>2</sub> O <sub>2</sub>	Hydrogen Peroxide
Hg	Mercury
h (hr)	Hour
kacfm	Actual Cubic Feet per Minute x 1000
kV	Kilovolts
kWh	Kilowatts per Hour
lb/lb-Mole	Pound(s) per Pound-Mole
lb/hr	Pound(s) per Hour
lb/MM Btu	Pound(s) per Million British Thermal Units of Heat Input
MACS	Miniature Acid Condensation System

## LIST OF ABBREVIATIONS (Cont.)

mA	Milliamperes
min	Minute
mm	Millimeters
min	Minutes
MM Btu	Million British Thermal Units
MWe	Electrical Generation Station Power Rating, Megawatts–Electric
N <sub>2</sub>	Nitrogen Gas
ND	Not Determined
NO <sub>x</sub>	Nitrous Oxides, Stoichiometry Unknown
O <sub>2</sub>	Oxygen Gas
PC	Pulverized Coal
PM	Particulate Matter, Particularly Apparent Solids Contained in Flue Gas
ppmv	Parts per Million, Volumetric Basis
PRSD	Percent Relative Standard Deviation
QA/QC	Quality Assurance / Quality Control
“S” Pitot	Stausscheibe or Reverse Type Pitot Tube
SCA	Specific Collection Area, i.e. ft <sup>2</sup> of ESP Plate Area per ft <sup>3</sup> of Flue Gas
SDEV	Standard Deviation
SO <sub>2</sub>	Sulfur Dioxide
SO <sub>3</sub>	Sulfur Trioxide
SO <sub>x</sub>	Combined Sulfur Dioxide and Sulfur Trioxide
Std Dev	Standard Deviation
Std ft <sup>3</sup>	Cubic Foot at Standard Conditions
Temp	Temperature
TC	Thermocouple
TR	Transformer–Rectifier
tph	Tons per Hour
V–I Curve	Voltage–Current Relationship, Especially in Reference to ESP
Vol	Volume
wt	Weight
Y-Factor	Dry Test Meter Volume Calibration

## EPA METHODS

Method 1	Sample Point Selection
Method 2	Determination of Volumetric Gas Flow
Method 3	Determination of Gas Composition (ORSAT)
Method 4	Determination of Flue Gas Moisture
Method 6	Determination of SO <sub>2</sub> Emissions
Method 17	Determination of Particulate Matter (In–Stack Filter Method)

## EXECUTIVE SUMMARY

The performance of an electrostatic precipitator (ESP) at a 160 MW<sub>e</sub> pulverized coal-fired power plant firing a medium-sulfur, bituminous coal was evaluated in September 1998 during injection of micronized coal to reduce NO<sub>x</sub> formation. No significant effect on the collection efficiency of the ESP was observed, but absolute particulate emissions did increase because of the higher ESP inlet loading. NYSEG had recently rebuilt the ESP to improve its effectiveness. New internals, new computer controlled transformer-rectifier sets, and an additional third field were installed. The plates have a 16-inch spacing. The micronized coal was injected in a reburn mode to reduce NO<sub>x</sub> formation.

Although there were notable differences in the parameters that affect ESP performance between the initial baseline operation and the micronized coal reburn (MCR) case, the performance, as measured by removal efficiency, was similar. These results are specific for the wide-plate spacing retrofit of the Milliken ESP.

## INTRODUCTION

NYSEG extensively modified the Milliken Station to accommodate a wet scrubber, flue gas desulfurization system. Modifications included upgrading the electrostatic precipitators (ESPs) on both units. The internals of the top portion of the ESPs were replaced using a wide plate spacing design by Belco Technologies Corp. New, computer controlled transformer-rectifier (TR) sets were also installed. The physical characteristics of the new ESPs are shown in the following table.

### Precipitator Characteristics

Date Built	1993
Plate Spacing, inches	16
Plate Height, feet	30
Fields	3
Field Depth, feet, each	9
Gas Velocity, fps	3.7
SCA, ft <sup>2</sup> /1,000 acfm gas @ full load	175

As shown, the plate spacing is sixteen inches and the SCA at full load is 175 ft<sup>2</sup> per 1,000 acfm of flue gas. Currently both Milliken Station units have identical ESPs. Each consists of two separate, parallel sections: a south, or "A", ESP and a north, or "B", ESP. Gas flow is evenly split between these sections dividing upstream of the air heaters and rejoining at the scrubber entrance. Each section has an additional divider wall that runs the length of the ESP box. The south and north sections are identical, parallel precipitators with three separate TR sets for each side. The two sections are enclosed in a single box. Design specifications for the ESPs built by Belco Technologies Corp. are tabulated in Appendix B of the Unit 2 Report.<sup>1</sup>

Data were obtained from two sources: a field test of the ESP performance conducted by CONSOL Research & Development and the Milliken Station data logger. Generally, the testing procedures used in this evaluation were the same as those used previously on Unit 2. Details of that testing procedure are published in *Unit 2 Electrostatic Precipitator Performance Test Results Before and After Modification*.<sup>1</sup> For the Unit 1 evaluation, detailed particulate sizes were not determined. This report provides the flue gas conditions and particle statistics as measured at the inlet and exit of both the north and south sides of the Unit 1 ESP. Appendix A contains a brief discussion of the sample port locations and general sampling procedure. It also lists the coal and ash analyses and the data from the performance testing. Gas flow rates, humidities, and temperatures measured during the field test are contained in Appendix B. The Milliken data logger provided general operating conditions and an indication of boiler and ESP operating stability during the field test. Averages of the operating parameters required are listed in Appendix B; selected instantaneous values will be presented later. An evaluation of the Unit 2 performance after modification was used as a baseline for this evaluation. The data for these earlier tests are listed along with the new, Unit 1 data in Appendices A and B.

The ESP field report discusses the test methods and results of duplicate testing of the Unit 1 ESP.<sup>1</sup> Inlet and exit data were obtained during the field testing for several parameters. The following parameters are included in this report:

Total particulate matter (PM)  
Flue gas composition (O<sub>2</sub> and H<sub>2</sub>O)  
Volumetric flue gas flow rate  
Flue gas temperature

Coal and ash samples were collected during the field test. The coal was analyzed as a single composite. The fly ash analyses were averaged.

One day of sampling was employed for the ESP. While the repeat trials were consistent, the performance appears to improve with time. As will be discussed, this may be the result of a system upset during the first test. The operating data for the boiler and individual TR sets are listed in Appendix B.

## DISCUSSION OF THE RESULTS

Three sets of inlet and outlet particle data were collected during the study of the effect of firing micronized coal on the Unit 1 ESP performance. Since a baseline evaluation of this coal on the Unit 1 ESP performance was not conducted, the results are compared to a previous evaluation of the Unit 2 ESP at similar conditions. Since the units are similar, this should not present a problem. During the Unit 2 ESP test periods, samples were collected individually for each side of the ESP, rather than a single sample as in this test program. Tables A-1 and A-2 list the coal and ash analyses for these two evaluations. The ash analyses were not determined for the Unit 1 evaluation.

The Unit 2 data, October 17-20, 1995, represent periods of very stable boiler operation as shown in Figure 1 (middle and bottom plots). Operation was far less stable during the micronized coal tests on Unit 1, September 9, 1998 as shown in the top plot on this same figure. Unlike the previous test periods, NYSEG was unable to baseload the unit.

Similarly, the ESP secondary voltage and current readings are stable for the baseline Unit 2 operation, while those of the Unit 1 TR sets show wide fluctuations. Specifically at 9:00 a.m. on September 9, 1998 during the line-out period, the Unit 1 TR sets indicate a severe disturbance. After that, they are relatively stable. This is shown on Figures 2-7. ESP TR sets A1, A2, B2, B3, and to a lesser extent A3 show wide fluctuations from about 7:30 a.m. to 10:00 a.m. In general, energization levels are about the same for comparable ESP fields during the baseline and MCR tests.

Figure 8 also shows an upset as indicated by the opacity reading during the same period and again shortly after noon. This latter upset is in the midst of the first duct sampling period and probably led to increased in the particulate loadings.



Penetration will be used to evaluate differences in ESP performance. Total particulate concentrations into and out of the ESP were collected as part of the procedure for each trial. These measurements were used to calculate the penetration. Penetration is defined as:

$$\text{Penetration} = 100 - \text{Percent Removal}$$

or

$$\text{Penetration} = 100 - \left[ \frac{\text{Concentration of Solids in Outlet}}{\text{Concentration of Solids in Inlet}} \right] \cdot 100$$

Since ESP performance, as indicated by percent removal, is constant for a given fly ash-size fraction, the penetration should be independent of micronized coal injection assuming that the size consist of the fly ash was the same for both determinations.

Figure 9 shows the penetration values for the baseline Unit 2 tests and the micronized coal test on Unit 1. The averages of the six baseline and of the three micronized tests are illustrated by the thick horizontal lines. While it appears that the penetration levels are higher for the micronized test, this is not a statistically valid conclusion. Statistically, there is no difference between the two averages. The dashed line at ~2.5% penetration shows the ~3 standard deviation error bar for the baseline tests. The Unit 1 average penetration (1.75%) is well below this, the 99% confidence interval limit. If test No. 1 for Unit 1 is omitted, the two averages are identical even though the carbon content of the fly ash is almost twice as high during the Unit 1 test. Thus, burning micronized coal in the boiler did not adversely affect the fly ash penetration for the Milliken ESP.

Particle size information was not requested for the Unit 1 evaluation. As a result, the penetration could not be modeled with sufficient accuracy and no attempt was made to do so. One would expect that the fly ash might have a finer size consist during the micronized coal tests, but the size consist was not measured. The loading was much higher as shown in Table 1. On a grains per dry standard cubic foot basis, the fly ash loading is 30% higher during the micronized coal tests. Even with a constant penetration, the absolute particulate emission increased by 30%.

Similarly the SO<sub>3</sub> levels were probably higher during the Unit 1 tests. Although SO<sub>3</sub> was not measured directly, some inferences can be made based on the SO<sub>2</sub> values, which were determined. Table 2 shows the average SO<sub>2</sub> loadings during the Unit 2 and Unit 1 testing periods. The SO<sub>2</sub> levels were more than 60% greater during the Unit 1 tests. Normally, it would be expected that the SO<sub>3</sub> levels would also be higher.

The higher SO<sub>3</sub> levels might compensate for the expected finer size consist during the Unit 1 evaluation. However, the required data were not obtained and this theory cannot be confirmed.

Additional observations may be made from the test data tables in the Appendices. ESP operating temperatures are similar in both tests. Carbon contents in the ash are higher for the MCR test (Table A-1). The solids loading is higher in the MCR test. When combined, these observations lead to the conclusion that they compensate for one another. The higher SO<sub>2</sub> (and probably SO<sub>3</sub>) levels in the MCR test would lower the resistivity as would the higher carbon content. The lower resistivity would normally increase the removal efficiency. The finer particle size, expected due to the addition of the micronized coal above the normal fuel feed point, would reduce ESP efficiency. Overall it appears these effects compensated for each other resulting in no significant change in penetration.

## CONCLUSIONS


Overfire micronized coal addition does not adversely affect the performance of the Milliken electrostatic precipitator, as measured by removal efficiency or penetration, although the carbon content of the fly ash increases from 2.4% to 3.7%. However, absolute emission increased approximately 30% due to the increase in ESP inlet loadings.

## REFERENCE


1. Maskew, J. T. and DeVito, M. S. *"Milliken Clean Coal Technology Demonstration Project, Unit 2 Electrostatic Precipitator Performance Test Results Before and After Modification, Final Report,"* a report to New York State Electric & Gas Corporation, November 1996.

**Figure 1**  
**Electric Generation of Tested Unit During Test Programs**

**Milliken Unit 1 Generation**



**Milliken Unit 2 Generation**



**Milliken Unit 2 Generation**






Figure 2

Secondary Voltage and Current for TSR-A1 During Test Programs

Milliken Unit 1 ESP – TSR-A1



Milliken Unit 2 ESP – TSR-A1



Milliken Unit 2 ESP – TSR-A1





Figure 3


Secondary Voltage and Current for TSR-A2 During Test Programs

Milliken Unit 1 ESP - TSR-A2




— Sec. Voltage, kV — Sec. Current, mA

Milliken Unit 2 ESP - TSR-A2



— Sec. Voltage, kV — Sec. Current, mA

Milliken Unit 2 ESP - TSR-A2




— Sec. Voltage, kV — Sec. Current, mA

Figure 4


Secondary Voltage and Current for TSR-A3 During Test Programs

Milliken Unit 1 ESP - TSR-A3




— Sec. Voltage, kV — Sec. Current, mA

Milliken Unit 2 ESP - TSR-A3



— Sec. Voltage, kV — Sec. Current, mA


Milliken Unit 2 ESP - TSR-A3




— Sec. Voltage, kV — Sec. Current, mA

Figure 5

Secondary Voltage and Current for TSR-B1 During Test Programs  
Milliken Unit 1 ESP – TSR-B1



Milliken Unit 2 ESP – TSR-B1



Milliken Unit 2 ESP – TSR-B1






Figure 6

Secondary Voltage and Current for TSR-B2 During Test Programs  
Milliken Unit 1 ESP – TSR-B2



Milliken Unit 2 ESP – TSR-B2



Milliken Unit 2 ESP – TSR-B2








Figure 7

Secondary Voltage and Current for TSR-B3 During Test Programs

Milliken Unit 1 ESP -- TSR-B3



Milliken Unit 2 ESP -- TSR-B3



Milliken Unit 2 ESP -- TSR-B3




Figure 8

Selected Emissions During Test Programs







Figure 9

# Measured Particulate Penetrations

NYSEG's Milliken Station



**TABLE 1  
MILLIKEN ESP PERFORMANCE TESTING – AVERAGE PARTICLE LOADINGS**

	Unit 2 North ESP Oct. 1995	Unit 2 South ESP Oct. 1995	Unit 1 ESP Sept. 1998
<b>Particulate Loading</b>			
gr/dscf	2.487	2.327	3.157
lb/hr	3574	3349	9220*
lb/MM Btu	4.818	4.51	6.289
<b>% ISOKINETIC</b>			
minimum	100.59	100.61	98.37
maximum	101.99	105.67	103.77

\* Value represents the total solids flow rate for both sides of the Unit 1 ESP.

**TABLE 2  
AVERAGE SULFUR LEVELS AT THE ESP INLET**

	Unit 2 North ESP Oct. 1995	Unit 2 South ESP Oct. 1995	Unit 1 ESP Sept. 1998
<b>SO<sub>2</sub> Calculations</b>			
lb/dscf	1.79E-4	1.86E-4	2.99E-4
lb/hr	1,797	1,874	6,116*
ppmv @ Duct Conditions	1,128	1,174	1,901
ppmv @ 0% O <sub>2</sub>	1,560	1,635	2,697

\* Value represents the total solids flow rate for both sides of the Unit 1 ESP.

## **APPENDIX A**

### **SAMPLING LOCATIONS**

#### **ESP Inlet**

The two Unit 1 ESP inlet sampling locations are shown in Figure A-1. CONSOL conducted sampling in the inlet ducts immediately upstream of the ESP. Each duct is fitted with a total of five, 6" sampling ports. A sampling scheme using every sampling port was used for the PM sampling. Each port contains three sample points. This scheme resulted in a total of 10 ports and 30 sampling points for the combined ducts. PM sampling was conducted for three minutes at each point which resulted in a total sampling time of 90 min.

#### **ESP Outlet**

Figure A-1 also shows the two Unit 1 ESP outlet sampling locations. The layout for these ducts is a mirror image of that for the inlet locations. Sampling was conducted in the two outlet ducts immediately downstream of the ESP. Each duct is fitted with a total of five, 6" sampling ports. The sampling scheme was identical to that used in the inlet duct with three sample points in each port. This resulted in a total of 10 ports and 30 sampling points. PM sampling was conducted for three minutes at each point which resulted in a total sampling time of 90 min.

#### **As-Fired Coal Samples**

Coal samples were collected from each of the individual gravimetric feeders located upstream of the coal mills. These samples were obtained by manually activating the automatic samplers installed on each feeder. These samples were coordinated with the emission measurements. All of the samples for the day were combined into a single sample for the entire test program.

### **EXPERIMENTAL PROCEDURE**

The emission sampling was conducted using EPA reference techniques, where applicable. In cases where no suitable reference method applied, sampling was conducted using EPA endorsed methodologies or other published, well-documented procedures. A summary of the sampling procedures used in this test program is provided below.

#### **Selection of Sampling Points**

The sampling points at both locations were selected as described in EPA Method 1. While both the ESP inlet and outlet locations failed to meet the optimum location criteria, these were the only location possible.

#### **Volumetric Flow Rate**

Individual point velocities and the duct volumetric flow rates were determined in conjunction with the PM sampling using the procedure outlined in EPA Method 2. The particulate sampling probes were equipped with calibrated type "S" Pitot assemblies complete with thermocouples.

### **Gas Composition (O<sub>2</sub>, CO<sub>2</sub>, and N<sub>2</sub>)**

Flue gas compositions at both locations were determined using a Teledyne Model Max 5 combustion gas analyzer. This instrument uses an electrochemical sensor to determine oxygen and calculates the CO<sub>2</sub> concentration based on fuel chemistry. Nitrogen is determined by difference. The O<sub>2</sub> and CO<sub>2</sub> concentration determined by this instrument were previously confirmed by ORSAT analysis conducted on gas bag samples. The dry molecular weight of the flue gas samples was calculated from these data using the calculations outlined in EPA Method 3.

### **Flue Gas Moisture Content**

Flue gas moisture was determined by measuring the condensate collected in the impinger assemblies for each PM samples. This procedure is outlined in both EPA Method 4 and Method 5.

### **Particulate Matter (PM) Concentrations**

PM sampling was conducted at both the ESP inlet and outlet as outlined in EPA Method 17. This method specifies the use of an in-stack filter at the front end of the sampling probe. Particulate matter is defined as any material collected on the filter at the duct temperature and pressure. Both the ESP inlet and outlet locations had a nominal average temperature of 290°F and an absolute pressure of 28.5" Hg.

A stainless steel filter canister fitted with a high efficiency ceramic filter was used for the inlet locations. This assembly holds up to 50 grams of particulate and is particularly well-suited for high particulate loading applications.

The location of the ESP outlet sampling ports made Method 5 sampling impossible. As a result, an in-stack filter system was used at this location. The high particulate removal efficiency of the ESP results in very low particulate concentrations in the outlet. To enhance the accuracy of our weight measurement of the collected sample, an in-stack 2.5 inch stainless steel filter holder fitted with a 2.5 inch quartz filter was used. These filters have greater weight stability and are also more easily recovered from the filter holder after sampling. Both attributes result in more accurate mass measurements. As with the inlet sampling, the filter temperature is maintained at the flue gas temperature. Particulate matter is defined as any material collected on the sampling media at duct conditions of ~290°F and an absolute pressure of ~28.5" Hg. A schematic illustrating the two particulate trains is shown in Figure A-2.

### **SO<sub>2</sub> Emissions**

SO<sub>2</sub> emissions were measured by replacing the water solution in the PM sampling impingers with a 3% hydrogen peroxide solution. After sampling, the impinger contents were analyzed for SO<sub>2</sub> as described in EPA Method 6. This technique is a BaCl<sub>2</sub> titration to a thordin endpoint. These measurements were completed at the ESP inlet only.

## **QA/QC PROCEDURES**

All of the testing and analysis were completed by trained individuals with experience specific to emission measurements and analysis. The sampling and associated QA/QC procedures were followed as prescribed in the sampling methods. All sampling was conducted under normal, baseload conditions.

Pretest calibrations were performed on the major sampling equipment, and included the Pitot tubes, sampling nozzles, dry test meters, meter orifices, barometer, and temperature readouts. The analytical balance used for the gravimetric filter analyses is checked out twice a year. The accuracy of this balance was checked daily with class "S" standard weights. The calibration data are on file at CONSOL R&D, Library, PA.

All field data were recorded on standard forms and are retained in a file binder at the CONSOL R&D office complex. Two senior test professionals checked all of the field data sheets and calculations.


The coal samples were analyzed in duplicate following standard ASTM methodology. All of the coal analyses fell well within the ASTM criteria for data quality. The analysis of standard reference material used as QC checks is available upon request.

The sampling team was in daily communication with the Unit 1 operators to assure that the unit was operating at the required test conditions.

## **RESULTS**

Analyses for the coal and inlet-fly ash samples collected during the testing are shown in Table A-1. For purposes of comparison, comparable analyses from the baseline test program on Unit 2 in October 1998 are also listed. Results of the PM testing are shown in Table A-2.

## ESP Inlet Sampling Ducts



## ESP Outlet Sampling Ducts


Total Ports Sampled per Duct- 5  
 Total Points Sampled per Duct- 15  
 Cross-Sectional Areas - 238 sq ft

**Figure A-1 - Milliken Unit #1 ESP Sampling Locations**



# EPA Method 17 Particulate Sampling Trains

## (ESP Inlet Sampling with Ceramic Thimble)



## (ESP Outlet Sampling with Quartz-Fiber Filter Disk)




Figure A-2 - Schematics of Particulate Sampling Trains

**Table A-1  
Analytical Data**

**COAL**

Coal Type	← Bituminous →				
Test Dates	10/17- 18/95	9/9/98	Test Dates	10/17- 18/95	9/9/98
Coal analysis, <u>wt% as received</u>	<u>Unit 2</u>	<u>Unit 1</u>	Ash analysis, <u>wt% ash</u>	<u>Unit 2</u>	<u>Unit 1</u>
Carbon	73.68	73.87	Li <sub>2</sub> O	0.02	ND
Hydrogen	4.77	4.73	Na <sub>2</sub> O	0.65	
Nitrogen	1.47	1.38	K <sub>2</sub> O	1.73	
Oxygen (diff.)	5.18	3.67	MgO	0.78	
Sulfur	1.75	2.84	CaO	2.83	
Moisture	6.46	6.09	Fe <sub>2</sub> O <sub>3</sub>	18.26	
Ash	6.69	7.42	Al <sub>2</sub> O <sub>3</sub>	23.47	
HHV	13,096	13,095	SiO <sub>2</sub>	47.44	
		Btu / lb	TiO <sub>2</sub>	0.96	
			P <sub>2</sub> O <sub>5</sub>	0.50	
			SO <sub>3</sub>	2.48	
			Unknown	0.87	

Analysis of the daily composite.

**ASH**

Test Dates	10/17- 18/95	9/9/98	Test Dates	10/17- 18/95	9/9/98
Ash analysis, <u>wt% as received</u>	<u>Unit 2</u>	<u>Unit 1</u>	Ash analysis, <u>wt% ash</u>	<u>Unit 2</u>	<u>Unit 1</u>
Carbon	2.40	3.69	Li <sub>2</sub> O	0.02	ND
Sulfur	0.45	0.57	Na <sub>2</sub> O	0.66	
Moisture	0.46	0.45 (Diff.)	K <sub>2</sub> O	1.70	
Ash	96.87	95.29	MgO	0.75	
			CaO	2.66	
			Fe <sub>2</sub> O <sub>3</sub>	17.37	
			Al <sub>2</sub> O <sub>3</sub>	23.19	
			SiO <sub>2</sub>	47.63	
			TiO <sub>2</sub>	1.07	
			P <sub>2</sub> O <sub>5</sub>	0.49	
			SO <sub>3</sub>	1.13	
			Unknown	3.32	

Average of the analyses of the test samples.

**TABLE A-2  
MILLIKEN UNIT 2 ESP PERFORMANCE TESTING**

North Side ESP

Location	ESP IN	ESP IN	ESP OUT	ESP IN	ESP OUT	ESP IN	ESP OUT	ESP OUT
Test #	#1	#2	#1	#3	#2	#4	#3	#4
Date	10-17-95	10-17-95	10-17-95	10-18-95	10-18-95	10-18-95	10-18-95	10-18-95
Start Time	0935	1430	0935	0839	0835	1250	1220	1520
Stop Time	1150	1640	1225	1030	1142	1440	1520	1720
Sample Type	M-17	M-17	M-17	M-17	M-17	M-17	M-17	M-17
<b>SAMPLING DATA:</b>								
Y factor of dry gas meter	0.973	0.973	0.996	0.973	0.996	0.973	0.996	0.996
Gas Volume - ft <sup>3</sup>	54.81	57.46	85.09	59.58	112.85	60.19	91.13	92.70
Delta H of dry gas meter - inches H <sub>2</sub> O	0.70	0.74	1.19	0.79	1.31	0.80	1.31	1.35
Meter Temperature - °F	105.5	116.8	102.1	128.7	121.7	130.1	117.7	117.4
C Factor of pitot tube	0.761	0.761	0.774	0.761	0.774	0.761	0.774	0.774
Nozzle Diameter - inch	0.246	0.246	0.274	0.246	0.274	0.246	0.274	0.274
A n (area of nozzle) - ft <sup>2</sup>	0.00033	0.00033	0.00041	0.00033	0.00041	0.00033	0.00041	0.00041
Area of Stack - ft <sup>2</sup>	119	119	119	119	119	119	119	119
H <sub>2</sub> O Weight - grams	71.9	70.9	106.6	83.9	139.6	91.5	132.1	125.7
Sample Time - min	108	108	144	108	180	108	144	144
Barometric Pressure - inches Hg	29.70	29.75	29.70	29.54	29.54	29.51	29.51	29.48
Static Pressure - inches H <sub>2</sub> O	-17.0	-16.3	-17.7	-17.3	-17.0	-17.3	-17.0	-17.0
% Oxygen	5.6	5.9	6.0	5.6	6.0	6.0	6.2	6.0
% Carbon Dioxide	13.4	13.1	13.0	13.4	13.0	13.0	12.8	13.0
% N <sub>2</sub> + CO	81.0	81.0	81.0	81.0	81.0	81.0	81.0	81.0
Stack Temp (Dry Bulb) - °F	287	291	273	292	291	296	294	296
"S" sample (avg vel pressure) - inches H <sub>2</sub> O	0.347	0.369	0.335	0.395	0.353	0.399	0.355	0.370
Dust Wt. - grams	6.8036	11.0943	0.0200	7.4694	0.0214	7.4687	0.0135	0.0158
<b>CALCULATED DATA:</b>								
DSCF SAMPLED - ft <sup>3</sup>	49.49	50.96	79.22	51.41	101.01	51.77	82.05	83.43
ABS ST PRES - inches Hg	28.45	28.55	28.40	28.27	28.29	28.24	28.26	28.23
ABS ST TEMP - °R	747	751	733	752	751	756	754	756
H <sub>2</sub> O - % by Vol	6.40	6.15	5.96	7.14	6.11	7.69	7.05	6.63
Water Volume - ft <sup>3</sup>	3.39	3.34	5.02	3.95	6.58	4.31	6.22	5.92
Dry Molecular Weight	30.37	30.33	30.32	30.37	30.32	30.32	30.30	30.32
Wet Molecular Weight	29.58	29.57	29.59	29.49	29.57	29.37	29.43	29.50
% Excess Air	35.5	38.1	39.0	35.5	39.0	39.0	40.8	39.0
Dry Mole Frac.	0.936	0.939	0.940	0.929	0.939	0.923	0.930	0.934
Wet Mole Frac.	0.064	0.061	0.060	0.071	0.061	0.077	0.070	0.066
<b>GAS FLOW DATA:</b>								
Gas Velocity - fps	36.11	37.27	35.77	38.84	37.25	39.23	37.54	38.35
- acfm	257818	266112	255411	277304	265975	280126	268027	273793
- dscfm	162182	167556	164217	170823	166004	170454	164782	168466
Excess Air Free - dscfm	118727	120256	117073	125052	118348	121520	115899	120102
<b>PARTICULATE LOADING:</b>								
- Grains/dscf	2.121	3.359	0.0039	2.242	0.0033	2.226	0.0025	0.0029
- lb/hr	2950	4826	5.5	3283	4.7	3254	3.6	4.2
- lb/MM Btu	4.09	6.61	0.008	4.30	0.006	4.39	0.005	0.006
ESP Collection Efficiency			99.82%		99.85%		99.89%	99.87%
% ISOKINETIC	101.99	101.64	97.47	100.59	98.35	101.49	100.61	100.06
<b>SO<sub>2</sub> CALCULATIONS:</b>								
- lb/dscf	1.74E-04	1.77E-04	1.60E-04	1.79E-04	1.79E-04	1.84E-04	1.84E-04	1.89E-04
- lb/hr	1692	1784	1579	1831	1783	1880	1819	1913
@ Duct Conditions - ppmv	1100	1121	1012	1131	1131	1161	1161	1196
@ 0% O <sub>2</sub> - ppmv	1503	1562	1420	1544	1586	1629	1651	1677
(O <sub>2</sub> Based) - lb/MMBtu	2.35	2.44	2.22	2.40	2.47	2.53	2.57	2.61
<b>COAL ANALYSIS:</b>								
% Carbon	79.02	79.02	79.02	78.64	78.64	78.64	78.64	78.64
% Hydrogen	5.14	5.14	5.14	5.16	5.16	5.16	5.16	5.16
% Nitrogen	1.57	1.57	1.57	1.59	1.59	1.59	1.59	1.59
% Sulfur	1.85	1.85	1.85	1.88	1.88	1.88	1.88	1.88
% Oxygen	5.37	5.37	5.37	5.67	5.67	5.67	5.67	5.67
% Ash	7.05	7.05	7.05	7.06	7.06	7.06	7.06	7.06
% Volatile Matter	38.95	38.95	38.95	39.15	39.15	39.15	39.15	39.15
Btu/lb	14010	14010	14010	14020	14020	14020	14020	14020
Carbon Conversion	99.90%	99.90%	99.90%	99.90%	99.90%	99.90%	99.90%	99.90%
Calculated Feed Rate, lb/hr (dry)	50055	50555	49169	52976	49945	51284	48814	50685
F-Factor	9880	9880	9880	9828	9828	9828	9828	9828
Moisture	7.0%	7.0%	7.0%	6.3%	6.3%	6.3%	6.3%	6.3%
Calculated F-Factor Firing Rate - lb/hr dry	102932	104257	101498	108909	103070	105832	100937	104598
Calculated F-Factor Firing Rate - lb/hr wet	110679	112104	109138	116231	110000	112948	107724	111630
<b>FLY ASH ANALYSIS:</b>								
% Ash	96.69	96.31	---	95.97	---	96.76	---	---
% Carbon	2.49	2.95	---	3.18	---	2.60	---	---
% Sulfur	0.47	0.47	---	0.46	---	0.42	---	---
Calculated MWe Rating	146	148	144	154	146	150	143	148

**TABLE A-3  
MILLIKEN UNIT 2 ESP PERFORMANCE TESTING**

South Side ESP

Location	ESP IN	ESP OUT	ESP IN	ESP OUT	ESP IN	ESP OUT
Test #	#1	#1	#2	#2	#3	#3
Date	10-19-95	10-19-95	10-19-95	10-19-95	10-20-95	10-20-95
Start Time	0835	0839	1350	1150	0825	0815
Stop Time	1025	1150	1550	1500	1025	1030
Sample Type	M-17	M-17	M-17	M-17	M-17	M-17
<b>SAMPLING DATA:</b>						
Y factor of dry gas meter	0.973	0.996	0.973	0.996	0.973	0.996
Gas Volume - ft <sup>3</sup>	54.41	87.56	57.59	88.44	61.14	93.38
Delta H of dry gas meter - inches H <sub>2</sub> O	0.74	1.24	0.79	1.27	0.82	1.37
Meter Temperature - °F	97.7	103.2	97.9	103.4	123.9	125.1
C Factor of pitot tube	0.761	0.774	0.761	0.774	0.761	0.774
Nozzle Diameter - inch	0.246	0.274	0.246	0.274	0.246	0.274
A n (area of nozzle) - ft <sup>2</sup>	0.00033	0.00041	0.00033	0.00041	0.00033	0.00041
Area of Stack - ft <sup>2</sup>	119	119	119	119	119	119
H <sub>2</sub> O Weight - grams	86.6	121.8	95.9	129.7	93.0	134.4
Sample Time - min	108	144	108	144	108	144
Barometric Pressure - inches Hg	29.65	29.65	29.65	29.60	29.46	29.46
Static Pressure - inches H <sub>2</sub> O	-17.5	-16.3	-17.0	-16.3	-17.0	-16.5
% Oxygen	5.7	6.5	5.9	6.3	5.8	6.5
% Carbon Dioxide	13.3	12.5	13.1	12.7	13.2	12.5
% N <sub>2</sub> + CO	81.0	81.0	81.0	81.0	81.0	81.0
Stack Temp (Dry Bulb) - °F	290	286	298	289	300	290
"S" sample (avg vel pressure) - inches H <sub>2</sub> O	0.370	0.349	0.381	0.355	0.410	0.373
Dust Wt. - grams	7.8308	0.0099	7.4413	0.0099	8.1563	0.0092
<b>CALCULATED DATA:</b>						
DSCF SAMPLED - ft <sup>3</sup>	49.74	81.24	52.64	81.89	53.05	82.89
ABS ST PRES - inches Hg	28.36	28.45	28.40	28.40	28.21	28.25
ABS ST TEMP - °R	750	746	758	749	760	750
H <sub>2</sub> O - % by Vol	7.58	6.60	7.90	6.94	7.63	7.10
Water Volume - ft <sup>3</sup>	4.08	5.74	4.52	6.11	4.38	6.33
Dry Molecular Weight - lb/lb-Mole	30.36	30.26	30.33	30.28	30.34	30.26
Wet Molecular Weight - lb/lb-Mole	29.42	29.45	29.36	29.43	29.40	29.39
% Excess Air	36.3	43.7	38.1	41.8	37.2	43.7
Dry Mole Frac.	0.924	0.934	0.921	0.931	0.924	0.929
Wet Mole Frac.	0.076	0.066	0.079	0.069	0.076	0.071
<b>GAS FLOW DATA:</b>						
Gas Velocity - fps	37.52	36.88	38.29	37.32	39.88	38.41
- acfm	267876	263349	273387	266462	284710	274255
- dscfm	165224	165553	166473	165929	172271	169345
Excess Air Free - dscfm	120163	114065	119478	115912	124464	116678
<b>PARTICULATE LOADING:</b>						
- Grains/dscf	2.429	0.002	2.181	0.002	2.372	0.002
- lb/hr	3441	3	3114	3	3504	2
- lb/MM Btu	4.70	0.004	4.28	0.004	4.61	0.003
ESP Collection Efficiency		99.92%		99.91%		99.93%
% ISOKINETIC	100.61	99.14	105.67	99.72	102.92	98.89
<b>SO<sub>2</sub> CALCULATIONS:</b>						
- lb/dscf	1.87E-04	1.83E-04	1.77E-04	1.80E-04	1.94E-04	1.91E-04
- lb/hr	1855	1814	1763	1793	2003	1938
@ Duct Conditions - ppmv	1183	1151	1115	1136	1225	1202
@ 0% O <sub>2</sub> - ppmv	1627	1671	1554	1627	1695	1745
(O <sub>2</sub> Based) - lb/MMBtu	2.53	2.61	2.42	2.54	2.63	2.72
<b>COAL ANALYSIS:</b>						
% Carbon	78.87	78.87	78.87	78.87	78.56	78.56
% Hydrogen	5.04	5.04	5.04	5.04	5.06	5.06
% Nitrogen	1.58	1.58	1.58	1.58	1.57	1.57
% Sulfur	1.86	1.86	1.86	1.86	1.88	1.88
% Oxygen	5.42	5.42	5.42	5.42	5.68	5.68
% Ash	7.23	7.23	7.23	7.23	7.25	7.25
% Volatile Matter	38.50	38.50	38.50	38.50	38.51	38.51
Btu/lb	13990	13990	13990	13990	13984	13984
Carbon Conversion	99.90%	99.90%	99.90%	99.90%	99.90%	99.90%
Calculated Feed Rate, lb/hr (dry)	50709	47754	50324	48628	52581	49040
F-Factor	9850	9850	9850	9850	9818	9818
Moisture	6.40%	6.40%	6.40%	6.40%	6.20%	6.20%
Calculated F-Factor Firing Rate - lb/hr dry	104637	99327	104041	100936	108786	101981
Calculated F-Factor Firing Rate - lb/hr wet	111792	106119	111155	107837	115976	108722
<b>ASH ANALYSIS:</b>						
% Ash	97.55	---	97.29	---	97.55	---
% Carbon	1.61	---	2.11	---	1.88	---
% Sulfur	0.49	---	0.42	---	0.42	---
<b>Calculated MWe Rating</b>	<b>148</b>	<b>140</b>	<b>147</b>	<b>143</b>	<b>154</b>	<b>144</b>

**TABLE A-4  
MILLIKEN UNIT 1 ESP PERFORMANCE TESTING**

Location	ESP IN	ESP OUT	ESP IN	ESP OUT	ESP IN	ESP OUT	3-Test Average	
Test #	#1	#1	#2	#2	#3	#3	ESP IN	ESP OUT
Date	9/9/98	9/9/98	9/9/98	9/9/98	9/9/98	9/9/98		
Start Time	1145	1232	1500	1502	1715	1715		
Stop Time	1400	1420	1650	1645	1910	1900		
Sample Type	M-17	M-17	M-17	M-17	M-17	M-17		
<b>SAMPLING DATA:</b>								
Y factor of dry gas meter	1.015	1.050	1.015	1.050	1.015	1.050		
Gas Volume - ft <sup>3</sup>	47.75	52.86	45.35	54.32	46.45	53.69		
Delta H of dry gas meter - inches H <sub>2</sub> O	1.01	1.24	1.01	1.29	0.92	1.19		
Meter Temperature - °F	97.8	99.8	96.9	104.6	102.2	103.2		
C Factor of pitot tube	0.796	0.797	0.796	0.797	0.796	0.797		
Nozzle Diameter - inch	0.251	0.269	0.250	0.270	0.251	0.269		
A <sub>n</sub> (area of nozzle) - ft <sup>2</sup>	0.00034	0.00039	0.00034	0.00040	0.00034	0.00039		
Area of Stack - ft <sup>2</sup>	238	238	238	238	238	238		
H <sub>2</sub> O Weight - grams	75.6	75.0	66.6	80.6	72.1	82.3		
Sample Time - min	90	90	90	90	90	90		
Barometric Pressure - inches Hg	29.18	29.18	29.18	29.18	29.18	29.18		
Static Pressure - inches H <sub>2</sub> O	-17.0	-17.2	-16.2	-16.3	-16.8	-16.8		
% Oxygen	6.3	7.2	6.2	7.3	6.0	7.3	6.2	7.3
% Carbon Dioxide	13.8	12.9	13.9	12.8	14.1	12.8	13.9	12.8
% N <sub>2</sub> + CO	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9
Stack Temp (Dry Bulb) - °F	296	285	297	290	300	292	298	289
"S" sample (avg vel pressure) - inches H <sub>2</sub> O	0.384	0.362	0.356	0.363	0.360	0.347		
Dust Wt. - grams	9.6173	0.0348	8.2520	0.0174	8.9063	0.0071		
<b>CALCULATED DATA:</b>								
DSCF SAMPLED - ft <sup>3</sup>	44.84	51.19	42.65	52.17	43.27	51.68		
ABS ST PRES - inches Hg	27.93	27.92	27.99	27.98	27.94	27.94		
ABS ST TEMP - °R	756	745	757	750	750	752		
H <sub>2</sub> O - % by Vol	7.36	6.45	6.85	6.78	7.28	6.98	7.2	6.7
Water Volume - ft <sup>3</sup>	3.56	3.53	3.14	3.80	3.40	3.88		
Dry Molecular Weight - lb/lb-Mole	30.46	30.35	30.47	30.34	30.50	30.34	30.48	30.34
Wet Molecular Weight - lb/lb-Mole	29.54	29.55	29.62	29.50	29.59	29.48	29.58	29.51
% Excess Air	42.6	51.8	41.6	52.9	39.8	52.9	41	53
Dry Mole Frac.	0.926	0.935	0.931	0.932	0.927	0.930		
Wet Mole Frac.	0.074	0.065	0.069	0.068	0.073	0.070		
<b>GAS FLOW DATA:</b>								
Gas Velocity - fps	40.36	38.96	38.80	39.13	39.15	38.35	39.44	38.81
- acfm	576392	556288	554067	558751	559007	547608	563155	554216
- dscfm	348138	344096	336747	342920	336326	334050	340404	340355
Excess Air Free - dscfm	243197	225556	236851	223144	239773	217372	239940	222024
<b>PARTICULATE LOADING:</b>								
- Grains/dscf	3.310	0.0105	2.985	0.0051	3.176	0.0021	3.157	0.006
- lb/hr	9879	30.9	8620	15.1	9160	6.1	9219.5	17.4
- lb/MM Btu	6.65	0.022	5.96	0.011	6.26	0.005	6.289	0.013
ESP Collection Efficiency by Concentration		99.68%		99.83%		99.93%		99.81%
ESP Collection Efficiency by Mass Loading		99.69%		99.82%		99.93%		99.81%
% ISOKINETIC	99.23	99.80	98.37	101.29	99.11	103.77		
<b>SO<sub>2</sub> CALCULATIONS:</b>								
- lb/dscf	2.96E-04		3.02E-04		3.00E-04		2.99E-04	
- lb/hr	6193		6100		6055		6116	
@ Duct Conditions - ppmv	1881		1917		1906		1901	
@ 0% O <sub>2</sub> - ppmv	2693		2725		2674		2697	
(O <sub>2</sub> Based) - lb/MMBtu	4.17		4.22		4.14		4.17	
<b>COAL ANALYSIS:</b>								
% Carbon	77.63	77.63	77.63	77.63	77.63	77.63	77.63	
% Hydrogen	5.12	5.12	5.12	5.12	5.12	5.12	5.12	
% Nitrogen	1.45	1.45	1.45	1.45	1.45	1.45	1.45	
% Sulfur	2.98	2.98	2.98	2.98	2.98	2.98	2.98	
% Oxygen	5.02	5.02	5.02	5.02	5.02	5.02	5.02	
% Ash	7.80	7.80	7.80	7.80	7.80	7.80	7.80	
% Volatile Matter	39.15	39.15	39.15	39.15	39.15	39.15	39.15	
Btu/lb	13944	13944	13944	13944	13944	13944	13944.00	
F-Factor	9825	9825	9825	9825	9825	9825	9825	
Moisture	1.3%	1.3%	1.3%	1.3%	1.3%	1.3%	1.3%	
Calculated F-Factor Firing Rate - lb/hr dry	106507	98781	103728	97725	105008	95197	105081	
Calculated F-Factor Firing Rate - lb/hr wet	107921	100093	105105	99022	106402	96461	106476	
<b>FLY ASH ANALYSIS:</b>								
% Ash	95.41		95.37		95.1		95.29	
% Carbon	3.51		3.79		3.78		3.69	
% Sulfur	0.63		0.54		0.53		0.57	

## APPENDIX B

### Operating Data Collected by the Plant Data Logger

#### BOILER / OPACITY DATA

Conditions at time of test.

Test 1

Date: September 9, 1998

Time: 1145 - 1420

ESP: Unit 1

Generator gross load 154.5 MW  
Coal rate 55.7 ton / h  
Heat rate 10,652 Btu / kWh

---

#### Electrical Data

TR Set # A-1  
Primary voltage 243 V  
Primary current 19.1 A  
Secondary voltage 64.7 kV  
Secondary current 122 mA

Sparking: Yes  No   
If Yes, Spark rate 0 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # A-2  
Primary voltage 357 V  
Primary current 127.2 A  
Secondary voltage 64.7 kV  
Secondary current 462 mA

Sparking: Yes  No   
If Yes, Spark rate 0.8 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # A-3  
Primary voltage 405 V  
Primary current 117.7 A  
Secondary voltage 64.7 kV  
Secondary current 640 mA

Sparking: Yes  No   
If Yes, Spark rate 0.5 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # B-1  
Primary voltage 267 V  
Primary current 29.5 A  
Secondary voltage 64.8 kV  
Secondary current 180 mA

Sparking: Yes  No   
If Yes, Spark rate 0.8 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

TR Set # B-2  
Primary voltage 360 V  
Primary current 85.7 A  
Secondary voltage 64.8 kV  
Secondary current 473 mA

Sparking: Yes  No   
If Yes, Spark rate 0.1 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

TR Set # B-3  
Primary voltage 423 V  
Primary current 105.9 A  
Secondary voltage 64.8 kV  
Secondary current 594 mA

Sparking: Yes  No   
If Yes, Spark rate 0.1 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

Test Conditions

Inlet gas flow 576.392\* acfm  
348.138\* dscfm  
Inlet mass loading 3.31\* gr / dscf  
Outlet gas flow 556.288\* acfm  
344.096\* dscfm  
Outlet mass loading 0.0105\* gr / dscf

Water, Inlet 7.4\* %  
Oxygen, Inlet 6.3\* %, dry  
Pressure, Inlet 27.93\* inches of Hg  
Efficiency 99.69\* %

Boiler / Opacity Test Data

Inlet ESP temp. 296\* °F  
Average temp. leaving  
Air heater 311 °F  
Exit ESP temp. 285\* °F

Average opacity 3.04 %  
Maximum opacity 5.19 %  
Soot blowing: Operating  Off

## Test 2

Date: September 9, 1998  
Time: 1500 - 1650  
ESP: Unit 1

Generator gross load 156.6 MW  
Coal rate 56.7 ton / h  
Heat rate 10,691 Btu / kWh

---

### Electrical Data

TR Set # A-1

Primary voltage 243 V  
Primary current 19.4 A  
Secondary voltage 64.7 kV  
Secondary current 123 mA

Sparking: Yes  No   
If Yes, Spark rate 0 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # A-2

Primary voltage 356 V  
Primary current 127.3 A  
Secondary voltage 64.6 kV  
Secondary current 461 mA

Sparking: Yes  No   
If Yes, Spark rate 1.0 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # A-3

Primary voltage 405 V  
Primary current 116.9 A  
Secondary voltage 64.7 kV  
Secondary current 636 mA

Sparking: Yes  No   
If Yes, Spark rate 0.9 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---



TR Set # B-1

Primary voltage 268 V  
 Primary current 30.5 A  
 Secondary voltage 64.7 kV  
 Secondary current 182 mA

Sparking: Yes  No   
 If Yes, Spark rate 0.6 sparks / min  
 Arcing: Yes  No   
 Back corona: Yes  No   
 TR status: On  Off  Tripped

TR Set # B-2

Primary voltage 358 V  
 Primary current 85.5 A  
 Secondary voltage 64.6 kV  
 Secondary current 471 mA

Sparking: Yes  No   
 If Yes, Spark rate 1.1 sparks / min  
 Arcing: Yes  No   
 Back corona: Yes  No   
 TR status: On  Off  Tripped

TR Set # B-3

Primary voltage 422 V  
 Primary current 104.7 A  
 Secondary voltage 64.8 kV  
 Secondary current 588 mA

Sparking: Yes  No   
 If Yes, Spark rate 0.02 sparks / min  
 Arcing: Yes  No   
 Back corona: Yes  No   
 TR status: On  Off  Tripped

Test Conditions

Inlet gas flow 554.067\* acfm  
366.747\* dscfm  
 Inlet mass loading 2.98\* gr / dscf  
 Outlet gas flow 558.751\* acfm  
342.920\* dscfm  
 Outlet mass loading 0.0051\* gr / dscf

Water, Inlet 6.9\* %  
 Oxygen, Inlet 6.2\* %, dry  
 Pressure, Inlet 27.99\* inches of Hg  
 Efficiency 99.82\* %

Boiler / Opacity Test Data

Inlet ESP temp. 297 \* °F  
 Average temp. leaving 312 °F  
 Air heater  
 Exit ESP temp. 290\* °F

Average opacity 2.11 %  
 Maximum opacity 2.67 %  
 Soot blowing: Operating  Off

### Test 3

Date: September 9, 1998  
Time: 1715 - 1910  
ESP: Unit 1

Generator gross load 156.0 MW  
Coal rate 56.2 ton / h  
Heat rate 10,643 Btu / kWh

---

#### Electrical Data

TR Set # A-1  
Primary voltage 240 V  
Primary current 17.9 A  
Secondary voltage 64.8 kV  
Secondary current 118 mA

Sparking: Yes  No   
If Yes, Spark rate 0 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # A-2  
Primary voltage 354 V  
Primary current 125.8 A  
Secondary voltage 64.5 kV  
Secondary current 457 mA

Sparking: Yes  No   
If Yes, Spark rate 1.5 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # A-3  
Primary voltage 405 V  
Primary current 117.6 A  
Secondary voltage 64.6 kV  
Secondary current 640 mA

Sparking: Yes  No   
If Yes, Spark rate 1.1 sparks / min  
Arcing: Yes  No   
Back corona: Yes  No   
TR status: On  Off  Tripped

---

TR Set # B-1

Primary voltage 267 V  
 Primary current 29.7 A  
 Secondary voltage 64.8 kV  
 Secondary current 180 mA

Sparking: Yes  No   
 If Yes, Spark rate 0.5 sparks / min  
 Arcing: Yes  No   
 Back corona: Yes  No   
 TR status: On  Off  Tripped

TR Set # B-2

Primary voltage 358 V  
 Primary current 86.0 A  
 Secondary voltage 64.5 kV  
 Secondary current 474 mA

Sparking: Yes  No   
 If Yes, Spark rate 1.7 sparks / min  
 Arcing: Yes  No   
 Back corona: Yes  No   
 TR status: On  Off  Tripped

TR Set # B-3

Primary voltage 424 V  
 Primary current 106.1 A  
 Secondary voltage 64.8 kV  
 Secondary current 597 mA

Sparking: Yes  No   
 If Yes, Spark rate 0.1 sparks / min  
 Arcing: Yes  No   
 Back corona: Yes  No   
 TR status: On  Off  Tripped

Test Conditions

Inlet gas flow 559,007\* acfm  
366,326\* dscfm  
 Inlet mass loading 3.18\* gr / dscf  
 Outlet gas flow 547,608\* acfm  
334,050\* dscfm  
 Outlet mass loading 0.0021\* gr / dscf

Water, Inlet 7.3\* %  
 Oxygen, Inlet 6.0\* %, dry  
 Pressure, Inlet 27.94\* inches of Hg  
 Efficiency 99.93\* %

Boiler / Opacity Test Data

Inlet ESP temp. 300\* °F  
 Average temp. leaving 312 °F  
 Air heater  
 Exit ESP temp. 292\* °F

Average opacity 2.09 %  
 Maximum opacity 2.11 %  
 Soot blowing: Operating  Off