

**FILE COPY**

Circulate \_\_\_\_\_

File No. 30.910A

**INTEGRATED DRY NO<sub>x</sub>/SO<sub>2</sub> EMISSIONS CONTROL SYSTEM  
ENVIRONMENTAL MONITORING REPORT**

**Calcium-Based Dry Sorbent Injection System Test Period:**

**April 30, 1993 through November 2, 1993**

**Calcium DSI Air Toxics Test October 19-20, 1993**

**Dioxins/Furans Air Toxics Text October 11-13, 1993**

**DOE Contract Number DE-FC22-91PC90550**

**Prepared by**

**Terry Hunt  
Public Service Company of Colorado  
Denver, CO**

**Thurston J. Hanley  
Martinez & Hromada Associates  
Denver, CO**

**Draft: January 18, 1996**

**Final: April 8, 1997**

## CONTENTS

<b>I.</b>	<b>Project Status</b> .....	1
A.	Test Summary .....	1
B.	Summary of Environmental Monitoring .....	1
<b>II.</b>	<b>Summary of Compliance Monitoring Results</b> .....	3
A.	Sulfur Dioxide Monitoring .....	3
B.	Opacity Monitoring .....	3
C.	Aqueous Stream Monitoring .....	4
<b>III.</b>	<b>Summary of Supplemental Monitoring Results</b> .....	5
A.	Gaseous Species Monitoring .....	5
B.	Particulate Monitoring .....	5
C.	Aqueous Stream Monitoring .....	5
D.	Solids Stream Monitoring .....	6
<b>IV.</b>	<b>Summary of Air Toxics Monitoring Results</b> .....	10
A.	Uncertainty Analysis .....	15
B.	Treatment of Non-Detectable Measurements .....	17
C.	Treatment of Blank Values .....	18
D.	Gaseous Species Monitoring .....	20
	Trace Metals .....	20
	Anions .....	24
	Baseline Dioxin and Furan Emissions .....	26
	FFDC Efficiency .....	28
E.	Solids Stream Monitoring .....	30
	Calcium-Based Sorbent Analysis .....	30
	Coal Analysis .....	31
	Fly Ash .....	34
	Bottom Ash .....	35
F.	Mass Balance Results .....	37
G.	Summary of Test Results .....	40

**Appendix A: State Emission Reports**

**Appendix B: Aqueous Stream Compliance Data**

**Appendix C: Calcium-Based DSI System Data Summary**

## TABLES

Table 1:	Arapahoe 4 SO <sub>2</sub> Emissions	3
Table 2:	Water Use by Flue-Gas Humidification System	6
Table 3:	Proximate Analysis for Baseline Air Toxics Testing	7
Table 4:	Ultimate Analysis for Baseline Air Toxics Testing	7
Table 5:	Proximate Analysis for Calcium-Based DSI System Air Toxics Testing	8
Table 6:	Ultimate Analysis for Calcium-Based DSI System Air Toxics Testing	8
Table 7:	Target Compounds for Calcium-Based DSI System	10
Table 8:	Target Compounds	11
Table 9:	Laboratories for Air Toxics Analyses	12
Table 10:	Stream Mass Flow Data	13
Table 11:	Average Operating Conditions and Continuous Emissions Data	15
Table 12:	Test Methods Different from EMP	16
Table 13:	Summary of Bias Values Used for Uncertainty Calculations	17
Table 14:	Trace Metal Emission Results for Calcium-Based DSI System	21
Table 15:	Comparison of Alternative Digestion Methods and INAA	22
Table 16:	Comparison of Fuel vs FFDC Inlet Measurements	23
Table 17:	Acid-Forming Anion Emission Results for Calcium-Based DSI System	25
Table 18:	Baseline Polychlorinated Dibenzo-P-Dioxin (PCDD) and Polychlorinated Dibenzofuran (PCDF) Emissions	27
Table 19:	FFDC Removal Efficiency (Calcium-Based DSI Test Period)	29
Table 20:	Air Toxics Analysis of Hydrated Lime	30
Table 21:	Trace Metals Analysis of Coal	33
Table 22:	Air Toxics Analysis of Ash for Calcium-Based DSI	36
Table 23:	Mass Balance Results for Calcium-Based DSI Test Period	39
Table 24:	Summary of Fuel Input, FFDC Inlet, and FFDC Outlet Levels	41
Table 25:	Distribution of Trace Metals Across Output Streams	42
Table 26:	Summary of Opacity Violations	Appendix A-1

## FIGURES

Figure 1: Sampling Locations .....	14
------------------------------------	----

## ABBREVIATIONS

ASME	American Society of Mechanical Engineers
ASTM	American Society of Testing and Materials
CARB	California Air Resources Board
CDH	Colorado Department of Health
CEM	Continuous emissions monitor
CO	Carbon monoxide
CO <sub>2</sub>	Carbon dioxide
CVAA	Cold vapor atomic absorptions
EMP	Environmental Monitoring Plan
EPA	Environmental Protection Agency
FC/VM	Fixed carbon/volatile matter
FFDC	Fabric filter dust collector
GC/MS	Gas chromatography/mass spectroscopy
GFAA	Graphite furnace atomic absorption
HF	Hydrofluoric acid
HHV	Higher heating value
IC	Ion chromatography
ICP	Inductively coupled plasma
ICP-AES	Inductively coupled plasma-atomic emission spectroscopy
INAA	Instrumental Neutron Activation Analysis
ISE	Ion specific electrode
MS	Mass spectrometry
NO	Nitric oxide
NO <sub>x</sub>	Oxides of nitrogen
O <sub>2</sub>	Molecular oxygen
PAH	Polycyclic aromatic hydrocarbons
PCDD	Polychlorinated dibenzo-p-dioxins
PCDF	Polychlorinated dibenzofurans

PID	Photoionization detector
PM <sub>10</sub>	Particulate matter less than 10 microns
PSCC	Public Service Company of Colorado
PTC	Power test code
QA	Quality assurance
SO <sub>2</sub>	Sulfur dioxide
SO <sub>3</sub>	Sulfur trioxide
VOC	Volatile organic compounds

### UNITS

Btu	British Thermal Unit
°F	degree Fahrenheit
DSCFM	dry standard cubic feet per minute
DSCF	dry standard cubic feet, 68°F and 1 atm
gpm	gallons per minute
gr	grains
kg	kilogram
lb	pound (mass)
lb/10 <sup>12</sup> Btu	pound per trillion British thermal units
lb/MMBtu	pounds per million British thermal units
m <sup>3</sup>	cubic meter
mg	milligram (10 <sup>-3</sup> gram)
µg	microgram (10 <sup>-6</sup> gram)
µg/Nm <sup>3</sup>	microgram per normal cubic meter (0°F, 1 atm)
MMBtu	Million Btu
MWe	Megawatt-electric
ng	nanogram (10 <sup>-9</sup> gram)
ng/Nm <sup>3</sup>	nanogram per normal cubic meter (0°F, 1 atm)
pCi	pico-Curie
ppm	parts per million
ppmc	parts per million corrected to 3% O <sub>2</sub> , dry
ppmd	parts per million, dry
ppmw	parts per million by weight

## **I. Project Status**

### **A. Test Summary**

The dry sorbent injection (DSI) system was tested with calcium-based sorbents from April 30, 1993 through November 2, 1993 at Public Service Company of Colorado's (PSCC) Arapahoe Unit 4 Steam Electric Generating Station.

The test consisted of two phases: (1) Optimization of the operating parameters and (2) Parametric tests on the optimized system to assess the performance as various boiler operating parameters were modified. Nearly 200 different tests were completed over this period. Calcium was injected both into the boiler at a temperature range of approximately 1000°F and into the inlet to the fabric filter dust collector (FFDC). Testing was conducted both with and without flue-gas humidification. After these two phases were completed, a series of air toxics tests were conducted. These tests measured air toxics during the injection of calcium-based reagents before the FFDC and during humidification. In addition, baseline air toxics tests for dioxins and furans were repeated.

### **B. Summary of Environmental Monitoring**

The purpose of this report is to document the environmental monitoring that was completed as part of the calcium injection test series. Monitoring was completed according to the *Environmental Monitoring Plan for the Integrated Dry NO<sub>x</sub>/SO<sub>2</sub> Emissions Control System*, dated February 1992 and its addendum dated July 1993.

Generally, the testing went well and there were no significant environmental events during the test period and there were no excursions of any compliance requirements during testing. A significant amount of supplemental monitoring was completed to determine the emissions while operating and testing the DSI system with calcium-based reagents. The test series report *Calcium-Based Dry*

*Sorbent Injection*, dated December 1994 contains a complete discussion of the calcium test program.

Additional supplemental monitoring to collect data for 21 potential air toxics was completed during the calcium injection testing. Sampling for this testing was conducted October 19 and 20, 1994. Additional baseline testing to determine a number of dioxins and furans was also conducted without the calcium injection system in operation. This baseline sampling was conducted October 11, 12, and 13, 1993.

## II. Summary of Compliance Monitoring Results

### A. Sulfur Dioxide Monitoring

Regulation 1, VI.A.3.a.(ii) of the State of Colorado states that the maximum emission of sulfur dioxide (SO<sub>2</sub>) is 1.2 lb/MMBtu. An Altech 180 continuous emission monitoring (CEM) system was installed at Arapahoe Unit 4 in June 1992. This monitor was used to collect emissions data during this test program. However, the monitor was not used for compliance monitoring during this test series.

SO<sub>2</sub> emissions for compliance monitoring were calculated from the amount of sulfur in the fuel. Table 1

Quarter (1993)	Avg. SO <sub>2</sub> Content (lb/MMBtu)	SO <sub>2</sub> Violations
2nd	0.844	None
3rd	0.861	None
4th	0.850	None

summarizes this data.

Table 1: Arapahoe 4 SO<sub>2</sub> Emissions

Emissions calculated to

be above the regulatory limit of 1.2 lb/MMBtu are provided to the state quarterly. The test period covered most of the second, all of the third, and part of the fourth quarters of 1993. Appendix A contains copies of the reports documenting this information to the Colorado Department of Health (CDH).

### B. Opacity Monitoring

According to Regulation 1, II.A.1., PSCC must report to the CDH anytime Arapahoe Unit 4 exceeds 20% opacity due to any air pollutant. The unit uses a Lear Siegler RM41 continuous opacity monitor to measure and record opacity.

During the test period, the average daily opacity ranged from 0.7 to 6.8%.

Arapahoe Unit 4 had thirty one 6-minute opacity excursions exceeding the 20%



opacity limit for a 99.93% compliance percentage over the test period. None of these excursions occurred, however, while testing the calcium-based DSI system and all were related to the startup and shutdown of the unit. Appendix A provides copies of the reports documenting this information to the CDH and the compliance rate calculation.

### **C. Aqueous Stream Monitoring**

Colorado Wastewater Discharge Permit No. CO-0001091 requires that Arapahoe Unit 4 must sample and report on various aqueous discharges. Appendix B contains copies of the reports provided to the CDH during the combustion test period for April through November of 1993. Note that there were no violations and that the station was in compliance 100.0% of the test period.

### **III. Summary of Supplemental Monitoring Results**

#### **A. Gaseous Species Monitoring**

Significant gas monitoring was done to determine the environmental effects of the Integrated Dry NO<sub>x</sub>/SO<sub>2</sub> Emissions Control System and, specifically, the DSI system using calcium-based sorbents. Appendix C contains a summary of all test data obtained during the calcium-based DSI testing conducted April 30 through November 2, 1993. The test summary contains average emissions by test for the following gases:

- Nitric oxide (NO)
- Carbon monoxide (CO)
- Carbon dioxide (CO<sub>2</sub>)
- Oxygen (O<sub>2</sub>)
- Sulfur dioxide (SO<sub>2</sub>)

#### **B. Particulate Monitoring**

Three particulate tests were conducted during the air toxics testing. Environmental Protection Agency (EPA) Method 5 was used to conduct these tests at the FFDC inlet and outlet. The inlet particulate levels ranged from 2.437 to 1.873 gr/DSCF and averaged 2.207 gr/DSCF. The outlet particulate levels were 0.0019, 0.0007, and 0.0006 gr/DSCF and averaged 0.0012 gr/DSCF. The high outlet value (0.0019 gr/DSCF) could be the result of rust and other materials not associated with combustion. The efficiency of the FFDC averaged 99.952%.

### C. Aqueous Stream Monitoring

No supplemental monitoring of aqueous streams was planned or required during the calcium-based DSI test program but, the consumptive water use of the flue-gas humidification system and urea injection system was recorded for informational purposes. Table 2 shows water use by month.

### D. Solids Stream Monitoring

#### Coal

Coal sampling and analysis was conducted during the air toxics sampling period. Two sets of coal samples were obtained. The first set of samples were obtained during baseline testing for dioxins and furans. The second set of samples were obtained during the air toxics testing with the calcium-based DSI system.

Month	Gallons	Acre -feet
May 1993	254,185	0.78
June 1993	490,849	1.51
July 1993	339,858	1.04
August 1993	0	0
September 1993	90,503	0.28
October 1993	260,359	0.80
November 1993	0	0
Total	1,435,754	4.41

Table 2: Water Use by Flue-Gas Humidification System

Table 3 lists the proximate analysis and Table 4 lists the ultimate analysis of the coal burned during the repeat of the baseline dioxin and furan sampling. Originally dioxin and furan sampling was completed under baseline conditions during the selective non-catalytic reduction air toxics test period completed March 8, 1993 through March 11, 1993. Due to contamination of native isomers in the method blanks, samples, and archived resin a valid measurement could not be obtained and the testing was repeated during the current air toxics test period. Except for the percent ash values which are slightly higher than normal, the results show good agreement and are typical for the bituminous coal fired at Arapahoe Unit 4.

Property	Test 1		Test 2		Test 3		Average	
	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis
%Moisture	10.34	--	10.10	--	10.22	--	10.22	--
%Ash	9.62	10.73	11.58	12.88	11.78	13.12	10.99	12.24
%Volatile	34.46	38.43	33.87	37.68	33.60	37.42	33.98	37.84
%Fixed Carbon	45.58	50.84	44.45	49.44	44.40	49.46	44.81	49.91
Total (%)	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
Btu/lb	11,197	12,488	10,962	12,193	10,933	12,177	11,051	11,030
FC/VM	1.32	1.32	1.31	1.31	1.32	1.32	1.32	1.32
lb SO <sub>2</sub> /MMBTu @ (100%)	0.79		0.86		0.84		0.83	

**Table 3: Proximate Analysis for Baseline Air Toxics Testing**

Property	Test 1		Test 2		Test 3		Average	
	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis
%Moisture	10.34	--	10.10	--	10.22	--	10.22	--
%Carbon	64.42	71.85	62.77	69.82	61.97	69.02	63.05	70.23
%Hydrogen	4.43	4.94	4.35	4.84	4.51	5.02	4.43	4.93
%Nitrogen	1.57	1.75	1.51	1.68	1.56	1.74	1.55	1.72
%Sulfur	0.44	0.49	0.47	0.52	0.46	0.51	0.46	0.51
%Ash	9.62	10.73	11.58	12.88	11.78	13.12	10.99	12.24
%Oxygen (diff)	9.18	10.24	9.22	10.26	9.50	10.59	9.30	10.36
Total (%)	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

**Table 4: Ultimate Analysis for Baseline Air Toxics Testing**

Table 5 lists the proximate analysis and Table 6 lists the ultimate analysis of the coal burned during the air toxics testing during the calcium-based DSI system. Generally, Arapahoe Unit 4 burns Colorado coal from the Yampa mine, but PSCC occasionally purchases spot market Colorado coal from the Edna mine.

The higher sulfur levels in the analyses indicate that Arapahoe Unit 4 fired its alternate coal both days of air toxics testing for the calcium-based DSI system.

Property	Test 1		Test 2		Test 3		Average	
	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis
% Moisture	11.33	--	12.15	--	11.60	--	11.69	--
% Ash	8.49	9.58	7.96	9.06	7.80	8.82	8.08	9.15
% Volatile	34.92	39.38	34.96	39.79	35.01	39.60	34.96	39.59
% Fixed Carbon	45.26	51.04	44.93	51.15	45.59	51.58	45.26	51.26
Total	100.00	100.00	100.00	100.00	100.00	100.00	99.99	100.00
FC/VM	1.30	1.30	1.29	1.29	1.30	1.30	1.30	1.30
Btu/lb	11,034	12,444	10,959	12,475	11,076	12,529	11,023	12,482
lb SO <sub>2</sub> / MMBtu	1.05		1.09		1.03		1.06	

**Table 5: Proximate Analysis for Calcium-Based DSI System Air Toxics Testing**

Property	Test 1		Test 2		Test 3		Average	
	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis	As Received	Dry Basis
% Moisture	11.33	--	12.15	--	11.60	--	11.69	--
% Carbon	62.71	70.72	62.29	70.91	63.14	71.42	62.71	70.95
% Hydrogen	4.38	4.94	4.30	4.90	4.36	4.93	4.35	4.92
% Nitrogen	1.59	1.79	1.61	1.83	1.64	1.85	1.61	1.82
% Sulfur	0.58	0.65	0.60	0.68	0.57	0.65	0.58	0.66
% Ash	8.49	9.58	7.96	9.06	7.80	8.82	8.08	9.15
% Oxygen (diff)	10.92	12.32	11.09	12.62	10.89	12.33	97	12.59
Total (%)	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

**Table 6: Ultimate Analysis for Calcium-Based DSI System Air Toxics Testing**

### Fly ash

Supplemental monitoring of fly ash and bottom ash was also completed during the calcium injection testing. The samples were obtained in order to perform mineralogical, elemental, anion, and leachate analyses. These analyses take a significant amount of time to perform. These results will be reported in the environmental monitoring section of the *Final Report, Volume 2: Project Performance and Economics*.

#### IV. Summary of Air Toxics Monitoring Results

A total of 21 potential air toxics was measured at Arapahoe 4 with the calcium-based DSI system operating. Table 7 lists the air toxics that were sampled during the calcium-based DSI testing. Table 8 compares the target air toxics measured during each of the four test series. This report presents baseline dioxin data and air toxics data for the calcium-based DSI system. Refer to the other three environmental monitoring reports for more information on the other tests conducted.

Trace Metals	Arsenic	Lead
	Cadmium	Molybdenum
	Copper	Phosphorous
	Mercury	Beryllium
	Selenium	Cobalt
	Calcium	Manganese
	Barium	Nickel
	Chromium	Vanadium
	Calcium	Sodium
Anions <sup>1</sup>	Chloride	Sulfate
	Fluoride	

1. Elemental precursors of these anions measured in the fuel (Cl, F, S).

**Table 7: Target Compounds for Calcium-Based DSI System**

Sampling of the baseline dioxins was conducted on October 11, 12, and 13, 1993. The air toxics tests for the calcium-based DSI system were conducted on October 19 and 20, 1993. No sampling occurred during sootblowing operations.

Target Compounds		Test Period					
		Low-NO <sub>x</sub> Combustion	SNCR		Calcium-Based DSI		Sodium- Based DSI
			Baseline <sup>3</sup>	SNCR	Baseline	Sodium	
Trace Metals		X		X		X	X
Acid-Forming Anions		X		X		X	X
Volatile Organic Compounds	Benzene/toluene	X	X				
	Formaldehyde	X					
Semi-Volatile Organic Compounds	PAH	X					
	PCDD/PCDF <sup>1</sup>		X <sup>2</sup>		X		
Solid Particulate		X		X		X	X
Radio Nuclides		X					
Trace Metals Speciation	Total/hexavalent chromium		X				
	Mercury		X				
Nitrogen Compounds		X		X			
HHV, Ultimate/ Proximate Analysis		X	X	X	X	X	X
Loss-On-Ignition		X		X		X	X

1. Polychlorinated dibenzo-p-dioxins (PCDD) and polychlorinated dibenzofurans (PCDF).

2. Due to anomalous contamination of native 2,3,7,8-PCDD/PCDF isomers in the method blanks, samples, and archived resin, the results of these tests are invalid and were repeated during the calcium-based DSI test period.

3. Some baseline tests were repeated in the SNCR test period.

**Table 8: Target Compounds**

PSCC contracted with Carnot, Inc. of Tustin, California to complete the air toxics work at Arapahoe Unit 4. Fossil Energy Research Corp. of Laguna Hills, California provided some assistance at the site and with data collection. Table 9 lists the laboratories used to analyze the collected samples.



Analysis	Laboratory	Location
Solid particulate	Carnot, Inc	Tustin, CA
Chloride and sulfate (as necessary for confirmation)	Carnot, Inc	Tustin, CA
Acid-forming anions	Curtis and Tompkins	Berkeley, CA
Trace metals	Curtis and Tompkins	Berkeley, CA
Semi-volatile organic compounds	Zenon Environmental Laboratories	Burlington, Ontario, Canada
LOI for ash	Commercial Testing and Engineering	Denver, CO
Trace metals and anions analysis of fuel and ash	Curtis and Tompkins	Berkeley, CA
Coal preparation and ultimate analysis, including anions	Commercial Testing and Engineering	Denver, CO
Neutron activation analysis	Massachusetts Institute of Technology	Cambridge, MA
Coal preparation	A. J. Edmonds	Long Beach, CA
Ash preparation and anion analysis	Commercial Testing and Engineering	Denver, CO
Ash preparation	Carnot	Tustin, CA

**Table 9: Laboratories for Air Toxics Analyses**

The Environmental Monitoring Plan (EMP) addendum for air toxics includes details on the method used to determine the total mass flow of the air toxics. In addition to the measured concentrations of the air toxics in the sample, mass flows of the solid and gas are required. Table 10 lists the mass flowrates for the flue gas and the solids used to determine the mass flow of the toxics. The actual flue-gas flowrate is used for each of the trace metal, particulate matter, and anion tests. The flue-gas flowrates for the VOC and cyanide tests were from the major test conducted concurrently. The existing plant equipment was used to measure the coal flow. The measured particulate loading and flue-gas flowrate was used to calculate the flowrate of the fly ash and the stack ash. The coal input and the fly ash flowrates were used to calculate the bottom ash flowrate.

Stream	Test	Location	Test 1	Test 2	Test 3	
Flue Gas Flow Rate (DSCFM)	Trace Metals	Inlet	271,100	279,700	276,300	
		Outlet	279,200	288,700	279,700	
	Particulate Matter	Inlet	252,500	263,000	272,700	
		Outlet	260,000	268,900	275,900	
	Anions	Inlet	252,500	263,000	272,700	
		Outlet	260,000	268,900	275,900	
	Dioxins and Furans	Inlet	232,600	199,100	225,200	
		Outlet	234,900	204,700	206,900	
	Coal Flow (lb/h)			101,800	105,400	104,300
	Fly Ash Flow (lb/h)			8,359	8,351	7,474
	Bottom Ash Flow (lb/h)			3,638	3,889	4,593
	Total Ash Flow (lb/h)			11,997	12,240	12,067
Stack Ash Flow (lb/h)			4.2	1.6	1.4	

Table 10: Stream Mass Flow Data

Table 11 lists the average operating conditions of Arapahoe Unit 4 during the calcium and baseline air toxics testing. All three baseline dioxin tests were conducted at 75 Mwe. A problem occurred on the first day of testing that limited load to 75MWe. The problem was corrected the following day but the remaining tests were conducted at the same load to provide three replicate tests. Figure 1 shows a simplified diagram of the unit and shows the five different sample locations. Gaseous samples were obtained at the inlet and the outlet of the FFDC. Solid samples of unpulverized coal, bottom ash, and fly ash were also obtained. This section lists the results of the air toxics testing. For details on the methods used for sampling, analysis, and quality assurance, see the *Environmental Monitoring Plan Addendum for Air Toxics Monitoring*, dated July 1993.




Figure 1: Sampling Locations

Property		Baseline Dioxins			Calcium-Based DSI Air Toxics		
		1	2	3	1	2	3
Unit load (MW, net) <sup>3</sup>		76	75	75	112	112	112
Input	Air (lb/h)	753,000	705,000	716,000	976,000	995,000	1,028,000
	Coal (lb/h)	67,600	68,900	72,200	101,800	105,400	104,300
Steam flow (lb/h)		638,000	632,000	630,000	959,000	966,000	966,000
DSI	Injection rate (lb/min)	--	--	--	51.5	52.4	51.7
	Ca/S	--	--	--	2.06	2.07	2.10
	Sorbent feeder output (A/B) <sup>4</sup>	--	--	--	56%/68%	57%/69%	56%/68%
	Humidification water (gpm)	--	--	--	70.9	66.8	72.8
FFDC outlet	%O <sub>2</sub> <sup>1</sup> , dry	7.70%	7.24%	7.34%	6.11%	6.25%	6.32%
	CO (ppmd) <sup>2</sup>	14.0	19.2	13.2	71.7	231	212
	NO (ppmd) <sup>2</sup>	216	194	196	225	221	225
	SO <sub>2</sub> (ppmd) <sup>2</sup>	308	308	307	280	283	262

1. From Carnot's portable O<sub>2</sub> that sampled at each sample point.
2. From a single point Altech CEM system located in the FFDC outlet duct.
3. The "B" ID fan was off line for the first baseline test. To maintain consistent operating conditions, the remaining tests were operated at 75 MW.
4. Indicates level of operation of "A" and "B" DSI feed systems.

**Table 11: Average Operating Conditions and Continuous Emissions Data**

Table 12 lists the methods used during this sampling program that differ from the EMP.

### A. Uncertainty Analysis

In the tables that follow, a value for uncertainty expressed as a percentage is provided for all data. The calculation method used is based upon ANSI/ASME PTC 19.1-1985, "Measurement of Uncertainty." The uncertainty is based on a 95% confidence interval for the mass emissions for the target species but is expressed as a percentage so that it may be applied to other units. A very important part of the method is assigning an estimated bias error for the major

	Species	EMP Specified Method	Method Used
FFDC Inlet	Arsenic	EPA SW 846-7060 (GFAA)	EPA SW 846-6010 (ICP)
	Cadmium	EPA SW 846-7131 (ICP)	EPA SW 846-6010 (ICP)
	Chromium	EPA SW 846-7191 (GFAA)	EPA SW 846-6010 (ICP)
FFDC Outlet	Arsenic	EPA SW 846-7060 (GFAA)	EPA SW 846-6010 (ICP)
	Cadmium	EPA SW 846-7131 (ICP)	EPA SW 846-6010 (ICP)
	Chromium	EPA SW 846-7191 (GFAA)	EPA SW 846-6010 (ICP)
Fuel	Arsenic	EPA SW 846-7060 (GFAA)	INAA
	Barium	EPA SW 846-6010 (ICP)	EPA SW 846-6010 (ICP with EPA3050 digestion)
	Chlorine	ASTM D-4208 & ISP	INAA
	Sulfate	EPA SW 846-300-IC	ASTM D4239 & LECO SC-132
	Cadmium	EPA SW 846-7131 (ICP)	INAA
	Mercury	EPA SW 846-7470 (CVAA)	INAA
	Selenium	EPA SW 846-7740 (GFAA)	INAA
	Chromium	EPA SW 846-7191 (GFAA)	EPA SW846-6010 (ICP-AES)
	Lead	EPA SW 846-7421 (GFAA)	EPA SW846-7420 (GFAA)
	Calcium	EPA SW 846-6010 (ICP)	EPA SW 846-6010 (ICP with EPA3050 digestion)
	Sodium	EPA SW 846-6010 (ICP)	EPA SW 846-6010 (ICP with EPA3050 digestion)
	Manganese	EPA SW 846-6010 (ICP)	INAA
	Vanadium	EPA SW 846-6010 (ICP)	INAA
Flyash/ Bottom Ash	Barium	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Beryllium	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Cadmium	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Chromium	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Cobalt	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Copper	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Manganese	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Mercury	EPA SW 846-7470 CVAA	EPA SW 846-7471 ICP-AES
	Molybdenum	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Nickel	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Phosphorus	EPA SW 846-6010 (ICP)	EPA SW 846-7060 ICP-AES
	Vanadium	EPA SW 846-6010 (ICP)	EPA SW 846-7060
	Calcium	EPA SW 846-6010 (ICP)	EPA SW 846-7060 (ICP with EPA3050 digestion)
	Sodium	EPA SW 846-6010 (ICP)	EPA SW 846-7471 (ICP with EPA3050 digestion)
	Fluoride	EPA 300.0(IC)	EPA 340.2 (ISE)
	Sulfate	EPA 300.0(IC)	ASTM D4239 & LECO SC-132

Table 12: Test Methods Different from EMP (TBD)

variables. The value presented represents only an approximation of the uncertainty as not all bias errors may be estimated. The uncertainty is also not a measure of long-term trace-species emissions for this boiler, but only the uncertainty for the specific test period. It was assumed that the samples are a normal population distribution. Table 13 summarizes the bias values used to determine uncertainties.

Location	Particle Collection <sup>1</sup>	Flowrate <sup>2</sup>	Fuel Flowrate <sup>3</sup>	Fly Ash Flowrate <sup>4</sup>	Bottom Ash Flow Rate <sup>4</sup>
Inlet	15%	0%	0%	15%	15%
Outlet	0%	0%	N/A	N/A	N/A

1. Bias based on difference between pitot and heat rate flowrates.
2. No bias estimated as measured inlet, measured outlet, and calculated flow agreed within +-5%
3. No bias estimated as calculated flue gas flow agreed with measured outlet flow.
4. Bias equals the inlet particle collection bias.

**Table 13: Summary of Bias Values Used for Uncertainty Calculations**

## B. Treatment of Non-Detectable Measurements

Many of the target species for which a measurement was attempted were not found using the specified sampling and analytical techniques. If a measurement for a target species was not found, the value that could have been measured (i.e. the detection limit) if the trace emissions were present are reported. The "non-detects" are shown as less than the detection limit. The difficulty occurs when averaging various samples of which some or all of the measurements are below the detection limit. The following summarizes the two cases:

- **All values below detection limit:** The arithmetic average of the detection limit is shown with a "<" sign to indicate that the trace species is less than the reported average detection limit. For example, if a species was not found and the method provided a detection limit of 0.45, the values is reported as <0.45.

- **Some, but not all, values below detection limit:** The value of all measurements above the detection limit are averaged with one-half of the detection limit. For example, if three measurements of 10, 8, and <6 are found, the average would be  $(10+8+6/2)/3$  or 7. Note that no "<" sign is used in these reported averages even though some of the values are below the detection limit. If the average calculated with this method is less than the greatest detection limit; the largest detection limit is reported and a "<" symbol is used. For example, if values of 6, <4, and <2 were reported, the average would be reported as <4 and not  $(6+4/2+2/2)/3$  or 3.

### **C. Treatment of Blank Values**

Three different types of blanks were used as part of the air toxics testing quality assurance (QA) program. The QA program included field blanks, reagent blanks, and laboratory preparation blanks.

Field blanks are samples obtained by assembling a complete sample train at the test site using the same procedures as when obtaining the actual sample. The sample train is then leak checked and disassembled to recover and analyze the sample. Field blanks are not used to "correct" the data generally but are used to provide an indication of the quality of the sample.

Reagent blanks consist of samples of the reagent and/or filters that are collected at the site. Analysis of these samples show if any of the results were caused by existing levels of the trace species in the material used to collect or recover the sample. If measurable values of the trace species are found, the data is usually corrected by subtracting the value measured in the reagent.

Laboratory reagent blanks consist of samples of the chemicals used during the measurement analysis. If measurable values of the trace species are found, the

data is usually corrected by subtracting the value measured in the reagent. Any measurable values in the laboratory reagent may be caused by initial trace species in the chemicals or by the analytical procedures.

In the tables that follow the value of the field blank is shown for reference, but none of the data has been changed due to these measurements. If a measurement has a value near the field blank measurement, there may be some question as to the accuracy of the data and the reported value may NOT be source related. A separate column lists a blank correction percentage for all trace species that were corrected due to either a reagent or laboratory reagent blank. This is an average percentage calculated as follows:

$$\% \text{ blank correct} = \frac{\sum \left( \frac{\text{blank value}}{\text{sample value}} \right)}{\text{number of samples}} \times 100$$

For example, if three samples contained 10, 5, and 4 mg/kg of a trace species and the reagent blank was 2 mg/kg, the blank correction would be:

$$\text{blank correction} = \left( \frac{2}{10} + \frac{2}{5} + \frac{2}{4} \right) \times \frac{100}{3} = 37\%$$

Thus, on average, the actual value measured was 37% higher than the value reported in the table. If the blank correction is reported as 0%, no blank correction was calculated and the reported value was the measured value. Note that in most cases a high blank correction value does not mean that the data is inaccurate. If a sample was contaminated with a trace species due to a filter, and the filter was analyzed and the data corrected, it is likely that the data is meaningful.



#### **D. Gaseous Species Monitoring**

This section reports the trace metal, acid-forming anion, and FFDC efficiency from the air toxics testing of the calcium-based DSI system. In addition, it reports the furan and dioxin data from the baseline tests.

##### Trace Metals

Table 14 lists the gaseous trace metal emissions for the calcium-based DSI test period. Although calcium and sodium are neither trace metals or air toxics, Table 14 also lists their results. At the FFDC inlet, all 15 trace metals, calcium, and sodium were reported above their detection limits.

Previous air toxics test series at Arapahoe reported a wide unexplained variation of barium, calcium, and sodium in various solid streams between different test methods. Curtis and Tompkins, the laboratory completing the analysis, investigated and discovered a problem with the ASTM D3683 ashing/acid digestion method of sample preparation. Coal samples were prepared according to ASTM D3683 and also EPA method 3050. The EPA method does not require ashing or digestion using HF acid. A comparison of the data with the two different digestion methods for both the calcium and sodium injection program compared to INAA is shown in Table 15. This data suggests that ASTM D3683 (that uses HF acid digestion) may have a significant low bias. The EPA 3050 method provides better precision between replicates and better accuracy when compared to INAA which does not require sample digestion.

Trace Metals	FFDC Inlet						FFDC Outlet							
	Test 1	Test 2	Test 3	Avg.	Uncert.	Field Blank	Blank Correct <sup>1</sup>	Test 1	Test 2	Test 3	Avg.	Uncert.	Field Blank	Blank Correct <sup>1</sup>
	$\mu\text{g}/\text{Nm}^3$						$\mu\text{g}/\text{Nm}^3$	%	$\mu\text{g}/\text{Nm}^3$					
Arsenic <sup>3</sup>	27	28	19	25	50	0.14	1.4L	0.070	0.24	<0.070	0.12	239	0.074	39L
Barium <sup>2,3,6</sup>	16	353	730	542	443	0.80	0.3R	1.7	1.7	0.14	1.2	190	0.14	50R
Beryllium	10	15	11	12	52	<0.035	0.0	<0.027	<0.027	<0.028	<0.027	29	<0.027	0.0
Cadmium	5.0	4.8	5.2	5.0	17	<0.089	0.0	<0.070	0.48	<0.070	0.18	349	<0.069	0.0
Chromium <sup>3</sup>	62	95	81	80	55	0.26	1.5R	0.14	0.14	0.68	0.32	244	0.14	75R
Cobalt	43	90	70	68	88	<0.35	0.0	<0.27	<0.27	<0.28	<0.27	29	<0.27	0.0
Copper	632	322	234	396	132	1.0	0.2R	0.70	0.53	0.33	0.52	89	0.12	47R
Lead	27	103	79	70	139	0.083	0.4R	0.29	1.1	0.05	0.48	288	0.079	42R
Manganese	146	125	140	137	25	0.18	0.2R	1.2	0.21	0.84	0.74	163	0.14	26R
Mercury	4.4	5.0	3.4	4.3	50	0.12	0.0	0.33	0.19	0.27	0.26	63	0.31	0.0
Molybdenum <sup>3</sup>	21	43	34	33	83	3.2	15.9R	0.27	0.27	0.28	0.27	4.2	0.27	79R
Nickel <sup>3</sup>	36	22	17	25	100	0.77	4.1R	0.27	0.27	0.28	0.27	4.2	0.27	42R
Selenium <sup>4</sup>	50	103	64	72	96	<0.89	0.0	<0.070	0.11	<0.070	<0.070	88	<0.069	0.0
Phosphorus	20,300	16,100	12,500	16,300	62	<8.9	0.02L	<1.4	<1.4	<1.4	<1.4	29	3.6	0.0
Vanadium	190	319	232	247	68	<0.18	0.0	<0.14	<0.14	<0.14	<0.14	29	<0.14	0.0
Calcium <sup>2,5,6</sup>	1,170	<90	1,960	1,560	320	8.9	2R	143	151	102	132	50	8.9	14R
Sodium <sup>3,5,6</sup>	4,920	2,570	2,380	3,290	108	8.9	2R	7.5	34	7.0	16	237	27	75R

Note: "<" indicates that the quantity measured was less than the detection limit thus the detection limit is shown

- "R" indicates reagent blank correction. "L" indicates laboratory blank correction.
- Tests Ba #1-Out and Ca #2-In not included in averages.
- Subtracting reagent blank lowered result below the detection for Ar #1-Out; Ba #3-Out; Cr #1-, 2-Out; Mb #1-, 2-, 3-Out; Ni #1-, 2-, 3-Out; and Na 3-Out.
- Average calculated by dividing non-detects in half was less than highest non-detect, so highest non-detect used for average.
- Results included, even though neither trace metals nor air toxics.
- Values for these metals at the FFDC inlet are reported but believed to be invalid due to a problem with sample preparation (see text).

**Table 14: Trace Metal Emission Results for Calcium-Based DSI System**

	Reagent	D3683 mg/Kg	E3050 mg/Kg	INAA mg/Kg
Barium	sodium	5,976	24,390	33,122
	calcium	6,670	17,447	28,925
Calcium	sodium	122,740	213,404	NP
	calcium	78,917	204,879	NP
Sodium	sodium	14,843	64,322	105,096
	calcium	31,849	27,423	46,099

**Table 15: Comparison of Alternate Digestion Methods with INAA**

EPA method 29, multi-metals method, also uses HF acid for digestion of solid matter collected in the sample train. Due to the potential negative bias that may be caused with HF acid, all data collected for barium, calcium, and sodium from the solid samples using Method 29 are believed invalid and are presented for information only. Table 16 compares the inlet fuel levels to the values measured at the FFDC inlet determined from the Method 29 test using HF digestion. Note the very large discrepancy in the inlet values. It is believed that the fuel values are more accurate and that the FFDC inlet values for the three elements presented are invalid. They are shown in this table only to note the large variation that was believed due to the HF digestion techniques. Note that the

inlet values are based on a large amount of particulate matter that is present at the FFDC inlet. Due to the very low particulate at the FFDC outlet, the possible interference with HF digestion is not believed to significantly affect the outlet data. While the fly ash and coal samples could be re-analyzed after the discovery of the possible HF interference, it was not possible to re-analyze the Method 29 train.

	Fuel lb/10 <sup>12</sup> Btu	FFDC Inlet lb/10 <sup>12</sup> Btu	Percent Difference
barium	17,400	431	3,937%
calcium	205,000	1,240	16,432%
sodium	27,400	2,580	962%

**Table 16: Comparison of fuel vs FFDC Inlet Measurements**

Uncertainties for copper, lead, and nickel were 100% and greater. The wide spread between the replicate tests caused the high uncertainty for these three elements. A review of the data logs and sample methods did not reveal any errors that could explain the differences.

The FFDC outlet trace metal emissions were very low with many at or near their detection limit. The high uncertainty values are due mainly to a wide variation of replicate tests. Due to the very low measured emissions, the reagent or laboratory blank corrections were also relatively high for many elements.

### Anions

Anions were measured from both the front (solid/liquid phase) and the back-half (gaseous phase) of each particulate train. As expected, the majority of all anions occur in the gaseous phase. Results of the testing are presented in Table 17.

At the FFDC inlet, the sample-train measured 465 ppm of gaseous sulfate and the CEM measured 460 ppm of SO<sub>2</sub>. The gaseous fraction represents SO<sub>2</sub> plus any SO<sub>3</sub> in the vapor phase. The sample-train measured 3 ppm of solid-phase sulfate at the FFDC inlet, representing sulfuric acid mist and solid-phase sulfate present at the 250°F filter temperature. At the FFDC outlet, the sample-train measured 287 ppm of gaseous sulfate and the CEM measured 275 ppm of SO<sub>2</sub>.

Acid Forming Anions		FFDC Inlet							FFDC Outlet						
		Test 1	Test 2	Test 3	Avg.	Uncert.	Field Blank	Blank Correct	Test 1	Test 2	Test 3	Avg.	Uncert.	Field Blank	Blank Correct
		ppmw							ppmw						
Chlorine (Cl <sup>-</sup> )	Total	0.59	0.75	0.64	0.66	36	N/A		0.25	0.32	0.30	0.29	33	N/A	
	Gaseous	0.56	0.72	0.61	0.63				0.24	0.30	0.29	0.28			
	Solid	0.035	0.034	0.031	0.033	0			<0.017	0.020	0.012	<0.017			0
Fluorine (F <sup>-</sup> )	Total	8.5	11	11	10	38	N/A		0.12	0.58	<0.06	0.24	293	N/A	
	Gaseous	8.2	10	11	9.6				0.09	0.54	<0.06	0.22			
	Solid	0.23	0.50	0.35	0.36	0			0.034	0.039	0.019	0.031			0
Sulfate (SO <sub>4</sub> <sup>-2</sup> )	Total	455	477	474	469	17	N/A		302	297	262	287	15	N/A	
	Gaseous	452	474	470	465				302	297	262	287			
	Solid	2.9	3.1	3.3	3.1				0.068	0.015	0.019	0.034			32R

1. "<" indicates that the quantity measured was less than the detection limit thus the detection limit is shown.
2. "R" indicates reagent blank correction. "L" indicates laboratory blank correction.
3. Solid fraction consists of filter and front-half rinse.
4. Gaseous fraction consists of bicarbonate/carbonate and 3% peroxide rinses.

**Table 17: Acid-Forming Anion Emission Results for Calcium-Based DSI System**

### Baseline Dioxin and Furan Emissions

Table 18 lists the gaseous polychlorinated dibenzo-P-dioxin (PCDD) and polychlorinated dibenzofuran (PCDF) emissions at the FFDC inlet and outlet. Note that sampling and analysis techniques were optimized to lower detection limits to an average 10 times lower than that of normal dioxin and furan tests.

All dioxins and furans were measured near or below their detection limits. At the FFDC outlet, OCDD and 23478 PeCDF were the only individual isomers detected in all three samples. However, these isomers were also detected in the field blank, so their detected levels may not be entirely source related.

In Table 18, the column headed by "EPA Equiv." lists the EPA toxic equivalent for each specie. These values can be used for comparing risk and are used in the establishment of emission limits for municipal solid waste (MSW) incinerators. These equivalent values were calculated by multiplying the average actual emission of a specie by its EPA risk factor.

The total emissions of EPA equivalent toxics at the FFDC inlet was 0.0015 ng/Nm<sup>3</sup> and consisted of 0.0008 ng/Nm<sup>3</sup> of detected species and 0.0007 ng/Nm<sup>3</sup> of nondetects. Thus, 47% of the total EPA equivalent at the inlet of the FFDC was due to nondetects. The total emissions of EPA equivalent toxics at the FFDC outlet was 0.0014 ng/Nm<sup>3</sup> and consisted of 0.0003 ng/Nm<sup>3</sup> of detected species and 0.0012 ng/Nm<sup>3</sup> of nondetects. Thus, the nondetects at the outlet relate to 86% of the total EPA equivalent toxics. For comparison, well controlled MSW incinerators typically have on the order of 1 ng/Nm<sup>3</sup> of equivalent toxic emissions, three orders of magnitude higher than Arapahoe Unit 4.

PCDD/PCDF	FFDC Inlet						FFDC Outlet								
	Test 1	Test 2	Test 3	Avg.	Uncert.	Field Blank	EPA Equiv.	Test 1	Test 2	Test 3	Avg.	Uncert.	Field Blank	EPA Equiv.	
	ng/Nm <sup>3</sup>						ng/Nm <sup>3</sup>						%		ng/Nm <sup>3</sup>
2378 TCDD <sup>1,2</sup>	<0.0006	0.0006	0.0006	0.0005	95	<0.0006	0.0005	0.0006	<0.0004	<0.0004	<0.0005	<0.0005	<0.0005	<0.0005	0.0005
12378 PeCDD <sup>1</sup>	<0.0006	0.0002	<0.0004	<0.0006	78	<0.0006	0.0003	<0.0007	<0.0007	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	0.0003
123478 HxCDD <sup>2</sup>	<0.0007	0.0007	0.0007	0.0006	88	<0.0008	0.0001	<0.0003	<0.0004	<0.0005	0.0006	0.0006	0.0006	<0.0012	0.0001
123678 HxCDD <sup>1</sup>	<0.0004	0.0002	<0.0003	<0.0004	48	<0.0005	0.0000	<0.0002	<0.0004	<0.0003	<0.0003	<0.0003	<0.0007	<0.0007	0.0000
123789 HxCDD	<0.0006	<0.0002	<0.0004	<0.0004	108	<0.0007	0.0000	<0.0004	<0.0006	<0.0003	<0.0005	<0.0005	<0.0010	<0.0010	0.0000
1234678 HpCDD <sup>1,2</sup>	<0.0008	0.0004	0.0004	0.0004	43	<0.0008	0.0000	0.0004	<0.0006	<0.0004	<0.0006	<0.0006	<0.0005	<0.0005	0.0000
OCDD	<0.0011	0.0037	0.0020	0.0021	191	0.0036	0.0000	0.0020	0.0012	0.0008	0.0021	0.0021	0.0010	0.0010	0.0000
2378 TCDF	<0.0020	<0.0011	<0.0013	<0.0014	91	<0.0018	0.0001	<0.0002	<0.0018	<0.0018	<0.0020	<0.0020	<0.0011	<0.0011	0.0002
12378 PeCDF <sup>1</sup>	<0.0005	<0.0002	0.0002	<0.0005	92	<0.0005	0.0000	0.0004	<0.0002	<0.0001	<0.0002	<0.0002	<0.0003	<0.0003	0.0000
23478 PeCDF	0.0005	0.0004	0.0004	0.0004	42	<0.0005	0.0002	0.0004	0.0004	0.0004	0.0004	0.0004	0.0004	0.0004	0.0002
123478 HxCDF <sup>1</sup>	<0.0006	<0.0002	<0.0004	<0.0004	126	<0.0004	0.0000	<0.0002	<0.0004	<0.0002	<0.0004	<0.0004	<0.0004	<0.0004	0.0000
123678 HxCDF	<0.0004	<0.0002	<0.0003	<0.0003	89	<0.0002	0.0000	<0.0004	<0.0003	<0.0001	<0.0002	<0.0002	<0.0004	<0.0004	0.0000
234678 HxCDF	<0.0007	<0.0003	<0.0004	<0.0005	101	<0.0004	0.0000	<0.0004	<0.0005	<0.0002	<0.0003	<0.0003	<0.0005	<0.0005	0.0000
123789 HxCDF	<0.0007	<0.0004	<0.0004	<0.0005	107	<0.0004	0.0001	<0.0004	<0.0005	<0.0002	<0.0004	<0.0004	<0.0005	<0.0005	0.0000
1234678 HpCDF	<0.0004	<0.0003	<0.0003	<0.0004	45	<0.0007	0.0000	<0.0003	<0.0003	<0.0002	<0.0004	<0.0004	<0.0004	<0.0004	0.0000
1234789 HpCDF	<0.0006	<0.0005	<0.0005	<0.0005	44	<0.0010	0.0000	<0.0005	<0.0005	<0.0004	<0.0005	<0.0005	<0.0006	<0.0006	0.0000
OCDF	<0.0006	<0.0004	<0.0006	<0.0005	51	<0.0010	0.0000	<0.0006	<0.0008	<0.0005	<0.0006	<0.0006	<0.0006	<0.0006	0.0000
Total TCDD <sup>1,2</sup>	<0.0006	0.0006	0.0006	0.0005	95	<0.0006	--	0.0006	<0.0004	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	--
Total PeCDD <sup>1</sup>	<0.0006	0.0002	<0.0005	<0.0006	79	<0.0006	--	<0.0007	<0.0005	<0.0005	<0.0006	<0.0006	<0.0005	<0.0005	--
Total HxCDD	<0.0005	0.0008	0.0005	0.0005	132	<0.0006	--	0.0009	<0.0005	0.0004	0.0005	0.0005	<0.0009	<0.0009	--
Total HpCDD <sup>1,2</sup>	<0.0008	0.0004	0.0004	0.0004	43	<0.0008	--	0.0010	<0.0006	<0.0005	<0.0006	<0.0006	<0.0005	<0.0005	--
Total TCDF	0.0019	0.0023	0.0028	0.0023	41	0.0019	--	0.0019	0.0016	0.0015	0.0017	0.0017	0.0014	0.0014	--
Total PeCDF	0.0011	0.0007	0.0014	0.0011	80	<0.0005	--	0.0011	0.0007	0.0007	0.0008	0.0008	0.0004	0.0004	--
Total HxCDF <sup>1</sup>	<0.0006	0.0003	<0.0004	<0.0006	69	<0.0006	--	0.0004	<0.0004	<0.0004	<0.0004	<0.0004	<0.0004	<0.0004	--
Total HpCDF	<0.0005	<0.0004	<0.0004	<0.0004	41	<0.0008	--	<0.0006	<0.0004	<0.0004	<0.0005	<0.0005	<0.0005	<0.0005	--
<b>Total</b>	0.0119	0.0144	0.0137	0.0133	27	--	0.0015 <sup>3</sup>	0.0185	0.0104	0.0093	0.0127	0.0127	--	--	0.0014 <sup>3</sup>

\* < indicates detection limit and that species was not detected.

1. By convention, the calculated mean cannot be smaller than the largest detection limit value. When this happens, the mean is reported as not detected below highest detection limit.

2. Detection limits varied by sample, a straight average with non-detects divided by two was taken, highest non-detect rule was deemed inappropriate.

3. Total EPA toxic equivalent (2, 3, 7, 8, TCDD Equivalent)

**Table 18: Baseline Polychlorinated Dibenzop-P-Dioxin (PCDD) and Polychlorinated Dibenzofuran (PCDF) Emissions**



### FFDC Efficiency

Table 19 shows the FFDC removal efficiency for trace metals, anions, calcium, and sodium. The FFDC did not affect flue gas concentrations of PCDDs or PCDFs. The FFDC averaged 98.6% removal efficiency for trace metals and 99.95% for particulates.

The FFDC's removal efficiency for mercury was 93.7%, significantly higher than was obtained in previous testing without calcium injection with humidification. Fly ash unburned carbon during this testing averaged 11.21%. Water was also injected into the flue gas to improve calcium utilization. The water injection cooled the flue gas to approximately 150°F. It is believed that the combination of low flue gas temperature and high unburned carbon in the fly ash allowed the higher than expected mercury removal.

As was discussed in the trace metals section, sodium, calcium, and barium are believed to be severely biased low. Thus the data for these three elements is presented for informational purposes but the relative numbers are considered invalid.

The combination of the FFDC with calcium injection with humidification obtained significant removal of the acid-forming anions. Removal of both chloride and fluoride were 55.1% and 97.5% respectively. The removals are comparable to previous testing with urea injection but are significantly higher than the original baseline which were 10% for chloride and 20% for fluorides. SO<sub>2</sub> removal during the test was approximately 37% due to the calcium and humidification system.

Species		Inlet	Outlet	FFDC Removal
Trace Metals		lb/10 <sup>12</sup> Btu	lb/10 <sup>12</sup> Btu	%
Arsenic		20	0.09	99.5
Barium <sup>2</sup>		431	0.94	99.8
Beryllium		9.5	<0.02	>99.8
Cadmium		3.9	0.15	96.2
Chromium		63	0.26	99.6
Cobalt		53	<0.22	>99.6
Copper		310	0.42	99.9
Lead		55	0.38	99.3
Manganese		108	0.59	99.4
Mercury		3.4	0.21	93.7
Molybdenum		26	0.22	99.1
Nickel		19	0.22	98.9
Selenium		57	<0.06	>99.9
Phosphorus		12,800	<1.1	>99.99
Vanadium		194	<0.11	>99.9
Calcium <sup>1,2</sup>		1,240	106	91.4
Sodium <sup>1,2</sup>		2,580	13	99.5
Average		--	--	<b>98.6</b>
<b>Total Particulate</b>		<b>4.27 lb/MMBtu</b>	<b>0.0021 lb/MMBtu</b>	<b>99.95%</b>
Acid-Forming Anions		lb/10 <sup>12</sup> Btu	lb/10 <sup>12</sup> Btu	%
Chloride (Cl)	Solid	41	<21	>48.9
	Gas	784	353	54.9
	Total	825	371	55.1
Fluoride (F)	Solid	241	21	91.3
	Gas	6,460	150	97.7
	Total	6,700	167	97.5
Sulfate	Solid	10,600	115	98.9
	Gas	1.57(10 <sup>6</sup> )	9.89(10 <sup>5</sup> )	37.1
	Total	1.58(10 <sup>6</sup> )	9.90(10 <sup>5</sup> )	37.5

NOTES:

"<" indicates that the quantity measured was less than the detection limit; thus the detection limit is shown.

">" indicates that the percentage removal is based on a detection limit so the expected minimum removal rate.

1. Included even though neither trace metals or air toxics.

2. Values for these metals are reported but are believed invalid due to a problem with sample preparation. (see text)

**Table 19: FFDC Removal Efficiency (Calcium-Based DSI Test Period)**

## E. Solids Stream Monitoring

### Calcium-Based Sorbent Analysis

Table 20 lists the trace metal and anion analysis results for the calcium-based sorbent (calcium hydroxide) and humidification water. Although calcium and sodium are neither trace metals nor air toxics, Table 20 also lists them.

The humidification water contained negligible amounts of trace metals but significant amounts of calcium, sodium, and acid-forming anions. The total mass input of air toxics due to the sorbent and water added to the process was insignificant in comparison to the amounts in the coal. Notable exceptions were molybdenum and chloride. The sorbent water contained 41% of the total mass input of molybdenum and 46% of the input chlorides. Other air toxics that were input due to the sorbent and water were much lower and ranged from 0 to 10% of those input from other sources on a mass basis.

Element	Calcium Sorbent		Sorbent H <sub>2</sub> O
	Test 22	Blank Correct	
	mg/kg	%	µg/L
Arsenic	<1.2	0	<5.0
Barium	9.0	0	34
Beryllium	<0.49	0	<2.0
Cadmium	<1.2	0	<5.0
Chromium <sup>1</sup>	5.1	0	<10
Cobalt	<4.9	0	<20
Copper	5.3	0	<5.0
Lead	<0.73	0	<3.0
Manganese <sup>1</sup>	45	22.4	<10
Mercury	<0.091	0	<0.20
Molybdenum	6.2	0	25
Nickel <sup>1</sup>	5.3	0	<20
Selenium	<61	0	<250
Phosphorous	195	0	<100
Vanadium	7.9	0	<10
Calcium	NP	0	27,000
Sodium	NP	0	17,000
Chloride	<5.0	0	22,973
Fluoride	34	0	960
Sulfate	170	0	104,350

1. Prep blank levels were higher than the sample values, so the samples were not blank corrected.

**Table 20: Air Toxics Analysis of Hydrated Lime**

## Coal Analysis

Previous air toxics testing at Arapahoe has shown the importance of obtaining representative solid samples. This is a difficult task due to the scale and current equipment. Coal sample procedures were modified and the ASTM D2234 collection method was followed more closely during the sodium- and calcium-based DSI test periods than during the low-NO<sub>x</sub> combustion and SNCR test periods. In addition, the ASTM D2013 preparation method was followed during the sodium- and calcium-based DSI test periods. For barium, lead, calcium, and sodium, EPA Method 3050 was used for coal digestion instead of ASTM D3683.

For many trace metal data points, there were two or three sets of results. On average, there were three sets of data with some having as many as six sets. For example, one point had results from:

- Curtis & Tompkins analysis using conventional digestion.
- Curtis & Tompkins analysis using EPA 3050 digestion.
- Standard Laboratory's analysis.
- Curtis & Tompkins triplicate analysis using conventional digestion.
- Curtis & Tompkins triplicate analysis using EPA 3050 digestion.
- INAA.

Except for a few cases, the results from these different sources did not agree. Ideally, if the data for one element from one set was consistent with expected levels and other process streams, then the data for elements within the same data set processed by the same lab and method would also be consistent.

Unfortunately, a common bias for a data set could not be found. Therefore, the

use of a particular data set depended solely on its agreement with levels determined in other input and output streams from the same test program.

For the low-NO<sub>x</sub> combustion and SNCR test periods, INAA was selected as the analytical technique most likely to produce representative data sets for arsenic, barium, mercury, selenium, and chloride because INAA:

- Could achieve lower detection limits for arsenic, mercury, selenium, and chloride.
- Results for barium agreed with USGS and Cyprus Yampa Valley coal data. ICP-AES results were biased low.

Since INAA is not a proven analytical technique for trace metal analysis of coal, it was not chosen to analyze an element unless there was a clear technical justification to discard the conventional data.

For the coal samples from the sodium- and calcium-based DSI test periods, INAA was the only technique used to analyze arsenic, mercury, selenium, and chloride. With the use of EPA 3050 digestion technique for barium, the ICP-AES analysis results for barium are no longer severely biased and are now consistent with expected levels. For sodium-based DSI test, the conventional analytical results for cadmium, chromium, manganese, and vanadium were considered as qualitative and discarded.

Table 21 lists the analysis of the coal for trace metals and acid-forming anions. Although calcium and sodium are neither trace metals nor air toxics, Table 21 also lists them. All trace metals were detected in each replicate. Most elements show relatively good precision (uncertainty less than 100%). A single high nickel reading caused uncertainty of 120%. While high the nickel readings are in the range expected for this coal.

Trace Metals	Base Test Method						INAA					
	Test 1	Test 2	Test 3	Avg.	Uncert.	Blank Correct	Test 1	Test 2	Test 3	Avg.	Uncert.	Blank Correct
	mg/kg						%					
Arsenic <sup>2</sup>	NP	NP	NP	NP	NP	0	0.54	0.48	0.51	0.51	14	0
Barium <sup>1</sup>	30	173	174	192	42	0	285	347	325	319	25	0
Beryllium	0.37	0.28	0.41	0.35	46	0	0.05	0.08	0.047	0.048	86	0
Cadmium <sup>2,3</sup>	0.12	<0.10	<0.12	<0.11	--	0	1.7	1.6	2.1	1.8	39	0
Chromium	2.6	1.9	2.9	2.5	52	0	0.81	0.91	0.82	0.85	17	0
Cobalt	1.3	0.8	1.0	1.0	60	0	6.7	7.8	8.4	7.6	28	0
Copper	5.2	3.4	4.5	4.4	53	0	0.024	0.035	0.030	0.030	46	0
Lead <sup>1</sup>	3.4	3.1	3.8	3.4	24	0	0.9	0.8	0.9	0.9	14	0
Manganese	14	11	23	16	104	0	1.29	1.37	1.14	1.27	22	0
Mercury <sup>2</sup>	NP	NP	NP	NP	NP	0	0.024	0.035	0.030	0.030	46	0
Molybdenum	0.52	0.32	0.42	0.42	60	0	0.9	0.8	0.9	0.9	14	0
Nickel	2.4	0.9	1.4	1.6	120	0	5.9	4.7	7.2	5.9	51	0
Selenium <sup>2</sup>	NP	NP	NP	NP	NP	0	1.29	1.37	1.14	1.27	22	0
Phosphorus	450	338	376	388	37	0	5.9	4.7	7.2	5.9	51	0
Vanadium	7.5	4.5	6.7	6.2	63	0	496	475	554	508	20	0
Calcium <sup>1,4</sup>	2,390	2,280	2,110	2,260	16	0						
Sodium <sup>1,4</sup>	432	265	211	302	95	0						
<b>Anions</b>	mg/kg						%					
Chloride (Cl) <sup>(2)</sup>	--	--	--	--	--	0	13	25	19	19	78	0
Fluorine (F)	80	70	70	73	20	0						
Sulfate	17,400	18,000	17,100	17,500	16	0						

\* < indicates that the quantity measured was less than the detection limit thus the detection limit is shown.  
 \*NP" indicates not performed.  
 All values are reported on an as-received basis for the coal.

1. Analysis performed after an EPA 3050 digestion (acid only).
2. INAA results were used for these trace species rather than the base method.
3. Cadmium average less than highest nondetect and reported as such.
4. Included even though neither are trace metals or air toxics.

**Table 21: Trace Metals Analysis of Coal**

### Fly Ash

Table 22 lists the results for the fly ash and bottom ash from the calcium-based DSI test period. Although calcium and sodium are neither trace metals nor air toxics, Table 22 also lists them. Cadmium is the only element reported below its detection limit. The results for barium, calcium, and sodium from Test-1 were not used in the average. The combination of EPA 3050 digestion and ICP-AES analysis is used only for these three elements, therefore a problem with the digestion or ICP analysis may have affected these results. The conventional digestion of the sodium sample for Test-1 also yielded a value an order of magnitude higher than the other samples. This suggests that EPA 3050 digestion failed to dissolve the entire samples of barium and calcium and that the sodium sample was contaminated. Test-3 for sodium appears to be negatively biased when compared with output stream levels.

Matrix effects and certain digestion techniques make the analysis of selenium very difficult. Selenium is by far the most problematic of potential air toxics elements to analyze. With the discovery that hydrofluoric (HF) acid was interfering with GFAA, ash samples were re-analyzed using EPA 3050 digestion. This method eliminated the need for diluting the ash samples to minimize interference as well as most of the questionable results and high detection limits. However, the ash results for selenium obtained with EPA 3050 digestion from the sodium- and calcium-based DSI test periods are not consistent with expected levels. Despite high detection limits and poor precision, the conventional ash results for selenium agree, on average, with expected values and are used in the mass balance.

### Bottom Ash

Overall, sample preparation does not appear to have biased the results of the bottom ash. The average results for arsenic, cadmium, mercury, and molybdenum were below the detection limit. Except for selenium and sodium, the replicates show good agreement. As with the fly ash, the conventional digestion methods used to analyze selenium often produce spurious data points. Also, since bottom ash levels of sulfate contribute less than 1% of the total sulfate stream, the spread in the sulfate results is considered negligible.



	Bottom Ash/Sluice Water <sup>7</sup>						Fly Ash					
	Test 1	Test 2	Test 3	Avg.	Uncert.	Blank Correct	Test 1	Test 2	Test 3	Avg.	Uncert.	Blank Correct
	mg/kg						mg/kg					
<b>Trace Metals</b>												
Arsenic	<1.2	<1.3	<1.2	<1.2	40	0	5.9	3.7	3.3	4.3	84	0
Barium <sup>1</sup>	900	1,100	1,000	1,000	29	0	580	1,100	990	1,045	31	0
Beryllium	3.9	3.6	3.8	3.8	27	0	3.7	2.9	2.7	3.1	37	0
Cadmium <sup>4</sup>	<1.1	<1.1	<1.1	<1.1	40	0	<1.1	<1.3	<1.4	<1.3	41	0
Chromium	23	20	23	22	27	0	27	20	20	22	50	0
Cobalt <sup>5</sup>	15	14	16	15	29	0	16	14	13	14	27	0
Copper	120	47	49	72	91	0	42	47	43	44	20	0
Lead	23	22	21	22	28	0	45	29	30	35	68	0
Manganese	100	83	180	121	111	0	150	96	100	115	68	0
Mercury	<0.020	<0.020	<0.020	<0.020	44	0	0.15	0.32	0.27	0.25	91	0
Molybdenum <sup>4</sup>	4.5	<4.3	<3.9	<4.3	37	0	4.6	7.8	7.5	6.6	70	0
Nickel	15	13	19	16	44	0	17	16	10	14	69	0
Selenium <sup>3</sup>	<11	23	<9.7	11	233	0	18	<13	7.8	11	148	0
Phosphorus	5,100	5,900	5,900	5,630	27	0	3,900	4,600	4,300	4,270	22	0
Vanadium	49	50	54	51	28	0	57	46	45	49	31	0
Calcium <sup>1,6</sup>	19,700	23,700	21,400	21,600	28		22,000	160,000	150,000	155,500	26	
Sodium <sup>1,6</sup>	1,320	1,370	1,310	1,340	33		63,000	2,600	1,700	2,150	27	
<b>Acid-Forming Anions</b>												
	mg/kg						mg/kg					
Chloride as Cl <sup>-</sup>	240	262	214	238	29	0	120	82	72	91	72	0
Fluoride as F <sup>(2)</sup>	6.9	6.2	5.1	6.1	34	0	1,100	73	72	1,100	N/A	0
Sulfate	186	260	1,680	710	297	0	66,500	49,400	59,900	58,600	33	0

- "<" indicates that the quantity measured was less than the detection limit, thus the detection limit is shown. 5. #1-Bottom Ash was higher than fuel input and not used in average.
- Replicates for #1-Fly Ash for Ba, Ca, and S not used in average, since not consistent with expected values. 6. Included even though neither are trace metals nor air toxics.
  - F1 results for #2- and #3-Fly Ash not used in average because of incomplete water extraction. 7. Trace metals results from bottom ash solid fraction only. For anions, Ca, and Na, solid and liquid fractions analyzed separately and combined proportionately by weight after sluice water blank corrections
  - Since detection limits varied by sample, highest non-detect not used for average.
  - Highest non-detect used for bottom ash average.

**Table 22: Air Toxics Analysis of Ash for Calcium-Based DSI**

## **F. Mass Balance Results**

Mass balances are an important quality check on toxics emissions data. Using different sample and analytical techniques to measure toxics in both gaseous and solid forms is difficult. Mass balances provide a quick means for determining how well various analytical methods agree. The low absolute quantities of the measured materials, however, makes the occurrence of a 100% mass balance very unlikely.

There are three major sources of potential error in the mass balance: operating conditions, analytical difficulties, and sample collection and handling. Since Arapahoe Unit 4 operated at or near steady-state conditions and the daily tests show that the same coal was fired throughout the tests, operating conditions are not likely to contribute any significant sources of error. Analytical difficulties usually only affect the results of individual replicates or species, so they are considered with each species. Normally, analytical difficulties outweigh sampling problems. On a utility coal-fired unit, however, obtaining representative samples from process streams flowing at thousands of pounds per hour adds a major source of potential error. It should also be noted that uncertainties only represent consistency, not accuracy.

In addition, recent findings from other Department of Energy (DOE) sponsored programs indicate that the sample digestion methods of EPA Method 29 are not effective for large quantities of ash and introduce a 20 to 60% negative bias. The difficulty of finding a correct digestion method and the need for different digestion methods for different elements casts doubt on the validity of the sample preparation procedures of both EPA Method 29 and the ASTM methods which use only one digestion method for all elements.

Only compounds dependent on the fuel inputs can be balanced. Since semi-volatile organic compounds depend on combustion parameters, they cannot be balanced. The boiler/FFDC mass balance uses the coal and calcium-based sorbent as its inputs and the bottom ash, fly ash, and FFDC outlet as its outputs. The boiler mass balance uses the coal for its only input and the FFDC inlet and the bottom ash as its outputs. For the sorbent results, nondetects are treated as zeroes if the detection limit is greater than 25% of the fuel input (selenium, for instance) or if the element is not expected to exist in the sorbent (arsenic and mercury, for example).

Table 23 shows the mass balance results for the calcium-based DSI test period. Based on fuel-input and fly ash levels, the FFDC results for mercury appear to be positively biased. For the boiler/FFDC balance, most species were in the range of 69 to 130%, except for barium, cobalt, and phosphorous. The following may have affected the results for these elements:

- Since the fuel input for barium is considered accurate, the barium levels in the ash are considered negatively biased by 30 to 40%.
- The fuel input for cobalt appears to be biased low.
- Since previous tests produced good closure for phosphorous, the phosphorous levels in the sorbent may be biased low. The phosphorous levels in the bottom ash, however, are higher than those in previous tests, so these values may also be causing the poor closure results.

Species	Inputs		Intermediate	Outputs			Mass Balance	
	Fuel	DSI <sup>1</sup> (Calcium)	FFDC Inlet	Bottom Ash	Fly Ash	FFDC Outlet	Boiler/ FFDC <sup>2</sup>	Boiler <sup>2</sup>
Trace Metals	lb/10 <sup>12</sup> Btu		lb/10 <sup>12</sup> Btu	lb/10 <sup>12</sup> Btu			%	
Arsenic <sup>3</sup>	47	<3.4	20	<4.4	30	0.093	75	52
Barium	17,400	26	NV	3,580	7,300	0.94	62	--
Beryllium	32	<1.4	9.5	13	22	<0.022	105	72
Cadmium <sup>3</sup>	5.4	<3.4	3.9	<3.9	<8.8	0.15	--	72
Chromium	224	14	63	79	157	0.26	99	63
Cobalt	93	<14	53	54	101	<0.22	144	115
Copper	396	14	310	172	308	0.42	117	122
Lead	310	<2.1	55	79	244	0.38	104	43
Manganese	1,450	123	108	448	812	0.59	80	38
Mercury <sup>3</sup>	2.7	<0.25	3.4	<0.072	1.7	0.21	74	128
Molybdenum	38	18	26	<15	46	0.22	110	108
Nickel	141	15	19	57	102	0.22	102	54
Selenium <sup>3</sup>	115	<174	57	38	77	<0.057	100	83
Phosphorus	35,200	532	12,800	20,300	29,800	<1.1	140	94
Vanadium	565	22	194	183	346	<0.11	90	67
<b>Average Metals</b>							<b>100</b>	<b>79</b>
Calcium <sup>4</sup>	205,000	1.47(10 <sup>6</sup> )	NV	77,300	1.08(10 <sup>6</sup> )	106	69	--
Sodium	27,400	522	NV	4,780	15,000	13	71	--
Acid-Forming Anions	lb/10 <sup>12</sup> Btu		lb/10 <sup>12</sup> Btu	lb/10 <sup>12</sup> Btu			%	
Chloride (Cl <sup>-</sup> ) <sup>3</sup>	1,720	712	825	848	645	371	77	98
Fluoride (F <sup>-</sup> )	6,650	122	6,700	21	7,680	167	116	101
Sulfate	1.59(10 <sup>6</sup> )	3,670	1.58(10 <sup>6</sup> )	2,790	410,000	990,000	88	100
<b>Average Anions</b>							<b>94</b>	<b>100</b>

"<" indicates that the quantity measured was less than the detection limit; thus the detection limit is shown.

"NP" indicates not performed, "NV" indicates not valid.

- Sorbent input stream includes trace metal and anion levels in both the calcium sorbent and the sorbent water.
- Boiler/FFDC mass balance calculated using: (outlet + fly ash + bottom ash)/(fuel + sorbent). Boiler mass balance calculated using: (inlet + bottom ash)/fuel.
- Fuel concentrations from INAA.
- Calcium sorbent flow rate as {(weight% of Ca) \* (Ca flow rate) \* (10<sup>6</sup>)} + (sorbent H<sub>2</sub>O flow rate).

**Table 23: Mass Balance Results for Calcium-Based DSI Test Period**

## **G. Summary of Test Results**

Table 24 summarizes the fuel input, FFDC inlet, and FFDC outlet results for each of the test periods. Yampa coal was fired at Arapahoe Unit 4 for low-NO<sub>x</sub> combustion, SNCR, and sodium-based DSI test periods. For the calcium-based DSI test period, Edna coal was fired at Arapahoe Unit 4. It is not clear whether the significantly higher values for many trace metals in the coal tested during the sodium- and calcium-based DSI test periods is due to more representative techniques or the coal matrix. The higher levels in the FFDC of these trace metals, however, indicates that changes in the coal matrix caused the higher levels in the fuel input.

The increase of the trace metal levels in the FFDC inlet are consistent with the fuel input levels. However, if the FFDC inlet is considered as a point of uncontrolled emissions, the emissions levels are consistently in the same range.

Improved FFDC removal efficiency with sorbent injection may account for the lower levels of chromium, copper, manganese, nickel, and vanadium in the sodium- and calcium-based DSI test periods. Both sodium and calcium injection before the FFDC significantly reduced the FFDC outlet levels of phosphorous, chloride, fluoride, and sulfate. The lower levels of arsenic, mercury, and selenium suggest that calcium injection removes these elements more effectively than sodium injection.

Parameter	Fuel Input				FFDC Inlet				FFDC Outlet			
	Low-NO <sub>x</sub> Combustion	SNCR	DSI (Sodium)	DSI (Calcium)	Low-NO <sub>x</sub> Combustion	SNCR	DSI (Sodium)	DSI (Calcium)	Low-NO <sub>x</sub> Combustion	SNCR	DSI (Sodium)	DSI (Calcium)
	lb/10 <sup>12</sup> Btu											
Arsenic	43	56	62	47	23	13	30	20	0.75	0.15	0.47	0.093
Barium	37,600	29,700	24,400	17,400	234	192	189	431	1.1	1.1	2.5	0.94
Beryllium	20	48	34	32	9.0	7.5	9.0	9.5	<0.021	<0.023	<0.023	<0.022
Cadmium	<4.5	<5.3	3.5	5.4	2.3	2.0	3.6	3.9	0.12	<0.066	<0.058	0.15
Chromium	97	125	272	224	50	51	135	63	0.66	0.30	0.15	0.26
Cobalt	84	114	122	93	30	26	43	53	<0.21	<0.23	<0.23	<0.22
Copper	241	324	568	396	169	206	245	310	1.1	1.3	0.59	0.42
Lead	185	195	358	310	64	46	80	55	0.44	0.40	0.36	0.38
Manganese	379	458	2,340	1,450	195	88	113	108	1.0	0.89	0.29	0.59
Mercury	1.9	1.7	4.6	2.7	1.3	1.9	1.2	3.4	<0.29	0.41	0.41	0.21
Molybdenum	9.0	44	45	38	10	12	32	26	0.17	0.27	0.23	0.22
Nickel	53.5	88	175	141	30	29	62	19	1.5	0.45	0.23	0.22
Selenium	73	127	47	115	22	12	<66	57	0.36	<0.064	0.36	<0.057
Phosphorous	36,700	27,700	48,500	35,200	14,300	9,300	11,600	12,800	6.7	4.6	1.5	<1.1
Vanadium	266	379	779	565	135	120	178	194	0.24	0.29	0.13	<0.11
Calcium	NP	185,000	213,000	205,000	NP	880	192	1,240	NP	29	33	106
Sodium	NP	29,300	64,300	27,400	NP	2,700	1,750	2,580	NP	367	112	13
Chloride	2,000	1,400	1,370	1,720	795	1,010	864	825	626	719	811	371
Fluoride	7,600	7,400	9,140	6,650	4,780	5,780	7,670	6,700	4,290	4,810	1140	167
Sulfate	1.18(10 <sup>6</sup> )	1.15(10 <sup>6</sup> )	1.17(10 <sup>6</sup> )	1.59(10 <sup>6</sup> )	10.6(10 <sup>6</sup> )	9.88(10 <sup>6</sup> )	1.14(10 <sup>6</sup> )	1.58(10 <sup>6</sup> )	9.83(10 <sup>6</sup> )	1.17(10 <sup>6</sup> )	3.69(10 <sup>6</sup> )	9.9(10 <sup>6</sup> )
Cyanide	N/A	N/A	N/A	N/A	<8	<12	NP	NP	<7	<9	NP	NP
Ammonia	N/A	N/A	N/A	N/A	<100	12,000	NP	NP	N/A	7,000	NP	NP

"<" indicates that the quantity measured was less than the detection limit thus the detection limit is shown.  
 "NP" indicates test not performed.

Table 24: Summary of Fuel Input, FFDC Inlet, and FFDC Outlet Levels

Table 25 compares the trace metal levels in the output streams as a percentage of the fuel input. A larger distribution of the trace metals in the bottom ash improved the mass balances for the sodium- and calcium-based DSI test periods. The bottom ash levels for the SNCR test period appear negatively biased by 15% of fuel input. For the low-NO<sub>x</sub> combustion test period, the bottom ash levels appear negatively biased by 20% of fuel input and the fly ash levels appear negatively biased by 15% of fuel input. The use of the same collection methods for all four test periods suggests that the closer adherence to ASTM preparation methods during the sodium- and calcium-based DSI test periods improved the trace metal results. Also, the use of more representative sampling techniques for fly ash during these test periods appears to have reduced the occurrence of poor trace metal results seen during the low-NO<sub>x</sub> combustion test period.

Test Period	Output Stream (% of Fuel Input <sup>1</sup> )			Total (% Closure)
	Bottom Ash	Fly Ash	FFDC Outlet	
Low-NO <sub>x</sub> Combustion <sup>2</sup>	9	53	2	64
SNCR	14	67	2	83
DSI (Sodium)	28	63	1	92
DSI (Calcium)	31	68	1	100

1. Fuel input for sodium- and calcium-based DSI test periods include the sorbent injection streams.
2. The fuel result for molybdenum appears to be severely biased low. The percentages for the low-NO<sub>x</sub> combustion test period are based on an average of the molybdenum levels in the fuels from the SNCR and sodium-based DSI test periods.

**Table 25: Distribution of Trace Metals Across Output Streams**

**INTEGRATED DRY NO<sub>x</sub>/SO<sub>2</sub> EMISSIONS CONTROL SYSTEM**

**ENVIRONMENTAL MONITORING REPORT**

**Calcium-Based Dry Sorbent Injection System Test Period:**

**April 30, 1993 through November 2, 1993**

**Calcium DSI Air Toxics Test October 19-20, 1993**

**Dioxins/Furans Air Toxics Test October 11-13, 1993**

**Appendix A: State Emission Reports**



**Opacity Compliance Calculation**

Table 26 summarizes the number of 6-minute opacity exceedances reported to the CDH during the testing period. These data are from the compliance reports sent to the CDH that follow.

Month	Number of Violations
April 30	0
May	5
June	2
July	0
August	5
September	14
October 1-20	5
Total	31

There were a total of 31 exceedances for a total of 186 minutes above 20% opacity. The calculation used to compute the Arapahoe 4's compliance with the 20% opacity limit is shown below.

**Table 26: Summary of Opacity Violations**

$$\begin{aligned}
 \% \text{compliance} &= 100 - \left( \frac{\text{compliance time}}{\text{operation time}} \times 100 \right) \\
 &= 100 - \left( \frac{186 \text{ min} \times \frac{1 \text{ h}}{60 \text{ min}}}{2,108.3 \text{ h} - \left( 28 \text{ days} \times \frac{24 \text{ h}}{\text{day}} \right) - \left( 1 \text{ day} \times \frac{23 \text{ h}}{\text{day}} \right) + 1,979 \text{ h} + \left( 20 \text{ days} \times \frac{24 \text{ h}}{\text{day}} \right)} \times 100 \right) \\
 &= 100 - 0.08005 \\
 &= 99.92\%
 \end{aligned}$$



Public Service  
Company of Colorado  
P.O. Box 840  
Denver, CO 80201-0840

July 29, 1993

Mr. Roy Doyle  
Air Pollution Control Division  
Colorado Department of Health  
4300 Cherry Creek Drive South  
Denver, CO 80222-1530

RE: Second Quarter, 1993 Excess Emissions Report, Arapahoe Units #1-4

Dear Roy:

Attached is the excess emissions report for the second quarter, 1993, for the Public Service Company of Colorado Arapahoe Steam Electric Generating Station, Units #1-4.

Dates not reported on the attached emissions report are those in which the units were not running. The operating hours for Units #1-4 during the quarter were: Unit #1 - 1,498.8 hours, Unit #2 - 1,508.9 hours, Unit #3 - 1,405.5 hours and Unit #4 - 2,108.3 hours.

Feel free to contact me at 294-2810 with any questions in this regard.

Sincerely,

Peter J. Cohlma  
Chief Environmental Scientist

PJC:tc

Attachments

**QUARTERLY EXCESS EMISSIONS REPORT (EER)**

**Fossil Fuel-Fired Steam Generators, Subpart D  
Suggested Format for Sources in Region VIII\*  
Minimum Requirements Under Section 60.7 (see instructions)**

**Part 1 - This report includes all the required information under section 60.7 for**

- a. Quarterly emission reporting period ending:  
March 31 (June 30) September 30 December 31
- b. Reporting year: 1993
- c. Reporting date: 07/14/93
- d. Person completing report: Mark Spomer
- e. Station name: Arapahoe Station
- f. Plant location: 2601 South Platte River Drive
- g. Person responsible for review and integrity of report: Peter J. Cohlma
- h. Mailing address for person in 1-g above:  
P. O. Box 840, Denver, Colorado 80201
- i. Phone number for 1-g above: 294-2810

**Part 2 - Instrument information, complete for each instrument.**

a. Opacity Monitor:	Unit 1	Unit 2	Unit 3	Unit 4
b. Manufacture:	Lear Siegler	L.S.	L.S.	L.S.
c. Model No:	RM41	RM41	RM41	RM41
d. Serial No:	568	1409	1369	997
e. Installation:	1/77	6/79	6/79	7/79

**Part 3 - Excess emissions (by pollutant)**

**Use Table I: Attach separate narrative per instructions.**

Part 4 - Conversion factors

a. Zero and Cal values used, by instruments:

	Unit 1	Unit 2	Unit 3	Unit 4
Zero	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
Cal	<u>52.5</u>	<u>51.7</u>	<u>58.0</u>	<u>48.5</u>

Part 5 - Continuous Monitoring System operation failures

See Table II: Complete one sheet for each monitor  
attach separate narrative per instructions.

Part 6 - Certification of report integrity, by per in 1-g above:

THIS IS TO CERTIFY THAT TO THE BEST OF MY KNOWLEDGE, THE  
INFORMATION PROVIDED IN THE ABOVE REPORT IS COMPLETE AND ACCURATE.

NAME Peter J. Cohlma

SIGNATURE Peter J. Cohlma

Title Chief Environmental Scientist

Date 7/29/93

• Suggested Format for Subpart D sources in:

Colorado, Montana, North Dakota, South Dakota, Utah, Wyoming

TABLE I

Excess Emissions

Date	Time* From - To	Pollutant	Magnitude* Lb/106 BTU
------	-----------------	-----------	-----------------------

SO<sup>2</sup>

No violations

Opacity

Attached is additional information for excesses occurring during the ~~1st~~ Quarter  
*2nd*

- As defined in the instructions form the applicable section of the Federal Register; attached narrative of causes, etc.

Continuous Monitoring System Operation Failures

<u>Date</u>	<u>Time* From - To</u>	<u>Instrument</u>	<u>Effect on Instrument Output</u>
5/17/93	0815 to 5/17/93 0900	Lear Siegler	Removed for calibration

\*\*\*\*\*  
OPACITY MONTHLY DATA REPORT  
\*\*\*\*\*

POWER PLANT: ARAPAHOE  
UNIT: 4 SOURCE - CURRENT  
REPORT START TIME: QUARTER = 2 4/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
4/01	0	0	0	0	0	24	3.4
4/02	0	0	0	0	0	24	3.4
4/03	0	0	0	0	0	24	3.4
4/04	0	0	0	0	0	23	3.2
4/05	0	0	0	0	0	24	3.1
4/06	0	0	0	0	0	24	3.4
4/07	0	0	0	0	0	24	3.6
4/08	0	0	0	0	0	24	3.5
4/09	0	0	0	0	0	24	3.3
4/10	0	0	0	0	0	24	3.5
4/11	0	0	0	0	0	24	3.3
4/12	0	0	0	0	0	24	3.6
4/13	0	0	0	0	0	24	3.4
4/14	0	0	0	0	0	24	3.4
4/15	0	0	0	0	0	24	3.3
4/16	0	0	0	0	0	24	3.3
4/17	0	0	0	0	0	24	3.3
4/18	0	0	0	0	0	24	3.5
4/19	0	0	0	0	0	24	3.5
4/20	0	0	0	0	0	24	3.3
4/21	0	0	0	0	0	24	3.3
4/22	0	0	0	0	0	24	3.5
4/23	0	0	0	0	0	24	3.7
4/24	0	0	0	0	0	24	3.6
4/25	0	0	0	0	0	24	3.4
4/26	0	0	0	0	0	24	3.6
4/27	0	0	0	0	0	24	3.4
4/28	0	0	0	0	0	24	3.4
4/29	0	0	0	0	0	24	3.5
4/30	0	0	0	0	0	24	3.4

-----  
MONTHLY TOTALS      0            0            0            0            0            719            3.4

REPORT COMPLETE

\*\*\*\*\*  
 OPACITY MONTHLY DATA REPORT  
 \*\*\*\*\*

POWER PLANT: ARAPAHOE  
 UNIT: 4 SOURCE - CURRENT  
 REPORT START TIME: QUARTER - 2 5/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
5/01	0	0	0	0	0	24	3.4
5/02	0	0	0	0	0	24	3.4
5/03	0	0	0	0	0	24	3.7
5/04	0	0	0	0	0	24	3.6
5/05	0	0	0	0	0	24	3.5
5/06	0	0	0	0	0	24	3.3
5/07	0	0	0	0	0	24	3.3
5/08	4	0	0	1	0	24	5.5
5/09	0	0	0	0	0	24	3.4
5/10	0	0	0	0	0	24	3.5
5/11	0	0	0	0	0	24	3.4
5/12	0	0	0	0	0	24	3.3
5/13	0	0	0	0	0	24	3.6
5/14	0	0	0	0	0	24	4.4
5/15	0	0	0	0	0	24	4.7
5/16	0	0	0	0	0	24	4.5
5/17	0	0	0	0	0	24	4.3
5/18	0	0	0	0	0	24	4.0
5/19	0	0	0	0	0	24	4.3
5/20	0	0	0	0	0	24	4.2
5/21	0	0	0	0	0	24	4.4
5/22	0	0	0	0	0	24	4.5
5/23	0	0	0	0	0	24	4.2
5/24	0	0	0	0	0	24	4.1
5/25	0	0	0	0	0	24	4.1
5/26	0	0	0	0	0	24	4.1
5/27	0	0	0	0	0	24	4.5
5/28	0	0	0	0	0	24	4.3
5/29	0	0	0	0	0	24	4.1
5/30	0	0	0	0	0	24	4.4
5/31	0	0	0	0	0	24	4.4
MONTHLY TOTALS	4	0	0	1	0	744	4.0

REPORT COMPLETE



\*\*\*\*\*  
OPACITY MONTHLY DATA REPORT  
\*\*\*\*\*

POWER PLANT: ARAPAHOE  
UNIT: 4 SOURCE - CURRENT  
REPORT START TIME: QUARTER - 2 6/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
6/01	0	0	0	0	0	24	4.3
6/02	0	0	0	0	0	24	4.2
6/03	0	0	0	0	0	24	4.2
6/04	0	0	0	0	0	24	4.2
6/05	0	0	0	0	0	24	6.9
6/06	0	0	0	0	0	24	3.7
6/07	0	0	0	0	0	24	4.2
6/08	0	0	0	0	0	24	3.5
6/09	0	0	0	0	0	24	4.0
6/10	0	0	0	0	0	24	3.3
6/11	0	0	0	0	0	24	3.6
6/12	0	0	0	0	0	24	3.4
6/13	0	0	0	0	0	24	3.6
6/14	0	0	0	0	0	24	3.4
6/15	0	0	0	0	0	24	3.7
6/16	0	0	0	0	0	24	3.6
6/17	0	0	0	0	0	24	3.9
6/18	0	0	0	0	0	24	4.3
6/19	0	0	2	0	0	24	3.6
6/20	0	0	0	0	0	24	3.2
6/21	0	0	0	0	0	24	3.3
6/22	0	0	0	0	0	24	3.3
6/23	0	0	0	0	0	24	3.3
6/24	0	0	0	0	0	24	3.5
6/25	0	0	0	0	0	24	3.4
6/26	0	0	0	0	0	24	3.2
6/27	0	0	0	0	0	24	3.3
6/28	0	0	0	0	0	24	3.5
6/29	0	0	0	0	0	24	3.4
6/30	0	0	0	0	0	24	3.4

-----  
MONTHLY TOTALS      0            0            2            0            0            720            3.7

REPORT COMPLETE

\*\*\*\*\*  
 OPACITY Violation Report  
 \*\*\*\*\*

POWER PLANT: ARAPAHOE  
 Unit: 4 Source - CURRENT  
 Report Period: Quarter = 2 1993

REASON CODES FOR:  
 HOURLY EXCLUSIONS = none  
 UPSET EXCLUSIONS = none

START DATE-TIME	END DATE-TIME	MIN-Z	MAX-Z	AVG-Z	TYPE	VIOLATION REASON
05/08/1993 12:12	05/08/1993 12:17	21.8	21.8	21.8	VIO	UNIT STARTUP
05/08/1993 12:30	05/08/1993 12:41	21.0	38.0	29.5	VIO	UNIT STARTUP
05/08/1993 12:54	05/08/1993 13:05	24.3	25.0	24.6	VIO	UNIT STARTUP
05/14/1993 11:54	05/14/1993 12:05	36.3	40.1	38.2	VIO	UNSPECIFIED CALIB/NOT CALIB
06/19/1993 04:00	06/19/1993 04:11	30.4	31.7	31.1	VIO	UNIT STARTUP



Public Service  
Company of Colorado  
Governmental and  
Environmental Affairs  
P. O. Box 840  
Denver, CO 80201 - 0840

October 28, 1993

Mr. Roy Doyle  
Air Pollution Control Division  
Colorado Department of Health  
4300 Cherry Creek Drive South  
Denver, CO 80222-1530

RE: Third Quarter, 1993 Excess Emissions Report, Arapahoe Units #1-4


Dear Roy:

Attached is the excess emissions report for the third quarter, 1993, for the Public Service Company of Colorado Arapahoe Steam Electric Generating Station, Units #1-4.

Dates not reported on the attached emissions report are those in which the units were not running. The operating hours for Units #1-4 during the quarter were: Unit #1 - 740.5 hours, Unit #2 - 679.2 hours, Unit #3 - 932.3 hours and Unit #4 - 1,979 hours.

Feel free to contact me at 294-2810 with any questions in this regard.

Sincerely,

  
Peter J. Cohlma  
Chief Environmental Scientist

PJC:tc

Attachments

SO<sub>2</sub> .861  
from Marilyn

QUARTERLY EXCESS EMISSIONS REPORT (EER)

Fossil Fuel-Fired Steam Generators, Subpart D  
Suggested Format for Sources in Region VIII\*  
Minimum Requirements Under Section 60.7 (see instructions)

Part 1 - This report includes all the required information under section 60.7 for

- a. Quarterly emission reporting period ending:  
March 31    June 30 (September 30)    December 31
- b. Reporting year: 1993
- c. Reporting date: 10/14/93
- d. Person completing report: Mark Spomer
- e. Station name: Arapahoe Station
- f. Plant location: 2601 South Platte River Drive
- g. Person responsible for review and integrity of report: Peter J. Cohlma
- h. Mailing address for person in 1-g above:  
P. O. Box 840, Denver, Colorado 80201
- i. Phone number for 1-g above: 294-2810

Part 2 - Instrument information, complete for each instrument.

a. Opacity Monitor:	Unit 1	Unit 2	Unit 3	Unit 4
b. Manufacture:	Lear Siegler	L.S.	L.S.	L.S.
c. Model No:	RM41	RM41	RM41	RM41
d. Serial No:	568	1409	1369	997
e. Installation:	1/77	6/79	6/79	7/79

Part 3 - Excess emissions (by pollutant)

Use Table I: Attach separate narrative per instructions.

**Part 4 - Conversion factors**

a. Zero and Cal values used, by instruments:

	Unit 1	Unit 2	Unit 3	Unit 4
Zero	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
Cal	<u>52.5</u>	<u>51.7</u>	<u>58.0</u>	<u>48.5</u>

**Part 5 - Continuous Monitoring System operation failures**

See Table II: Complete one sheet for each monitor  
attach separate narrative per instructions.

**Part 6 - Certification of report integrity, by per in 1-g above:**

THIS IS TO CERTIFY THAT TO THE BEST OF MY KNOWLEDGE, THE  
INFORMATION PROVIDED IN THE ABOVE REPORT IS COMPLETE AND  
ACCURATE.

NAME Peter J. Cohlma

SIGNATURE *Peter J. Cohlma*

Title Chief Environmental Scientist

Date 10/28/93

\* Suggested Format for Subpart D sources in:

Colorado, Montana, North Dakota, South Dakota, Utah, Wyoming

TABLE I

Excess Emissions

Date Time\* From -- To Pollutant Magnitude\* Lb/106 BTU

SO<sup>2</sup>

No violations

Opacity

Attached is additional information for excesses occurring during the Third Quarter

\* As defined in the instructions form the applicable section of the Federal Register; attached narrative of causes, etc.

## Continuous Monitoring System Operation Failures

<u>Date</u>	<u>Time* From -- To</u>	<u>Instrument</u>	<u>Effect on Instrument Output</u>
7/14/93	0900 to 7/14 1545	#3 L.S.	Calib. and filter audit
7/28/93	0755 to 7/28 1400	#2 L.S.	Calib. and filter audit
9/10/93	0800 to 9/13 1423	#1 L.S.	Calib. and filter audit
9/27/93	0640 to 9/27 1355	#4 L.S.	Calib. and filter audit

\*\*\*\*\*  
 -----  
 OPACITY MONTHLY DATA REPORT  
 -----  
 \*\*\*\*\*

POWER PLANT: ARAPAHOE  
 UNIT: 4 SOURCE = CURRENT  
 REPORT START TIME: QUARTER = 3 7/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
7/01	0	0	0	0	0	24	3.1
7/02	0	0	0	0	0	24	3.1
7/03	0	0	0	0	0	24	3.6
7/04	0	0	0	0	0	24	3.3
7/05	0	0	0	0	0	24	3.4
7/06	0	0	0	0	0	24	3.1
7/07	0	0	0	0	0	24	3.3
7/08	0	0	0	0	0	24	3.5
7/09	0	0	0	0	0	24	3.4
7/10	0	0	0	0	0	24	2.9
7/11	0	0	0	0	0	24	3.6
7/12	0	0	0	0	0	24	3.2
7/13	0	0	0	0	0	24	3.9
7/14	0	0	0	0	0	24	4.4
7/15	0	0	0	0	0	24	4.3
7/16	0	0	0	0	0	24	4.1
7/17	0	0	0	0	0	24	4.3
7/18	0	0	0	0	0	24	3.9
7/19	0	0	0	0	0	24	4.3
7/20	0	0	0	0	0	24	4.4
7/21	0	0	0	0	0	24	4.0
7/22	0	0	0	0	0	24	4.0
7/23	0	0	0	0	0	24	4.3
7/24	0	0	0	0	0	24	4.3
7/25	0	0	0	0	0	24	3.9
7/26	0	0	0	0	0	24	3.8
7/27	0	0	0	0	0	24	4.0
7/28	0	0	0	0	0	24	4.0
7/29	0	0	0	0	0	24	4.2
7/30	0	0	0	0	0	24	4.2
7/31	0	0	0	0	0	24	3.9

-----  
 MONTHLY TOTALS 0 0 0 0 0 744 3.8

REPORT COMPLETE



\*\*\*\*\*  
 -----  
 OPACITY MONTHLY DATA REPORT  
 -----  
 \*\*\*\*\*

POWER PLANT: ARAPAHOE  
 UNIT: 4 SOURCE = CURRENT  
 REPORT START TIME: QUARTER = 3 8/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
8/01	0	0	0	0	0	24	4.2
8/02	0	0	0	0	0	24	4.4
8/03	0	0	0	0	0	24	4.8
8/04	0	0	0	0	0	24	4.3
8/05	0	0	0	0	0	24	4.2
8/06	0	0	0	0	0	24	4.2
8/07	0	0	0	0	0	24	3.9
8/08	0	0	0	0	0	24	3.9
8/09	0	0	0	0	0	24	3.8
8/10	0	0	0	0	0	24	4.3
8/11	0	0	0	0	0	24	4.2
8/12	0	0	0	0	0	24	4.6
8/13	0	0	0	0	0	24	4.4
8/14	0	0	0	0	0	24	4.1
8/15	0	0	0	0	0	24	4.0
8/16	0	0	0	0	0	24	4.0
8/17	0	0	0	0	0	24	3.9
8/18	0	0	0	0	0	24	4.5
8/19	0	0	0	0	0	24	4.3
8/20	0	0	0	0	0	24	4.5
8/21	0	0	0	0	0	24	4.0
8/22	0	0	0	0	0	24	3.7
8/23	0	0	0	0	0	24	3.6
8/24	0	0	0	0	0	24	3.4
8/25	0	0	0	0	0	24	3.6
8/26	0	0	0	0	0	24	4.3
8/27	0	0	0	0	0	23	5.9
8/28	0	0	0	0	0	24	5.6
8/29	0	2	1	1	1	24	5.9
8/30	0	0	0	0	0	24	4.9
8/31	0	0	0	0	0	24	4.9

-----  
 MONTHLY TOTALS 0 2 1 1 1 743 4.3

REPORT COMPLETE

\*\*\*\*\*  
-----OPACITY-MONTHLY-DATA-REPORT-----  
\*\*\*\*\*

POWER PLANT: ARAPAHOE  
UNIT: 4 SOURCE = CURRENT  
REPORT START TIME: QUARTER = 3 9/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
9/01	0	0	0	0	0	24	5.0
9/02	0	0	0	0	0	24	4.9
9/03	0	0	0	0	0	24	4.8
9/04	0	0	0	0	0	24	5.2
9/05	0	0	0	0	0	24	5.1
9/06	0	0	0	0	0	24	4.9
9/07	0	0	0	0	0	24	5.4
9/08	0	0	0	0	0	24	5.3
9/09	0	0	0	0	0	24	5.2
9/10	0	0	0	0	0	24	5.3
9/11	0	0	0	0	0	24	5.4
9/12	0	0	0	0	0	24	5.3
9/13	0	0	0	0	0	24	5.5
9/14	0	0	0	0	0	24	5.3
9/15	0	0	0	0	0	24	5.3
9/16	0	0	0	0	0	24	5.6
9/17	0	0	0	0	0	24	5.3
9/18	0	0	0	0	0	24	5.1
9/19	0	0	0	0	0	24	4.8
9/20	0	0	0	0	0	24	5.2
9/21	0	0	0	0	0	24	5.4
9/22	0	0	0	0	0	24	5.4
9/23	1	3	0	1	0	24	5.9
9/24	3	1	1	2	2	24	6.8
9/25	0	0	0	0	0	24	5.1
9/26	0	0	0	0	0	24	5.4
9/27	0	0	0	0	0	20	3.3
9/28	0	0	0	0	0	24	0.9
9/29	0	0	0	0	0	24	1.1
9/30	0	0	0	0	0	24	1.1

-----  
MONTHLY TOTALS    4            4            1            3            2            716            4.8

REPORT COMPLETE

\*\*\*\*\*  
OPACITY Violation Report  
\*\*\*\*\*

POWER PLANT: ARAPAHOE  
 Unit: 4 Source = CURRENT  
 Report Period: Quarter = 3 1993

REASON CODES FOR:  
 HOURLY EXCLUSIONS = none  
 UPSET EXCLUSIONS = none

START DATE-TIME	END DATE-TIME	MIN-%	MAX-%	AVG-%	TYPE	VIOLATION REASON
07/13/1993 15:00	07/13/1993 15:05	36.1	36.1	36.1	VIO	CALLS - NOT COUNTED
08/29/1993 15:00	08/29/1993 15:05	29.6	29.6	29.6	VIO	UNIT STARTUP
08/29/1993 17:00	08/29/1993 17:23	29.1	45.3	35.8	VIO	UNIT STARTUP
09/23/1993 11:36	09/23/1993 12:05	22.9	36.9	28.9	VOF	UNIT SHUTDOWN
09/24/1993 02:24	09/24/1993 02:29	59.6	59.6	59.6	VIO	UNIT STARTUP
09/24/1993 02:36	09/24/1993 03:11	21.4	50.8	35.4	VIO	UNIT STARTUP
09/24/1993 04:36	09/24/1993 04:41	22.0	22.0	22.0	VIO	UNIT STARTUP
09/24/1993 05:06	09/24/1993 05:11	29.8	29.8	29.8	VIO	COAL MILL OPERATION
09/27/1993 13:06	09/27/1993 13:11	44.8	44.8	44.8	VIO	CALLS & AUDIT NOT COUNTED



Public Service  
Company of Colorado  
Governmental and  
Environmental Affairs  
P. O. Box 840  
Denver, CO 80201 - 0840

January 27, 1994

Mr. Roy Doyle  
Air Pollution Control Division  
Colorado Department of Health  
4300 Cherry Creek Drive South  
Denver, CO 80222-1530

**RE: Fourth Quarter, 1993 Excess Emissions Report, Arapahoe Units #1-4**

Dear Roy:

Attached is the excess emissions report for the fourth quarter, 1993, for the Public Service Company of Colorado Arapahoe Steam Electric Generating Station, Units #1-4.

Dates not reported on the attached emissions report are those in which the units were not running. The operating hours for Units #1-4 during the quarter were: Unit #1 - 2,033.7 hours, Unit #2 - 2,068.2 hours, Unit #3 - 2,070.3 hours and Unit #4 - 2,181.9 hours.

Feel free to contact me at 294-2810 with any questions in this regard.

Sincerely,

A handwritten signature in cursive script that reads "Peter J. Cohlma".

Peter J. Cohlma  
Chief Environmental Scientist

PJC:tc

Attachments

QUARTERLY EXCESS EMISSIONS REPORT (EER)

Fossil Fuel-Fired Steam Generators, Subpart D  
Suggested Format for Sources in Region VIII\*  
Minimum Requirements Under Section 60.7 (see instructions)

Part 1 - This report includes all the required information under section 60.7 for

- a. Quarterly emission reporting period ending:  
March 31 June 30 September 30 (December 31)
- b. Reporting year: 1993
- c. Reporting date: 01/12/94
- d. Person completing report: Mark Spomer
- e. Station name: Arapahoe Station
- f. Plant location: 2601 South Platte River Drive
- g. Person responsible for review and integrity of report: Peter J. Cohlma
- h. Mailing address for person in 1-g above:  
P. O. Box 840, Denver, Colorado 80201
- i. Phone number for 1-g above: 294-2810

Part 2 - Instrument information, complete for each instrument.

a. Opacity Monitor:	Unit 1	Unit 2	Unit 3	Unit 4
b. Manufacture:	Lear Siegler	L.S.	L.S.	L.S.
c. Model No:	RM41	RM41	RM41	RM41
d. Serial No:	568	1409	1369	997
e. Installation:	1/77	6/79	6/79	7/79

Part 3 - Excess emissions (by pollutant)

Use Table I: Attach separate narrative per instructions.

Part 4 - Conversion factors

a. Zero and Cal values used, by instruments:

	Unit 1	Unit 2	Unit 3	Unit 4
Zero	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
Cal	<u>53.4</u>	<u>51.7</u>	<u>58.0</u>	<u>49.5</u>

Part 5 - Continuous Monitoring System operation failures

See Table II: Complete one sheet for each monitor  
attach separate narrative per instructions.

Part 6 - Certification of report integrity, by per in 1-g above:

THIS IS TO CERTIFY THAT TO THE BEST OF MY KNOWLEDGE, THE  
INFORMATION PROVIDED IN THE ABOVE REPORT IS COMPLETE AND  
ACCURATE.

NAME Peter J. Cohlma  
SIGNATURE Peter J. Cohlma  
Title Chief Environmental Scientist  
Date 1/27/94

\* Suggested Format for Subpart D sources in:

Colorado, Montana, North Dakota, South Dakota, Utah, Wyoming

TABLE I

Excess Emissions

Date Time\* From -- To Pollutant Magnitude\* Lb/106 BTU

SO<sup>2</sup>

No violations

Opacity

Attached is additional information for excesses occurring during the ~~Third~~ Quarter

*Fourth*

\* As defined in the instructions form the applicable section of the Federal Register; attached narrative of causes, etc.



\*\*\*\*\*  
-----  
OPACITY MONTHLY DATA REPORT  
-----  
\*\*\*\*\*

POWER PLANT: ARAPAHOE  
UNIT: 4 SOURCE = CURRENT  
REPORT START TIME: QUARTER = 4 10/1993

DAY	----- VIOLATION CATEGORY -----					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
10/01	0	0	0	0	0	24	1.0
10/02	0	0	0	0	0	24	1.2
10/03	0	0	0	0	0	24	1.4
10/04	0	0	0	0	0	24	1.7
10/05	0	0	0	0	0	24	1.9
10/06	0	0	0	0	0	24	1.8
10/07	0	0	0	0	0	24	1.7
10/08	0	0	0	0	0	24	0.8
10/09	1	0	1	0	0	24	2.2
10/10	0	0	0	0	0	24	1.1
10/11	0	0	0	0	0	24	1.2
10/12	0	0	0	0	0	24	1.0
10/13	0	0	0	0	0	24	1.2
10/14	0	0	0	0	0	24	1.7
10/15	0	0	0	0	0	24	1.7
10/16	0	0	0	0	0	24	1.5
10/17	0	0	0	0	0	24	1.7
10/18	0	0	0	0	0	24	1.2
10/19	0	0	0	0	0	24	0.9
10/20	0	0	0	0	0	24	0.7
10/21	0	0	0	0	0	24	1.3
10/22	0	0	0	0	0	24	1.6
10/23	0	0	0	0	0	24	1.9
10/24	0	0	0	0	0	24	1.7
10/25	0	0	0	0	0	24	1.5
10/26	0	0	0	0	0	24	1.5
10/27	0	0	0	0	0	24	1.6
10/28	0	0	0	0	0	24	1.2
10/29	0	0	0	0	0	24	1.8
10/30	0	0	0	0	0	24	2.1
10/31	0	0	0	0	0	25	2.0

-----  
MONTHLY  
TOTALS    1        0        1        2        1        745        1.5

REPORT COMPLETE







\*\*\*\*\*  
 \*\*\*\*\*  
 \*\*\*\*\* OPACITY MONTHLY DATA REPORT \*\*\*\*\*  
 \*\*\*\*\*

POWER PLANT: ARAPAHOE  
 UNIT: 4 SOURCE = CURRENT  
 REPORT START TIME: QUARTER = 4 11/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
11/01	0	0	0	0	0	24	1.6
11/02	0	0	0	0	0	24	2.1
11/03	0	0	0	0	0	24	1.7
11/04	0	0	0	0	0	24	1.4
11/05	0	0	0	0	0	24	1.3
11/06	0	0	0	0	0	24	1.2
11/07	0	0	0	0	0	24	1.2
11/08	0	0	0	0	0	24	1.4
11/09	0	0	0	0	0	24	1.4
11/10	0	0	0	0	0	24	1.4
11/11	0	0	0	0	0	24	1.5
11/12	0	0	0	0	0	24	1.4
11/13	0	0	0	0	0	24	0.8
11/14	0	0	0	0	0	24	1.1
11/15	0	0	0	0	0	24	1.3
11/16	0	0	0	0	0	24	1.4
11/17	0	0	0	0	0	24	1.3
11/18	0	0	0	0	0	24	1.1
11/19	0	0	0	0	0	24	1.4
11/20	0	0	0	0	0	24	1.0
11/21	0	0	0	0	0	24	1.3
11/22	0	0	0	0	0	24	1.5
11/23	0	0	0	0	0	24	2.0
11/24	0	0	0	0	0	24	1.6
11/25	0	0	0	0	0	24	1.6
11/26	0	0	0	0	0	24	1.2
11/27	0	0	0	0	0	24	1.0
11/28	0	0	0	0	0	24	1.4
11/29	0	0	0	0	0	24	1.2
11/30	0	0	0	0	0	24	1.6

-----  
 MONTHLY TOTALS      0            0            0            0            0            **720**            1.4

REPORT COMPLETE



\*\*\*\*\*  
 \*\*\*\*\*  
 \*\*\*\*\* OPACITY MONTHLY DATA REPORT \*\*\*\*\*  
 \*\*\*\*\*

POWER PLANT: ARAPAHOE  
 UNIT: 4 SOURCE = CURRENT  
 REPORT START TIME: QUARTER = 4 12/1993

DAY	VIOLATION CATEGORY					WEIGHT FACTOR	AVERAGE OPACITY %
	A 20-25%	B 25-30%	C 30-35%	D 35-45%	E OVER 45%		
12/01	0	0	0	0	0	24	1.4
12/02	0	0	0	0	0	24	1.3
12/03	0	0	0	0	0	24	1.4
12/04	0	0	0	0	0	24	0.9
12/05	0	0	0	0	0	24	1.4
12/06	0	0	0	0	0	24	1.8
12/07	0	0	0	0	0	24	1.3
12/08	0	0	0	0	0	24	1.5
12/09	0	0	0	0	0	24	1.2
12/10	0	0	0	0	0	24	1.0
12/11	0	0	0	0	0	24	1.5
12/12	0	0	0	0	0	24	1.4
12/13	0	0	0	0	0	24	1.3
12/14	0	0	0	0	0	24	1.4
12/15	0	0	0	0	0	24	1.9
12/16	0	0	0	0	0	24	1.7
12/17	0	0	0	0	0	24	1.7
12/18	0	0	0	0	0	24	1.8
12/19	0	0	0	0	0	24	1.9
12/20	0	0	0	0	0	24	1.5
12/21	0	0	0	0	0	24	1.8
12/22	0	0	0	0	0	24	1.6
12/23	0	0	0	0	0	24	1.7
12/24	0	0	0	0	0	24	1.3
12/25	0	0	0	0	0	24	1.2
12/26	0	0	0	0	0	24	1.4
12/27	0	0	0	0	0	24	1.9
12/28	0	0	0	0	0	24	1.4
12/29	0	0	0	0	0	24	1.8
12/30	0	0	0	0	0	24	1.9
12/31	0	0	0	0	0	24	1.8
MONTHLY TOTALS	0	0	0	0	0	744	1.5

PORT COMPLETE

**INTEGRATED DRY NO<sub>x</sub>/SO<sub>2</sub> EMISSIONS CONTROL SYSTEM**

**ENVIRONMENTAL MONITORING REPORT**

**Calcium-Based Dry Sorbent Injection System Test Period:**

**April 30, 1993 through November 2, 1993**

**Calcium DSI Air Toxics Test October 19-20, 1993**

**Dioxins/Furans Air Toxics Test October 11-13, 1993**

**Appendix B: Aqueous Stream Compliance Data**

PERMITS P.O. BOX 840  
DENVER, COLORADO 80201

00-0001021  
PERMIT NUMBER

00-0001021  
DISCHARGE NUMBER

MONITORING PERIOD  
FROM 03 04 01 TO 03 04 30  
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (34-61)			QUALITY OR CONCENTRATION (34-61)			NO. EX ANALYSIS (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE							0	20/30	
WATER DEG FAHRENHEIT									
00011 1 0 0									
EFFLUENT GROSS VALUE									
PH				7.490			0	20/30	INSIT
00400 1 0 0				6.500	9.000	SU			
EFFLUENT GROSS VALUE				Minimum	Maximum				
SOLIDS, TOTAL TSS							0	4/30	
SUSPENDED									
00530 1 0 0									
EFFLUENT GROSS VALUE									
OIL AND GREASE									
00556 1 0 0				Contingent			0	4/30	BHR CH
EFFLUENT GROSS VALUE									
ZINC, TOTAL									
(AS ZN)									
01092 1 0 0							0	1/30	GR
EFFLUENT GROSS VALUE									
FLOW, IN CONDUIT OR									
THRU TREATMENT PLANT									
00050 1 0 0							0	39/30	
EFFLUENT GROSS VALUE									
CHLORINE TOTAL									
RESIDUAL									
00060 1 0 0							0	4/30	
EFFLUENT GROSS VALUE									
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.			TELEPHONE			DATE		
MEKELS, JAMES R.									
FOR GOVT & ENV AFFAIRS	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			AREA CODE			NUMBER		
							303-942808		
TYPED OR PRINTED							YEAR		
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)							MO		
							03 05 11		
							DAY		

0001091  
 PERMIT NUMBER

001A  
 DISCHARGE NUMBER

**MONITORING PERIOD**

FROM YEAR 73 OR 01 TO YEAR 73 OR 01 MO 04 DAY 30

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

ADDRESS P. O. BOX 640  
 DENVER, COLORADO 80201

FACILITY OR AGENCY  
 LOCATION

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (55-57)	MINIMUM (48-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
OIL AND GREASE VISUAL		0	YES				0	4 / 30	
	PERMIT REQUIREMENT	Inst. Max.	NO					1 / 7	VIS
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1319. (Penalty under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 1 year.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 EXCELS, JOHN'S R.  
 COR, GOVT & ENV AFFAIRS

TYPED OR PRINTED

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
*John R. Exceles*

AREA CODE NUMBER  
 303 942808

TELEPHONE

DATE

YEAR 93 MO 05 DAY 11

NAME PUBLIC SERVICE UTILITIES COMPANY  
 ADDRESS P.O. BOX 840  
 DENVER, COLORADO 80201

00-0001071 PERMIT NUMBER  
 002A DISCHARGE NUMBER

FINAL

NOTE: Read instructions before completing this form.

PARAMETER (2-27)	(3 Card Only) QUANTITY OR LOADING (46-53)		(4 Card Only) QUANTITY OR CONCENTRATION (54-61)		AVERAGE (46-53)		MINIMUM (38-45)		MAXIMUM (54-61)		UNITS	NO. OF EX (62-69)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	UNITS						
TEMPERATURE	NO DISCHARGE													
WATER DEG FAHRENHEIT														
00011 1 0 0														
EFFLUENT GROSS VALUE	NO DISCHARGE													
PH														
00400 1 0 0														
EFFLUENT GROSS VALUE														
SOLIDS, TOTAL TSS														
SUSPENDED														
00530 1 0 0														
EFFLUENT GROSS VALUE														
OIL AND GREASE														
TRON EXTR GRAY METAL														
00556 1 0 0														
EFFLUENT GROSS VALUE														
ZINC, TOTAL														
(AS ZR)														
01092 1 0 0														
EFFLUENT GROSS VALUE														
FLOW, IN CONDUIT OR														
THRU TREATMENT PLANT														
00050 1 0 0														
EFFLUENT GROSS VALUE														
CHLORINE TOTAL														
RESIDUAL														
00060 1 0 0														
EFFLUENT GROSS VALUE														

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 5 years and 5 years)

JAMES R. WELLS, JAMES R. WELLS, GOVT & ENV AFFS  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  
 OFFICER OR AUTHORIZED AGENT

DATE: 93 05 11  
 YEAR: 93  
 MO: 05  
 DAY: 11

TELEPHONE: 303 992 8008  
 AREA CODE: 303  
 NUMBER: 992 8008

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED

City Name/Location if different  
 MS PUBLIC SERVICE COMPANY OF COLORADO  
 DRESS P. O. BOX 840  
 DENVER, COLORADO 80201

FINAL

0001091 PERMIT NUMBER  
 002A DISCHARGE NUMBER

MONITORING PERIOD  
 FROM 73 04 01 TO 73 04 30  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (46-53)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
IL AND GREASE USUAL	NO DISCHARGE								
4066 1 0 0									
EFFLUENT GROSS VALUE									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIG-NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 HEXELG, JAMES R.  
 COR. GOVT & ENV AFFRS  
 TYPED OR PRINTED  
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 X *James R. Hexelg*  
 TELEPHONE  
 AREA CODE NUMBER  
 303 742 8808  
 DATE  
 YEAR MONTH DAY  
 73 05 11

FINAL

0016  
DISCHARGE NUMBER

00001031  
PERMIT NUMBER

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
99	05	01	99	05	31

FROM (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (34-61)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE					72.400	(15)	0	20/31	
WATER DEG FAHRENHEIT					86.000	DEGF		5/7	INSIT
0011 1 0 0					Daily Max.				
EFLUENT GROSS VALUE				8.110	8.740	(12)	0	20/31	
0100 1 0 0				6.500	9.000	CU		5/7	GR
EFLUENT GROSS VALUE				Minimum	Maximum				
0105 1 0 0				21.150	28.000	(19)	0	4/31	
EFLUENT GROSS VALUE				30.000	100.000	MG/L		1/7	BHR CU
0106 1 0 0				30-Day Avg.	Daily Max.				
EFLUENT GROSS VALUE				Contingent		(19)	0	4/31	
0107 1 0 0				15.000	20.000	MG/L		1/7	GR
EFLUENT GROSS VALUE				30-Day Avg.	Daily Max.				
0108 1 0 0				< 0.005	< 0.005	(19)	0	1/31	
EFLUENT GROSS VALUE				0.880	0.880	MG/L		1/30	GR
0109 1 0 0				30-Day Avg.	Daily Max.				
EFLUENT GROSS VALUE				0.547		(03)	0	43/31	
0110 1 0 0				1.000		MGD		30/30	INST
EFLUENT GROSS VALUE				30-Day Avg.					
0111 1 0 0					< 0.05	(19)	0	4/31	
EFLUENT GROSS VALUE					0.110	MG/L		1/7	GR
0112 1 0 0					Daily Max.				

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 6 months and 5 years.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  
 NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JAMES L. ...  
 BR 0001 & 117 APPLD  
 TYPED OR PRINTED  
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TELEPHONE  
 DATE  
 YEAR 93  
 MO 05  
 DAY 14  
 NUMBER 303-942804  
 AREA CODE

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT



001A DISCHARGE NUMBER  
 PERMIT NUMBER  
 MONITORING PERIOD  
 YEAR MO DAY TO YEAR MO DAY  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(1 and Only) QUANTITY OR LOADING (34-35)			(4 and Only) QUALITY OR CONCENTRATION (34-35)			NO. EX. ANALYSIS (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
	AVERAGE (46-51)	MAXIMUM (54-61)	UNITS (51-53)	MINIMUM (58-65)	AVERAGE (46-53)	MAXIMUM (54-61)				UNITS (51-53)
DIL AND GREENE VISUAL 34066 1 0 0	PERMIT REQUIREMENT							0	4 / 31	
	SAMPLE MEASUREMENT		Inst. Max.					1 / 7	VIS	
DEVELOPMENT GROSS VOLU	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. Penalties under these statutes may include (fine up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JAMES R. WELLS  
 CORPORATE & ENVIRONMENTAL  
 TYPED OR PRINTED  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 TELEPHONE NUMBER  
 AREA CODE  
 DATE  
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REGISTRATION NUMBER 93 04 14

NAME: FREDERICK S. BELL COMPANY, DE CALIFORNIA

ADDRESS: P.O. BOX 410, BERKELEY, CALIFORNIA 94701

DISCHARGE MONITORING PERMIT (2-16)

00 0001091 PERMIT NUMBER

002A DISCHARGE NUMBER

FINAL

Expires 3-31-88

MONITORING PERIOD

FROM	TO
YEAR MO DAY	YEAR MO DAY
78 05 01	78 05 31

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)		(4 Card Only) QUALITY OR CONCENTRATION (46-53)		UNITS	NO. EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (54-61)	MINIMUM (38-45)	AVERAGE (46-53)				
TEMPERATURE	NO DISCHARGE							
WATER DEG F (MIN-MAX)								
0011 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
H								
0400 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
SOLIDS, TOTAL TSS	NO DISCHARGE							
SUSPENDED								
0050 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
OIL AND GREASE								
REON EXTR BRGW METH								
0055 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
PH, TOTAL								
AS ZND								
0102 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
COU, TO CORRUPT OR								
THRU TREATMENT PLANT								
0050 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
TH OTRF TOTAL								
RESIDUAL								
0060 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 6 months and 5 years.

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER  
 SIGNATURE: James R. Rexels  
 OFFICER OR AUTHORIZED AGENT

TELEPHONE: 303 942 808  
 AREA CODE: 303  
 NUMBER: 942 808  
 DATE: YEAR 78, MO 06, DAY 14

TYPED OR PRINTED

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

City Name/Location (if different)  
 ADDRESS: 11111 11111 COLLEGE BL  
 BOX 330  
 DENVER, COLORADO 80201  
 FACILITY: BRIDGE  
 LOCATION

DISCHARGE MONITORING PERIOD (17-19)  
 0024  
 DISCHARGE NUMBER

PERMIT NUMBER  
 00001091

MONITORING PERIOD  
 FROM: YEAR 93 MO 01 DAY 01 TO YEAR 93 MO 31 DAY 31  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (34-61)			QUALITY OR CONCENTRATION (34-61)			NO. OF EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (46-53)	UNITS (46-53)	AVERAGE (46-53)	MINIMUM (46-53)	MAXIMUM (46-53)			
TEARDROPS	SAMPLE MEASUREMENT	NO DROPS							
	PERMIT REQUIREMENT								
4055	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
ELEVATED DROPS	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
15041	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
4055	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
15041	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
4055	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
15041	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
4055	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
15041	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER  
 EXCELS, JAMES R.  
 GRIFFIN & ENV AFFAIRS

TYPED OR PRINTED

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1319. (Penalty under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 X James R. Griffin

TELEPHONE: 303 942 8008

DATE: YEAR 93 MO 06 DAY 14

MS PUBLIC SERVICE COMPANY OF COLORADO  
 ADDRESS P. O. BOX 340  
 DENVER, COLORADO 80201

PERMIT NUMBER: CO-0001091  
 DISCHARGE NUMBER: 001A

Expires 3-31-88

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
73	06	01	73	06	30

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

SALTY ARAPAHOE  
 LOCATION

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(1 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. OF EX (62-64)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE							0	27/30	
WATER DEG FAHRENHEIT									
0011 1 0 0								5/7	INSIT
EFFLUENT GROSS VALUE							0	27/30	
H				7.770		(12)			
0400 1 0 0				6.500		SU		5/7	GR
EFFLUENT GROSS VALUE				Minimum					
SOLIDS, TOTAL TSS					16.367	(19)		6/30	
SUSPENDED					30.000	MG/L		1/7	BHR CO
0530 1 0 0					30-Day Avg.	Daily Max.		6/30	
EFFLUENT GROSS VALUE									
OIL AND GREASE				Contingent		(19)		6/30	
FREON EXTR-GRAV METH					15.000	MG/L		1/7	GR
0556 1 0 0					30-Day Avg.	Daily Max.		1/30	
EFFLUENT GROSS VALUE					(0.005)	(19)		6/30	
ZINC, TOTAL					0.860	MG/L		1/30	GR
(AS ZN)					30-Day Avg.	Daily Max.		24/30	
01092 1 0 0								30/30	INST
EFFLUENT GROSS VALUE					0.187	(03) MGD		4/30	
FLOW, IN CONDUIT OR								1/7	GR
THRU TREATMENT PLANT									
0050 1 0 0									
EFFLUENT GROSS VALUE									
CHLORINE TOTAL									
RESIDUAL									
0060 1 0 0									
EFFLUENT GROSS VALUE									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 23 USC § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JEXELS, JAMES R.  
 MGR, GOVT & ENV AFFERS

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 3033942808

DATE  
 93 07 12

TELEPHONE  
 AREA CODE NUMBER

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED

FINAL

(2-19)

PERMIT NUMBER  
CO 0001091

DISCHARGE NUMBER  
001A

(2-10)

PERMIT NUMBER  
CO 0001091

DISCHARGE NUMBER  
001A

NAME PUBLIC UTILITIES COMPANY OF COLORADO  
ADDRESS P.O. BOX 840  
DENVER, COLORADO 80201

FACILITY AROPAJIDE  
LOCATION

MONITORING PERIOD  
FROM 93 06 01 TO 93 06 30  
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (55-62)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
TOL AND CRUISE VISUAL	0	0	1 YES				0	6 / 30	SIS
		Inst. Max	0 NO					1 / 7	
EFFLUENT GROSS VALUE									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
JACKELS, JAMES R.  
MR. GOVT & ENV AFFRS

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
*James R. Jackels*

TELEPHONE  
DATE  
YEAR 93 MO 07 DAY 12  
AREA NUMBER 303 942 808

TYPED OR PRINTED  
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

LU 0001091  
 PERMIT NUMBER

002A  
 DISCHARGE NUMBER

ADDRESS P. O. BOX 840  
 DENVER, COLORADO 80201

MONITORING PERIOD  
 FROM 73 06 01 TO 93 06 30  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(1 Card Only) QUANTITY OR LOADING (46-53)		(4 Card Only) QUANTITY OR CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	AVERAGE			
TEMPERATURE	NO DISCHARGE						
WATER DEG FAHRENHEIT							
0011 1 0 0							
EFLUENT GROSS VALUE	NO DISCHARGE						
0400 1 0 0							
EFLUENT GROSS VALUE							
SOLIDS, TOTAL TSS	NO DISCHARGE						
SUSPENDED							
0530 1 0 0							
EFLUENT GROSS VALUE	NO DISCHARGE						
OIL AND GREASE							
PREON EXTR GRAY METH							
0556 1 0 0							
EFLUENT GROSS VALUE	NO DISCHARGE						
LEAD, TOTAL							
(AS ZN)							
1092 1 0 0							
EFLUENT GROSS VALUE	NO DISCHARGE						
LOW, IN CONDUIT OR							
THRU TREATMENT PLANT							
0050 1 0 0							
EFLUENT GROSS VALUE	NO DISCHARGE						
CHLORINE TOTAL							
RESIDUAL							
0060 1 0 0							
EFLUENT GROSS VALUE	NO DISCHARGE						

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THESE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING PERMITS OR MY BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SEVERE PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1101 AND 33 USC 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  
 EXCELS, JAMES R.  
 FOR, GOVT & ENV AFFRS

TELEPHONE  
 303 942 8008

DATE  
 93 07 12

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED

NAME PUBLIC SERVICE COMPANY OF COLORADO  
 ADDRESS P.O. BOX 340  
DENVER COLORADO 80201

PERMIT NUMBER CO 0001091  
 DISCHARGE NUMBER 002A

FINAL

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
73	06	01	93	06	30

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUANTITY OR CONCENTRATION (54-61)			NO. OF EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (47-52)	UNITS (48-53)	MINIMUM (46-53)	AVERAGE (46-53)	MAXIMUM (47-52)			
	NO DISCHARGE								
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319 (Producers under their statute may include firms up to 8 firms and or maximum imprisonment of 6 months & 5 years)

*James R. Exels*  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

303 942808  
 AREA NUMBER

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 EXELS, JAMES R.  
 ENGR, GOVT & ENV AFFRS

TYPED OR PRINTED

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DATE  
 93 07 12  
 YEAR MONTH DAY

TELEPHONE

PUBLIC SERVICE COMPANY OF CALIFORNIA  
 1000 P. O. BOX 340  
 DEL MAR, CALIFORNIA 92014

PERMIT NUMBER 0016  
 DISCHARGE NUMBER

MONITORING PERIOD  
 FROM 7/1/77 TO 7/31/77  
 (20/20) (22/20) (24/20) (26/20) (28/20) (30/31)

NOTE: Read instructions before completing this form.

PARAMETER (12-17)	QUANTITY OR LOADING (14-15)			QUALITY OR CONCENTRATION (16-21)			NO. EX (42-43)	FREQUENCY ANALYSIS (44-48)	SAMPLE TYPE (49-70)
	AVERAGE (46-51)	MAXIMUM (52-53)	UNITS (54-55)	AVERAGE (46-51)	MAXIMUM (52-53)	UNITS (54-55)			
TEMPERATURE							0	15/31	
WATER LOG FAILURE RATE								5/7	INSIT
SOIL							0	15/31	
FLUORIDE GROSS VALUE								5/7	
1								15/31	
0400								5/7	GR
EFFLUENT GROSS VALUE							0	3/31	
SOLIDS, TOTAL TSS								1/7	BHR COM
UNSPENDED								3/31	
0530								3/31	
EFFLUENT GROSS VALUE								1/7	GR
OIL AND GREASE								1/31	
IRON EXTR GROSS VALUE								1/7	GR
0556								1/31	
EFFLUENT GROSS VALUE								1/30	GR
PHOSPHORIC ACID								18/31	
0620								30/30	INST
EFFLUENT GROSS VALUE								3/31	
CHLORINE TOTAL								1/7	GR
RESIDUAL									
0060									
EFFLUENT GROSS VALUE									

I HEREBY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SEVERAL PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE PROBABILITY OF FINE AND IMPRISONMENT (SEE 18 U.S.C. 1001) AND 18 U.S.C. 1519. (Analyst's under these statistics may include fines up to \$10,000 and/or minimum imprisonment of between 6 months and 5 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 EX-103, JAMES R.  
 BR, 6001 & 119 AVENUE

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 3034942000  
 AREA CODE NUMBER

TELEPHONE DATE  
 YEAR MO DAY

93 08 11

TYPED OR PRINTED COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



(1719)

0910  
DISCHARGE NUMBER

00000921  
PERMIT NUMBER

**MONITORING PERIOD**

YEAR	MO	DAY	YEAR	MO	DAY
73	07	01	73	07	31

NOTE: Read instructions before completing this form.

PARAMETER (12-17)	(J (and Only) (46-51) QUANTITY OR LOADING (34-61)			(K (and Only) (46-51) QUANTITY OR CONCENTRATION (34-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
<del> </del>							0	3 / 31	
SAMPLE MEASUREMENT			11.3						
PERMIT REQUIREMENT			0.00					1/7	VIS
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 18 U.S.C. § 1019. (Penalties under these statutes may include fines up to \$100,000 and/or maximum imprisonment of 5 years and 6 months.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
*James R. Waples*  
 TELEPHONE NUMBER: 303-942-0000  
 AREA CODE: 303

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER  
 EXCELS, JAMES R.  
 BR, 6001 & 6111 STS  
 TYPED OR PRINTED

DATE: 08 11 73

TELEPHONE: 303-942-0000

AREA CODE: 303

NUMBER: 942000

YEAR: 73

MO: 08

DAY: 11

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all area limits here)

11111  
DISCHARGE NUMBER

11111  
PERMIT NUMBER

**MONITORING PERIOD**

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

YEAR	MO	DAY	YEAR	MO	DAY
73	07	01	73	07	31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(4 Card Only) QUANTITY OR LOADING (54-61)		(4 Card Only) QUANTITY OR CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (66-67)	MAXIMUM (68-69)	AVERAGE (66-67)	MAXIMUM (68-69)			
TEMPERATURE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						
TOTAL TSS	NO DISCHARGE						
	PERMIT REQUIREMENT						
OIL AND GREASE	NO DISCHARGE						
	PERMIT REQUIREMENT						

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF WHOSE INDIVIDUAL IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 1351c 13319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 5 years, 6 months, and 1 year.

TELEPHONE

AREA CODE NUMBER

3004 942808

93 08 11

YEAR MO DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TYPED OR PRINTED

MEYILLE PRINCIPAL EXECUTIVE OFFICER

XELS, JAMES R.

R, GOVT & ENV AFFS

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

FINAL

0020  
DISCHARGE NUMBER

100000021  
PERMIT NUMBER

15-10

100000021  
PERMIT NUMBER

MONITORING PERIOD  
 FROM YEAR 1987 TO YEAR 1987  
 MO 01 DAY 01 TO MO 01 DAY 31  
 (26.27) (26.29) (30.31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (46-51)		QUANTITY OR CONCENTRATION (31-61)		NO. OF EX (62-63)	FREQUENCY ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	MINIMUM	MAXIMUM			
(40) DISCHARGE							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							
SAMPLE MEASUREMENT							
PERMIT REQUIREMENT							

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THESE INDIVIDUALS, IMMEDIATELY PREVIOUS TO THE OBTAINING OF THE INFORMATION RECEIVED AND AS THE INFORMATION FOR WHICH THIS PERMIT IS BEING OBTAINED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF, I AM AWARE THAT THERE ARE NO UNLAWFUL PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 1505c 1319 (Penalties under these statutes may include fines up to \$100,000 and/or maximum imprisonment of 10 years or 1 year).

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JAMES R. WELCH  
 JR., GOVT & ENV AFFAIRS  
 TELEPHONE  
 303 942 8008  
 AREA NUMBER  
 303  
 CODE  
 9428008  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 DATE  
 YEAR 93 MO 08 DAY 11

TYPED OR PRINTED  
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

001A  
DISCHARGE NUMBER

LU 0001091  
PERMIT NUMBER

82221  
DENVER, COLORADO

**MONITORING PERIOD**

YEAR	MO	DAY	YEAR	MO	DAY
83	08	01	83	08	31

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (34-61)			QUALITY OR CONCENTRATION (34-61)			NO. OF EX (42-63)	FREQUENCY OF ANALYSIS (44-65)	SAMPLE TYPE (49-70)
	AVERAGE (46-53)	MAXIMUM (46-53)	UNITS (46-53)	MINIMUM (48-63)	AVERAGE (46-53)	MAXIMUM (44-61)			
TEMPERATURE							0	10/31	
WATER DEG FAHRENHEIT									
011 1 0 0								5/7	INST
ELUENT GROSS VALUE									
400 1 0 0				6.150			0	10/31	
ELUENT GROSS VALUE									
LIIDS, TOTAL TSS									
SPEXENDE									
530 1 0 0				6.500 Minimum	12.400	15.600	0	2/31	GR
ELUENT GROSS VALUE									
L AND GREASE									
ION EXTR-GRAY METI									
556 1 0 0				Contingent			0	0/31	
ELUENT GROSS VALUE									
MC, TOTAL									
S ZN)									
052 1 0 0									
ELUENT GROSS VALUE									
OV, IN CONDUIT OR									
RU TREATMENT PLANT									
050 1 0 0									
ELUENT GROSS VALUE									
LORJRE TOTAL									
SIGNAL									
060 1 0 0									
ELUENT GROSS VALUE									
ME/TITLE PRINCIPAL EXECUTIVE OFFICER									
WEXELS, JAMES R.									
R, GOVT & ENV AFFRS									
TYPED OR PRINTED									
MENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
303942908  
AREA NUMBER  
93 09 13  
YEAR MO DAY

TELEPHONE  
DATE

FINAL

1719  
001A  
DISCHARGE NUMBER

1219  
001091  
PERMIT NUMBER

MONITORING PERIOD  
FROM YEAR 79 MO 06 DAY 01 TO YEAR 80 MO 06 DAY 31  
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. OF EX (62-63)	FREQUENCY OF ANALYSIS (64-65)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (55-56)	MINIMUM (48-49)	AVERAGE (46-53)	MAXIMUM (54-61)			
IL AND GREASE USUAL		0					0	2 / 31	
	4066 1 0 0 EFFLUENT GROSS VALUE	INST. MAX.						1 / 7	VIS
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)

JAMES R. WEXELS  
PRINCIPAL EXECUTIVE OFFICER

303-942608  
AREA NUMBER

DATE  
YEAR 93  
MONTH 09  
DAY 10

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ADDRESS P. O. BOX 140  
DENVER, COLORADO 80201

DISCHARGE NUMBER

PERMIT NUMBER

**MONITORING PERIOD**

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)  
YEAR MO DAY YEAR MO DAY  
83 03 01 83 03 31

NOTE: Read instructions before completing this form.

PARAMETER (22-37)	(3 Card Only) QUANTITY OR LOADING (34-61)		QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE			
TEMPERATURE	NO DISCHARGE							
WATER DEG FAHRENHEIT								
00011 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
PH								
00400 1 0 0								
EFFLUENT GROSS VALUE								
SOLIDS, TOTAL TSS--								
SUSPENDED								
00530 1 0 0								
EFFLUENT GROSS VALUE								
OIL AND GREASE								
FREON EXTR GRAY HRTS								
00556 1 0 0								
EFFLUENT GROSS VALUE								
ZINC, TOTAL								
(AS ZN)								
01052 1 0 0								
EFFLUENT GROSS VALUE								
FLOW, IN CONDUIT OR								
THRU TREATMENT PLANT								
00050 1 0 0								
EFFLUENT GROSS VALUE								
CHLORINE TOTAL								
RESIDUAL								
00060 1 0 0								
EFFLUENT GROSS VALUE								

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SAME TO BE TRUE, CORRECT AND ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1100 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 3 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
JEXELS, JAMES R.  
MR. GOVT & ENV AFFRS

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
3032742808  
AREA CODE NUMBER  
93 09 13  
YEAR MO DAY  
TELEPHONE

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
TYPED OR PRINTED  
PAGE 01 OF 01

MS - LUBA...  
 BOX 310  
 COLORADO 80201

001A  
 DISCHARGE NUMBER

MONITORING PERIOD  
 FROM (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)  
 YEAR MO DAY TO YEAR MO DAY  
 93 07 01 TO 93 07 30

NOTE: Read instructions before completing this form.

PARAMETER (22-37)	(1 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (34-61)	UNITS (34-61)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (34-61)			
IL AND BRIDGE EQUAL		0	YES				0	3 / 30	
EFFLUENT CROSS VALUE		INST. MAX.	NO					1 / 7	VIS
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

TELEPHONE  
 303 542 2000  
 AREA NUMBER

DATE  
 YEAR 93 MO 10 DAY 12

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
*James R. Wexler*

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$100,000 and/or maximum imprisonment of between 6 months and 5 years.)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED  
 WEXLER, JAMES R.  
 EXECUTIVE OFFICER

FINAL

PERMIT NUMBER  
0001091

DISCHARGE NUMBER  
002A

MONITORING PERIOD  
YEAR MO DAY TO YEAR MO DAY  
93 09 01 93 09 30

FROM (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

QUALITY OR CONCENTRATION (34-41)  
AVERAGE MINIMUM MAXIMUM UNITS

FREQUENCY OF ANALYSIS (64-68) (69-70)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (34-61)		QUALITY OR CONCENTRATION (34-41)		NO. OF SAMPLES (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	AVERAGE	MAXIMUM			
TEMPERATURE	NO DISCHARGE						
WATER DEG FAHRENHEIT							
0011 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						
0400 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						
SOLIDS, TOTAL TSS							
0500 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						
11 AND GUAGE							
REGON EXTR GRAY IN TH							
0500 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						
INC, TOTAL							
0100 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						
FLOW, IN CONDUIT OF							
THRU TREATMENT PLANT							
0000 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						
FLOWING, TOTAL							
ESTUINAL							
0000 1 0 0							
EFFLUENT GROSS VALUE	NO DISCHARGE						

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  
DATE

TELEPHONE

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
ADDRESS, JOHN R.  
68,0091 & ENV AFFRS

AREA CODE NUMBER  
303 942 8008

YEAR MO DAY  
93 10 12

TYPED OR PRINTED  
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



FINAL

002A  
DISCHARGE NUMBER

00001091  
PERMIT NUMBER

0000  
DENVER, COLORADO

BOX 310  
DENVER, COLORADO

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
93	09	01	93	09	30

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (22-37)	(1 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
NO DISCHARGE									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION TO BE TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 6 months, and 5 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JAMES R. WELLS  
 DIRECTOR & ENV AFFAIRS  
 TYPED OR PRINTED  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 DATE  
 TELEPHONE  
 AREA CODE NUMBER  
 YEAR MO DAY

FINAL

0010  
DISCHARGE NUMBER

0001091  
PERMIT NUMBER

PUBLIC SERVICE COMPANY OF COLORADO  
ORDER P.O. BOX 840  
DENVER, COLORADO 80201

MONITORING PERIOD			
YEAR	MO	DAY	DAY
93	10	01	31
FROM (20-21) (22-23) (24-25)			
TO (26-27) (28-29) (30-31)			

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (54-61)		QUALITY OR CONCENTRATION (46-53)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
TEMPERATURE					0	20/31	
WATER DEO FAIRNESS						5/7	INSIT
0011 1 0 0					0	20/31	
EFFLUENT GROSS VALUE						5/7	GR
0400 1 0 0					0	4/31	
EFFLUENT GROSS VALUE						1/7	BHR CD
SOLIDS, TOTAL TSS					0	0/31	
SUSPENDED						1/7	GR
0050 1 0 0					0	1/31	
EFFLUENT GROSS VALUE						1/30	GR
OIL AND GREASE					0	31/31	
PERON EXTR GRAV METH						30/30	INST
0055 1 0 0					0	4/31	
EFFLUENT GROSS VALUE						1/7	GR
ZINC, TOTAL					0	1/31	
(AS ZN)						1/30	GR
0102 1 0 0					0	4/31	
EFFLUENT GROSS VALUE						1/7	GR
FLOW, IN CONDUIT OR					0	31/31	
THRU TREATMENT PLANT						30/30	INST
0050 1 0 0					0	4/31	
EFFLUENT GROSS VALUE						1/7	GR
PHOSPHORUS, TOTAL					0	31/31	
RESTRICTION						30/30	INST
0020 1 0 0					0	4/31	
EFFLUENT GROSS VALUE						1/7	GR

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 6 months and 5 years)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JEFFREY J. JONES R.  
 FOR GOVT & ENV AFFRS

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

93 11 16

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED

ADDRESS P. O. BOX 810  
DENVER, COLORADO 80201

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
73	10	01	73	10	31

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (22-37)	(1 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. OF ANALYSIS (61-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (55-60)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
IL AND GREASE EQUAL		0	1-YES				0	4 / 31	
EFFLUENT CROSS VALUE		INST. MAX.	0-110					1 / 7	VIS
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JEXELS, JAMES R.  
 FOR. ODOT & ENV AFFERS

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or a maximum imprisonment of 6 months and 3 years).

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
*James R. Jexels*

TELEPHONE  
 AREA CODE NUMBER  
 303 942 608  
 DATE  
 YEAR MO DAY  
 93 11 16

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

UTILITY ABRAHAMSON

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
73	10	01	73	10	31

FROM (20-21) (22-23) (24-25) TO (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (54-61)		QUALITY OR CONCENTRATION (34-41)			NO. OF EX (42-47)	FREQUENCY OF ANALYSIS (44-48)	SAMPLE TYPE (49-50)
	AVERAGE (46-53)	MAXIMUM (47-51)	AVERAGE (46-53)	MINIMUM (48-49)	MAXIMUM (34-41)			
TEMPERATURE	NO DISCHARGE							
ENTER DEGREE FAHRENHEIT								
011 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
400 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
SOLIDS, TOTAL TSS	NO DISCHARGE							
SPENDED								
0530 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
OIL AND GREASE	NO DISCHARGE							
REDON EXTR-GRAV METH								
0556 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
INC, TOTAL								
AS ZN)								
1092 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
LOW, IN CONDUIT OR								
THRU TREATMENT PLANT								
0050 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							
CHLORINE TOTAL								
RESIDUAL								
0060 1 0 0								
EFFLUENT GROSS VALUE	NO DISCHARGE							

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of 6 months and 5 years.)

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER: JAMES R. BERGOVI & ENV AFFRS  
 OFFICER OR AUTHORIZED AGENT  
 TELEPHONE: 303-942-0008  
 AREA NUMBER: 303-942-0008  
 DATE: 11 16 73  
 YEAR: 73  
 MO: 11  
 DAY: 16

PERMIT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED

ADDRESS: 1000 P.O. BOX 840  
DENVER, COLORADO 80201

002A  
DISCHARGE NUMBER

CO-0001091  
PERMIT NUMBER

MONITORING PERIOD  
FROM 73 10 01 TO 73 10 31  
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUANTITY OR CONCENTRATION (54-61)			NO. OF EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-51)	MAXIMUM (46-51)	UNITS (46-51)	MINIMUM (54-55)	AVERAGE (54-55)	MAXIMUM (54-55)			
OIL AND GREASE EQUAL 4066 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT	NO DISCHARGE							
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								
	SAMPLE MEASUREMENT								
	PERMIT REQUIREMENT								

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION AND COMPLETELY BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1318. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.

JAMES R. WEXELS  
PRINCIPAL EXECUTIVE OFFICER  
ENVIRONMENTAL AFFAIRS

TELEPHONE: 303 942808  
AREA NUMBER: 303  
DATE: 93 11 16

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER  
EXELS, JAMES R.  
ENVIRONMENTAL AFFAIRS  
TYPED OR PRINTED  
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

FINAL

PERMIT NUMBER 0010  
DISCHARGE NUMBER 0010

ADDRESS C. U. BOX 140  
DENVER, COLORADO 80201

MONITORING PERIOD  
FROM 01/01/73 TO 01/30/73  
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(1 Card Only) QUANTITY OR LOADING (34-61)			(4 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-55)	MAXIMUM (36-61)	UNITS (46-53)	AVERAGE (46-53)	MAXIMUM (34-61)	UNITS (46-53)			
TEMPERATURE							0	25/30	
WATER DEG FAHRENHEIT						(15)		5/7	INSIT
0011 1 0 0						Daily Max.		25/30	
EFFLUENT GROSS VALUE						8.610	0	25/30	
0400 1 0 0						7.000	0	5/7	GR
EFFLUENT GROSS VALUE						Maximum		5/30	
SOLIDS, TOTAL TSS						22.800	0	5/30	
SUSPENDED						16.560		1/7	BHR CDJ
0550 1 0 0						30,000		0/30	
EFFLUENT GROSS VALUE						30-Day Avg.		1/30	GR
OIL AND GREASE						Contingent		30/30	
IRON EXTR-GRAV METH						15,000		30/30	INST
00556 1 0 0						30-Day Avg.		5/30	
EFFLUENT GROSS VALUE						0.018	0	1/7	
SLUDGE, TOTAL						0.880		1/30	GR
(AS ZN)						30-Day Avg.		30/30	
01092 1 0 0						0.006		30/30	
EFFLUENT GROSS VALUE						1.000		5/30	
FLOW, IN CONDUIT OR						30-Day Avg.		1/7	GR
THRU TREATMENT PLANT						(03)			
00050 1 0 0									
EFFLUENT GROSS VALUE									
BIOLOGIC TOTAL									
RESIDUAL									
00060 1 0 0									
EFFLUENT GROSS VALUE									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 JAMES N. WELLS, JR.  
 MGR, GOVT & ENV AFFRS

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 3031942808

OFFICER OR AUTHORIZED AGENT NUMBER  
 3031942808

DATE  
 YEAR 73 MO 12 DAY 14

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TYPED OR PRINTED

CITY OF DENVER  
 DEPARTMENT OF ENVIRONMENT AND AERIAL PHOTOGRAPHY  
 1400 BROADWAY, DENVER, COLORADO 80201  
 PERMIT NUMBER: CO-0001091  
 DISCHARGE NUMBER: UVAZ

**MONITORING PERIOD**  
 FROM 93 11 01 TO 93 11 30  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (34-61)			(3 Card Only) QUALITY OR CONCENTRATION (34-61)			NO. OF ANALYSIS (62-65)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-72)
	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (55-62)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (55-62)			
OIL AND GREASE VISUAL		0	YES				0	5 / 30	
		INST. MAX.	NO					1 / 7	VIS
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IMMEDIATELY RESPONSIBLE FOR OBTAINING ACCURATE AND COMPLETE INFORMATION THAT THERE ARE NO FALSE PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF ONE YEAR IMPRISONMENT SEE 18 U.S.C. 1001 AND 33 U.S.C. 1318 (Penalties under these Statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

NAME/TITLE: JAMES R. WEXELS, JR. PRINCIPAL EXECUTIVE OFFICER  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT: *James R. Wexels, Jr.*  
 TELEPHONE NUMBER: 303 744 2808  
 DATE: 93 12 14

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 TYPED OR PRINTED: HGR.GOV1 & ENV OFFIC

ADDRESS 1100 S. U. HIGH BLVD  
DENVER, COLORADO 80201

FACILITY BRASABUC  
 LOCATION \_\_\_\_\_

PERMIT NUMBER \_\_\_\_\_

**MONITORING PERIOD**

YEAR	MO	DAY	YEAR	MO	DAY
93	11	01	93	11	30

NOTE: Read instructions before completing this form.

PARAMETER (22-27)	(I Card Only) QUANTITY OR LOADING (54-61)			(I Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (68-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE	NO DISCHARGE								
WATER DEG FAHRENHEIT									
00011 1 0 0									
EFFLUENT GROSS VALUE	NO DISCHARGE								
PH									
00400 1 0 0									
EFFLUENT GROSS VALUE									
SOLIDS, TOTAL TSS									
SUSPENDED									
00530 1 0 0									
EFFLUENT GROSS VALUE									
OIL AND GREASE									
FREON EXTR GRAY METH									
00536 1 0 0									
EFFLUENT GROSS VALUE									
ZINC, TOTAL									
(AS ZN)									
01092 1 0 0									
EFFLUENT GROSS VALUE									
FLOW, IN CONDUIT OR									
THRU TREATMENT PLANT									
00050 1 0 0									
EFFLUENT GROSS VALUE									
CHLORINE TOTAL									
RESIDUAL									
00060 1 0 0									
EFFLUENT GROSS VALUE									

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER		TELEPHONE	DATE
MEXELS, JAMES R.		303 2942008	93 12 14
MGR, GOVT & ENV AFFRS		AREA NUMBER	YEAR MO DA
TYPED OR PRINTED		OFFICER OR AUTHORIZED AGENT	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE AND AM AWARE THAT THERE ARE NO OTHER VIOLATIONS OF THE AND INFORMATION SEE 18 U.S.C. 1003 AND THE POSSIBILITY OF FINE AND IMPRISONMENT (see up to 5 years) 33 U.S.C. 1319 (Pollution under these include up to 6 months and 5 years)

800-634-7349 50-TOL PREVIOUS EDITIONS TO BE USED



CO-0001071 PERMIT NUMBER  
 00240 DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
93	11	01	93	11	30

FROM (2021) (22-23) (24-25) TO (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (22-27)	(3 Card Only) QUANTITY OR LOADING (34-61)			QUALITY OR CONCENTRATION (54-61)			NO. EX. (67-67)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE (46-53)	MAXIMUM (34-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
NO DISCHARGE									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									
SAMPLE MEASUREMENT									
PERMIT REQUIREMENT									

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIG NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under (b)(6) statute may include fines up to \$25,000 and/or maximum imprisonment of 6 months and 1 year.)

PRINCIPAL EXECUTIVE OFFICER  
 JAMES R. XELS  
 R. GOVT & ENV AFFRS  
 TYPED OR PRINTED

TELEPHONE  
 303-942808  
 AREA NUMBER  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 James R. Xels

DATE  
 YEAR 93  
 MONTH 12  
 DAY 14

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**INTEGRATED DRY NO<sub>x</sub>/SO<sub>2</sub> EMISSIONS CONTROL SYSTEM**

**ENVIRONMENTAL MONITORING REPORT**

**Calcium-Based Dry Sorbent Injection System Test Period:  
April 30, 1993 through November 2, 1993**

**Appendix C: Calcium-Based DSI System Data Summary**

Data Used For Duct Injection Trend Plots.

<u>Test</u>	<u>Date</u>	<u>Load</u>	<u>Ca/S</u>	<u>Tapp_calc</u>	<u>ΔSO2</u>	<u>ΔSO2 @ Ca/S=2</u>
582	5/12/93	108	1.54	49	21.2	27.5
605	6/28/93	107	1.63	65	12.1	14.8
605	6/28/93	109	1.66	76	9.2	11.1
605	6/28/93	108	1.76	61	19.1	21.7
605	6/29/93	108	2.07	40	20.5	19.8
605	6/29/93	106	1.87	43	20.5	21.9
610	7/1/93	109	1.69	36	32.0	37.9
610	7/1/93	106	1.82	25	29.4	32.3
582	5/12/93	108	1.36	69	13.8	
582	5/12/93	108	1.41	67	16.3	
612	7/2/93	104	1.07	38	14.8	
578	5/10/93	100	1.69	59	20.0	23.7
579	5/11/93	100	1.71	56	19.1	22.3
580	5/11/93	100	1.85	50	19.5	21.1
584	5/13/93	100	1.55	48	20.7	26.7
610	7/1/93	100	1.69	36	32.6	38.6
603	6/22/93	95	1.75	47	20.8	23.8
576	5/3/93	100	2.41			
579	5/11/93	100	0.95	51	12.0	
584	5/13/93	99	0.78	47	11.4	
610	7/1/93	98	1.09	24	22.6	
605	6/28/93	91	1.69	41	22.6	26.7
605	6/28/93	91	1.74	39	20.8	23.9
605	6/28/93	91	1.33	45	16.9	
605	6/29/93	86	1.63	41	23.4	
600	6/16/93	80	1.86	40	23.3	25.1
604	6/22/93	80	1.78	36	17.8	20.0
599	6/15/93	80	0.40	35	2.3	
601	6/17/93	80	0.85	45	12.9	
602	6/21/93	80	0.39	45	3.9	
610	7/1/93	78	1.42	42	19.3	
612	7/2/93	79	1.40	44	20.6	
581	5/12/93	70	1.73	44	20.3	23.5
586	5/14/93	70	1.70	20	37.0	43.7
583	5/13/93	70	1.66	38	19.3	23.3
604	6/22/93	50	1.75	45	22.2	25.4
604	6/22/93	59	1.53	45	23.8	31.1
606	6/29/93	60	1.64	38	22.5	27.4
606	6/30/93	58	1.75	38	18.8	21.5
608	7/1/93	60	1.72	34	19.7	22.9
609	7/1/93	60	1.72	29	23.4	27.2
611	7/2/93	61	1.59	36	25.5	32.1
705	10/19/93	112	2.06	28	37.0	35.9
706	10/20/93	112	2.07	28	35.4	34.2
707	10/20/93	112	2.10	29	37.8	36.0
709	10/26/93	102	2.03	50	26.9	26.5
712	10/27/93	101	1.97	29	28.1	28.5
715	11/1/93	112	2.23	32	34.4	30.9
717	11/1/93	113	1.90	35	30.9	32.5
719	11/2/93	114	2.04	36	26.8	26.3
720	11/2/93	114	2.10	32	28.6	27.2
721	11/2/93	114	2.15	30	32.9	30.6

PSSC Arapahoe Unit 4 Calcium/Humidification-Duct Injection, Ca(OH)2 calculations based upon 68% CaO

Test	Date & Time	Boiler		Sorbent Feed		Injector		Humidification		Baghouse Temps				Humid calc									
		Load	O2cr	Loc	A/W	B.e	Flow	Ca/S	Comp	Calc	Air	Tgo	Twl	H2O	A/W	Grid	Out	IDin	Opsis	Ta	Tcalc	%F	%W
		MWt	%wet	%	%	%	D/min	%	%	scfm	%F	%F	gpm	%F	%F	%F	%F	%F	%F	%F	%F	%F	%F
575	4/30/93:1420	100	3.90	Duct	50	50	19.2	1.02	5	1.3	3684		35.0	1.05	202	206							8.27
575	4/30/93:1500	100	3.90	Duct	50	50	19.2	1.02	8	2.8	3639		40.0	0.90	194	199							8.28
575	4/30/93:1635	100	3.90	Duct	50	50	19.2	1.01	8	3.4	3550		47.0	0.70	175	185							8.28
576	5/3/93:1615	100	3.50	Duct	100	100	38.4	2.41	21	18.0	3457	258	52	54.0	0.60	223	180			170	49	149	8.53
577	5/6/93:1130	53	7.30	Duct			0.0	0.00	2	3.4	4200	248	55	30.0	1.57	160	185*			167		165	6.77
577	5/6/93:1340	55	7.10	Duct	45	45	17.3	1.81	10	4.8	4188	252	55	31.0	1.55	160				160		169	6.75
577	5/6/93:1515	55	7.00	Duct	45	45	17.3	1.85	13	7.1	4145	254	55	35.5	1.31	150				154		160	6.74
577	5/6/93:1735	55	7.00	Duct	45	45	17.3	1.84	16	9.8	4109	255	56	38.5	1.21	142				151		151	6.87
578	5/10/93:0800	105	4.10	Duct	0	0	0.0	0.00		-2.3										253			8.83
578	5/10/93:1405	100	3.70	Duct	88	88	33.8	1.68	19	15.3	3990	276	55	48.0	0.89	160	173			179	56	179	8.34
578	5/10/93:1600	100	3.60	Duct	88	88	33.8	1.56	22	18.6	3973	278	56	49.0	0.87	160	170			173	53	173	8.83
578	5/10/93:1800	100	3.60	Duct	96	96	36.9	1.69	23	20.0	3957	282	55	50.0	0.84	160	170			174	53	175	8.93
578	5/10/93:2023	100	3.64	Duct	96	96	36.9	1.71	26	22.4	3960	280	56	50.0	0.84	160	168			174	51	173	9.11
578	5/10/93:2221	100	3.57	Duct	96	96	36.9	1.86	27	23.0	3974	276	56	49.0	0.86	160	167			173	50	173	8.99
578	5/11/93:0032	100	3.97	Duct	90	90	34.6	1.82	28	21.0	4000	271	56	47.0	0.91	160	167			172	50	174	9.00
578	5/11/93:0230	100	3.94	Duct	85	85	32.7	1.76	22	19.1	4029	266	55	45.0	0.96	160	165			171	48	173	8.99
578	5/11/93:0430	100	3.94	Duct	85	85	32.7	1.71	22	20.1	4023	266	55	45.0	0.95	160	164			170	47	172	8.99
578	5/11/93:0620	100	3.93	Duct	85	85	32.7	1.66	24	20.7	4011	266	55	45.0	0.94	160	164			170	47	172	8.99
578	5/11/93:0830	100	4.00	Duct	85	85	32.7	1.64	20	14.9	3980	270	54	46.0	0.91	160	164			170	47	174	8.96
579	5/11/93:1100	100	4.00	Duct	0	90	17.4	0.90	18	12.3	3917	275	56	52.0	0.79	150	162			167	45	167	8.89
579	5/11/93:1300	100	4.20	Duct	0	90	17.4	0.94	17	13.2	3875	280	56	54.0	0.75	150	163			167	46	167	9.00
579	5/11/93:1500	100	4.00	Duct	0	90	17.4	0.96	16	11.5	3875	281	54	54.0	0.75	150	164			170	47	169	8.96
579	5/11/93:1700	100	3.90	Duct	0	90	17.4	0.99	16	11.4	3867	282	55	55.0	0.74	150	163			168	46	168	9.02
579	5/11/93:1900	100	3.96	Duct	0	90	17.4	1.00	19	11.6	3866	283	55	55.0	0.72	150	164			168	47	169	9.05
580	5/11/93:2100	100	3.94	Duct	90	90	34.6	1.94	26	20.2	3861	284	55	56.0	0.71	150	162			168	45	168	9.28
580	5/11/93:2300	100	3.95	Duct	80	80	30.8	1.76	23	19.1	3869	278	56	55.0	0.73	150	161			167	44	165	9.34
581	5/12/93:0010	70	5.84	Duct	56	56	21.5	1.80	22	21.5	4040	258	55	41.0	1.06	150	156			160	41	160	7.99
581	5/12/93:0200	70	5.83	Duct	53	53	20.4	1.70	25	19.6	4057	254	55	40.0	1.11	150	154			156	39	159	7.96
581	5/12/93:0400	70	5.86	Duct	53	53	20.4	1.69	24	20.0	4062	253	55	40.0	1.11	150	153			155	38	158	7.88
581	5/12/93:0545	70	5.86	Duct	53	53	20.4	1.66	12	10.0	4481	252	56	0.0		241	183			188	68	252	7.87
582	5/12/93:1240	108	3.20	Duct	95	95	36.5	1.81	23	14.8	3866	288	56	55.0	0.74	160	184			189	65	180	9.51
582	5/12/93:1420	108	3.20	Duct	95	95	36.5	1.54	24	21.2	3810	291	56	63.0	0.69	150	175			180	56	168	9.59
582	5/12/93:2040	108	3.31	Duct	95	95	36.5	1.36	16	13.8	3877	288	56	51.0	0.79	170	201			82	82	188	9.49
582	5/12/93:2250	108	3.31	Duct	100	100	38.4	1.41	19	16.3	3908	286	57	51.0	0.81	170	182			190	63	186	9.49
583	5/13/93:0020	70	5.25	Duct	80	80	30.8	1.74	23	21.2	4013	261	56	44.0	1.00	142	169			169	53	153	8.30
583	5/13/93:0300	70	5.21	Duct	75	75	28.8	1.64	25	19.3	4049	256	56	42.0	1.06	142	154			155	38	153	8.22
583	5/13/93:0430	70	5.23	Duct	75	75	28.8	1.67	25	19.2	4046	255	55	41.0	1.07	142	150			152	34	154	8.23
584	5/13/93:0530	100	3.48	Duct	100	100	38.4	1.57	22	18.9	3989	266	55	45.0	0.95	160	160			165	44	171	9.54
584	5/13/93:0735	100	3.50	Duct	100	100	38.4	1.55	24	20.7	3897	274	56	52.0	0.80	152	162			168	46	165	9.39
584	5/13/93:0930	99	3.40	Duct	0	100	19.4	0.78	17	11.4	3867	277	56	53.5	0.76	149	160			165	44	164	9.27
585	5/14/93:0035	69	5.37	Duct	60	60	23.1	1.68	30	23.8	3998	259	55	46.0	0.94	128	156			156	41	144	8.06
585	5/14/93:0230	70	5.27	Duct	60	60	23.1	1.64	30	24.6	4011	255	55	46.0	0.95	129	144			145	29	142	8.00
586	5/14/93:0310	70	5.19	Duct	60	60	23.1	1.66	38	36.1	3971	256	56	49.0	0.86	124	140			142	25	136	8.04
586	5/14/93:0420	70	5.26	Duct	60	60	23.1	1.72	37	37.6	3977	254	55	49.0	0.88	124	137			139	22	134	8.00
586	5/14/93:0545	70	5.26	Duct	60	60	23.1	1.71	44	39.4	3979	254	56	48.0	0.89	125	136			137	21	136	7.98
586	5/14/93:0705	70	5.50	Duct	60	60	23.1	1.69	41	35.1	3971	252	56	49.0	0.86	124	134			136	19	132	8.16

Test	Date & Time	GAS ANAL ECON-DRY (1-12)						GAS ANALYSIS INLET-WET .....						GAS ANALYSIS OUTLET-WET .....						O2	Comments
		NO	CO	SO2	CO2	O2	%dry	NO	CO	SO2	CO2	H2O	O2	NO	CO	SO2	CO2	H2O	O2		
		ppm	ppm	ppm	%	%		ppm	ppm	ppm	%	%	ppm	ppm	ppm	%	%	%	%		
575	4/30/93 1420	235	194	424	13.53	5.25		180	154	348	12.02	8.22	4.90	192	233	332	11.73	10.48	4.90		
575	4/30/93 1500	235	194	424	13.53	5.25		180	180	347	12.05	8.20	4.90	187	281	328	11.89	10.88	4.75		
575	4/30/93 1635	235	194	424	13.53	5.25		179	184	351	12.07	8.26	4.85	187	329	327	11.54	11.54	4.60		
576	5/3/93 1615	225	166	320	13.04	5.27		195	153	268	10.87	7.69	6.30	208	663	229	11.44	11.85	5.00		
577	5/6/93 1130	199	11	263	10.28	9.20		150	14	235	9.41	6.76	8.60	164	7	232	9.25	9.38	8.55		
577	5/6/93 1340	199	11	263	10.28	9.20		163	11	228	9.21	6.63	8.78	163	7	208	9.08	9.39	8.65		
577	5/6/93 1515	199	11	263	10.28	9.20		166	11	225	9.23	6.66	8.72	164	6	198	8.98	9.63	8.67		
577	5/6/93 1735	202	10	259	10.43	8.95		163	10	225	9.22	6.63	8.75	165	6	193	8.99	9.87	8.60		
578	5/10/93 0800	255	44	370	14.10	5.50		181	50	295	10.94	7.62	7.05	195	183	355	12.96	8.91	4.60		
578	5/10/93 1405	255	44	370	14.10	5.50		203	225	398	13.62	9.14	3.65	195	97	295	12.03	11.64	5.05		
578	5/10/93 1600	230	194	445	14.78	4.42		194	344	430	13.53	9.06	3.62	189	89	311	12.15	11.89	4.75		
578	5/10/93 1800	230	194	445	14.78	4.42		203	135	427	13.62	9.03	3.85	184	105	308	12.28	12.07	4.72		
578	5/10/93 2023	230	194	445	14.78	4.42		199	104	422	13.59	9.24	3.80	186	49	291	12.19	12.08	4.91		
578	5/10/93 2221	219	96	422	14.72	4.70		199	51	385	13.47	9.18	3.96	189	60	266	12.22	12.02	4.91		
578	5/11/93 0032	241	63	383	14.58	4.92		208	52	367	13.40	9.29	4.00	194	37	259	12.08	11.97	5.05		
578	5/11/93 0230	241	63	383	14.58	4.92		195	126	365	13.67	9.46	3.70	198	45	261	12.09	11.63	5.03		
578	5/11/93 0430	234	71	392	14.41	4.80		207	50	368	13.39	9.18	4.05	194	62	265	12.13	11.73	5.00		
578	5/11/93 0620	234	71	392	14.41	4.80		208	55	380	13.43	9.20	4.01	192	57	270	12.12	11.73	5.05		
578	5/11/93 0830	234	71	392	14.41	4.80		212	52	383	13.44	9.15	4.05	188	91	295	12.27	11.89	4.90		
579	5/11/93 1100	234	71	392	14.41	4.80		207	50	375	13.36	9.08	4.05	190	53	292	12.00	12.08	5.10		
579	5/11/93 1300	234	71	392	14.41	4.80		215	32	352	13.17	8.99	4.38	191	98	279	12.05	12.10	5.00		
579	5/11/93 1500	239	123	368	14.36	4.95		213	44	348	13.34	9.17	4.15	192	87	275	11.83	12.24	5.10		
579	5/11/93 1700	239	123	368	14.36	4.95		215	57	338	13.30	9.26	4.10	192	116	266	11.87	12.45	5.10		
579	5/11/93 1900	239	123	368	14.36	4.95		206	89	339	13.44	9.43	3.87	188	64	267	12.01	12.66	4.85		
580	5/11/93 2100	239	123	368	14.36	4.95		214	185	345	13.37	9.68	3.85	185	46	240	11.80	12.93	5.11		
580	5/11/93 2300	239	123	368	14.36	4.95		200	155	345	13.68	9.96	3.50	190	85	242	11.98	12.78	4.95		
581	5/12/93 0010	223	29	284	11.80	7.75		201	14	266	11.04	8.20	6.80	179	17	185	9.89	10.94	7.65		
581	5/12/93 0200	223	29	284	11.80	7.75		205	12	267	11.00	8.17	6.80	182	17	191	9.98	10.84	7.62		
581	5/12/93 0400	223	29	284	11.80	7.75		205	13	270	11.16	8.14	6.72	174	22	193	10.10	10.90	7.48		
581	5/12/93 0545	223	29	284	11.80	7.75		199	15	282	11.59	8.36	6.35	180	30	231	10.48	7.78	7.63		
582	5/12/93 1240	240	387	387.4	14.62	4.55		214	161	363	13.47	9.71	3.80	196	277	278	12.20	12.71	4.70		
582	5/12/93 1420	240	387	387.4	14.62	4.55		212	189	430	13.63	9.88	3.65	189	363	305	12.21	13.13	4.50		
582	5/12/93 2040	247	557	505	14.41	4.60		205	742	488	13.48	9.84	3.60	198	399	375	12.04	12.42	4.72		
582	5/12/93 2250	247	557	505	14.41	4.60		206	860	499	13.54	9.87	3.55	199	344	369	12.11	12.39	4.82		
583	5/13/93 0020	211	113	428	12.20	7.25		190	21	406	11.46	8.51	6.32	167	88	285	10.30	11.56	7.08		
583	5/13/93 0300	211	113	428	12.20	7.25		194	16	399	11.20	8.32	6.50	172	44	289	10.28	11.29	7.18		
583	5/13/93 0430	211	113	428	12.20	7.25		199	16	395	11.35	8.37	6.43	168	53	287	10.33	11.30	7.10		
584	5/13/93 0530	224	212	500	14.48	4.60		187	194	480	13.61	9.89	3.60	181	144	345	12.06	12.23	4.85		
584	5/13/93 0735	224	213	500	14.48	4.60		194	309	487	13.59	9.69	3.68	182	152	340	11.98	12.58	4.90		
584	5/13/93 0930	220	373	496	14.31	4.70		191	484	490	13.54	9.65	3.65	180	188	380	11.93	12.57	4.95		
585	5/14/93 0035	210	61	350	12.17	7.20		194	19	328	11.64	8.45	5.98	164	46	217	10.21	11.67	7.05		
585	5/14/93 0230	210	61	350	12.17	7.20		200	18	335	11.60	8.47	5.85	170	79	219	10.37	11.67	6.95		
586	5/14/93 0310	210	61	350	12.17	7.20		199	25	325	11.46	8.33	6.15	165	83	186	10.46	11.99	6.75		
586	5/14/93 0420	210	61	350	12.17	7.20		199	39	325	11.98	8.62	5.60	181	38	172	10.37	11.77	7.00		
586	5/14/93 0545	210	61	350	12.17	7.20		200	38	322	11.82	8.48	5.80	159	164	170	10.40	11.91	6.80		
586	5/14/93 0705	210	61	350	12.17	7.20		201	24	309	11.24	8.17	6.60	173	62	179	10.08	11.56	7.25		

H2O off

O2 changd

PSCC Arapahoe Unit 4 Calcium/Humidification-Duct Injection, Ca(OH)<sub>2</sub> calculations based upon 68% CaO

Test Date & Time	Boiler		Sorber Feed		Injector cal		ASO <sub>2</sub> Red		Humidification		Baghouse Temps				Humid calc							
	Load	O <sub>2</sub> cr	Loc	A.W	B.e	Flow	Ca/S*	Comp	Calc	Air	Tgo	Twt	H <sub>2</sub> O	AW	Grid	Out	IDin	Opsis	Ta	Tcalc	H <sub>2</sub> Oe	
	MWe	%wet	%	%	%	bu/min	%	%	%	scfm	°F	°F	gpm	°F	°F	°F	°F	°F	°F	°F	%W	
575	4/30/93	1420	100	3.90	Duct	50	50	19.2	1.02	5	1.3	3684	35.0	1.05	202	206					8.27	
575	4/30/93	1500	100	3.90	Duct	50	50	19.2	1.02	8	2.8	3639	40.0	0.90	194	199					8.25	
575	4/30/93	1635	100	3.90	Duct	50	50	19.2	1.01	8	3.4	3550	47.0	0.70	175	185					8.28	
576	5/3/93	1615	100	3.50	Duct	100	100	38.4	2.41	21	16.0	3457	52	54.0	0.60	223	180					149 8.53
577	5/6/93	1130	53	7.30	Duct			0	0	0	2	3.4	4200	248	55	30.0	1.57	160	185			170 49 165 6.77
577	5/6/93	1340	55	7.10	Duct	45	45	17.3	1.81	10	4.8	4188	252	55	31.0	1.55	160					167 169 6.75
577	5/6/93	1515	55	7.00	Duct	45	45	17.3	1.85	13	7.1	4145	254	55	35.5	1.31	150					160 160 6.74
577	5/6/93	1735	55	7.00	Duct	45	45	17.3	1.84	16	9.8	4109	255	56	38.5	1.21	142					154 151 6.87
578	5/10/93	0800	105	4.10	Duct	0	0	0	0	0	2.3							253				8.83
578	5/10/93	1405	100	3.70	Duct	88	88	33.8	1.68	19	15.3	3990	276	55	48.0	0.89	160	173				179 56 179 8.34
578	5/10/93	1600	100	3.60	Duct	88	88	33.8	1.56	22	18.6	3973	278	56	49.0	0.87	160	170				173 53 173 8.83
578	5/10/93	1800	100	3.60	Duct	96	96	36.9	1.69	23	20.0	3957	282	55	50.0	0.84	160	170				174 53 175 8.93
578	5/10/93	2023	100	3.64	Duct	96	96	36.9	1.71	26	22.4	3960	280	56	50.0	0.84	160	168				174 51 173 9.11
578	5/10/93	2221	100	3.57	Duct	96	96	36.9	1.86	27	23.0	3974	276	56	49.0	0.85	160	167				173 50 173 8.99
578	5/11/93	0032	100	3.97	Duct	90	90	34.6	1.82	28	21.0	4000	271	56	47.0	0.91	160	167				172 50 174 9.00
578	5/11/93	0230	100	3.94	Duct	85	85	32.7	1.76	22	19.1	4029	266	55	45.0	0.96	160	165				171 48 173 8.99
578	5/11/93	0430	100	3.93	Duct	85	85	32.7	1.71	22	20.1	4023	266	55	45.0	0.95	160	164				170 47 172 8.99
578	5/11/93	0620	100	3.93	Duct	85	85	32.7	1.66	24	20.7	4011	266	55	45.0	0.94	160	164				170 47 172 8.99
578	5/11/93	0830	100	4.00	Duct	85	85	32.7	1.64	20	14.9	3980	270	54	46.0	0.91	160	164				170 47 174 8.96
579	5/11/93	1100	100	4.00	Duct	0	90	17.4	0.90	18	12.3	3917	275	56	52.0	0.79	150	162				167 45 167 8.89
579	5/11/93	1300	100	4.20	Duct	0	90	17.4	0.94	17	13.2	3875	280	56	54.0	0.75	150	163				167 46 167 9.00
579	5/11/93	1500	100	4.00	Duct	0	90	17.4	0.96	16	11.5	3875	281	54	54.0	0.75	150	164				170 47 169 8.96
579	5/11/93	1700	100	3.90	Duct	0	90	17.4	0.99	16	11.4	3867	282	55	55.0	0.74	150	163				168 46 168 9.02
579	5/11/93	1900	100	3.96	Duct	0	90	17.4	1.00	19	11.6	3866	283	55	55.0	0.72	150	164				168 47 169 9.05
580	5/11/93	2100	100	3.94	Duct	90	90	34.6	1.94	26	20.2	3861	284	55	56.0	0.71	150	162				168 45 168 9.28
580	5/11/93	2300	100	3.95	Duct	80	80	30.8	1.76	23	19.1	3869	278	56	55.0	0.73	150	161				167 44 165 9.34
581	5/12/93	0010	70	5.84	Duct	56	56	21.5	1.80	22	21.5	4040	258	55	41.0	1.06	150	156				160 41 160 7.99
581	5/12/93	0200	70	5.83	Duct	53	53	20.4	1.70	25	19.6	4057	254	55	40.0	1.11	150	154				156 39 159 7.96
581	5/12/93	0400	70	5.86	Duct	53	53	20.4	1.69	24	20.0	4062	253	55	40.0	1.11	150	153				155 38 158 7.88
581	5/12/93	0545	70	5.86	Duct	53	53	20.4	1.66	12	10.0	4481	252	56	0		241	183				188 68 252 7.87
582	5/12/93	1240	108	3.20	Duct	95	95	36.5	1.81	23	14.8	3866	288	56	55.0	0.74	160	184				189 65 180 9.51
582	5/12/93	1420	108	3.20	Duct	95	95	36.5	1.54	24	21.2	3810	291	56	63.0	0.69	150	175				180 56 168 9.59
582	5/12/93	2040	108	3.31	Duct	95	95	36.5	1.36	16	13.8	3877	288	56	51.0	0.79	170	201				82 188 9.49
582	5/12/93	2250	108	3.31	Duct	100	100	38.4	1.41	19	16.3	3908	286	57	51.0	0.81	170	182				190 63 186 9.49
583	5/13/93	0020	70	5.25	Duct	80	80	30.8	1.74	23	21.2	4013	261	56	44.0	1.00	142	169				169 53 153 8.30
583	5/13/93	0300	70	5.21	Duct	75	75	28.8	1.64	25	19.3	4049	256	56	42.0	1.06	142	154				155 38 153 8.22
583	5/13/93	0430	70	5.23	Duct	75	75	28.8	1.67	25	19.2	4046	255	55	41.0	1.07	142	150				152 34 154 8.23
584	5/13/93	0530	100	3.48	Duct	100	100	38.4	1.57	22	18.9	3989	266	55	45.0	0.95	160	160				165 44 171 9.54
584	5/13/93	0735	100	3.50	Duct	100	100	38.4	1.55	24	20.7	3897	274	56	52.0	0.80	152	162				168 46 165 9.39
584	5/13/93	0930	99	3.40	Duct	0	100	19.4	0.78	17	11.4	3867	277	56	53.5	0.76	149	160				165 44 164 9.27
585	5/14/93	0035	69	5.37	Duct	60	60	23.1	1.68	30	23.6	3998	259	55	46.0	0.94	128	156				156 41 144 8.06
585	5/14/93	0230	70	5.27	Duct	60	60	23.1	1.64	30	24.6	4011	255	55	46.0	0.95	129	144				145 29 142 8.00
586	5/14/93	0310	70	5.19	Duct	80	80	23.1	1.66	38	38.1	3971	258	56	49.0	0.86	124	140				142 25 136 8.04
586	5/14/93	0420	70	5.28	Duct	60	60	23.1	1.72	37	37.6	3977	254	55	49.0	0.88	124	137				139 22 134 8.00
586	5/14/93	0545	70	5.26	Duct	60	60	23.1	1.71	44	39.4	3979	254	56	48.0	0.89	125	136				137 21 136 7.98
586	5/14/93	0705	70	5.50	Duct	60	60	23.1	1.69	41	35.1	3971	252	56	49.0	0.86	124	134				136 19 132 8.16

Test Date & Time	GAS ANAL ECON-DRY (11-12)				GAS ANALYSIS INLET-WET .....				GAS ANALYSIS OUTLET-WET .....				O2 %	Comments			
	NO ppm	CO ppm	SO2 ppm	O2 %	NO ppm	CO ppm	SO2 ppm	H2O %	NO ppm	CO ppm	SO2 ppm	CO2 %			H2O %		
575 4/30/93:1420	235	194	424	13.53	5.25	180	154	348	12.02	8.22	4.90	192	233	332	11.73	10.46	4.90
575 4/30/93:1500	235	194	424	13.53	5.25	180	180	347	12.05	8.20	4.90	187	281	328	11.89	10.88	4.75
575 4/30/93:1635	235	194	424	13.53	5.25	179	184	351	12.07	8.26	4.85	187	329	329	11.54	11.54	4.60
576 5/3/93:1615	225	166	320	13.04	5.27	195	153	268	10.87	7.69	6.30	208	663	227	11.44	11.85	5.00
577 5/6/93:1130	199	11	263	10.28	9.20	160	14	235	9.41	6.78	8.60	164	7	232	9.25	9.38	8.55
577 5/6/93:1340	199	11	263	10.28	9.20	163	11	228	9.21	6.63	8.78	163	7	208	9.08	9.39	8.65
577 5/6/93:1515	199	11	263	10.28	9.20	166	11	225	9.23	6.66	8.72	164	6	198	8.98	9.63	8.67
577 5/6/93:1735	202	10	259	10.43	8.95	163	10	225	9.22	6.63	8.75	165	6	193	8.99	9.87	8.60
578 5/10/93:0800	255	44	370	14.10	5.50	181	50	295	10.94	7.62	7.05	195	183	355	12.96	8.91	4.60
578 5/10/93:1405	255	44	370	14.10	5.50	203	225	398	13.62	9.14	3.65	195	97	295	12.03	11.64	5.05
578 5/10/93:1600	230	194	445	14.78	4.42	194	344	430	13.53	9.06	3.62	189	89	311	12.15	11.89	4.75
578 5/10/93:1800	230	194	445	14.78	4.42	203	135	427	13.62	9.03	3.85	184	105	308	12.28	12.07	4.72
578 5/10/93:2023	230	194	445	14.78	4.42	199	104	422	13.59	9.24	3.80	186	49	291	12.19	12.08	4.91
578 5/10/93:2221	219	96	422	14.72	4.70	199	51	385	13.47	9.18	3.96	189	60	266	12.22	12.02	4.91
578 5/11/93:0032	241	63	383	14.58	4.92	208	52	367	13.40	9.29	4.00	194	37	259	12.08	11.97	5.05
578 5/11/93:0230	241	63	383	14.58	4.92	195	126	365	13.67	9.46	3.70	198	45	261	12.09	11.63	5.03
578 5/11/93:0430	234	71	392	14.41	4.80	207	50	368	13.39	9.18	4.05	194	62	265	12.13	11.73	5.00
578 5/11/93:0620	234	71	392	14.41	4.80	208	55	380	13.43	9.20	4.01	192	57	270	12.12	11.73	5.05
578 5/11/93:0830	234	71	392	14.41	4.80	212	52	383	13.44	9.15	4.05	188	91	295	12.27	11.89	4.90
579 5/11/93:1100	234	71	392	14.41	4.80	207	50	375	13.36	9.08	4.05	190	53	292	12.00	12.08	5.10
579 5/11/93:1300	234	71	392	14.41	4.80	215	32	352	13.17	8.99	4.38	191	98	279	12.05	12.10	5.00
579 5/11/93:1500	239	123	368	14.36	4.95	213	44	348	13.34	9.17	4.15	192	87	275	11.83	12.24	5.10
579 5/11/93:1700	239	123	368	14.36	4.95	215	57	338	13.30	9.26	4.10	192	116	266	11.87	12.45	5.10
579 5/11/93:1900	239	123	368	14.36	4.95	206	89	339	13.44	9.43	3.87	188	64	267	12.01	12.66	4.85
580 5/11/93:2100	239	123	368	14.36	4.95	214	185	345	13.37	9.68	3.85	185	46	240	11.80	12.93	5.11
580 5/11/93:2300	239	123	368	14.36	4.95	200	155	345	13.68	9.96	3.50	190	85	242	11.98	12.78	4.95
581 5/12/93:0010	223	29	284	11.80	7.75	201	14	266	11.04	8.20	6.80	179	17	185	9.89	10.94	7.65
581 5/12/93:0200	223	29	284	11.80	7.75	205	12	287	11.00	8.17	6.80	182	17	191	9.98	10.84	7.62
581 5/12/93:0400	223	29	284	11.80	7.75	205	13	270	11.16	8.14	6.72	174	22	193	10.10	10.90	7.48
581 5/12/93:0545	223	29	284	11.80	7.75	199	15	282	11.59	8.36	6.35	180	30	231	10.48	7.78	7.63
582 5/12/93:1240	240	387	387.4	14.62	4.55	214	161	363	13.47	9.71	3.80	196	277	278	12.20	12.71	4.70
582 5/12/93:1420	240	387	387.4	14.62	4.55	212	189	430	13.63	9.68	3.65	189	363	305	12.21	13.13	4.50
582 5/12/93:2040	247	557	505	14.41	4.60	205	742	488	13.48	9.84	3.60	198	399	375	12.04	12.42	4.72
582 5/12/93:2250	247	557	505	14.41	4.60	206	860	499	13.54	9.87	3.55	199	344	369	12.11	12.39	4.82
583 5/13/93:0020	211	113	428	12.20	7.25	190	21	406	11.46	8.51	6.32	167	88	285	10.30	11.56	7.08
583 5/13/93:0300	211	113	428	12.20	7.25	194	16	399	11.20	8.32	6.50	172	44	289	10.28	11.29	7.18
583 5/13/93:0430	211	113	428	12.20	7.25	199	16	395	11.35	8.37	6.43	168	53	287	10.33	11.30	7.10
584 5/13/93:0530	224	212	500	14.48	4.60	187	194	480	13.61	9.89	3.60	181	144	345	12.06	12.23	4.85
584 5/13/93:0735	224	213	500	14.48	4.60	194	309	487	13.59	9.69	3.68	182	152	340	11.98	12.58	4.90
584 5/13/93:0930	220	373	496	14.31	4.70	191	484	490	13.54	9.65	3.65	180	188	380	11.93	12.57	4.95
585 5/14/93:0035	210	61	350	12.17	7.20	194	19	328	11.64	8.45	5.98	164	46	217	10.21	11.67	7.05
585 5/14/93:0230	210	61	350	12.17	7.20	200	18	335	11.60	8.47	5.85	170	79	219	10.37	11.67	6.95
586 5/14/93:0310	210	61	350	12.17	7.20	199	25	325	11.46	8.33	6.15	165	83	186	10.46	11.99	6.75
586 5/14/93:0420	210	61	350	12.17	7.20	199	39	325	11.98	8.62	5.60	181	38	172	10.37	11.77	7.00
586 5/14/93:0545	210	61	350	12.17	7.20	200	38	322	11.82	8.48	5.80	159	164	170	10.40	11.91	6.80
586 5/14/93:0705	210	61	350	12.17	7.20	201	24	309	11.24	8.17	6.60	173	62	179	10.08	11.56	7.25

O2 changed

H2O off

Humid





GAS ANAL ECON.DRY (1-12) GAS ANALYSIS INLET-WET ..... GAS ANALYSIS OUTLET-WET .....

Test Date & Time	GAS ANAL ECON.DRY (1-12)				GAS ANALYSIS INLET-WET .....				GAS ANALYSIS OUTLET-WET .....				O2 %	Comments				
	NO	CO	SO2	CO2	ppm	ppm	ppm	%	NO	CO	SO2	CO2			ppm	ppm	ppm	%
587 5/18/93.0907	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	242	152	365	12.32	8.99	5.10	No Sorbent
587 5/18/93.1018	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	288	155	388	13.84	0.00	5.40	EE 1-12
587 5/18/93.1039	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	248	200	247	11.81	0.00	7.40	EE 1.2
587 5/18/93.1046	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	318	69	411	14.34	0.00	4.90	EE 3.4
587 5/18/93.1055	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	298	75	430	14.89	0.00	4.40	EE 5.6
587 5/18/93.1105	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	290	310	475	16.17	0.00	3.00	EE 7.8
587 5/18/93.1115	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	313	66	410	14.34	0.00	5.05	EE 9.10
587 5/18/93.1123	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	270	17	330	11.50	0.00	8.10	EE 11.12
587 5/18/93.1135	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	293	125	380	13.93	0.00	5.35	EE 1-12
587 5/18/93.1150	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	246	125	345	12.16	8.80	5.25	Altech Out
587 5/18/93.1214	278	138	420	14.26	4.90	278	138	420	14.26	0.00	4.90	288	142	395	13.86	0.00	5.40	Base Drift
587 5/18/93.1214	288	142	395	13.86	5.40	288	142	395	13.86	0.00	5.40	249	120	355	12.01	8.54	5.40	No Sorbent
588 5/19/93.0943	261	69	392	13.14	5.30	261	69	392	13.14	0.00	5.30	223	65	360	11.65	8.75	5.00	No Sorbent
588 5/19/93.1043	261	69	392	13.14	5.30	261	69	392	13.14	0.00	5.30	255	43	378	13.34	0.00	5.10	EE 1-12
588 5/19/93.1053	261	69	392	13.14	5.30	261	69	392	13.14	0.00	5.30	210	48	342	11.73	8.81	4.91	Altech Out
588 5/19/93.1100	261	69	392	13.14	5.30	261	69	392	13.14	0.00	5.30	219	50	214	10.76	0.00	8.00	EE 1.2
588 5/19/93.1108	261	69	392	13.14	5.30	261	69	392	13.14	0.00	5.30	288	24	415	14.22	0.00	4.05	EE 3.4
588 5/19/93.1137	261	69	392	13.14	5.30	261	69	392	13.14	0.00	5.30	228	34	240	10.99	0.00	7.70	EE 1.2
589 5/19/93.1155	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	246	57	390	13.50	0.00	4.85	EE 1-12
589 5/19/93.1206	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	205	53	341	11.66	8.73	5.15	Altech Out
590 5/19/93.1239	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	235	35	283	11.15	0.00	7.55	EE 1.2
591 5/19/93.1620	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	187	49	341	11.79	8.84	4.95	No Sorbent
591 5/19/93.1745	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	217	30	330	12.87	0.00	5.55	EE 1-12
591 5/19/93.1756	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	206	15	205	10.84	0.00	7.70	EE 1.2
591 5/19/93.1805	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	246	16	381	13.92	0.00	4.35	EE 3.4
591 5/19/93.1814	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	225	38	402	14.05	0.00	4.10	EE 9.10
591 5/19/93.1826	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	170	25	196	10.30	0.00	8.10	EE 11.12
591 5/19/93.1837	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	224	50	422	14.84	0.00	3.40	EE 7.8
591 5/19/93.1845	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	229	26	378	13.45	0.00	4.85	EE 5.6
591 5/19/93.1854	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	215	35	330	13.20	0.00	5.20	EE 1-12
591 5/19/93.1905	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	188	25	303	11.45	8.85	5.05	Altech Out
591 5/19/93.2001	222	56	385	13.42	4.95	222	56	385	13.42	0.00	4.95	221	27	370	13.08	0.00	5.40	Base Drift
592 5/20/93.0905	249	38	392	14.02	4.55	249	38	392	14.02	0.00	4.55	214	38	348	12.04	9.30	4.45	No Sorbent
592 5/20/93.1056	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	208	21	359	11.93	9.23	4.70	No Sorbent
592 5/20/93.1212	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	244	54	400	13.80	0.00	4.65	EE 1-12
592 5/20/93.1221	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	233	31	214	10.78	0.00	7.90	EE 1.2
592 5/20/93.1230	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	272	79	435	14.19	0.00	4.05	EE 3.4
592 5/20/93.1247	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	275	59	430	14.47	0.00	4.15	3.4.HiPres
592 5/20/93.1255	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	220	83	240	10.89	0.00	7.65	1.2.HiPres
592 5/20/93.1303	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	237	97	428	13.99	0.00	4.35	1-12.Hi P
592 5/20/93.1320	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	229	120	240	11.00	0.00	7.50	EE 1.2
592 5/20/93.1329	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	273	144	442	14.45	0.00	3.80	EE 3.4
592 5/20/93.1337	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	249	77	427	13.66	0.00	4.80	EE 1-12
592 5/20/93.1412	243	28	405	13.85	4.55	243	28	405	13.85	0.00	4.55	256	57	445	13.53	0.00	4.80	Base Drift
593 5/21/93.0047	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	184	8	380	10.41	8.32	6.60	No Sorbent
593 5/21/93.0118	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	217	12	392	11.74	0.00	6.95	EE 1-12



Test Date & Time	GAS ANAL ECON-DRY (1-12)					GAS ANALYSIS INLET-WET					GAS ANALYSIS OUTLET-WET					Comments		
	NO ppm	CO ppm	SO2 ppm	CO2 %	O2 %dry	NO ppm	CO ppm	SO2 ppm	CO2 %	H2O %	NO ppm	CO ppm	SO2 ppm	CO2 %	H2O %		O2 %	
593 5/2/93:0126	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	185	32	296	10.98	0.00	7.90	EE 1.2
593 5/2/93:0138	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	228	14	458	12.72	0.00	5.80	EE 3.4
593 5/2/93:0144	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	170	9	209	8.37	0.00	11.00	EE 11.12
593 5/2/93:0157	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	227	9	438	12.24	0.00	6.45	EE 9.10
593 5/2/93:0210	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	214	16	387	11.73	0.00	6.90	EE 1-12
593 5/2/93:0221	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	185	10	350	10.38	8.26	6.60	Altech Out
593 5/2/93:0301	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	213	14	380	11.84	0.00	6.80	EE 1-12
593 5/2/93:0308	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	182	11	346	10.42	8.33	6.51	Altech Out
593 5/2/93:0316	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	186	25	250	11.11	0.00	7.50	EE 1.2
593 5/2/93:0324	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	165	9	181	8.41	0.00	10.80	EE 11.12
593 5/2/93:0430	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	207	26	380	11.97	0.00	6.45	EE 1-12
593 5/2/93:0436	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	177	21	347	10.62	8.36	6.30	Altech Out
593 5/2/93:0535	217	13	430	11.96	6.75	217	13	430	11.96	0.00	6.75	207	42	415	11.74	0.00	6.75	Base Drift
594 6/8/93:1000	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	253	130	285	11.26	8.14	5.30	No Sorbent
594 6/8/93:1056	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	263	160	298	13.29	0.00	5.15	EE 1-12
594 6/8/93:1109	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	238	375	190	10.30	0.00	7.75	EE 1.2
594 6/8/93:1119	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	309	150	335	13.61	0.00	4.30	EE 3.4
594 6/8/93:1130	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	273	19	345	13.83	0.00	4.25	EE 9.10
594 6/8/93:1138	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	210	20	225	11.72	0.00	6.25	EE 11.12
594 6/8/93:1147	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	261	100	299	13.09	0.00	5.10	EE 1-12
594 6/8/93:1157	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	229	100	280	11.82	8.44	4.65	Altech Out
594 6/8/93:1456	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	212	69	260	11.27	12.40	4.70	Altech Out
594 6/8/93:1536	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	231	75	290	11.87	8.42	4.70	Altech Out
594 6/8/93:1551	272	200	315	12.93	5.30	272	200	315	12.93	0.00	5.30	258	85	330	13.14	0.00	5.10	Base Drift
594 6/8/93:1551	258	85	330	13.14	5.10	258	85	330	13.14	0.00	5.10	231	74	305	12.03	8.47	4.70	No Sorbent
595 6/9/93:0731	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	189	18	289	10.92	8.16	5.95	No Sorbent
595 6/9/93:0818	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	199	25	193	10.07	0.00	8.25	EE 1.2
595 6/9/93:0827	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	240	17	339	13.12	0.00	5.20	EE 3.4
595 6/9/93:0835	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	212	22	344	13.17	0.00	5.30	EE 9.10
595 6/9/93:0848	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	146	59	210	11.05	0.00	7.35	EE 11.12
595 6/9/93:0900	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	209	27	290	12.21	0.00	6.15	EE 1-12
595 6/9/93:0917	213	23	325	12.24	6.10	213	23	325	12.24	0.00	6.10	185	23	270	11.09	8.11	5.80	Altech Out
596 6/9/93:1350	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	195	19	290	10.95	7.98	5.90	No Sorbent
596 6/9/93:1437	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	214	22	289	12.00	0.00	6.45	EE 1-12
596 6/9/93:1455	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	195	20	270	10.98	8.07	5.90	Altech Out
596 6/9/93:1542	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	181	15	240	10.25	12.37	5.95	Altech Out
596 6/9/93:1625	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	181	16	240	10.28	12.44	5.93	Altech Out
596 6/9/93:1656	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	191	18	273	11.11	8.19	5.80	Altech Out
596 6/9/93:1715	217	25	320	12.16	6.10	217	25	320	12.16	0.00	6.10	194	19	290	11.19	8.17	5.70	Base Drift
597 6/10/93:1053	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	211	110	290	11.14	7.89	5.90	No Sorbent
597 6/10/93:1247	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	191	593	240	12.35	0.00	6.15	EE 1.2
597 6/10/93:1259	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	241	300	321	14.49	0.00	4.20	EE 3.4
597 6/10/93:1306	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	246	90	342	13.48	0.00	5.15	EE 5.6
597 6/10/93:1315	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	253	31	360	14.04	0.00	4.65	EE 7.8
597 6/10/93:1319	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	247	20	320	12.71	0.00	5.85	EE 9.10
597 6/10/93:1328	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	190	16	165	9.24	0.00	9.20	EE 11.12



Test	Date & Time	GAS ANAL ECON DRY (1-12)					GAS ANALYSIS INLET WET .....					GAS ANALYSIS OUTLET WET .....					Comments				
		NO	CO	SO2	CO2	O2	ppm	ppm	ppm	%	%dry	NO	CO	SO2	CO2	H2O		O2	%	ppm	ppm
597	6/10/93 1335	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	190	225	240	11.22	0.00	7.00	EE 1		
597	6/10/93 1343	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	179	860	239	12.81	0.00	5.10	EE 2		
597	6/10/93 1349	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	248	190	303	14.24	0.00	3.85	EE 3		
597	6/10/93 1355	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	249	35	299	13.10	0.00	5.20	EE 4		
597	6/10/93 1403	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	222	250	294	12.61	0.00	5.85	EE 1-12		
597	6/10/93 1412	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	196	225	265	11.44	8.27	5.40	Allech Out		
597	6/10/93 1533	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	180	200	230	10.38	12.36	5.85	Allech Out		
597	6/10/93 1625	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	174	200	228	10.49	12.73	5.65	Allech Out		
597	6/10/93 1720	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	175	150	228	10.55	12.77	5.60	Allech Out		
597	6/10/93 1751	230	175	328	12.62	6.00	230	175	328	12.62	0.00	6.00	211	265	310	12.25	0.00	6.05	Base Drift		
597	6/10/93 1751	211	265	310	12.25	6.05	211	265	310	12.25	0.00	6.05	190	210	284	11.13	8.37	5.75	Allech Out		
598	6/11/93 0741	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	211	53	290	11.29	8.61	5.40	No Sorbent		
598	6/11/93 0838	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	230	75	295	12.70	0.00	5.80	EE 1-12		
598	6/11/93 0849	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	217	8	155	8.25	0.00	10.10	EE 1,2		
598	6/11/93 0857	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	261	23	248	11.45	0.00	6.95	EE 3,4		
598	6/11/93 0906	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	270	21	339	13.40	0.00	5.05	EE 5,6		
598	6/11/93 0912	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	254	33	360	14.36	0.00	4.25	EE 7,8		
598	6/11/93 0919	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	207	154	383	15.38	0.00	3.00	EE 9,10		
598	6/11/93 0929	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	172	56	220	12.26	0.00	6.15	EE 11,12		
598	6/11/93 0934	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	200	57	262	11.25	8.50	5.50	Allech Out		
598	6/11/93 0942	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	225	120	287	12.49	0.00	5.80	EE 1-12		
598	6/11/93 0957	240	62	325	12.66	5.80	240	62	325	12.66	0.00	5.80	241	36	304	12.26	0.00	6.10	Base Drift		

PSCC Arapahoe Unit 4 Calcium/Humidification-Duct Injection Ca(OH)<sub>2</sub> calculations based upon 68% CaO

Test	Date & Time	Boiler		Sorbent Feed		Injector cal		Humidification		Baghouse Temps						Humid calc						
		Load	O <sub>2</sub> cr	Loc	A w	B e	Flow	Ca/S	Comp	Calc	Air	Tgo	Twl	H2O	AW	Grid	Out	IDin	Opsis	Ta	Tcalc	H2Oe
		MWe	%wet		%	%	bl/min	%	%	scfm	F	F	gpm	F	F	F	F	F	F	F	F	%aw
599	6/15/93	0750	80	5.70	Duct	0	0	0	0	266	266	54.0	0.73	150	196	196	30	148	8.80	266	266	
599	6/15/93	0915	80	5.70	Duct	35	0	6.7	0.41	9	3.6	385.4	271	63	385.4	271	63	54.0	0.73	150	196	
599	6/15/93	1100	80	6.20	Duct	35	0	6.7	0.42	11	1.7	379.7	280	64	379.7	280	64	59.0	0.66	147	160	
599	6/15/93	1300	80	6.10	Duct	35	0	6.7	0.40	10	2.3	379.5	284	64	379.5	284	64	60.0	0.65	148	154	
600	6/16/93	0840	81	5.00	Duct	70	70	26.9	1.46	24	17.6	366.8	267	64	366.8	267	64	51.0	0.81	147	192	
600	6/16/93	1100	81	5.00	Duct	81	81	31.2	1.88	30	22.1	385.0	271	65	385.0	271	65	51.0	0.79	147	158	
600	6/16/93	1300	80	4.90	Duct	75	74	28.7	1.88	27	21.5	384.5	273	65	384.5	273	65	52.0	0.79	147	157	
600	6/16/93	1500	80	5.00	Duct	70	69	26.8	1.82	30	22.6	385.5	272	65	385.5	272	65	51.0	0.79	147	156	
600	6/16/93	1800	80	5.00	Duct	67	66	25.6	1.82	30	26.8	384.0	272	65	384.0	272	65	51.0	0.79	147	154	
601	6/17/93	0800	80	5.30	Duct	60	0	11.4	0.87	7	10.2	397.6	252	63	41.0	1.03	154	211				
601	6/17/93	0900	81	5.20	Duct	60	0	11.4	0.85	16	12.4	395.4	253	63	43.0	0.97	147	170				
601	6/17/93	1100	81	5.20	Duct	60	0	11.4	0.86	20	13.6	394.6	256	63	43.0	0.96	147	159				
601	6/17/93	1300	81	5.20	Duct	60	0	11.4	0.84	17	12.0	395.8	257	64	43.0	0.97	147	158				
601	6/17/93	1500	81	5.10	Duct	60	0	11.4	0.84	17	13.1	393.5	257	63	44.0	0.94	148	157				
601	6/17/93	1550	81	5.20	Duct	60	0	11.4	0.85	17	12.9	395.1	257	63	43.0	0.96	146	157				
602	6/21/93	0900	80	5.10	Duct	36	0	6.9	0.38	10	4.3	388.0	262	63	45.0	0.88	149	203				
602	6/21/93	1100	81	5.20	Duct	38	0	7.2	0.38	10	4.2	387.1	264	64	48.0	0.84	147	166				
602	6/21/93	1300	80	5.20	Duct	40	0	7.6	0.40	10	3.6	387.2	269	62	49.0	0.84	147	161				
603	6/22/93	0925	96	4.10	Duct	85	85	32.7	1.59	21	22.9	382.7	274	63	56.0	0.70	149	203				
603	6/22/93	1114	95	4.20	Duct	92	92	35.4	1.97	24	18.7	378.1	280	63	59.0	0.66	150	161				
603	6/22/93	1300	95	4.20	Duct	80	81	30.9	1.91	27	18.2	376.0	283	64	60.0	0.64	147	156				
603	6/22/93	1500	95	4.20	Duct	72	73	27.9	1.64	26	20.2	379.1	282	65	57.0	0.68	147	160				
603	6/22/93	1650	95	4.10	Duct	72	73	27.9	1.69	30	24.0	378.5	284	64	59.0	0.67	147	162				
604	6/22/93	1850	81	5.50	Duct	63	63	24.2	1.77	22	16.8	384.3	275	64	53.0	0.77	143	158				
604	6/22/93	2100	80	5.65	Duct	62	62	23.8	1.79	25	18.8	386.6	268	64	49.0	0.85	147	157				
604	6/22/93	2320	50	7.50	Duct	42	42	16.1	1.75	26	22.2	407.0	248	64	34.0	1.35	145	153				
604	6/23/93	0100	59	6.90	Duct	42	42	16.1	1.53	25	23.8	402.4	248	64	36.0	1.27	146	151				
605	6/28/93	1110	106	4.90	Duct	70	71	27.0	2.00	22	12.8	368.1	286	65	65.0	0.58	146	193	187			
605	6/28/93	1240	106	4.80	Duct	61	62	23.5	1.70	16	12.7	373.8	290	65	62.0	0.62	158	184	179			
605	6/28/93	1350	107	4.80	Duct	61	62	23.5	1.63	16	11.5	374.0	293	66	61.0	0.63	168	187	182			
605	6/28/93	1500	109	4.60	Duct	65	66	25.1	1.66	14	9.2	375.5	295	66	58.0	0.65	177	190	187			
605	6/28/93	1705	108	3.60	Duct	68	69	26.2	1.72	24	18.2	368.0	294	65	66.0	0.56	148	173	172			
605	6/28/93	1905	108	4.10	Duct	68	69	26.2	1.78	26	20.1	368.9	291	65	65.0	0.58	145	173	170			
605	6/28/93	2100	91	4.70	Duct	56	56	21.5	1.33	23	16.9	374.6	279	65	60.0	0.63	146	161	159			
605	6/28/93	2300	91	5.20	Duct	72	72	27.7	1.69	27	22.6	377.2	273	65	59.0	0.63	146	155	155			
605	6/29/93	0100	91	5.30	Duct	72	72	27.7	1.71	27	18.8	377.2	272	64	59.0	0.65	147	152	155			
605	6/29/93	0300	90	5.30	Duct	72	72	27.7	1.79	27	20.1	375.6	272	65	60.0	0.64	146	153	154			
605	6/29/93	0430	91	5.20	Duct	72	72	27.7	1.73	27	21.4	377.3	270	65	58.0	0.66	147	152	154			
605	6/29/93	0700	91	5.20	Duct	72	72	27.7	1.72	28	22.9	375.7	270	65	59.0	0.64	147	151	153			
605	6/29/93	0905	94	5.10	Duct	74	74	28.4	1.68	25	17.9	372.2	276	65	61.0	0.61	147	152	154			
605	6/29/93	1100	96	5.10	Duct	74	74	28.4	1.68	25	17.9	372.2	279	65	61.0	0.61	147	154	156			
605	6/29/93	1220	109	4.20	Duct	84	85	32.4	2.03	36	27.7	354.5	288	66	75.0	0.46	147	155	156			
605	6/29/93	1550	107	4.20	Duct	84	85	32.4	2.11	38	33.8	355.1	292	65	74.0	0.46	149	162	162			
605	6/29/93	1700	106	4.40	Duct	69	69	26.4	1.87	27	20.5	356.2	293	65	73.0	0.47	150	155	154			
605	6/29/93	2120	86	5.30	Duct	65	65	25.0	1.63	29	23.4	370.2	272	65	60.0	0.63	147	152	153			
606	6/29/93	2300	60	6.80	Duct	48	48	18.5	1.64	28	22.5	390.1	256	65	41.0	1.02	144	149	150			

Test Date & Time	GAS ANAL ECON-DRY (1-12)					GAS ANALYSIS INLET-WET .....					GAS ANALYSIS OUTLET-WET .....					Comments		
	NO ppm	CO ppm	SO2 ppm	CO2 %	O2 %dry	NO ppm	CO ppm	SO2 ppm	CO2 %	H2O %	NO ppm	CO ppm	SO2 ppm	CO2 %	H2O %			
599 6/15/93 0750	207	30	378	11.82	6.45	196	9	339	10.75	8.71	6.02	177	15	298	9.97	12.32	6.42	Base
599 6/15/93 0915	207	30	378	11.82	6.45	200	7	329	10.42	7.82	6.42	183	12	292	9.64	11.77	6.85	
599 6/15/93 1100	213	17	379	11.51	6.95	196	6	351	10.83	7.87	6.00	179	12	310	9.97	11.82	6.45	ΔLoad
600 6/16/93 0840	226	257	440	12.67	6.45	213	26	396	11.56	8.70	5.45	182	297	290	10.48	12.31	6.22	
600 6/16/93 1100	226	257	440	12.67	6.45	212	27	352	11.41	8.66	5.61	186	126	241	10.25	12.13	6.52	
600 6/16/93 1300	226	257	440	12.67	6.45	221	16	325	11.20	8.98	5.65	191	85	224	10.20	12.79	6.50	
600 6/16/93 1500	226	257	440	12.67	6.45	213	19	318	11.31	8.92	5.48	181	176	220	10.42	12.66	6.15	
600 6/16/93 1800	226	257	440	12.67	6.45	219	21	298	11.19	8.85	5.73	184	53	196	10.36	12.58	6.30	
601 6/17/93 0800	218	77	304	12.22	6.80	205	23	273	11.08	9.15	6.00	175	79	224	10.33	11.99	6.53	
601 6/17/93 0900	218	77	304	12.22	6.80	208	21	268	10.78	8.87	6.40	180	52	210	9.95	11.67	7.15	
601 6/17/93 1100	218	77	304	12.22	6.80	209	21	272	10.92	8.91	6.05	179	64	207	9.69	11.43	7.08	
601 6/17/93 1300	218	77	304	12.22	6.80	211	25	280	10.98	9.04	5.95	182	62	224	10.24	12.13	6.50	
601 6/17/93 1500	218	77	304	12.22	6.80	207	26	280	11.07	9.12	5.90	187	43	216	10.03	11.99	6.78	
601 6/17/93 1550	218	77	304	12.22	6.80	203	27	280	11.14	9.26	5.75	183	48	217	10.10	12.10	6.62	
602 6/21/93 0900	208	49	410	11.79	7.10	208	20	388	11.18	9.19	5.58	182	34	327	10.18	12.10	6.58	
602 6/21/93 1100	208	49	410	11.79	7.10	214	19	392	10.99	8.89	6.00	167	30	334	10.03	12.02	6.80	
602 6/21/93 1300	208	49	410	11.79	7.10	210	24	394	11.08	8.66	5.95	188	27	340	10.19	11.93	6.65	
603 6/22/93 0925	247	69	415	12.87	5.90	217	51	360	10.83	8.52	6.10	189	33	258	10.71	12.43	6.20	
603 6/22/93 1114	247	69	415	12.87	5.90	224	29	345	11.80	8.72	4.90	187	45	245	10.57	12.11	6.00	
603 6/22/93 1300	247	69	415	12.87	5.90	224	31	325	11.77	8.72	4.30	195	63	220	10.46	12.10	6.15	
603 6/22/93 1500	247	69	415	12.87	5.90	221	33	323	11.69	9.03	5.00	189	109	230	10.64	12.18	5.85	
603 6/22/93 1650	247	69	415	12.87	5.90	223	31	311	11.68	9.12	5.05	196	56	208	10.38	12.11	6.10	load follow
604 6/22/93 1850	247	69	415	12.87	5.90	213	27	281	10.92	8.16	6.15	192	21	198	9.45	11.08	7.55	
604 6/22/93 2100	247	69	415	12.87	5.90	214	26	273	10.78	8.71	6.20	188	22	193	9.62	11.68	7.25	
604 6/22/93 2320	165	111	249	9.44	9.80	161	78	258	9.72	7.88	7.70	142	83	163	8.03	9.97	9.45	
604 6/23/93 0100	191	130	266	10.08	9.15	168	74	262	9.99	8.07	7.30	149	107	167	8.51	10.25	8.80	
605 6/28/93 1110	274	18	262	11.61	6.38	216	15	227	10.41	10.54	4.90	221	15	175	9.65	13.47	5.90	w/Nat Gas
605 6/28/93 1240	274	18	262	11.61	6.38	239	13	233	10.54	10.59	4.90	220	14	183	9.81	13.44	5.70	
605 6/28/93 1350	274	18	262	11.61	6.38	251	16	235	10.48	10.14	5.30	235	17	190	9.85	13.08	5.85	
605 6/28/93 1500	274	18	262	11.61	6.38	251	16	243	10.54	10.17	5.22	234	16	203	10.01	13.06	5.70	
605 6/28/93 1705	274	18	262	11.61	6.38	237	18	255	10.73	10.50	4.75	215	20	190	10.08	13.87	5.30	
605 6/28/93 1905	274	18	262	11.61	6.38	253	17	241	10.48	10.43	5.05	208	35	183	10.34	14.40	4.90	NGas off
605 6/28/93 2100	250	32	330	12.05	6.80	225	19	297	10.93	8.23	6.20	204	25	230	10.32	12.20	6.25	
605 6/28/93 2300	250	32	330	12.05	6.80	227	28	298	10.80	8.30	6.30	208	32	210	10.04	11.93	6.70	
605 6/29/93 0100	250	32	330	12.05	6.80	229	18	296	10.88	8.26	6.20	209	21	217	10.05	11.80	6.72	
605 6/29/93 0300	250	26	326	11.86	6.95	227	23	292	10.60	8.01	6.00	207	18	205	9.92	11.67	6.85	
605 6/29/93 0430	250	26	326	11.86	6.95	228	18	290	10.68	8.10	6.40	213	16	206	9.88	11.62	6.90	
605 6/29/93 0700	250	26	326	11.86	6.95	228	18	288	10.71	7.99	6.60	214	19	203	9.83	11.50	6.95	
605 6/29/93 0905	250	26	326	11.86	6.95	239	19	282	10.57	7.92	6.75	215	40	202	10.20	12.01	6.55	
605 6/29/93 1100	250	26	326	11.86	6.95	232	24	290	10.79	7.74	6.55	214	28	215	9.74	11.51	7.00	NGas on
605 6/29/93 1220	264	31	298	12.01	5.90	238	21	260	10.86	9.90	5.05	211	41	170	10.06	13.83	5.55	NGas on
605 6/29/93 1550	264	31	298	12.01	5.90	238	17	258	10.92	10.29	4.80	216	18	152	9.83	13.72	5.62	
605 6/29/93 1700	264	31	298	12.01	5.90	218	17	242	10.76	10.89	4.50	198	19	148	8.54	12.24	7.50	NGas off
605 6/29/93 2120	212	55	295	10.84	8.25	221	23	302	11.10	8.31	5.95	196	72	210	10.27	12.04	6.40	TCShield
606 6/29/93 2300	193	20	280	10.45	8.50	218	26	270	9.91	7.77	7.58	193	28	188	9.02	10.76	8.15	

PSCC Atapahoe Unit 4 Calcium/Humidification-Duct Injection, Ca(OH)2 calculations based upon 68% CaO

Test	Date & Time	Boiler		Sorbent Feed		Injector cal		Humidification		Bughouse Temps						Humid calc							
		Load	O2cr	Loc	A.W	B.e	%	Flow	Ca/S	Comp	Calc	Air	Tgo	Twl	H2O	A.W	Grid	Out	IDin	Opsis	Ta	Tcalc	%W
		MWe	%wet		%	%	g/min	%	%	scfm	°F	°F	gpm	°F	°F	°F	°F	°F	°F	°F	°F	°F	°F
606	6/30/93 0100	60	6.40	Duct	48	48	18.5	1.66	23	16.5	3951	250	65	38.0	1.09	147	148	148	147	30	153	7.49	
606	6/30/93 0300	60	6.40	Duct	48	48	18.5	1.67	23	15.9	3965	246	65	38.0	1.14	147	147	148	147	30	152	7.29	
606	6/30/93 0500	58	6.80	Duct	48	48	18.5	1.74	25	20.5	3965	248	64	38.0	1.12	147	147	149	147	30	150	7.26	
606	6/30/93 0630	58	6.80	Duct	48	48	18.5	1.74	24	18.3	3972	247	64	37.0	1.13	147	147	148	147	30	152	7.31	
606	6/30/93 0845	58	6.80	Duct	48	48	18.5	1.76	25	17.6	3948	249	65	38.0	1.10	147	147	149	147	30	151	7.37	
607	6/30/93 1045	48	6.90	Duct	48	48	18.5	2.15	30	24.4	4022	241	65	32.0	1.38	146	148	149	148	30	149	7.53	
607	6/30/93 1400	100	4.10	Duct	42	42	16.1	0.92	24	17.8	3636	280	63	65.0	0.54	148	151	152	154	30	155	9.08	
607	6/30/93 1600	91	5.30	Duct	73	73	28.1	1.80	31	28.1	3631	280	64	66.0	0.54	146	150	153	152	30	142	9.57	
607	6/30/93 1644	90	4.30	Duct	73	73	28.1	1.79	32	26.6	3683	279	64	61.0	0.60	145	150	151	152	30	156	8.57	
607	6/30/93 1900	84	4.80	Duct	66	66	25.4	1.72	43	25.7	3700	275	64	59.0	0.63	145	150	151	152	30	149	8.66	
607	6/30/93 2100	90	5.10	Duct	80	80	30.8	1.93	36	31.5	3639	276	64	65.0	0.56	146	149	152	154	30	150	8.57	
607	6/30/93 2300	74	6.40	Duct	66	66	25.4	1.82	34	28.1	3756	265	64	54.5	0.71	147	148	151	152	30	147	9.05	
607	7/1/93 0100	74	6.40	Duct	62	62	23.8	1.83	32	26.4	3794	260	65	51.0	0.76	146	148	150	151	30	143	8.95	
608	7/1/93 0300	60	7.10	Duct	48	48	18.5	1.72	24	18.8	3875	249	64	42.0	0.96	142	144	146	145	30	147	7.74	
608	7/1/93 0500	60	7.00	Duct	48	48	18.5	1.72	25	20.6	3889	247	64	41.0	1.00	143	144	145	144	30	147	7.60	
609	7/1/93 0645	60	6.90	Duct	48	48	18.5	1.72	28	23.4	3874	247	64	42.5	0.95	137	141	142	141	25	142	7.69	
610	7/1/93 1010	100	3.80	Duct	76	76	29.2	1.69	36	32.6	3626	279	65	66.0	0.54	147	148	152	152	30	153	9.32	
610	7/1/93 1150	109	3.60	Duct	83	83	31.9	1.69	43	32.0	3547	287	64	72.0	0.48	147	149	152	156	30	155	9.59	
610	7/1/93 1340	107	4.30	Duct	85	85	32.7	1.79	36	30.0	3475	289	64	79.0	0.43	146	151	155	158	30	141	9.26	
610	7/1/93 1505	105	4.60	Duct	85	85	32.7	1.84		28.8	3515	287	65	75.0	0.47	148	157	163	163	30	145	9.52	
610	7/1/93 1800	98	5.00	Duct	100	0	19.1	1.09	26	22.6	3525	289	65	73.0	0.48	150	157	159	162		141	9.56	
610	7/1/93 2300	78	5.90	Duct	100	0	19.1	1.42	22	19.3	3521	272	65	57.0	0.68	151	149	154	155		158	8.08	
611	7/2/93 0100	61	6.70	Duct	94	0	17.9	1.70	33	25.8	2917	257	65	44.5	0.86	143	145	148	147	30	149	7.83	
611	7/2/93 0300	61	6.90	Duct	86	0	16.4	1.54	30	25.1	2921	256	65	44.5	0.86	143	143	146	145	30	148	7.81	
611	7/2/93 0500	51	6.90	Duct	86	0	16.4	1.55	28	21.2	2910	254	64	43.5	0.86	142	146	149	149	30	148	7.44	
611	7/2/93 0645	61	6.80	Duct	86	0	16.4	1.52	29	25.6	2890	253	64	43.0	0.88	143	142	146	144	30	146	7.83	
612	7/2/93 0915	79	5.80	Duct	100	0	19.1	1.40	13	20.6	2906	269	65	55.0	0.65	152	147	154	154	30	159	7.55	
612	7/2/93 1120	106	4.60	Duct	100	0	19.1	1.06	22	12.8	3318	291	64	77.0	0.48	151	150	156	158	30	155	8.56	
612	7/2/93 1250	102	4.60	Duct	100	0	19.1	1.08	15	16.8	3348	293	65	75.0	0.51	153	150	157	157	30	156	8.74	



Test	Date & Time	GAS ANAL ECON-DRY (1-12)				GAS ANALYSIS INLET-WET .....				GAS ANALYSIS OUTLET-WET .....				Comments					
		NO ppm	CO ppm	SO2 ppm	O2 %dry	NO ppm	CO ppm	SO2 ppm	H2O %	NO ppm	CO ppm	SO2 ppm	H2O %		O2 %				
606	6/30/93 0100	193	20	280	10.45	8.50	214	25	274	10.06	7.84	7.30	191	25	201	9.12	10.61	8.18	
606	6/30/93 0300	230	38	291	10.69	8.90	226	25	259	9.63	7.46	7.98	189	30	160	7.67	9.44	10.60	blr upset
606	6/30/93 0500	187	32	280	10.44	8.80	172	28	264	9.96	7.63	7.56	153	27	184	8.91	10.37	8.45	3mills
606	6/30/93 0630	187	32	280	10.44	8.80	174	26	264	9.96	7.68	7.55	158	21	189	8.91	10.36	8.45	
606	6/30/93 0845	187	32	280	10.44	8.80	177	24	260	9.94	7.74	7.55	157	19	188	8.86	10.52	8.42	
607	6/30/93 1045	197	32	253	9.67	9.38	188	29	232	9.10	7.64	8.50	163	26	160	8.45	10.45	8.87	load follow
607	6/30/93 1400	273	73	348	12.71	5.80	236	43	317	11.85	9.29	4.95	212	51	235	10.78	13.19	5.52	
607	6/30/93 1600	273	73	348	12.71	5.80	244	32	250	9.60	7.79	7.95	199	245	180	9.61	12.50	6.95	
607	6/30/93 1644	237	131	325	12.31	6.75	224	27	302	11.42	8.99	5.50	196	127	203	10.61	13.03	5.80	
607	6/30/93 1900	237	131	325	12.31	6.75	223	24	300	11.29	8.96	5.70	194	49	198	10.21	12.73	6.40	
607	6/30/93 2100	231	81	314	11.63	7.20	229	28	292	10.79	8.79	6.25	203	54	184	10.12	12.79	6.45	
607	6/30/93 2300	231	81	314	11.63	7.20	206	20	265	10.07	8.54	7.30	189	23	174	9.36	12.06	7.60	
607	7/1/93 0100	231	81	314	11.63	7.20	197	17	252	9.61	8.05	7.90	175	21	170	8.97	11.56	8.12	113 sat
608	7/1/93 0300	194	21	271	10.16	9.05	182	18	248	9.53	7.96	8.02	159	14	181	8.72	11.00	8.52	30Ta, 143
608	7/1/93 0500	194	21	271	10.16	9.05	182	18	250	9.58	7.87	7.94	164	18	178	8.73	10.88	8.48	
609	7/1/93 0645	192	21	272	10.34	8.85	178	18	254	9.79	7.99	7.70	161	14	171	8.72	11.00	8.48	25Ta, 138°
610	7/1/93 1010	248	103	345	12.95	5.90	221	35	309	11.61	9.52	5.05	203	109	188	10.70	13.33	5.60	
610	7/1/93 1150	252	199	355	13.43	5.15	236	35	310	11.71	9.34	5.05	209	93	192	10.98	13.59	5.40	
610	7/1/93 1340	252	199	355	13.43	5.15	241	28	295	11.13	8.59	5.75	214	44	188	10.49	13.13	6.00	
610	7/1/93 1505	252	199	355	13.43	5.15	249	22	290	11.08	8.79	5.80	218	43	190	10.42	12.89	6.00	
610	7/1/93 1800	252	199	355	13.43	5.15	221	27	290	10.93	8.32	6.60	216	29	206	9.70	12.08	6.85	Load droppe
610	7/1/93 2300	210	18	279	10.52	8.60	207	17	266	10.19	8.72	6.95	185	16	191	9.33	12.26	7.55	
611	7/2/93 0100	195	21	272	10.32	8.96	182	18	252	9.85	8.43	7.36	165	15	163	8.85	11.65	8.20	al/w=0.5
611	7/2/93 0300	195	21	272	10.32	8.96	183	18	251	9.78	8.30	7.52	166	13	166	8.85	11.55	8.21	
611	7/2/93 0500	195	21	272	10.32	8.96	182	17	253	9.83	8.01	7.40	167	13	174	8.88	11.17	8.25	H2O upset
611	7/2/93 0645	201	16	272	10.42	8.60	187	17	258	9.98	8.17	7.40	165	13	171	9.03	11.25	8.05	
612	7/2/93 0915	201	16	272	10.42	8.60	203	17	268	10.29	8.15	7.00	190	16	195	9.47	11.64	7.30	
612	7/2/93 1120	264	36	332	12.50	6.35	233	27	292	11.15	8.55	5.83	216	24	235	10.52	12.92	5.95	
612	7/2/93 1250	264	36	332	12.50	6.35	229	25	290	10.91	8.55	6.10	207	26	225	10.35	12.75	6.10	



Test	Date & Time	Economizer Exit, dry (1-12)					Baghouse Inlet Gas Analysis, wet					Stack Gas Analysis, wet					NO	NO	Comments			
		CO	NO2	CO2	O2	SO2	CO	NO2	CO2	H2O	O2	SO2	CO	NO2	CO2	H2O				O2	SO2	
		ppm	ppm	%	%dry	ppm	ppm	ppm	%	%	ppm	ppm	ppm	%	%	%	ppm	ppm				
705	10/19/93 11:30	123	3	13.92	4.85	480	240	39	-4	12.62	9.17	4.25	438	227	83	-3	11.47	12.90	4.80	252	195	Toxics 22
705	10/19/93 12:30	97	1	13.92	4.70	475	245	69	-3	13.08	9.25	3.58	457	219	86	-3	11.53	12.82	4.70	247	197	
705	10/19/93 13:30	59	0	13.77	4.90	472	246	40	-4	12.72	8.99	4.00	431	222	45	-3	11.45	12.73	4.85	252	200	
705	10/19/93 14:30	49	0	13.53	5.05	453	247	42	-4	12.95	9.15	3.70	437	221	58	-3	11.47	12.86	4.80	239	196	
705	10/19/93 15:30	56	0	13.72	4.90	460	248	30	-4	12.69	8.99	4.10	426	235	48	-2	11.37	12.79	4.90	240	195	
705	10/19/93 16:30	79	1	13.84	4.70	460	245	66	-4	13.30	9.32	3.35	435	215	55	-3	11.57	12.77	4.80	235	192	Toxics 23
706	10/20/93 8:30	408	4	13.24	5.00	457	229	52	-3	12.24	9.42	4.20	430	215	264	-3	11.14	12.98	5.05	240	190	
706	10/20/93 9:30	225	1	13.30	5.05	460	235	20	-3	12.02	9.11	4.62	417	221	109	-3	10.84	12.54	5.35	250	200	
706	10/20/93 10:30	308	1	13.38	5.05	461	234	50	-3	12.18	9.27	4.30	425	213	176	-3	10.95	12.95	5.10	243	192	
706	10/20/93 12:50	138	2	12.82	4.80	450	230	37	-3	12.24	9.28	4.22	431	215	191	-3	11.04	12.70	5.20	250	194	
707	10/20/93 14:30	204	1	13.10	5.30	451	238	35	-4	11.98	9.11	4.50	422	219	200	-4	10.81	12.62	5.25	264	200	Toxics 24
707	10/20/93 15:30	192	1	12.83	5.68	438	242	39	-4	11.79	9.04	4.70	412	221	188	-4	10.82	13.30	5.20	222	200	
707	10/20/93 16:40	198	2	12.92	5.60	449	240	47	-4	11.56	9.10	4.50	418	218	215	-3	10.89	12.98	5.25	230	194	
707	10/20/93 17:30	171	1	12.85	5.50	432	237	28	-3	11.71	8.89	4.85	392	228	179	-3	10.80	12.92	5.25	207	191	
707	10/20/93 18:40	169	1	12.07	5.35	207	240	45	-4	12.07	9.20	4.50	392	221	142	-3	10.83	12.83	5.25	219	193	
708	10/26/93 14:30	259	2	13.84	4.30	468	205	51	-4	12.60	9.16	3.80	430	188	177	-3	11.52	12.13	4.45	355	165	50 deg approach
709	10/26/93 15:50	184	2	13.53	4.70	450	208	38	-2	12.56	9.17	3.82	423	190	14	-2	11.31	11.92	4.83	277	170	
710	10/26/93 17:10	237	1	13.80	4.43	450	205	38	-3	12.45	9.07	3.90	413	188	184	-2	11.54	12.12	4.52	260	165	
711	10/27/93 9:40	312	4	13.40	4.40	338	215	69	-3	12.40	9.09	3.85	315	198	225	-3	11.28	12.22	4.60	245	178	30 deg approach
712	10/27/93 14:30	370	2	13.17	4.50	365	210	134	-4	11.94	8.62	4.10	325	198	224	-3	11.06	12.44	4.70	212	177	
713	10/27/93 15:10	424	1	13.21	4.60	378	210	60	-4	11.87	8.54	4.30	330	195	355	-3	11.04	12.50	4.67	200	170	
714	11/1/93 9:10	256	1	13.66	4.40	413	245	57	-5	12.56	8.06	4.05	385	230	228	-3	12.40	8.89	4.50	380	225	Base
715	11/1/93 13:40	119	2	13.70	4.90	380	260	43	-4	12.58	8.00	4.10	355	233	147	-4	11.47	12.78	4.80	220	205	
716	11/1/93 16:50	215	1	14.60	4.45	397	250	48	-4	12.74	9.02	3.90	348	220	144	-3	11.57	12.75	4.70	195	205	
717	11/1/93 17:50	166	0	14.05	4.70	365	255	42	-4	12.67	8.04	4.05	340	227	167	-3	11.78	12.66	4.40	217	195	B feeder only
719	11/2/93 11:30	220	2	14.04	4.80	360	250	51	-3	12.83	8.83	4.00	337	225	201	-3	11.70	12.38	4.70	223	205	
720	11/2/93 14:40	391	1	13.81	4.70	350	250	70	-3	12.99	8.97	3.70	330	215	215	-2	11.68	12.70	4.60	210	200	
721	11/2/93 14:40	149	2	14.00	4.55	385	240	46	-4	12.80	8.83	4.10	361	216	125	-3	11.71	12.81	4.65	220	197	good?