

**FILE COPY**

~~6600142~~  
File No. 22.908

**COMMERCIAL-SCALE DEMONSTRATION OF THE  
LIQUID PHASE METHANOL PROCESS**

**ENVIRONMENTAL MONITORING PLAN (FINAL)**

**AUGUST 1996**

**PREPARED BY**

**AIR PRODUCTS AND CHEMICALS, INC.**

**AND**

**EASTMAN CHEMICAL COMPANY  
KINGSPORT, TENNESSEE**

**FOR**

**AIR PRODUCTS LIQUID PHASE CONVERSION COMPANY, L.P.**

**UNITED STATES DEPARTMENT OF ENERGY  
PITTSBURGH ENERGY TECHNOLOGY CENTER  
UNDER COOPERATIVE AGREEMENT NO. DE-FC22-92PC90543**

**ENVIRONMENTAL MONITORING PLAN**  
**LPMEOH™ Process Demonstration Facility**

**INDEX**

- 1. Introduction and Demonstration Plan Goals**
  - 1.1 Environmental Monitoring Plan Purpose
  - 1.2 *Environmental Monitoring Plan Scope*
  
- 2. Project Description**
  - 2.1 Background and History of the Project
  - 2.2 Project Schedule
  - 2.3 Site and Facility Description
  
- 3. Process Description**
  - 3.1 General Description
  - 3.2 Detailed Description
  
- 4. Emissions and Discharges**
  - 4.1 General Description
  - 4.2 Atmospheric Emissions and Control Systems
  - 4.3 Aqueous Discharges and Control Systems
    - 4.3.1 Flows to the Wastewater Treatment Plant
    - 4.3.2 Flows Directly to the Holston River
    - 4.3.3 Flow to Eastman Plant 19
  - 4.4 Solid Waste Discharges and Management Systems
    - 4.4.1 Spent Catalyst Slurry
    - 4.4.2 Guard Bed Catalyst
  
- 5. Compliance Monitoring**
  - 5.1 Existing System
    - 5.1.1 Gaseous Streams
    - 5.1.2 Aqueous Streams
    - 5.1.3 Solid Wastes
  - 5.2 Demonstration Project
    - 5.2.1 Air Permit
    - 5.2.2 Aqueous Streams
    - 5.2.3 Solid Wastes
  
- 6. Supplemental Monitoring**
  - 6.1 General
  - 6.2 Existing Subsystem Data
    - 6.2.1 Catalyst Guard Bed
    - 6.2.2 Methanol Distillation
    - 6.2.3 Coal Gasification

- 6.3 Liquid Phase Methanol Data
- 6.3.1 Catalyst Poisons Study
- 6.3.2 LPMEOH™ Reactor Study
- 6.3.3 Air Monitoring
- 6.3.4 Noise
- 6.3.5 Liquid Waste Monitoring
- 6.3.6 Solid Waste
- 6.3.7 Confirmation of Environmental Monitoring Plan from Task 5 Topical Reports

**7. Data Management and Reporting**

- 7.0 General - Background and Overview
- 7.1 Eastman Reporting of "Publicly Available Technical Data"
- 7.2 Reporting of Information in Technical Progress Reports
- 7.3 Reporting of EMP Compliance Monitoring Information
- 7.4 Reporting of EMP Supplemental Monitoring Information
- 7.5 Environmental Monitoring Reports (EMR's)
- 7.6 Report Requirements Check List

**APPENDIX**

- A. Process Flow Diagrams
- B. Equipment List
- C. Milestone Schedule
- D. Work Breakdown Summary
- E. Equipment Arrangement Plan
- F. Equipment Arrangement Isometric
- G. Air Permit Application
- H. Approved Air Permit
- I. 1994 Catalyst Poisons Study
- J. 1996 LPMEOH™ Reactor Study

## 1. Introduction and Demonstration Plan Goals

The Clean Coal Technology Program is a nearly \$7 billion technology demonstration program that was legislated by Congress to be funded jointly by the federal government and industrial sector participants. The goal of the Clean Coal Technology Program is to make available to the United States marketplace a number of advanced, more efficient, reliable, and environmentally responsive coal utilization and environmental control technologies.

Air Products Liquid Phase Conversion Company, L.P. (the Partnership), a joint venture between Air Products and Chemicals, Inc. (Air Products) and Eastman Chemical Company (Eastman), will design, construct, own and operate a 260 ton-per-day Liquid Phase Methanol (LPMEOH™) demonstration unit at the Eastman facility in Kingsport, Tennessee. The demonstration unit will be located on property currently owned by Eastman. It will take synthesis gas from Eastman's coal gasifier and will supply an existing downstream chemical plant with methanol. Some of the methanol produced will be used in stationary and mobile demonstrations to test the fuel characteristics of the methanol produced.

### 1.1 Environmental Monitoring Plan Purpose

As specified in the Cooperative Agreement, the Partnership is required to develop an Environmental Monitoring Plan (EMP) which describes in detail the environmental monitoring activities to be performed during the operation of the LPMEOH™ demonstration unit. The purpose of the EMP is to: 1) document the extent of compliance monitoring activities, i.e. those monitoring activities required to meet permit requirements, 2) confirm the specific environmental impacts predicted in the National Environmental Policy Act documentation, and 3) establish an information base for the assessment of the environmental performance of the technology for future commercialization.

### 1.2 Environmental Monitoring Plan Scope

This plan describes the LPMEOH™ demonstration unit that will be constructed on Eastman's site in Kingsport, Tennessee; it describes the compliance monitoring and supplemental monitoring that is associated with the new demonstration unit and the production of methanol. It further provides information from Eastman's existing facilities to provide an overall assessment of the LPMEOH™ technology.

Phase 3, Task 4 of this demonstration project is off-site fuel testing of the product methanol. This testing will take place in 1998 and 1999, two years after start up. An EMP supplement for this task will be provided at a later date; but at least 60 days prior to the start of Phase 2, Task 4 Off-site Testing Construction.

If the decisions from the Design Verification Testing (DVT Phase 1, Task 5) are to demonstrate the production of dimethyl ether (DME) as a mixed co-product with methanol; then an additional supplement to this EMP will be written. The production of DME is not considered in this EMP.

## 2. Project Description

### 2.1 Background and History of the Project

The purpose of this proposed project is to demonstrate the commercial viability of the Liquid Phase Methanol (LPMEOH™) Process using coal-derived synthesis gas. This project is planned to be conducted pursuant to the U. S. Department of Energy (DOE) Clean Coal Technology Program.

The United States needs future sources of alternative liquid fuels. With domestic oil production declining and imports increasing, the potential of producing affordable liquid fuels from non-petroleum sources could one day prove both strategically and economically important. The LPMEOH™ Process offers an extremely attractive route to supplementing our liquid fuel supplies with methanol made from the abundant coal reserves of the United States.

Methanol also has a broad range of commercial applications. It can be substituted for or blended with gasoline to power vehicles. It is an excellent fuel for the rapid-start combustion turbines used by utilities to meet peak electricity demands. It contains no sulfur and has exceptionally low nitrogen oxide characteristics when burned. It can also be used as a chemical feedstock.

Air Products and Eastman have entered into a joint venture known as Air Products Liquid Phase Conversion Company, L.P. (The Partnership). The Partnership will participate with the DOE in the Clean Coal Technology demonstration of Liquid Phase Methanol technology. The Partnership will design, build, own, and operate a nominal 260 ton-per-day LPMEOH™ process unit at Eastman's integrated coal gasification facility site in Kingsport, Tennessee. The program objectives are to demonstrate the LPMEOH™ process scale-up and operability (up to four years) under various coal-based synthesis gas feed compositions and to gain operating experience for future synthesis gas conversion projects. The LPMEOH™ technology offers significant potential, over existing foreign Lurgi and Imperial Chemical Industries methanol production technologies to reduce electric power generation costs with the co-production of chemical feedstocks and alternative liquid fuels. The domestically developed LPMEOH™ technology uses United States coal to produce clean, storable, liquid fuels and chemical feedstocks. Eventual commercialization of the LPMEOH™ process would provide chemical feedstock and electric power cost savings, lower sulfur dioxide (SO<sub>2</sub>) and nitrogen oxide (NO<sub>x</sub>) emissions, and reduce the use of imported liquid fuels.

The LPMEOH™ technology to be demonstrated at the Eastman facility could someday be used as an adjunct to an integrated gasification combined cycle (IGCC) power plant—one of the cleanest and most efficient of the 21st century power generating options. When the IGCC power plant is not generating at its full capacity, excess coal gas could be used to make methanol. The methanol could be stored onsite and used in peaking

turbines or sold as a commercial fuel or a chemical feedstock. In this configuration, the cost of making methanol from coal is likely to be competitive with stand alone natural gas-to-methanol facilities.

The LPMEOH™ demonstration unit will be integrated with Eastman's facility, accepting synthesis gas and converting it to methanol, for use as a chemical feedstock within the Eastman facility. A portion of the methanol production would be used as a fuel, for use as a low-NO<sub>x</sub> combustion fuel for testing in stationary power applications and mobile transportation use.

These end-use tests would provide a basis for the comparison of the product methanol with conventionally accepted fuels including emission levels and economic viability. The program goal of demonstrating methanol as a fuel would lead to the potential for greater use of oxygenated fuels, which burn cleaner than conventional fuels, thereby reducing air emissions from mobile (e.g., buses and vanpools) and stationary (e.g., engines, turbines, and boilers) sources.

The U. S. Department of Energy, under the Clean Coal Technology Program, will provide cost-shared financial assistance for the construction of the commercial-scale LPMEOH™ demonstration unit by The Partnership. Air Products will design and construct the LPMEOH™ demonstration unit and Eastman will operate it. The demonstration unit will be a nominal 260 ton-per-day-unit situated on a 0.6 acre plot within the existing Eastman facility in Kingsport, Tennessee.

The Eastman coal gasification facility has operated commercially since 1983. Eastman currently both produces and purchases methanol for use at the site. The net affect of adding the LPMEOH™ demonstration unit is to require the purchase of a nominal 30 tons per day of additional methanol for the site. This net amount also includes the methanol which will be used in tests of combustion turbines and vehicles. At this site, it will be possible to ramp up and down to demonstrate the unique load following flexibility of the LPMEOH™ demonstration unit for application to coal-based electric power generation facilities.

The operation at Eastman may also include the production of dimethyl ether (DME) as a mixed coproduct with methanol for demonstration as a potentially storable fuel pending preliminary laboratory and market Design Verification Test (DVT Phase 1, Task 5) results.

## 2.2 Project Schedule

The project is divided into the following three phases:

- Design
- Construction
- Operation

The design phase includes all of the engineering needed to construct the demonstration unit. This activity started in October of 1993 and was completed in early 1996. The Construction Phase started in October of 1995 and includes the fabrication of the equipment and the field construction tasks (foundations, steel erection, etc.). The demonstration unit is expected to be commissioned by the end of 1996. The off-site product-use testing is included in the operation phase and is expected to start in early 1998 and finish in late 1999. The demonstration unit will operate (Phase 3) for four years. During this period it will be operated to prove the commercial viability of the process. This Methanol Operation task is described in Task 2.1 of Phase 3 of the "Statement of Work". The latest "Milestone Schedule Status Report" and the "Work Breakdown Summary" (from the "Statement of Work") are included in Appendixes C and D.

### 2.3 Site and Facility Description

The 0.6 acre site proposed for the LPMEOH™ demonstration unit is located in Kingsport, Tennessee, at the Eastman facility. The Eastman facility is on the western edge of Sullivan County and includes a small portion of Hawkins County. The world headquarters of Eastman Chemical Company are also located in Kingsport. The Eastman facility also includes the eastern half of Long Island, where the demonstration unit is being built adjacent to existing process facilities.

The Kingsport area is shown in Figure 2.2-1. The location of the proposed plant on Long Island is shown on Figure 2.2-2. A photograph of the Eastman facility as it currently exists is also shown on Plate 2.1. The current site is a gravel covered area bounded to the north by an elevated pipe rack, to the west by an interplant road that runs between the future process area and a chemical manufacturing plant, to the east by an existing methyl acetate plant, and to the south by an interplant road and control and change house. The demonstration unit will resemble the existing facility surroundings.

The proposed project includes four major process areas. The reaction area includes the reactor and its associated equipment. The purification area includes two distillation columns and their heat exchangers. The storage/utility area comprises oil and product methanol storage. The catalyst preparation/reduction area is under roof with several large vessels, slurry handling equipment, and a utility oil skid. An equipment arrangement plan and isometric view are included in Appendixes E and F.



Kingsport Convention and Visitors Bureau  
 Great Kingsport Area Chamber of Commerce, Inc.  
 931 E. Main  
 Kingsport, Tennessee 37603  
 (615) 316-1010




FIGURE 2.2-1 KINGSPORT AREA




FIGURE 2.2-2 LOCATION OF PROPOSED PROJECT SITE



PROPOSED SITES

PLATE 2 / AERIAL PHOTOGRAPH OF LONG ISLAND

### 3. Process Description

#### 3.1 General Description

The reactor used in the LPMEOH™ process is unlike the conventional gas phase reactors that use fixed beds of catalyst pellets and largely depend upon recycle diluent gas to both dilute the carbon monoxide concentration and control the temperature rise caused by the heat of reaction. The LPMEOH™ reactor is a slurry reactor with small, powder-size catalyst particles suspended in inert mineral oil. The synthesis gas bubbles up through the slurry where the hydrogen and carbon monoxide dissolve in the oil and diffuse to the catalyst surface where the methanol reaction occurs. The product methanol diffuses out of the slurry and exits as a vapor with the unreacted synthesis gas. The inert oil acts as a heat sink and permits isothermal operation. The net heat of reaction is removed via an internal heat exchanger which produces steam. Unlike the gas phase reactors, that limit the per-pass conversion of synthesis gas to methanol to accommodate the reaction exotherm, the LPMEOH™ reactor maintains isothermal operation. The methanol vapor leaves the reactor and is condensed to a liquid, sent to the distillation columns for removal of higher alcohols, water, and other impurities, and is then stored in the day tanks for sampling prior to being sent to Eastman's methanol storage. A portion of the unreacted synthesis gas is sent back to the reactor with the synthesis gas recycle compressor, improving cycle efficiency. The methanol will be used for downstream feedstocks and for off-site fuel testing.

Unlike the gas phase reactors, the LPMEOH™ reactor is tolerant to CO-rich gas. Shift and carbon dioxide removal are not required. Low hydrogen-to-carbon monoxide ratios are acceptable as is any carbon dioxide content. Finally, in contrast to the gas phase reactor in which the catalyst is sensitive to flow variations and changes from steady-state, the LPMEOH™ reactor is eminently suited for load-following and for on-off operation.

The LPMEOH™ demonstration unit will be integrated with Eastman's coal gasification facility and inserted in parallel with an existing Lurgi technology methanol unit.

#### 3.2 Detailed Description

The LPMEOH™ demonstration unit consists of three main process sections: methanol synthesis, product purification, and catalyst slurry preparation and handling. The process flow diagrams for the various sections are shown in Appendix A (Sheets 1 through 7); and an equipment list is provided in Appendix B. (Block diagrams for the Kingsport complex and the LPMEOH™ Facility are also provided in Figures 7-1 and 7-2). A glossary of synthesis gas terminology is provided in Table 3-1. A discussion of each major plant section, with reference to the specific process flow diagram sheets in Appendix A, follows.

Table 3-1

## Glossary of Syngas Terms - Process Description

## LPMEOH™ Demonstration Unit

A. Syngas Terms:

|   | <u>Term:</u>    | <u>Definition:</u>  |
|---|-----------------|---|
| a | Syngas          | Abbreviation for Synthesis Gas  |
| b | Synthesis Gas   | A gas containing primarily* hydrogen (H <sub>2</sub> ), carbon monoxide (CO), or mixtures of H <sub>2</sub> and CO; intended for "synthesis" in a reactor to form methanol and/or other hydrocarbon products. |
| c | Feed Gas (Feed) | Syngas "fed" to a reactor for synthesis.  |
| d | Reduction Gas   | A nitrogen/carbon monoxide mixture used to reduce fresh catalyst.   |

The four feed gas streams for the LPMEOH™ slurry reactor are:

|   |                    |   |
|---|--------------------|---|
| e | Balanced Gas       | A syngas with a composition of hydrogen (H <sub>2</sub> ), carbon monoxide (CO) and carbon dioxide (CO <sub>2</sub> ) in stoichiometric balance for the production of methanol (approximately 2:1). |
| f | CO Gas             | A syngas containing primarily CO.   |
| g | H <sub>2</sub> Gas | A syngas with a H <sub>2</sub> to CO ratio greater than 2.  |
| h | Recycle Gas        | The portion of unreacted syngas effluent from the reactor, "recycled" as a feed gas.  |
| i | Reactor Feed       | The sum of the above four gases, as combined and fed to the LPMEOH™ reactor.  |

\*(Syngas may also contain carbon dioxide (CO<sub>2</sub>), water (H<sub>2</sub>O), and other gases).

### Methanol Synthesis (Sheets 1, 2, 3)

Three sources of synthesis gas from the Kingsport facility will be capable of combining to form the LPMEOH™ reactor feed stream. Approximately half of the Balanced Gas fresh feed to the Lurgi methanol unit will be diverted to the LPMEOH™ demonstration unit (Stream 30). A high purity carbon monoxide (CO) gas stream will also be available from the Kingsport cold boxes (Stream 10). The third feed stream will be the hydrogen (H<sub>2</sub> Gas) exiting the Lurgi unit (Stream 20). Since the H<sub>2</sub> Gas stream is at a lower pressure than the other two feed streams, it will be combined with the Recycle Gas stream (Stream 149), made up of unconverted synthesis gas from the LPMEOH™ reactor, and compressed in the (29K-01 feed gas) compressor.

The CO Gas and Balanced Gas streams will be combined and passed through the (29C-40 Carbonyl) Guard Bed. This bed, packed with activated carbon, will protect the methanol catalyst against possible upsets of iron and nickel carbonyl contaminants.

The combined Reactor Feed gas composition is typically 60.9% H<sub>2</sub>, 25.1% CO, 4.1% N<sub>2</sub> and 9.0% CO<sub>2</sub> (stream 109). This high pressure Reactor Feed gas stream is heated to approximately 402°F in the 29E-02 feed/product heat exchanger against the reactor effluent. The feed is then sparged into the 29C-01 LPMEOH™ reactor, mixes with the catalyst slurry and is partially converted to methanol vapor, releasing the heat of reaction to be absorbed by the slurry. The slurry temperature is controlled by varying the steam temperature within the heat exchanger tubes, which is accomplished by adjusting the steam pressure.

Disengagement of the product gas (methanol vapor and unreacted synthesis gas) from the catalyst/oil slurry occurs in the freeboard region of the LPMEOH™ reactor. Any entrained slurry droplets leaving the top of the reactor will be collected in the 29C-06 cyclone separator. An oil flush is maintained to this vessel to assist in the knockout of slurry. The product gas passes through the tubeside of the 29E-02 exchanger, where it is cooled to 250°F by heat exchanging the effluent gas stream against the reactor inlet gas stream. The condensed liquid oil droplets are collected in the 29C-05 High Pressure Oil Separator and then pumped back with the entrained slurry from the 29C-06 separator to the LPMEOH™ reactor by the 29G-01 A/B oil circulation pumps. To make up for oil losses into the product recovery train, fresh oil is added into the 29C-05 separator via the 29G-03 A/B pumps. Bypasses have been installed to allow both the 29C-06 and 29C-05 separators to free drain back to the reactor without the use of the 29G-01 pumps. In this mode, the fresh makeup oil would be added as a flush to the 29C-06 separator.

The product gas (stream 120) is further cooled to 105°F in an air-cooled exchanger (29E-03) and a cooling water exchanger (29E-04). The liquid methanol which is condensed is collected in the 29C-03 product separator. The overhead stream from the 29C-03 product separator contains unreacted syngas, 0.9% uncondensed methanol, and 2 ppmw uncondensed oil. Approximately 91% of this unreacted syngas stream is recycled back to the LPMEOH™ reactor after undergoing compression in the 29K-01 compressor. The balance of the unreacted gas returns to the Kingsport facility at 100°F and is sent to the boilers.

### Product Purification (Sheet 3, 7)

The condensed methanol (*stream 204*) contains 6 volume % dissolved gases, methyl formate, water, and some higher alcohols. These impurities are removed in a two column distillation train which will produce a methyl acetate feed-grade methanol product. The liquid (*stream 204*) from the 29C-03 product separator is flashed into the 29C-12 Methanol Stabilizer Feed Drum at approximately 70 psig. This vessel has one hour of holdup time to allow for some lag time due to rate and composition changes between the reactor train and the distillation system. Flashed gas from this separator is combined with the overheads of the two columns and sent to the Eastman boilers.

The first distillation column (29C-10) removes the dissolved gases and lighter boiling impurities, such as methyl formate, in the overhead (*stream 211*). The bottoms from this column are fed to the second train (29C-20) where the purified methanol product is removed as a top stage distillate product. Any non-condensable are combined with the overhead stream from the 29C-10 and 29C-12. The bottom draw from the 29C-20 is a crude methanol stream heavy in higher alcohols, water and any of the oil which was carried over from the reactor. This stream will be sent to the Lurgi distillation system for recovery of 25% (by weight) of the raw methanol and disposal of the oil, higher alcohols and water.

The methanol product produced from the 29C-20 distillation column is pumped by the 29G-21 methanol rectifier reflux pump to either the 29D-20 or 29D-21 lot tanks. After the appropriate purity checks are completed, the contents of the lot tanks will be transferred via the 29G-23 methanol transfer pump to Eastman bulk storage. In some off-design cases where impurities are greater than normal, the lot tanks will be rejected to Eastman's existing methanol Plant 19 for recovery. Product methanol for off-site fuel testing will be produced at limited times during the demonstration period by using only the first distillation column. The bottoms product will be cooled in the 29E-23 heat exchanger before transferring to the lot tanks.

### Catalyst Preparation and Slurry Handling (Sheets 4, 5, 6)

The catalyst slurry is activated in the 29C-30 reduction vessel which is an agitated, 304 stainless steel vessel equipped with a heating/cooling jacket. This vessel has three purposes:

1. Fresh Slurry Mix Tank
2. Catalyst Reduction Vessel
3. Spent Slurry Receiver.

Any reclaimed oil stored in the 29C-31 accumulator is first gravity drained into the top oil fill nozzle of the reduction vessel. The balance of 740 gallons of mineral oil is added using the 29G-34 pump. The oil is heated to approximately 200°F using the jacketed utility oil skid. Once the oil is at temperature, 2250 lb. of catalyst oxide is added to form a 30 wt% catalyst slurry mixture. The agitator is used during this time to ensure adequate suspension and more uniform concentration of the slurry.

Reduction gas, consisting of a blend of 96 volume % nitrogen and 4 volume % carbon monoxide (CO), is introduced into the reduction vessel via a gas sparger. The agitator is not required once the reduction gas is introduced. Over the course of the reduction, the slurry temperature is carefully increased while the consumption of CO is monitored to determine when the catalyst is completely reduced. The loss of oil to the vapor phase results in an increase to the catalyst concentration in the slurry from 30 wt % to approximately 40 wt %. The gas stream exiting the reduction vessel is cooled in the 29E-31 condenser, to condense any oil vapors leaving the reduction vessel against the reduction feed. The condensed oil is collected in the 29C-31 separator over the course of the reduction. This oil is reclaimed at the beginning of the next catalyst reduction batch. The temperature in the 29C-31 separator condensate accumulator is controlled by bypassing the reduction feed to minimize the amount of water condensed and collected with the oil.

The catalyst reduction procedure is completed in approximately 20 hours. At the end of reduction, the catalyst is fully active and can be transferred directly to the LPMEOH™ reactor via the 29G-30 transfer pump.

As new catalyst slurry is added to the LPMEOH™ reactor, the catalyst inventory is maintained by withdrawing an equivalent amount of partially deactivated or spent slurry from the reactor. Prior to transferring the slurry from the reactor, the 29C-30 catalyst reduction vessel is pre-warmed using the utility oil skid. The spent slurry is pressure transferred back to the 29C-30 catalyst reduction vessel via the recycle control valve around the 29G-30 Slurry Transfer Pump. Once there, the slurry is purged of the dissolved gases and cooled to a safe handling level at a rate of 60°F/hour using the utility oil system. After cooling, the spent slurry is transferred to the drums or tote bins. The containers will either be shipped off-site to a processor for metals recovery or will be hauled to the on-site incinerator.



## 4. Emissions and Discharges

### 4.1 General Description

Figure 4-1 "LPMEOH™ Plant Process and Waste Streams" is a diagram that shows the processing blocks, the emissions from these areas and the disposal points. The disposal points for the gas streams leaving the process are 1) existing Eastman boilers, 2) an existing Eastman scrubber, 3) the atmosphere, and 4) a new vent scrubber (item 29C-120). The great majority of the material is unconverted synthesis gas which goes to the boilers and is burned. These streams will be detailed in subsequent sections.

The solid waste streams will go to either 1) an offsite metals reclaimer, or 2) an existing Eastman incinerator.

The liquid wastes including storm water run-off from process areas will be treated in Eastman's existing Wastewater Treatment Facility.

### 4.2 Atmospheric Emissions and Control Systems

Four types of streams comprise the emission to the atmosphere:

- 1) Those that are treated in an existing vent scrubber in Plant 31 (31C-30)
- 2) Those that are sent to an existing boiler and burned
- 3) Those that are vented through the new 29C-120 Vent Scrubber to the atmosphere
- 4) Those that are vented directly to the atmosphere through local vents.

These streams are listed in Table 4-1. No new control devices are added except for the 29C-120 Vent Scrubber. This device is designed to handle plant emergency situations. The great majority of the plant safety valves are either vented to the 29D-02 Slurry Tank (if they contain oil) or the 29D-01 Safety Relief Knock-Out Drum. These vessels would contain liquids for identification and disposal. The vapors from these tanks go to the 29C-120 vent scrubber. Since this stream might contain methanol vapor, it is contacted with a water spray before it is vented through the tall stack to the atmosphere. The water spray is activated by a flow vane which detects any flow to the 29C-120. The scrub water from this vessel goes to the sewer and on to the wastewater treatment facility. Appendix A, Sheet 5 shows the relationship of the 29D-01 and 29C-120 described previously.

### 4.3 Aqueous Discharges and Control Systems

The aqueous discharges of the facility are directed to three discharge points.

- The existing Eastman wastewater treatment plant
- Directly to the Holston River
- To the existing Eastman Plant 19 (Lurgi Methanol Plant)




FIGURE 4-1 LPMEOH™ DEMONSTRATION UNIT PROCESS AND WASTE STREAMS

**TABLE 4-1 ATMOSPHERIC EMISSIONS  
Environmental Monitoring Plan**

**LISTING OF WASTE STREAMS THAT END UP BEING VENTED TO THE ATMOSPHERE**

| (a)<br>Point  | Stream description                                     | Source        | Valve    | (d)<br>MB point | (b)<br>Flow | (c)<br>Analysis |
|---|--|---------------|----------|-----------------|-------------|-----------------|
| <b>To Existing Vent Scrubber in Eastman's in Plant 31</b> |  |               |          |                 |             |                 |
| 21  | MeOH Storage Vent                                      | D-20 & D-21   | PSV 1680 |                 | N           | N               |
| 22  | MeOH Drain Tank Vent                                   | D-25          | PSV 1648 |                 | N           | N               |
| <b>To Tail Gas Header- To Existing Eastman Boilers</b>    |  |               |          |                 |             |                 |
| 24  | Compressor (process side) Seal Gas                     | K-01          |          |                 | N           | N               |
| 29  | Reduction Gas Vent                                     | C-31          |          |                 | N           | GC #10          |
| 25  | Guard Bed Regeneration                                 |               |          |                 | N           | N               |
| 23  | Plant Feed Gas Bypass                                  |               | V 1041   |                 | N           | N               |
| 19  | Distillation Fuel Gas                                  | C-11,C12&C-21 |          | 19              | FI-810      | GC #8           |
| 37  | Analytical Sample Streams                              |               |          |                 | N           | N               |
| 148   | Main Purge Gas Stream                                  | C-03          | PV 150   | 148             | FI 157      | GC #7           |
| 27  | Total of all the above streams to the Existing Boilers |               |          |                 | N           | N               |
| <b>Vented Directly to the Atmosphere</b>                  |  |               |          |                 |             |                 |
| 35  | Compressor(gear box side)Seal Gas                      | K-01          |          |                 | N           | N               |
| 35  | Oil Storage Tank(D-30) Vent                            | D-30          | PCV1421  |                 | N           | N               |
| 35  | Oil Water separator(C-50)Vent                          | C-50          |          |                 | N           | N               |
| 35  | Start up steam   | C-02          | V1608    |                 | N           | N               |
| 34  | Equipment Leak Emissions                               |               |          |                 | N           | Y               |
| 35  | Compressor(K-01)lube Oil Vent                          | K-70          |          |                 | N           | N               |
| <b>Vented Through 29C-120 Vent Scrubber</b>               |  |               |          |                 |             |                 |
| 36  | Safety Relief KO Drum(D-01)                            | D-01.D-02     | FT801    | 765             | N           | N               |

Notes:

(a) Point refers to points shown on Figures 7-1, 7-2, and 7-3

(b) N= not measured; Y= measured

(c) N= not analyzed; Y= analyzed; GC# = analyzed at continuous gas chromatograph point #

(d) MB Point = Material Balance Point shown on Process Flowsheet (Appendix A)

### 4.3.1 Aqueous Flows to the Wastewater Treatment Plant

#### 4.3.1.1 Process Flows

The following process waste streams are directed to the sewer system which flows to the Eastman wastewater treatment plant

- Boiler Feedwater Blowdown
- Scrub Water from 29C-120 (intermittent flow)

#### 4.3.1.2 Non Process Flows

All of the process areas are curbed and contain catch basins leading to the sewer system. Process areas which might have an oil or catalyst slurry spill are directed to an oil water separator installed below grade. The function of this device is to first of all collect the solids in a head works area (the velocity through the separation is less than 3 ft/min). Any oil is separated by uniquely designed plates that attract the oil to their surface, the oil flows up along the surface and is skimmed away to a storage compartment. As required, this oil will be removed by a licensed contractor for disposal. The solids will also be removed and disposed of in the same manner. The process areas that do not have the oil spill potential will bypass the oil/water separator and go directly to the interceptor sewer. These flows are shown in Figure 4-2.

### 4.3.2 Aqueous Flows Directly to the Holston River

- Cooling Tower Blowdown - The LPMEOH™ facility receives cooling water from an existing cooling tower. To the extent that it contributes additional heat load to the tower it will induce an incremental blowdown requirement. The tower blowdown goes directly to the river without treatment.
- Stormwater runoff from non process areas will flow through the storm-water drains, ditches, and/or swales and will be directed to the river.

### 4.3.3 Aqueous Flow to Eastman Lurgi Methanol Plant (Plant 19)

The bottoms from the 29C-20 methanol rectifier column contain methanol, water and higher alcohols. This stream goes to a distillation tower in the existing Lurgi plant for recovery of additional methanol. It contributes to a waste stream that is generated at the bottom of a subsequent distillation tower. Currently, the alcohol/water stream is treated in the wastewater treatment facility. However, due to the increased flow from the Liquid Phase Methanol plant and the limitations of Plant 19 distillation, it may become necessary to install additional controls in order to comply with HON<sup>1</sup> requirements. Eastman is evaluating the current capabilities of Plant 19's distillation section.

<sup>1</sup>Hazardous Organics Portion of National Emission Standards for Hazardous Air Pollutants

# STORMWATER FLOWS LPMEOH




FIGURE 4-2 LPMEOH STORM WATER RUN OFF

#### 4.4 Solid Waste Discharges and Management Systems

The plant has only two solid waste streams:

- Spent Catalyst - a slurry
- Guard Bed Adsorbent

##### 4.4.1 Spent Catalyst Slurry

A portion (about 5%) of the catalyst slurry is removed from the reactor every 12-14 days. This slurry is approximately 40 weight % reduced catalyst and 60 weight % mineral oil. It is cooled and stripped with nitrogen to remove any alcohols or other light materials (this stripping gas goes to the boilers). The slurry is put into drums and sent to a metals reclaimer where the copper and zinc values are recovered.

##### 4.4.2 Guard Bed Adsorbent

It is anticipated that a single charge of activated carbon will last for the four-year demonstration. Provisions are made for regenerating the adsorbent by heating with nitrogen gas (this waste gas also goes to the existing Eastman boilers). When the carbon loses its ability to adsorb nickel or iron carbonyl it will be removed, packaged in fiber drums and sent to the existing Eastman incinerator. An alternative might be to send it back to the manufacturer for recycling.

## 5. Compliance Monitoring

### 5.1 Existing System

Eastman's Kingsport facility has approximately 600 process emission sources. These permits account for over 2600 process vents. The State of Tennessee has granted an air construction permit for the LPMEOH™ addition. The LPMEOH™ Process emission source contains five process vents, three from oil storage equipment, one from the relief system, and the last vent accounting for equipment leaks. These vents and the permit will be described later in this section.

The LPMEOH™ demonstration unit will impact the air permits for two other process emission sources, the B-325 boilers and the plant 31 scrubber. In addition, because of the large capacity of Eastman's waste water treatment facility, the affect on the existing permit for the outfall to the river is negligible. All of these issues will be addressed in more detail later in this section.

#### 5.1.1 Gaseous Streams

##### 5.1.1.1 Boilers

NSPS and the HON require Eastman to monitor whether flow from the waste gas header is being vented to the boiler, to another control device such as the flare, or to the atmosphere. Normally, flow is directed to the boiler. A semi annual report is filed with the state indicating when the stream is diverted to the flare. No other monitoring is required.

Another regulation that covers one of the boilers is the Boiler and Industrial Furnace regulations that are part of RCRA. Since a vent is being added to the header, a waste characterization will be needed. This would involve initial sampling and analysis of the header gas after the LPMEOH™ demonstration unit is operational. The current law also requires additional sampling after three years. These samples will be analyzed for metals, chlorine, heating value, and ash.

##### 5.1.1.2 Plant 31 (Methyl Acetate Plant)

Documentation produced by the permitting personnel at Eastman in agreement with state regulators do not indicate that controlled storage tanks will need to be monitored to meet NSPS and HON regulations, but that the device that is controlling the emissions will need to be monitored. Measuring water flow and acetic acid flow to the absorber is adequate proof of the removal efficiency and will be all that is required. Regardless, because Plant 31 is a covered HON process, this monitoring will have to be done and no additional monitoring equipment will be required.

## 5.1.2 Aqueous Streams

### 5.1.2.1 Discharges to the Sewer

Wastewater from the demonstration unit is combined with wastewater from all the plants in the coal gasification complex in Eastman's interceptor sewer (ITS). This combined wastewater stream will be monitored for total flow, Total Organic Carbon (TOC), and pH before the Waste Water Treatment (WWT) Plant and at the outfall as specified in the NPDES permit. All process areas are curbed and drain to the ITS to contain any potential spills.

## 5.1.3 Solid Wastes

The solid process wastes generated by the demonstration unit will not be co-mingled. A discussion of their monitoring is included in Section 5.2.3.

## 5.2 Demonstration Project

### 5.2.1 Air Permit

The Air Permit for the LPMEOH™ demonstration unit is included in the Appendix. It identifies five new sources from this demonstration (see Fig. 5-2):

- A. Conservation Vent from 29D-30 Fresh Oil Storage Tank
- B. Conservation Vent from Tank 29D-31 Reclaimed Oil Storage Tank
- C. Conservation Vent from Tank 29C-36 Slurry Centrifuge Surge Pot
- D. Relief System; Vent from Water scrubber 29C-120
- E. Equipment leaks (Fugitive Emissions)

Table 5-2 shows the type and quantity of emissions from each of these sources. Note that process changes have resulted in the deletion of 29D-31 and 29C-36 tank vents. These sources had negligible emissions so there is no impact on the permitted quantities.

Point A above does not require monitoring as determined by the State because the vapor pressure of the mineral oil it contains is extremely low. As mentioned above, points B and C no longer exist.

The permit for point D shows a very small flow of carbon monoxide (0.88 tons/yr.). The design of the system producing this material (Conservation vent on 29D-02) has changed from 2% vol. CO to 2% vol H<sub>2</sub>. The flow has been reduced to .02 lb./hr of H<sub>2</sub> which would produce approximately 0.09 tons/yr. of H<sub>2</sub> emission in this stack. Any other flows to this source would happen only under upset conditions. The demonstration unit has been designed to minimize the scenarios where the safety valves will be lifted. This stream does not require monitoring as determined by the EPA; there is no applicable standard for hydrogen.



Flow Diagram

for Item 7 of APC-21 (& 24)




FIGURE 5-2

Emission Changes for New/Modified Sources

| Vent Code | Type of Emission | * Application Max. Lb/Hr | This Application Max. Lb/Hr | Net Change Max. Lb/Hr | Hrs./Yr. | Net Change Max. TYP |
|-----------|------------------|--------------------------|-----------------------------|-----------------------|----------|---------------------|
| A         | VOC              | Not Applicable           | Negligible                  | -                     | 8760     | Negligible          |
| B         | VOC              | Not Applicable           | Negligible                  | -                     | 8760     | Negligible          |
| C         | VOC              | Not Applicable           | Negligible                  | -                     | 8760     | Negligible          |
| D         | CO               | Not Applicable           | 0.20                        | +0.20                 | 8760     | +0.88               |
| Fugitives | VOC              | Not Applicable           | 4.56 TPY                    | -                     | 8760     | +4.56               |
| E         | CO               | Not Applicable           | 1.72 TPY                    | -                     | 8760     | +1.72               |
|           | TSP              | Not Applicable           | 0.10 TPY                    | -                     | 8760     | +0.10               |
|           | Others           | Not Applicable           | 1.68 TPY                    | -                     | 8760     | +1.68               |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |

|                        |                  |             |
|------------------------|------------------|-------------|
| Total Emission Change: | max.<br>lbs./hr. | max.<br>TPY |
| VOC                    | -                | +4.56       |
| TSP                    | -                | +0.10       |
| SO <sub>2</sub>        | -                | -           |
| NO <sub>x</sub>        | -                | -           |
| CO <sup>x</sup>        | -                | +2.60       |
| Other                  | -                | +1.68       |

Previous Application Submittal Date  
 (New Source)

TABLE 5-2

#### 5.2.1.1 Fugitive Emissions

Under requirements covered in the HON, Eastman is required to establish a Leak Detection and Repair (LDAR) program for the LPMEOH™ demonstration unit. This program will use EPA method 21 to test all potential leak points for fugitive VOC emissions on a regular basis. Leak and repairs will be documented as specified in the HON.

The LDAR program requires monitoring on a quarterly basis. The monitoring involves using a flame ionization detector to sniff the air around potential leak points such as valve packing and piping flanges. The detector checks ppm levels of Volatile Organic Compounds (VOC). At this time, the Fugitive Emission Management (FEMS) database for the demonstration unit has not been built. However, Table 5-3 shows an example of a FEMS database report for the existing methanol unit. A "leaker" is defined as a potential leakpoint with emission greater than 500 ppm VOC. Leakers must be repaired within a specified timeframe. If the percent of leakers drops below 2% of the total number of potential leakpoints, the reporting frequency drops to once every six months.

In addition to the LDAR requirements, the Industrial Hygiene Department will conduct a workplace exposure study to determine the normal CO background concentration. This will be done by placing a portable CO analyzer and recorder on a LPMEOH™ operations person during the course of a full day. The analyzer will record the concentration of CO that is encountered in a normal day of plant operation. This study will be conducted once within six months after the start of operations. Experience has shown that unless procedures change this one time study will be adequate for the four year program.

#### 5.2.1.2 Particulate Emissions

Particulate emissions from the catalyst handling process will be monitored by the Industrial Hygiene Department in periodic workplace exposure studies. Similar to the CO monitor, a device to monitor particulates will be worn by a LPMEOH™ operator during the catalyst charging process. The device will record the normal exposure level to particulate emissions that personnel will encounter during this process. This study will be conducted once during the first year of operation. Experience has shown that unless procedures change this one time study will be adequate for the four year program.

#### 5.2.2 Aqueous Streams

The aqueous discharges from the demonstration unit are described in section 4.3. None of the sources end up as new discharge points to the environment, each represents a small addition to an existing discharge point. As described in section 5.1.2 these streams do not effect the existing Eastman permits and therefore are not required to be

monitored separately. As required by the NPDES permit, the combined stream is monitored at the outfall of the wastewater treatment facility. These results are reported quarterly to the State and will be included in the quarterly Environmental Monitoring Report (EMR).

### 5.2.3 Solid Wastes

There are two solid waste streams from the demonstration unit. The first is the spent catalyst slurry which will be sent offsite to a metals reclaimer. The second stream is spent guard bed adsorbent (note that there are two guard beds in the process, the existing one which contains a catalytic material and the new bed which contains an adsorbent material) which will be incinerated on site. The Eastman incinerator is classified as a hazardous waste incinerator. Both hazardous and non-hazardous waste can be burned in this incinerator. The state only requires that input rate of hazardous waste be monitored. Because the guard bed adsorbent for the demonstration unit is similar to the guard bed adsorbent used in the existing Methanol unit which is considered non-hazardous based on testing required by RCRA, compliance monitoring should not be required. It will be necessary to confirm the non-hazardous classification when the new guard bed is in operation.

TABLE 5-3 Leak Summary Report

Acid Division

Reporting Period Start Date :07/01/95

Reporting Period Ending Date :02/01/96

PAGE 1 OF 2

Area ACID-AA

Sub Area MEOH

| Equipment Type  | Chemical State / Monitor Type | Initial Number Scheduled | Points Remaining | Number Leakers | Percent Leakers | Number of Repair Attempts | Number Repaired | Number Still Leaking | Percent Repaired | Number Repair Delays |
|-----------------|-------------------------------|--------------------------|------------------|----------------|-----------------|---------------------------|-----------------|----------------------|------------------|----------------------|
| CON             | Light Liquid / Monitor        | 785                      | 0                | 8              | 1.02            | 11                        | 8               | 0                    | 100              | 0                    |
| CON             | Light Liquid / Visual         | 234                      | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| CON             | Vapor / Monitor               | 219                      | 0                | 3              | 1.37            | 4                         | 3               | 0                    | 100              | 0                    |
| CON             | Vapor / Visual                | 128                      | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| Summary for CON |                               | 1366                     | 0                | 11             | N/A             | 15                        | 11              | 0                    | N/A              | 0                    |
| CVS             | Vapor / Monitor               | 31                       | 0                | 0              | .000            | 0                         | 0               | 0                    | ****             | 0                    |
| CVS             | Vapor / Visual                | 6                        | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| Summary for CVS |                               | 37                       | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| INS             | Light Liquid / Visual         | 77                       | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| INS             | Vapor / Visual                | 18                       | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| Summary for INS |                               | 95                       | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| PMP             | Light Liquid / Monitor        | 152                      | 0                | 8              | 5.26            | 10                        | 7               | 1                    | 87.5             | 0                    |

Note 1: "Initial Number Scheduled" includes first monitoring attempts only.  
 Note 2: "Number of Repair Attempts" includes multiple attempts on the same point.  
 Note 3: "Percent Leakers" is based on the total number of points monitored.  
 Note 4: For CON & SCR, Light Liquid or Vapor points with Visual compliance method are Exempt points.

**Leak Summary Report**  
**Acid Division**

Reporting Period Start Date : 07/01/95  
Reporting Period Ending Date : 02/01/96

TABLE 5-3  
PAGE 2 OF 2

Area ACID-AA

Sub Area MEOH

| Equipment Type          | Chemical State / Monitor Type | Initial Number Scheduled | Points Remaining | Number Leakers | Percent Leakers | Number of Repair Attempts | Number Repaired | Number Still Leaking | Percent Repaired | Number Repair Delays |
|-------------------------|-------------------------------|--------------------------|------------------|----------------|-----------------|---------------------------|-----------------|----------------------|------------------|----------------------|
| PMP                     | Light Liquid / Visual         | 589                      | 0                | 1              | N/A             | 1                         | 1               | 0                    | N/A              | 0                    |
| <b>Summary for PMP</b>  |                               |                          |                  |                |                 |                           |                 |                      |                  |                      |
|                         |                               | 741                      | 0                | 9              | N/A             | 11                        | 8               | 1                    | N/A              | 0                    |
| PRV                     | Vapor / Visual                | 120                      | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| <b>Summary for PRV</b>  |                               |                          |                  |                |                 |                           |                 |                      |                  |                      |
|                         |                               | 120                      | 0                | 0              | N/A             | 0                         | 0               | 0                    | N/A              | 0                    |
| VLV                     | Light Liquid / Monitor        | 1045                     | 274              | 12             | 1.15            | 12                        | 11              | 1                    | 91.7             | 1                    |
| VLV                     | Light Liquid / Visual         | 1                        | 0                | 1              | N/A             | 1                         | 1               | 0                    | N/A              | 0                    |
| VLV                     | Vapor / Monitor               | 313                      | 91               | 4              | 1.28            | 4                         | 2               | 2                    | 50.0             | 2                    |
| <b>Summary for VLV</b>  |                               |                          |                  |                |                 |                           |                 |                      |                  |                      |
|                         |                               | 1359                     | 365              | 17             | N/A             | 17                        | 14              | 3                    | N/A              | 3                    |
| <b>Summary for MEOH</b> |                               |                          |                  |                |                 |                           |                 |                      |                  |                      |
|                         |                               | 3718                     | 365              | 37             | N/A             | 43                        | 33              | 4                    | N/A              | 3                    |

Note 1: "Initial Number Scheduled" includes first monitoring attempts only.

Note 2: "Number of Repair Attempts" includes multiple attempts on the same point.

Note 3: "Percent Leakers" is based on the total number of points monitored.

Note 4: For CON & SCR, Light Liquid or Vapor points with Visual compliance method are Exempt points.

## 6. Supplemental Monitoring

### 6.1 General

The attached Figure 6-1 is from the Cooperative Agreement. It describes in simple terms how the Liquid Phase Methanol Demonstration Unit integrates with existing Eastman Facilities. The Cooperative Agreement states that even though the data from the existing subsystems (non-shaded blocks) are not considered contract data, Eastman will provide certain types of "Publicly Available Technical Data" for these units. An outline of this data is contained in section 6.2.

A description of the data that will be collected on the Liquid Phase Methanol Demonstration Unit is given in 6.3.

### 6.2 Existing Subsystem Data

#### 6.2.1 Catalyst Guard Bed

The existing catalyst guard bed (shown in Figure 7-1) at Eastman's gasification facility is designed to remove all sulfur containing compounds from the feed synthesis gas. It has been in service since 1991. The guard bed catalyst has been replaced only one time, in 1995. It is not expected to be replaced again until 1999. Figure 6-2 shows a configuration of the guard bed with relevant dimensions. The synthesis gas streams before and after the guard bed are analyzed periodically for hydrogen sulfide. From this analysis, a sulfur removal efficiency can be determined (typically the efficiency is 45-50% removal).

#### 6.2.2 Methanol Distillation

Refined methanol from the LPMEOH™ demonstration unit would be combined with refined methanol product from the Distillation unit in Eastman's existing Plant 19 (Lurgi Methanol Plant). In addition, a crude methanol stream from the LPMEOH™ demonstration unit would be fed to the Distillation unit in Plant 19 for further refining. All of the refined methanol will be used in Eastman's existing methyl acetate production facility. Table 6-1 lists the specification that Eastman uses as the basis for their internal acceptance criteria.

#### 6.2.3 Coal Gasification

In order to corroborate coal gasification data from other Clean Coal Technology projects, Eastman will provide publicly available data from the existing gasification complex. Figure 6-1 shows a schematic of the Eastman Coal Gasification and Gas Cleanup facility with the major streams entering the facility and the major effluent streams. Table 6-2 lists the streams and the parameters that will be monitored and reported from publicly available data.

### 6.3 Liquid Phase Methanol Data

#### 6.3.1 1994 Catalyst Poisons Study

A comprehensive study of all three of the future feed streams to the Kingsport LPMEOH™ facility was conducted by APCI's and Eastman's analytical teams. The study was completed over a one year period and analyzed the following streams and solids for trace compounds which might poison the LPMEOH™ catalyst:

- spent catalyst from Eastman's existing Lurgi unit
- spent guard bed adsorbents from the Lurgi unit
- gas cylinders of the three feed streams collected at two different points in time and analyzed by APCI's analytical team in Allentown
- on-line sampling conducted by both Eastman and APCI analytical experts at Kingsport

The study included the elements and inorganic compounds that are recognized as Hazardous Air Pollutants (HAPS). A summary of our findings, as well as individual reports on different analytical tests are included in the appendix.

#### 6.3.2 1996 LPMEOH™ Reactor Study

An additional study is planned to assure that the Kingsport feed gases do not contain any, as of yet, unquantified trace compounds that could poison the catalyst. This study will be conducted in mid-1996 and will involve running a portable lab-scale slurry autoclave using two of the feed gases at the Eastman site. The portable unit will be equipped with different size guard beds to allow testing of various adsorbents, should a catalyst poison be found. It will also be equipped with appropriate gas chromatograph equipment to allow quantification of known catalyst poisons, as well as the bulk gas analysis. The tests are expected to last approximately 4 weeks. The schedule for construction and startup of the portable laboratory, the details of the analytical equipment being installed, as well as, a P&ID for the test unit are attached in the appendix.

#### 6.3.3 Air Monitoring


No supplemental air monitoring is expected.

#### 6.3.4 Noise

The plant is designed to meet OSHA noise regulations. The K-01 feed gas compressor is expected to be near the 85 dBA limit during operation. This unit will be tested during startup.



BLOCK FLOW DIAGRAM



**FIGURE 6-1**

# 10C-30 CATALYST GUARD BED

## SUPPORT/CATALYST LOADING




FIGURE 6-2

# TABLE 6-1

## Refined Methanol Internal Acceptance Criteria

| <u>Component</u> | Upper<br>Internal<br>Manufacturing<br>Limit (wt. %) |
|------------------|---|
| Acetic Acid      | 0.0030 %  |
| Water            | 0.0300 %  |
| Decane           | 12 ppm  |
| Methyl Alcohol   | 99.9 % (lower limit)                                |
| Acetone          | 125 ppm   |
| Ethyl Alcohol    | 500 ppm   |

TABLE 6-1

**List of Streams Entering and Leaving Eastman's Coal Gasification Facility**

| Stream | Description                                 | Parameters* |
|--------|---|-------------|
| ① Coal | Fresh coal to gasifier                      | F,C,H       |
| ② O2   | Oxygen fed to gasifier                      | F           |
| ③ H2O  | Water fed to gasifier                       | F           |
| ④ WW   | Waste water from Gasifier                   | F,C         |
| ⑤ SG   | Clean Syngas from gasification facility     | F,C,T,P     |
| ⑥ S    | Sulfur recovered from gasification facility | F,A         |
| ⑦ CO2  | Carbon dioxide produced from gasifier       | F,A         |
| ⑧ Slag | Slag generated from gasifier                | F           |

- \*  
 A = Assay or Purity  
 C = Composition  
 F = Flow  
 H = Heat Value  
 P = Pressure  
 T = Temperature

**TABLE 6-2**

### 6.3.5 Liquid Waste Monitoring

#### 6.3.5.1 Non-Process Flows

The oil water separator will be inspected monthly. The volume of materials (oil and solids) that are removed will be recorded. The amount of any waste oils that are generated by the facility will be recorded. (Function of the oil water separator and waste disposal are described in 4.3.1.2.)

### 6.3.6 Solid Waste

#### 6.3.6.1 Spent Catalyst Slurry

Each batch of spent catalyst will be analyzed for percent solids.

The total weight of the material will also be reported. This will be compared to the Environmental Assessment (EA) data. (Disposal of this non-hazardous material is described in 4.4.1.)

#### 6.3.6.2 Spent Guard Bed (29C-40) Adsorbent

This material will either go to the Eastman incinerator or will be returned to the supplier. The weight and volume will be recorded. (Disposal of this material is described in 4.4.2.)

### 6.3.7 Confirmation of EMP from Task 5 Topical Reports

The Phase 3, Task 5 - Data Collection and Monitoring task in the Statement of Work will provide confirmation of the environmental acceptability of the LPMEOH™ technology for replication in future projects. Air Products will prepare Topical Reports as further outlined in the Demonstration Test Plan and Technical Progress Reports containing the analysis of the operation of the LPMEOH™ Process Demonstration Unit. These Reports will include compositions, temperatures, pressures and flowrates of materials and energy entering and leaving the LPMEOH™ Process Demonstration Facility. This will include any potential HAPS (Hazardous Air Pollutants) determined to be of significance.

If the Task 5 analysis of the operation of the LPMEOH™ Process Demonstration Unit show any discrepancies which might impact the environmental acceptability of the LPMEOH™ technology, then this Environmental Monitoring Plan will be appropriately modified to address the discrepancy.

## Section 7 - Data Management and Reporting

### 7.0 General - Background and Overview

The LPMEOH™ process will be commercialized in conjunction with integrated gasification combined cycle (IGCC) electric power generation facilities. The LPMEOH™ process is aimed at directly converting synthesis gas, as produced by modern coal gasifiers, to produce liquid fuels and chemical feedstocks as a coproduct with electricity. The demonstration at Kingsport has some of the features of this commercial application, such as the coal gasification and gas cleanup facility, which operates steadily at full load, both at Kingsport and for commercial applications. However, other needs of the demonstration are not available at Kingsport, such as : a) synthesis gas compositions rich in carbon monoxide "as-produced" directly from the coal gasifier, and b) a combined cycle power plant with electricity demand load-following. Other CCT Projects (e.g. - Tampa, Wabash River) are demonstrating IGCC, so commercial and environmental data will be available from these CCT Programs, to fill in the gaps that cannot be done directly in the demonstration at Kingsport. The LPMEOH™ process demonstration at Kingsport must therefore depend in part, on a carefully developed test plan, with specific tests which simulate operation of future IGCC/LPMEOH™ commercial plant designs in which methanol is coproduced with power in a combined cycle coal gasification plant.

The carefully developed operation test plan is to be carried out during the four-year methanol operation phase (Task 2.1 of Phase 3). Task 2.1 is broken into three sequential tasks, in each of which appropriate test runs will be conducted to simulate and demonstrate the commercial IGCC design integration. The actual test runs will depend on the results of previous operations. A "run authorization" document containing the run goals, feed gas availability, safety concerns, details of the operating conditions, non-typical samples to be taken and expected results for each specific case, will be issued and will be available for DOE review prior to the start of the run. Results of each run will be reported in the Quarterly Technical Progress Reports, including compositions, temperatures, pressures and flow rates of materials and energy entering and leaving the LPMEOH™ process demonstration facility, in addition to recycle streams, run lengths, and other data indicative of process reliability and operability.

#### **EMP Data Management and Reporting.**

The EMP data management and reporting will take into account:

- the differences between the Kingsport demonstration and future IGCC/LPMEOH™ commercial plant designs; and
- the environmental data which other CCT IGCC projects will provide; and
- the timing of the different operational test stages and specific tests to be done at Kingsport during Task 2.1 Methanol Operation.

Two EMP objectives must also be satisfied:

- the need to have environmental data which characterizes the special attributes of the LPMEOH™ process technology; e.g. - to support engineering data requirements on environmental impacts of future projects, (In general, this data will be gathered and included in the Quarterly Technical Progress Reports for the specific commercial Task 2.1 tests).
- the need to identify and confirm environmental impacts and the performance predicted in the NEPA documentation for this project. (In general, this data will be gathered and included in the EMR quarterly and annual reports, under the Compliance Monitoring (5.0), and the Supplemental Monitoring (6.0) Sections, and summarized later in this Section 7.).

Overall data management and reporting, to meet these two EMP objectives, is discussed in Sections 7.1 through 7.5 of this EMP. Figure 7-1 shows how Eastman's Coal Gasification and Lurgi Methanol Units integrate with the LPMEOH™ demonstration unit. Figure 7-2 shows the main flows to and from the LPMEOH™ demonstration unit and details which flows are continuous and which are intermittent. Figure 7-3 shows the miscellaneous streams that leave the LPMEOH™ demonstration unit. A description of each of these streams is provided in Table 7-1, which also describes details of the data to be reported, the frequency of data collection and of the sampling and analytic methods.

#### 7.1 Eastman Reporting of "Publicly Available Technical Data".


Refer to Figure 7-1 and Table 7-1. Eastman reporting of "Publicly Available Technical Data.", relating to the three LPMEOH™ process related areas (described in the Statement of Work), will be done as follows:

**(a) The gasifier facility at Kingsport.** Material balance point #'s; 1, 2, 3, 4, 5, 6, 7, and 8 will be provided in the first year of operation of the LPMEOH™ demonstration unit. If a significant change in gasifier facility operation (e.g., feed stock change, equipment modifications or additions, etc.) occurs, then an update will be provided.

**(b) Catalyst Guard Bed on Balanced Gas.** Material balance point #'s 5 and 9, including quantities of trace impurities entering and leaving the Catalyst Guard Bed, will be provided in the first year of operation of the LPMEOH™ demonstration unit. If a significant change occurs (e.g. new or additional catalyst, process change, upsets, etc.), then an update on these material balance points will be provided.

Information that has a significant impact on the cost of the guard bed unit, including frequency of replacement of guard bed materials, overall sizes or dimensions of equipment, information on run lengths indicative of process reliability or operability and information relating to operating costs anticipated for a commercial facility, will

# INTEGRATION OF EXISTING FACILITIES WITH LPMEOH™ FACILITY



**FIGURE 7-1**



# "LPMEOH™ FACILITY"

## SIMPLIFIED ENVIRONMENTAL MONITORING DIAGRAM





FIGURE 7-2

# MISCELLANEOUS STREAMS LEAVING THE LPMEOH™ FACILITY



**FIGURE 7-3**

be provided in the first year of operation of the LPMEOH™ demonstration unit. An update will be provided if a significant change (as defined above) occurs.

**(c) Crude Grade Methanol Distillation.** A typical analysis of the crude grade methanol (Material Balance Point # 242) for the first year of operation of the LPMEOH™ demonstration unit will be used for engineering calculations, which will be made to determine the ultimate disposition of the Contained Components. The impact on Material Balance Point # 28 will be calculated and reported, as part of this engineering calculation. During subsequent Process Operational Tests, the composition of the crude methanol is expected to change, and additional engineering calculations of the impact, covering the range of typical compositions, will be done.

The above three areas will be included in separate, Special Topical Reports to be issued in Year 1, and will be summarized in the Year 1 Annual EMR report. Table 7-1 summarizes the streams, and the tests and reporting that will be provided. Updates, if any, will be included in subsequent Quarterly EMRs.

## 7.2 Reporting of Information in Technical Progress Reports

Refer to Figure 7-2 and Table 7-1. Material balance point #'s 10, 20, 30 (synthesis gas in), 216, 242, (methanol product out), and 148 (unreacted synthesis gas out; e.g. - the fuel gas which would go to the combined cycle power plant in the commercial embodiment) are the essential key flow streams for commercial operations. These balance point #'s and the internal *streams* Recycle Gas (149), Reactor Feed Gas (109), Reactor Section Effluent Gas (120) and Methanol to Distillation (204) will be summarized in the Quarterly Technical Progress Reports for the various operational test runs during the four-year methanol operation phase (Task 2.1 of Phase 3).

Material balance point 19 is specific to product purity requirements, but at least one of the three streams that comprise stream 19 will be present on all future commercial projects. All such streams would go to a tail gas fuel header similar to what is being demonstrated at Kingsport. Tail gas fuel header design data for point 19 will be reported in the Quarterly Technical Progress Reports.

Reporting of information on these material balance points will also be included in separate Topical Reports prepared throughout the demonstration period. Table 7-1 summarizes these streams, and the tests and reporting that will be provided.

## 7.3 Reporting of EMP Compliance Monitoring Information

Refer to Figures 7-2, 7-3 and Table 7-1. Material balance point #'s 27 and 34 will be reported in the Quarterly Environmental Monitoring Report (EMR), as part of the Compliance Monitoring Information described in Section 5 of this EMP.

If there are changes to the Clean Air laws that would require additional reporting, then these data will be included in the Quarterly EMRs. Table 7-1 summarizes these

compliance monitoring points, and the tests and reporting that will be provided in the EMRs.

#### 7.4 Reporting of EMP Supplemental Monitoring Information

Refer to Figures 7-2, 7-3 and Table 7-1. The remaining material balance point #'s shown in these Figures are as follows: balance point #'s 29, 21, 22, 23, 24, 25 and 26 in Figure 7-2; and balance points #'s 37, 31, 32, 33, and 36 in Figure 7-3. These balance point #'s will be reported in the Quarterly EMR, as part of the Supplemental Monitoring Information described in Section 6 of this EMP. Data for points not monitored will be calculated or estimated. Summary of points defined in Stream 35 contain normally N<sub>2</sub> or steam under normal process conditions; the EMR will report any deviations. Table 7-1 summarizes these streams, and the tests and reporting that will be provided in the EMR.

A table which summarizes the total synthesis gas use and Methanol Production for the reporting period will also be provided in the Quarterly EMRs. The table will list the following:

- Total synthesis gas consumption (units of thousands of standard cubic feet) for Stream #10, #20, and #30.
- Total methanol production (units of tons) for Stream #216 and #242
- Total plant purge (units of thousands of standard cubic feet) for Stream #148.

#### 7.5 Environmental Monitoring Reports (EMR's)

Environmental monitoring shall be conducted under the EMP and shall be reported in quarterly and annual Environmental Monitoring Reports (EMRs). The EMR's will be prepared on a quarterly basis, for the anticipated four-year operating period. The reports will contain the following:

- a description of project status including a summary of Methanol Production and synthesis gas use.
- details of the sampling and analytical procedures.
- summaries of the environmental and health monitoring data collected, including Compliance and Supplemental Monitoring information per Section 7.3 and 7.4 above.
- the project's permit compliance status.
- copies of compliance reports and analyses sent by Participants to regulatory agencies.
- identification of problem areas encountered, with an action plan and status report of resolution.
- recommendations of modification or deletion of supplemental monitoring tasks not yielding useful data.
- appendices with sampling and analytical data sheets.

The Annual EMR shall contain the fourth quarterly report, and will summarize and analyze information from prior reports.

7.6 Reporting Requirements Check List

A Reporting Requirements Check List is provided (Table 7-2) for the reports that are described in the EMP and the DTP.

TABLE 7-1

| Stream No.   | 1                      | 2                       |
|--|------------------------|-------------------------|
| Description  | Fresh Coal to Gasifier | Oxygen Feed to Gasifier |
| PFD Material Balance Point No.                           | N/A                    | N/A                     |
| Gas Chromatograph Point No.                              | N/A                    | N/A                     |
| Reported in:   |                        |                         |
| EMRs (Compliance)  |                        |                         |
| EMRs (Supplemental)                                      |                        |                         |
| Technical Progress Reports                               |                        |                         |
| Topical Report   | X                      | X                       |
| Temperature  | X                      | X                       |
| Pressure   | X                      | X                       |
| Flow Rate  |                        |                         |
| Composition  |                        |                         |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |                        |                         |
| Hydrogen   |                        |                         |
| Carbon Monoxide  |                        |                         |
| Nitrogen   |                        |                         |
| Carbon Dioxide   |                        |                         |
| Methanol   |                        |                         |
| Dimethyl Ether   |                        |                         |
| Methane  |                        |                         |
| Oxygen (Argon)   |                        |                         |
| "Other" (by difference)                                  |                        |                         |
| <b>Coal Analysis (Wt %)</b>                              | X                      |                         |
| Hydrogen   |                        |                         |
| Argon  |                        |                         |
| Sulfur   |                        |                         |
| Oxygen   |                        |                         |
| Nitrogen   |                        |                         |
| Moisture   |                        |                         |
| Fixed Carbon   |                        |                         |
| Ash  |                        |                         |
| Chlorine   |                        |                         |
| Heating Value (BTU/#)                                    |                        |                         |
| <b>Methanol Analysis (Wt %)</b>                          |                        |                         |
| Acetic Acid  |                        |                         |
| Water  |                        |                         |
| Decane   |                        |                         |
| Methanol   |                        |                         |
| Acetone  |                        |                         |
| Ethanol  |                        |                         |
| % O <sub>2</sub>   |                        | X                       |
| Analysis Frequency                                       | N/A                    | N/A                     |
| Sampling Technique                                       | Grab                   | Piped to Analyzer       |
| Analytical Method  | Infrared, ICP          | Paramagnetic            |

| Stream No.   | 3                         | 4                          |
|--|---------------------------|----------------------------|
| Description  | Water Feed to Gasifier    | Waste Water from Gasifier  |
| PFD Material Balance Point No.                       | N/A                       | N/A                        |
| Gas Chromatograph Point No.                          | N/A                       | N/A                        |
| Reported in:   |                           |                            |
| EMRs (Compliance)                                    |                           |                            |
| EMRs (Supplemental)                                  |                           |                            |
| Technical Progress Reports                           |                           |                            |
| Test Series Report (one time)                        | X                         | X                          |
| Temperature  | X                         | X                          |
| Pressure   | X                         | X                          |
| Flow Rate  |                           |                            |
| Composition  | Treated Water No Analysis |                            |
| <b>GC Analysis of Gases in LPMEOH™ Plant (Vol %)</b> |                           |                            |
| Hydrogen   |                           |                            |
| Carbon Monoxide                                      |                           |                            |
| Nitrogen   |                           |                            |
| Carbon Dioxide                                       |                           |                            |
| Methanol   |                           |                            |
| Dimethyl Ether                                       |                           |                            |
| Methane  |                           |                            |
| Oxygen (Argon)                                       |                           |                            |
| "Other" (by difference)                              |                           |                            |
| <b>Coal Analysis (Wt %)</b>                          |                           |                            |
| Hydrogen   |                           |                            |
| Argon  |                           |                            |
| Sulfur   |                           |                            |
| Oxygen   |                           |                            |
| Nitrogen   |                           |                            |
| Moisture   |                           |                            |
| Fixed Carbon   |                           |                            |
| Ash  |                           |                            |
| Chlorine   |                           |                            |
| Heating Value (BTU/#)                                |                           |                            |
| <b>Methanol Analysis (Wt %)</b>                      |                           |                            |
| Acetic Acid  |                           |                            |
| Water  |                           |                            |
| Decane   |                           |                            |
| Methanol   |                           |                            |
| Acetone  |                           |                            |
| Ethanol  |                           |                            |
| PPM Total Organic Carbon                             |                           | X                          |
| Analysis Frequency                                   | N/A                       | N/A                        |
| Sampling Technique                                   | N/A                       | Grab                       |
| Analytical Method                                    | N/A                       | IC, IR, ICP, Potentiometer |

| Stream No.<br>Description                                | 5<br>Clean Synthesis Gas from<br>Gasification | 6<br>Sulfur Recovered from<br>Gasification |
|--|---|--|
| PFD Material Balance Point No.                           | N/A   | N/A  |
| Gas Chromatograph Point No.                              | N/A   | N/A  |
| Reported in:   |   |  |
| EMRs (Compliance)  |   |  |
| EMRs (Supplemental)                                      |   |  |
| Technical Progress Reports                               |   |  |
| Test Series Report (one time)                            | X   | X  |
| Temperature  | X   | X  |
| Pressure   | X   | X  |
| Flow Rate  | X   | X  |
| Composition  |   |  |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |   |  |
| Hydrogen   |   |  |
| Carbon Monoxide  |   |  |
| Nitrogen   |   |  |
| Carbon Dioxide   |   |  |
| Methanol   |   |  |
| Dimethyl Ether   |   |  |
| Methane  |   |  |
| Oxygen (Argon)   |   |  |
| "Other" (by difference)                                  |   |  |
| <b>Raw Synthesis Analysis (Vol %)</b>                    | X   |  |
| Hydrogen   |   |  |
| Carbon Monoxide  |   |  |
| Carbon Dioxide   |   |  |
| Hydrogen Sulfide   |   |  |
| Oxygen (Argon)   |   |  |
| Nitrogen   |   |  |
| Nitrogen Oxide (NOx)                                     |   |  |
| <b>Methanol Analysis (Wt %)</b>                          |   |  |
| Acetic Acid  |   |  |
| Water  |   |  |
| Decane   |   |  |
| Methanol   |   |  |
| Acetone  |   |  |
| Ethanol  |   |  |
| % Sulfur   |   | X  |
| Analysis Frequency                                       | N/A   | N/A  |
| Sampling Technique                                       | Grab  | Grab                                       |
| Analytical Method  | GC  |  |



| Stream No.   | 7  | 8                            |
|--|--|------------------------------|
| Description  | Carbon Dioxide Produced<br>from Gasifier | Slag Generated from Gasifier |
| PFD Material Balance Point No.                           | N/A                                      | N/A                          |
| Gas Chromatograph Point No.                              | N/A                                      | N/A                          |
| Reported in:   |  |                              |
| EMRs (Compliance)  |  |                              |
| EMRs (Supplemental)                                      |  |                              |
| Technical Progress Reports                               |  |                              |
| Test Series Report (one time)                            | X  | X                            |
| Temperature  | X  | X                            |
| Pressure   | X  | X                            |
| Flow Rate  | X  | X                            |
| Composition  |  | Not Analyzed                 |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |  |                              |
| Hydrogen   |  |                              |
| Carbon Monoxide  |  |                              |
| Nitrogen   |  |                              |
| Carbon Dioxide   |  |                              |
| Methanol   |  |                              |
| Dimethyl Ether   |  |                              |
| Methane  |  |                              |
| Oxygen (Argon)   |  |                              |
| "Other" (by difference)                                  |  |                              |
| <b>Coal Analysis (Wt %)</b>                              |  |                              |
| Hydrogen   |  |                              |
| Argon  |  |                              |
| Sulfur   |  |                              |
| Oxygen   |  |                              |
| Nitrogen   |  |                              |
| Moisture   |  |                              |
| Fixed Carbon   |  |                              |
| Ash  |  |                              |
| Chlorine   |  |                              |
| Heating Value (BTU/#)                                    |  |                              |
| <b>Methanol Analysis (Wt %)</b>                          |  |                              |
| Acetic Acid  |  |                              |
| Water  |  |                              |
| Decane   |  |                              |
| Methanol   |  |                              |
| Acetone  |  |                              |
| Ethanol  |  |                              |
| % CO <sub>2</sub>  | X  |                              |
| Analysis Frequency                                       | N/A                                      |                              |
| Sampling Technique                                       | Grab                                     |                              |
| Analytical Method  | GC                                       |                              |

| Stream No.<br>Description                                | 9<br>Balanced (Synthesis) Gas<br>from Existing Guard Bed | 10<br>CO Gas to LPMEOH Facility |
|--|--|---------------------------------|
| PFD Material Balance Point No.                           | N/A  | 10                              |
| Gas Chromatograph Point No.                              | N/A  | 2                               |
| Reported in:   |  |                                 |
| EMRs (Compliance)  |  |                                 |
| EMRs (Supplemental)                                      |  | X (Summary Data)                |
| Technical Progress Reports                               |  | X                               |
| Test Series Report (one time)                            | X  |                                 |
| Temperature  | X  | X                               |
| Pressure   | X  | X                               |
| Flow Rate  | X  | X                               |
| Composition  |  |                                 |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |  | X                               |
| Hydrogen   |  |                                 |
| Carbon Monoxide  |  |                                 |
| Nitrogen   |  |                                 |
| Carbon Dioxide   |  |                                 |
| Methanol   |  |                                 |
| Dimethyl Ether   |  |                                 |
| Methane  |  |                                 |
| Oxygen (Argon)   |  |                                 |
| "Other" (by difference)                                  |  |                                 |
| <b>Raw Syngas (Vol %)</b>                                | X  |                                 |
| Hydrogen   |  |                                 |
| Carbon Monoxide  |  |                                 |
| Carbon Dioxide   |  |                                 |
| Hydrogen Sulfide   |  |                                 |
| Oxygen (Argon)   |  |                                 |
| Nitrogen   |  |                                 |
| Nitrogen Oxides (NOx)                                    |  |                                 |
| <b>Methanol Analysis (Wt %)</b>                          |  |                                 |
| Acetic Acid  |  |                                 |
| Water  |  |                                 |
| Decane   |  |                                 |
| Methanol   |  |                                 |
| Acetone  |  |                                 |
| Ethanol  |  |                                 |
| Analysis Frequency                                       | N/A  | Continuous                      |
| Sampling Technique                                       | Grab   | Piped to GC                     |
| Analytical Method  | GC   | GC                              |

| Stream No.  | 19                    | 20                        |
|---|-----------------------|---------------------------|
| Description   | Distillation Fuel Gas | H2 Gas to LPMEOH Facility |
| PFD Material Balance Point No.  | --                    | 20                        |
| Gas Chromatograph Point No.   | 8                     | 3                         |
| Reported in:  |                       |                           |
| EMRs (Compliance)   |                       |                           |
| EMRs (Supplemental)   |                       | X (Summary Data)          |
| Technical Progress Reports  | X                     | X                         |
| Test Series Report (one time)   |                       |                           |
| Temperature   | X                     | X                         |
| Pressure  | X                     | X                         |
| Flow Rate   | X                     | X                         |
| Composition   |                       |                           |
| GC Analysis of Gases in LPMEOH™ Plant (Vol %)   | X                     | X                         |
| <div style="border: 1px solid black; padding: 5px;">           Hydrogen<br/>           Carbon Monoxide<br/>           Nitrogen<br/>           Carbon Dioxide<br/>           Methanol<br/>           Dimethyl Ether<br/>           Methane<br/>           Oxygen (Argon)<br/>           "Other" (by difference)         </div> |                       |                           |
| <b>Coal Analysis (Wt %)</b>   |                       |                           |
| <div style="border: 1px solid black; padding: 5px;">           Hydrogen<br/>           Argon<br/>           Sulfur<br/>           Oxygen<br/>           Nitrogen<br/>           Moisture<br/>           Fixed Carbon<br/>           Ash<br/>           Chlorine<br/>           Heating Value (BTU/#)         </div>           |                       |                           |
| <b>Methanol Analysis (Wt %)</b>   |                       |                           |
| <div style="border: 1px solid black; padding: 5px;">           Acetic Acid<br/>           Water<br/>           Decane<br/>           Methanol<br/>           Acetone<br/>           Ethanol         </div>  |                       |                           |
| Analysis Frequency  | Continuous            | Continuous                |
| Sampling Technique  | Piped to GC           | Piped to GC               |
| Analytical Method   | GC                    | GC                        |

| Stream No.   | 21   | 22  |
|--|--|---|
| Description  | Methanol Storage Tank (D-20 and D-21) Vent (Intermittent Flow) | Methanol Drain Tank (D-25) Vent (Intermittent Flow) |
| PFD Material Balance Point No.                       | -  | -   |
| Gas Chromatograph Point No.                          | -  | -   |
| Reported in:   | Not Monitored (see section 5.1.1.2 of this report)             | Not Monitored (see section 5.1.1.2 of this report)  |
| EMRs (Compliance)                                    |  |   |
| EMRs (Supplemental)                                  |  |   |
| Technical Progress Reports                           |  |   |
| Test Series Report (one time)                        |  |   |
| Temperature  |  |   |
| Pressure   |  |   |
| Flow Rate  |  |   |
| Composition  |  |   |
| <b>GC Analysis of Gases in LPMEOH™ Plant (Vol %)</b> |  |   |
| Hydrogen   |  |   |
| Carbon Monoxide                                      |  |   |
| Nitrogen   |  |   |
| Carbon Dioxide                                       |  |   |
| Methanol   |  |   |
| Dimethyl Ether                                       |  |   |
| Methane  |  |   |
| Oxygen (Argon)                                       |  |   |
| "Other" (by difference)                              |  |   |
| <b>Coal Analysis (Wt %)</b>                          |  |   |
| Hydrogen   |  |   |
| Argon  |  |   |
| Sulfur   |  |   |
| Oxygen   |  |   |
| Nitrogen   |  |   |
| Moisture   |  |   |
| Fixed Carbon   |  |   |
| Ash  |  |   |
| Chlorine   |  |   |
| Heating Value (BTU/#)                                |  |   |
| <b>Methanol Analysis (Wt %)</b>                      |  |   |
| Acetic Acid  |  |   |
| Water  |  |   |
| Decane   |  |   |
| Methanol   |  |   |
| Acetone  |  |   |
| Ethanol  |  |   |
| Analysis Frequency                                   |  |   |
| Sampling Technique                                   |  |   |
| Analytical Method                                    |  |   |

| Stream No.   | 23   | 24                                    |
|--|--|---------------------------------------|
| Description  | Bypass (intermittent flow)                             | Compressor (process side)<br>seal gas |
| PFD Material Balance Point No.                           | -  | -                                     |
| Gas Chromatograph Point No.                              | -  | -                                     |
| Reported in:   | Not monitored; bypass is<br>mainly used during startup | Not monitored                         |
| EMRs (Compliance)  |  |                                       |
| EMRs (Supplemental)                                      |  |                                       |
| Technical Progress Reports                               |  |                                       |
| Test Series Report (one time)                            |  |                                       |
| Temperature  |  |                                       |
| Pressure   |  |                                       |
| Flow Rate  |  |                                       |
| Composition  |  |                                       |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |  |                                       |
| Hydrogen   |  |                                       |
| Carbon Monoxide  |  |                                       |
| Nitrogen   |  |                                       |
| Carbon Dioxide   |  |                                       |
| Methanol   |  |                                       |
| Dimethyl Ether   |  |                                       |
| Methane  |  |                                       |
| Oxygen (Argon)   |  |                                       |
| "Other" (by difference)                                  |  |                                       |
| <b>Coal Analysis (Wt %)</b>                              |  |                                       |
| Hydrogen   |  |                                       |
| Argon  |  |                                       |
| Sulfur   |  |                                       |
| Oxygen   |  |                                       |
| Nitrogen   |  |                                       |
| Moisture   |  |                                       |
| Fixed Carbon   |  |                                       |
| Ash  |  |                                       |
| Chlorine   |  |                                       |
| Heating Value (BTU/#)                                    |  |                                       |
| <b>Methanol Analysis (Wt %)</b>                          |  |                                       |
| Acetic Acid  |  |                                       |
| Water  |  |                                       |
| Decane   |  |                                       |
| Methanol   |  |                                       |
| Acetone  |  |                                       |
| Ethanol  |  |                                       |
| Analysis Frequency                                       |  |                                       |
| Sampling Technique                                       |  |                                       |
| Analytical Method  |  |                                       |

| Stream No.<br>Description                                | 25<br>Guard Bed Regeneration<br>(intermittent flow) | 26<br>Analytical Sample Vents |
|--|---|-------------------------------|
| PFD Material Balance Point No.                           | -   | -                             |
| Gas Chromatograph Point No.                              | -   | -                             |
| Reported in:   | Not monitored                                       | Not monitored                 |
| EMRs (Compliance)  |   |                               |
| EMRs (Supplemental)                                      |   |                               |
| Technical Progress Reports                               |   |                               |
| Test Series Report (one time)                            |   |                               |
| Temperature  |   |                               |
| Pressure   |   |                               |
| Flow Rate  |   |                               |
| Composition  |   |                               |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |   |                               |
| Hydrogen   |   |                               |
| Carbon Monoxide  |   |                               |
| Nitrogen   |   |                               |
| Carbon Dioxide   |   |                               |
| Methanol   |   |                               |
| Dimethyl Ether   |   |                               |
| Methane  |   |                               |
| Oxygen (Argon)   |   |                               |
| "Other" (by difference)                                  |   |                               |
| <b>Coal Analysis (Wt %)</b>                              |   |                               |
| Hydrogen   |   |                               |
| Argon  |   |                               |
| Sulfur   |   |                               |
| Oxygen   |   |                               |
| Nitrogen   |   |                               |
| Moisture   |   |                               |
| Fixed Carbon   |   |                               |
| Ash  |   |                               |
| Chlorine   |   |                               |
| Heating Value (BTU/#)                                    |   |                               |
| <b>Methanol Analysis (Wt %)</b>                          |   |                               |
| Acetic Acid  |   |                               |
| Water  |   |                               |
| Decane   |   |                               |
| Methanol   |   |                               |
| Acetone  |   |                               |
| Ethanol  |   |                               |
| Analysis Frequency                                       |   |                               |
| Sampling Technique                                       |   |                               |
| Analytical Method  |   |                               |

| Stream No.<br>Description                                | 27<br>Total flow to boilers           | 28<br>Wastewater and alcohols to<br>WWTS   |
|--|---------------------------------------|--|
| PFD Material Balance Point No.                           | -                                     |  |
| Gas Chromatograph Point No.                              | -                                     |  |
| Reported in:   |                                       |  |
| EMRs (Compliance)  | X                                     |  |
| EMRs (Supplemental)                                      |                                       | X  |
| Technical Progress Reports                               |                                       |  |
| Test Series Report (one time)                            |                                       |  |
| Temperature  |                                       | Eastman will supply data<br>comparing flow, composition<br>and BOD loads before and<br>after the addition of<br>LPMEOH. Information will |
| Pressure   |                                       |  |
| Flow Rate  |                                       |  |
| Composition  |                                       |  |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> | X                                     |  |
| Hydrogen   |                                       | be reported annually during<br>the demonstration.  |
| Carbon Monoxide  |                                       |  |
| Nitrogen   |                                       |  |
| Carbon Dioxide   |                                       |  |
| Methanol   |                                       |  |
| Dimethyl Ether   |                                       |  |
| Methane  |                                       |  |
| Oxygen (Argon)   |                                       |  |
| "Other" (by difference)                                  |                                       |  |
| <b>Coal Analysis (Wt %)</b>                              |                                       |  |
| Hydrogen   |                                       |  |
| Argon  |                                       |  |
| Sulfur   |                                       |  |
| Oxygen   |                                       |  |
| Nitrogen   |                                       |  |
| Moisture   |                                       |  |
| Fixed Carbon   |                                       |  |
| Ash  |                                       |  |
| Chlorine   |                                       |  |
| Heating Value (BTU/#)                                    |                                       |  |
| <b>Methanol Analysis (Wt %)</b>                          |                                       | X  |
| Acetic Acid  |                                       |  |
| Water  |                                       |  |
| Decane   |                                       |  |
| Methanol   |                                       |  |
| Acetone  |                                       |  |
| Ethanol  |                                       |  |
| Analysis Frequency                                       | See Section 5.1.1.1 of this<br>report | Annual   |
| Sampling Technique                                       | Grab                                  | Grab   |
| Analytical Method  | GC                                    | GC/IR/TC   |

|  |                                      |
|--|--------------------------------------|
| Stream No.   | 29                                   |
| Description  | Reduction Gas (intermittent flow)    |
| PFD Material Balance Point No.                       |                                      |
| Gas Chromatograph Point No.                          |                                      |
| Reported in:   |                                      |
| EMRs (Compliance)                                    |                                      |
| EMRs (Supplemental)                                  |                                      |
| Technical Progress Reports                           | X                                    |
| Test Series Report (one time)                        |                                      |
| Temperature  | X                                    |
| Pressure   | X                                    |
| Flow Rate  | - (approximated from inlet gas flow) |
| Composition  |                                      |
| <b>GC Analysis of Gases in LPMEOH™ Plant (Vol %)</b> | X                                    |
| Hydrogen   |                                      |
| Carbon Monoxide                                      |                                      |
| Nitrogen   |                                      |
| Carbon Dioxide                                       |                                      |
| Methanol   |                                      |
| Dimethyl Ether                                       |                                      |
| Methane  |                                      |
| Oxygen (Argon)                                       |                                      |
| "Other" (by difference)                              |                                      |
| <b>Coal Analysis (Wt %)</b>                          |                                      |
| Hydrogen   |                                      |
| Argon  |                                      |
| Sulfur   |                                      |
| Oxygen   |                                      |
| Nitrogen   |                                      |
| Moisture   |                                      |
| Fixed Carbon   |                                      |
| Ash  |                                      |
| Chlorine   |                                      |
| Heating Value (BTU/#)                                |                                      |
| <b>Methanol Analysis (Wt %)</b>                      |                                      |
| Acetic Acid  |                                      |
| Water  |                                      |
| Decane   |                                      |
| Methanol   |                                      |
| Acetone  |                                      |
| Ethanol  |                                      |
| Analysis Frequency                                   | Continuous                           |
| Sampling Technique                                   | Piped to GC                          |
| Analytical Method                                    | GC                                   |



| Stream No.<br>Description                                | 30<br>Balanced Gas to LPMEOH<br>Facility | 31<br>Spent Catalyst   |
|--|--|--|
| PFD Material Balance Point No.                           | 30                                       | -  |
| Gas Chromatograph Point No.                              | 1  | -  |
| Reported in:   |  |  |
| EMRs (Compliance)  |  |  |
| EMRs (Supplemental)                                      | X (Summary Data)                         | X  |
| Technical Progress Reports                               | X  |  |
| Test Series Report (one time)                            |  |  |
| Temperature  | X  | X  |
| Pressure   | X  | X  |
| Flow Rate  | X  | X  |
| Composition  |  | Total weight of slurry and %<br>solids will be reported. See<br>section 6.3.6.1 of this report |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> | X  |  |
| Hydrogen   |  |  |
| Carbon Monoxide  |  |  |
| Nitrogen   |  |  |
| Carbon Dioxide   |  |  |
| Methanol   |  |  |
| Dimethyl Ether   |  |  |
| Methane  |  |  |
| Oxygen (Argon)   |  |  |
| "Other" (by difference)                                  |  |  |
| <b>Coal Analysis (Wt %)</b>                              |  |  |
| Hydrogen   |  |  |
| Argon  |  |  |
| Sulfur   |  |  |
| Oxygen   |  |  |
| Nitrogen   |  |  |
| Moisture   |  |  |
| Fixed Carbon   |  |  |
| Ash  |  |  |
| Chlorine   |  |  |
| Heating Value (BTU/#)                                    |  |  |
| <b>Methanol Analysis (Wt %)</b>                          |  |  |
| Acetic Acid  |  |  |
| Water  |  |  |
| Decane   |  |  |
| Methanol   |  |  |
| Acetone  |  |  |
| Ethanol  |  |  |
| Analysis Frequency                                       | Continuous                               | Approx. Biweekly   |
| Sampling Technique                                       | Piped to GC                              | Grab   |
| Analytical Method  | GC                                       | Filtration   |

| Stream No.                     | 32   | 33  |
|--------------------------------|--|---|
| Description                    | Guard Bed Adsorbent to Incinerator   | Compressor & Pump Lubricants to Energy Recovery                                 |
| PFD Material Balance Point No. | -  | -   |
| Gas Chromatograph Point No.    | -  | -   |
| Reported in:                   |  |   |
| EMRs (Compliance)              |  |   |
| EMRs (Supplemental)            | X  | X   |
| Technical Progress Reports     |  |   |
| Test Series Report (one time)  |  |   |
| Temperature                    | X  | X   |
| Pressure                       | X  | X   |
| Flow Rate                      | X  | X   |
| Composition                    | Weight of Adsorbent removal will be reported. See section 6.3.6.2 of this report | Weight/Volume of materials will be reported. See section 6.3.5.1 of this report |

**GC Analysis of Gases in****LPMEOH™ Plant (Vol %)**

|                         |
|-------------------------|
| Hydrogen                |
| Carbon Monoxide         |
| Nitrogen                |
| Carbon Dioxide          |
| Methanol                |
| Dimethyl Ether          |
| Methane                 |
| Oxygen (Argon)          |
| "Other" (by difference) |

**Coal Analysis (Wt %)**

|                       |
|-----------------------|
| Hydrogen              |
| Argon                 |
| Sulfur                |
| Oxygen                |
| Nitrogen              |
| Moisture              |
| Fixed Carbon          |
| Ash                   |
| Chlorine              |
| Heating Value (BTU/#) |

**Methanol Analysis (Wt %)**

|             |
|-------------|
| Acetic Acid |
| Water       |
| Decane      |
| Methanol    |
| Acetone     |
| Ethanol     |

|                    |               |             |
|--------------------|---------------|-------------|
| Analysis Frequency | At Bed Change | As Required |
| Sampling Technique | N/A           | N/A         |
| Analytical Method  | N/A           | N/A         |

| Stream No.<br>Description      | 34<br>Equipment leak (fugitive<br>emissions) | 35<br>Miscellaneous Vent to the<br>Atmosphere |
|--------------------------------|--|---|
| PFD Material Balance Point No. | -  | -   |
| Gas Chromatograph Point No.    | -  | -   |
| Reported in:                   |  | Not Monitored                                 |
| EMRs (Compliance)              | X  |   |
| EMRs (Supplemental)            |  |   |
| Technical Progress Reports     |  |   |
| Test Series Report (one time)  |  |   |
| Temperature                    | N/A  |   |
| Pressure                       | N/A  |   |
| Flow Rate                      | X  |   |
| Composition                    | See section 5.2.1.1 of this<br>report        |   |

**GC Analysis of Gases in  
LPMEOH™ Plant (Vol %)**

|                         |
|-------------------------|
| Hydrogen                |
| Carbon Monoxide         |
| Nitrogen                |
| Carbon Dioxide          |
| Methanol                |
| Dimethyl Ether          |
| Methane                 |
| Oxygen (Argon)          |
| "Other" (by difference) |

**Coal Analysis (Wt %)**

|                       |
|-----------------------|
| Hydrogen              |
| Argon                 |
| Sulfur                |
| Oxygen                |
| Nitrogen              |
| Moisture              |
| Fixed Carbon          |
| Ash                   |
| Chlorine              |
| Heating Value (BTU/#) |

**Methanol Analysis (Wt %)**

|             |
|-------------|
| Acetic Acid |
| Water       |
| Decane      |
| Methanol    |
| Acetone     |
| Ethanol     |

|                    |                     |
|--------------------|---------------------|
| ppm VOC            | X                   |
| Analysis Frequency | Quarterly           |
| Sampling Technique | EPA Method 21       |
| Analytical Method  | Ion Flame Detection |

|                                |                                     |  |
|--------------------------------|-------------------------------------|--|
| Stream No.                     | 36                                  | 37   |
| Description                    | Vents through 29C-120 vent scrubber | Waste Oil  |
| PFD Material Balance Point No. | -                                   | -  |
| Gas Chromatograph Point No.    | -                                   | -  |
| Reported in:                   | Not monitored                       |  |
| EMRs (Compliance)              |                                     |  |
| EMRs (Supplemental)            |                                     | X  |
| Technical Progress Reports     |                                     |  |
| Test Series Report (one time)  |                                     |  |
| Temperature                    |                                     | X  |
| Pressure                       |                                     | X  |
| Flow Rate                      |                                     | X  |
| Composition                    |                                     | Waste oil will be removed from the oil/water separator and volume will be reported. See section 6.3.5.1 of this report |

**GC Analysis of Gases in  
LPMEOH™ Plant (Vol %)**

|                         |
|-------------------------|
| Hydrogen                |
| Carbon Monoxide         |
| Nitrogen                |
| Carbon Dioxide          |
| Methanol                |
| Dimethyl Ether          |
| Methane                 |
| Oxygen (Argon)          |
| "Other" (by difference) |

**Coal Analysis (Wt %)**

|                       |
|-----------------------|
| Hydrogen              |
| Argon                 |
| Sulfur                |
| Oxygen                |
| Nitrogen              |
| Moisture              |
| Fixed Carbon          |
| Ash                   |
| Chlorine              |
| Heating Value (BTU/#) |

|                    |             |
|--------------------|-------------|
| Analysis Frequency | As required |
| Sampling Technique | N/A         |
| Analytical Method  | N/A         |

| Stream No.<br>Description                                | 109<br>Reactor Feed Gas | 120<br>Reactor Section Effluent Gas<br>(syngas/methanol) |
|--|-------------------------|--|
| PFD Material Balance Point No.                           | 109                     | 120  |
| Gas Chromatograph Point No.                              | 5                       | 6  |
| Reported in:   |                         |  |
| EMRs (Compliance)  |                         |  |
| EMRs (Supplemental)                                      |                         |  |
| Technical Progress Reports                               | X                       | X  |
| Test Series Report (one time)                            |                         |  |
| Temperature  | X                       | X  |
| Pressure   | X                       | X  |
| Flow Rate  | X                       | X  |
| Composition  |                         |  |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> | X                       | X  |
| Hydrogen   |                         |  |
| Carbon Monoxide  |                         |  |
| Nitrogen   |                         |  |
| Carbon Dioxide   |                         |  |
| Methanol   |                         |  |
| Dimethyl Ether   |                         |  |
| Methane  |                         |  |
| Oxygen (Argon)   |                         |  |
| "Other" (by difference)                                  |                         |  |
| <b>Coal Analysis (Wt %)</b>                              |                         |  |
| Hydrogen   |                         |  |
| Argon  |                         |  |
| Sulfur   |                         |  |
| Oxygen   |                         |  |
| Nitrogen   |                         |  |
| Moisture   |                         |  |
| Fixed Carbon   |                         |  |
| Ash  |                         |  |
| Chlorine   |                         |  |
| Heating Value (BTU/#)                                    |                         |  |
| <b>Methanol Analysis (Wt %)</b>                          |                         |  |
| Acetic Acid  |                         |  |
| Water  |                         |  |
| Decane   |                         |  |
| Methanol   |                         |  |
| Acetone  |                         |  |
| Ethanol  |                         |  |
| Analysis Frequency                                       | Continuous              | Continuous   |
| Sampling Technique                                       | Piped to GC             | Piped to GC  |
| Analytical Method  | GC                      | GC   |

|   |                    |             |
|---|--------------------|-------------|
| Stream No.  | 148                | 149         |
| Description   | Main (Plant) Purge | Recycle Gas |
| PFD Material Balance Point No.  | 148                | 149         |
| Gas Chromatograph Point No.   | 7                  | 7           |
| Reported in:  |                    |             |
| EMRs (Compliance)   |                    |             |
| EMRs (Supplemental)   | X (Summary Data)   |             |
| Technical Progress Reports  | X                  | X           |
| Test Series Report (one time)   |                    |             |
| Temperature   | X                  | X           |
| Pressure  | X                  | X           |
| Flow Rate   | X                  | X           |
| Composition   |                    |             |
| GC Analysis of Gases in<br>LPMEOH™ Plant (Vol %)  | X                  | X           |
| <div style="border: 1px solid black; padding: 5px;">           Hydrogen<br/>           Carbon Monoxide<br/>           Nitrogen<br/>           Carbon Dioxide<br/>           Methanol<br/>           Dimethyl Ether<br/>           Methane<br/>           Oxygen (Argon)<br/>           "Other" (by difference)         </div> |                    |             |
| <b>Coal Analysis (Wt %)</b>   |                    |             |
| <div style="border: 1px solid black; padding: 5px;">           Hydrogen<br/>           Argon<br/>           Sulfur<br/>           Oxygen<br/>           Nitrogen<br/>           Moisture<br/>           Fixed Carbon<br/>           Ash<br/>           Chlorine<br/>           Heating Value (BTU/#)         </div>           |                    |             |
| <b>Methanol Analysis (Wt %)</b>   |                    |             |
| <div style="border: 1px solid black; padding: 5px;">           Acetic Acid<br/>           Water<br/>           Decane<br/>           Methanol<br/>           Acetone<br/>           Ethanol         </div>  |                    |             |
| Analysis Frequency  | Continuous         | Continuous  |
| Sampling Technique  | Piped to GC        | Piped to GC |
| Analytical Method   | GC                 | GC          |

|  |                          |                          |
|--|--------------------------|--------------------------|
| Stream No.   | 204                      | 216                      |
| Description  | Methanol to Distillation | Refined (Grade) Methanol |
| PFD Material Balance Point No.                           | 204                      | 216                      |
| Gas Chromatograph Point No.                              | N/A                      | N/A                      |
| Reported in:   |                          |                          |
| EMRs (Compliance)  |                          |                          |
| EMRs (Supplemental)                                      |                          | X (Summary Data)         |
| Technical Progress Reports                               | X                        | X                        |
| Test Series Report (one time)                            |                          |                          |
| Temperature  | X                        | X                        |
| Pressure   | X                        | X                        |
| Flow Rate  | X                        | X                        |
| Composition  |                          |                          |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |                          |                          |
| Hydrogen   |                          |                          |
| Carbon Monoxide  |                          |                          |
| Nitrogen   |                          |                          |
| Carbon Dioxide   |                          |                          |
| Methanol   |                          |                          |
| Dimethyl Ether   |                          |                          |
| Methane  |                          |                          |
| Oxygen (Argon)   |                          |                          |
| "Other" (by difference)                                  |                          |                          |
| <b>Coal Analysis (Wt %)</b>                              |                          |                          |
| Hydrogen   |                          |                          |
| Argon  |                          |                          |
| Sulfur   |                          |                          |
| Oxygen   |                          |                          |
| Nitrogen   |                          |                          |
| Moisture   |                          |                          |
| Fixed Carbon   |                          |                          |
| Ash  |                          |                          |
| Chlorine   |                          |                          |
| Heating Value (BTU/#)                                    |                          |                          |
| <b>Methanol Analysis (Wt %)</b>                          | X                        | X                        |
| Acetic Acid  |                          |                          |
| Water  |                          |                          |
| Decane   |                          |                          |
| Methanol   |                          |                          |
| Acetone  |                          |                          |
| Ethanol  |                          |                          |
| Analysis Frequency                                       | Weekly                   | Daily                    |
| Sampling Technique                                       | Grab                     | Grab                     |
| Analytical Method  | GC/IR/TC                 | GC/IR/TC                 |

|  |  |
|--|--|
| Stream No.   | 242  |
| Description  | Crude (Grade) Methanol to<br>Lurgi (Methanol) Unit |
| PFD Material Balance Point No.                           | 242  |
| Gas Chromatograph Point No.                              | N/A  |
| Reported in:   |  |
| EMRs (Compliance)  |  |
| EMRs (Supplemental)                                      | X (Summary Data)                                   |
| Technical Progress Reports                               | X  |
| Test Series Report (one time)                            |  |
| Temperature  | X  |
| Pressure   | X  |
| Flow Rate  | X  |
| Composition  |  |
| <b>GC Analysis of Gases in<br/>LPMEOH™ Plant (Vol %)</b> |  |
| Hydrogen   |  |
| Carbon Monoxide  |  |
| Nitrogen   |  |
| Carbon Dioxide   |  |
| Methanol   |  |
| Dimethyl Ether   |  |
| Methane  |  |
| Oxygen (Argon)   |  |
| "Other" (by difference)                                  |  |
| <b>Coal Analysis (Wt %)</b>                              |  |
| Hydrogen   |  |
| Argon  |  |
| Sulfur   |  |
| Oxygen   |  |
| Nitrogen   |  |
| Moisture   |  |
| Fixed Carbon   |  |
| Ash  |  |
| Chlorine   |  |
| Heating Value (BTU/#)                                    |  |
| <b>Methanol Analysis (Wt %)</b>                          | X  |
| Acetic Acid  |  |
| Water  |  |
| Decane   |  |
| Methanol   |  |
| Acetone  |  |
| Ethanol  |  |
| Analysis Frequency                                       | Weekly   |
| Sampling Technique                                       | Grab   |
| Analytical Method  | GC/IR/TC   |




TABLE 7-2

**REPORTING REQUIREMENTS  
CHECK LIST**

| <u>REPORT</u>  | <u>DEFINED IN</u> | <u>FREQUENCY</u>   |
|--|-------------------|--|
| 1. Topical Reports -<br>Reports on specific classes of operation (e.g., Texaco-type syngas operation; load following and turndown operation; etc.) | DTP               | As required - 60 days after completion of last run in class.   |
| 2. Special (Topical) Report -<br>Provides information on Eastman Gasification and Gas Clean-up systems.  | EMP               | One time - during the first year of operation.   |
| 3. Technical Progress Reports -<br>Provide information on plant operations on a quarterly basis.   | DTP               | Quarterly during operating years - 60 days after end of quarter.   |
| 4. Environmental Monitoring Reports -<br>Provide Compliance and a supplemental monitoring information on a quarterly basis.                        | EMP               | Quarterly during the operating years. The 4th quarter report will also include an annual summary - 60 days after end of quarter. |
| 5. Special (Topical) Report -<br>Provide Data collected in two programs to characterize the Eastman Feed gases (includes analysis of HAPS)         | EMP               | One time - by December 1996  |

## APPENDIX A

### PROCESS FLOW DIAGRAMS




| PROPERTY DATA |             | ANALYSIS DATA |             | OPERATION DATA |             | DESIGN DATA |             |
|---------------|-------------|---------------|-------------|----------------|-------------|-------------|-------------|
| ITEM          | UNIT        | ITEM          | UNIT        | ITEM           | UNIT        | ITEM        | UNIT        |
| 1             | TEMPERATURE | 1             | TEMPERATURE | 1              | TEMPERATURE | 1           | TEMPERATURE |
| 2             | PRESSURE    | 2             | PRESSURE    | 2              | PRESSURE    | 2           | PRESSURE    |
| 3             | FLOW RATE   | 3             | FLOW RATE   | 3              | FLOW RATE   | 3           | FLOW RATE   |
| 4             | LEVEL       | 4             | LEVEL       | 4              | LEVEL       | 4           | LEVEL       |
| 5             | PH          | 5             | PH          | 5              | PH          | 5           | PH          |
| 6             | ANALYSIS    | 6             | ANALYSIS    | 6              | ANALYSIS    | 6           | ANALYSIS    |
| 7             | DESIGN      | 7             | DESIGN      | 7              | DESIGN      | 7           | DESIGN      |
| 8             | OPERATION   | 8             | OPERATION   | 8              | OPERATION   | 8           | OPERATION   |
| 9             | DESIGN      | 9             | DESIGN      | 9              | DESIGN      | 9           | DESIGN      |
| 10            | OPERATION   | 10            | OPERATION   | 10             | OPERATION   | 10          | OPERATION   |
| 11            | DESIGN      | 11            | DESIGN      | 11             | DESIGN      | 11          | DESIGN      |
| 12            | OPERATION   | 12            | OPERATION   | 12             | OPERATION   | 12          | OPERATION   |
| 13            | DESIGN      | 13            | DESIGN      | 13             | DESIGN      | 13          | DESIGN      |
| 14            | OPERATION   | 14            | OPERATION   | 14             | OPERATION   | 14          | OPERATION   |
| 15            | DESIGN      | 15            | DESIGN      | 15             | DESIGN      | 15          | DESIGN      |
| 16            | OPERATION   | 16            | OPERATION   | 16             | OPERATION   | 16          | OPERATION   |
| 17            | DESIGN      | 17            | DESIGN      | 17             | DESIGN      | 17          | DESIGN      |
| 18            | OPERATION   | 18            | OPERATION   | 18             | OPERATION   | 18          | OPERATION   |
| 19            | DESIGN      | 19            | DESIGN      | 19             | DESIGN      | 19          | DESIGN      |
| 20            | OPERATION   | 20            | OPERATION   | 20             | OPERATION   | 20          | OPERATION   |
| 21            | DESIGN      | 21            | DESIGN      | 21             | DESIGN      | 21          | DESIGN      |
| 22            | OPERATION   | 22            | OPERATION   | 22             | OPERATION   | 22          | OPERATION   |
| 23            | DESIGN      | 23            | DESIGN      | 23             | DESIGN      | 23          | DESIGN      |
| 24            | OPERATION   | 24            | OPERATION   | 24             | OPERATION   | 24          | OPERATION   |
| 25            | DESIGN      | 25            | DESIGN      | 25             | DESIGN      | 25          | DESIGN      |
| 26            | OPERATION   | 26            | OPERATION   | 26             | OPERATION   | 26          | OPERATION   |
| 27            | DESIGN      | 27            | DESIGN      | 27             | DESIGN      | 27          | DESIGN      |
| 28            | OPERATION   | 28            | OPERATION   | 28             | OPERATION   | 28          | OPERATION   |
| 29            | DESIGN      | 29            | DESIGN      | 29             | DESIGN      | 29          | DESIGN      |
| 30            | OPERATION   | 30            | OPERATION   | 30             | OPERATION   | 30          | OPERATION   |
| 31            | DESIGN      | 31            | DESIGN      | 31             | DESIGN      | 31          | DESIGN      |
| 32            | OPERATION   | 32            | OPERATION   | 32             | OPERATION   | 32          | OPERATION   |

PROPERTY DATA  
 ANALYSIS DATA  
 OPERATION DATA  
 DESIGN DATA

PROPERTY DATA  
 ANALYSIS DATA  
 OPERATION DATA  
 DESIGN DATA

PROPERTY DATA  
 ANALYSIS DATA  
 OPERATION DATA  
 DESIGN DATA


PROPERTY DATA  
 ANALYSIS DATA  
 OPERATION DATA  
 DESIGN DATA




| NO. | REVISION | DATE     | BY   | CHKD. | APP'D. | DESCRIPTION |
|-----|----------|----------|------|-------|--------|-------------|
| 1   | AS SHOWN | 11/15/55 | W.S. | W.S.  | W.S.   | AS SHOWN    |
| 2   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 3   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 4   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 5   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 6   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 7   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 8   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 9   | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 10  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 11  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 12  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 13  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 14  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 15  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 16  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 17  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 18  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 19  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 20  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 21  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 22  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 23  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 24  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 25  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 26  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 27  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 28  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 29  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 30  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 31  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |
| 32  | REVISED  | 11/15/55 | W.S. | W.S.  | W.S.   | REVISED     |

|  |  |  |  |
|--|--|--|--|
|  |  | <b>HERCULES EASTMAN DIVISION</b><br>A Division of the Hercules Company<br>10000 Kingsport Road, Kingsport, Tennessee, U.S.A.                                 |  |
| PROJECT NO. 8216P2<br>SECTION NO. 8216P2-1                       |  | TITLE<br><b>KINGSPORT LIQUID PHASE METHANOL<br/>                 PROCESS FLOW DIAGRAM<br/>                 SYNTHESIS SECTION<br/>                 8216P2</b> |  |
| DRAWN BY: [Blank]<br>CHECKED BY: [Blank]<br>APPROVED BY: [Blank] |  | DATE: 11/15/55   |  |
| SCALE: AS SHOWN  |  | SHEET NO. 2 OF 2   |  |

|                                |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |
|--------------------------------|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|
| 2                              | 4 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 |
| SHEET 2 OF 2<br>TOTAL SHEETS 2 |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |





| <p><b>PROPRIETARY DATA</b></p> <p>This information is the property of Eastman Chemical Company and is not to be disclosed to any other party without the written consent of Eastman Chemical Company. This information is not to be used for any purpose other than that for which it was originally intended. It is intended to be used only for the purpose of the design of the process described herein.</p> |                         | <p><b>GENERAL DATA</b></p> <p>DATE: 10/1/82<br/>         DRAWN BY: J. L. HARRIS<br/>         CHECKED BY: J. L. HARRIS<br/>         APPROVED BY: J. L. HARRIS</p> |  | <p><b>DESIGN DATA</b></p> <p>PROJECT: 8215F4<br/>         SHEET: 2 OF 2</p> |  | <p><b>REVISIONS</b></p> <table border="1"> <tr> <th>NO.</th> <th>DESCRIPTION</th> <th>DATE</th> </tr> <tr> <td>1</td> <td>ISSUED FOR CONSTRUCTION</td> <td>10/1/82</td> </tr> </table> |  | NO. | DESCRIPTION | DATE | 1 | ISSUED FOR CONSTRUCTION | 10/1/82 |
|--|-------------------------|--|--|---|--|--|--|-----|-------------|------|---|-------------------------|---------|
| NO.  | DESCRIPTION             | DATE   |  |   |  |  |  |     |             |      |   |                         |         |
| 1  | ISSUED FOR CONSTRUCTION | 10/1/82  |  |   |  |  |  |     |             |      |   |                         |         |
| <p>TEMPERATURE: 29F-31</p>   |                         | <p>PRODUCTS: NONE</p>  |  | <p>UNIT: 29F-31</p>   |  |  |  |     |             |      |   |                         |         |
| <p>LET US PROTECT YOUR AND OURS WITH CARE</p>  |                         |  |  |   |  |  |  |     |             |      |   |                         |         |

**TEMPERATURE**  
 29F-31

**PRODUCTS**  
 NONE

**UNIT**  
 29F-31

**PROPRIETARY DATA**  
 This information is the property of Eastman Chemical Company and is not to be disclosed to any other party without the written consent of Eastman Chemical Company. This information is not to be used for any purpose other than that for which it was originally intended. It is intended to be used only for the purpose of the design of the process described herein.

**GENERAL DATA**


DATE: 10/1/82  
 DRAWN BY: J. L. HARRIS  
 CHECKED BY: J. L. HARRIS  
 APPROVED BY: J. L. HARRIS

**DESIGN DATA**

PROJECT: 8215F4  
 SHEET: 2 OF 2

**REVISIONS**

| NO. | DESCRIPTION             | DATE    |
|-----|-------------------------|---------|
| 1   | ISSUED FOR CONSTRUCTION | 10/1/82 |



### PROPERTY DATA


THIS SHEET IS UNCLASSIFIED  
DATE 01-11-2011 BY [redacted]


| ITEM | DESCRIPTION | UNITS | AS-BUILT | REVISION | DATE | BY | APP'D |
|------|-------------|-------|----------|----------|------|----|-------|
| 1    | AS-BUILT    |       |          |          |      |    |       |
| 2    | REVISED     |       |          |          |      |    |       |
| 3    | REVISED     |       |          |          |      |    |       |
| 4    | REVISED     |       |          |          |      |    |       |
| 5    | REVISED     |       |          |          |      |    |       |
| 6    | REVISED     |       |          |          |      |    |       |
| 7    | REVISED     |       |          |          |      |    |       |
| 8    | REVISED     |       |          |          |      |    |       |
| 9    | REVISED     |       |          |          |      |    |       |
| 10   | REVISED     |       |          |          |      |    |       |
| 11   | REVISED     |       |          |          |      |    |       |
| 12   | REVISED     |       |          |          |      |    |       |
| 13   | REVISED     |       |          |          |      |    |       |
| 14   | REVISED     |       |          |          |      |    |       |
| 15   | REVISED     |       |          |          |      |    |       |
| 16   | REVISED     |       |          |          |      |    |       |
| 17   | REVISED     |       |          |          |      |    |       |
| 18   | REVISED     |       |          |          |      |    |       |
| 19   | REVISED     |       |          |          |      |    |       |
| 20   | REVISED     |       |          |          |      |    |       |
| 21   | REVISED     |       |          |          |      |    |       |
| 22   | REVISED     |       |          |          |      |    |       |
| 23   | REVISED     |       |          |          |      |    |       |
| 24   | REVISED     |       |          |          |      |    |       |
| 25   | REVISED     |       |          |          |      |    |       |
| 26   | REVISED     |       |          |          |      |    |       |
| 27   | REVISED     |       |          |          |      |    |       |
| 28   | REVISED     |       |          |          |      |    |       |
| 29   | REVISED     |       |          |          |      |    |       |
| 30   | REVISED     |       |          |          |      |    |       |
| 31   | REVISED     |       |          |          |      |    |       |
| 32   | REVISED     |       |          |          |      |    |       |

### KINGSPORT LIQUID PHASE METHANOL PROCESS FLOW DIAGRAM GENERAL UTILITIES SECTION 8215P5

NONE

29F-A





**PROPERTY DATA**

The data shown on this drawing is based on the following conditions:

1. All materials are at 60°F unless otherwise noted.

2. All materials are at 1 atm unless otherwise noted.

3. All materials are at 100% unless otherwise noted.

4. All materials are at 100% unless otherwise noted.

5. All materials are at 100% unless otherwise noted.

| ITEM | DESCRIPTION              | UNIT  | VALUE |
|------|--------------------------|-------|-------|
| 1    | 290-30 FRESH OIL STORAGE | CU FT | 100   |
| 2    | 290-31                   | CU FT | 100   |
| 3    | 290-14                   | CU FT | 100   |
| 4    | 290-15                   | CU FT | 100   |
| 5    | 290-16                   | CU FT | 100   |


TEMPERATURE DIVISION  
KINGSPORT LIQUID PHASE METHANOL  
PROCESS FLOW DIAGRAM  
CATALYST RECOVERY SECTION  
8215P6

|                                |                                     |                               |
|--------------------------------|-------------------------------------|-------------------------------|
| NO. 290-11A G3                 | CONDENSATE G3                       | FROM FEAR TRINCE FILL STATION |
| EA SEAL OIL RETURN FROM 290-08 | EB OIL TO 290-30/290-31             | EB OIL TO 290-02              |
| SAFE LOCATION                  | 291-35A/B SEAL OIL TO 290-07/290-30 | OIL TO 290-02/290-30          |
| OIL FLUSH TO 290-30            | OIL FLUSH TO 290-07/290-08          |                               |

PROPERTY DATA

|      |                          |       |       |
|------|--------------------------|-------|-------|
| ITEM | DESCRIPTION              | UNIT  | VALUE |
| 1    | 290-30 FRESH OIL STORAGE | CU FT | 100   |
| 2    | 290-31                   | CU FT | 100   |
| 3    | 290-14                   | CU FT | 100   |
| 4    | 290-15                   | CU FT | 100   |
| 5    | 290-16                   | CU FT | 100   |





|  |  |  |  |
|--|--|--|--|
| <p>TEMPESSE EASTMAN DIVISION</p> <p>KINGSFORT LIQUID PHASE METHANOL</p> <p>PROCESS FLOW DIAGRAM</p> <p>PRODUCT STORAGE SECTION</p> <p>B21SP7</p>       |  | <p>DATE: NONE</p> <p>SCALE: NONE</p>   |  |
| <p>PROOFERS</p>  |  | <p>PROJECT NO. 3-8275-55.01A</p> <p>REV. 1</p> <p>REV. 2</p>   |  |
| <p>PROPERTY DATA</p> <p>MEAN PRODUCT</p> <p>FROM DISTILLATION &amp; PRODUCT STORAGE PROCESS EQUIPMENT TRAINS</p> <p>FROM 290-02</p> <p>FROM 290-02</p> |  | <p>PROPERTY DATA</p> <p>MEAN PRODUCT</p> <p>FROM DISTILLATION &amp; PRODUCT STORAGE PROCESS EQUIPMENT TRAINS</p> <p>FROM 290-02</p> <p>FROM 290-02</p> |  |
| <p>MEAN PRODUCT</p>  |  | <p>MEAN PRODUCT</p>  |  |
| <p>REJECT MEAN TO PRO-STORAGE</p>  |  | <p>REJECT MEAN TO PRO-STORAGE</p>  |  |
| <p>MEAN TO PRO-STORAGE</p>   |  | <p>MEAN TO PRO-STORAGE</p>   |  |
| <p>MEAN TO LOADING RACK</p>  |  | <p>MEAN TO LOADING RACK</p>  |  |
| <p>VENT TO PLANT 30-30 SCRAPPER</p>  |  | <p>VENT TO PLANT 30-30 SCRAPPER</p>  |  |
| <p>VAPOR RETURN FROM TRAILER LOADING RACK</p>  |  | <p>VAPOR RETURN FROM TRAILER LOADING RACK</p>  |  |

Appendix B - Equipment List

| Equipment No. | Description                              | Process Flow Diagram No. | Equipment No. | Description                              | Process Flow Diagram No. |
|---------------|--|--------------------------|---------------|--|--------------------------|
| 29C-01        | LPMEOH Reactor                           | 2                        | 29E-11        | Methanol Stabilizer Condenser            | 3                        |
| 29C-02        | Steam Drum                               | 5                        | 29E-20        | Methanol Rectifier Reboiler              | 3                        |
| 29C-03        | High Pressure Methanol Separator         | 3                        | 29E-21        | Methanol Rectifier Air Cooler Condenser  | 3                        |
| 29C-05        | Secondary Oil K.O. Vessel                | 2                        | 29E-22        | Methanol Rectifier Cooling Water Subcool | 3                        |
| 29C-06        | Cyclone                                  | 2                        | 29E-23        | Crude Methanol Cooler                    | 3                        |
| 29C-07        | Compressor K.O. Separator                | 1                        | 29E-31        | Reduction Vessel Overhead Condenser      | 4                        |
| 29C-10        | Methanol Stabilizer Tray Column          | 3                        | 29E-32        | Utility Oil Heater                       | 4                        |
| 29C-11        | Methanol Stabilizer Reflux Drum          | 3                        | 29E-33        | Utility Oil Cooler                       | 4                        |
| 29C-12        | Methanol Stabilizer Feed Drum            | 3                        | 29E-40        | Regeneration Heater                      | 1                        |
| 29C-13        | Stabilizer Condensate Pot                | 3                        | 29G-01A/B     | Condensed Oil Circulation Pump           | 2                        |
| 29C-20        | Methanol Rectifier Tray Column           | 3                        | 29G-02        | Slurry Return Pump                       | 5                        |
| 29C-21        | Methanol Rectifier Reflux Drum           | 3                        | 29G-03A/B     | Oil Make-up Pump                         | 6                        |
| 29C-23        | Rectifier Condensate Pot                 | 3                        | 29G-04A/B     | Boiler Feed Water Pump                   | 5                        |
| 29C-30        | Catalyst Reduction Vessel                | 4                        | 29G-10A/B     | Methanol Stabilizer Underflow Pump       | 4                        |
| 29C-31        | Reduction Condensate Accumulator         | 4                        | 29G-11A/B     | Methanol Stabilizer Reflux Pump          | 4                        |
| 29C-32        | Utility Oil Surge Tank                   | 4                        | 29G-20A/B     | Methanol Rectifier Underflow Pump        | 4                        |
| 29C-40        | Carbonyl Guard Bed                       | 1                        | 29G-21A/B     | Methanol Rectifier Reflux Pump           | 4                        |
| 29C-50        | Oil/Water Separator                      | 5                        | 29G-23A/B     | Methanol Transfer Pump                   | 7                        |
| 29C-120       | Vent Scrubber                            | 5                        | 29G-25        | Methanol Drain Tank Lift Pump            | 7                        |
| 29D-01        | Safety Relief K.O. Drum                  | 5                        | 29G-30        | Slurry Transfer Pump                     | 4                        |
| 29D-02        | Slurry Tank                              | 5                        | 29G-32        | Utility Oil Circulating Pump             | 4                        |
| 29D-20        | Methanol Lot Tank                        | 7                        | 29G-34        | Oil Feed Pump                            | 6                        |
| 29D-21        | Methanol Lot Tank                        | 7                        | 29G-60A/B     | Caustic Metering Pump                    | 3                        |
| 29D-25        | Methanol Area Drain Tank                 | 7                        | 29K-01        | Syngas Recycle Compressor                | 1                        |
| 29D-30        | Fresh Oil Storage Tank                   | 6                        | 29SP-001      | Steam Drum Blowdown Cooler               | 5                        |
| 29D-60        | Caustic Mix Tank                         | 3                        | 29Y-01A/B     | Fresh Feed Syngas Filter                 | 1                        |
| 29E-01        | Syngas Compressor Recycle Cooler         | 1                        | 29Y-02        | Slurry Tank Agitator                     | 5                        |
| 29E-02        | Syngas Feed/Product Economizer           | 2                        | 29Y-10        | Methanol Product Filter                  | 3                        |
| 29E-03        | Methanol Product Air Cooler Condenser    | 3                        | 29Y-30        | Catalyst Reduction Agitator              | 4                        |
| 29E-04        | Methanol Product Cooling Water Condenser | 3                        | 29Y-35A/B     | Seal Oil Filter                          | 6                        |
| 29E-10        | Methanol Stabilizer Reboiler             | 3                        | 29Y-60        | Caustic Tank Agitator                    | 3                        |

# APPENDIX C

# MILESTONE SCHEDULE STATUS REPORT

## LIQUID PHASE METHANOL DEMONSTRATION

### DE-FC22-92PC90543


| Task Name                             | Duration | Start     | End       | % Comp | % Sched | Years |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
|---------------------------------------|----------|-----------|-----------|--------|---------|-------|----|----|----|----|----|----|---|---|---|--|--|--|--|--|--|
|                                       |          |           |           |        |         | 93    | 94 | 95 | 96 | 97 | 98 | 99 | 0 | 1 | 2 |  |  |  |  |  |  |
| <b>PHASE 1: DESIGN</b>                |          |           |           |        |         |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| PROJECT DEFINITION(TASK 1)            | 51.20 m  | Oct/01/93 | Dec/30/97 | 97     | 79      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| CONTINUATION APPLICATION(B.P.#2)      | 12.04 m  | Oct/01/93 | Sep/30/94 | 100    | 100     |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| PERMITTING(TASK 2)                    | 9.00 d   | Aug/02/94 | Aug/10/94 | 100    | 100     |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| NEPA FONSI APPROVAL                   | 32.07 m  | Nov/17/93 | Jul/15/96 | 98     | 98      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DESIGN ENGINEERING(TASK 3)            | 0.00 d   | Jun/30/95 | Jun/30/95 | 100    | 100     |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| VENDOR ENGINEERING                    | 27.71 m  | Apr/15/94 | Aug/01/96 | 98     | 97      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| OFF-SITE TESTING(TASK 4)              | 22.83 m  | Aug/10/94 | Jul/01/96 | 99     | 99      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| UPDATED FUEL TEST PLAN APPROVAL       | 46.35 m  | Feb/25/94 | Dec/30/97 | 10     | 40      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DECISION TO CONTINUE DME TESTING      | 0.00 d   | Aug/31/96 | Aug/31/96 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| PLANNING, ADMIN & DME DVT(TASK 5)     | 0.00 d   | Dec/01/96 | Dec/01/96 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| <b>PHASE 2: CONSTRUCTION</b>          |          |           |           |        |         |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| PROCUREMENT(TASK 1)                   | 39.16 m  | Oct/01/93 | Dec/30/96 | 95     | 83      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| CONSTRUCTION(TASK 2)                  | 50.18 m  | Oct/17/94 | Dec/15/98 | 60     | 48      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| TRAINING & COMMISSIONING(TASK 3)      | 21.61 m  | Oct/17/94 | Aug/01/96 | 98     | 93      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| OFF-SITE TESTING(TASK 4)              | 14.12 m  | Oct/02/95 | Dec/02/96 | 41     | 60      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| PLANNING & ADMINISTRATION(TASK 5)     | 15.70 m  | Sep/05/95 | Dec/23/96 | 25     | 60      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| CONTINUATION APPLICATION(B.P.#3)      | 9.57 m   | Mar/01/98 | Dec/15/98 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| <b>PHASE 3: OPERATION</b>             |          |           |           |        |         |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| START-UP(TASK 1)                      | 42.69 m  | Jun/01/95 | Dec/15/98 | 30     | 30      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| METHANOL OPERATION(TASK 2.1)          | 2.08 m   | May/31/96 | Aug/01/96 | 40     | 40      |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DISMANTLE PLANT(TASK 2.3)             | 2.08 m   | Dec/27/96 | Dec/28/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| ON-SITE PRODUCT USE DEMO(TASK 3)      | 1.22 m   | Dec/27/96 | Feb/01/97 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| OFF-SITE PRODUCT USE DEMO(TASK 4)     | 49.52 m  | Jan/26/97 | Mar/06/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DATA ANALYSIS/REPORTS(TASK 5)         | 7.98 m   | May/01/01 | Dec/28/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| PLANNING & ADMINISTRATIVE(TASK 6)     | 2.08 m   | Aug/01/97 | Oct/02/97 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| <b>PROVISIONAL DME IMPLEMENTATION</b> |          |           |           |        |         |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DME DVT(PDU TESTS)(TASK 3.6)          | 20.02 m  | May/01/98 | Dec/28/99 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DECISION TO IMPLEMENT                 | 56.35 m  | Dec/27/96 | Aug/30/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
| DESIGN, MODIFY & OPERATE(TASK 3.2.2)  | 60.31 m  | Dec/27/96 | Dec/28/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
|                                       | 47.41 m  | Apr/01/97 | Mar/07/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
|                                       | 9.57 m   | Apr/01/97 | Jan/15/98 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
|                                       | 0.00 d   | Mar/01/98 | Mar/01/98 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |
|                                       | 32.36 m  | Jul/01/98 | Mar/07/01 | 0      | 0       |       |    |    |    |    |    |    |   |   |   |  |  |  |  |  |  |

# APPENDIX D

**Table 1.1.1  
Work Breakdown Summary**

|           |          |                             |   |
|-----------|----------|-----------------------------|---|
| Phase I   | Task 1   | 1.1                         | Project Definition                                    |
|           | Task 2   | 1.2                         | Permitting  |
|           | Task 3   | 1.3                         | Design Engineering                                    |
|           | Task 4   | 1.3                         | Off-site Testing (Definition and Design)              |
|           | Task 5   | 1.5                         | Planning, Administration and DME Verification Testing |
| Phase II  | Task 1   | 2.1                         | Procurement   |
|           | Task 2   | 2.2                         | Construction  |
|           | Task 3   | 2.3                         | Training and Commissioning                            |
|           | Task 4   | 2.4                         | Off-site Testing (Procurement and Construction)       |
|           | Task 5   | 2.5                         | Planning and Administration                           |
| Phase III | Task 1   | 3.1                         | Startup   |
|           | Task 2   | 3.2                         | LPMEOH™ Process Demonstration Facility Operation      |
|           | Task 2.1 | 3.2.1                       | Methanol Operation                                    |
|           | Task 2.2 | 3.2.2                       | DME Design, Modification and Operation                |
|           | Task 2.3 | 3.2.2                       | LPMEOH™ Process Demonstration Facility Dismantlement  |
|           | Task 3   | 3.3                         | On-site Testing (Product Use Demonstration)           |
|           | Task 4   | 3.4                         | Off-site Testing (Fuel Use Demonstration)             |
|           | Task 5   | 3.5                         | Data Collection and Monitoring                        |
| Task 6    | 3.6      | Planning and Administration |   |

# APPENDIX E




CIVIL PLANT  
472

|   |  |   |
|---|--|---|
|   |  | TEMNESSE EASTMAN DIVISION<br>1715 - 1-0<br>L.P.M.C. |
| KINGSPORT TOWN PHASE II FLUID<br>EQUIPMENT AREA<br>3-8215 6201-311 101 0-1  |  | L.P.M.C.  |
| DISTILLATION AREA<br>REACTOR STRUCTURE<br>CATALYST BUILDING<br>METAL STORAGE (DIKED)<br>12' WIDE ASPHALT ROADWAY<br>12' WIDE GRAVEL ROADWAY<br>40' x 12' TRAILER CONSTRUCTION BUILDING PAD<br>TEMPORARY FENCE |  | PRODUCT   |
| 12' x 12' TRAILER<br>PRELIMINARY  | 24' x 40' TRAILER<br>TEMPORARY<br>JOINT VENTURE OFFICE | 12' x 12' TRAILER<br>PRELIMINARY                    |



# APPENDIX F



|   |  |   |  |  |  |
|---|--|---|--|--|--|
| TEMPELSE EASTMAN DIVISION<br>1000 W. 10th Street, Tulsa, Oklahoma 74103 |  | PRODUCT<br>   |  | KINGSFORD TONHO PHASE MECHANISM<br>KOMPASATI AIRRANGA MEKONORRHO VII W<br>KOMPASATI AIRRANGA MEKONORRHO ASI<br>3 NOV 63 00:50:10 3 11 11 |  |
| PROJECT<br>1000 W. 10th Street, Tulsa, Oklahoma 74103                   |  | DRAWING NO.<br>1000 W. 10th Street, Tulsa, Oklahoma 74103   |  | SHEET NO.<br>1000 W. 10th Street, Tulsa, Oklahoma 74103  |  |
| DESIGNER<br>1000 W. 10th Street, Tulsa, Oklahoma 74103                  |  | CHECKED<br>1000 W. 10th Street, Tulsa, Oklahoma 74103       |  | DATE<br>1000 W. 10th Street, Tulsa, Oklahoma 74103   |  |
| APPROVED<br>1000 W. 10th Street, Tulsa, Oklahoma 74103                  |  | TITLE<br>1000 W. 10th Street, Tulsa, Oklahoma 74103         |  | SCALE<br>1000 W. 10th Street, Tulsa, Oklahoma 74103  |  |
| MATERIALS<br>1000 W. 10th Street, Tulsa, Oklahoma 74103                 |  | MANUFACTURING<br>1000 W. 10th Street, Tulsa, Oklahoma 74103 |  | ASSEMBLY<br>1000 W. 10th Street, Tulsa, Oklahoma 74103   |  |
| PARTS LIST<br>1000 W. 10th Street, Tulsa, Oklahoma 74103                |  | DIMENSIONS<br>1000 W. 10th Street, Tulsa, Oklahoma 74103    |  | WEIGHT<br>1000 W. 10th Street, Tulsa, Oklahoma 74103   |  |
| COMMENTS<br>1000 W. 10th Street, Tulsa, Oklahoma 74103                  |  | REVISIONS<br>1000 W. 10th Street, Tulsa, Oklahoma 74103     |  | APPROVALS<br>1000 W. 10th Street, Tulsa, Oklahoma 74103  |  |

APPENDIX G  
AIR PERMIT APPLICATION

APC-20  
 PERMIT APPLICATION

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH EMISSION SOURCE, ATTACH APPROPRIATE SOURCE DESCRIPTION FORMS.

|   |             |                                  |                                       |                       |
|---|-------------|----------------------------------|---------------------------------------|-----------------------|
| 1. Organization's Legal Name Eastman Chemical Company |             |                                  | ///<br>For                            | APC Company-Point No. |
| 2. Mailing Address (St/Rd/P.O. Box)<br>P. O. Box 1993 |             |                                  | ///<br>APC                            | APC Log/Permit No.    |
| City<br>Kingsport                                     | State<br>TN | Zip Code<br>37662                | Phone With Area Code<br>(615)229-2000 |                       |
| 3. Principal Technical Contact J. H. Albrecht         |             |                                  | Phone With Area Code<br>(615)229-5877 |                       |
| 4. Site Address (St/Rd/Hwy)<br>South Eastman Road     |             |                                  | County Name<br>Sullivan               |                       |
| City of Distance to Nearest Town<br>Kingsport         |             | Zip Code<br>37662                | Phone With Area Code<br>(615)229-2000 |                       |
| 5. Emission Source No. B-486-1                        |             | Permit Renewal<br>Yes ( ) No (X) | SIC No. 2869                          |                       |

6. Brief Description of Emission Source  
 Production of Methanol and Dimethyl Ether

7. Type of Permit Request (Complete One Line Only)

|                   |                           |                 |                 |                                  |
|-------------------|---------------------------|-----------------|-----------------|----------------------------------|
| Construction      | Starting Date             | Completion Date |                 |                                  |
| (X)               | 3/1/95                    | 12/31/96        |                 |                                  |
| Operating         | Date Construction Started | Date Completed  | Last Permit No. | Emission Source Reference Number |
| ( )               |                           |                 | New Source      | New Source                       |
| Location Transfer | Transfer Date             |                 | Last Permit No. | Emission Source Reference Number |
| ( )               |                           |                 |                 |                                  |

Address of Last Location

8. Describe Changes That Have Been Made to This Equipment or Operation Since the Last Construction or Operating Permit Application.

New Source.

9. Signature (Application Must Be Signed Before It Will Be Processed)

*Barry M. Mitchell*

10. Signer's name (Type or Print)

B. M. Mitchell

Title

Authorized Signatory

APC-21 & 24  
 PROCESS OR FUEL BURNING SOURCE DESCRIPTION

|  |                  |                          |                           |                    |                             |
|--|------------------|--------------------------|---------------------------|--------------------|-----------------------------|
| 1. Organization Name   |                  | Eastman Chemical Company |                           | ///<br>For         | APC Company-Point No.       |
| 2. Emission Source No.   |                  | B-486-1                  |                           | ///<br>APC         | APC Log/Permit No.          |
| 3. Description of Process or Fuel Burning Unit<br>Production of Methanol and Dimethyl Ether  |                  |                          |                           |                    |                             |
| 4. Normal Operation:   | Hours/Day        | Days/Week                | Weeks/Year                | Days/Year          | Hours/Year                  |
|  | 24               | 7                        | 52                        | 365                | 8760                        |
| 5. Type of Permit Application  |                  |                          |                           |                    | (Check Below One Only)      |
| Process Source: Apply for a separate permit for each source, (check at right, and complete lines 6, 7 and 8)   |                  |                          |                           |                    | X                           |
| Process Source with in-process fuel: Products of combustion contact materials heated. Apply for a Separate permit for each source. (Check a right, and complete line 6, 7, 8, 10 to 14)  |                  |                          |                           |                    |                             |
| Non-Process Fuel Burning Source: Products of combustion do not contact materials heated. Complete this form for each boiler or fuel burner and complete and emission point description form (APC-22) for each stack. (Check at right and complete lines 8 to 14) |                  |                          |                           |                    |                             |
| 6. Type of Operation   |                  |                          | Normal Batch Time         | Normal Batches/Day |                             |
| Continuous (X) Batch ( )   |                  |                          |                           |                    |                             |
| 7. Process Material Inputs and In-Process Solid Fuels  |                  | Diagram Reference*       | Input Rates (Pounds/Hour) |                    | (For APC Use Only) SCC Code |
|  |                  |                          | Design                    | Actual             |                             |
| 1.   | Synthesis Gas    | 1                        | 35,500                    | 35,500             |                             |
| 2.   | Sodium Hydroxide | 6                        | 1                         | 1                  |                             |
| 3.   | Carbon Monoxide  | 2                        | 4,600                     | 4,600              |                             |
| 4.   | Hydrogen Purge   | 3                        | 5,500                     | 5,500              |                             |
| 5.   | Oil              | 5                        | 6,200                     | 6,200              |                             |
| 6.   | Catalyst         | 4                        | 1,600                     | 1,600              |                             |
| 7.   |                  |                          |                           |                    |                             |
|  |                  |                          | Totals**                  |                    | 54,000                      |

\* A Flow Diagram Must Be Attached  
 \*\*Total Rounded to 2 Significant Figures

8. Total Emissions for  
 This PES  
 (Tons/Year):

|                 | Average | Maximum | Other (Specify) | Average | Maximum |
|-----------------|---------|---------|-----------------|---------|---------|
| Particulates    | 0.10    | 0.10    | CO <sub>2</sub> | 1.38    | 1.38    |
| SO <sub>2</sub> | 0       | 0       | H <sub>2</sub>  | 0.30    | 0.30    |
| NO <sub>x</sub> | 0       | 0       |                 |         |         |
| CO              | 2.60    | 2.60    |                 |         |         |
| VOC             | 4.56    | 4.56    |                 |         |         |

J. Boiler or Burner Data. (Complete Lines 9 to 14 using a separate form for each boiler.)

| Boiler Number     | Stack Number ** | Type of Firing*** | Rated Boiler Horsepower | Rated Input Capacity (10 <sup>6</sup> Btu/Hr) | Fuel Type |           |
|-------------------|-----------------|-------------------|-------------------------|---|-----------|-----------|
|                   |                 |                   |                         |   | Primary   | Secondary |
| Not Applicable    |                 |                   |                         |   |           |           |
| Boiler Serial No. |                 | Date Constructed  | Last Modification Date  |   |           |           |

\*\* Boilers with same stack will have same stack number.

\*\*\* Cyclone spreader (with or without reinjection), pulverized (wet or dry bottom, with or without reinjection), other stoker (specify type), hand fired, automatic, or other type (describe below in comments.)

10. Fuel Data. (Complete for a process source with in-process fuel or a nonprocess fuel burning source.) Not Applicable

| Fuels Used                    | Annual Usage         | Hourly Usage |         | Percent Sulfur | Percent Ash | Btu Value of Fuel | (For APC Only) SCC Code |
|-------------------------------|----------------------|--------------|---------|----------------|-------------|-------------------|-------------------------|
|                               |                      | Design       | Average |                |             |                   |                         |
| Natural Gas:                  | 10 <sup>6</sup> CUFT | CUFT         | CUFT    | ///            | ///         | 1,000             |                         |
| #2 Fuel Oil:                  | 10 <sup>3</sup> GAL  | GAL          | GAL     |                | ///         |                   |                         |
| #5 Fuel Oil:                  | 10 <sup>3</sup> GAL  | GAL          | GAL     |                | ///         |                   |                         |
| #6 Fuel Oil:                  | 10 <sup>3</sup> GAL  | GAL          | GAL     |                | ///         |                   |                         |
| Coal:                         | TONS                 | LBS          | LBS     |                |             |                   |                         |
| Wood:                         | TONS                 | LBS          | LBS     | ///            | ///         |                   |                         |
| Liquid Propane                | 10 <sup>3</sup> GAL  | GAL          | GAL     | ///            | ///         | 85,000            |                         |
| Other: (Specify Type & Units) |                      |              |         |                |             |                   |                         |

11. If Wood is Used as a Fuel, Specify Types and Estimate Percent by Weight of Bark. <sup>Not</sup> ~~Applicable~~

12. If Wood is Used With Other Fuels, Specify Percent by Weight of Wood Charged to the Burner. Not Applicable

13. Comments:


14. If a Standby or Interruptible Fuel is Used, Give Type of Fuel, Annual Quantity Used, and the Schedule or Program for Use Not Applicable

|                                |   |                           |   |
|--------------------------------|---|---------------------------|---|
| Sulfur Content of Standby Fuel | % | If Coal, Show Ash Content | % |
|--------------------------------|---|---------------------------|---|

Btu Value \_\_\_\_\_

Flow Diagram

for Item 7 of APC-21 (& 24)



STATE OF TENNESSEE  
 DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
 DIVISION OF AIR POLLUTION CONTROL

PROCESS EMISSION SOURCE  
 NUMBER B-486-1  
 PAGE 5 OF 15  
 DATE DEC 02 1994  
 TANK ID NUMBER 29D-30  
 VENT ID NUMBER A

APC - 27  
 STORAGE TANK DESCRIPTION

PROCESS TANK  
 STORAGE TANK

|   |  |  |                               |
|---|--|--|-------------------------------|
| 1. ORGANIZATION NAME - EASTMAN CHEMICAL COMPANY   |  | FOR! APC COMPANY-POINT NO                |                               |
| 2. PROCESS EMISSION SOURCE NO.<br>B-486-1   |  | ! APC! APC SEQUENCE NO.                  |                               |
| 3. TANK LATITUDE<br>36 DEG 31' 7" N   | TANK LONGITUDE<br>82 DEG 32' 48" W     | UTM VERTICAL<br>4042400 N                | UTM HORIZONTAL<br>361500 E    |
| 4. TANK ID NUMBER<br>29D-30   | VENT ID NUMBER<br>A                    | CONSTRUCTION DATE<br>3/1/95              |                               |
| 5. DIAMETER (FT)<br>9.0   | HEIGHT (FT)<br>22.1                    | CAPACITY (GAL)<br>10500.                 |                               |
| 6. CYLINDER (VERT)<br>X   | CYLINDER (HORZ)                        | SPHERE                                   | OTHER (DESCRIBE)              |
| 7. TANK COLOR<br>WHITE  | ALUMINUM                               | GRAY                                     | OTHER (DESCRIBE)              |
| A. ROOF:  | SPECULAR                               | DIFFUSE                                  | LIGHT! MEDIUM! DARK!          |
| B. SHELL:   |  |  | X                             |
| 8. PAINT CONDITION  | GOOD<br>X                              | POOR                                     | NO PAINT                      |
| 9. TANK TYPE!<br>FIXED ROOF<br>X  | FLOATING ROOF                          | OPEN TOP                                 | UNDERGROUND! OTHER (DESCRIBE) |
| 10. INSULATED<br>NONE   | TEMPERATURE<br>77. DEGREES F           | PRESSURE<br>14. PSIA                     |                               |
| 1. FOR FLOATING ROOF TANKS COMPLETE: NOT APPLICABLE   |  |  |                               |
| A. ROOF TYPE  | DOUBLE DECK                            | PONTOON                                  | PAN OTHER (DESCRIBE)          |
| B. SEAL TYPE  | SINGLE                                 | DOUBLE                                   | OTHER (DESCRIBE)              |
| C. SHELL CONSTRUCTION!  | RIVETED                                | WELDED                                   | OTHER (DESCRIBE)              |
| 2. LIST ALL LIQUIDS, VAPORS, GASES, OR MIXTURES TO BE STORED IN THIS TANK.<br>GIVE THE PERCENT BY WEIGHT OF EACH COMPONENT. SEE APC - 27 SHEET 3. |  |  |                               |
| 3. OUTAGE: AVERAGE DISTANCE FROM TOP OF TANK TO LIQUID SURFACE (FEET)<br>11.0   | AVG. THROUGHPUT (GALLONS / DAY)<br>99. | MAXIMUM NO. OF TANK TURNS PER YEAR<br>3. |                               |



PROCESS EMISSION SOURCE  
NUMBER B-486-1  
PAGE 6 OF 15  
DATE DEC 02 1994  
TANK ID NUMBER 29D-30  
VENT ID NUMBER A

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF AIR POLLUTION CONTROL

APC - 27  
STORAGE TANK DESCRIPTION

|     |               |        |           |                |                  |
|-----|---------------|--------|-----------|----------------|------------------|
| 14. | LOADING TYPE: | BOTTOM | SUBMERGED | VAPOR BALANCED | OTHER (DESCRIBE) |
|     |               |        | X         |                |                  |

15. OPERATING HOURS/YEAR 8760. OPERATING DAYS/YEAR 365.

16. SPECIAL VAPOR CONTROL DEVICES:

CONSERVATION VENT

17. OPERATIONAL DATA:

CONTINUOUS FILLING AND DISCHARGING  
AVERAGE DAILY LEVEL FLUCTUATION N/A  
AVERAGE DAILY VOLUME FLUCTUATION N/A

BATCH FILLING

AVERAGE NUMBER OF GALLONS PER FILLING 6000.  
AVERAGE NUMBER OF FILLS PER YEAR 6.

18. INERT GAS OR NITROGEN FLOW:  
GAS FLOW 0.08300 SCFM  
SATURATION OF GAS 100.0 %

19. TOTAL VOC EMISSIONS: Negligible TONS/YEAR

20. TOTAL PARTICULATE EMISSIONS: 0.00 TONS/YEAR

21. EMISSIONS ESTIMATION METHOD AP - 42

PROCESS EMISSION SOURCE  
NUMBER B-486-1  
PAGE 7 OF 15  
DATE DEC 02 1994  
TANK ID NUMBER 29D-30  
VENT ID NUMBER A

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF AIR POLLUTION CONTROL

APC - 27  
STORAGE TANK DESCRIPTION

12. (CONTINUED)

| COMPONENT         | WEIGHT<br>PERCENT | MOL.<br>WEIGHT | VAPOR<br>PRESSURE<br>(PSIA) AT<br>77. DEG F |
|-------------------|-------------------|----------------|---|
| White Mineral Oil | 100.0             | 450.0          | 0.0000                                      |

STATE OF TENNESSEE  
 DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
 DIVISION OF AIR POLLUTION CONTROL

PROCESS EMISSION SOURCE  
 NUMBER B-486-1  
 PAGE 8 OF 15  
 DATE DEC 0 2 1994  
 TANK ID NUMBER 29D-31  
 VENT ID NUMBER B

APC - 27  
 STORAGE TANK DESCRIPTION

PROCESS TANK  
 STORAGE TANK

|           |  |  |   |                            |                  |      |
|-----------|--|--|---|----------------------------|------------------|------|
| 1.        | ORGANIZATION NAME - EASTMAN CHEMICAL COMPANY   | FOR                                    | APC COMPANY-POINT NO                      |                            |                  |      |
| 2.        | PROCESS EMISSION SOURCE NO.<br>B-486-1   | APC                                    | APC SEQUENCE NO.                          |                            |                  |      |
| 3.        | TANK LATITUDE<br>36 DEG 31' 7" N   | TANK LONGITUDE<br>82 DEG 32' 48" W     | UTM VERTICAL<br>4042400 N                 | UTM HORIZONTAL<br>361500 E |                  |      |
| 4.        | TANK ID NUMBER<br>29D-31   | VENT ID NUMBER<br>B                    | CONSTRUCTION DATE<br>3/1/95               |                            |                  |      |
| 5.        | DIAMETER (FT)<br>4.0   | HEIGHT (FT)<br>11.6                    | CAPACITY (GAL)<br>1000.                   |                            |                  |      |
| 6.        | CYLINDER (VERT)<br>X   | CYLINDER (HORZ)                        | SPHERE                                    | OTHER (DESCRIBE)           |                  |      |
| 7.        | TANK COLOR<br>WHITE  | ALUMINUM                               | GRAY                                      | OTHER (DESCRIBE)           |                  |      |
| A. ROOF:  | X  | SPECULAR                               | DIFFUSE                                   | LIGHT                      | MEDIUM           | DARK |
| B. SHELL: |  |  |   | X                          |                  |      |
| 8.        | PAINT CONDITION  | GOOD<br>X                              | POOR                                      | NO PAINT                   |                  |      |
| 9.        | TANK TYPE<br>FIXED ROOF<br>X   | FLOATING ROOF                          | OPEN TOP                                  | UNDERGROUND                | OTHER (DESCRIBE) |      |
| 10.       | INSULATED<br>NONE  | TEMPERATURE<br>122. DEGREES F          | PRESSURE<br>15. PSIA                      |                            |                  |      |
| 11.       | FOR FLOATING ROOF TANKS COMPLETE: NOT APPLICABLE   |  |   |                            |                  |      |
| A.        | ROOF TYPE  | DOUBLE DECK                            | PONTOON                                   | PAN                        | OTHER (DESCRIBE) |      |
| B.        | SEAL TYPE  | SINGLE                                 | DOUBLE                                    | OTHER (DESCRIBE)           |                  |      |
| C.        | SHELL CONSTRUCTION   | RIVETED                                | WELDED                                    | OTHER (DESCRIBE)           |                  |      |
| 12.       | LIST ALL LIQUIDS, VAPORS, GASES, OR MIXTURES TO BE STORED IN THIS TANK.<br>GIVE THE PERCENT BY WEIGHT OF EACH COMPONENT. SEE APC - 27 SHEET 3. |  |   |                            |                  |      |
| 13.       | OUTAGE: AVERAGE DISTANCE FROM TOP OF TANK TO LIQUID SURFACE (FEET)<br>5.8  | AVG. THROUGHPUT (GALLONS / DAY)<br>51. | MAXIMUM NO. OF TANK TURNS PER YEAR<br>19. |                            |                  |      |

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF AIR POLLUTION CONTROL

PROCESS EMISSION SOURCE  
NUMBER B-486-1  
PAGE 9 OF 15  
DATE DEC 02 1994  
TANK ID NUMBER 29D-31  
VENT ID NUMBER B

APC - 27  
STORAGE TANK DESCRIPTION

|                   |        |           |                |                  |
|-------------------|--------|-----------|----------------|------------------|
| 14. LOADING TYPE: | BOTTOM | SUBMERGED | VAPOR BALANCED | OTHER (DESCRIBE) |
|                   | X      |           |                |                  |

15. OPERATING HOURS/YEAR 8760. OPERATING DAYS/YEAR 365.

16. SPECIAL VAPOR CONTROL DEVICES:

CONSERVATION VENT

17. OPERATIONAL DATA:

CONTINUOUS FILLING AND DISCHARGING  
AVERAGE DAILY LEVEL FLUCTUATION N/A  
AVERAGE DAILY VOLUME FLUCTUATION N/A

BATCH FILLING  
AVERAGE NUMBER OF GALLONS PER FILLING 500.  
AVERAGE NUMBER OF FILLS PER YEAR 37.

18. INERT GAS OR NITROGEN FLOW:  
GAS FLOW 0.08300 SCFM  
SATURATION OF GAS 100.0 %

19. TOTAL VOC EMISSIONS: Negligible TONS/YEAR

20. TOTAL PARTICULATE EMISSIONS: 0.00 TONS/YEAR

21. EMISSIONS ESTIMATION METHOD AP - 42

PROCESS EMISSION SOURCE  
NUMBER B-486-1  
PAGE 10 OF 15  
DATE DEC 02 1994  
TANK ID NUMBER 29D-31  
VENT ID NUMBER B

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF AIR POLLUTION CONTROL

APC - 27  
STORAGE TANK DESCRIPTION

12. (CONTINUED)

| COMPONENT         | WEIGHT<br>PERCENT | MOL.<br>WEIGHT | VAPOR<br>PRESSURE<br>(PSIA) AT<br>122. DEG F |
|-------------------|-------------------|----------------|--|
| White Mineral Oil | 100.0             | 450.0          | 0.0000                                       |

PROCESS EMISSION SOURCE  
 NUMBER B-486-1  
 PAGE 11 OF 15  
 DATE DEC 6 2 1994  
 TANK ID NUMBER 29C-36  
 VENT ID NUMBER C

-STATE OF TENNESSEE  
 DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
 -DIVISION OF AIR POLLUTION CONTROL

APC - 27  
 STORAGE TANK DESCRIPTION

PROCESS TANK  
 STORAGE TANK

|  |  |  |                            |                  |      |
|--|--|--|----------------------------|------------------|------|
| 1. ORGANIZATION NAME - EASTMAN CHEMICAL COMPANY  |  | FOR  | APC COMPANY-POINT NO       |                  |      |
| 2. PROCESS EMISSION SOURCE NO.<br>B-486-1  |  | APC  | APC SEQUENCE NO.           |                  |      |
| 3. TANK LATITUDE<br>36 DEG 31' 7" N  | TANK LONGITUDE<br>82 DEG 32' 48" W     | UTM VERTICAL<br>4042400 N                  | UTM HORIZONTAL<br>361500 E |                  |      |
| 4. TANK ID NUMBER<br>29C-36  | VENT ID NUMBER<br>C                    | CONSTRUCTION DATE<br>3/1/95                |                            |                  |      |
| 5. DIAMETER (FT)<br>2.0  | HEIGHT (FT)<br>4.7                     | CAPACITY (GAL)<br>110.                     |                            |                  |      |
| 6. CYLINDER (VERT)<br>X  | CYLINDER (HORZ)                        | SPHERE                                     | OTHER (DESCRIBE)           |                  |      |
| 7. TANK COLOR<br>WHITE   | ALUMINUM                               | GRAY                                       | OTHER (DESCRIBE)           |                  |      |
| A. ROOF:   | SPECULAR                               | DIFFUSE                                    | LIGHT                      | MEDIUM           | DARK |
| B. SHELL:  |  |  | X                          |                  |      |
| 8. PAINT CONDITION   | GOOD<br>X                              | POOR                                       | NO PAINT                   |                  |      |
| 9. TANK TYPE<br>FIXED ROOF<br>X  | FLOATING ROOF                          | OPEN TOP                                   | UNDERGROUND                | OTHER (DESCRIBE) |      |
| 10. INSULATED<br>NONE  | TEMPERATURE<br>122. DEGREES F          | PRESSURE<br>15. PSIA                       |                            |                  |      |
| 11. FOR FLOATING ROOF TANKS COMPLETE: NOT APPLICABLE   |  |  |                            |                  |      |
| A. ROOF TYPE   | DOUBLE DECK                            | PONTOON                                    | PAN                        | OTHER (DESCRIBE) |      |
| B. SEAL TYPE   | SINGLE                                 | DOUBLE                                     |                            | OTHER (DESCRIBE) |      |
| C. SHELL CONSTRUCTION  | RIVETED                                | WELDED                                     |                            | OTHER (DESCRIBE) |      |
| 12. LIST ALL LIQUIDS, VAPORS, GASES, OR MIXTURES TO BE STORED IN THIS TANK.<br>GIVE THE PERCENT BY WEIGHT OF EACH COMPONENT. SEE APC - 27 SHEET 3. |  |  |                            |                  |      |
| 13. OUTAGE: AVERAGE DISTANCE FROM TOP OF TANK TO LIQUID SURFACE (FEET)<br>2.3  | AVG. THROUGHPUT (GALLONS / DAY)<br>50. | MAXIMUM NO. OF TANK TURNS PER YEAR<br>166. |                            |                  |      |

PROCESS EMISSION SOURCE  
NUMBER B-486-1  
PAGE 12 OF 15  
DATE DEC 02 1984  
TANK ID NUMBER 29C-36  
VENT ID NUMBER C

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF AIR POLLUTION CONTROL

APC - 27  
STORAGE TANK DESCRIPTION

|                   |        |           |                |                  |
|-------------------|--------|-----------|----------------|------------------|
| 14. LOADING TYPE: | BOTTOM | SUBMERGED | VAPOR BALANCED | OTHER (DESCRIBE) |
|                   |        | X         |                |                  |

15. OPERATING HOURS/YEAR 8760. OPERATING DAYS/YEAR 365.

16. SPECIAL VAPOR CONTROL DEVICES:

CONSERVATION VENT

17. OPERATIONAL DATA:

CONTINUOUS FILLING AND DISCHARGING  
AVERAGE DAILY LEVEL FLUCTUATION N/A  
AVERAGE DAILY VOLUME FLUCTUATION N/A

BATCH FILLING  
AVERAGE NUMBER OF GALLONS PER FILLING 88.  
AVERAGE NUMBER OF FILLS PER YEAR 208.

18. INERT GAS OR NITROGEN FLOW:  
GAS FLOW 0.08300 SCFM  
SATURATION OF GAS 100.0 %

19. TOTAL VOC EMISSIONS: Negligible TONS/YEAR

20. TOTAL PARTICULATE EMISSIONS: 0.00 TONS/YEAR

21. EMISSIONS ESTIMATION METHOD AP - 42

PROCESS EMISSION SOURCE  
NUMBER B-486-1  
PAGE 13 OF 15  
DATE DEC 02 1994  
TANK ID NUMBER 29C-36  
VENT ID NUMBER C

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF AIR POLLUTION CONTROL

APC - 27  
STORAGE TANK DESCRIPTION

12. (CONTINUED)

| COMPONENT         | WEIGHT<br>PERCENT | MOL.<br>WEIGHT | VAPOR<br>PRESSURE<br>(PSIA) AT<br>122. DEG F |
|-------------------|-------------------|----------------|--|
| White Mineral Oil | 100.0             | 450.0          | 0.0000                                       |



APC-22  
 EMISSION POINT DESCRIPTION

|   |   |                            |                           |                            |  |         |             |          |         |
|---|---|----------------------------|---------------------------|----------------------------|--|---------|-------------|----------|---------|
| 1. Organization Name  |   | Eastman Chemical Company   |                           | ///<br>For                 | APC Company-Point No.                          |         |             |          |         |
| 2. Emission Source No.  |   | Flow Diagram Point No.     |                           | ///<br>APC                 | APC Sequence No.                               |         |             |          |         |
| B-486-1   |   | D                          |                           |                            |  |         |             |          |         |
| 3. Location:  | Latitude<br>36° 31' 7" N                      | Longitude<br>82° 32' 48" W | UTM Vertical<br>4042400 N | UTM Horizontal<br>361500 E |  |         |             |          |         |
| 4. Brief Emission Point Description<br>Vent from scrubber   |   |                            |                           |                            |  |         |             |          |         |
| 5. Normal Operation:  | Hours/Days<br>24                              | Days/Week<br>7             | Weeks/Year<br>52          | Days/Year<br>365           | Hours/Year<br>8760                             |         |             |          |         |
| 6. Stack or Emission Point Data:  | Height Above Grade (FT)<br>60                 | Diameter (FT)<br>0.3       | Temperature (°F)<br>100   | % of Time Over 125°F<br>0  | Direction of Exit (Up, Down, Horizontal)<br>Up |         |             |          |         |
| Data at Exit Conditions:  | Flow (Actual Ft <sup>3</sup> /Min.)<br>0.13   | Velocity (Ft/Sec)<br>0.03  | Moisture (Volume %)<br>2  |                            |  |         |             |          |         |
| Data at Standard Conditions:<br>(70°F and 29.92 In. Hg.)  | Flow (Dry Std. Ft <sup>3</sup> /Min.)<br>0.10 | Velocity (Ft/Sec)<br>0.02  |                           |                            |  |         |             |          |         |
| 7. Air Contaminants   |   |                            |                           |                            |  |         |             |          |         |
|   | Emissions (Lbs/Hr)                            |                            | Concentration             |                            | Emissions (TPY)                                |         | Emissions*  | Control* | Control |
|   | Average                                       | Maximum                    | Average                   | Max.                       | Average  | Maximum | Est. Method | Device   | Eff. %  |
| Particulates  | -   |                            | **                        | **                         |  |         |             |          |         |
| Sulfur Dioxide  | -   |                            | ***                       | ***                        |  |         |             |          |         |
| Nitrogen Oxides   | -   |                            | PPM                       | PPM                        |  |         |             |          |         |
| Organic Compounds   | -   |                            | PPM                       | PPM                        |  |         |             |          |         |
| Carbon Monoxide   | 0.2   | 0.2                        | PPM<br>400,000            | PPM<br>400,000             | 0.88   | 0.88    | 2           | 000      | -       |
| Fluorides   | -   |                            |                           |                            |  |         |             |          |         |
| Other (Specify)   | -   |                            |                           |                            |  |         |             |          |         |
| 8. Check Types of Monitoring and Recording Instruments That are Attached:<br>Opacity Monitor ( ). SO <sub>2</sub> Monitor ( ). NO <sub>x</sub> Monitor ( ). Other (Specify in Comments) ( )<br>None (X) |   |                            |                           |                            |  |         |             |          |         |
| 9. Comments: (Continue on Back if Needed)   |   |                            |                           |                            |  |         |             |          |         |

\* Refer to the back of the permit application form for estimation method and control device codes.  
 \*\* Exit gas particulate concentration units: process - grains/dry standard ft<sup>3</sup> (70°F); wood fired boilers - grains/dry standard ft<sup>3</sup> (70°F); all other boilers - lbs/million Btu heat input.  
 \*\*\* Exit gas sulfur dioxide concentrations units: process - ppm by volume, dry bases; boiler - lbs/million Btu heat input.

APC-22  
 EMISSION POINT DESCRIPTION

|                        |                          |                            |                           |                            |
|------------------------|--------------------------|----------------------------|---------------------------|----------------------------|
| 1. Organization Name   | Eastman Chemical Company |                            | ///<br>For<br>///<br>APC  | APC Company-Point No.      |
| 2. Emission Source No. | Flow Diagram Point No.   |                            |                           | APC Sequence No.           |
|                        | B-486-1                  | E                          |                           |                            |
| 3. Location:           | Latitude<br>36° 31' 7" N | Longitude<br>82° 32' 48" W | UTM Vertical<br>4042400 N | UTM Horizontal<br>361500 E |

4. Brief Emission Point Description  
 Equipment Leaks

|  |  |                        |                          |                           |  |
|--|--|------------------------|--------------------------|---------------------------|--|
| 5. Normal Operation:                                     | Hours/Days<br>24                           | Days/Week<br>7         | Weeks/Year<br>52         | Days/Year<br>365          | Hours/Year<br>8760                       |
| 6. Stack or Emission Point Data:                         | Height Above Grade (FT)<br>-               | Diameter (FT)<br>-     | Temperature (°F)<br>-    | % of Time Over 125°F<br>- | Direction of Exit (Up, Down, Horizontal) |
| Data at Exit Conditions:                                 | Flow (Actual Ft <sup>3</sup> /Min.)<br>-   | Velocity (Ft/Sec)<br>- | Moisture (Volume %)<br>- |                           |  |
| Data at Standard Conditions:<br>(70°F and 29.92 In. Hg.) | Flow (Dry Std. Ft <sup>3</sup> /Min.)<br>- | Velocity (Ft/Sec)<br>- |                          |                           |  |

7. Air Contaminants

|                             | Emissions (lbs/Hr) |         | Concentration |      | Emissions (TPY) |         | Emissions*  | Control* | Control |
|-----------------------------|--------------------|---------|---------------|------|-----------------|---------|-------------|----------|---------|
|                             | Average            | Maximum | Average       | Max. | Average         | Maximum | Est. Method | Device   | Eff. %  |
| Particulates                | -                  | -       | **            | **   | -               | 0.10    | 3           | 000      | -       |
| Sulfur Dioxide              | -                  | -       | ***           | ***  | -               | -       | -           | -        | -       |
| Nitrogen Oxides             | -                  | -       | PPM           | PPM  | -               | -       | -           | -        | -       |
| Organic Compounds           | -                  | -       | PPM           | PPM  | -               | 4.56    | 5           | 000      | -       |
| Carbon Monoxide             | -                  | -       | PPM           | PPM  | -               | 1.72    | 5           | 000      | -       |
| Fluorides                   | -                  | -       | -             | -    | -               | -       | -           | -        | -       |
| Other (Specify)<br>Hydrogen | -                  | -       | -             | -    | -               | 0.30    | 5           | 000      | -       |

8. Check Types of Monitoring and Recording Instruments That are Attached:  
 Opacity Monitor ( ). SO<sub>2</sub> Monitor ( ). NO<sub>x</sub> Monitor ( ). Other (Specify in Comments) (X)  
 None ( )

9. Comments: (Continue on Back if Needed)  
 Leak detection and repair as required by Title III.

\* Refer to the back of the permit application form for estimation method and control device codes.

\* Exit gas particulate concentration units: process - grains/dry standard ft<sup>3</sup> (70°F); wood fired boilers - grains/dry standard ft<sup>3</sup> (70°F); all other boilers - lbs/million Btu heat input.

\*\*\* Exit gas sulfur dioxide concentrations units: process - ppm by volume, dry bases; boilers lbs/million Btu heat input.

BACT/LAER Discussion

Flow Diagram Reference Point A, B, C

1. Description of Reference Point

Conservation vents for Tanks 29D-30, 29D-31, and 29C-36.

2. Description of Emissions

Inert gas with a potential for a small quantity of VOC as a result of tank filling operations, breathing losses, and inert gas purges on level devices.

3. Alternatives Considered

Because low VOC emissions are produced due to the low vapor pressure of the stored chemical, no emission abatement was considered for these sources.

4. Relative Cost of Alternative Systems

Not applicable.

5. Relative Efficiencies of Alternative Systems

Not applicable.

6. Process Steps Which Inherently Reduce Emission Levels

None.

7. Reasons for Selection of the System Chosen

The low vapor pressure of the stored chemical results in low VOC emissions without the installation of emission control equipment. Emissions are negligible.

BACT/LAER Discussion

Flow Diagram Reference Point D

1. Description of Reference Point

Vent from a water scrubber.

2. Description of Emissions

Emissions consist of carbon monoxide.

3. Alternatives Considered

Due to the low potential for emissions as a result of process constraints, no alternatives were considered.

4. Relative Cost of Alternative Systems

Not applicable.

5. Relative Efficiencies of Alternative Svstems

Not applicable.

6. Process Steps Which Inherently Reduce Emission Levels

None.

7. Reasons for Selection of the System Chosen

Process constraints do not allow CO emissions to reach a significant level.

SACT/LAER Discussion

Flow Diagram Reference Point E

1. Description of Reference Point

Fugitive emissions from valves, flanges, and open equipment. Leak detection and repair will be employed per Title III.

2. Description of Emissions

These emissions consist of VOCs (including Methanol), CO, particulates, and other (H<sub>2</sub> and CO<sub>2</sub>).

3. Alternatives Considered

Because of the applicability of the HON, no other alternatives were considered.

4. Relative Cost of Alternative Systems

Not applicable.

5. Relative Efficiencies of Alternative Systems

Not applicable.

6. Process Steps Which Inherently Reduce Emission Levels

None.

7. Reasons for Selection of the System Chosen

Leak detection and repair, as required by Title III, represent the best management practices available.

Emission Changes for New/Modified Sources

| Vent Code | Type of Emission | * Application Max. Lb/Hr | This Application Max. Lb/Hr | Net Change Max. Lb/Hr | Hrs./Yr. | Net Change Max. TYP |
|-----------|------------------|--------------------------|-----------------------------|-----------------------|----------|---------------------|
| A         | VOC              | Not Applicable           | Negligible                  | -                     | 8760     | Negligible          |
| B         | VOC              | Not Applicable           | Negligible                  | -                     | 8760     | Negligible          |
| C         | VOC              | Not Applicable           | Negligible                  | -                     | 8760     | Negligible          |
| D         | CO               | Not Applicable           | 0.20                        | +0.20                 | 8760     | +0.88               |
| Fugitives | VOC              | Not Applicable           | 4.56 TPY                    | -                     | 8760     | +4.56               |
| E         | CO               | Not Applicable           | 1.72 TPY                    | -                     | 8760     | +1.72               |
|           | TSP              | Not Applicable           | 0.10 TPY                    | -                     | 8760     | +0.10               |
|           | Others           | Not Applicable           | 1.68 TPY                    | -                     | 8760     | +1.68               |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |
|           |                  |                          |                             |                       |          |                     |

|                        |                  |             |
|------------------------|------------------|-------------|
| Total Emission Change: | max.<br>lbs./hr. | max.<br>TPY |
| VOC                    | -                | +4.56       |
| TSP                    | -                | +0.10       |
| SO <sub>2</sub>        | -                | -           |
| NO <sub>x</sub>        | -                | -           |
| CO <sub>x</sub>        | -                | +2.60       |
| Other                  | -                | +1.68       |

\* Previous Application Submittal Date  
 (New Source)

**APPENDIX H**  
**APPROVED AIR PERMIT**

(BEST COPY AVAILABLE AT THIS TIME- WILL PROVIDE BETTER COPIES AT MEETING 4/25/96 FSF)

DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
NASHVILLE, TENNESSEE 37243-1531



Permit to Construct or Modify an Air Contaminant Source Issued Pursuant to Tennessee Air Quality Act

Date Issued: **MAR 16 1995**

Permit Number:  
**941010P**

Date Expires: February 1, 1997

Issued To:

Installation Address:

**Eastman Chemical Company**

**South Eastman Road  
Kingsport**

Installation Description:

Emission Source Reference No.:

**B-48651  
Production of Methanol and Dimethyl Ether  
Three (3) Tanks; Vents: A, B, C, D, and E**

**82-1010-88**

The holder of this permit shall comply with the conditions contained in this permit as well as all applicable provisions of the Tennessee Air Pollution Control Regulations.

CONDITIONS:

1. The application that was utilized in the preparation of this permit is dated December 2, 1994 and signed by Mr. B.M. Mitchell of the permitted facility. If this person terminates his/her employment or is reassigned different duties such that he/she is no longer the responsible person to represent and bind the facility in environmental permitting affairs, the owner or operator of this air contaminant source shall notify the Technical Secretary of the change. Said notification shall be in writing and submitted within thirty (30) days of the change. The notification shall include the name and title of the new person assigned by the source owner or operator to represent and bind the facility in environmental permitting affairs. All representations, agreements, covenants and conditions and covenants made by the former responsible person that were used in the establishment of limiting permit conditions on this permit will continue to be binding on the facility until such time that a revision to this permit is obtained that would change said representations, agreements and covenants.

(Continued on the next page)

*SGT. GAH John W. Walker*  
TECHNICAL SECRETARY

No Authority is Granted by this Permit to Operate, Construct, or Maintain any Installation in Violation of any Law, Statute, Code, Ordinance, Rule, or Regulation of the State of Tennessee or any of its Political Subdivisions.

NON-TRANSFERABLE

POSTAL INSTALLATION ADDRESS



- 2. Maximum process material input rate shall not exceed 54,000 pounds per hour (lb/hr).
- 3. This permit is only valid for the tanks listed below:

| Tank ID | Capacity (Gallons) |
|---------|--------------------|
| 29D-30  | 10,500             |
| 29D-31  | 1,000              |
| 29C-36  | 110                |

- 4. Carbon monoxide (CO) emitted from Vent D shall not exceed 0.2 lb/hr.
  - 5. Fugitive CO emitted from this source (pumps, valves, flanges, etc.) shall not exceed 1.72 tons per year (ton/yr).
  - 6. Fugitive particulate matter emitted from this source (pumps, valves, flanges, etc.) shall not exceed 0.1 ton/yr.
- This emission limitation is established pursuant to Rule 1200-3-7-.01(5) of Tennessee Air Pollution Control Regulations and the information contained in the agreement letter dated April 15, 1986 from the permittee.
- 7. Fugitive volatile organic compounds emitted from this source (pumps, valves, flanges, etc.) shall not exceed 4.56 ton/yr.

8. The permittee shall certify the start-up date of the air contaminant source regulated by this permit by submitting a copy of this permit with the information required in Attachment B of this condition completed to the Technical Secretary's representatives listed below:

A. DATE OF START-UP: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 (month) (day) (year)

B. Anticipated operating rate: \_\_\_\_\_ percent of maximum rated capacity.

For the purpose of complying with this condition, start-up of the air contaminant source shall be the date of the setting in operation of the source for the production of product for sale or use as raw materials or steam or heat production.

The undersigned represents that he/she has the full authority to represent and bind the permittee in environmental permitting affairs. The undersigned further represents that the above provided information is true to the best of his/her knowledge and belief.

|                               |  |                      |
|-------------------------------|--|----------------------|
| Signature                     |  | Date                 |
| Signer's name (Type or print) |  | Title                |
|                               |  | Phone with area code |

Note: This certification is not an application for an operating permit. At a minimum, the appropriate application form, usually an APCI 20, must be submitted requesting an operating permit. The application must be submitted in accordance with the requirements of this permit.

The completed certification shall be delivered to Compliance Validation Program and the Field Office at the addresses listed below no later than 10 days after the air contaminant source is started-up.

|   |   |
|---|---|
| Compliance Validation Program<br>Division of Air Pollution Control<br>901 1602 21st Annex<br>4014 Church Street<br>Nashville, TN 37213-1511 | Johnson City Field Office<br>Division of Air Pollution Control<br>210 1110 East 1st St<br>Johnson City, TN 37601-2163 |
|---|---|

(Continued on the next page)

MAR 16 1995

- 9. Visible emissions from this source shall not exceed 20 percent or greater opacity as determined by EPA Method 9, as published in the Federal Register, Volume 39, Number 219 on November 12, 1974 (6 minute average)
- 10. This permit shall serve as a temporary operating permit from initial start-up to the receipt of a standard operating permit, (regardless of the expiration date), provided the operating permit is applied for within thirty (30) days of initial start-up and the conditions of this permit and any applicable emission standards are met.

(End of conditions)

# APPENDIX I

CATALYST POISONS STUDY

To: Distribution Dept./Loc.:

From: C. M. Chen Dept./Ext.: PSE Process Eng./1-3315

Date: 9 May 1995

Subject: Updated summary of Kingsport LPMEOH feed stream analysis results

Distribution:

*Air Products:*

- D. M. Brown \*
- W. R. Brown \*
- D. A. Chin-Fatt \*
- P. A. Clark \*
- P. J. Clark \*
- D. P. Drown/F. S. Frenduto \*
- S. A. Gardner \*
- F. A. Lucrezi \*
- E. S. Schaub/V. E. Stein/B. L. Bhatt/M. S. Mazdai/S. P. DiMartino \*
- B. A. Toseland/X-D Peng \*

*Eastman Chemical:*

- M. S. Baggett
- T. T. Golob
- W. C. Jones
- J. L. Phillips
- K. M. Pittman
- J. K. Sanders

\* sent via MS Mail

The attached table is an *updated* summary of Kingsport gas feed stream analytical results. Results of gas scrubbing followed by ICP-AES (10 January 1995 report) and gas chromatographic analysis (23 February 1995 analysis report) have been incorporated into the table.

Please call me (610-481-3315) if you have any questions or comments.

\_\_\_\_\_  
Christopher M. Chen

**Methanol Feed Contaminants: Summary of Analytical Results (rev. 4/28/95)**

✓ HAPS

| Component                           | Catalyst Limit (ppmv) | Analytical Method Used | Sampling Technique | Sample Date | ppmv in  |                | Comments   |
|-------------------------------------|-----------------------|------------------------|--------------------|-------------|--|----------------|--|
|                                     |                       |                        |                    |             | Syngas Feed, pre-G-Bed   | Makeup         |  |
| Acetylene                           | 5                     | GC-FID                 | Offline gas        | 8/5/94      | < 0.5 (Note 2)   | < 0.5 (Note 2) |  |
|                                     |                       | GC-FID                 | Offline gas        | 2/94        | < 1 (Note 2)   | < 1 (Note 2)   |  |
| Hydrogen Sulfide (H <sub>2</sub> S) | 0.01 ?                | HGA-AAS                | Charcoal tube      | 8/5/94      | <del>0.02</del>  | < 0.001        | Eastman syngas guard bed                                   |
|                                     |                       | ICP-AES                | Acid scrub         | 4/94        | < 0.04   | < 0.04         |  |
|                                     |                       | TOP-SIMS               | Spent catalyst     | 1993        | Significant amount of AsO <sub>2</sub> <sup>-</sup> detected on spent catalyst surface vs. fresh catalyst. |                |  |
| Inert Gases (I <sub>2</sub> & F)    | 0.01                  | TOP-SIMS               | Spent catalyst     | 1993        | No additional amount detected on spent catalyst surface vs. fresh catalyst. No further analysis performed. |                |  |
|                                     |                       | FT-IR                  | Offline gas        | 2/94        | < 1  | < 1            |  |
| Iron (Fe)                           | 0.01                  | ICP-AES                | Acid scrub         | 12/94       | < 0.01   | < 0.01         | APCI guard bed for upset                                   |
|                                     |                       | F-AAS                  | Offline gas        | 8/5/94      | < 0.01   | < 0.01         |  |
|                                     |                       | ICP-AES                | Acid scrub         | 4/94        | < 0.025  | N/A            | < 0.025  |
|                                     |                       | F-AAS                  | Charcoal tube      | 8/5/94      | < 0.05   | < 0.04         | < 0.07   |
|                                     |                       | TOP-SIMS               | Spent catalyst     | 1993        | Slightly more Fe <sup>+</sup> detected on spent catalyst surface vs. fresh catalyst.                       |                |  |
| Nickel (Ni)                         | 0.01                  | ICP-AES                | Charcoal tube      | 8/5/94      | ≤ 0.001  | < 0.002        | APCI guard bed for upset                                   |
|                                     |                       | ICP-AES                | Acid scrub         | 12/94       | < 0.01   | < 0.01         |  |
|                                     |                       | ICP-AES                | Acid scrub         | 4/94        | < 0.025  | N/A            | < 0.025  |
|                                     |                       | TOP-SIMS               | Spent catalyst     | 1993        | No additional amount of Ni <sup>+</sup> detected on spent catalyst surface vs. fresh catalyst.             |                |  |
| Nitrogen compounds                  | 10                    | ion chromatography     | Acid scrub         | 3/94        | < 0.23   | < 0.23         | Need more sensitive analysis and/or portable test trailer. |
|                                     |                       | FT-IR                  | Offline gas        | 2/94        | < 1  | < 1            |  |
| Ammonia                             | 0.01                  | FT-IR                  | Offline gas        | 2/94        | < 1  | < 1            | Need more sensitive analysis and/or portable test trailer. |
|                                     |                       | ion chromatography     | Caustic scrub      | 3/94        | < 5  | < 7.5          |  |
|                                     |                       | TOP-SIMS               | Spent catalyst     | 1993        | No additional amount of CN <sup>-</sup> detected on spent catalyst surface vs. fresh catalyst.             |                |  |

conditions used for this analysis are listed in Table 3. The argon and oxygen content was obtained on the same instrument using a calcium chabazite column to separate argon from oxygen. The chromatographic conditions used for this analysis are listed in Table 4.

All three samples were screened for amines on a Hewlett-Packard 5890A gas chromatograph using a SPB-5 FSOT capillary column interfaced to a nitrogen-phosphorus detector (NPD). None of the samples contained any detectable levels of amines. The lower limit of detection for amine compounds is approximately 0.5 mole ppm. The chromatographic conditions are listed in Table 5. The samples were also screened for carbonyl sulfide (COS) on a Hewlett-Packard 5890 Series II gas chromatograph using a Chromosil 330 packed teflon column interfaced to a flame photometric detector (FPD). None of the samples contained any detectable levels of COS. The lower limit of detection for COS is approximately 4 mole ppm. The chromatographic conditions are listed in Table 6.

The sample was also analyzed on a DB-WAX FSOT capillary column interfaced to a flame ionization detector (FID) for determination of any additional organic compounds. Quantitation was obtained using an external standardization procedure with a detector response factor determined for methanol. The chromatographic conditions are listed in Table 7.

## RESULTS AND DISCUSSION

The concentration values reported for each sample in Table 1 have been normalized to 100% accountability. The total accountabilities for the "CO Feed" and "Syngas" samples were very close to 100% prior to normalization. However, the total accountability for the "Purge Gas" sample had a total accountability higher than 100%. This is mostly due to the high hydrogen content in the sample. The Eastman Syngas standard used to quantitate the hydrogen content only had 50 mole % hydrogen.

(  
"Kingsport"-type syngas  
Hendrix & Allentown

Table 1

## Sample Composition (Mole %)

| Components      | CO Feed                     | Syn Gas                     | Purge Gas                   |
|-----------------|-----------------------------|-----------------------------|-----------------------------|
| Hydrogen        | 1.76 (0.30)                 | 68.06 (0.23)                | 73.07 (0.85)                |
| Argon           | 0.16 (0.30)                 | 0.06 (2.78)                 | 0.94 (0.20)                 |
| Oxygen          | 0.08 (1.43)                 | 0.40 (0.41)                 | 7.14 (0.04)                 |
| Nitrogen        | 0.91 (0.99)                 | 0.40 (2.43)                 | 7.80 (0.41)                 |
| Carbon Monoxide | 97.03 (0.17)                | 27.96 (0.93)                | 5.92 (0.21)                 |
| Carbon Dioxide  | N.D. (<0.001)               | 3.00 (0.94)                 | 2.88 (0.32)                 |
| Methane         | 0.05 (0.99)                 | 0.12 (2.76)                 | 1.28 (0.05)                 |
| Ethane          | N.D. (<0.00005)             | 0.0006 (3.44)               | 0.03 (0.18)                 |
| Ethylene        | N.D. (<0.00005)             | N.D. (<0.00005)             | N.D. (<0.00005)             |
| Acetylene       | N.D. (<0.00005)             | N.D. (<0.00005)             | N.D. (<0.00005)             |
| Propane         | N.D. (<0.00005)             | N.D. (<0.00005)             | 0.01 (1.05)                 |
| Propylene       | N.D. (<0.00005)             | N.D. (<0.00005)             | N.D. (<0.00005)             |
| Iso-butane      | N.D. (<0.00005)             | N.D. (<0.00005)             | 0.0006 (0.10)               |
| n-Butane        | N.D. (<0.00005)             | N.D. (<0.00005)             | 0.004 (0.48)                |
| Iso-pentane     | N.D. (<0.00005)             | N.D. (<0.00005)             | 0.0003 (0.77)               |
| n-Pentane       | N.D. (<0.00005)             | N.D. (<0.00005)             | 0.0009 (0.37)               |
| Hexanes         | N.D. (<0.00005)             | N.D. (<0.00005)             | 0.0002 (1.38)               |
| Amines          | N.D. (<0.00005)             | N.D. (<0.00005)             | N.D. (<0.00005)             |
| COS             | N.D. (<0.0004)<br>(<0.0005) | N.D. (<0.0004)<br>(<0.0005) | N.D. (<0.0004)<br>(<0.0005) |
| Acetonitrile    | N.D. (<0.05)                | N.D. (<0.05)                | N.D. (<0.05)                |
| Methanol        | N.D. (<0.05)                | N.D. (<0.05)                | 0.34 (0.38)                 |

Note: The data above is presented in the format X(S) where X is the average of two determinations and S is the relative percent standard deviation of the analysis.  
N.D. = Not Detected.

Don't forget to update

Table 2

### Gas Chromatographic Conditions

**Instrument:** Hewlett-Packard 5890 Series II Refinery Gas Analyzer

**Columns:**

*Analysis of Inerts* - Chrompack 25 meter x 0.53 mm ID Molsieve 5A PLOT fused silica capillary column; Chrompack 27.5 meter x 0.53 mm ID PoraPLOT Q PLOT fused silica capillary column.

*Analysis of Hydrocarbons* - Chrompack 50 meter x 0.53 mm ID AL203/KCL PLOT fused silica capillary column.

**Oven Temperature Program:**

|                     |           |
|---------------------|-----------|
| Initial Temperature | 40 °C     |
| Initial Time        | 6 min     |
| Program Rate        | 12 °C/min |
| Final Temperature   | 180 °C    |
| Final Time          | 18 min    |

**Carrier Gas: Helium**

|                                 |            |
|---------------------------------|------------|
| Flow Rate (Molsieve/PoraPLOT Q) | 7.5 ml/min |
| Column Headpressure             | 22 psig    |
| Flow Rate (AL203/KCL)           | 6 ml/min   |
| Column Headpressure             | 8 psig     |
| Splitter Flow Rate              | 40 ml/min  |

**Detector Type: Thermal Conductivity/Flame Ionization**

|                              |                 |
|------------------------------|-----------------|
| Detector Temperature         | 200 °C / 200 °C |
| TCD Reference Flow           | 22.5 ml/min     |
| FID Hydrogen                 | 30 ml/min       |
| FID Air                      | 360 ml/min      |
| Valve / Injector Temperature | 120 °C          |

**Injection Volume:** 25 microliters at atmospheric pressure

**Injection Mode:** Valco gas sampling valves

**Data System:** Hewlett-Packard 3396 integrator (Stored HP Methods RGA01 and RGA02)

**Quantitation Method:** External Standard (Calib. Std. # 2, 3, 4 and 8; Scotty Std. # 100 and 101)



Table 3

**Gas Chromatographic Conditions**

**Instrument:** Hewlett-Packard 5890A Gas Chromatograph

**Columns:** Activated Charcoal 80/100 mesh packed nickel column, 10' x 1/8"

**Oven Temperature Program:**

|                     |     |        |
|---------------------|-----|--------|
| Initial Temperature | 40  | °C     |
| Initial Time        | 4   | min    |
| Program Rate        | 10  | °C/min |
| Final Temperature   | 120 | °C     |
| Final Time          | 1   | min    |

**Carrier Gas:** Nitrogen

|                     |    |        |
|---------------------|----|--------|
| Flow Rate           | 30 | ml/min |
| Column Headpressure | 22 | psig   |

**Detector Type:** TCD

|                         |     |        |
|-------------------------|-----|--------|
| Detector Temperature    | 200 | °C     |
| Amplifier/Range Setting | 0   |        |
| Reference               | 20  | ml/min |

**Injector Temperature:** 0 °C

**Injection Volume:** 1 cc @ 1 atm.

**Injection Mode:** Valco gas sampling valve

**Data System:** HP-3396 Integrator

**Quantitation Method:** External Standard

**Calibration Standard:** Calib. Std. # 16, Eastman Syn Gas Standard

**Sample Preparation:** None

Table 4

**Gas Chromatographic Conditions**

**Instrument:** Hewlett-Packard 5890A Gas Chromatograph

**Columns:** Calcium Chabazite 80/100 mesh packed SS column, 6' x 1/8"

**Oven Temperature Program:**

|                     |     |        |
|---------------------|-----|--------|
| Initial Temperature | 40  | °C     |
| Initial Time        | 5   | min    |
| Program Rate        | 15  | °C/min |
| Final Temperature   | 210 | °C     |
| Final Time          | 1   | min    |

**Carrier Gas: Helium**

|                     |    |        |
|---------------------|----|--------|
| Flow Rate           | 22 | ml/min |
| Column Headpressure | 25 | psig   |

**Detector Type: TCD**

|                         |     |        |
|-------------------------|-----|--------|
| Detector Temperature    | 200 | °C     |
| Amplifier/Range Setting | 0   |        |
| Reference               | 33  | ml/min |

**Injector Temperature:** Room Temperature

**Injection Volume:** 5 cc @ 1 atm.

**Injection Mode:** Valco gas sampling valve

**Data System:** HP-3396 Integrator

**Quantitation Method:** External Standard

**Calibration Standard:** Calib. Std. # 2, 3

**Sample Preparation:** None

Table 5

**Gas Chromatographic Conditions**

**Instrument:** Hewlett-Packard 5890A Gas Chromatograph

**Columns:** SPB-5 FSOT capillary column, 30 meter x 0.32 mm I.D., 1.0 micron film. Col. # 224

**Oven Temperature Program:**

|                     |     |        |
|---------------------|-----|--------|
| Initial Temperature | 45  | °C     |
| Initial Time        | 5   | min    |
| Program Rate        | 8   | °C/min |
| Final Temperature   | 220 | °C     |
| Final Time          | 10  | min    |

**Carrier Gas: Helium**

|                     |     |        |
|---------------------|-----|--------|
| Flow Rate           | 2.1 | ml/min |
| Column Headpressure | 9.5 | psig   |
| Splitter Flow Rate  | 20  | ml/min |

**Detector Type: NPD**

|                         |     |        |
|-------------------------|-----|--------|
| Detector Temperature    | 280 | °C     |
| Amplifier/Range Setting | 0   |        |
| Hydrogen                | 3.5 | ml/min |
| Air                     | 110 | ml/min |
| NPD Make-up             | 28  | ml/min |

**Injector Temperature:** 150 °C

**Injection Volume:** 0.5 cc @ 1 atm.

**Injection Mode:** Manual injection

**Data System:** HP-3396 Integrator

**Quantitation Method:**

**Calibration Standard:**

**Sample Preparation:** None

Table 6

**Gas Chromatographic Conditions**

**Instrument:** Hewlett-Packard 5890 Series II Gas Chromatograph

**Columns:** Chromosil 330 packed teflon column, 8' x 1/8"

**Oven Temperature Program:**

|                     |    |        |
|---------------------|----|--------|
| Initial Temperature | 45 | °C     |
| Initial Time        | 2  | min    |
| Program Rate        | 10 | °C/min |
| Final Temperature   | 70 | °C     |
| Final Time          | 2  | min    |

**Carrier Gas: Helium**

|                     |    |        |
|---------------------|----|--------|
| Flow Rate           | 10 | ml/min |
| Column Headpressure | 15 | psig   |

**Detector Type: FPD**

|                         |     |        |
|-------------------------|-----|--------|
| Detector Temperature    | 150 | °C     |
| Amplifier/Range Setting | 0   |        |
| Hydrogen                | 100 | ml/min |
| Air                     | 110 | ml/min |
| FPD Make-up             | 24  | ml/min |

**Injector Temperature:** 80 °C

**Injection Volume:** 2.5 cc @ 1 atm.

**Injection Mode:** Valco gas sampling valve

**Data System:** HP-3396 Integrator

**Quantitation Method:**

**Calibration Standard:**

**Sample Preparation:** None

Table 7

**Gas Chromatographic Conditions****Instrument:** Hewlett-Packard 5890 Series II Gas Chromatograph**Columns:** DB-Wax FSOT capillary column, 30 meter x 0.25 mm I.D., 0.5 micron film. Col. # 92**Oven Temperature Program:**

|                     |     |        |
|---------------------|-----|--------|
| Initial Temperature | 40  | °C     |
| Initial Time        | 10  | min    |
| Program Rate        | 8   | °C/min |
| Final Temperature   | 160 | °C     |
| Final Time          | 2   | min    |

**Carrier Gas: Helium**

|                     |     |        |
|---------------------|-----|--------|
| Flow Rate           | 1.8 | ml/min |
| Column Headpressure | 9.1 | psig   |
| Splitter Flow Rate  | 20  | ml/min |

**Detector Type: FID**

|                         |     |        |
|-------------------------|-----|--------|
| Detector Temperature    | 270 | °C     |
| Amplifier/Range Setting | 2   |        |
| Hydrogen                | 30  | ml/min |
| Air                     | 310 | ml/min |
| FID Make-up             | 28  | ml/min |

**Injector Temperature:** 150 °C**Injection Volume:** 1 cc @ 1 atm.**Injection Mode:** Valco gas sampling valve**Data System:** PE Nelson 2700 Turbochrome**Quantitation Method:** External Standard**Calibration Standard:** 11664-10-3 (3.43 mole % methanol in Argon)**Sample Preparation:** None


PURGE GAS  
RGA Analysis - TCD

Sample Name : PURGE GAS  
FileName : A:\M21A006.RAW  
Method : default  
Start Time : 1.71 min  
Scale Factor: 0.0

End Time : 23.61 min  
Plot Offset: 0 mV

Sample #: 2  
Date : 1/6/95 10:24 AM  
Time of Injection: 11/21/94  
Low Point : 0.47 mV  
Plot Scale: 3.1 mV  
High Point : 3.5

Response [ $\mu$ V]




PURGE GAS  
RGA Analysis - PID

Sample Name : PURGE GAS  
FileName : A:\N21B006.RAW  
Method : default  
Start Time : 3.58 min  
Scale Factor: 0.0

End Time : 31.00 min  
Plot Offset: 0 mV

Sample #: 2  
Date : 1/6/95 10:27 AM  
Time of Injection: 11/21/94 03:32 PM  
Low Point : 0.38 mV  
Plot Scale: 4.5 mV  
High Point : 4.8

Response [uV]



# Analysis Report

RECEIVED



JUN - 1 1994

To: Elizabeth S. Schaub  
PROCESS ENGINEERING Dept./Loc.: PSG Proc Eng / A12A3

From: Patrick J. Clark  
Dept./Ext.: CRSD-ATC / 6504

Date: 31 May 1994  
Lab Name: Separations And Mass Spectrometry

Subject: Gas Chromatographic Analysis of Process Gas Streams from Eastman Chemical (Kingsport, TN)

Sample No.: See Below

c: CS File No. 1432, LB File, SAMS Circ., A. J. Di Gioia, C. M. Chen  
*6/6/94 via mail* *lower D.L. = 0.5 ppm*

## SUMMARY:

*• No aromatics (benzene or higher)*  
*• No acetonitrile*  
*• will perform analysis for O<sub>2</sub>/Ar split this week*

Three samples of feed gas to the proposed Liquid Phase Methanol facility at the Eastman Chemical complex at Kingsport, TN were analyzed for composition by gas chromatography. The samples were designated as follows: "CO Feed to AC2O Plant" described as a pure CO stream from a HYCO cold box, "Inlet Feed to MeOH Plant" described as the main syngas supply from the Lurgi plant feed, and "Purge Gas from MeOH Plant" described as the purge gas from the Lurgi methanol plant. The mole percent compositions of these process streams are tabulated in Table 1. The expected compositions, provided by Eastman Chemical, are also included in Table 1.

All of the samples contained hydrogen, oxygen/argon, nitrogen, carbon monoxide and methane. The sample identified as "Inlet Feed to MeOH Plant" also contained carbon dioxide, ethane and methanol. The sample identified as "Purge Gas from MeOH Plant" also contained carbon dioxide, ethane, ethylene, propane, propylene, iso-butane, n-butane, iso-pentane, n-pentane and n-hexane as well as methanol. The samples did not contain any detectable hydrocarbons heavier than C6.

Although two of the samples contained methanol, no other oxygenated organic compounds or amine compounds were detected in any of the samples. The estimated lower limit of detection for these types of compounds is approximately 0.5 mole ppm.

## PROBLEM DEFINITION:

Air Products will be constructing a 250 ton per day Liquid Phase Methanol facility at the Eastman Chemical complex in Kingsport (TN). Currently, a Texaco gasifier is used to convert coal into syngas which is used to produce a variety of chemicals, including methanol (using conventional Lurgi fixed bed technology), acetic acid and acetic anhydride. The LPMEOH plant will have three different sources of feed gas as described above. It is essential to know the composition of these feed streams, especially the presence of any components which may cause deactivation of the catalyst.

|                      |                    |            |                              |
|----------------------|--------------------|------------|------------------------------|
| Request No.:         | 022225             | Analyst:   | PJC                          |
| Charge No.:          | 00-3-8215.51.10.11 |            |                              |
| Notebook No.:        | 10975-99           |            |                              |
| Method No.:          |                    |            |                              |
| Phone Date:          | 31 May 1994        |            |                              |
| Sample Receipt Date: | 01 March 1994      | Doc. Name: | s:\reports\1400\1432scha.doc |



## ANALYTICAL PROCEDURES:

A Hewlett-Packard 5890 Series II Refinery Gas Analyzer (RGA) was used for the quantitative analysis of oxygen/argon, nitrogen, carbon monoxide, carbon dioxide and the C1 to C6 hydrocarbons. An external standardization procedure was used for quantitation. The standards and samples were introduced into the gas chromatograph at atmospheric pressure using a gas sampling manifold interfaced to a vacuum system and a ballast cylinder system. The chromatographic conditions used for this analysis are listed in Table 2. Representative chromatograms are shown in Figures 1 and 2.

The quantitative analysis for hydrogen was performed on a Hewlett-Packard 5890A gas chromatograph using nitrogen carrier gas. An external standardization procedure was used for quantitation. The chromatographic conditions used for this analysis are listed in Table 3.

The sample was also analyzed on a DB-WAX FSOT capillary column interfaced to a flame ionization detector for determination of any additional organic compounds. Quantitation was obtained using an external standardization procedure with a detector response factor determined for methanol. The chromatographic conditions are listed in Table 4. The chromatogram shown in Figure 3 illustrates the elution order and retention times for a number of potential components of interest. A representative chromatogram of the "Purge Gas from the MeOH Plant" is shown in Figure 4.

## RESULTS AND DISCUSSION:

The concentration values reported for each sample in Table 1 have been normalized to 100% accountability. The total accountabilities for the samples identified as "Inlet Feed to MeOH Plant" and "Purge Gas from MeOH Plant" were very close to 100% prior to normalization. However, the total accountability for the sample identified as "CO Feed to AC2O Plant" was quite low due to residual helium being present in the sample cylinder. The sample cylinders were initially filled with helium [and vented to atmospheric pressure prior to shipment to Eastman Chemical for filling]. During sampling, Eastman pressurized the cylinder with the process stream, vented the cylinder to atmospheric pressure and then refilled with the process stream. Apparently the process pressure for the latter sample was inadequate to completely purge all residual helium from the sample cylinder.

Table 1

| Component       | Retention Time (min.) | Sample Composition (mole percent) |                           |                           |
|-----------------|-----------------------|-----------------------------------|---------------------------|---------------------------|
|                 |                       | CO Feed to AC2O Plant             | Inlet Feed to MeOH Plant  | Purge Gas from MeOH Plant |
| hydrogen        |                       | 1.8 (0.02)<br>[2 %]               | 68.36 (0.014)<br>[67.8 %] | 82.26 (0.45)<br>[74 %]    |
| oxygen/argon    | 7.76                  | 0.35 (0.001)                      | 0.14 (0.0009)             | 1.36 (0.001)              |
| nitrogen        | 10.08                 | 0.83 (0.004)<br>[1 %]             | 0.35 (0.0018)<br>[0.5 %]  | 3.63 (0.006)<br>[12 %]    |
| carbon monoxide | 16.02                 | 97.0 (0.08)<br>[97 %]             | 26.56 (0.025)<br>[27.7 %] | 7.94 (0.041)<br>[11 %]    |
| carbon dioxide  | 3.95                  | N.D. (< 0.0010)                   | 4.50 (0.029)<br>[4.0 %]   | 3.96 (0.015)<br>[3 %]     |
| methane         | 4.45                  | 0.044 (0.001)                     | 0.062 (0.0004)            | 0.73 (0.004)              |
| ethane          | 5.34                  | N.D. (< 0.00005)                  | 0.00035 (0.00004)         | 0.0082 (0.0001)           |
| ethylene        | 6.58                  | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.00008 (0.00001)         |
| propane         | 9.34                  | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.0034 (0.00005)          |
| propylene       | 13.47                 | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | < 0.0001                  |
| iso-butane      | 15.64                 | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.00014                   |
| n-butane        | 16.31                 | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.0011 (0.00004)          |
| iso-pentane     | 21.90                 | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.00012 (0.00001)         |
| n-pentane       | 22.43                 | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.00034                   |
| n-hexane        | 28.1                  | N.D. (< 0.00005)                  | N.D. (< 0.00005)          | 0.00014 (0.00001)         |
| acetylene       |                       | N.D.                              | N.D.                      | N.D. (phase converter)    |
| methanol        |                       | N.D. (< 0.00005)                  | 0.032 (0.004)             | 0.10 (0.006)              |

How much  
O<sub>2</sub> ?  
→ clearly not Argon.

NOTE: The results above are reported in the format X ( S ) where X is the average of two determinations and S is the standard deviation of the analysis.

The expected compositions for the primary components, as provided by Eastman Chemical, are included in brackets [ ] below each reported concentration.

Table 2

Gas Chromatographic Conditions for Instrument: Hewlett-Packard 5890 Series II Refinery Gas Analyzer

Columns:

*Analysis of Inerts* - Chrompack 25 meter x 0.53 mm ID Molsieve 5A PLOT fused silica capillary column; Chrompack 27.5 meter x 0.53 mm ID PoraPLOT Q PLOT fused silica capillary column.

*Analysis of Hydrocarbons* - Chrompack 50 meter x 0.32 mm ID AL203/KCL PLOT fused silica capillary column.

Oven Temperature Program:

|                     |          |                     |          |
|---------------------|----------|---------------------|----------|
| Initial Temperature | 40 °C    | Final Temperature   | 180 °C   |
| Initial Time        | 6 min    | Final Time          | 16.5 min |
| Program Rate        | 8 °C/min | Total Analysis Time | 40.0 min |

Carrier Gas: Helium

|                                 |            |                       |            |
|---------------------------------|------------|-----------------------|------------|
| Flow Rate (Molsieve/PoraPLOT Q) | 5.5 mL/min | Flow Rate (AL203/KCL) | 1.3 mL/min |
| Column Headpressure             | 16 psig    | Column Headpressure   | 12 psig    |
| Splitter Flow Rate              | 30 mL/min  |                       |            |

Detector Type: Thermal Conductivity/Flame Ionization

|                              |                 |
|------------------------------|-----------------|
| Detector Temperature         | 200 °C / 200 °C |
| TCD Reference Flow           | 15.7 mL/min     |
| FID Hydrogen                 | 30 mL/min       |
| FID Air                      | 360 mL/min      |
| Valve / Injector Temperature | 120 °C          |

Injection Mode \ Volume: Valco gas sampling valves / 1 mL at atmospheric pressure

Data System: Hewlett-Packard 3396 integrator (Stored HP Method RGA)  
PE-Nelson Turbochrom Data System (Stored Methods RGA\_TCD and RGA\_FID)

Calibration Standards: External Standardization

Standard No. 2 - 0.1970 mole % oxygen/argon, 0.1080 mole % nitrogen, 0.1031 mole % carbon monoxide, 0.0963 mole % methane

Standard No. 8 - 74.3 mole % carbon monoxide, 25.7 mole % methane

Standard No. 33 - 37.0 mole % hydrogen, 0.50 mole % oxygen, 0.50 mole % nitrogen, 0.50 mole % carbon monoxide, 0.50 mole % carbon dioxide, 46.0 mole % methane, 10.0 mole % ethane, 1.0 mole % ethylene, 2.0 mole % propane, 0.15 mole % propylene, 0.7 mole % isobutane, 0.7 mole % n-butane, 0.5 mole % isopentane

Scotty Standard No. 100 - 16.3 mole ppm methane, 15.3 mole ppm ethane, 16.7 mole ppm ethylene, 21.2 mole ppm propane, 12.3 mole ppm propylene, 16.6 mole ppm n-butane

Table 3

Gas Chromatographic Conditions  
(hydrogen)

Instrument: Hewlett-Packard 5890A Gas Chromatograph

Columns: 10 ft. x 1/8-inch OD nickel column packed with 60/80 mesh Activated Charcoal

Oven Temperature Program:

|                     |           |
|---------------------|-----------|
| Initial Temperature | 40 °C     |
| Initial Time        | 4 min     |
| Program Rate        | 10 °C/min |
| Final Temperature   | 120 °C    |
| Final Time          | 1 min     |
| Total Analysis Time | 13.0 min  |

Carrier Gas: Nitrogen

|                     |           |
|---------------------|-----------|
| Flow Rate           | 22 mL/min |
| Column Headpressure | 22 psig   |

Detector Type: Thermal Conductivity

|                              |           |
|------------------------------|-----------|
| Detector Temperature         | 200 °C    |
| TCD Reference Flow           | 33 mL/min |
| Valve / Injector Temperature | ambient   |

Injection Volume: 1 mL at atmospheric pressure

Injection Mode: Valco gas sampling valve

Data System: Hewlett-Packard 3396 integrator / PE-Nelson Turbochrom Data System

Quantitation Method: External Standardization

Calibration Standard: Standard No. 16 - 5.01 mole % hydrogen  
Standard No. 17 - 39.5 mole % hydrogen  
Standard No. 18 - 60.0 mole % hydrogen

Table 4

Gas Chromatographic Conditions for Instrument: Hewlett-Packard 5890A

Column: J&W Scientific DB-WAX FSOT capillary, 30 m x 0.32 mm ID, 0.5 micron film thickness  
Column No. 196

Oven Temperature Program

|                     |          |
|---------------------|----------|
| Initial Temperature | 40 °C    |
| Initial Time        | 10 min   |
| Program Rate        | 8 °C/min |
| Final Temperature   | 160 °C   |
| Final Time          | 5 min    |
| Total Time          | 30.0 min |

Carrier Gas Helium

|                      |             |
|----------------------|-------------|
| Flow Rate            | 1.8 mL/min  |
| Carrier Gas Velocity | 27.3 cm/sec |
| Column Headpressure  | 9.2 psig    |
| Splitter Flow Rate   | 20 mL/min   |

Injector Temperature 150 °C

Injection Mode / Volume gas-tight syringe / 1.0 cc at atmospheric pressure

Detector Type Flame Ionization

|                           |            |
|---------------------------|------------|
| Detector Temperature      | 200 deg C  |
| Amplifier / Range Setting | 0          |
| Hydrogen                  | 30 mL/min  |
| Air                       | 300 mL/min |
| FID Make-up               | 28 mL/min  |

Quantitation Method External Standardization

Figure 1 PURGE GAS FROM MEOH PLANT

RGA Analysis - TCD





Figure 2 PURGE GAS FROM MEOH PLANT

RGA Analysis - FID






FIGURE 3. Elution Order of Organic Compounds on DB-WAX Capillary Column




FIGURE 4. "Purge Gas from MeOH Plant" on DB-WAX Capillary Column



RECEIVED

Analysis Report

MAY 05 1994



To: E. S. Schaub /*cmc* <sup>PROCESS ENGINEERING</sup> Dept./Loc.: PSG Eng. / A12A3  
From: S. A. Gardner *SAG* Dept./Ext.: CRSD / 4637  
Date: 2 May 1994 Lab Name: Spectroscopy  
Subject: Infrared Analysis of Gas Cylinders from Eastman Chemical  
Sample No.: Inlet Feed to MeOH Plant; CO Feed to AC20 Plant; Purge Gas from MeOH Plant

c: P. J. Clark; E. J. Karwacki; F. A. Lucrezi; D. R. Latshaw/IR Lab

SUMMARY:

Three cylinders of gas sampled at Eastman Chemical's Kingsport, TN facility were submitted for infrared analysis to determine their composition. The Inlet Feed to MeOH Plant sample contained percent levels of CO and CO<sub>2</sub>, as well as a significant amount of CH<sub>4</sub>. A small amount of C<sub>2</sub>H<sub>6</sub> was also present. The CO Feed to AC20 Plant sample contained percent levels of CO and a significant amount of CH<sub>4</sub>. The Purge Gas from MeOH Plant sample was found to contain percent levels of CO and CO<sub>2</sub>, as well as a significant amount of CH<sub>4</sub>. The spectra were specifically examined for the presence of HCN, SO<sub>2</sub>, HCl, NO, NO<sub>2</sub>, N<sub>2</sub>O and NH<sub>3</sub>. No indications for the presence of these compounds were observed. Ammonia is a very strong absorber in the infrared. Its lower detection limit (LDL) was estimated to be in the ppb range. The LDLs for the remaining compounds were estimated to be 1 ppm. However, CO and CH<sub>4</sub> present in the samples would interfere with SO<sub>2</sub>, HCl and N<sub>2</sub>O bands, thus significantly raising the LDLs for these compounds in the samples. Copies of spectra are attached for your reference.

ANALYTICAL PROCEDURES:

A portion of each sample was drawn into an evacuated 9.3 meter pathlength gas cell in a Nicolet 8220 FT-IR gas analyzer. The Inlet Feed to MeOH Plant and Purge Gas from MeOH Plant samples were also analyzed in a one inch pathlength cell to bring the CO, CO<sub>2</sub> and CH<sub>4</sub> bands onto scale. All spectra were obtained by co-adding 150 scans at 2.0 cm<sup>-1</sup> resolution and were referenced against a background of the evacuated cells.

Request No.: 022225  
Charge No.: 00-3-8215.51.10.11  
Notebook No.: 14094-10  
Method No.: none  
Print Date: 5/2/94  
Sample Receipt Date: 4/28/94  
Spectra No: 17253-17262; 17264; 17266-17270

Figure 1

17281

22225.01 / INLET FEED MEOH.PLT / 759.8 TORR / 9.3 M CELL 28 APR 94 14:53:18

7.9980

6.6851

5.3322

3.9993

2.6664

1.3335

0.0006

Absorbance

Wavenumber (cm<sup>-1</sup>)

4000.0 3400.0 2800.0 2200.0 1800.0 1500.0 1200.0 800.00 400.00

5000




Figure 2

2225.01 / INLET FEED MEOH FLT / 1 INCH CELL / 759.5 TORR 29 Apr 94 08:43:00

17255

Absorbance  
0.0005  
0.1943  
0.3881  
0.5819  
0.7757  
0.9695  
1.1633

Wavenumber (cm-1)  
4000.0  
3400.0  
2800.0  
2200.0  
1800.0  
1500.0  
1200.0  
900.0  
400.00




Figure 3

8.0060

6.6716

5.3373

Absorbance

3.0029

2.6686

1.3342

0.0001

22225.02 / CO FEED TO AC20 PLT / 759.1 TORR / 9.3 M CELL 28 APR 84 14:26:12

JP250

915




Fig 2 4


17289

2225.03 / PURGE GAS MECH FLT / 759.4 TORR / 9.3 M CELL / 29 APR 94 13:00:03

Absorbance  
0.0002 1.3325 2.6652 3.9979 5.3306 6.6633 / 9960

4000.0 3400.0 2800.0 2200.0 1800.0 1500.0 1200.0 900.00 400.00  
Wavenumber (cm<sup>-1</sup>)

SA15



17287

22225.03 / PURGE GAS MECH PLOT / 1 INCH CELL / 759.7 TORR / 29 APR 94 12:24:34

Figure 5

Absorbance  
0.0002 0.1734 0.3469 0.5205 0.6941 0.8677 1.0412

4000.0 3400.0 2500.0 2200.0 1800.0 1500.0 1200.0 900.00 400.00  
Wavenumber (cm<sup>-1</sup>)

5A15




Figure 6

3871

VAPOUR-PHASE LIBRARY - 6/89: CARBON MONOXIDE

Absorbance  
0.0000  
0.1665  
0.3330  
0.4995  
0.6660  
0.8325  
0.9990

4000.0 3400.0 2800.0 2200.0 1800.0 1500.0 1200.0 900.00 400.00  
Wavenumber (cm-1)





Figure 7

VAPOUR-PHASE LIBRARY - 6/89: CARBON DIOXIDE

3673






*Polys 87*

VAPOR-PHASE LIBRARY T-6/89: METHANE

Absorbance  
0.0000  
0.1685  
0.3330  
0.4995  
0.6660  
0.8325  
0.9990

4000.0 3400.0 2800.0 2200.0 1800.0 1500.0 1200.0 900.00 400.00  
Wavenumber (cm<sup>-1</sup>)




*Trace 9*

VAPOR PHASE LIBRARY - 6/89:ETHANE

Absorbance  
0.0000 0.1885 0.3330 0.4995 0.6660 0.8325 0.9990

4000.0 3400.0 2800.0 2200.0 1800.0 1600.0 1200.0 900.00 400.00  
Wavenumber (cm<sup>-1</sup>)



4091


VAPOR-PHASE LIBRARY - 6/89: HYDROGEN CYANIDE

Hydric 10

Absorbance  
0.0000  
0.1555  
0.3330  
0.4995  
0.6660  
0.8325  
0.9990

4000.0  
3000.0  
2000.0  
1800.0  
1500.0  
1200.0  
900.00  
400.00

Wavenumber (cm<sup>-1</sup>)



Analysis Report

RECEIVED

Bos/CC/Fl  
JMS  
KRB-man only



T E. S. Schaub MAR 11 1994 Dept/Loc.: Proc. Eng.  
 From: P. A. Clark PROCESS ENGINEERING Dept/Ext.: CRSD/R3111 4870  
 Date: 8 March 1994 Lab Name: Surface Science  
 Subject: TOF-SIMS of Methanol Catalyst Materials  
 Sample No.: X20602-130-A (fresh), X20602-130-B (spent 1989), X20602-130-C (spent 1993)

cc: P. J. Clark, F. A. Lucrezi, <sup>c.M. Chen</sup> ~~J. T. Cheng~~

SUMMARY:

Time-of-Flight Secondary Ion Mass Spectrometry has been used to characterize the surface composition of three samples of a liquid phase methanol catalyst. This catalyst is currently being evaluated by Tennessee Eastman. We have examined the fresh catalyst, a sample of spent catalyst from 1989, and a sample of spent catalyst from 1993. The TOF-SIMS analyses were conducted to confirm the presence of impurity species previously observed in XPS analyses (conducted by Tennessee Eastman's analytical group).

PROBLEM DEFINITION:

Analysis of surface impurities present on a spent liquid phase methanol catalyst.

4/8/94 Call from Paul Clark  
 Fluorine: Not detected on { fresh cat.  
{ 1993 spent cat.  
 (Ref Fig. 10)  
 Detected on 1989 spent cat. (weak signal → small amt)  
 @ 19

Request No.: 021469  
 Charge No.: 00-3-8215.51.10.11  
 Notebook No.: 13927-46  
 Method No.: NONE  
 Done Date: 2/24/94  
 Sample Receipt Date:  
 Spectra No: CE&A Tape 2-94 (2)

Lab File Name: Clark, P. A.  
 Analyst: PAC  
 Data Analyzed: 2/24/94  
 Data Captured: 2/94  
 Data Reported: 2/25/94  
 Doc. Name: 21469.doc

ANALYTICAL PROCEDURES:

T. TOF-SIMS experiments were conducted by F. Radicati di Brozolo of Charles Evans and Associates, Redwood City, CA. The analyses were conducted on a Charles Evans & Associates TFS TOF-SIMS unit. The TOF-SIMS experiment is explained in Attachment 1.

RESULTS AND DISCUSSION:

Table 1 provides a summary of the elements detected by TOF-SIMS. In addition, the chemical form of the species is also included in Table 1. The TOF-SIMS analysis detected As, S, N, Fe, Cl, Na, Cr, K, and Ca.

Table 1  
Elements Detected in TOF-SIMS Analysis

| Element | Fresh Catalyst | Spent Catalyst ('89) | Spent Catalyst ('93) | Species Detected   |
|---------|----------------|----------------------|----------------------|--|
| As      | YES            | YES                  | YES                  | AsO <sup>+</sup> , AsO <sup>-</sup> , AsO <sub>2</sub> <sup>-</sup> , AsO <sub>3</sub> <sup>-</sup>                        |
| S       | YES            | YES                  | YES                  | SO <sub>2</sub> <sup>-</sup> , SO <sub>3</sub> <sup>-</sup> , SO <sub>4</sub> <sup>-</sup> , HSO <sub>4</sub> <sup>-</sup> |
| N       | YES            | YES                  | YES                  | CN <sup>-</sup> , NO <sub>3</sub> <sup>-</sup> , C <sub>3</sub> H <sub>8</sub> N <sup>+</sup>                              |
| Fe      | ND             | YES                  | YES                  | Fe <sup>+</sup>  |
| Ni      | ND             | yes (trace ?)        | ND                   |  |
| Ba      | ND             | ND                   | ND                   |  |
| Cl      | YES            | YES                  | YES                  | Cl <sup>-</sup>  |
| Co      | ND             | ND                   | ND                   |  |
| Na      | YES            | YES                  | YES                  | Na <sup>+</sup>  |
| Se      | ND             | ND                   | ND                   |  |
| Cr      | YES            | ND                   | ND                   | Cr <sup>+</sup>  |
| B       | ND             | ND                   | ND                   |  |
| Be      | ND             | ND                   | ND                   |  |
| K       | ND             | YES                  | YES                  |  |
| Ag      | ND             | ND                   | ND                   |  |
| Tl      | ND             | ND                   | ND                   |  |
| Ca      | YES            | YES                  | YES                  | Ca <sup>+</sup>  |

interesting →

ND, Not Detected

The relative distributions of certain species are summarized in Table 2.

While TOF-SIMS is not quantitative, we can make relative comparisons among the samples (i.e., normalize the positive ion signal intensities to Al<sup>+</sup> and the negative ion signal intensities to <sup>63</sup>Cu<sup>-</sup>).

We can use relative comparisons to ascertain if a particular species is increasing in intensity (relative to the fresh catalyst) during activation.

Table 2  
Distributions of Fe<sup>+</sup>, Ni<sup>+</sup>, Ca<sup>+</sup>, K<sup>+</sup>, and Na<sup>+</sup> Normalized in Al<sup>+</sup>  
and Distributions of CN<sup>-</sup>, NO<sub>3</sub><sup>-</sup>, SO<sub>3</sub><sup>-</sup>, and AsO<sub>2</sub><sup>-</sup> Normalized to Cu-  
For Fresh Catalyst, Spent Catalyst From 1989, and  
Spent Catalyst From 1993

|                                  | Fresh Catalyst | Spent Catalyst (89) | Spent Catalyst (93) |
|----------------------------------|----------------|---------------------|---------------------|
| Fe/Al                            | ND             | 0.33                | 0.016               |
| Ni/Al                            | ND             | 0.015               | ND                  |
| Ca/Al                            | 0.0088         | 0.63                | 0.016               |
| K/Al                             | ND             | 0.10                | 0.011               |
| Na/Al                            | 0.22           | 0.71                | 0.29                |
| Cr/Al                            | 0.16           | ND                  | ND                  |
| C <sub>3</sub> H <sub>8</sub> N* | ND             | ND                  | 0.0054              |
| CN/Cu                            | 8.2            | 7.7                 | 3.3                 |
| NO <sub>3</sub> /Cu              | 3.5            | 0.91                | 0.13                |
| SO <sub>3</sub> /Cu              | 1.7            | 7.2                 | 1.0                 |
| AsO <sub>2</sub> /Cu             | 0.12           | 1.9                 | 8.9                 |
| Cl/Cu                            | 14             | 23                  | 15                  |

Can only make qualitative comparison for a particular species (by fresh vs. spent cat.)  
much less

sig.?

interesting →

SIMS analysis may fragment amine → CN<sup>-</sup>.  
more if CN<sup>-</sup> was orig. present.  
Dennis Brown also questioned if  
H<sub>2</sub>N<sup>+</sup> fragmenting to give amine.

\* Other amine type species summarized in Table 3.

N<sup>-</sup> Not Detected

Table 3  
Amine Species Detected On Surface of 1993 Spent Catalyst

| <u>Nominal Mass</u> | <u>Secondary Ion</u>                         | <u>Measured Mass</u> | <u>Deviation (mamu)</u> |
|---------------------|--|----------------------|-------------------------|
| 30m/z               | CH <sub>4</sub> N <sup>+</sup>               | 30.030               | 4                       |
| 38                  | C <sub>2</sub> N <sup>+</sup>                | 38.013               | -11                     |
| 56                  | C <sub>3</sub> H <sub>6</sub> N <sup>+</sup> | 56.052               | -3                      |
| 58                  | C <sub>3</sub> H <sub>8</sub> N <sup>+</sup> | 58.063               | 2                       |

Iron, nickel, and potassium were not detected on the fresh catalyst, but did appear after the catalyst was activated. The level of Fe contamination is higher on the 1989 spent catalyst sample than on the 1993 sample. Nickel also appears as a contaminant on the 1989 spent catalyst, but does not appear on the 1993 sample. Potassium is detected in higher amounts on the spent catalyst for 1989 than the 1993 sample.

The levels of Na<sup>+</sup>, SO<sub>3</sub><sup>-</sup>, and Cl<sup>-</sup> contamination were highest on the spent catalyst from 1989. The Na<sup>+</sup>, SO<sub>3</sub><sup>-</sup>, and Cl<sup>-</sup> levels in the 1993 spent catalyst were nearly equivalent to the levels present on the fresh catalyst. Based upon these observations, the catalyst does not pick up additional amounts of Na<sup>+</sup>, SO<sub>3</sub><sup>-</sup>, and Cl<sup>-</sup> from the gas stream during activation.

The levels of Cr<sup>+</sup>, CN<sup>-</sup>, and NO<sub>3</sub><sup>-</sup> appear to decrease after activation. Only the level of As increases after activation. Moreover, there appears to be more As contamination on the 1993 spent catalyst than on the 1989 catalyst sample.

A series of amine type species are present on the surface of the 1993 spent catalyst (see Figures 1 - 4, attached). We observe CH<sub>4</sub>N<sup>+</sup> at 30.030m/z, C<sub>2</sub>N<sup>+</sup> at 38.013m/z, C<sub>3</sub>H<sub>6</sub>N<sup>+</sup> at 56.052m/z, and C<sub>3</sub>H<sub>8</sub>N<sup>+</sup> at 58.063m/z. The corresponding secondary ion structures and mass deviations are summarized in Table 3.

Higher mass species appearing at 103m/z, 105m/z, 107m/z, and 119m/z in the positive ion SIMS spectra are most likely organic type species: C<sub>8</sub>H<sub>7</sub><sup>+</sup>, C<sub>7</sub>H<sub>3</sub>O<sup>+</sup> (102.96m/z), C<sub>8</sub>H<sub>9</sub><sup>+</sup>, C<sub>7</sub>H<sub>5</sub>O<sup>+</sup> (104.95m/z), C<sub>8</sub>H<sub>11</sub><sup>+</sup>, C<sub>7</sub>H<sub>7</sub>O<sup>+</sup> (106.95m/z), and C<sub>9</sub>H<sub>11</sub><sup>+</sup>, C<sub>7</sub>H<sub>13</sub>O<sup>+</sup> (118.99m/z and 57mamu deviation).

All the positive and negative ion TOF-SIMS spectra are attached (Figures 4 - 14).

Please feel free to contact me if you require additional information.


Paula  
Paula A. Cornelio Clark

v. mail. from  
Paula Clark

olefinic moieties  
(unsat'd C=C bonds)  
also present on fresh catalyst.  
"adventitious carbons" - normally present  
on inorganic moieties

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2    DATE : 10 Feb 94 14:25    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 1211701  
 APCI/CLARK; SAMPLE X-20602-130-A;    FIRST PELLETT; SPOT 1  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 112  
 DATA SET: 1 Spectra; 5 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI


FILE NAME: FEB15P6    DATE : 15 Feb 94 12:55    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 376308  
 APCI/CLARK; SAMPLE X-20602-130-B;    PELLETT 3  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FILE NAME: FEB15P10    DATE : 15 Feb 94 14:40    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C;    PELLETT 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI



CHARLES EVANS & ASSOCIATES

101 Chesapeake Drive  
 Redwood City, CA 94061 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2 DATE : 10 Feb 94 14:25 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 1211701  
 APCI/CLARK; SAMPLE X20602-130-A; FIRST PELLET; SPOT 1  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 312  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI


FILE NAME: FEB15P8 DATE : 15 Feb 94 12:55 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 376308  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLET 1  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15P10 DATE : 15 Feb 94 14:40 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLET 2  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FIGURE \_\_\_\_\_

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2    DATE : 10 Feb 94 14:25    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 1211701  
 APCI/CLARK; SAMPLE X-20602-130-A;    FIRST PELLET; SPOT 1  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 312  
 DATA SET: 1 Spectra; 5 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI


FILE NAME: FEB15P8    DATE : 15 Feb 94 12:55    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 376338  
 APCI/CLARK; SAMPLE X-20602-130-B;    PELLET 3  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FILE NAME: FEB15P10    DATE : 15 Feb 94 14:40    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C;    PELLET 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FIGURE \_\_\_\_\_

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921




FILE NAME: FEB10P2 DATE : 10 Feb 94 14:25 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 1211701  
 APCI/CLARK; SAMPLE X20602-130-A; FIRST PELLETT; SPOT 1  
 + ICNS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 312  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15P8 DATE : 15 Feb 94 12:55 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 376308  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLETT 3  
 + ICNS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15P10 DATE : 15 Feb 94 14:40 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLETT 2  
 + ICNS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2 DATE : 15 Feb 94 9:24 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 596754  
 APCI/CLARK; SAMPLE X20602-130-A; PELLET 2  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop IDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI


FILE NAME: FEB15P8 DATE : 15 Feb 94 12:55 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 376108  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLET 3  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop IDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15P10 DATE : 15 Feb 94 14:40 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLET 2  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop IDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FIGURE \_\_\_\_\_

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2    DATE : 15 Feb 94 9:24    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 596754  
 APCI/CLARK; SAMPLE X20602-130-A; PELLETT 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI


FILE NAME: FEB15P9    DATE : 15 Feb 94 12:55    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 376308  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLETT 3  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FILE NAME: FEB15P10    DATE : 15 Feb 94 14:40    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLETT 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FIGURE 3

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2    DATE: 15 Feb 94 9:24    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL: 596754  
 APCI/CLARK; SAMPLE X-20602-130-A; PELLETT 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI


FILE NAME: FEB15P8    DATE: 15 Feb 94 12:55    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL: 376138  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLETT 3  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FILE NAME: FEB15P10    DATE: 15 Feb 94 14:40    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL: 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLETT 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FIGURE 4

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4547; FAX: 369-7921




FILE NAME: FEB10P2 DATE: 15 Feb 94 9:24 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL: 595754  
 APCI/CLARK; SAMPLE X20602-130-A; PELLET 2  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15P8 DATE: 15 Feb 94 12:55 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL: 376108  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLET 3  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15P10 DATE: 15 Feb 94 14:40 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL: 2275670  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLET 2  
 + IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10P2    DATE : 15 Feb 94 9:24    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 596754  
 APCI/CLARK: SAMPLE X20602-130-A;    PELLET 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 125:  
 DATA SET: 1 Spectra; 5 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI


FILE NAME: FEB15P8    DATE : 15 Feb 94 12:55    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 376308  
 APCI/CLARK: SAMPLE X-20602-130-B;    PELLET 3  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 125:  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FILE NAME: FEB15P10    DATE : 15 Feb 94 14:40    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 2275670  
 APCI/CLARK: SAMPLE X-20602-130-C;    PELLET 2  
 + IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 125:  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI



CHARLES EVANS & ASSOCIATES

391 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921




FILE NAME: FEB10N2 DATE : 15 Feb 94 9:46 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 1149172  
 APCI/CLARK; SAMPLE I-20602-130-A; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 3 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB10N4 DATE : 15 Feb 94 10:18 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 574258  
 APCI/CLARK; SAMPLE I-20602-130-B; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15N10 DATE : 15 Feb 94 15: 3 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2532368  
 APCI/CLARK; SAMPLE I-20602-130-C; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921




FILE NAME: FES10N2 DATE : 15 Feb 94 9:46 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 1149172  
 APCI/CLARK; SAMPLE X-20602-130-A; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 3 Image(s) RASTER SIZE: 820µm RASTER TYPE: Pull NI

FILE NAME: FES10N4 DATE : 15 Feb 94 10:18 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 574258  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Pull NI

FILE NAME: FES10N10 DATE : 15 Feb 94 15:3 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2532368  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Pull NI

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921




FILE NAME: FEB10N2 DATE : 15 Feb 94 9:46 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 1149172  
 APCI/CLARK: SAMPLE X-20602-130-A; PELLETT 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 3 Image(s) RASTER SIZE: 820 $\mu$ m RASTER TYPE: Full NI

FILE NAME: FEB10N4 DATE : 15 Feb 94 10:18 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 574258  
 APCI/CLARK: SAMPLE X-20602-130-B; PELLETT 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820 $\mu$ m RASTER TYPE: Full NI

FILE NAME: FEB15N10 DATE : 15 Feb 94 15: J ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2532368  
 APCI/CLARK: SAMPLE X-20602-130-C; PELLETT 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-Stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820 $\mu$ m RASTER TYPE: Full NI

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921



FILE NAME: FEB10N2    DATE : 15 Feb 94 9:46    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 1149172  
 APCI/CLARK; SAMPLE X-20602-130-A; PELLETT 2  
 - IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250-  
 DATA SET: 1 Spectra; 3 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI


FILE NAME: FEB10N4    DATE : 15 Feb 94 10:18    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 574158  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLETT 2  
 - IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FILE NAME: FEB15N10    DATE : 15 Feb 94 15: 3    ACQUISITION TIME: 15.0 MIN.    TOTAL INTEGRAL : 2532368  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLETT 2  
 - IONS    PRIMARY GUN: LMIG    TIME RECORDER: 1-Stop TDC    X-Y SOURCE: Raster    TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s)    RASTER SIZE: 820µm    RASTER TYPE: Full NI

FIGURE

CHARLES EVANS & ASSOCIATES

301 Chesapeake Drive  
 Redwood City, CA 94063 USA  
 Phone: (415)-369-4567; FAX: 369-7921




FILE NAME: FEB10N2 DATE : 15 Feb 94 9:46 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 1149172  
 APCI/CLARK; SAMPLE X-20602-130-A; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 3 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB10N4 DATE : 15 Feb 94 10:19 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 574258  
 APCI/CLARK; SAMPLE X-20602-130-B; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 5 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

FILE NAME: FEB15N10 DATE : 15 Feb 94 15: 3 ACQUISITION TIME: 15.0 MIN. TOTAL INTEGRAL : 2532368  
 APCI/CLARK; SAMPLE X-20602-130-C; PELLET 2  
 - IONS PRIMARY GUN: LMIG TIME RECORDER: 1-stop TDC X-Y SOURCE: Raster TIME PER CHANNEL: 1250  
 DATA SET: 1 Spectra; 6 Image(s) RASTER SIZE: 820µm RASTER TYPE: Full NI

## Static Secondary Ion Mass Spectrometry (Static SIMS)

A schematic diagram of the Static SIMS experiment is shown below:



In this experiment, a sample (under vacuum) is bombarded by a primary ion beam (Ar, Xe, Ga, or Cs). The ion implants in the solid lattice and generates an area of perturbation known as a collision cascade. This collision cascade results in the desorption of positively and negatively charged secondary ions, neutral species, and electrons. The positive and negative secondary ions are then extracted from the gas phase and mass analyzed in a time-of-flight based mass analyzer.

When the SIMS experiment is conducted under static conditions, the primary ion beam current density is reduced so as to promote the desorption of intact molecular species. Thus, Static SIMS can provide unambiguous identification of species at the sample surface.

Currently, the Static SIMS data are collected on a Charles Evans & Associates TFS SIMS instrument located at Charles Evans & Associates in Redwood City, CA. Data analysis is conducted in house, using a TFS SIMS computer workstation located in the CRSD-Surface Science Laboratory (R&D3/D155).

# APPENDIX J

LPMEOH REACTOR STUDY

To: N. R. Shaub Dept/Ext. Facilities Svcs./X6534  
From: T.A. Dahl Dept/Ext. GETC/X6361  
Date: May 10, 1995  
Subject: Field Test Unit (FTU) at Iron Run.

---

CC: D.M. Brown Dept/Loc. PSG Tech/A31E2  
B.A. Toseland Dept/Loc. GETC/I7066

Unit Summary:

The Field Test Unit (FTU) will be contained in a 48 foot trailer consisting of office and laboratory space. The Unit will process Synthesis Gas, by passing it through several adsorption beds to remove trace impurities from the gas stream. The gas is piped to a Slurry Phase Reactor where a percentage of the Gas is converted to Alcohol's. The reactor effluent is analyzed by G.C., then vented to atmosphere.

The process Gas enters the Lab portion of the trailer at approximately 800psig. It can then be reduced by a regulator or increased by a compressor. When the gas is at the desired pressure, Maximum of 1300psig, it then passes through the adsorber system to remove any impurities in the gas stream. The clean gas is then piped to the reactor system, here again the pressure can be either increased or decreased as necessary. The reactor will operate at pressures to 1300psig and temperatures to 670 F. The product of the reactor is analyzed then vented to an exhaust stack. No product will be produced.

An excess flow valve in the process gas feed line just inside the lab wall, limits the feed gas to a maximum of 15 liters / minute = 0.5298 cubic feet / minute or 31.8 cubic feet / hour. Pressure switches and relief valves are installed in the system to prevent over pressurization.

The exhaust gas flow will be sufficient to dilute the vented product gas to a non hazardous level. Flammable and toxic gas monitors are located in the trailer. These monitors will cause the system to shut down if an unsafe condition should occur.

NFPA Rating of this laboratory:

Fire-4

Health-2

Reactivity-1

Emergency assessment on the above rating, as well as the Unit's hazards review, will be available upon request.

---

T.A. Dahl

Protec



Memorandum

PRODUCTS

---

To: T. A. Dahl Dept/Loc.: G&E Tech. Center, I7066  
From: Kevin B. Snyder Kevin Dept/Ext.: EH&S, TT Area Facilities  
Date: 23 August 1995  
Subject: **Minor Source Determination for Methanol Synthesis Field Test Unit,  
Microclave System and Autoclave System**

---

c: J. A. Berseth (A6121)/File 3.0.3  
T. E. Solodar (A33G1)  
R. W. Skinner (A6126)

Pennsylvania's Department of Environmental Protection (DEP) has determined that your methanol synthesis sources at Iron Run are exempted from requiring a construction or operating permit because they are all minor sources of contamination. If the quantities of pollutants emitted change because of a change in the process or there is an increase in the hours of operation, please let me or Ron Skinner know.

A copy of the three minor source approvals are attached for your records.

**Attachments**

\\n\Documents\Snyder\JD02306

COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL RESOURCES  
BUREAU OF AIR QUALITY CONTROL

COUNTY:

JUL 27 1995  
CITY:  
STATE:

Request for Determination of Requirement  
for Plan Approval/Operating Permit Application  
(Submit In Triplicate)

Type of Source: Methanol Synthesis

Date of Installation: 7/95

Owner of Source: Air Products & Chemicals, Inc.

Employer I.D. No.: 23-1274955

Mailing Address: P.O. Box 25780, Lehigh Valley, PA 18002-5780 (Iron Run)

Contact Person: Kevin B. Snyder

Telephone: 610-481-6238

Location of Source(s):

Street Address: 7066 Snowdrift Road

Municipality: Upper Macungie Township

Estimated Emissions: Field Test Unit (FTU)

County: Lehigh

| Pollutant       | CO     | H <sub>2</sub> | CO <sub>2</sub> | N <sub>2</sub> | Methanol | Di-Methyl Ether |
|-----------------|--------|----------------|-----------------|----------------|----------|-----------------|
| Quantity lbs/hr | 0.33   | 0.015          | 0.13            | 0.0083         | 0.085    | 0.068           |
| Quantity s/yr   | 1900.8 | 86.4           | 748.8           | 47.8           | 489.6    | 391.7           |

Thomas A. Dahl  
Signature Thomas A. Dahl

Research Specialist  
Title

7/19/95  
Date

1. Averaged 20 days per month, 24 hrs. per day

OFFICIAL USE ONLY

Date Received: \_\_\_\_\_

Reviewed By: Mark J. Wagner

Pursuant to the authority contained in 25 PA Code §127.1418) the source(s) is exempted from the plan approval and permitting requirements. This determination does not exempt the source(s) from compliance with all other applicable air quality regulations.

The source(s) does not qualify for exemption from plan approval/permitting requirements under PA Code §127.1418) and plan approval application(s) must be submitted. The Department is prohibited from acting on an application until 30 days after the municipality and county have received notification by the company. Pertinent forms are attached.

[Signature]  
CHIEF - ENGINEERING SERVICES SECTION

Signature

Title

Date

AUG 16 1995

(Over)

Field Test Description

The Field Test Unit (FTU) processes synthesis gas, by passing it first through several adsorption beds to remove trace impurities. The gas is then piped to a 300 cc Autoclave Reactor which converts a percentage of the gas to Methanol and Dimethyl Ether. The Reactor effluent is analyzed by Gas Chromatograph, then vented to atmosphere thru a vent stack. The vent stack is 20 feet high, with 1000 ft<sup>3</sup> per minute air flow. For safety reasons, the process gas is shut off at the source if air flow is lost in the vent stack.


---

OFFICIAL USE ONLY

Remarks:


Recycled Paper 

FIELD TEST UNIT  
GAS FEED SYSTEM



I.A.D. 5/16/95


FIELD TEST UNIT  
ADSORBER SYS.



N2


T.A.D. 5/19/95

FIELD TEST UNIT  
AUTOCLAVE SYS.




T.A. DAHL  
5/23/95

FIELD TEST UNIT  
GC GAS SYSTEM




1.A.D. 5/25/95  
FIELD TEST UNIT  
SHEET 4 OF 6



T.A.D. 5/24/95  
FIELD TEST UNIT  
SHEET 5 OF 6

FTUPDGC





T.A.D. 5/24/95  
FIELD TEST UNIT  
SHEET 6 OF 6

FTUBUGC

**Memorandum**

To: Tom Dahl Dept./Loc.: PS&E Res. / I7066  
From: Dean Chin-Fatt Dept./Ext.: CRSD-ATC RD3 / X3666  
Date: 6 April 1994 Separations Laboratory  
Subject: Gas Chromatographic Equipment for Mobile Trailer

cc: CS File; P.J. Clark; A.J. Di Gioia; LB File

Enclosed is the equipment cost for the gas chromatographs required for the new mobile trailer. From the meeting on 21 March, 1995, it had been decided that the new chromatographs should be configured to do the same gas analyses as done by the GCs in the previous trailer. However, some additional requirements were added. First, the data acquisition is to be done by PE Nelson Turbochrom (similar to the system used in Lab 17). Second, the PID used to do the sulfur analysis in the old system is no longer a viable method to do this analysis, a new detector needed to be found to do low levels of sulfur. Lastly, due to limited space it was desired not to have integrators and to have all data acquisition and valve control through PE Nelson Turbochrom.

The following systems should meet the above requirements. The "Poisons GC" will be an HP-6890 GC with one electronic pressure controlled (EPC) packed injector and the appropriate valving to do simultaneous injections of the sample onto two columns. One column will be interfaced to an Hewlett-Packard Electron Capture Detector (ECD) to do the nickel and iron carbonyls and the other column to a Sievers Sulfur Chemiluminescence Detector (SCD) to do trace sulfur analysis. The SCD will monitor carbonyl sulfide, hydrogen sulfide and sulfur dioxide to 0.03 mg/L.

The second "Bulk Gas GC" will be another HP-6890 GC with two thermal conductivity detectors (TCD), one flame ionization detector (FID) with full EPC. The FID will be configured to do hydrocarbon analysis or alcohols. The first TCD analyzes for carbon dioxide, oxygen, nitrogen, methane and carbon monoxide. The lower limit for all components is 200 ppm except for carbon monoxide which is 400 ppm. The second TCD detects hydrogen to a lower detection limit of 100 ppm. The TCD signals are electronically summed to provide a single signal output.

These GCs will be configured by Wasson ECE, a certified Hewlett-Packard channel supplier. The base HP-6890 instrument is purchased from Hewlett-Packard and shipped to Wasson along with the Sievers SCD. Wasson will install the Sievers detector, the necessary valves, and columns to perform the analyses stated above. Upon completion of the configuration Wasson will test, install the equipment, train personnel in the use of the equipment and guarantee the performance of the GCs to meet all the detection limits specified above. The Nelson Turbochrom equipment and computer work station will have to be ordered separately and installed in the trailer when the GCs arrive. Turbochrom cannot as yet fully control the new HP-6890 GC so Turbochrom 900 series A/D interfaces will have to be used.

Automation of the stream selection system will be done by Chatham Instruments. Since integrators will not be used the Nelson Turbochrom system will have to be able to control the stream select valves. This will require that some external computer code be written for Turbochrom to fully control and read the sample stream number from the stream select valves into the computer. The old stream select valves can be refurbished and

used again in the new system to help control cost. As of yet I do not have a quote for the stream select valve automation.

COST ESTIMATE

Mobile Trailer

System 1 "POISONS GC"

|                        | Part No.      |                     | Price           |
|------------------------|---------------|---------------------|-----------------|
| <b>Hewlett-Packard</b> | 1540A         | HP-6890 GC          | 7642.20         |
|                        | Option 102    | EPC Packed Injector | 1889.40         |
|                        | Option 230    | ECD                 | 3402.80         |
| <b>Sievers</b>         | Model 355     | SCD                 | 15630.00        |
| <b>Wasson ECE</b>      | Configuration |                     | 14855.00        |
|                        |               | <b>Subtotal</b>     | <b>43419.40</b> |

System 2 "BULK GC"

|                        | Part No.      |                        | Price           |
|------------------------|---------------|------------------------|-----------------|
| <b>Hewlett-Packard</b> | 1540A         | HP-6890 GC             | 7642.20         |
|                        | Option 102    | EPC Packed Injector    | 1889.40         |
|                        | Option 112    | EPC Capillary Injector | 2603.80         |
|                        | Option 220    | TCD with EPC           | 2603.80         |
|                        | Option 210    | FID with EPC           | 2603.80         |
|                        | Option 301    | 3 Channel EPC          | 1518.10         |
| <b>Wasson ECE</b>      | Configuration |                        | 17125.00        |
|                        |               | <b>Subtotal</b>        | <b>35986.10</b> |
|                        |               | <b>Grand Total</b>     | <b>79405.50</b> |