

**COMMERCIAL-SCALE DEMONSTRATION OF THE
LIQUID PHASE METHANOL (LPMEOH™) PROCESS**

ENVIRONMENTAL MONITORING REPORT NO. 3

For The Period

1 October - 31 December 1997

Prepared by

**Air Products and Chemicals, Inc.
Allentown, Pennsylvania**

and

**Eastman Chemical Company
Kingsport, Tennessee**

for the

Air Products Liquid Phase Conversion Company, L.P.

**Prepared for the United States Department of Energy
Federal Energy Technology Center
Under Cooperative Agreement No. DE-FC22-92PC90543**

Patents cleared by Chicago on 02 March 1998.

DISCLAIMER

This report was prepared by Air Products & Chemicals, Inc. and Eastman Chemical Company for the Air Products Liquid Phase Conversion Company, L.P., pursuant to a Cooperative Agreement partially funded by the U.S. Department of Energy, and neither Air Products & Chemicals, Inc., Eastman Chemical Company, the Air Products Liquid Phase Conversion Company, L.P., nor any of their subcontractors nor the U.S. Department of Energy, nor any person acting on behalf of either:

- (A) Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- (B) Assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report.

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute its endorsement, recommendation, or favoring by the U.S. Department of Energy. The views and opinions of authors expressed herein does not necessarily state or reflect those of the U.S. Department of Energy.

Table of Contents

ACRONYMS AND DEFINITIONS.....	4
1. Introduction	6
2. Project Description	6
3. Process Description	7
4. Environmental Monitoring Plan (EMP) Description	9
4.1 Eastman Reporting of Publically Available Technical Data.....	9
4.2 Compliance Monitoring	10
4.3 Supplemental Monitoring	10
5. Project Summary	14
6. Updates on Eastman "Chemicals-from-Coal" Publically Available Technical Data	14
6.1 Gasifier Facility	14
6.2 10C-30 Catalyst Guard Bed	14
6.3 Wastewater and Alcohols to Wastewater Treatment System.....	14
7. Compliance Monitoring.....	16
7.1 Combined Vapor Flow from Demonstration Unit to Boiler	16
7.2 Fugitive Emissions	16
7.2.1 Leak Detection and Repair (LDAR)	16
7.2.2 Ambient Carbon Monoxide Background Concentration	16
7.3 Particulate Emissions.....	16
7.4 Wastewater Treatment System Outlet Stream	16
8. Supplemental Monitoring	17
8.1 Total Synthesis Gas Use and Methanol Production.....	17
8.2 Oil/Water Separator	17
8.3 Compressor and Pump Lubricants	17
8.4 Spent Catalyst Slurry.....	17
8.5 29C-40 Catalyst Guard Bed Spent Adsorbent	17
8.6 Noise	17
9. Compliance.....	19
9.1 Compliance with Permit Limits.....	19
10. Problems and Recommendations	19
APPENDICES.....	20
APPENDIX A - SIMPLIFIED PROCESS FLOW DIAGRAM	20
APPENDIX B - LEAK DETECTION AND REPAIR REPORTS	21
APPENDIX C - NPDES REPORTS FOR WASTEWATER TREATMENT SYSTEM OUTLET STREAM	22

ACRONYMS AND DEFINITIONS

Acurex	-	Acurex Environmental Corporation
Air Products	-	Air Products and Chemicals, Inc.
AFDU	-	Alternative Fuels Development Unit - The "LaPorte PDU"
Balanced Gas	-	A syngas with a composition of hydrogen (H ₂), carbon monoxide (CO), and carbon dioxide (CO ₂) in stoichiometric balance for the production of methanol
BOD	-	Biochemical Oxygen Demand
Carbon Monoxide Gas	-	A syngas containing primarily carbon monoxide (CO); also called CO Gas
Crude Grade Methanol	-	Underflow from rectifier column (29C-20), defined as 80 wt% minimum purity; requires further distillation in existing Eastman equipment prior to use
DME	-	dimethyl ether
DOE	-	United States Department of Energy
DOE-FETC	-	The DOE's Federal Energy Technology Center (Project Team)
DOE-HQ	-	The DOE's Headquarters - Coal Fuels and Industrial Systems (Project Team)
DTP	-	Demonstration Test Plan - The four-year Operating Plan for Phase 3, Task 2 Operation
DVT	-	Design Verification Testing
Eastman	-	Eastman Chemical Company
EIV	-	Environmental Information Volume
EMP	-	Environmental Monitoring Plan
EMR	-	Environmental Monitoring Report
EPRI	-	Electric Power Research Institute
HAPs	-	Hazardous Air Pollutants
Hydrogen Gas	-	A syngas containing an excess of hydrogen (H ₂) over the stoichiometric balance for the production of methanol; also called H ₂ Gas
IGCC	-	Integrated Gasification Combined Cycle, a type of electric power generation plant
IGCC/OTM	-	An IGCC plant with a "Once-Thru Methanol" plant (the LPMEOH™ Process) added-on
KSCF	-	Thousand Standard Cubic Feet
KSCFH	-	Thousand Standard Cubic Feet per Hour
LaPorte PDU	-	The DOE-owned experimental unit (PDU) located adjacent to Air Products' industrial gas facility at LaPorte, Texas, where the LPMEOH™ process was successfully piloted
LDAR	-	Leak Detection and Repair
LPDME	-	Liquid Phase DME process, for the production of DME as a mixed coproduct with methanol
LPMEOH™	-	Liquid Phase Methanol (the technology to be demonstrated)
Main Plant Purge	-	Unreacted synthesis gas stream from LPMEOH™ process returned to Eastman's fuel gas header
mg/m ³	-	Milligrams per cubic meter
NEPA	-	National Environmental Policy Act
NPDES	-	National Pollutant Discharge Elimination System
OSHA	-	Occupational Safety and Health Administration
Partnership	-	Air Products Liquid Phase Conversion Company, L.P.
PDU	-	Process Development Unit
PFD	-	Process Flow Diagram(s)
ppbv	-	parts per billion (volume basis)
Project	-	Production of Methanol/DME Using the LPMEOH™ Process at an Integrated Coal Gasification Facility
psia	-	Pounds per Square Inch (Absolute)
psig	-	Pounds per Square Inch (gauge)
P&ID	-	Piping and Instrumentation Diagram(s)
RCRA	-	Resource and Conservation Recovery Act
Refined Grade Methanol	-	Distilled methanol, defined as 99.8wt% minimum purity; used directly in downstream Eastman processes
SCFH	-	Standard Cubic Feet per Hour
SI/hr-kg	-	Standard Liter(s) per Hour per Kilogram of Catalyst

ACRONYMS AND DEFINITIONS (cont'd)

Syngas	-	Abbreviation for Synthesis Gas
Synthesis Gas	-	A gas containing primarily hydrogen (H ₂) and carbon monoxide (CO), or mixtures of H ₂ and CO; intended for "synthesis" in a reactor to form methanol and/or other hydrocarbons (synthesis gas may also contain CO ₂ , water, and other gases)
Tie-in(s)	-	the interconnection(s) between the LPMEOH™ Process Demonstration Facility and the Eastman Facility
TLV	-	Threshold Limit Value
TPD	-	Ton(s) per Day
WBS	-	Work Breakdown Structure
wt	-	Weight

1. Introduction

The Liquid Phase Methanol (LPMEOH™) Demonstration Project at Kingsport, Tennessee, is a \$213.7 million effort being conducted under a cooperative agreement between the U.S. Department of Energy (DOE) and Air Products Liquid Phase Conversion Company, L.P. (the Partnership). Air Products and Chemicals, Inc. (Air Products) and Eastman Chemical Company (Eastman) formed the Partnership to execute the Demonstration Project. A demonstration unit producing 80,000 gallons per day (260 tons-per-day (TPD)) of methanol from coal-derived synthesis gas (syngas) was designed, constructed, and began a four-year operational period in April of 1997 at a site located at the Eastman complex in Kingsport. The Partnership will own and operate the facility for the four-year demonstration period.

This project is sponsored under the DOE's Clean Coal Technology Program, and its primary objective is to "demonstrate the production of methanol using the LPMEOH™ Process in conjunction with an integrated coal gasification facility." The project will also demonstrate the suitability of the methanol produced for use as a chemical feedstock or as a low-sulfur dioxide, low-nitrogen oxides alternative fuel in stationary and transportation applications. The project may also demonstrate the production of dimethyl ether (DME) as a mixed coproduct with methanol, if laboratory- and pilot-scale research and market verification studies show promising results. If implemented, the DME would be produced during the last six months of the four-year demonstration period.

The LPMEOH™ process is the product of a cooperative development effort by Air Products and the DOE in a program that started in 1981. It was successfully piloted at a 10-TPD rate in the DOE-owned experimental unit at Air Products' LaPorte, Texas, site. This Demonstration Project is the culmination of that extensive cooperative development effort.

2. Project Description

The demonstration unit, which occupies an area of 0.6 acre, is integrated into the existing 4,000-acre Eastman complex located in Kingsport, Tennessee. The Eastman complex employs approximately 12,000 people. In 1983, Eastman constructed a coal gasification facility utilizing Texaco technology. The syngas generated by this gasification facility is used to produce carbon monoxide and methanol. Both of these products are used to produce methyl acetate and ultimately cellulose acetate and acetic acid. The availability of this highly reliable coal gasification facility was the major factor in selecting this location for the LPMEOH™ Process Demonstration. Three different feed gas streams (hydrogen gas or H₂ Gas, carbon monoxide gas or CO Gas, and Balanced Gas) will be diverted from existing operations to the LPMEOH™ Demonstration Unit, thus providing the range of syngas ratios (hydrogen to carbon monoxide) needed to meet the technical objectives of the Demonstration Project.

For descriptive purposes and for design and construction scheduling, the project has been divided into four major process areas with their associated equipment:

- *Reaction Area* - Syngas preparation and methanol synthesis reaction equipment.
- *Purification Area* - Product separation and purification equipment.
- *Catalyst Preparation Area* - Catalyst and slurry preparation and disposal equipment.
- *Storage/Utility Area* - Methanol product, slurry, and oil storage equipment.

The physical appearance of this facility closely resembles the adjacent Eastman process plants, including process equipment in steel structures.

- *Reaction Area*

The reaction area includes feed gas compressors, catalyst guard beds, the reactor, a steam drum, separators, heat exchangers, and pumps. The equipment is supported by a matrix of structural steel. The most salient feature is the reactor, since with supports, it is approximately 84-feet tall.

- *Purification Area*

The purification area features two distillation columns with supports; one is approximately 82-feet tall, and the other 97-feet tall. These vessels resemble the columns of the surrounding process areas. In addition to the columns, this area includes the associated reboilers, condensers, air coolers, separators, and pumps.

- *Catalyst Preparation Area*

The catalyst preparation area consists of a building with a roof and partial walls, in which the catalyst preparation vessels, slurry handling equipment, and spent slurry disposal equipment are housed. In addition, a hot oil utility system is included in the area.

- *Storage/Utility Area*

The storage/utility area includes two diked lot-tanks for methanol, two tanks for oil storage, a slurry holdup tank, a trailer loading/unloading area, and an underground oil/water separator. A vent stack for safety relief devices is located in this area.

3. Process Description

The LPMEOH™ Demonstration Unit is integrated with Eastman's coal gasification facility. A simplified process flow diagram is included in Appendix A. Syngas is introduced into the slurry reactor, which contains a slurry of liquid mineral oil with suspended solid particles of catalyst. The syngas dissolves through the mineral oil, contacts the catalyst, and reacts to form methanol. The heat of reaction is absorbed by the slurry and is removed from the slurry by steam coils. The methanol vapor leaves the reactor, is condensed to a liquid, sent to the distillation columns for removal of higher alcohols, water, and other impurities, and is then stored in the day tanks for sampling before being sent to Eastman's methanol storage. Most of the unreacted syngas is recycled back to the reactor with the syngas recycle

compressor, improving cycle efficiency. The methanol will be used for downstream feedstocks and in off-site fuel testing to determine its suitability as a transportation fuel and as a fuel for stationary applications in the power industry.

Demonstration Test Plan

Following the start-up of the LPMEOH™ Demonstration Unit, a four-year test plan is being performed by Air Products and Eastman. The goals of the Test Plan are structured to meet the commercialization objectives for the LPMEOH™ Process. Excerpts from Commercialization Objectives from the program Statement of Work are included here to provide the global perspective of the Demonstration Plan:

"Primary Objective

The primary objective of the Project is to demonstrate the commercial scale production of methanol using the LPMEOH™ Process...

The LPMEOH™ Process technology is expected to be commercialized as part of an IGCC electric power generation system. Therefore, the Project incorporates the commercially important aspects of the operation of the LPMEOH™ Process which would enhance IGCC power generation. These important aspects of LPMEOH™ Process integrations are:

- The coproduction of electric power and of high value liquid transportation fuels and/or chemical feedstocks from coal. This coproduction requires that the partial conversion of synthesis gas to storable liquid products be demonstrated.
- Using an energy load following operating concept which allows conversion of off-peak energy, at attendant low value, into peak energy commanding a higher value. The load-following concept makes use of gasifier capacity that is under utilized during low-demand periods by using the LPMEOH™ Process to convert the excess synthesis gas to a storable liquid fuel for use in electric power generation during the peak energy periods. This operating concept requires that on/off and synthesis gas load following capabilities be demonstrated...

During operation, the instrumentation system will allow for the collection of engineering data, analysis and reporting which will be done by on-site technical personnel. Typical reporting will include on-stream factors, material and energy balances, reactor and equipment performance, comparison with laboratory and LaPorte Alternative Fuels Development Unit (AFDU) results, conversion efficiencies and catalyst activity...

Secondary Objective

A secondary objective of the Project is to demonstrate the production of DME (Dimethyl ether) as a mixed coproduct with methanol...

Subject to Design Verification Testing (DVT), the Partnership proposes to enhance the Project by including the demonstration of the slurry reactor's capability to produce DME as a mixed co-product with methanol...

DVT is required to address issues such as catalyst activity and stability and to provide data for engineering design and demonstration decision making...

At the conclusion of the DVT Steps, a joint Partnership/DOE decision will be made regarding continuation of the methanol/DME demonstration. Timing of the final decision must ensure that the necessary design, procurement, construction and commissioning can be completed to allow for (Phase 3, Task 2.2) operation at the end of the primary LPMEOH™ process demonstration period."

The full Demonstration Test Plan (issued September 1996) provides details in the strategy and conditions to be tested during the four-year operating period.

4. Environmental Monitoring Plan (EMP) Description

Air Products Liquid Phase Conversion Company, L.P., has constructed and is operating the 260 ton-per-day Liquid Phase Methanol (LPMEOH™) Demonstration Unit at the Eastman Chemical facility in Kingsport, Tennessee. As specified in the Cooperative Agreement, the Partnership developed an Environmental Monitoring Plan (EMP) (issued August 1996) which describes in detail the environmental monitoring activities to be performed during the operation of the LPMEOH™ Demonstration Unit. The purpose of the EMP is to: 1) document the extent of compliance monitoring activities, i.e., those activities required to meet permit requirements, 2) confirm the specific environmental impacts predicted in the National Environmental Policy Act documentation, and 3) establish an information base for the assessment of the environmental performance of the technology for future commercialization.

The EMP describes three categories of environmental monitoring which are performed as a result of the operation of the LPMEOH™ Demonstration Unit. Details of streams internal to the demonstration unit are available in the Technical Progress Reports for the Project.

4.1 Eastman Reporting of Publicly Available Technical Data

As defined in the Statement of Work for the Demonstration Project, Eastman will provide data on three areas of operation of the Chemicals-from-Coal complex (refer to Table 4.1 for a breakdown of the streams to be monitored):

- 1) Gasifier material balance data
- 2) 10C-30 Guard Bed operating data
- 3) Wastewater and alcohols to wastewater treatment system

This technical information provides information from Eastman's existing facilities to provide an overall assessment of the LPMEOH™ technology. A separate Topical Report (during Year 1 of the operation of the demonstration unit) provides this information, and a summary is available in the Year 1 Annual Environmental Monitoring Report (EMR). Updates, if any, are included in Quarterly EMRs if a significant change occurs.

4.2 Compliance Monitoring

Four areas of compliance monitoring have been identified to satisfy the permit requirements for the demonstration unit (Table 4.2):

- 1) Combined Vapor Flow from Demonstration Unit to Boiler
- 2) Fugitive Emissions
- 3) Particulate Emissions
- 4) Wastewater Treatment System Outlet Stream

Each of these sources is monitored at a frequency mandated by the relevant permit or industrial hygiene practice. The EMRs will include the results of any compliance monitoring generated during the reporting period.

4.3 Supplemental Monitoring

Three areas of supplemental monitoring have been identified in the EMP (Table 4.3):

Summary of Major Material Balance Streams for Demonstration Unit

The major feed streams (CO Gas, H₂ Gas, Balanced Gas) and product flows (Refined Grade Methanol, Crude Grade Methanol, Main Plant Purge) are provided as a summary table of the cumulative stream flows for the reporting period.

Solid/Liquid Discharges

Four other streams can be generated from the demonstration unit:

- 1) Compressor and Pump Lubricants
- 2) Oil Recovered in Oil/Water Separator
- 3) Spent Catalyst
- 4) 29C-40 Guard Bed Adsorbent

Any quantities generated during the reporting period are included in the EMR.

Noise

The EMP identified that a noise survey around the 29K-01 Recycle Compressor was planned during the initial start-up of the demonstration unit.

TABLE 4.1

LPMEOH™ DEMONSTRATION UNIT

**PUBLICLY AVAILABLE TECHNICAL DATA FROM EASTMAN
CHEMICALS-FROM-COAL COMPLEX**

<u>Environmental Media</u>	<u>General Parameters</u>
Coal	Pressure, Temperature, Coal Analysis
Oxygen to Gasifier	Pressure, Temperature, %O ₂
Water to Gasifier	Pressure, Temperature
Waste Water from Gasifier	Pressure, Temperature, Total Organic Carbon
Clean Synthesis Gas from Gasifier	Pressure, Temperature, Flow
Sulfur Recovered from Gasifier	Pressure, Temperature, Flow, %S
Carbon Dioxide from Gasifier	Pressure, Temperature, Flow, %CO ₂
Slag from Gasifier	Pressure, Temperature, Flow
Balanced Gas from 10C-30 Guard Bed	Pressure, Temperature, Flow, Composition
Wastewater and Alcohols to Wastewater Treatment System	Flow, Composition, BOD

TABLE 4.2
LPMEOH™ DEMONSTRATION UNIT
COMPLIANCE MONITORING

Environmental Media

General Parameters

Combined Vapor Flow from Demonstration Unit to Boiler

Composition

Fugitive Emissions

Leak Detection and Repair (LDAR) Report, Volatile Organic Carbon (VOC), Background Ambient CO Concentration

Particulate Emissions

Threshold Limit Value (TLV)

Wastewater Treatment System Outlet Stream

Flow, Total Organic Carbon, pH

TABLE 4.3

LPMEOH™ DEMONSTRATION UNIT

SUPPLEMENTAL MONITORING

Environmental Media

General Parameters

CO Gas to LPMEOH™ Demonstration Unit	Cumulative Flow for Quarter
H ₂ Gas to LPMEOH™ Demonstration Unit	Cumulative Flow for Quarter
Balanced Gas to LPMEOH™ Demonstration Unit	Cumulative Flow for Quarter
Main Vapor Purge from LPMEOH™ Demonstration Unit	Cumulative Flow for Quarter
Refined Grade Methanol	Cumulative Flow for Quarter
Crude Grade Methanol	Cumulative Flow for Quarter
Compressor and Pump Lubricants	Weight or Volume
Oil Recovered in Oil/Water Separator	Weight or Volume
Spent Catalyst	Weight, Weight% Solids
29C-40 Guard Bed Adsorbent	Weight or Volume
Noise Survey for 29K-01 Recycle Compressor	dBa

5. Project Summary

Synthesis gas was first introduced to the LPMEOH™ Demonstration Unit on 02 April 1997. The nameplate capacity of 80,000 gallons of methanol per day (260 tons-per-day) was achieved on 06 April 1997. During November and December of 1997, the initial charge of catalyst slurry was drained from the LPMEOH™ Reactor, and a startup charge of fresh catalyst was activated and brought onstream. A 31-day continuous operating campaign was completed on 03 November 1997. Table 5.1 summarizes the onstream time and outages of the LPMEOH™ Demonstration Unit during the reporting period.

6. Updates on Eastman "Chemicals-from Coal" Facility Publicly Available Technical Data

6.1 Gasifier Facility

The report on publicly available technical data from the Eastman "Chemicals-from-Coal" facility, which includes data on the streams associated with the Gasifier facility, will be issued during the first year of operation of the LPMEOH™ Demonstration Unit.

6.2 10C-30 Catalyst Guard Bed

The report on publicly available technical data from the Eastman "Chemicals-from-Coal" facility, which includes data on the streams around and the operation of the 10C-30 Catalyst Guard Bed, will be issued during the first year of operation of the LPMEOH™ Demonstration Unit.

During the reporting period, the adsorbent in the 10C-30 Catalyst Guard Bed was removed and replaced with fresh material. The quantities of adsorbent which were removed from the 10C-30 for disposal (and placed into drums) were 75 cubic feet of manganese oxide and 155 cubic feet of zinc oxide. Equivalent quantities of fresh adsorbent were added to the vessel. This material was sent to Eastman's onsite incinerator for disposal.

6.3 Wastewater and Alcohols to Wastewater Treatment System

The report on publicly available technical data from the Eastman "Chemicals-from-Coal" facility, which includes data on the streams associated with the wastewater and alcohols to the Wastewater Treatment System, will be issued during the first year of operation of the LPMEOH™ Demonstration Unit. This will consist of a comparison of the flow, composition, and BOD load of this stream before and after the addition of the LPMEOH™ Demonstration Unit.

Insert Table 5-1

7. Compliance Monitoring

7.1 Combined Vapor Flow from Demonstration Unit to Boiler

A sample of the header gas from the LPMEOH™ Demonstration Unit must be analyzed as part of the Boiler and Industrial Furnace regulations within RCRA. Sampling is currently required every three years. During the development of the EMP, it was anticipated that the new tie-in from the LPMEOH™ Demonstration Unit to the Eastman fuel header would require testing as a new source. After the EMP was published, it was determined that the new tie-in was not considered a significant change and did not require testing. Therefore, with the current sampling schedule, the next sample will be taken in February of 2000.

No activity occurred during the reporting period.

7.2 Fugitive Emissions

7.2.1 Leak Detection and Repair (LDAR)

Appendix B contains two reports on Leak Detection and Repair at the LPMEOH™ Demonstration Unit. Due to the April 1997 start-up date, there is some overlap between these reports. All items (valves, pump seals, fittings) which were found to exceed the allowable leakage rate (as measured by concentration levels in air) were repaired by Eastman.

7.2.2 Ambient Carbon Monoxide Background Concentration

This one-time study will record the concentration of CO that is encountered by a LPMEOH™ operations person during the course of a normal day of plant operations.

No activity occurred during the reporting period. The ambient CO background concentration study is scheduled to be performed during the first quarter of calendar year 1998.

7.3 Particulate Emissions

This one-time study was completed in July of 1997, and documents the exposure level to particulate emissions that is encountered by a LPMEOH™ operations person during the catalyst charging process. The report on this study is included in Environmental Monitoring Report No. 1. Some engineering modifications to the catalyst loading system are planned to reduce the dust concentration and potential personnel exposure.

7.4 Wastewater Treatment System Outlet Stream

The reports on the outfall from the Wastewater Treatment System (Discharge Number 002) for the reporting period is attached in Appendix C. There were no permit excursions.

A process stream within the existing Eastman facility which is impacted by the operation of the LPMEOH™ Demonstration Unit contains the byproduct alcohols and water which are generated in parallel with the production of methanol. This stream is sent to the Eastman Wastewater Treatment System. The annual EMR will contain a comparison of the flow, composition, and BOD load of this stream before and after the addition of the LPMEOH™ Demonstration Unit.

8. Supplemental Monitoring

8.1 Total Synthesis Gas Use and Methanol Production

Table 8.1 contains the summary of the major process flows to and from the LPMEOH™ Demonstration Unit for the reporting period. Approximately 2,400,000 gallons (8,000 tons) of methanol (Refined and Crude Grades) were produced during the reporting period.

8.2 Oil/Water Separator

Since the startup of the LPMEOH™ Demonstration Unit in April of 1997, about 24,000 pounds of oil have been removed from the Oil/Water Separator. This material has been incinerated for energy recovery.

8.3 Compressor and Pump Lubricants

No material was generated during the reporting period.

8.4 Spent Catalyst Slurry

A total of 90,800 pounds of methanol synthesis catalyst were removed from the LPMEOH™ reactor during the outage between 03 November and 19 December 1997. This material is presently stored on site, and arrangements are being made to ship this material to the off-site catalyst reclaimer.

8.5 29C-40 Catalyst Guard Bed Spent Adsorbent

During the reporting period, the adsorbent in the 29C-40 Catalyst Guard Bed was removed and replaced with fresh material. Approximately 6,300 pounds of activated carbon were removed from the vessel (placed into drums), and an equivalent quantity of fresh material was added. The spent activated carbon is presently stored on site, and will be sent offsite for disposal during the first quarter of calendar year 1998.

8.6 Noise

The results of noise dosimetry measurements of the entire LPMEOH™ Demonstration Unit were reported in Environmental Monitoring Report No. 1. The results of an area noise survey at each platform of the LPMEOH™ Demonstration Unit and around the 29K-01

Table 8-1

**Synthesis Gas Use and Methanol Production - October/December 1997
LPMEOH™ Demonstration Unit**

	October 1997	November 1997	December 1997	Total
Consumption, KSCF				
Balanced Gas	345,581.0	34,073.0	240,468.0	620,122.0
CO Gas	0.0	0.6	0.0	0.6
H ₂ Gas	0.0	0.0	0.0	0.0
Production, Tons				
Crude Methanol	928.1	60.1	1,325.0	2,313.3
Refined Methanol	3,629.6	337.6	1,697.4	5,664.6
Total Purge Gas, KSCF	45,727.0	5,425.0	20,657.0	71,809.0

Recycle Compressor were reported in Environmental Monitoring Report No. 2. No additional surveys were performed during the reporting period.

9. Compliance

9.1 Compliance with Permit Limits

There were no excursions outside permit limits associated with the operation of the LPMEOH™ Demonstration Unit.


10. Problems and Recommendations

There have been no significant problems arising in the environmental area.

APPENDICES

APPENDIX A - SIMPLIFIED PROCESS FLOW DIAGRAM

SIMPLIFIED PROCESS DIAGRAM KINGSFORT LPMEOH - 260 TPD PLANT LPMEOH™ PROCESS DEMONSTRATION FACILITY



APPENDIX B - LEAK DETECTION AND REPAIR REPORTS

Reporting Period 01 April - 30 September 1997 (10 pages)

Reporting Period 01 July - 31 December 1997 (10 pages)

40 CFR Part 63 SubPart H -- Semi-Annual Monitoring Summary
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Printed: 11/06/1997 at 13:38:54
Period: 04/01/1997 to 09/30/1997

PROCESS UNIT: METHANOL 29 COMPONENT CLASS: VALVES

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
04/01/1997	06/30/1997	259	0	0.00	0	0
07/01/1997	09/30/1997	254	0	0.00	0	0

40 CFR Part 63 SubPart H -- Semi-Annual Monitoring Summary

PAGE 2

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: PUMPS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
04/01/1997	04/30/1997	12	1	9.09	0	0
05/01/1997	05/31/1997	11	0	0.00	0	0
06/01/1997	06/30/1997	11	0	0.00	0	0
07/01/1997	07/31/1997	11	2	18.18	0	0
08/01/1997	08/31/1997	11	2	18.18	0	0
09/01/1997	09/30/1997	11	0	0.00	0	0

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: COMPRESSORS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
-----------------	---------------	------------------	-------------------	--------------------	----------------------	--------------------------

* * * No COMPRESSORSs Identified on Unit METHANOL 29 * * *

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: AGITATORS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
-----------------	---------------	------------------	-------------------	--------------------	----------------------	--------------------------

* * * No AGITATORSs Identified on Unit METHANOL 29 * * *

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: CONNECTORS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
-----------------	---------------	------------------	-------------------	--------------------	----------------------	--------------------------

* * * The end date of the monitoring period for CONNECTORS
 In Unit METHANOL 29 falls outside the specified period. * * *
 * * * The closest monitoring period for CONNECTORS
 In Unit METHANOL 29 is 04/01/1997 --> 03/31/1998 * * *
 * * * The following is the current status of this monitoring period. * * *

04/01/1997	03/31/1998	515	0		0	0
------------	------------	-----	---	--	---	---

End Of Report - (ver. 2.4)

40CFR Part 63 SubPart H - Semi Annual Delayed Repairs Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Printed: 11/06/1997 at 13:39:53
Period: 04/01/1997 to 09/30/1997

PROCESS UNIT: METHANOL 29

COMPONENT TAG	DRAWING NUMBER	COMPONENT CLASS	INSPECTION DATE
---------------	----------------	-----------------	-----------------

REASON FOR DELAYED REPAIR

* * * No delayed repairs logged for period. * * *

End Of Report

40 CFR Part 63 SubPart H -- Semi-Annual Exempt Compressor Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Printed: 11/06/1997 at 13:40:25
Period: 04/01/1997 to 09/30/1997

PROCESS UNIT: METHANOL 29

INSPECTION DATE	DRAWING NUMBER	COMPONENT TAG	BACK- GROUND	TEST READING	NET READING	TEST RESULT
--------------------	-------------------	------------------	-----------------	-----------------	----------------	----------------

* * * No Compressors Identified on Unit METHANOL 29 * * *

End Of Report

40 CFR Part 63 SubPart H -- Semi-Annual Pressure Relief Device Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Printed: 11/06/1997 at 13:40:58
Period: 04/01/1997 to 09/30/1997

PROCESS UNIT: METHANOL 29

INSPECTION DATE	DRAWING NUMBER	COMPONENT TAG	BACK- GROUND	TEST READING	NET READING	TEST RESULT
--------------------	-------------------	------------------	-----------------	-----------------	----------------	----------------

* * * No Pressure Relief Devices Identified on Unit METHANOL 29 * * *

End Of Report

40 CFR Part 63 SubPart H -- Semi-Annual Closed Vent System Report
 EASTMAN CHEMICAL
 P.O. Box 511
 Kingsport, TN 37662

Printed: 11/06/1997 at 13:41:29
 Period: 04/01/1997 to 09/30/1997

PROCESS UNIT: METHANOL 29

INSPECTION DATE	DRAWING NUMBER	COMPONENT TAG	BACK-GROUND	TEST READING	NET READING	TEST RESULT
06/03/1997	29F-B-003	291686V2	4	24	20	pass
06/03/1997	29F-B-003	291765V1	4	147	143	pass
06/03/1997	29F-B-003	291963V1	6	12	6	pass
08/14/1997	29F-B-003	291963V1	4	142	138	pass
08/14/1997	29F-B-003	291688F1	4	24	20	pass
08/14/1997	29F-B-003	291688F2	4	24	20	pass
08/14/1997	29F-B-003	291764F3	4	15	11	pass
08/14/1997	29F-B-003	291764G4	4	15	11	pass
08/14/1997	29F-B-003	291764S6	4	17	13	pass
08/14/1997	29F-B-003	291764V5	4	18	14	pass
08/14/1997	29F-B-003	29G105F1	4	21	17	pass
08/14/1997	29F-B-003	29G105F2	4	24	20	pass
08/14/1997	29F-B-003	29G105F4	4	20	16	pass
08/14/1997	29F-B-003	29G103V3	4	20	16	pass
09/15/1997	29F-B-003	291686F1	4	25	21	pass
09/15/1997	29F-B-003	291686F5	4	12	8	pass
09/15/1997	29F-B-003	291686F5	6	1046	1040	fail
09/15/1997	29F-B-003	291686I4	5	150	145	pass
09/15/1997	29F-B-003	291686S3	4	9	5	pass
09/15/1997	29F-B-003	291687F1	4	22	18	pass
09/15/1997	29F-B-003	291764V7	4	6	2	pass
09/22/1997	29F-B-003	291686F5	4	63	59	pass

End Of Report

40 CFR Part 63 Subpart H Inventory Update Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Printed: 11/06/1997 at 13:42:37
Period: 04/01/1997 to 09/30/1997

PROCESS UNIT: METHANOL 29

COMPONENT CLASS	ADDED	REMOVED
END CAPS FOR OPEN ENDED LINES	0	0
CLOSED VENT SYS/CTRL DEVICE	20	9
CONNECTOR	8	1
INSTRUMENTATION SYSTEMS	0	0
PUMP	0	1
VALVE	8	2
PRODUCT ACCUMULATOR VESSEL	6	0

End Of Report.

SEMI ANNUAL
40 CFR Part 63 SubPart H -- Semi-Annual Monitoring Summary
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Period: 07/01/1997 to 12/31/1997

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: VALVES

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
07/01/1997	09/30/1997	254	0	0.00	0	0
10/01/1997	12/31/1997	239	0	0.00	0	0

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: PUMPS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
07/01/1997	07/31/1997	11	2	18.18	0	0
08/01/1997	08/31/1997	11	2	18.18	0	0
09/01/1997	09/30/1997	11	0	0.00	0	0
10/01/1997	10/31/1997	11	0	0.00	0	0
11/01/1997	11/30/1997	11	0	0.00	0	0
12/01/1997	12/31/1997	11	0	0.00	0	0

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: COMPRESSORS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
-----------------	---------------	------------------	-------------------	--------------------	----------------------	--------------------------

* * * No COMPRESSORs In CMPU * * *

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: AGITATORS

PERIOD START	PERIOD END	NUMBER TESTED	NUMBER LEAKERS	PERCENT LEAKERS	NUMBER UNREPAIRED	NUMBER NOT REPAIRABLE
-----------------	---------------	------------------	-------------------	--------------------	----------------------	--------------------------

* * * No AGITATORSs In CMPU * * *

PROCESS UNIT: METHANOL 29

COMPONENT CLASS: CONNECTORS

```
=====
PERIOD      PERIOD      NUMBER      NUMBER      PERCENT      NUMBER      NUMBER NOT
START       END         TESTED     LEAKERS     LEAKERS     UNREPAIRED  REPAIRABLE
=====
```

```
*** No Data Logged For Connectors ***
```

End Of Report - (ver. 2.4)

40CFR Part 63 SubPart H - Semi Annual Delayed Repairs Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Period: 07/01/1997 to 12/31/1997

PROCESS UNIT: METHANOL 29

```
=====
COMPONENT   DRAWING      COMPONENT   INSPECTION
TAG         NUMBER      CLASS      DATE
=====
```

REASON FOR DELAYED REPAIR

```
=====
* * * No delayed repairs logged for period. * * *
```

End Of Report

40 CFR Part 63 SubPart H -- Semi-Annual Exempt Compressor Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Period: 07/01/1997 to 12/31/1997

PROCESS UNIT: METHANOL 29

INSPECTION DATE	DRAWING NUMBER	COMPONENT TAG	BACK- GROUND	TEST READING	NET READING	TEST RESULT
--------------------	-------------------	------------------	-----------------	-----------------	----------------	----------------

* * * No Exempt Compressors In C MPU * * *

End Of Report

40 CFR Part 63 SubPart H -- Semi-Annual Pressure Relief Device Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Period: 07/01/1997 to 12/31/1997

PROCESS UNIT: METHANOL 29

INSPECTION DATE	DRAWING NUMBER	COMPONENT TAG	BACK- GROUND	TEST READING	NET READING	TEST RESULT
--------------------	-------------------	------------------	-----------------	-----------------	----------------	----------------

* * * No Pressure Relief Devices In CPU * * *

End Of Report

40 CFR Part 63 SubPart H -- Semi-Annual Closed Vent System Report
 EASTMAN CHEMICAL
 P.O. Box 511
 Kingsport, TN 37662

Period: 07/01/1997 to 12/31/1997

PROCESS UNIT: METHANOL 29

INSPECTION DATE	DRAWING NUMBER	COMPONENT TAG	BACK- GROUND	TEST READING	NET READING	TEST RESULT
08/14/1997	29F-B-003	291963V1	4	142	138	pass
08/14/1997	29F-B-003	291688F1	4	24	20	pass
08/14/1997	29F-B-003	291688F2	4	24	20	pass
08/14/1997	29F-B-003	291764F3	4	15	11	pass
08/14/1997	29F-B-003	291764S4	4	15	11	pass
08/14/1997	29F-B-003	291764S6	4	17	13	pass
08/14/1997	29F-B-003	291764V5	4	18	14	pass
08/14/1997	29F-B-003	29G105F1	4	21	17	pass
08/14/1997	29F-B-003	29G105F2	4	24	20	pass
08/14/1997	29F-B-003	29G105F4	4	20	16	pass
08/14/1997	29F-B-003	29G105V3	4	20	16	pass
09/15/1997	29F-B-003	291686F1	4	25	21	pass
09/15/1997	29F-B-003	291686F5	4	12	8	pass
09/15/1997	29F-B-003	291686F5	6	1046	1040	fail
09/15/1997	29F-B-003	291686I4	5	150	145	pass
09/15/1997	29F-B-003	291686S3	4	9	5	pass
09/15/1997	29F-B-003	291687F1	4	22	18	pass
09/15/1997	29F-B-003	291764V7	4	6	2	pass
09/22/1997	29F-B-003	291686F5	4	63	59	pass

End Of Report

40 CFR Part 63 SubPart H Inventory Update Report
EASTMAN CHEMICAL
P.O. Box 511
Kingsport, TN 37662

Period: 07/01/1997 to 12/31/1997

PROCESS UNIT: METHANOL 29

COMPONENT CLASS	ADDED	REMOVED
END CAPS FOR OPEN ENDED LINES	0	0
CLOSED VENT SYS/CTRL DEVICE	0	1
CONNECTOR	12	0
INSTRUMENTATION SYSTEMS	0	0
PUMP	0	0
VALVE	2	1
PRODUCT ACCUMULATOR VESSEL	0	0

End Of Report

**APPENDIX C - NPDES REPORTS FOR WASTEWATER TREATMENT SYSTEM
OUTLET STREAM**

PERMITTEE NAME/ADDRESS: **IN EASTMAN DIVISION**
DIVISION OF EASTMAN CHEMICAL CO.
P O BOX 1993
KINGSPOST, TN 37662-5393
 Facility: **TN EASTMAN - KINGSPORT**
 Location: **SULLIVAN COUNTY TN 37662-5393**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) MAJOR (SUBR 06) FORM APPROVED
 DISCHARGE MONITORING REPORT (DMR) F - FINAL OMB No. 2040-0004
 INDUSTRIAL PROCESS WASTEWATER EFFLUENT
 *** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

TN0002640 002 G
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 FROM 97-10-01 TO 97-10-31

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	(3 Card Only) (46-53)		Quantity or (54-57)		Loading		(4 Card Only) (38-45)		Quality or (46-53)		Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	Requirement	Maximum	Unit	Minimum	Maximum	Average	Unit	Minimum	Maximum	Average	Unit			
PH	SAMPLE MEASUREMENT PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	Continuous	N/A
00400 1 0 0	EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	CONTINUOUS	RECORDER
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT PERMIT REQUIREMENT	2,391	5,132	(26)	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	31/31	Composite
00530 1 0 0	EFFLUENT GROSS VALUE	11111	35954	DAILY MAX	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	DAILY	COMPOSITE
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	<49	152	(26)	*****	*****	*****	*****	*****	<0.2	1	(19)	*****	0	31/31	Composite
00610 2 0 0	EFFLUENT NET VALUE	6000	12000	DAILY MAX	*****	*****	*****	*****	*****	30.5	61	DAILY MAX	*****	0	DAILY	COMPOSITE
CYANIDE, TOTAL (AS CN)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	BDL	BDL	(26)	*****	*****	*****	*****	*****	BDL	BDL	(19)	*****	0	1/7	Grab
00720 2 0 0	EFFLUENT NET VALUE	14.51	104.83	DAILY MAX	*****	*****	*****	*****	*****	0.058	0.419	DAILY MAX	*****	0	WEEKLY	GRAB
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	3.36	4.39	(26)	*****	*****	*****	*****	*****	0.015	0.018	(19)	*****	0	1/7	Composite
01034 2 0 0	EFFLUENT NET VALUE	12.51	25.02	DAILY MAX	*****	*****	*****	*****	*****	0.050	0.100	DAILY MAX	*****	0	WEEKLY	COMPOSITE
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	<0.76	0.94	(26)	*****	*****	*****	*****	*****	<0.003	0.004	(19)	*****	0	1/7	Composite
01042 2 0 0	EFFLUENT NET VALUE	12.51	25.02	DAILY MAX	*****	*****	*****	*****	*****	0.050	0.100	DAILY MAX	*****	0	WEEKLY	COMPOSITE
LEAD, TOTAL (AS PB)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	BDL	BDL	(26)	*****	*****	*****	*****	*****	BDL	BDL	(19)	*****	0	1/7	Composite
01051 2 0 0	EFFLUENT NET VALUE	43.03	172.64	DAILY MAX	*****	*****	*****	*****	*****	0.172	0.690	DAILY MAX	*****	0	WEEKLY	COMPOSITE
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER <i>John F. Webb</i> OFFICER OR AUTHORIZED AGENT															
H. H. Holliman, President	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OFFICER OR AUTHORIZED AGENT															
Tennessee Eastman Division	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OFFICER OR AUTHORIZED AGENT															
TYPED OR PRINTED	AREA CODE NUMBER (423) 229-2000 YEAR MO DAY 97-11-12															

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.
 EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

*** NO DISCHARGE [] ***
 NOTE: Read instructions before completing this form.

MONITORING PERIOD
 FROM 97 - 10 - 01 TO 97 - 10 - 31

PARAMETER (32-37)	(3 Card Only) (46-53)			(4 Card Only) (38-49)			Quality or (46-53)		Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
	Average	Maximum	Unit	Minimum	Average	Maximum	Unit	Minimum	Maximum	Unit			
NICKEL, TOTAL (AS NI)	5.67	6.68	(26)	*****	0.025	0.031	(19)	0	1/7	Composite			
01067 2 0 0 EFFLUENT NET VALUE	422.84 MON AVG	995.80 DAILY MAX	LBS/DAY	*****	1.690 MON AVG	3.980 DAILY MAX	MG/L	0	WEEKLY	COMPOSITE			
ZINC, TOTAL (AS ZN)	7.72	9.19	(26)	*****	0.034	0.041	(19)	0	1/7	Composite			
01092 2 0 0 EFFLUENT NET VALUE	158.00 MON AVG	317.75 DAILY MAX	LBS/DAY	*****	0.635 MON AVG	1.270 DAILY MAX	MG/L	0	WEEKLY	COMPOSITE			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	26.37 REPORT	37.08 REPORT	(03)	*****	*****	*****	*****	0	Continuous	N/A			
50050 1 0 0 EFFLUENT GROSS VALUE	1.074 MON AVG	13000 DAILY MAX	MGD	*****	*****	*****	*****	0	CONTINUOUS	RECORDER			
BOD, CARBONACEOUS 05 DAY, 20C	6000 MON AVG	13000 DAILY MAX	LBS/DAY	*****	*****	*****	*****	0	31/31	Composite			
80082 2 W 0 EFFLUENT NET VALUE				*****	*****	*****	*****		DAILY	COMPOSITE			
MEASUREMENT PERMIT REQUIREMENT													
MEASUREMENT PERMIT REQUIREMENT													
MEASUREMENT PERMIT REQUIREMENT													
MEASUREMENT PERMIT REQUIREMENT													
MEASUREMENT PERMIT REQUIREMENT													
MEASUREMENT PERMIT REQUIREMENT													
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER <i>John F. Webb</i> OFFICER OR AUTHORIZED AGENT												
H. H. Holliman, President	TELEPHONE (423) 229-2000												
Tennessee Eastman Division	AREA CODE NUMBER 97 - 11 - 12												
TYPED OR PRINTED	YEAR MO DAY												

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.

EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 3 OF 6

DISCHARGE MONITORING REPORT (DMR)
 002 G
 DISCHARGE NUMBER

PERMIT NUMBER
 TN0002640

MONITORING PERIOD
 FROM 97-11-01 TO 97-11-30

PARAMETER (32-37)

PH

00400 1 0 0
 EFFLUENT GROSS VALUE

SOLIDS, TOTAL
 SUSPENDED

00530 1 0 0
 EFFLUENT GROSS VALUE

NITROGEN, AMMONIA
 TOTAL (AS N)

00610 2 0 0
 EFFLUENT NET VALUE

CYANIDE, TOTAL (AS CN)

00720 2 0 0
 EFFLUENT NET VALUE

CHROMIUM, TOTAL (AS CR)

01034 2 0 0
 EFFLUENT NET VALUE

COPPER, TOTAL (AS CU)

01042 2 0 0
 EFFLUENT NET VALUE

LEAD, TOTAL (AS PB)

01051 2 0 0
 EFFLUENT NET VALUE

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 H. H. Holliman, President

Tennessee Eastman Division

TYPED OR PRINTED

PARAMETER (32-37)	(3 Card Only) (46-53)		Quantity or (54-61)		Loading Unit	(4 Card Only) (38-45)		Quality or (46-53)		Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-66)	Sample Type (69-70)
	Average	Requirement	Maximum	Minimum		Average	Minimum	Maximum	Unit					
PH	0	Continuous	N/A
00400 1 0 0 EFFLUENT GROSS VALUE	0	CONTINUOUS	REORDER
SOLIDS, TOTAL SUSPENDED	0	30/30	Composite
00530 1 0 0 EFFLUENT GROSS VALUE	839	1111	2,230	(26)	0	DAILY	COMPOSITE
NITROGEN, AMMONIA TOTAL (AS N)	<31	6000	12000	(26)	0	30/30	Composite
00610 2 0 0 EFFLUENT NET VALUE	6000	12000	12000	(26)	0	DAILY	COMPOSITE
CYANIDE, TOTAL (AS CN)	BDL	BDL	BDL	(26)	0	1/7	Grab
00720 2 0 0 EFFLUENT NET VALUE	14.51	104.83	104.83	(26)	0	WEEKLY	GRAB
CHROMIUM, TOTAL (AS CR)	3.17	25.02	25.02	(26)	0	1/7	Composite
01034 2 0 0 EFFLUENT NET VALUE	12.51	25.02	25.02	(26)	0	WEEKLY	COMPOSITE
COPPER, TOTAL (AS CU)	<0.94	12.51	25.02	(26)	0	1/7	Composite
01042 2 0 0 EFFLUENT NET VALUE	12.51	25.02	25.02	(26)	0	WEEKLY	COMPOSITE
LEAD, TOTAL (AS PB)	BDL	BDL	BDL	(26)	0	1/7	Composite
01051 2 0 0 EFFLUENT NET VALUE	43.03	172.64	172.64	(26)	0	WEEKLY	COMPOSITE
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
Tennessee Eastman Division	43.03	172.64	172.64	(26)	0	WEEKLY	COMPOSITE
TYPED OR PRINTED	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
COMMENT AND EXPLANATION OF ANY VIOLATIONS	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
EPA FORM 3320-1 (REV. 9-88) Previous editions may be used.	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
OFFICER OR AUTHORIZED AGENT	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
SIGNATURE OF PRINCIPAL EXECUTIVE	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
AREA CODE NUMBER	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE
YEAR MO DAY	BDL	BDL	BDL	(26)	0	WEEKLY	COMPOSITE

John F. Welsh
 SIGNATURE OF PRINCIPAL EXECUTIVE

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

MONITORING PERIOD
 FROM 97-11-01 TO 97-11-30

DISCHARGE NUMBER
 002 G

PARAMETER (32-37)	(3 Card Only) (46-53)		Quantity or (54-61)		Loading Unit	(4 Card Only) (38-45)		Quality or (46-53)		Concentration (54-61)	NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
	Average	MON AVG	Maximum	DAILY MAX		Minimum	Average	Maximum	Minimum				
NICKEL, TOTAL (AS NI)	5.96	7.82	7.82	(26)		0.025	0.030	0.025	0.030	(19)	0	1/7	Composite
01067 2 0 0 EFFLUENT NET VALUE	422.84	995.80	995.80	LBS/DAY		1.690	3.980	1.690	3.980	MG/L	0	WEEKLY	COMPOSITE
ZINC, TOTAL (AS ZN)	6.10	8.06	8.06	(26)		0.025	0.031	0.025	0.031	(19)	0	1/7	Composite
01092 2 0 0 EFFLUENT NET VALUE	158.00	317.75	317.75	LBS/DAY		0.635	1.270	0.635	1.270	MG/L	0	WEEKLY	COMPOSITE
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	27.11	32.73	32.73	(03)		*****	*****	*****	*****		0	Continuous	N/A
50050 1 0 0 EFFLUENT GROSS VALUE	REPORT	REPORT	REPORT	MGD		*****	*****	*****	*****		0	CONTINUOUS	RECORDER
BOD, CARBONACEOUS 35 DAY, 20C	827	1,955	1,955	(26)		*****	*****	*****	*****		0	30/30	Composite
80082 2 W 0 EFFLUENT NET VALUE	6000	13000	13000	LBS/DAY		*****	*****	*****	*****		0	DAILY	COMPOSITE
SAMPLE MEASUREMENT													
PERMIT REQUIREMENT													
SAMPLE MEASUREMENT													
PERMIT REQUIREMENT													
SAMPLE MEASUREMENT													
PERMIT REQUIREMENT													
SAMPLE MEASUREMENT													
PERMIT REQUIREMENT													
SAMPLE MEASUREMENT													
PERMIT REQUIREMENT													
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS)													
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER											TELEPHONE		DATE
H. H. Holliman, President											(423) 229-2000		97 - 12 - 10
Tennessee Eastman Division											AREA CODE NUMBER		YEAR MO DAY
TYPED OR PRINTED											OFFICER OR AUTHORIZED AGENT		
COMMENT AND EXPLANATION OF ANY VIOLATIONS													
In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.													
EPA FORM 3320-1 (REV. 9-88) Previous editions may be used.													

PARAMETER (32-37)	LOADING (54-61)	CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			
PH						
00400 1 0 0 EFFLUENT GROSS VALUE			7.6	0	CONTINUOUS	N/A
SOLIDS, TOTAL SUSPENDED			MAXIMUM		CONTINUOUS	RECORDER
00530 1 0 0 EFFLUENT GROSS VALUE				0	31/31	Composite
NITROGEN, AMMONIA TOTAL (AS N)					DAILY	COMPOSITE
00610 2 0 0 EFFLUENT NET VALUE			0.4	0	31/31	Composite
CYANIDE, TOTAL (AS CN)			61		DAILY	COMPOSITE
00720 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Grab
CHROMIUM, TOTAL (AS CR)			0.419		WEEKLY	GRAB
01034 2 0 0 EFFLUENT NET VALUE			0.012	0	1/7	Composite
COPPER, TOTAL (AS CU)			0.050		WEEKLY	COMPOSITE
01042 2 0 0 EFFLUENT NET VALUE			<0.008	0	1/7	Composite
LEAD, TOTAL (AS PB)			0.050		WEEKLY	COMPOSITE
01051 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Composite
NAME/TITLE, PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED						

PARAMETER (32-37)	LOADING (54-61)	CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			
PH						
00400 1 0 0 EFFLUENT GROSS VALUE			7.6	0	CONTINUOUS	N/A
SOLIDS, TOTAL SUSPENDED			MAXIMUM		CONTINUOUS	RECORDER
00530 1 0 0 EFFLUENT GROSS VALUE				0	31/31	Composite
NITROGEN, AMMONIA TOTAL (AS N)					DAILY	COMPOSITE
00610 2 0 0 EFFLUENT NET VALUE			0.4	0	31/31	Composite
CYANIDE, TOTAL (AS CN)			61		DAILY	COMPOSITE
00720 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Grab
CHROMIUM, TOTAL (AS CR)			0.419		WEEKLY	GRAB
01034 2 0 0 EFFLUENT NET VALUE			0.012	0	1/7	Composite
COPPER, TOTAL (AS CU)			0.050		WEEKLY	COMPOSITE
01042 2 0 0 EFFLUENT NET VALUE			<0.008	0	1/7	Composite
LEAD, TOTAL (AS PB)			0.050		WEEKLY	COMPOSITE
01051 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Composite
NAME/TITLE, PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED						

PARAMETER (32-37)	LOADING (54-61)	CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			
PH						
00400 1 0 0 EFFLUENT GROSS VALUE			7.6	0	CONTINUOUS	N/A
SOLIDS, TOTAL SUSPENDED			MAXIMUM		CONTINUOUS	RECORDER
00530 1 0 0 EFFLUENT GROSS VALUE				0	31/31	Composite
NITROGEN, AMMONIA TOTAL (AS N)					DAILY	COMPOSITE
00610 2 0 0 EFFLUENT NET VALUE			0.4	0	31/31	Composite
CYANIDE, TOTAL (AS CN)			61		DAILY	COMPOSITE
00720 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Grab
CHROMIUM, TOTAL (AS CR)			0.419		WEEKLY	GRAB
01034 2 0 0 EFFLUENT NET VALUE			0.012	0	1/7	Composite
COPPER, TOTAL (AS CU)			0.050		WEEKLY	COMPOSITE
01042 2 0 0 EFFLUENT NET VALUE			<0.008	0	1/7	Composite
LEAD, TOTAL (AS PB)			0.050		WEEKLY	COMPOSITE
01051 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Composite
NAME/TITLE, PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED						

PARAMETER (32-37)	LOADING (54-61)	CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			
PH						
00400 1 0 0 EFFLUENT GROSS VALUE			7.6	0	CONTINUOUS	N/A
SOLIDS, TOTAL SUSPENDED			MAXIMUM		CONTINUOUS	RECORDER
00530 1 0 0 EFFLUENT GROSS VALUE				0	31/31	Composite
NITROGEN, AMMONIA TOTAL (AS N)					DAILY	COMPOSITE
00610 2 0 0 EFFLUENT NET VALUE			0.4	0	31/31	Composite
CYANIDE, TOTAL (AS CN)			61		DAILY	COMPOSITE
00720 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Grab
CHROMIUM, TOTAL (AS CR)			0.419		WEEKLY	GRAB
01034 2 0 0 EFFLUENT NET VALUE			0.012	0	1/7	Composite
COPPER, TOTAL (AS CU)			0.050		WEEKLY	COMPOSITE
01042 2 0 0 EFFLUENT NET VALUE			<0.008	0	1/7	Composite
LEAD, TOTAL (AS PB)			0.050		WEEKLY	COMPOSITE
01051 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Composite
NAME/TITLE, PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED						

PARAMETER (32-37)	LOADING (54-61)	CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			
PH						
00400 1 0 0 EFFLUENT GROSS VALUE			7.6	0	CONTINUOUS	N/A
SOLIDS, TOTAL SUSPENDED			MAXIMUM		CONTINUOUS	RECORDER
00530 1 0 0 EFFLUENT GROSS VALUE				0	31/31	Composite
NITROGEN, AMMONIA TOTAL (AS N)					DAILY	COMPOSITE
00610 2 0 0 EFFLUENT NET VALUE			0.4	0	31/31	Composite
CYANIDE, TOTAL (AS CN)			61		DAILY	COMPOSITE
00720 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Grab
CHROMIUM, TOTAL (AS CR)			0.419		WEEKLY	GRAB
01034 2 0 0 EFFLUENT NET VALUE			0.012	0	1/7	Composite
COPPER, TOTAL (AS CU)			0.050		WEEKLY	COMPOSITE
01042 2 0 0 EFFLUENT NET VALUE			<0.008	0	1/7	Composite
LEAD, TOTAL (AS PB)			0.050		WEEKLY	COMPOSITE
01051 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Composite
NAME/TITLE, PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED						

PARAMETER (32-37)	LOADING (54-61)	CONCENTRATION (54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			
PH						
00400 1 0 0 EFFLUENT GROSS VALUE			7.6	0	CONTINUOUS	N/A
SOLIDS, TOTAL SUSPENDED			MAXIMUM		CONTINUOUS	RECORDER
00530 1 0 0 EFFLUENT GROSS VALUE				0	31/31	Composite
NITROGEN, AMMONIA TOTAL (AS N)					DAILY	COMPOSITE
00610 2 0 0 EFFLUENT NET VALUE			0.4	0	31/31	Composite
CYANIDE, TOTAL (AS CN)			61		DAILY	COMPOSITE
00720 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Grab
CHROMIUM, TOTAL (AS CR)			0.419		WEEKLY	GRAB
01034 2 0 0 EFFLUENT NET VALUE			0.012	0	1/7	Composite
COPPER, TOTAL (AS CU)			0.050		WEEKLY	COMPOSITE
01042 2 0 0 EFFLUENT NET VALUE			<0.008	0	1/7	Composite
LEAD, TOTAL (AS PB)			0.050		WEEKLY	COMPOSITE
01051 2 0 0 EFFLUENT NET VALUE			BDL	0	1/7	Composite
NAME/TITLE, PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED						

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.
 EPA FORM 3320-1 (REV. 9-88) Previous editions may be used.

PERMITTEE NAME/ADDRESS:
 TN EASTMAN DIVISION
 DIVISION OF EASTMAN CHEMICAL CO.
 P.O. BOX 1993
 KINGSPOET, TN 37662-5393

Facility: TN EASTMAN - KINGSPOET
 Location: SULLIVAN COUNTY TN 37662-5393

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

TN0002640
 PERMIT NUMBER


002 G
 DISCHARGE NUMBER

MAJOR (SUBR 06)
 F - FINAL
 INDUSTRIAL PROCESS WASTEWATER
 EFFLUENT

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD
 FROM 97 - 12 - 01 TO 97 - 12 - 31

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53)	Quantity or Loading (54-61)		(4 Card Only) (38-45)	Quality or Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	Maximum		Unit	Minimum			
NICKEL, TOTAL (AS NI)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	<3.36	4.91	(26)	<0.015	0.024	0	1/7	Composite
		422.84 MON AVG	995.80 DAILY MAX	LBS/DAY	1.690 MON AVG	3.980 DAILY MAX			
ZINC, TOTAL (AS ZN)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	7.63	9.86	(26)	0.035	0.047	0	1/7	Composite
		158.00 MON AVG	317.75 DAILY MAX	LBS/DAY	0.635 MON AVG	1.270 DAILY MAX			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT PERMIT REQUIREMENT	25.74	30.87	(03)	*****	*****	0	Continuous	N/A
		REPORT MON AVG	REPORT DAILY MAX	MGD	*****	*****			
BOD, CARBONACEOUS	SAMPLE MEASUREMENT PERMIT REQUIREMENT	612	1,436	(26)	*****	*****	0	31/31	Composite
		6000 MON AVG	13000 DAILY MAX	LBS/DAY	*****	*****			
80082 2 W 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT				*****	*****		DAILY	COMPOSITE
					*****	*****			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	SAMPLE MEASUREMENT PERMIT REQUIREMENT						TELEPHONE		
							DATE		
H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER:  OFFICER OR AUTHORIZED AGENT (423) 229-2000 AREA CODE NUMBER 98 - 01 - 13 YEAR MO. DAY									


I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 31 USC 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND/OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 3 YEARS.)

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 (Reference all attachments here)

In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.

EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PARAMETER (32-37) Sample Type (69-70)

PARAMETER (32-37)	MEASUREMENT	(3 Card Only) (46-53)			(4 Card Only) (38-45)			Quality or Concentration (46-53) (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)	
		Average	Maximum	Unit	Minimum	Average	Maximum	Unit	Unit				
32102 2 0 0 EFFLUENT NET VALUE 1,2-DICHLOROETHANE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	50 MON AVG	951 DAILY MAX	LBS/DAY	BDL	0.018 MON AVG	0.038 DAILY MAX	MG/L	0.038 DAILY MAX	0	QUARTERLY	GRAB	
32103 2 0 0 EFFLUENT NET VALUE CHLOROFORM	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	1501 MON AVG	5279 DAILY MAX	LBS/DAY	BDL	0.068 MON AVG	0.211 DAILY MAX	MG/L	0.211 DAILY MAX	0	QUARTERLY	GRAB	
32106 2 0 0 EFFLUENT NET VALUE TOLUENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	526 MON AVG	1151 DAILY MAX	LBS/DAY	BDL	0.021 MON AVG	0.046 DAILY MAX	MG/L	0.046 DAILY MAX	0	QUARTERLY	GRAB	
34010 2 0 0 EFFLUENT NET VALUE ACENAPHTHYLENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	1051 MON AVG	2002 DAILY MAX	LBS/DAY	BDL	0.026 MON AVG	0.080 DAILY MAX	MG/L	0.080 DAILY MAX	0	QUARTERLY	GRAB	
34200 2 0 0 EFFLUENT NET VALUE ACENAPHTHENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	2200 MON AVG	406 DAILY MAX	LBS/DAY	BDL	0.008 MON AVG	0.016 DAILY MAX	MG/L	0.016 DAILY MAX	0	QUARTERLY	GRAB	
34205 2 0 0 EFFLUENT NET VALUE ACRYLONITRILE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	550 MON AVG	1476 DAILY MAX	LBS/DAY	BDL	0.022 MON AVG	0.059 DAILY MAX	MG/L	0.059 DAILY MAX	0	QUARTERLY	GRAB	
34215 2 0 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	(19)	BDL	BDL	0	2/Quarter	Grab	
	PERMIT REQUIREMENT	2402 MON AVG	6055 DAILY MAX	LBS/DAY	BDL	0.096 MON AVG	0.242 DAILY MAX	MG/L	0.242 DAILY MAX	0	QUARTERLY	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER													
H. H. Holliman, President													
Tennessee Eastman Division													
TYPED OR PRINTED													
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  OFFICER OR AUTHORIZED AGENT													
										AREA CODE NUMBER		YEAR MO DAY	
										(423) 229-2000		98 - 01 - 13	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.

EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: **TN EASTMAN DIVISION**
DIVISION OF EASTMAN CHEMICAL CO.
P.O. BOX 1993
KINGSPORT, TN 37662-5393
 Facility: **TN EASTMAN - KINGSPORT**
 Location: **SULLIVAN COUNTY TN 37662-5393**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 MAJOR (SUBR 06)
 F - FINAL
 PROCESSED WW QUARTERLY REPORT
 EFFLUENT

DISCHARGE MONITORING REPORT (DMR)
 002 Q
 DISCHARGE NUMBER

TN0002640
 PERMIT NUMBER

FORM APPROVED
 OMB No. 2040-0004

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) (46-53)		Loading Unit	(4 Card Only) (38-45)		Quality or Concentration (46-53)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	Maximum		Minimum	Average	Maximum	Unit			
ANTHRACENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	BDL	BDL	0	2/Quarter	Grab
34220 2 0 0	PERMIT REQUIREMENT	0.25 MON. AVG	0.41 DAILY MAX	LBS/DAY	BDL	0.002 DAILY MAX	0.001 MON. AVG	0.002 DAILY MAX	0	QUARTERLY	GRAB
BENZENE, DISSOLVED	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	BDL	BDL	0	2/Quarter	Grab
34235 2 0 0	PERMIT REQUIREMENT	9.26 MON. AVG	34.03 DAILY MAX	LBS/DAY	BDL	0.136 DAILY MAX	0.037 MON. AVG	0.136 DAILY MAX	0	QUARTERLY	GRAB
BENZO (K) FLUORANTHENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	BDL	BDL	0	2/Quarter	Grab
34242 2 0 0	PERMIT REQUIREMENT	2.00 MON. AVG	4.06 DAILY MAX	LBS/DAY	BDL	0.016 DAILY MAX	0.008 MON. AVG	0.016 DAILY MAX	0	QUARTERLY	GRAB
BENZO (A) PYRENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	BDL	BDL	0	2/Quarter	Grab
34247 2 0 0	PERMIT REQUIREMENT	2.00 MON. AVG	4.06 DAILY MAX	LBS/DAY	BDL	0.016 DAILY MAX	0.008 MON. AVG	0.016 DAILY MAX	0	QUARTERLY	GRAB
CHLOROBENZENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	BDL	BDL	0	2/Quarter	Grab
34301 2 0 0	PERMIT REQUIREMENT	3.75 MON. AVG	7.01 DAILY MAX	LBS/DAY	BDL	0.028 DAILY MAX	0.015 MON. AVG	0.028 DAILY MAX	0	QUARTERLY	GRAB
CHRYSENE	SAMPLE MEASUREMENT	BDL	BDL	(26)	BDL	BDL	BDL	BDL	0	2/Quarter	Grab
34320 2 0 0	PERMIT REQUIREMENT	0.25 MON. AVG	0.41 DAILY MAX	LBS/DAY	BDL	0.002 DAILY MAX	0.001 MON. AVG	0.002 DAILY MAX	0	QUARTERLY	GRAB
DIETHYL PHTHALATE	SAMPLE MEASUREMENT	0.26	0.26	(26)	0.001	0.001	0.001	0.001	0	2/Quarter	Grab
34336 2 0 0	PERMIT REQUIREMENT	20.27 MON. AVG	50.79 DAILY MAX	LBS/DAY	0.081 MON. AVG	0.203 DAILY MAX	0.081 MON. AVG	0.203 DAILY MAX	0	QUARTERLY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<p> H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED OFFICER OR AUTHORIZED AGENT </p>										
<p> SIGNATURE OF PRINCIPAL EXECUTIVE <i>John F. Webb</i> TELEPHONE (423) 229-2000 AREA CODE NUMBER 98 - 01 - 13 YEAR MO DAY </p>											

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.
 EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

FORM APPROVED
 OMB No. 2040-0004

002 Q
 DISCHARGE NUMBER

MONITORING PERIOD
 FROM 97 - 10 - 01 TO 97 - 12 - 31

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) (46-53)		Loading Unit	(4 Card Only) (38-45)		Concentration Maximum (54-61)	NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	Maximum		Minimum	Average				
DIMETHYL PHTHALATE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34341 2 0 0	PERMIT REQUIREMENT	1176 MON AVG DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	*****	0.047 DAILY MAX	0	QUARTERLY	GRAB
FLUORANTHENE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34376 2 0 0	PERMIT REQUIREMENT	1707 MON AVG DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	*****	0.068 DAILY MAX	0	QUARTERLY	GRAB
FLUORENE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34381 2 0 0	PERMIT REQUIREMENT	0.25 MON AVG DAILY MAX	0.002 DAILY MAX	LBS/DAY	*****	*****	0.002 DAILY MAX	0	QUARTERLY	GRAB
HEXACHLOROBUTADIENE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34391 2 0 0	PERMIT REQUIREMENT	16.00 MON AVG DAILY MAX	0.049 DAILY MAX	LBS/DAY	*****	*****	0.049 DAILY MAX	0	QUARTERLY	GRAB
HEXACHLOROETHANE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34396 2 0 0	PERMIT REQUIREMENT	13.51 MON AVG DAILY MAX	0.054 DAILY MAX	LBS/DAY	*****	*****	0.054 DAILY MAX	0	QUARTERLY	GRAB
METHYL CHLORIDE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34418 2 0 0	PERMIT REQUIREMENT	1152 MON AVG DAILY MAX	0.190 DAILY MAX	LBS/DAY	*****	*****	0.190 DAILY MAX	0	QUARTERLY	GRAB
METHYLENE CHLORIDE	MEASUREMENT	BDL	BDL	(26)	*****	*****	BDL	0	2/Quarter	Grab
34423 2 0 0	PERMIT REQUIREMENT	10.01 MON AVG DAILY MAX	0.089 DAILY MAX	LBS/DAY	*****	*****	0.089 DAILY MAX	0	QUARTERLY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	H. H. Holliman, President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>John F. White</i> TELEPHONE (423) 229-2000 AREA CODE NUMBER (423) 229-2000 YEAR MO DAY 98 - 01 - 13									

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.
 EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS:
 TN EASTMAN DIVISION
 DIVISION OF EASTMAN CHEMICAL CO.
 P.O. BOX 1993
 KINGSPOST, TN 37662-5393

Facility: TN EASTMAN - KINGSPOST
 Location: SULLIVAN COUNTY TN 37662-5393

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

TN0002640
 PERMIT NUMBER

002 Q
 DISCHARGE NUMBER

MAJOR (SUBR 06)
 F - FINAL

PROCESSED WW QUARTERLY REPORT
 EFFLUENT


*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD

FROM 97 - 10 - 01 TO 97 - 12 - 31

PARAMETER (32-37)	MEASUREMENT REQUIREMENT	(3 Card Only) (46-53)		Quantity or (54-61)		Loading Unit	(4 Card Only) (38-45)		Quality or (46-53)		Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-66)	Sample Type (69-70)
		Average	Maximum	Minimum	Maximum		Minimum	Average	Maximum	Unit					
NITROBENZENE	SAMPLE MEASUREMENT	*****	BDL	*****	BDL	(26)	*****	*****	*****	*****	BDL	(19)	0	2/Quarter	Grab
34447 2 0 0	PERMIT REQUIREMENT	6.76 MON. AVG	17.01 DAILY MAX	*****	*****	LBS/DAY	*****	0.027 MON. AVG	*****	0.068 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
PHENANTHRENE	SAMPLE MEASUREMENT	*****	BDL	*****	BDL	(26)	*****	*****	*****	*****	BDL	(19)	0	2/Quarter	Grab
34461 2 0 0	PERMIT REQUIREMENT	0.25 MON. AVG	0.41 DAILY MAX	*****	*****	LBS/DAY	*****	0.001 MON. AVG	*****	0.002 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
PYRENE	SAMPLE MEASUREMENT	*****	BDL	*****	BDL	(26)	*****	*****	*****	*****	BDL	(19)	0	2/Quarter	Grab
34469 2 0 0	PERMIT REQUIREMENT	0.25 MON. AVG	0.41 DAILY MAX	*****	*****	LBS/DAY	*****	0.001 MON. AVG	*****	0.002 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	*****	0.82	*****	0.004	(19)	*****	*****	*****	0.004	(19)	0	2/Quarter	Grab	
34475 2 0 0	PERMIT REQUIREMENT	15.50 MON. AVG	14.01 DAILY MAX	*****	*****	LBS/DAY	*****	0.022 MON. AVG	*****	0.056 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
1,1 - DICHLOROETHANE	SAMPLE MEASUREMENT	*****	BDL	*****	BDL	(26)	*****	*****	*****	*****	BDL	(19)	0	2/Quarter	Grab
34496 2 0 0	PERMIT REQUIREMENT	5.50 MON. AVG	14.76 DAILY MAX	*****	*****	LBS/DAY	*****	0.022 MON. AVG	*****	0.059 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
1,1 - DICHLOROETHYLENE	SAMPLE MEASUREMENT	*****	BDL	*****	BDL	(26)	*****	*****	*****	*****	BDL	(19)	0	2/Quarter	Grab
34501 2 0 0	PERMIT REQUIREMENT	7.00 MON. AVG	6.26 DAILY MAX	*****	*****	LBS/DAY	*****	0.016 MON. AVG	*****	0.025 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
1,1,1 - TRICHLOROETHANE	SAMPLE MEASUREMENT	*****	BDL	*****	BDL	(26)	*****	*****	*****	*****	BDL	(19)	0	2/Quarter	Grab
34506 2 0 0	PERMIT REQUIREMENT	15.25 MON. AVG	13.51 DAILY MAX	*****	*****	LBS/DAY	*****	0.021 MON. AVG	*****	0.054 DAILY MAX	MGL	QUARTERLY	0	QUARTERLY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER H. H. Holliman, President Tennessee Eastman Division TYPED OR PRINTED															
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  OFFICER OR AUTHORIZED AGENT															
AREA CODE NUMBER (423) 229-2000 YEAR MO DAY 98 - 01 - 13															

(Reference all attachments here)

COMMENT AND EXPLANATION OF ANY VIOLATIONS

In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.

EPA FORM 3320-1 (REV. 9-88) Previous editions may be used.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS:
 TN EASTMAN DIVISION
 DIVISION OF EASTMAN CHEMICAL CO.
 P.O. BOX 1993
 KINGSPORT, TN 37662-5393
 Facility: TN EASTMAN - KINGSPORT
 Location: SULLIVAN COUNTY TN 37662-5393


NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 002 Q
 DISCHARGE NUMBER

MAJOR (SUBR 06)
 F - FINAL
 PROCESSED WW QUARTERLY REPORT
 EFFLUENT

FORM APPROVED
 OMB No. 2040-0004

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

MONITORING PERIOD
 FROM 97 - 10 - 01 TO 97 - 12 - 31

PARAMETER (32-37)	(3 Card Only) (46-53)	Quantity or (54-61)		Loading Unit	(4 Card Only) (38-45)		Quality or (46-53)		Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	Maximum		Minimum	Average	Maximum	Unit	Unit				
1,1,2 - TRICHLOROETHANE	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34511 2 0 0	PERMIT REQUIREMENT	5.25	13.51	LBS/DAY	*****	BDL	0.021	0.054	DAILY MAX	MG/L		QUARTERLY	GRAB
BENZO (A) ANTHRACENE	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34526 2 0 0	PERMIT REQUIREMENT	2.00	4.06	LBS/DAY	*****	BDL	0.008	0.016	DAILY MAX	MG/L		QUARTERLY	GRAB
1,2 - DICHLOROBENZENE	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34536 2 0 0	PERMIT REQUIREMENT	19.27	40.78	LBS/DAY	*****	BDL	0.077	0.163	DAILY MAX	MG/L		QUARTERLY	GRAB
1,2 - DICHLOROPROPANE	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34541 2 0 0	PERMIT REQUIREMENT	36.28	57.55	LBS/DAY	*****	BDL	0.153	0.230	DAILY MAX	MG/L		QUARTERLY	GRAB
1,2 - TRANS - DICHLOROETHYLENE	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34546 2 0 0	PERMIT REQUIREMENT	5.25	13.51	LBS/DAY	*****	BDL	0.021	0.054	DAILY MAX	MG/L		QUARTERLY	GRAB
1,2,4 - TRICHLORO - BENZENE	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34551 2 0 0	PERMIT REQUIREMENT	17.01	35.03	LBS/DAY	*****	BDL	0.068	0.140	DAILY MAX	MG/L		QUARTERLY	GRAB
1,3 - DICHLOROPROPENE, TOTAL WEIGHT	MEASUREMENT	*****	BDL	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
34561 2 0 0	PERMIT REQUIREMENT	7.26	11.01	LBS/DAY	*****	BDL	0.029	0.044	DAILY MAX	MG/L		QUARTERLY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER													
H. H. Holliman, President													
Tennessee Eastman Division													
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT													
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT													
TELEPHONE													
(423) 229-2000													
AREA CODE NUMBER													
89 - 01 - 13													
YEAR MO DAY													

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPC-C-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.

EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 5 OF 8

002 Q
 DISCHARGE NUMBER

TN0002640
 PERMIT NUMBER

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

MONITORING PERIOD
 FROM 97 - 10 - 01 TO 97 - 12 - 31

PARAMETER (32-37)	X	(3 Card Only) (46-53)			Loading (54-61)			(4 Card Only) (38-45)			Quality or (46-53)			Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	MON AVG	DAILY MAX	Maximum	Unit	Minimum	MON AVG	DAILY MAX	Unit	Average	MON AVG	DAILY MAX	Maximum	Unit			
1,3 - DICHLOROBENZENE	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34566 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	7.76 MON AVG	11.01 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.044 DAILY MAX	MG/L	0.031 MON AVG	BDL	0.044 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
1,4 - DICHLOROBENZENE	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34571 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	7.76 MON AVG	7.01 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.028 DAILY MAX	MG/L	0.015 MON AVG	BDL	0.028 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
2 - CHLOROPHENOL	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34586 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	7.76 MON AVG	21.52 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.098 DAILY MAX	MG/L	0.031 MON AVG	BDL	0.098 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
2 - NITROPHENOL	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34591 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	10.26 MON AVG	17.26 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.069 DAILY MAX	MG/L	0.041 MON AVG	BDL	0.069 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
2,4 - DICHLOROPHENOL	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34601 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	9.76 MON AVG	28.02 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.112 DAILY MAX	MG/L	0.039 MON AVG	BDL	0.112 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
2,4 - DIMETHYLPHENOL	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34606 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	1.60 MON AVG	9.01 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.036 DAILY MAX	MG/L	0.018 MON AVG	BDL	0.036 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
2,4 - DINITROTOLUENE	SAMPLE MEASUREMENT	*****	BDL	BDL	(26)	*****	BDL	BDL	(19)	*****	BDL	BDL	(19)	0	2/Quarter	Grab		
34611 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	28.27 MON AVG	71.31 DAILY MAX	BDL DAILY MAX	LBS/DAY	*****	BDL	0.285 DAILY MAX	MG/L	0.113 MON AVG	BDL	0.285 DAILY MAX	MG/L	0	QUARTERLY	GRAB		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		<p style="text-align: center;"><i>John F. Webb</i></p> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OFFICER OR AUTHORIZED AGENT																
H. H. Holliman, President																		
Tennessee Eastman Division																		
TYPED OR PRINTED																		
COMMENT AND EXPLANATION OF ANY VIOLATIONS		(Reference all attachments here)																
In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.																		
EPA FORM 3320-1 (REV. 9-88) Previous editions may be used.		(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)																
		AREA CODE NUMBER: (423) 229-2000 YEAR: 98 - 01 - 13 MO: DATE																

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

MONITORING PERIOD
 FROM 97 - 10 - 01 TO 97 - 12 - 31

FROM 97 - 10 - 01 TO 97 - 12 - 31

Facility: TN EASTMAN - KINGSPORT
 Location: SULLIVAN COUNTY TN 37662-5393

PARAMETER (32-37)	MEASUREMENT	(3 Card Only) (46-53)			(4 Card Only) (38-45)			Quality or Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
		Average	Maximum	Unit	Minimum	Average	Maximum	Unit	Unit			
2,4 - DINITROPHENOL	SAMPLE MEASUREMENT	*****	BDL	(26)	*****	BDL	(19)	*****	BDL	0	2/Quarter	Grab
34616 2 0 0	PERMIT REQUIREMENT	17.76 MON AVG	30.77 DAILY MAX	LBS/DAY	*****	0.123 DAILY MAX	MG/L	0.071 MON AVG	0.123 DAILY MAX	0	QUARTERLY	GRAB
2,6 - DINITROTOLUENE	SAMPLE MEASUREMENT	*****	BDL	(26)	*****	BDL	(19)	*****	BDL	0	2/Quarter	Grab
34626 2 0 0	PERMIT REQUIREMENT	63.80 MON AVG	160.38 DAILY MAX	LBS/DAY	*****	0.641 DAILY MAX	MG/L	0.255 MON AVG	0.641 DAILY MAX	0	QUARTERLY	GRAB
4 - NITROPHENOL	SAMPLE MEASUREMENT	*****	BDL	(26)	*****	BDL	(19)	*****	BDL	0	2/Quarter	Grab
34646 2 0 0	PERMIT REQUIREMENT	18.01 MON AVG	31.02 DAILY MAX	LBS/DAY	*****	0.124 DAILY MAX	MG/L	0.072 MON AVG	0.124 DAILY MAX	0	QUARTERLY	GRAB
4,6 - DINITRO - O - CRESOL	SAMPLE MEASUREMENT	*****	4.86	(26)	*****	0.022	(19)	*****	0.022	0	2/Quarter	Grab
34657 2 0 0	PERMIT REQUIREMENT	19.52 MON AVG	69.31 DAILY MAX	LBS/DAY	*****	0.277 DAILY MAX	MG/L	0.078 MON AVG	0.277 DAILY MAX	0	QUARTERLY	GRAB
PHENOL, SINGLE COMPOUND	SAMPLE MEASUREMENT	*****	BDL	(26)	*****	BDL	(19)	*****	BDL	0	2/Quarter	Grab
34694 2 0 0	PERMIT REQUIREMENT	3.75 MON AVG	6.51 DAILY MAX	LBS/DAY	*****	0.026 DAILY MAX	MG/L	0.015 MON AVG	0.026 DAILY MAX	0	QUARTERLY	GRAB
NAPHTHALENE	SAMPLE MEASUREMENT	*****	BDL	(26)	*****	BDL	(19)	*****	BDL	0	2/Quarter	Grab
34696 2 0 0	PERMIT REQUIREMENT	5.50 MON AVG	14.76 DAILY MAX	LBS/DAY	*****	0.059 DAILY MAX	MG/L	0.022 MON AVG	0.059 DAILY MAX	0	QUARTERLY	GRAB
ETHYL BENZENE	SAMPLE MEASUREMENT	*****	BDL	(26)	*****	BDL	(19)	*****	BDL	0	2/Quarter	Grab
37371 2 0 0	PERMIT REQUIREMENT	8.01 MON AVG	27.02 DAILY MAX	LBS/DAY	*****	0.108 DAILY MAX	MG/L	0.032 MON AVG	0.108 DAILY MAX	0	QUARTERLY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<p>H. H. Holliman, President</p> <p>Tennessee Eastman Division</p> <p>TYPED OR PRINTED</p> <p>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER <i>John F. White</i> OFFICER OR AUTHORIZED AGENT</p>											
AREA CODE NUMBER	(423) 229-2000											
YEAR MO DAY	98 - 01 - 13											

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

In addition to taking reasonable steps to prevent instances of noncompliance through the implementation of SPCC and SPCC-type plans, employee training, etc. when a potentially significant instance occurs, we notify the Division and provide information concerning the steps taken or planned to reduce, eliminate, and prevent recurrence of the instance.

EPA FORM 3320-1 (REV. 9-88) Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 7 OF 8

002 Q
 DISCHARGE NUMBER

TN0002640
 PERMIT NUMBER

MONITORING PERIOD
 FROM 97 - 10 - 01 TO 97 - 12 - 31

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53)		Quantity or (54-61)		Loading Unit	(4 Card Only) (38-45)		Quality or (46-53)		Concentration (54-61)		NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)
	Average	PERMIT	Maximum	DAILY MAX		Minimum	Average	Maximum	Unit	Minimum	Maximum			
BIS (2-ETHYLHEXYL) PHTHALATE	25.77	69.81	0.90	(26)	(26)	*****	0.004	*****	0.103	0.279	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
DI - N - BUTYL PHTHALATE	*****	BDL	BDL	(26)	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
VINYL CHLORIDE	*****	BDL	BDL	(26)	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
TRICHLOROETHYLENE	*****	BDL	BDL	(26)	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
HEXACHLOROBENZENE	*****	BDL	BDL	(26)	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
3,4 BENZOFLUORANTHENE	*****	BDL	BDL	(26)	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
CHLOROETHANE	*****	BDL	BDL	(26)	(26)	*****	BDL	*****	*****	BDL	(19)	0	2/Quarter	Grab
EFFLUENT NET VALUE	MON AVG	DAILY MAX	DAILY MAX	LBS/DAY	LBS/DAY	*****	DAILY MAX	*****	MON AVG	DAILY MAX	MGL		QUARTERLY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	T CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 31 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)													
H. H. Holliman, President	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER <i>John F. Webb</i> OFFICER OR AUTHORIZED AGENT													
Tennessee Eastman Division	TYPED OR PRINTED SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OFFICER OR AUTHORIZED AGENT													