

**ENHANCING THE USE OF COALS  
BY GAS REBURNING - SORBENT INJECTION**

Environmental Monitoring Report  
City Water, Light and Power's Lakeside Station Unit 7  
Long Term Testing Period  
October 4, 1993 - June 3, 1994

Prepared for:  
U.S. Department of Energy  
Gas Research Institute  
State of Illinois Department of  
Energy and Natural Resources

Prepared by:  
Energy and Environmental Research Corporation  
18 Mason  
Irvine, California 92718

February, 1995

3305051

## 1.0 INTRODUCTION

Energy and Environmental Research Corporation (EER) has completed demonstrations of Gas Reburning-Sorbent Injection (GR-SI) at two field sites. The discussions which follow pertain to measurements taken from the demonstration at City Water, Light and Power's (CWLP) Lakeside Station Unit 7 in Springfield, Illinois, which was performed under a Clean Coal Technology Program (Round 1) through the principal sponsorship of the U.S. Department of Energy. Cosponsors include the Gas Research Institute, the Illinois State Department of Energy and Natural Resources (ENR) and the host utility. Environmental monitoring was conducted for two purposes, to satisfy the requirements of operating permits granted by the Illinois Environmental Protection Agency (IEPA) and to verify environmental acceptability of the GR-SI process.

The GR-SI demonstration program at Lakeside Unit 7 was performed in three phases. Phase 1 - Design and Permitting, entailed characterization of the host boiler, then finalization of process and engineering design of the GR-SI system. Phase I was initiated in June 1987 and completed in March 1989. Phase II - Construction and Startup, was initiated upon completion of design tasks and was completed in February 1993. Phase III - Operation, Data Collection, Reporting and Disposition, was conducted from July 1993 to June 1994. In Phase III, the GR-SI system was evaluated initially through optimization tests, which are short-term tests in which specific operating parameters are varied to determine their impact on emissions and boiler performance. The optimization testing involved GR only tests, SI only tests, and GR-SI tests. Results from testing, carried out from July 28 to October 1, 1993, were presented in a separate report. Following Optimization Testing, long-term GR-SI operation was initiated to demonstrate the combined technology over an extended period with the unit under dispatch load control. Long-term testing was conducted from October 4, 1993 to June 3, 1994. The environmental monitoring data from this period are presented in this report.

Environmental monitoring in Phases I and II was limited to compliance monitoring as required by IEPA. Adherence to a particulate matter emissions limit of  $0.1 \text{ lb}/10^6 \text{ Btu}$  was determined by monitoring of opacity, with any opacity excursions greater than 30% required for reporting to IEPA. The National Pollutant Discharge Elimination System (NPDES) permit required monitoring of aqueous discharges to Lake Springfield and Sugar Creek. Limits on 30 day average and maximum daily concentrations of specific pollutants are specified by the NPDES permit and vary with the nature of the discharge. The common limits are for pH, total suspended solids and oil/grease. For some aqueous streams, limits of total iron, copper, residual chlorine, are also specified. GR-SI operation was thought potentially to impact outfalls 004 and 008, which are the ash pond discharge and the water runoff from the coal pile, respectively. Outfall 004 has a pH limit of 6 to 9, 30 day average limit of total suspended solids (15 mg/l) and oil/grease (15 mg/l), and daily maximum limit of total suspended solids (30 mg/l) and oil/grease (20 mg/l). Outfall 008 has the same limits for pH, total suspended solids and oil/grease, but additional limits of total iron for 30 day average (2 mg/l) and daily maximum (4 mg/l). Compliance with these limits was determined by weekly or bimonthly monitoring as specified by the NPDES permit.

In Phase III testing of the GR-SI system a wide range of additional measurements were taken by EER to verify that emissions control goals for the project were met and that other discharges were either unaffected or acceptable. Emissions were measured with a Continuous Emissions Monitoring System (CEMS), which extracted gas at the boiler exit. Gas samples were plumed, conditioned by moisture removal and then analyzed by instruments for NO<sub>x</sub>, SO<sub>2</sub>, CO, CO<sub>2</sub>, O<sub>2</sub>, and hydrocarbons (HC). The data were averaged and corrected to a standard O<sub>2</sub> concentration. A wide range of process data from plant instrumentation was also recorded. These included opacity, particulate matter emissions and data presented in the Optimization Testing Environmental Monitoring Report.

## 2.0 GAS REBURNING-SORBENT INJECTION

GR-SI is an advanced pollution control technology designed to reduce emissions of NO<sub>x</sub> and SO<sub>2</sub> by 60% and 50%, respectively, in this application. It has been under development from pilot to full scale for the last two decades. In this program GR-SI has been demonstrated at two coal fired utility boilers in Illinois, with tangential and cyclone firing configuration. GR involves the injection of natural gas in the area above the coal burners to form a fuel rich region in which NO<sub>x</sub> formed in the burner region is reduced by a variety of hydrocarbon fragments and free radicals to N<sub>2</sub>. The quantity of natural gas used is typically in the 15 to 25% gas heat input range. Burnout (Overfire) air is injected higher up in the furnace to burn out the fuel. The flows of coal, burner air, natural gas, and overfire air produce three zones designated as Burner Zone, Reburning Zone, and Burnout Zone, each with its unique stoichiometry. Typical stoichiometries for this unit are 1.1, 0.9, and 1.18 for the three zones, respectively. The SI process involves injection of dry hydrated lime sorbent (Ca(OH)<sub>2</sub>) into the upper furnace cavity for capture of SO<sub>2</sub>. Micron-sized sorbent (mean diameter under 5 microns) is conveyed to the boiler and injected with air. In the upper furnace the sorbent first undergoes calcination to form a highly reactive Calcium Oxide (CaO), which then undergoes sulfation to form Calcium Sulfate (CaSO<sub>4</sub>) and Calcium Sulfite (CaSO<sub>3</sub>). These solids are then collected with the fly ash by the particulate collection device, an Electrostatic Precipitator in the case of Lakeside Unit 7. The SI process is applied typically with a Ca (Sorbent) to S (Coal) molar ratio of 1.5 to 2.5.

Natural gas firing in GR has several environmental benefits in addition to NO<sub>x</sub> control. These include reduction in SO<sub>2</sub> at a level corresponding to the gas heat input, a modest reduction in CO<sub>2</sub>, and acceptable CO emissions from judicious design of the overfire air system. Additional benefits include reductions in the quantity of bottom ash, bottom ash sluice water, and fly ash. The reduction in fly ash should result in lower stack opacity. The emissions of N<sub>2</sub>O, which were not measured at this site, are unaffected by GR as demonstrated at another GR-SI demonstration at Illinois Power Company's Hennepin Station Unit 1. At this site, N<sub>2</sub>O emissions under GR-SI reached a maximum of 4.3 ppm, and typically averaged from 0.5 to 3.2 ppm over the test periods.

The SI process reduces SO<sub>2</sub> emissions by 30 to 50 percent, depending on boiler-specific factors, the sorbent type, and injection details. The major GR-SI waste product (fly ash/spent sorbent mixture) is conveyed pneumatically from the ESP hoppers to a special silo. A dustless unloader

is then used to convey the ash with water addition to trucks, which then carry it to a landfill for disposal.

### 3.0 DESCRIPTION OF HOST UNIT

City Water, Light and Power's Lakeside Station Unit 7 is a 33 MW<sub>e</sub> cyclone fired boiler. At its maximum continuous rating the unit produces 320,000 lb/hr steam, at a temperature of 910°F and pressure of 875 psig. It fires crushed high sulfur Illinois bituminous coal in 2 7-ft diameter cyclone furnaces. Flue gases flow through a refractory-lined primary furnace, a secondary furnace, secondary and primary superheaters, a two-drum steam generating bank, a regenerative air heater, an ESP, then to the stack. It operates in cycling service normally coming on line during the summer months. It is equipped with an F. L. Smidt ESP, which receives flue from both Units 7 and 8. The ESP has a Specific Collection Area (SCA) of 500 ft<sup>2</sup>/ 1000 ACFM under full load of both units. Typically, both bottom and fly ash are sluiced to an on site ash pond, but due to changes in the fly ash composition under GR-SI, this was discontinued during the course of this project. Under GR-SI operation, the bottom ash sluicing to the pond continued, but fly ash was collected dry in an ash silo and then trucked to a landfill.

### 4.0 RESULTS

#### 4.1 AIR EMISSIONS

Extensive air emissions measurements were made under three conditions: GR-SI, GR, and SI. The results of CEMS data averaged over the test periods are tabulated in Tables 1 through 3. Table 1 lists data from GR-SI operation, Table 2 shows GR-only data and Table 3 shows SI-only data. For comparison, the pre-project baseline emissions from the unit under full load (33 MW<sub>e</sub>), measured in 1988, are summarized below.

<u>Unit</u> lb/10 <sup>6</sup> Btu	<u>NO<sub>x</sub></u> 0.95	<u>SO<sub>2</sub></u> 5.05	<u>Particulate Matter</u> 0.00733
---------------------------------------	-------------------------------	-------------------------------	--------------------------------------

Baseline testing conducted in Phase III (1993 - 1994) indicated that the NO<sub>x</sub> emissions vary with electric load according to the equation: NO<sub>x</sub> = 0.522 + 0.0134\*(load). This equation may be used over the normal boiler load range of 19 to 34 MW<sub>e</sub>. In Phase III, baseline SO<sub>2</sub> emissions were found to be 5.9 lb/10<sup>6</sup> Btu.

GR-SI testing was conducted intermittently from 10/5/93 to 6/2/94. The total duration of GR-SI operation was 200.3 hours, with average gas heat input of 22% and Ca/S molar ratio of 1.79. The average emissions for all GR-SI tests were:

<u>Species</u> Unit	<u>NO<sub>x</sub></u> ppm 248	<u>NO<sub>x</sub></u> lb/10 <sup>6</sup> Btu 0.331	<u>SO<sub>2</sub></u> ppm 1312	<u>SO<sub>2</sub></u> lb/10 <sup>6</sup> Btu 2.441	<u>CO<sub>2</sub></u> % 14.2	<u>CO</u> ppm 184
------------------------	-------------------------------------	--	--------------------------------------	--	------------------------------------	-------------------------

TABLE 1. GRSI LONG-TERM TESTING EMISSIONS SUMMARY.

Test I. D.	Test Date	Gross Power (MW)	Gas Heat (% 10ft)	Ca/S Molar Ratio	CEMS O2 (% dry)	Plant O2 (% wet)	COc (ppm @ 3% O2)	CO2c (% @ 3% O2)	NOxc (ppm @ 3% O2)	NOx (lb/MBtu)	SO2c (ppm @ 3% O2)	SO2 (lb/MBtu)
GRSI-1B	5-Oct-93	33	22.2	1.63	4.42	3.41	49	14.2	304	0.405	1350	2.510
GRSI-1C	5-Oct-93	33	22.3	1.68	4.76	3.63	35	14.2	327	0.435	1358	2.527
GRSI-1A	5-Oct-93	33	22.0	1.77	3.52	2.56	187	14.3	280	0.372	1440	2.676
GRSI-13A	6-Oct-93	23	26.2	1.90	4.02	2.71	352	14.1	171	0.227	1425	2.636
GRSI-13B	6-Oct-93	24	20.4	1.90	3.78	2.52	194	14.4	210	0.280	1474	2.742
GRSI-13D	6-Oct-93	24	14.9	1.91	3.43	2.46	66	14.6	273	0.365	1470	2.774
GRSI-11A2	6-Oct-93	24	26.2	1.97	3.78	2.75	117	14.2	220	0.293	1269	2.367
GRSI-13C	6-Oct-93	24	17.5	2.00	3.64	2.44	177	14.5	228	0.304	1400	2.625
GRSI-3C	7-Oct-93	33	18.6	1.75	3.36	2.47	173	14.4	283	0.377	1388	2.592
GRSI-3B	7-Oct-93	33	20.7	1.75	3.37	2.48	141	14.3	267	0.356	1280	2.382
GRSI-3D	7-Oct-93	34	14.2	1.87	3.40	2.60	52	14.6	366	0.492	1530	2.877
GRSI-3A	7-Oct-93	33	25.6	1.90	3.37	2.40	346	14.0	238	0.315	1125	2.091
GRSI-15A	11-Oct-93	24	22.2	1.10	3.66	2.63	295	14.1	193	0.257	1640	3.047
GRSI-15B	11-Oct-93	24	22.2	1.80	3.34	2.41	446	14.1	179	0.238	1342	2.499
GRSI-12A	11-Oct-93	24	21.8	1.82	4.78	3.52	193	14.0	219	0.292	1618	3.011
GRSI-12B	11-Oct-93	24	22.2	1.90	4.43	3.28	68	14.1	256	0.341	1415	2.631
GRSI-15C	11-Oct-93	24	22.4	2.70	3.33	2.40	441	14.1	182	0.243	1231	2.301
GRSI-101B	2-Nov-93	32	23.4	1.49	4.05	3.13	108	14.3	289	0.384	1480	2.750
GRSI-101B	11-Nov-93	31	23.3	1.72	3.96	2.81	154	14.3	267	0.356	1391	2.584
GRSI-101C	11-Nov-93	31	23.0	1.74	4.01	2.79	158	14.2	298	0.396	1234	2.290
GRSI-101A	11-Nov-93	31	22.9	1.75	4.13	3.03	75	14.2	272	0.362	1332	2.472
GRSI-201B	12-Nov-93	23	23.3	2.06	4.05	2.90	252	14.2	200	0.265	1302	2.426
GRSI-202A	12-Nov-93	23	23.0	2.09	5.66	3.27	110	13.8	242	0.321	1030	1.916
GRSI-201A	12-Nov-93	23	23.1	2.12	4.77	3.01	256	14.1	195	0.259	1148	2.124
GRSI-202B	12-Nov-93	23	23.3	2.12	6.47	3.77	56	13.7	271	0.360	1184	2.198
GRSI-201C	12-Nov-93	23	23.2	2.14	3.75	2.57	256	14.2	212	0.281	1092	2.038
GRSI 15-Nov-93	26	22.2	1.67	5.72	3.51	56	14.1	259	0.343	1365	2.528	
GRSI 16-Nov-93	23	22.2	1.97	5.16	3.42	83	14.0	233	0.310	1147	2.137	
GRSI 17-Nov-93	23	22.1	1.74	4.66	3.41	66	14.3	244	0.325	1414	2.638	
GRSI 16-Feb-94	29	21.5	1.33	4.65	3.74	85	14.2	302	0.402	1529	2.852	
GRSI 18-Feb-94	27	20.0	1.38	4.93	3.28	99	14.2	277	0.369	1448	2.700	
GRSI 28-Mar-94	30	21.7	1.21	4.89	3.57	83	14.3	312	0.414	1703	3.169	
GRSI 29-Mar-94	28	22.4	1.69	4.49	3.32	150	14.2	282	0.375	1181	2.201	
GRSI 30-Mar-94	31	22.2	1.78	4.65	3.32	129	14.2	286	0.380	1136	2.113	
GRSI 31-Mar-94	32	22.6	1.66	4.33	3.31	199	14.2	252	0.337	1250	2.336	
GRSI 4-Apr-94	30	23.3	1.79	4.23	3.13	284	14.1	214	0.285	1300	2.415	
GRSI 6-Apr-94	31	21.8	1.57	4.01	3.05	140	14.3	245	0.327	1254	2.338	
GRSI-20	7-Apr-94	20	22.5	2.10	5.67	4.11	85	13.9	209	0.279	1210	2.245
GRSI-25	7-Apr-94	25	22.8	1.56	5.43	3.65	157	14.2	212	0.282	1402	2.605
GRSI-30	7-Apr-94	31	22.8	1.63	4.52	2.98	181	14.2	251	0.334	1182	2.193
GRSI-25	7-Apr-94	25	22.9	1.94	4.94	3.26	238	14.2	210	0.281	1241	2.305
GRSI 8-Apr-94	25	22.8	1.97	4.68	3.34	239	14.2	215	0.285	1163	2.155	
GRSI-23-24	13-May-94	24	21.8	1.86	4.20	3.16	143	14.1	208	0.277	1249	2.315
GRSI-19-28	13-May-94	28	19.5	1.65	3.77	2.59	203	14.1	243	0.325	1269	2.372
GRSI-22-28	13-May-94	28	21.8	1.77	4.35	3.20	206	13.9	270	0.364	1192	2.211
GRSI 14-May-94	31	21.7	1.72	4.21	2.97	164	14.0	241	0.321	1183	2.203	
GRSI-23-30	15-May-94	30	22.0	1.73	4.22	3.14	164	14.0	269	0.359	998	1.855
GRSI-23-30	16-May-94	30	22.1	1.76	3.85	2.94	322	14.2	237	0.317	1184	2.272
GRSI-20-25	16-May-94	25	20.8	1.75	4.22	3.16	274	14.3	219	0.291	1252	2.331
GRSI-1	17-May-94	25	20.6	1.57	4.40	3.34	330	14.3	247	0.331	1217	2.222
GRSI-2	17-May-94	25	22.3	2.06	4.00	2.89	254	14.2	247	0.329	1300	2.400
GRSI-23-33	2-Jun-94	33	22.1	1.64	3.82	2.30	375	14.6	270	0.359	1487	2.766
GRSI-23-31	2-Jun-94	31	22.7	1.81	4.47	2.79	292	14.5	256	0.340	1308	2.429
Average GRSI		28	21.9	1.79	4.30	3.03	184	14.2	248	0.331	1312	2.441

Note: MBtu = Million Btu

TABLE 2. GR LONG-TERM TESTING EMISSIONS SUMMARY.

Test I. D.	Test Date	Gross Power (MW)	Gas Heat (% totl)	Ca/S Molar Ratio	CEMS O2 (% dry)	Plant O2 (% wet)	COe (ppm @ 3% O2)	CO2c (% @ 3% O2)	NOxe (ppm @ 3% O2)	NOx (lb/MBtu)	SO2c (ppm @ 3% O2)	SO2 (lb/MBtu)
GR 113B	26-Oct-93	24	24.6	0.00	4.53	3.49	198	14.2	235	0.312	2333	4.330
GR 113A	26-Oct-93	25	24.6	0.00	4.50	3.38	454	14.3	210	0.279	2310	4.287
GR 113C	26-Oct-93	25	25.0	0.00	4.16	3.25	221	14.2	232	0.308	2293	4.254
GR 111A	26-Oct-93	25	26.0	0.00	3.76	2.70	520	14.2	200	0.265	2272	4.210
GR 111B	26-Oct-93	25	20.1	0.00	3.53	2.67	418	14.5	224	0.298	2407	4.489
GR 101B	27-Oct-93	34	24.7	0.00	4.28	3.32	136	14.4	333	0.441	2397	4.449
GR 101C	27-Oct-93	34	24.9	0.00	4.21	3.39	46	14.4	333	0.442	2372	4.400
GR 101D	27-Oct-93	34	24.9	0.00	4.28	3.37	27	14.4	334	0.443	2332	4.327
GR 101A	27-Oct-93	34	24.7	0.00	4.52	3.30	283	14.3	292	0.387	2322	4.309
GR 104A	27-Oct-93	34	24.9	0.00	4.36	3.34	29	14.3	325	0.431	2298	4.262
GR 104B	27-Oct-93	34	24.9	0.00	4.38	3.34	42	14.3	335	0.444	2294	4.256
GR 104C	27-Oct-93	34	24.9	0.00	4.39	3.35	51	14.2	349	0.462	2301	4.268
GR 102A	28-Oct-93	33	23.7	0.00	4.31	3.33	74	14.3	341	0.453	2415	4.487
GR 102B	28-Oct-93	33	20.1	0.00	4.01	3.14	45	14.4	355	0.473	2485	4.633
GR 102C	28-Oct-93	33	15.1	0.00	3.81	3.06	18	14.6	405	0.544	2628	4.928
GR 103B	28-Oct-93	33	25.7	0.00	4.87	3.84	25	14.0	343	0.454	2368	4.388
GR 103A	28-Oct-93	33	25.6	0.00	3.71	2.73	323	14.1	289	0.384	2365	4.383
GR 112A2	29-Oct-93	24	21.4	0.00	3.81	2.99	383	14.5	234	0.311	2471	4.601
GR 112A	29-Oct-93	24	24.1	0.00	4.09	3.15	297	14.3	232	0.308	2399	4.454
GR 112B	29-Oct-93	24	20.4	0.00	3.89	3.05	175	14.5	250	0.334	2489	4.640
GR 112C	29-Oct-93	24	14.9	0.00	3.80	3.05	58	14.8	310	0.413	2637	4.946
GR-106B	10-Nov-93	32	25.0	0.00	3.78	2.53	520	14.3	242	0.320	2371	4.399
GR-107C	10-Nov-93	32	25.1	0.00	3.79	2.48	521	14.3	284	0.376	2351	4.359
GR-107B	10-Nov-93	32	25.1	0.00	3.71	2.55	518	14.2	255	0.338	2345	4.350
GR-106C	10-Nov-93	32	25.3	0.00	4.32	3.08	537	14.3	249	0.330	2340	4.339
GR-106B	10-Nov-93	32	25.0	0.00	3.78	2.53	520	14.3	242	0.320	2371	4.399
GR-107C	10-Nov-93	32	25.1	0.00	3.79	2.48	521	14.3	284	0.376	2351	4.359
GR-107B	10-Nov-93	32	25.1	0.00	3.71	2.55	518	14.2	255	0.338	2345	4.350
GR-106C	10-Nov-93	32	25.3	0.00	4.32	3.08	537	14.3	249	0.330	2340	4.339
GR	15-Nov-93	26	23.0	0.00	5.10	3.45	195	14.3	222	0.295	2414	4.489
GR	16-Nov-93	23	22.0	0.00	4.35	3.26	250	14.3	230	0.306	2337	4.366
GR 114 A	17-Nov-93	23	23.0	0.00	4.94	3.86	50	14.4	226	0.301	2350	4.368
GR 114 C	17-Nov-93	23	23.1	0.00	4.90	3.70	46	14.3	246	0.327	2377	4.418
GR	17-Nov-93	23	22.4	0.78	4.60	3.64	68	14.4	242	0.321	2190	4.086
GR	23-Nov-93	23	22.2	0.00	4.13	3.36	223	14.3	228	0.304	2432	4.526
GR	16-Feb-94	26	21.4	0.00	4.51	3.45	228	14.3	307	0.412	2440	4.548
GR	17-Feb-94	26	22.2	0.00	5.14	3.84	83	14.1	285	0.380	2360	4.389
GR	18-Feb-94	28	21.2	0.00	4.51	3.55	108	14.3	281	0.377	2418	4.508
GR	28-Mar-94	30	22.2	0.00	4.13	3.22	134	14.5	273	0.364	2462	4.582
GR	29-Mar-94	28	20.9	0.01	4.20	3.45	189	14.5	314	0.419	2500	4.658
GR	6-Apr-94	31	20.1	0.00	4.14	3.29	116	14.4	284	0.385	2513	4.698
GR-25-25	8-Apr-94	25	23.8	0.00	5.06	3.55	163	14.2	188	0.249	1882	3.478
GR-25-25	8-Apr-94	25	23.1	0.00	4.45	3.44	300	13.9	209	0.278	2405	4.469
GR-25-30	8-Apr-94	29	14.3	0.00	4.95	3.87	190	14.7	384	0.518	2690	5.063
GR-23-25	9-Apr-94	20	22.1	0.00	6.41	5.05	38	14.1	247	0.328	2422	4.510
GR-23-23	9-Apr-94	24	23.1	0.00	5.26	4.11	57	14.2	225	0.299	2394	4.451
GR-23-29	9-Apr-94	29	23.4	0.00	4.76	3.80	142	14.1	225	0.299	2342	4.350
GR-23-30	11-Apr-94	30	23.0	0.00	4.29	3.51	100	14.2	231	0.308	2332	4.335
GR-23-26	11-Apr-94	26	23.7	0.00	5.21	4.12	23	14.1	219	0.292	2372	4.407
GR-23-25	12-Apr-94	26	23.6	0.00	4.93	4.02	57	14.0	217	0.288	2332	4.332
GR-23-30	12-Apr-94	30	21.4	0.00	4.43	3.54	116	14.2	287	0.383	2435	4.535

Note: MBtu = Million Btu

TABLE 2. GR LONG-TERM TESTING EMISSIONS SUMMARY. (CONTINUED)

Test I. D.	Test Date	Gross Power (MW)	Gas Heat (% , totl)	Ca/S Molar Ratio	CEMS O2 (% , dry)	Plant O2 (% , wet)	COc (ppm @ 3% O2)	CO2c (% @ 3% O2)	NOxc (ppm @ 3% O2)	NOx (lb/MBtu)	SO2c (ppm @ 3% O2)	SO2 (lb/MBtu)
GR-23-25	14-Apr-94	25	23.8	0.00	4.59	3.59	61	14.1	223	0.297	2298	4.267
GR-23-30	14-Apr-94	30	23.5	0.00	4.63	3.71	66	14.2	255	0.338	2344	4.355
GR-15-30	14-Apr-94	30	15.6	0.00	3.60	2.91	80	14.5	278	0.373	2499	4.684
GR-20-30	14-Apr-94	30	20.2	0.00	3.69	3.04	113	14.3	256	0.342	2237	4.171
GR-25-25	14-Apr-94	25	24.9	0.00	4.11	3.32	135	13.9	206	0.273	2094	3.886
GR-20-25	15-Apr-94	25	19.2	0.00	3.96	3.07	106	14.4	209	0.279	2329	4.347
GR-15-25	15-Apr-94	25	14.8	0.00	3.95	3.18	42	14.5	256	0.344	2370	4.446
GR-23-25	15-Apr-94	25	24.3	0.00	4.21	3.23	152	14.1	201	0.267	2188	4.062
GR-23-30	15-Apr-94	31	23.1	0.00	4.25	3.52	62	14.2	256	0.340	2260	4.202
GR-30Mw	16-Apr-94	32	23.1	0.00	4.46	3.59	61	14.1	278	0.370	2244	4.172
GR-25Mw	16-Apr-94	25	24.3	0.00	4.62	3.80	31	13.8	236	0.313	2173	4.035
GR-15-20	16-Apr-94	20	16.2	0.00	4.83	3.75	35	14.4	284	0.379	2309	4.326
GR-20-20	16-Apr-94	19	19.7	0.00	5.10	4.00	31	14.2	259	0.345	2237	4.174
GR-23-20	17-Apr-94	20	23.3	0.00	4.72	3.65	59	13.8	233	0.309	2076	3.856
GR-23-20	18-Apr-94	21	23.3	0.00	4.41	3.28	104	13.8	209	0.277	2146	3.988
GR-23-32	18-Apr-94	32	23.8	0.00	3.87	3.31	126	13.8	249	0.332	1969	3.658
GR-23-25	18-Apr-94	25	24.5	0.00	3.97	3.04	177	13.8	170	0.225	2074	3.848
GR-24-25	19-Apr-94	26	24.7	0.00	4.04	3.12	117	13.5	166	0.221	1960	3.636
GR-23-24	20-Apr-94	25	23.4	0.00	4.52	3.59	28	14.1	233	0.309	2390	4.443
GR-23-30	21-Apr-94	30	23.6	0.00	4.41	3.64	136	14.1	266	0.353	2238	4.158
GR	17-May-94	25	22.5	0.01	4.09	3.07	258	14.3	220	0.292	1885	3.465
GR	18-May-94	25	22.7	0.00	4.60	3.63	112	14.3	230	0.307	2464	4.582
Average GR		28	22.7	0.01	4.35	3.35	178	14.2	260	0.346	2331	4.336

TABLE 3. SI LONG-TERM TESTING EMISSIONS SUMMARY.

Test I. D.	Test Date	Gross Power (MW)	Gas Heat (% , totl)	Ca/S Molar Ratio	CEMS O2 (% , dry)	Plant O2 (% , wet)	COc (ppm @ 3% O2)	CO2c (% @ 3% O2)	NOxc (ppm @ 3% O2)	NOx (lb/MBtu)	SO2c (ppm @ 3% O2)	SO2 (lb/MBtu)
SI-30	2-Nov-93	23	0.0	1.72	5.52	4.23	11	15.2	652	0.889	1858	3.547
SI-28	2-Nov-93	23	0.0	1.74	5.07	4.04	8	15.2	619	0.843	1976	3.762
SI-27	2-Nov-93	23	0.0	1.75	4.96	4.04	10	15.2	624	0.851	2057	3.923
SI-29	2-Nov-93	23	0.0	1.77	5.25	4.10	7	15.3	649	0.885	1907	3.644
SI-23	3-Nov-93	23	0.0	1.14	5.32	4.25	7	15.2	689	0.940	2171	4.133
SI-18	3-Nov-93	19	0.0	1.56	6.26	4.79	12	14.9	613	0.835	2114	4.030
SI-16	3-Nov-93	19	0.0	1.64	5.56	4.51	11	15.1	622	0.848	2173	4.139
SI-17	3-Nov-93	19	0.0	1.71	5.84	4.59	13	15.1	633	0.863	2106	4.016
SI-24	3-Nov-93	23	0.0	2.24	5.21	4.17	11	15.1	664	0.903	1622	3.108
SI-23-25	2-Jun-94	25	0.0	1.67	5.13	3.77	39	15.3	661	0.901	2112	4.034
SI-25	3-Jun-94	26	0.0	1.79	5.18	3.71	39	15.2	640	0.872	1858	3.541
SI-31	3-Jun-94	31	0.0	1.58	4.44	3.12	27	15.3	678	0.924	1841	3.428
Average SI		23	0.0	1.69	5.31	4.11	16	15.2	645	0.879	1983	3.775

Note: MBtu = Million Btu

All concentrations in ppm and percent (%) have been corrected to 3% O<sub>2</sub>. These data show a reduction in NO<sub>x</sub> of 63% from the baseline. A 59% reduction in SO<sub>2</sub> was due primarily to sorbent capture but also to fuel replacement. CO emissions were on average in the upper range of the acceptable level, 184 ppm.

GR-only operation was conducted for 229.4 hours, with average gas heat input of 23% and O<sub>2</sub> of 4.4%. The average emissions measured under this condition were:

<u>Species</u>	<u>NO<sub>x</sub></u>	<u>NO<sub>x</sub></u>	<u>SO<sub>2</sub></u>	<u>SO<sub>2</sub></u>	<u>CO<sub>2</sub></u>	<u>CO</u>
Unit	ppm	lb/10 <sup>6</sup> Btu	ppm	lb/10 <sup>6</sup> Btu	%	ppm
	260	0.346	2331	4.336	14.2	178

Under GR-only operation, NO<sub>x</sub> emissions were reduced by 61% from the baseline. The SO<sub>2</sub> level was reduced by 27% due to fuel replacement. Under GR-only operation CO emissions averaged 178 ppm.

SI-only testing was conducted on a few days during this period, for a total duration of 21.6 hours. The average Ca/S molar ratio was 1.69. Average emissions measured under this condition were:

<u>Species</u>	<u>NO<sub>x</sub></u>	<u>NO<sub>x</sub></u>	<u>SO<sub>2</sub></u>	<u>SO<sub>2</sub></u>	<u>CO<sub>2</sub></u>	<u>CO</u>
Unit	ppm	lb/10 <sup>6</sup> Btu	ppm	lb/10 <sup>6</sup> Btu	%	ppm
	645	0.879	1983	3.775	15.2	16

The SO<sub>2</sub> level reflects a reduction of 36%. NO<sub>x</sub> levels were below the baseline levels stated previously due to air staging during SI-only operation. Under this condition CO emissions were maintained at very low levels.

Emissions of hydrocarbons (HC) were not measured during long-term testing due to operational difficulties of the Beckman 402 instrument. Hydrocarbon emissions data under GR only operation were presented in the Optimization Testing Environmental Monitoring Report.

The flue gas opacity at the ESP outlet was logged by the Boiler Performance Monitoring System (BPMS) along with other operating/performance parameters. Since under sorbent injection the particulate loading into the ESP increases, there was potential for an increase in opacity. The opacity, averaged for the three test conditions, increased only marginally when sorbent was injected. The average, maximum, and minimum opacity for each condition were as follows:

Baseline Average Opacity (%)	5.8
Baseline Maximum Opacity (%)	10.4
Baseline Minimum Opacity (%)	2.0

GR Average Opacity (%)	5.1
GR Maximum Opacity (%)	9.0
GR Minimum Opacity (%)	2.1
SI Average Opacity (%)	5.9
SI Maximum Opacity (%)	7.7
SI Minimum Opacity (%)	4.1
GR-SI Average Opacity (%)	5.2
GR-SI Maximum Opacity (%)	7.5
GR-SI Minimum Opacity (%)	3.0

The ESP had sufficient capacity to collect the added particulate matter, maintaining low emissions. The Excess Opacity Reports, found in Appendix A, indicate that opacity exceeded 30% only during start-up of Units 7 or 8.

#### 4.2 PARTICULATE LOADING

On June 2, 1994 three particulate sampling runs were performed while the unit was under GR-SI operation. The sampling was according to U.S. EPA Method 5 which is used to measure total particulate loading. The results of these measurements are listed in Table 4. The average grain loading was 0.0080 gr/dscf, with a range of 0.0059 to 0.010 gr/dscf. The average hourly emissions were 8.76 lb/hr, with a range of 6.23 to 10.58 lb/hr. These correspond to an average emissions rate of 0.016 lb/ $10^6$  Btu (range 0.012 to 0.019 lb/ $10^6$  Btu) which is far below the compliance limit of 0.10 lb/ $10^6$  Btu. The average flue gas flow from the unit was 219,356 acfm, which corresponds to a stack gas velocity of 20.7 ft/s.

#### 4.3 AQUEOUS DISCHARGE

Monitoring of aqueous discharge conducted by CWLP personnel, according to NPDES permit requirements, show that limits were met. On rare occasion when a limit was exceeded, successive measurements were below the stated limit. The Discharge Monitoring Reports are found in Appendix B.

### 5.0 CONCLUSIONS

Application of GR, SI, and GR-SI to CWLP's Lakeside Unit 7 resulted in significant reductions in emissions without deleterious effects on the environment. Under GR-SI, NO<sub>x</sub> emissions were reduced on average by 63%, while under GR-only operation the reduction was 61%. SO<sub>2</sub> emissions were reduced by 59% under GR-SI and by 36% under SI-only operation. Emissions of CO were increased during GR operation, averaging 184 ppm under GR-SI and 178 ppm under GR-only, compared to 16 ppm under SI-only operation. Opacity was not affected by GR-SI; the 30% limit was exceeded during start-up of Units 7 or 8. Particulate emissions during GR-SI operation averaged 0.016 lb/ $10^6$  Btu, which is far below the 0.10 lb/ $10^6$  limit. Monitoring of

TABLE 4. STACK PARTICULATE MATTER EMISSIONS.  
(UNDER GR-SI OPERATION)

Test Run Number	1	2	3	Avg.
Test Date	6/2/94	6/2/94	6/2/94	6/2/94
Sampling Period	1045 - 1155	1311 - 1418	1446 - 1553	1045 - 1553
Particulate Concentration:				
@ Flue Conditions, grainsacf	0.0048	0.0058	0.0034	0.0047
@ Flue Conditions, grainsdscf	0.0081	0.0100	0.0059	0.0080
Emissions Rate:				
lb/hr	9.47	10.58	6.23	8.76
lb/MBtu (F = 9,780)	0.016	0.019	0.012	0.016
Stack Gas Flow Rate:				
@ Flue Conditions, acfm	231,172	212,144	214,753	219,356
@ Standard Conditions, dscfm	136,174	123,393	123,553	127,707
Stack Gas Temperature, Deg F	324	327	331	327
Stack Gas Moisture, % by Volume	10.73	11.58	12.06	11.46
% CO <sub>2</sub> by Volume, dry basis	12.00	12.60	12.20	12.27
% O <sub>2</sub> by Volume, dry basis	5.80	5.28	6.00	5.69
% Excess Air	36.48	32.20	38.47	35.72

Note: MBtu = Million Btu

aqueous discharge streams indicates that limits were generally met, but when occasionally exceeded, the following measurement was in the acceptable range.

## **APPENDIX A**

### **EXCESS OPACITY REPORTS**

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: October 1993

Date	Start-End	Component	Cause	Corrective Action Taken
------	-----------	-----------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Boiler Hours  
Unit #7 - 319  
Unit #8 - 0

Month/Year: October 1993

Date	Start	Opacity (%)	Cause	Corrective Action Taken
10-4	00:00	60.0	Startup #7	
	:06	58.0	"	
	:12	50.0	"	
	:18	41.0	"	
	:24	45.0	"	
	:30	45.0	"	
	:36	32.0	"	
	01:36	80.0	"	
	:42	72.0	"	
	:48	61.0	"	
	:54	69.0	"	
	02:00	56.0	"	
	:06	75.0	"	
	:12	59.0	"	
	:18	69.0	"	
	:24	65.0	"	
	:30	64.0	"	
	:36	66.0	"	
	:42	47.0	"	
	:48	61.0	"	
	:54	56.0	"	
	03:00	39.0	"	
	04:00	31.0	"	
	:06	58.0	"	
	:18	42.0	"	
	:24	47.0	"	
	:30	31.0	"	
	:36	55.0	"	
	:42	50.0	"	
	:54	43.0	"	
	05:00	48.0	"	
	:12	45.0	"	
	:18	46.0	"	
	:30	47.0	"	
10-10	21:06	59.0	Startup #7	
	:12	46.0	"	
	:18	36.0	"	
10-11	00:30	72.0	Startup #7	
	:36	61.0	"	
	:42	51.0	"	
	:48	64.0	"	
	:54	57.0	"	
	01:00	47.0	"	
	:06	45.0	"	
	:12	44.0	"	
	:18	45.0	"	
	:24	45.0	"	
	:30	43.0	"	
	:36	40.0	"	
	:42	48.0	"	
	:54	73.0	"	

Excess Opacity Report  
 Lakeside - October 1993  
 Page -3-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
10-13	18:54	41.0	Startup #7	
	19:00	71.0	"	
	:06	66.0	"	
	:12	43.0	"	
	:18	48.0	"	
	:24	63.0	"	
	:30	34.0	"	
	:42	53.0	"	
	23:54	53.0	"	
10-14	00:00	48.0	"	
	:06	39.0	"	
	:12	32.0	"	
	04:18	35.0	"	
	:30	46.0	"	
	:36	38.0	"	
	:42	45.0	"	
	:48	36.0	"	
10-15	01:12	35.0	"	
	:42	37.0	"	
	:54	66.0	"	
	03:30	68.0	"	
	:36	50.0	"	
	04:54	31.0	"	
	05:00	33.0	"	
	07:48	37.0	"	
	:54	36.0	"	
	08:06	38.0	"	
	:18	45.0	"	
	:24	40.0	"	
	:30	42.0	"	
	:36	39.0	"	
	:42	61.0	"	
	:48	67.0	"	
10-25	00:06	39.0	Startup #7	
	:12	31.0	"	
	02:06	42.0	"	
	:12	58.0	"	
	:18	50.0	"	
	:24	47.0	"	
	:30	49.0	"	
	:36	48.0	"	
	:42	66.0	"	
	:48	43.0	"	
	:54	44.0	"	
	03:00	45.0	"	
	:06	48.0	"	
	:12	31.0	"	
	:18	32.0	"	
	:24	44.0	"	

Excess Opacity Report  
Lakeside - October 1993  
Page -4-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
10-25	04:12	35.0	Startup #7	
	05:06	32.0	"	
	:12	36.0	"	
	09:24	58.0	"	
	:30	51.0	"	
	:36	75.0	"	
	:42	70.0	"	
	:48	65.0	"	
	:54	52.0	"	
	10:00	32.0	"	
	:12	35.0	"	
	:54	39.0	"	
	11:00	58.0	"	
	:06	50.0	"	
	:12	59.0	"	
	:18	60.0	"	
	:24	45.0	"	
	:30	56.0	"	
	:36	57.0	"	
	:42	39.0	"	
	:48	52.0	"	
	:54	61.0	"	
	12:00	50.0	"	
	:06	35.0	"	
	:12	57.0	"	
	:18	43.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: November 1993

Date	Start-End	Component	Cause	Corrective Action Taken
------	-----------	-----------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: November 1993

Boiler Hours  
Unit #7 - 397  
Unit #8 - 92

Date	Start	Opacity (%)	Cause	Corrective Action Taken
11-2	00:30	51.0	#7 Startup	
	:36	73.0	"	
	:42	73.0	"	
	:48	55.0	"	
	01:00	38.0	"	
	:06	59.0	"	
	:18	58.0	"	
	:24	55.0	"	
	:36	63.0	"	
	:42	35.0	"	
	02:18	61.0	"	
	:24	49.0	"	
	:42	42.0	"	
	04:54	63.0	"	
	05:00	32.0	"	
	:06	40.0	"	
	:12	49.0	"	
	:30	35.0	"	
	:42	54.0	"	
	:48	52.0	"	
	:54	38.0	"	
	06:18	31.0	"	
	:24	42.0	"	
	:30	82.0	"	
	:36	58.0	"	
11-5	14:18	76.0	Test-Fired #8	
	:24	51.0	"	
11-7	09:54	61.0	Startup #8	
	10:00	52.0	"	
	:06	51.0	"	
	:12	61.0	"	
	:18	61.0	"	
	:24	61.0	"	
	:30	59.0	"	
	:42	58.0	"	
	:48	59.0	"	
	:54	59.0	"	
	11:00	59.0	"	
	:06	59.0	"	
	:12	59.0	"	
	:18	60.0	"	
	:24	59.0	"	
	:30	58.0	"	
	:36	57.0	"	
	:42	55.0	"	
	:48	52.0	"	
	:54	50.0	"	
	12:00	56.0	"	
	:06	72.0	"	
	:12	47.0	"	

Excess Opacity Report  
 Lakeside - November 1993  
 Page -2-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
11-7	12:18	67.0	Startup #8	
	:24	81.0	"	
	:30	70.0	"	
	:336	69.0	"	
	:42	71.0	"	
	:48	70.0	"	
	:54	78.0	"	
	13:00	64.0	"	
	:06	65.0	"	
	:12	68.0	"	
	:18	57.0	"	
	:24	72.0	"	
	:30	78.0	"	
	:36	70.0	"	
	:42	52.0	"	
	:48	40.0	"	
	14:00	34.0	"	
	15:00	53.0	"	
	:06	45.0	"	
	:36	82.0	"	
	:42	72.0	"	
	:48	39.0	"	
	:54	35.0	"	
	16:00	46.0	"	
	:06	38.0	"	
	:18	78.0	"	
	:24	53.0	"	
	:30	37.0	"	
	:36	59.0	"	
11-9	21:36	55.0	Startup #7	
	:42	46.0	"	
	:48	35.0	"	
	23:12	35.0	"	
	:18	35.0	"	
	:36	39.0	"	
	:42	56.0	"	
	:48	43.0	"	
	:54	35.0	"	
11-10	00:00	63.0	Startup #7	
	:06	37.0	"	
	:12	31.0	"	
	:18	45.0	"	
	:24	51.0	"	
	:30	33.0	"	
	:36	68.0	"	
	:42	50.0	"	
	:48	33.0	"	
	:54	50.0	"	
	01:00	66.0	"	
	:05	70.0	"	
	:12	55.0	"	
	:18	39.0	"	

Excess Opacity Report  
 Lakeside - November 1993  
 Page -3-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
11-10	02:00	60.0	Startup #7	
	:06	66.0	"	
	:12	62.0	"	
	:18	46.0	"	
	:24	31.0	"	
	03:54	44.0	"	
	04:00	46.0	"	
	:54	42.0	"	
	05:12	46.0	"	
	:24	35.0	"	
	:36	51.0	"	
	:42	48.0	"	
	:48	31.0	"	
	:54	47.0	"	
	06:12	38.0	"	
11-14	23:06	75.0	Startup #7	
	:12	64.0	"	
	:18	48.0	"	
	:24	40.0	"	
	:30	35.0	"	
	:36	32.0	"	
11-15	02:06	55.0	Startup #7	
	:12	63.0	"	
	:18	46.0	"	
	:48	35.0	"	
	:54	38.0	"	
	03:54	33.0	"	
	05:36	42.0	"	
11-22	00:48	36.0	Startup #7	
	:54	32.0	"	
	01:00	32.0	"	
	:18	31.0	"	
	:24	33.0	"	
	:30	34.0	"	
	:36	33.0	"	
	:42	65.0	"	
	:48	75.0	"	
	:54	74.0	"	
	02:00	62.0	"	
	:06	63.0	"	
	:12	68.0	"	
	:18	60.0	"	
	:24	53.0	"	
	:30	54.0	"	
	:36	47.0	"	
	:42	46.0	"	
	:54	48.0	"	

Excess Opacity Report  
 Lakeside - November 1993  
 Page -4-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
11-23	01:18	56.0	Startup #7	
	:24	64.0	"	
	:30	65.0	"	
	:42	54.0	"	
	:48	49.0	"	
	:54	33.0	"	
	02:18	58.0	"	
	:54	33.0	"	
	03:30	37.0	"	
	:36	46.0	"	
	04:24	47.0	"	
	:30	45.0	"	
	:36	41.0	"	
	:54	33.0	"	
	05:06	54.0	"	
	:12	54.0	"	
	:18	52.0	"	
	:30	49.0	"	
11-24	19:42	32.0	"	
	:48	41.0	"	
	:54	37.0	"	
	20:00	34.0	"	
	:06	44.0	"	
	:12	36.0	"	
11-29	00:54	75.0	Startup #8	
	01:00	48.0	"	
	:06	38.0	"	
	:12	80.0	"	
	:18	80.0	"	
	:24	81.0	"	
	:30	81.0	"	
	:36	81.0	"	
	:42	81.0	"	
	:48	81.0	"	
	:54	81.0	"	
	02:00	81.0	"	
	:06	81.0	"	
	:12	82.0	"	
	:18	82.0	"	
	:24	82.0	"	
	:30	79.0	"	
	:36	77.0	"	
	:42	82.0	"	
	:48	73.0	"	
	:54	65.0	"	
	03:00	74.0	"	
	:06	68.0	"	

Excess Opacity Report  
Lakeside - November 1993  
Page -5-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
11-29	03:12	44.0	Startup #8	
	:18	45.0	"	
	:30	61.0	"	
	:36	57.0	"	
	:42	38.0	"	
	:48	44.0	"	
	:54	50.0	"	
	04:00	37.0	"	
	:06	42.0	"	
	:12	54.0	"	
	:30	57.0	"	
	:36	40.0	"	
	:54	40.0	"	
	05:00	63.0	"	
	:30	39.0	"	
	:36	39.0	"	
	:54	31.0	"	
	06:00	71.0	"	
	:12	43.0	"	
	:18	31.0	"	
	:24	38.0	"	
	:36	35.0	"	
	:42	39.0	"	
	:48	34.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: December 1993

Date	Start-End	Component	Cause	Corrective Action Taken
------	-----------	-----------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: December 1993

Boiler Hours

Unit #7 - 0

Unit #8 - 0

Date	Start	Opacity (%)	Cause	Corrective Action Taken
------	-------	-------------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: January 1994

Date	Start-End	Component	Cause	Corrective Action Taken
------	-----------	-----------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: January 1994

Boiler Hours  
Unit #7 -  
Unit #8 -

Date	Start	Opacity (%)	Cause	Corrective Action Taken
1/17	04:06	74.0	Startup #8	
	:12	77.0	"	
	:18	78.0	"	
	:24	77.0	"	
	:30	77.0	"	
	:36	78.0	"	
	:42	79.0	"	
	:48	80.0	"	
	:54	81.0	"	
	05:00	82.0	"	
	:06	79.0	"	
	:12	82.0	"	
	:18	81.0	"	
	:24	79.0	"	
	:30	76.0	Startup #7 & #8	
	:36	68.0	"	
	:42	66.0	"	
	:48	65.0	"	
	:54	62.0	"	
	06:00	61.0	"	
	:06	70.0	"	
	:12	71.0	"	
	:18	62.0	"	
	:24	63.0	"	
	:30	67.0	"	
	:36	58.0	"	
	:42	43.0	"	
	:48	39.0	"	
	:54	35.0	"	
	07:00	33.0	"	
	:06	32.0	"	
	:12	31.0	"	
	:18	34.0	"	
	:36	42.0	"	
1/31	02:42	59.0	Startup #7	
	:48	62.0	"	
	:54	62.0	"	
	03:00	62.0	"	
	:06	62.0	"	
	:12	62.0	"	
	:18	63.0	"	
	:24	64.0	"	
	:30	65.0	"	
	:36	65.0	"	
	:42	66.0	"	
	:48	79.0	"	
	:54	65.0	"	

Excess Opacity Report  
Lakeside - January 1994  
Page -2-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
1/31	04:00	63.0	Startup #7	
	:06	60.0	"	
	:12	58.0	"	
	:18	58.0	"	
	:24	59.0	"	
	:30	51.0	"	
	:36	38.0	"	
	05:48	58.0	"	
	:54	50.0	"	
	06:00	54.0	"	
	:06	44.0	"	
	09:00	31.0	"	
	:06	50.0	"	
	:12	41.0	"	
	:36	35.0	"	
	10:54	36.0	"	
	11:00	32.0	"	
	16:06	35.0	Startup #8	
	:12	31.0	"	
	:18	32.0	"	
	:24	37.0	"	
	:30	53.0	"	
	:36	59.0	"	
	:42	59.0	"	
	:48	41.0	"	
	19:00	34.0	"	
	:06	63.0	"	
	:42	46.0	"	
	20:12	32.0	"	
	:30	60.0	"	
	:36	72.0	"	
	:42	79.0	"	
	:48	75.0	"	
	:54	69.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: February 1994

Date	Start-End	Component	Cause	Corrective Action Taken
------	-----------	-----------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: February 1994

Boiler Hours  
Unit #7 -  
Unit #8 -

Date	Start	Opacity (%)	Cause	Corrective Action Taken
2/10	23:48	37.0	Startup #7 & #8	
	:54	56.0	"	
2/11	00:00	47.0	Startup #7 & #8	
	:06	51.0	"	
	:12	51.0	"	
	:18	50.0	"	
	:24	48.0	"	
	:30	47.0	"	
	:36	46.0	"	
	:42	45.0	"	
	:48	44.0	"	
	:54	43.0	"	
	01:00	41.0	"	
	:06	39.0	"	
	:12	36.0	"	
	:18	33.0	"	
	:24	31.0	"	
	02:06	47.0	"	
	:12	73.0	"	
	:18	65.0	"	
	:24	60.0	"	
	:30	55.0	"	
	:36	45.0	"	
	:42	52.0	"	
	:48	63.0	"	
	:54	68.0	"	
	03:00	61.0	"	
	:06	62.0	"	
	:12	33.0	"	
	:18	42.0	"	
	:24	45.0	"	
	04:00	35.0	"	
	:12	35.0	"	
	:18	51.0	"	
	:24	41.0	"	
	:30	31.0	"	
	05:12	51.0	"	
	:30	36.0	"	
	:42	41.0	"	
2/15	14:18	58.0	Startup #7	
	:24	38.0	"	
	17:18	43.0	"	
	:24	41.0	"	
	:36	41.0	"	
	18:06	35.0	"	
	:12	38.0	"	
	:24	33.0	"	
	:30	41.0	"	

Excess Opacity Report  
 Lakeside - February 1994  
 Page -2-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
2/23	00:06	43.0	Startup #7 & #8	
	:18	51.0	"	
	:24	42.0	"	
	:30	43.0	"	
	:42	46.0	"	
	:48	49.0	"	
	:54	51.0	"	
	01:00	51.0	"	
	:06	51.0	"	
	:12	51.0	"	
	:18	50.0	"	
	:24	48.0	"	
	:30	46.0	"	
	:36	43.0	"	
	:42	40.0	"	
	:48	38.0	"	
	:54	37.0	"	
	02:00	34.0	"	
	:06	32.0	"	
	03:00	44.0	"	
	:06	57.0	"	
	:12	32.0	"	
	:24	32.0	"	
	:30	70.0	"	
	:36	46.0	"	
	:42	69.0	"	
	:48	38.0	"	
	:54	53.0	"	
	04:06	34.0	"	
	:12	50.0	"	
	:18	35.0	"	
	:24	52.0	"	
	:30	32.0	"	
	:42	48.0	"	
	05:00	55.0	"	
	:42	52.0	"	
	:48	52.0	"	
	:54	45.0	"	
	06:00	45.0	"	
	:06	49.0	"	
	:12	59.0	"	
	:18	57.0	"	
	:24	56.0	"	
	:30	54.0	"	
	:36	42.0	"	
	:48	57.0	"	
	:54	54.0	"	
	07:00	32.0	"	
	:06	40.0	"	
	:12	64.0	"	
	:18	51.0	"	
	:24	37.0	"	
	:30	45.0	"	
	:36	60.0	"	
	:42	43.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: March 1994

Date	Start-End	Component	Cause	Corrective Action Taken
3/8	21:00	IO Malfunction	Lightning hitting	Replaced IO Malf.
3/11	14:30	Board	Lakeside stack	Board

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: March 1994

Boiler Hours  
Unit #7 -  
Unit #8 -

Date	Start	Opacity (%)	Cause	Corrective Action Taken
3-25	10:48	32.0	#7&#8 Startup	
	:54	45.0	"	
	11:00	65.0	"	
	:06	68.0	"	
	:12	68.0	"	
	:18	65.0	"	
	:24	61.0	"	
	:30	57.0	"	
	:36	54.0	"	
	:42	51.0	"	
	:48	48.0	"	
	:54	46.0	"	
	12:00	43.0	"	
	:05	42.0	"	
	:12	41.0	"	
	:18	41.0	"	
	:24	41.0	"	
	:30	42.0	"	
	:36	40.0	"	
	:42	43.0	"	
	:48	32.0	"	
	13:30	40.0	"	
	:36	36.0	"	
	:42	31.0	"	
	:48	46.0	"	
	:54	34.0	"	
	14:00	33.0	"	
	15:24	33.0	"	
	16:18	35.0	"	
	:30	40.0	"	
	17:00	36.0	"	
	:05	39.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: April 1994

Date	Start-End	Component	Cause	Corrective Action Taken
4/11	08:18-	IO Malfunction	Lightning hitting	Replaced IO
4/19	12:00	Board	Lakeside Stack	Malfunction Board

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: April 1994

Boiler Hours  
Unit #7 - 548  
Unit #8 - 556

Date	Start	Opacity (%)	Cause	Corrective Action Taken
4-28	01:18	50.0	Startup	
	:24	38.0	"	
	:42	50.0	"	
	:48	36.0	"	
	02:00	30.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: May 1994

Date	Start-End	Component	Cause	Corrective Action Taken
------	-----------	-----------	-------	-------------------------

N O N E

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Opacity Limit: 30%

Month/Year: May 1994

Boiler Hours  
Unit #7 - 284  
Unit #8 - 86

Date	Start	Opacity (%)	Cause	Corrective Action Taken
5-10	09:18	34.0	Startup #7	
	:24	87.0	"	
	:30	87.0	"	
	:36	86.0	"	
	:42	85.0	"	
	:48	84.0	"	
	:54	84.0	"	
	10:00	84.0	"	
	:06	84.0	"	
	:12	84.0	"	
	:18	84.0	"	
	:24	84.0	"	
	:30	82.0	"	
	:36	80.0	"	
	:42	78.0	"	
	:48	78.0	"	
	11:00	78.0	"	
	:06	80.0	"	
	:12	80.0	"	
	:18	80.0	"	
	:24	80.0	"	
	:30	84.0	"	
	:36	74.0	"	
	:42	75.0	"	
	:48	60.0	"	
	:54	76.0	"	
	12:00	80.0	"	
	:06	70.0	"	
	:12	73.0	"	
	:18	54.0	"	
	:24	70.0	"	
	:30	70.0	"	
	:36	66.0	"	
	:42	54.0	"	
	:48	64.0	"	
	:54	64.0	"	
	13:00	58.0	"	
	:06	64.0	"	
	:12	60.0	"	
	:18	42.0	"	
	:24	65.0	"	
	:30	48.0	"	
	:36	56.0	"	
	:42	35.0	"	
	:48	54.0	"	
	:54	59.0	"	
	14:06	46.0	"	
	:12	34.0	"	
	:24	47.0	"	
	:36	43.0	"	

Excess Opacity Report  
 Lakeside - May 1994  
 Page -2-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
5-10	17:36	46.0	Startup #7	
	:42	55.0	"	
	:48	64.0	"	
	:54	53.0	"	
	18:00	51.0	"	
	:06	51.0	"	
	:12	60.0	"	
	:18	53.0	"	
	:42	42.0	"	
	:48	45.0	"	
	:54	55.0	"	
	19:00	41.0	"	
	:06	39.0	"	
	:12	40.0	"	
	:18	49.0	"	
	:24	49.0	"	
	:30	41.0	"	
	:36	35.0	"	
	:48	64.0	"	
	:54	40.0	"	
	20:00	33.0	"	
	:06	41.0	"	
	:12	68.0	"	
	:18	72.0	"	
	:24	70.0	"	
	:30	76.0	"	
5-30	16:36	62.0	Startup #7 & #8	
	:42	60.0	"	
	:48	49.0	"	
	:54	40.0	"	
	17:00	34.0	"	
	:06	71.0	"	
	:12	56.0	"	
	:18	48.0	"	
	:24	40.0	"	
	:30	32.0	"	
	:42	30.0	"	
	:48	63.0	"	
	:54	72.0	"	
	18:00	71.0	"	
	:06	70.0	"	
	:12	69.0	"	
	:18	69.0	"	
	:24	69.0	"	
	:30	70.0	"	
	:36	71.0	"	
	:42	72.0	"	
	:48	73.0	"	
	:54	74.0	"	
	19:00	76.0	"	
	:06	76.0	"	
	:12	81.0	"	
	:18	88.0	"	
	:24	75.0	"	
	:30	72.0	"	
	:36	72.0	"	
	:42	72.0	"	
	:48	52.0	"	
	:54	82.0	"	

Excess Opacity Report  
akeside - May 1994  
age -3-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
5-30	20:00	89.0	"	
	:06	76.0	"	
	:12	38.0	"	
	:18	59.0	"	
	:42	81.0	"	
	:48	75.0	"	
	:54	72.0	"	
	21:00	71.0	"	
	:06	65.0	"	
	:12	65.0	"	
	:18	70.0	"	
	:24	70.0	"	
	:30	59.0	"	
	:36	71.0	"	
	:42	50.0	"	
	:48	60.0	"	
	:54	52.0	"	
	22:00	38.0	"	
	:18	62.0	"	
	:24	50.0	"	
	:30	52.0	"	
	:36	50.0	"	
	:42	44.0	"	
	:48	63.0	"	
	23:00	44.0	"	
	:06	35.0	"	
	:12	35.0	"	
	:18	50.0	"	
	:24	50.0	"	
	:30	47.0	"	
	:36	49.0	"	
	:42	62.0	"	
	:48	36.0	"	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

UNIT OPACITY CEM  
DOWNTIME REPORT

Unit: Lakeside

Month/Year: June 1994

Date	Start-End	Component	Cause	Corrective Action Taken
6/18	13:30-14:30	Recorder	Paper Jam	

CITY WATER, LIGHT & POWER  
3100 Stevenson Drive

EXCESS OPACITY REPORT

Unit: Lakeside

Capacity Limit: 30%

Month/Year: June 1994

Boiler Hours  
Unit #7 - 360  
Unit #8 - 404

date	Start	Opacity (%)	Cause	Corrective Action Taken
6-2	14:00	33.0	Stack test probe in path	
	16:06	41.0	"	
	:12	32.0	"	
6-4	01:24	65.0	Shutdown #7	
	:30	52.0	"	
	02:18	40.0	"	
	:24	40.0	"	
-7	02:18	61.0	Startup #8	
	:48	41.0	"	
	:54	34.0	"	
	03:00	48.0	"	
	:06	57.0	"	
	:12	58.0	"	
	:18	60.0	"	
	:24	62.0	"	
	:30	64.0	"	
	:36	68.0	"	
	:42	70.0	"	
	:48	72.0	"	
	:54	73.0	"	
	04:00	73.0	"	
	:06	65.0	"	
	:12	69.0	"	
	:18	77.0	"	
	:24	43.0	"	
	:30	62.0	"	
	:36	66.0	"	
	:42	59.0	"	
	:48	35.0	"	
	:54	60.0	"	
	05:00	65.0	"	
	:06	64.0	"	
	:12	38.0	"	
	:24	48.0	"	
	:30	67.0	"	
	:36	42.0	"	
	:48	36.0	"	
	:54	66.0	"	
	05:06	53.0	"	
	:12	57.0	"	
	:18	62.0	"	
	:24	53.0	"	
	:30	64.0	"	
	:36	42.0	"	
	07:06	49.0	"	
	:12	43.0	"	
	:18	34.0	"	
	:36	43.0	"	
	:42	52.0	"	
	:48	42.0	"	

Excess Opacity Report  
 Lakeside - June 1994  
 Page -2-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
5-7	03:00	61.0	Startup #3	
	:18	39.0	"	
	:24	72.0	"	
	:30	72.0	"	
	:36	72.0	"	
5-8	03:18	50.0	Shutdown #8	
	:24	33.0	"	
	09:18	53.0	"	
	:24	82.0	"	
	:30	77.0	"	
	:36	72.0	"	
	:42	39.0	"	
5-25	07:30	44.0	Startup #7&8	
	:36	51.0	"	
	:42	58.0	"	
	:48	58.0	"	
	:54	52.0	"	
	08:00	60.0	"	
	:06	47.0	"	
	:12	58.0	"	
	:18	54.0	"	
	:24	48.0	"	
	:30	50.0	"	
	:36	42.0	"	
	:42	42.0	"	
	:48	33.0	"	
	:54	47.0	"	
	09:00	40.0	"	
	15:00	47.0	"	
	:06	48.0	"	
	:12	39.0	"	
	:18	51.0	"	
	:24	38.0	"	
	:30	37.0	"	
	:36	31.0	"	
	:42	45.0	"	
	:54	48.0	"	
	16:00	59.0	"	
	:06	48.0	"	
	:12	44.0	"	
	:30	62.0	"	
	:36	42.0	"	
	:42	53.0	"	
	:48	31.0	"	
	:54	56.0	"	
	17:06	43.0	"	
	21:42	36.0	"	
	:48	43.0	"	
	22:00	57.0	"	
	:12	48.0	"	
	:24	38.0	"	
5-26	04:36	55.0	Shutdown #7	
	:42	42.0	"	
	:48	42.0	"	
	:54	36.0	"	

Excess Opacity Report  
 Lakeside - June 1994  
 Page -3-

Date	Start	Opacity (%)	Cause	Corrective Action Taken
J-26	05:00	50.0		
	:06	48.0	"	
	:12	56.0	"	
	:18	53.0	"	
	:24	45.0	"	
	:30	36.0	"	
	:36	60.0	"	
	:42	40.0	"	
	:48	38.0	"	
	:54	43.0	"	
	06:00	47.0	"	
	12:54	47.0	Startup #8	
	13:00	51.0	"	
	:06	50.0	"	
	:12	50.0	"	
	:18	39.0	"	
	:24	48.0	"	
	:30	38.0	"	
	:36	46.0	"	
	19:42	41.0	"	
	:48	37.0	"	
	:54	51.0	"	
	20:06	34.0	"	
	:12	43.0	"	
	:18	44.0	"	
6-27	02:30	78.0	Startup #8	
	:36	63.0	"	
	:42	47.0	"	
	:45	37.0	"	
	05:42	49.0	"	
	:48	53.0	"	
	:54	53.0	"	
	06:00	47.0	"	
	:06	33.0	"	
	:12	64.0	"	
	:18	31.0	"	
	07:36	35.0	"	
	:42	35.0	"	
	08:36	51.0	"	
	:42	56.0	"	
	:48	52.0	"	
	09:06	51.0	"	
	10:48	100.0	"	
	:54	100.0	"	
	11:00	55.0	"	
	:18	59.0	"	

## **APPENDIX B**

### **WATER DISCHARGE MONITORING REPORTS**



## DISCHARGE MONITORING REPORT

**CITY WATER, LIGHT & POWER  
SEVENTH & MONROE  
SPRINGFIELD, IL 62757  
(217) 736-4980**

14. 10.	IL 0024767	14. 10. 1993	004	14. 10. 1993	LONGWAVE
	PRIMARIA KUUMMI				
10. 10.	111	11. 10. 1993			

176-721	126-759	(108-218)
913	12	9
110		
110		
913	12	9

Parameter	Quantity (kg)			Concentration (ppm)			Concentration (ppm)			Concentration (ppm)			
	AVAILABILITY	MAXIMUM	UNITS	PICF MANHATTAN	AVAILABILITY	MAXIMUM	PICF MANHATTAN	AVAILABILITY	MAXIMUM	PICF MANHATTAN	AVAILABILITY	MAXIMUM	
Flow	5.912	5.912	MGD										
pH	7.000	7.000											
Total Suspended Solids	5.912	5.912	MGD										
Oil and Grease	0.000	0.000											
Boron	0.000	0.000											
DRAFT OF THIS REPORT EXCLUDING DATA													
PEASCO, Lynn A.				Central Manager, Public Utilities				DATE				DRAFT	
NOVEMBER 11, 1974				9/3/74				1/2/74				SUBMISSION OF REPORT	
NOVEMBER 11, 1974				1/2/74				1/4/74				SIGNATURE OF AUTHORIZED AGENT	

PAGE 5 OF 12

This Agency is authorized to furnish this information under Illinois Law.  
Statutes, 1970, Chapter 111 1/2, Section 1042. Disclosure of this information  
is required. Failure to do so may result in a civil penalty up to \$10,000.00 per  
day of violation or a fine up to \$25,000.00 per day of violations and imprison-  
ment.

DISCHARGE MONITORING REPORT

**City Water, Light & Power**  
Seventh & Monroe  
Springfield, IL 62757  
(217) 785-4990

۱۳

11	11	11
IL_0024767		
"HUMAN HUMAN"		
AUDITION PERIOD		
1100M	YATAN	MO
1105	1132320	1124250
004	113	112
1111	SIC	
1111	LAWYER	11ONGURD
1111	1126-231	1126-230
1111	1146-311	1146-310
1111	119	110
1111	114	111

There was no discharge December 28, 1993 through January 3, 1994.

COMM 15

This Agency is authorized to require this information under Illinois law and Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$100,000 per day of violation or a fine up to \$25,000.00 per day of violation and imprisonment.

DISCLIGNE MONITORING REPORT

**CITY WATER, LIGHT & POWER**  
Seventh & Monroe  
Springfield, IL 62757  
(217) 726-4080

卷之三

This Agency is authorized to require this information under Illinois Statute, 1979, Chapter 111-1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per day of violation or a fine up to \$25,000.00 per day of violations and damages.

卷之三

卷之三

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMENTS  
DISCHARGE MONITORING REPORT

**City Water, Light & Power**  
Seventh & Monroe  
Springfield, IL 62757  
(217) 786-4080

THE JOURNAL OF CLIMATE

100

**Statutes, 1975, Chapter 111-1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$ 10,000.00 per day of violation or a fine up to \$25,000.00 per day of violation and imprisonment.**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMUNICATI  
DISCHARGE MONITORING REPORT

PERMITTING FEE  
ADDRESS  
CITY  
PHONE

City Water, Light & Power	Springfield, IL 62757
Seventh & Monroe	(217) 786-4080

Address  
Post

14. LAT.	11. 0024767
15. LONG.	111.51
16. DIST.	004
17. SIC	
18. NAME	PEMBAYA NUMBER II

REPORTING PERIOD	FROM	TO
	YEAR	MONTH
	DAY	DAY

PAGE 5 OF 12

This Agency is authorized to require this information under Illinois Revised Statutes, 1979, Chapter 111 1/2, Section 10-02, Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per day.

## NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMENTS DISCHARGE MONITORING REPORT

**NAME** City Water, Light & Power  
55 Seventh & Monroe  
Springfield, IL 62757  
(217) 786-4080

COMMENTS

Refer to NON letter dated May 16, 1994 for TSS exceedances.

126-211		127-211		128-211	
YRAN	MU	YRAN	MU	YRAN	MU
9	4	0	4	9	1
YRAN	MU	YRAN	MU	YRAN	MU
10					

any person to whom it is given to obtain such information under Illinois Revised Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per day of violation or from \$1,000.00 to \$5,000.00 for each new offense.

PAST 5 00 17

64



NAME  
John Doe, Jr., Esq.

DISCHARGE Monitoring Report (MVR)

(17-9)

PERMIT NUMBER

11001234567

PERMIT NUMBER

11-62707

FROM

01/01/2011

TO

01/01/2012

YEAR

MO

DAY

01

Q4

YEAR

MO

DAY

01



MAIL FOLT DIS NON MGT HIS  
DISCHARGE MONITORING REPORT

PUBLIC FACILITY NAME  
ABOVE 55  
Seventh & Monroe  
Springfield, IL 62757  
(217) 786-4080

COMMUNIS

No discharge during this period.

11.	0024767	PLANT NUMBER
008	SAC	LATITUDE
105		LONGITUDE

REPORTING PERIOD	FROM	TO	YARD	YARD	YARD	YARD
120-210	022-223	124-225	176-211	178-209	180-211	181-209

PARAMETER	SAMPLE DATE		QUANTITY (kg/d)		CONCENTRATION (ppm)		FREQUENCY OF ANALYSIS	SAMPLE TYPE
	MINIMUM	MAXIMUM	AVG	STD	MINIMUM	MAXIMUM		
Flow	0	0	0	0	0	0	1/1	EST
pH	7.0	7.0	7.0	0.0	15	30	1/1	EST
Total Suspended Solids	0	0	0	0	15	20	1/1	GRAB
Oil and Grease	0	0	0	0	2.0	4.0	1/1	GRAB
Total Iron	0	0	0	0	1	1	1/1	GRAB
Dissolved Iron	0	0	0	0	1	1	1/1	GRAB
TOTAL MONITORING INFORMATION								
Francesco, Lynn A.	General Manager	Public Utilities	9	3	2	14	1	1
MAIL	0001	MMI	001	YIAH	MMI	DAY		

This Agency is authorized to require this information under Illinois Uniform Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$25,000.00 per day of violation or a fine up to \$10,000.00 per month up to one year. This form has been approved by the

PAGE 4 OF 12

SIGNATURE OR PRINTED NAME  
DRAFTED ON AUTHORIZED DATE  
DRAFTED ON AUTHORIZED DATE

## NATIONAL POLLUTANT DISCHARGE LUMINATION SYSTEM COMMUNITIES

## DISCHARGE MONITORING REPORT

1

DISCHARGE NUMBER: City Water, Light & Power  
 ADDRESS: Seventh & Monroe  
 Springfield, IL 62757  
 PHONE: (217) 786-4080

COMMUNITIES

No discharge during this period.

DISCHARGE NUMBER	DISCHARGE DATE	SIC	DISCHARGE CONDITION
W. 0024767	008		
PERMIT NUMBER	DIS	DIS	
REPORTING PERIOD	FROM	TO	YESTERDAY

PARAMETER	TEST DATE	QUANTITY (GRAMS)		CERTIFICATION		TEST DATE	TESTER
		MINIMUM	AVAILABILITY	MAXIMUM	AVAILABILITY		
Flow							
Flow							
pH							
Total Suspended Solids							
Oil and Grease							
Total Iron							
Dissolved Iron							
NAME OF INDIVIDUAL EXECUTIVE OFFICER		NAME OF THE OFFICE		DATE			
Frasco, Lynn A.		General Manager	Public Utilities	9/4	1/4		
MAIL		IN MAIL	BY AIR	9/4	1/4		

This Agency is authorized to require this information under Illinois Statute, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per day of violation or a criminal fine up to \$10,000.00 per day.

PAGE 9 OF 12

*D. Frasco*

Signature of Executive Officer  
or Person Authorized to Act

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMUNITIES  
DISCHARGE MONITORING REPORT

REPORTER'S NAME: City Water, Light & Power  
ADDRESS: Seventh & Monroe  
Springfield, IL 62757  
(217) 786-4080  
REPORT DATE: 11-16-1981  
REPORT NUMBER: II, 0024767  
SIC: 008  
ACT: 000  
PERMIT NUMBER: 120-211 122-229 124-269  
PERIOD: 10/01/81 TO 10/31/81  
REPORT PERIOD: 10/01/81 TO 10/31/81  
REPORT TIME: 10:00 AM  
DISCHARGE: 10  
Q: 1  
A: 0  
W: 1  
M: 1  
Y: 1  
D: 1

No discharge during this period.

PARAMETER	JULY 1981		AVERAGE		CUMULATIVE		DISCHARGE		TESTS	
	MINIMUM	AVAILABILITY	MAXIMUM	UNITS	MINIMUM	AVAILABILITY	MAXIMUM	UNITS	TESTS	TESTS
Flow				MGD						
PH									1/1	1/1
Total Suspended Solids										
Oil and Grease										
Total Iron										
Dissolved Iron										
NAME OF PERSONNEL EXAMINING DISCHARGE										
Frasco, Lynn A.		General Manager	Public Utilities	0	0	0	1	1	1/1	1/1
11-16-1981		YEAR	MO	DAY						
This Agency is authorized to require this information under Illinois Revised Statute, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per day of violation or a fine up to \$25,000.00 per day of violation and imprisonment.										
Signature of Person Authorizing and Date W.C. 242-00779										

## DISCHARGE MONITORING REPORT

COMMENTS

No discharge during this period.

1.	II, 0024767	III MMII MMII
2.	008	015
3.	SAC	LATHUW LONTJUNI
4.		
5.		

REPORTING PERIOD		FROM	TO	YTD	MTD	DAY
9	4	0	2	0	1	
9	4	0	1	0	1	
9	4	0	0	1	0	1
9	4	0	0	0	0	1

PARAMETER	SAMPLE		QUANTITY		CONCENTRATION		TEST		SAMPLING TYPE
	MINIMUM	MAXIMUM	AVAILABILITY	UNITS	MINIMUM	MAXIMUM	AVAILABILITY	UNITS	
Flow				4 cu. yds.	146.53	146.53		146 cu. ft.	EST
Reported					100	100		100	EST
Plume Condition					1X	1X		1X	GRAB
Reported									COMP
pH					6.0	9.0		1/7	GRAB
Total Suspended Solids								mp/l	1/7
Oil and Grease								mp/l	1/7
Total Iron								mp/l	1/7
Dissolved Iron								mg/l	1/7
General Manager Public Utilities	9/4/1981	9/3/1981	10/15/1981	TEST					
Francesco, Lynn A.	TEST	TEST	TEST	TEST					

THIS AGENCY IS AUTHORIZED TO REQUIRE THIS INFORMATION UNDER ILLINOIS REVISED STATUTE, 1979, CHAPTER 1A-1/2, SECTION 1042, DISCLOSURE OF \$10,000.00 DUE IF REQUIRED; FAILURE TO DO SO MAY RESULT IN A CIVIL PENALTY UP TO \$10,000.00 DUE DAILY OF VIOLATION OR A FINE UP TO \$25,000.00 PER DAY OF VIOLATION AND IMPRISONMENT UP TO ONE YEAR. THIS FORM IS BEING MAILED PURSUANT TO THE REQUIREMENTS OF THE FEDERAL FAIR CREDIT REPORTING ACT.

PAGEL

Page 9 of 12

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMENTS  
**DISCHARGE MONITORING REPORT**

**CITY WATER, LIGHT & POWER**  
Seventh & Monroe  
Springfield, IL 62757  
(217) 786-4080

RECEIVED  
LIBRARY OF THE  
UNIVERSITY OF TORONTO LIBRARIES  
1961

Arts Press

PARAMETER	MINIMUM	MIDDLE
Flow	100000	1000000

CORPORATION	ALPHONSO	PHILIP
PL		

Total Suspended Solids	Acetone	Methyl Carnitine
100	100	100

Oil and Grease

ITEM	TEST	RESULT
Total Iron	PURITY CONDITION	
	DISCOLORATION	
	ODOR	

DISSOLVED IRON

DEPARTMENT OF EDUCATION  
EDUCATIONAL COUNCIL

Frasco, Lynn A.	NAME OF PRINCIPAL EXECUTIVE OFFICER	GENERAL MANAGER
CONDITION	GENERAL	GENERAL

卷之三

COMM

No discharge during this period

PAPERS 12

One Twenty-Eight (128) to furnish this information under Illinois Revised Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMENTS  
DISCHARGE MONITORING REPORT

1

MATERIAL NAME City Water, Light & Power  
NCESS Seventh & Monroe  
Springfield, IL 62757  
(217) 786-4080

COMMENTS

Total and Dissolved Iron were not analyzed due  
to lab error.

REPORTING PERIOD		FROM		TO		LATITUDE		LONGITUDE	
REPORT NUMBER	PERMIT NUMBER	008	008	10	10	41 56 01 N	87 46 29 W	41 56 01 N	87 46 29 W
112 321	112 321	112 321	112 321	112 321	112 321	112 321	112 321	112 321	112 321

PARAMETER	MEASUREMENT		MEASUREMENT		CONCENTRATION		CONCENTRATION		QUALITY OF ANALYSIS	SAMPLE TYPE
	MINIMUM	AVAILABILITY	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS		
Flow	0.00	0.008	0.24	NCD	167.430	166.530	154.61	mg/l	1/30	EST
pH									1/7	EST
Total suspended solids					6.0		8.05	mg/l	1/30	GRAB
Total Oil and Grease							9.0	mg/l	1/7	GRAB
Total Iron							72	mg/l	1/30	COMP
Dissolved Iron					15	30	15	mg/l	1/30	COMP
Total Dissolved Solids					15	20	15	mg/l	1/7	GRAB
Total Chlorides					2.0	4.0	2.0	mg/l	1/7	COMP
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										
Total Chlorine										
Total Dissolved Solids										
Total Chloride										

NATIONAL POLLUTANT DISCHARGE LIMITATION SYSTEM COMMUNIC

DISCHARGE MONITORING REPORT

PERMITTING NAME: City Water, Light & Power  
 ADDRESS: Seventh & Monroe  
 Springfield, IL 62757  
 PHONE: (217) 786-6080  
 L  
 14 141  
 11. 0024767  
 PERMIT NUMBER:  
 55

No discharge during this period.

REPORTING PERIOD FROM	04/05/2011	TO	10/05/2011	QUANTITY	144.631
YR/MO/DAY	AMT	MO	DAY	AVAILABILITY	144.631

PARAMETER	2 CONSECUTIVE MONTHS		4 QUARTERLY PERIODS		12 MONTHS		FREQUENCY OF ANALYSIS	SAMPLE TYPE
	MINIMUM	MAXIMUM	MINIMUM	MAXIMUM	MINIMUM	MAXIMUM		
Flow								
Flow								
Flow								
Flow								
Total Suspended Solids								
Total Suspended Solids								
Oil and Grease								
Oil and Grease								
Total Iron								
Dissolved Iron								
NAME OF PRINCIPAL EXECUTIVE OFFICER	DATE		DATE		DATE		DATE	
Frasco, Lynn A.	General Manager	Public Utilities	4	6	1	3	1	1
NAME	YEAR	MO	DAY	YEAR	MO	DAY	YEAR	MO

This Agency is authorized to require this information under Illinois Law.  
 Statute, 1979, Chapter 111, 11042, Disclosure of this information is required.  
 Failure to do so may result in a civil penalty up to \$10,000.00 per  
 day of violation or a fine up to \$26,000.00 per day of violation and increments.

JULY 17, 2011  
 PAGE 9 OF 17

WR 242 NOV 17/11

S. J. Frasco  
 SIGNATURE OF PRINCIPAL EXECUTIVE  
 OFFICER AUTHORIZED TO SIGN

JULY 17, 2011  
 PAGE 9 OF 17

Business Name/Address (include  
other names/locations if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (17-19)

NAME: SPRINGFIELD CWP  
ADDRESS: 211 AND MIDDLE STREET  
LOCATION: SPRINGFIELD

LINE: ENVIRONMENTAL AFFAIRS

LINE: GENERAL MANAGER, PUBLIC UTIL.

LINE: SPRINGFIELD

LINE: 62207

LINE: 62257

DISCHARGE NUMBER  
**100P4767**

MONITORING PERIOD  
**(18-19) (24-25)**

FROM  
**94/06/01**

TO  
**94/06/30**

YEAR  
**94**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**95**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**96**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**97**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**98**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**99**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**00**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**01**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**02**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**03**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**04**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**05**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**06**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**07**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**08**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**09**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**10**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**11**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**12**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**13**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**14**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**15**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**16**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**17**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**18**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**19**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**20**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**21**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**22**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**23**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**24**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**25**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**26**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**27**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**28**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**29**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**30**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**31**

MONTH  
**JUN**

DAY  
**15**

YEAR  
**01**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**02**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**03**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**04**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**05**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**06**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**07**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**08**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**09**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**10**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**11**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**12**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**13**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**14**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**15**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**16**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**17**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**18**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**19**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**20**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**21**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**22**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**23**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**24**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**25**

MONTH  
**JULY**

DAY  
**15**

YEAR  
**26**