

Mark B. Bezilla
Vice President - Nuclear

419-321-7676
Fax: 419-321-7582

Docket Number 50-346

License Number NPF-3

Serial Number 3089

November 29, 2004

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: Correction of Information Provided Regarding Response to Generic Letter 95-07

Ladies and Gentlemen:

During an Extent of Condition review of prior NRC submittals for completeness and accuracy, a minor inaccuracy was identified with information provided for the Davis-Besse Nuclear Power Station (DBNPS) in letter Serial Number 2360, "Response to NRC Generic Letter 95-07, 'Pressure Locking and Thermal Binding of Safety-Related Power Operated Gate Valves,'" dated February 13, 1996. A correction to this letter is specified below (double underline indicates new inserted text; strikethrough indicates deleted previous text).

A portion of the evaluation for thermal binding of valve RC 200, Pressurizer Vent Stop Valve, on page 21 of the Attachment is modified as follows:

Mode 1 and 2 This valve is normally closed, and is not required to be operated in Modes
Mode 3 1, 2, or 3. Thus, but is routinely opened during operations. ~~When open, the~~
~~valve is heated to near RCS temperature. Once closed, significant~~
~~cooldown occurs. The valve has not thermally bound even when exposed~~
~~to conditions which would be similar to expected worst case service~~
~~conditions. Therefore, thermal binding is not of concern in these modes.~~

The FirstEnergy Nuclear Operating Company (FENOC) does not believe that the minor inaccuracy being corrected by this letter constitutes information that is inaccurate or incomplete in any material respect. The correction specified above addresses statements of fact that may have been incomplete or inaccurate at the time of the original submittal. No attempt has been made to update the contents of letter Serial 2360 with currently available information regarding pressure locking and thermal binding of safety-related power operated gate valves.

Should you have any questions or require additional information, please contact Mr. Robert W. Schrauder, Director – Performance Improvement, at (419) 321-7181.


A056

Docket Number 50-346
License Number NPF-3
Serial Number 3089
Page 2 of 2

The statements contained in this submittal are true and correct to the best of my knowledge and belief. I am authorized by the FirstEnergy Nuclear Operating Company to make this submittal. I declare under penalty of perjury that the foregoing is true and correct.

Executed on November 29, 2004.

Very truly yours,

A handwritten signature in black ink, appearing to read "Mark B. Bezilla". The signature is written in a cursive, flowing style.

Mark B. Bezilla

GMW

Attachment 1: Commitment List

cc: Regional Administrator, NRC Region III
DB-1 Senior NRC/NRR Project Manager
DB-1 Senior NRC Resident Inspector
Utility Radiological Safety Board

Docket Number 50-346
License Number NPF-3
Serial Number 3089
Attachment 1, Page 1 of 1

COMMITMENT LIST

The following list identifies those actions committed to by the Davis-Besse Nuclear Power Station in this document. Any other actions discussed in the submittal represent intended or planned actions by Davis-Besse. They are described only as information and are not regulatory commitments. Please notify the Director – Performance Improvement (419) 321-7181 at Davis-Besse of any questions regarding this document or associated regulatory commitments.

COMMITMENTS

DUE DATE

None

N/A