

13 SEER Standard for Central Air Conditioners and Heat Pumps

Table 2. Impacts of 13 SEER central air conditioner and heat pump standard compared with 12 SEER standard, 2006-2025

<i>Projection</i>	<i>2015</i>	<i>2025</i>	<i>Cumulative</i>	
			<i>2006-2015</i>	<i>2006-2025</i>
<i>Electricity consumption savings (billion kilowatthours)</i>	<i>11.1</i>	<i>16.6</i>	<i>59.6</i>	<i>211.7</i>
<i>Energy bill savings (billion 2004 dollars)</i>	<i>0.8</i>	<i>0.7</i>	<i>5.7</i>	<i>12.6</i>
<i>Equipment cost increase (billion 2004 dollars)</i>	<i>0.5</i>	<i>0.2</i>	<i>5.8</i>	<i>8.9</i>
<i>Net present value (billion 2004 dollars)</i>	<i>—</i>	<i>—</i>	<i>-0.1</i>	<i>3.6</i>
<i>Increase in air conditioner stock efficiency (percent)</i>	<i>5.6</i>	<i>6.8</i>	<i>—</i>	<i>—</i>
<i>Carbon dioxide emissions reduction (million metric tons)</i>	<i>1.1</i>	<i>-3.6</i>	<i>7.8</i>	<i>1.0</i>